



STATE OF MAINE  
Department of Environmental Protection

JOHN ELIAS BALDACCI  
GOVERNOR

David P. Littell  
COMMISSIONER

July 27, 2009

Mr. Patrick Cloutier  
South Portland Water Pollution Control Facility  
P. O. Box 9422  
South Portland, Maine 04116-9422

RE: Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME0100633  
Maine Waste Discharge License (WDL) Application #W001370-5M-I-R  
**Final Permit/License, City of South Portland-Amended Page**

Dear Mr. Cloutier:

Enclosed please find a copy of amended Page 7 of 28 of your **final** Maine MEPDES Permit/WDL which was approved by the Department of Environmental Protection. The table on page 7 of 28 was amended on 7/27/09 to include the discharge limitations and monitoring requirements for Cyanide Amenable to Chlorination.

If you have any questions regarding this matter, please feel free to contact me at (207) 287-7658 or at [phyllis.a.rand@maine.gov](mailto:phyllis.a.rand@maine.gov).

Sincerely,

A handwritten signature in cursive script that reads 'Phyllis Arnold Rand'.

Phyllis Arnold Rand  
Division of Water Quality Management  
Bureau of Land and Water Quality

Enclosure

cc: Stuart Rose-DEP/SMRO  
Sandy Mojica-USEPA

Jim Jones, Ron Letarte-City of S. Portland  
Lori Mitchell-DMU Doug Koopman-USEPA

AUGUSTA  
17 STATE HOUSE STATION  
AUGUSTA, MAINE 04333-0017  
(207) 624-6550 FAX: (207) 624-6024  
RAY BLDG., HOSPITAL ST.

BANGOR  
106 HOGAN ROAD  
BANGOR, MAINE 04401  
(207) 941-4570 FAX: (207) 941-4584

PORTLAND  
312 CANCO ROAD  
PORTLAND, MAINE 04103  
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE  
1235 CENTRAL DRIVE, SKYWAY PARK  
PRESQUE ISLE, MAINE 04769-2094  
(207) 764-6477 FAX: (207) 764-1507

web site: [www.maine.gov/dep](http://www.maine.gov/dep)

**SPECIAL CONDITIONS**

**A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) – OUTFALL #001A**

**SECONDARY TREATED WASTE WATER - OUTFALL #001A<sup>(1)</sup>**

Effluent Characteristic	Discharge Limitations						Minimum Monitoring Requirements	
	<u>Monthly Average</u> as specified	<u>Weekly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Monthly Average</u> as specified	<u>Weekly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Measurement Frequency</u> as specified	<u>Sample Type</u> as specified
Ammonia as N <sub>[00610]</sub> (June 1 – October 31)	659 lbs/Day [26]	---	---	13,000 ug/L [28]	---	---	2/Year [02/YR]	24 Hr. Composite [24]
Ammonia as N <sub>[00610]</sub> (November 1 – May 31)	931 lbs/Day [26]	---	---	18,000 ug/L [28]	---	---	2/Year [02/YR]	24 Hr. Composite [24]
Total Zinc <sub>[01092]</sub>	---	---	35 lbs/Day [26]		---	677 ug/L [28]	1/Year [01/YR]	24 Hr. Composite [24]
Bis (2-ethylhexyl) phthalate [39100]	2.1 lbs/Day [26]	---	---	41 ug/L [28]	---	---	1/Year [01/YR]	Grab [GR]
Cyanide Amenable to Chlorination [00722]			0.37 lbs/day [26]			7.2 ug/L [28]	1/Quarter [01/90]	Grab [GR]

*Amended table on 7/27/09 to include Cyanide Amenable to Chlorination discharge limitations and monitoring requirements.*