



STATE OF MAINE
Department of Environmental Protection

JOHN ELIAS BALDACCI
GOVERNOR

David P. Littell
COMMISSIONER

August 2, 2010

Mr. Mark Holt
Town of Jay
99 Main Street
Jay, ME. 04239

RE: Maine Waste Discharge License #W002689-6B-G-R
Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME0101061
Final Permit/License

Dear Mr. Holt:

Enclosed please find a copy of your **final** Maine MEPDES/WDL which was approved by the Department of Environmental Protection. Please read the permit and its attached conditions carefully. You must follow the conditions in the order to satisfy the requirements of law. Any discharge not receiving adequate treatment is in violation of State Law and is subject to enforcement action.

Any interested person aggrieved by a Department determination made pursuant to applicable regulations, may appeal the decision following the procedures described in the attached DEP FACT SHEET entitled "*Appealing a Commissioner's Licensing Decision.*"

If you have any questions regarding this matter, please feel free to call me at 287-7693.

Sincerely,

A handwritten signature in cursive script, appearing to read "G. Wood".

Gregg Wood
Division of Water Quality Management
Bureau of Land and Water Quality

Enc. Beth DeHaas, DEP/CMRO
Sandy Mojica, USEPA



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
17 STATE HOUSE STATION
AUGUSTA, ME 04333

DEPARTMENT ORDER

IN THE MATTER OF

TOWN OF JAY)	MAINE POLLUTANT DISCHARGE
NORTH JAY WWTF)	ELIMINATION SYSTEM PERMIT
JAY, FRANKLIN COUNTY, MAINE)	AND
PUBLICLY OWNED TREATMENT WORKS)	WASTE DISCHARGE LICENSE
W002689-6B-F-R)	
ME0101061)	
APPROVAL)	RENEWAL

Pursuant to the provisions of the Federal Water Pollution Control Act, Title 33 USC, Section 1251, et. seq. and Maine Law 38 M.R.S.A., Section 414-A et seq., and applicable regulations, the Department of Environmental Protection (Department hereinafter) has considered the application of the TOWN OF JAY (Town/permittee hereinafter) with its supportive data, agency review comments, and other related materials on file and FINDS THE FOLLOWING FACTS:

APPLICATION SUMMARY

The Town has submitted a timely and complete application to the Department for renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0101061 / Maine Waste Discharge License (WDL) #W002689-5L-E-R, (permit hereinafter) issued by the Department on August 2, 2005, and is due to expire on August 2, 2010. It is noted the 8/2/05 permit was modified on 12/29/08 to eliminate water quality based limits for toxic pollutants that were no longer of concern and incorporated new water quality based limitations for toxic pollutants that were of concern based on an updated statistical evaluation. The 8/2/05 permit and the 12/29/08 permit modification approved the discharge of up to a monthly average flow of 0.060 million gallons per day (MGD) of secondary treated waste waters to Sevenmile Stream, Class B, in Jay (North Jay), Maine.

PERMIT SUMMARY

This permitting action is similar to the 8/2/05 permit in that it is carrying forward all the terms and conditions with the following exception that this permit is eliminating the monthly average water quality based mass and concentration limitations for bis(2-ethylhexhyl)phthalate.

CONCLUSIONS

BASED on the findings in the attached Fact Sheet dated June 8, 2010, and subject to the Conditions listed below, the Department makes the following conclusions:

1. The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
2. The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
3. The provisions of the State's antidegradation policy, 38 MRSA Section 464(4)(F), will be met, in that:
 - (a) Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
 - (b) Where high quality waters of the State constitute an outstanding national resource, that water quality will be maintained and protected;
 - (c) The standards of classification of the receiving water body are met or, where the standards of classification of the receiving water body are not met, the discharge will not cause or contribute to the failure of the water body to meet the standards of classification;
 - (d) Where the actual quality of any classified receiving water body exceeds the minimum standards of the next highest classification, that higher water quality will be maintained and protected; and
 - (e) Where a discharge will result in lowering the existing quality of any water body, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
4. The discharge will be subject to effluent limitations that require application of best practicable treatment.

ACTION

THEREFORE, the Department APPROVES the above noted application of the TOWN OF JAY, to discharge up to a monthly average flow of 0.060 MGD of secondary treated waste waters to Sevenmile Stream, Class B, SUBJECT TO THE ATTACHED CONDITIONS, and all applicable standards and regulations:

1. *“Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable To All Permits,”* revised July 1, 2002, copy attached.
2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
3. This permit becomes effective upon the date of signature and expires at midnight five (5) years thereafter.

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application June 7, 2010.

Date of application acceptance June 7, 2010.

This Order prepared by GREGG WOOD, BUREAU OF LAND AND WATER QUALITY

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. Beginning the effective date of the permit, the permittee is authorized to discharge secondary treated sanitary waste waters from **OUTFALL #001** to the Sevenmile Stream. Such waste water discharges shall be limited and monitored by the permittee as specified below:

Effluent Characteristic	Discharge Limitations						Minimum Monitoring Requirements	
	<u>Monthly Average</u>	<u>Weekly Average</u>	<u>Daily Maximum</u>	<u>Monthly Average</u>	<u>Weekly Average</u>	<u>Daily Maximum</u>	<u>Measurement Frequency</u>	<u>Sample Type</u>
Flow [50050]	0.060 MGD [03]	---	Report MGD[03]	---	---	---	Continuous [99/99]	Recorder [RC]
<u>BOD⁽¹⁾</u> <i>June 1 – September 30</i> <i>October 1 – May 31</i> [00310]	5 lbs/day 15 lbs/day [26]	7.5 lbs/day 23 lbs/day [26]	8.5 lbs/day 25 lbs/day [26]	10 mg/L 30 mg/L [19]	15 mg/L 45 mg/L [19]	17 mg/L 50 mg/L [19]	2/Month [02/30] 2/Month [02/30]	Composite[24] Composite [24]
BOD ₅ % Removal ⁽¹⁾ [81010]	---	---	---	85% [23]	---	---	1/Month [01/30]	Calculate [CA]
TSS ⁽¹⁾ [00530]	15 lbs/day [26]	23 lbs/day [26]	25 lbs/day[26]	30 mg/L[19]	45 mg/L [19]	50 mg/L[19]	2/Month [02/30]	Composite [24]
TSS % Removal ⁽¹⁾ [81011]	---	---	---	85% [23]	---	---	1/Month [01/30]	Calculate [CA]
Settleable Solids [00545]	---	---	---	---	---	0.3 ml/L [25]	2/Month [02/30]	Grab [GR]
<u>E. Coli Bacteria⁽²⁾</u> [31633] <i>May 15 – September 30</i>	---	---	---	64/100 ml ⁽³⁾ [13]	---	427/100 ml[13]	2/Month [02/30]	Grab [GR]
Total Residual Chlorine ⁽⁴⁾ [50060]	---	---	---	0.1 mg/L [19]	---	0.3 mg/L [19]	1/Day [01/01]	Grab [GR]
pH (Std. Unit)[00400]	---	---	---	---	---	6.0 – 9.0 [12]	1/Day [01/01]	Grab [GR]
Lead (Total) [01051]	0.0032 #/day [26]	---	---	13 ug/L [28]	---	---	2/Year [02/YR]	Composite [24]

The italicized numeric values bracketed in the table above and the tables that follow are code numbers that Department personnel utilized to code the monthly Discharge Monitoring Reports (DMR's).

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) – OUTFALL #001

SURVEILLANCE LEVEL TESTING – Beginning upon issuance of the permit and lasting through 12 months prior to permit expiration:

Effluent Characteristic	Discharge Limitations						Monitoring Requirements	
	Monthly Average	Weekly Average	Daily Maximum	Monthly Average	Weekly Average	Daily Maximum	Measurement Frequency	Sample Type
Whole Effluent Toxicity (WET) ⁽⁵⁾								
<u>A-NOEL</u>								
<i>Ceriodaphnia dubia</i> [TDA3B]	---	---	---	---	---	Report % [23]	1/2 Years [01/2Y]	Composite [24]
<i>Salvelinus fontinalis</i> [TDA6F]	---	---	---	---	---	Report % [23]	1/2 Years [01/2Y]	Composite [24]
<u>C-NOEL</u>								
<i>Ceriodaphnia dubia</i> [TBP3B]	---	---	---	---	---	Report % [23]	1/2 Years [01/2Y]	Composite [24]
<i>Salvelinus fontinalis</i> [TBQ6F]	---	---	---	---	---	Report % [23]	1/2 Years [01/2Y]	Composite [24]
Analytical Chemistry ^(6,7) [51477]	---	---	---	---	---	Report ug/L [28]	1/2 Years [01/2Y]	Composite/ Grab [24/GR]

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

Sampling – Composite and grab sampling of the treatment plant effluent for compliance with this permit shall be conducted after the last treatment unit such that samples are representative of the effluent being discharged to the receiving waters. Any change in sampling location must be approved by the Department in writing.

Sampling and analysis must be conducted in accordance with; a) methods approved in 40 Code of Federal Regulations (CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, or c) as otherwise specified by the Department. Samples that are sent out for analysis shall be analyzed by a laboratory certified by the State of Maine's Department of Human Services. Samples that are sent to another POTW licensed pursuant to *Waste discharge licenses*, 38 M.R.S.A. § 413 or laboratory facilities that analyze compliance samples in-house are subject to the provisions and restrictions of *Maine Comprehensive and Limited Environmental Laboratory Certification Rules*, 10-144 CMR 263 (last amended February 13, 2000).

All analytical test results shall be reported to the Department including results which are detected below the respective reporting limits (RLs) specified by the Department or as specified by other approved test methods. See **Attachment A** of this permit for a list of the Department's RLs. If a non-detect analytical test result is below the respective RL, the concentration result shall be reported as <Y where Y is the detection limit achieved by the laboratory for each respective parameter. Reporting a value of <Y that is greater than an established RL is not acceptable and will be rejected by the Department. For mass, if the analytical result is reported as <Y or if a detectable result is less than a RL, report a <X lbs/day, where X is the parameter specific limitation established in the permit.

1. **Percent removal**- The treatment facility shall maintain a minimum of 85 percent removal of both BOD₅ and TSS for waste waters receiving a secondary level of treatment. The percent removal shall be based on a monthly average calculation using influent and effluent concentrations. The percent removal shall be waived when the monthly average influent concentration is less than 200 mg/L. For instances when this occurs, the facility shall report "NODI-9" for this parameter on the monthly Discharge Monitoring Report (DMR).
2. ***E. coli* bacteria** - Limits are seasonal and apply between May 15th and September 30th of each calendar year. The Department reserves the right to require disinfection on a year-round basis to protect the health and welfare of the public.
3. ***E. coli* bacteria** – The monthly average limitation is a geometric mean limitation and shall be calculated and reported as such.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

4. **Total residual chlorine (TRC)** – – Monitoring for TRC is only required when elemental chlorine or chlorine-based compounds are in use for effluent disinfection. For instances when a facility has not disinfected with chlorine-based compounds for an entire reporting period, the facility shall report “NODI-9” for this parameter on the monthly DMR. The permittee shall utilize approved test methods that are capable of bracketing the TRC limitations in this permit.
5. **Whole effluent toxicity (WET) testing** - Definitive WET testing is a multi-concentration testing event which provides a point estimate of toxicity in terms of No Observed Effect Level, commonly referred to as NOEL or NOEC. Tests shall be conducted such that a minimum of five dilutions bracketing the critical acute and chronic dilutions of 17.5:1 and 20.4:1 respectively (5.7% and 4.9% respectively - mathematical inverse of the dilution factor). A-NOEL is defined as the acute no observed effect level with survival as the end point. C-NOEL is defined as the chronic no observed effect level with survival, reproduction and growth as the end points. See **Attachment B** of this permit for the Department’s WET report form.
 - a. **Surveillance level testing** - Beginning upon issuance and lasting through 12 months prior to the expiration date of the permit, the permittee shall initiate surveillance level WET tests at a frequency of once every two years (1/2 Years). Tests shall be conducted in a different calendar quarter of each year such that a WET testing is conducted in two of the four calendar quarters during the first four years of the permit. Testing shall be conducted on the water flea (*Ceriodaphnia dubia*) and the brook trout (*Salvelinus fontinalis*).
 - b. **Screening level testing** - Beginning 12 months prior to permit expiration and lasting through permit expiration and every five years thereafter, the permittee shall conduct screening level WET testing at a minimum frequency of twice per year (2/Year) on the water flea and brook trout.

Test results must be submitted to the Department not later than the next Discharge Monitoring Report (DMR) required by the permit, provided, however, the permittee may review the toxicity reports for up to 10 business days after receiving the test results from the laboratory conducting the testing before submitting them. The permittee shall evaluate test results being submitted and identify to the Department possible exceedences of the critical acute and chronic water quality thresholds of 5.7% and 4.9%, respectively.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

Toxicity tests must be conducted by an experienced laboratory approved by the Department. The laboratory must follow procedures as described in the following USEPA methods manuals.

- a. Short Term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Water to Freshwater Organisms, Fourth Edition, October 2002, EPA-821-R-02-013.
- b. Methods for Measuring the Acute Toxicity of Effluent and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, October 2002, EPA-821-R-02-012.

The permittee is also required to analyze the effluent for the nine (9) parameters specified in the WET chemistry section, and the twelve (12) parameters specified in the analytical chemistry section of the form in **Attachment A** of this permit each time a WET test is performed.

6. **Analytical Chemistry** – Refers to a suite of chemical tests that include ammonia nitrogen (as N), total aluminum, total arsenic, total cadmium, total chromium, total copper, cyanide amenable to chlorination, total lead, total nickel, total silver, total zinc and total residual chlorine.
 - a. **Surveillance level testing** - Beginning upon issuance and lasting through 12 months prior to the expiration date of the permit, the permittee shall initiate surveillance level analytical testing at a frequency of once every two years (1/2 Years).
 - b. **Screening level testing** - Beginning 12 months prior to permit expiration and lasting through permit expiration and every five years thereafter, the permittee shall conduct screening level analytical testing at a minimum frequency of twice per year (2/Year).

Analytical chemistry and priority pollutant testing shall be conducted on samples collected at the same time as those collected for whole effluent toxicity tests, when applicable, and shall be conducted using methods that permit detection of a pollutant at existing levels in the effluent or that achieve the most current minimum reporting levels of detection as specified by the Department. See **Attachment A** of this permit for a list of the Department's most current reporting limits (RLs).

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

Analytical chemistry and priority pollutant test results must be submitted to the Department not later than the next Discharge Monitoring Report (DMR) required by the permit, provided, however, that the permittee may review the laboratory reports for up to 10 business days after receiving the test results from the laboratory conducting the testing before submitting them. The permittee shall evaluate test results being submitted and identify to the Department, possible exceedences of the acute, chronic or human health AWQC as established in Chapter 584. For the purposes of DMR reporting, enter a "1" for yes, testing done this monitoring period or "NODI-9" monitoring not required this period.

7. **Priority Pollutant Testing** – Priority pollutant testing refers to analysis for levels of priority pollutants listed in Department rule 06-096 CMR Chapter 525 Section 4.VI. Screening level testing shall be conducted once per year (1/Year) beginning 12 months prior to permit expiration and every five years thereafter. Surveillance level priority pollutant testing is not required pursuant to Department rule 06-096 CMR Chapter 530 Section 2.D.

B. NARRATIVE EFFLUENT LIMITATIONS

1. The effluent shall not contain a visible oil sheen, foam or floating solids at any time that would impair the uses designated by the classification of the receiving waters.
2. The effluent shall not contain materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the uses designated by the classification of the receiving waters.
3. The discharge shall not cause visible discoloration or turbidity in the receiving waters which would impair the uses designated by the classification of the receiving waters.
4. Notwithstanding specific conditions of this license the effluent must not lower the quality of any classified body of water below such classification, or lower the existing quality of any body of water if the existing quality is higher than the classification.

SPECIAL CONDITIONS

C. TREATMENT PLANT OPERATOR

The person who has the management responsibility over the treatment facility must hold a **Grade III** certificate (or higher) or must be a Maine Registered Professional Engineer pursuant to *Sewerage Treatment Operators*, Title 32 M.R.S.A., Sections 4171-4182 and *Regulations for Wastewater Operator Certification*, 06-096 CMR 531 (effective May 8, 2006). All proposed contracts for facility operation by any person must be approved by the Department before the permittee may engage the services of the contract operator.

D. LIMITATIONS FOR INDUSTRIAL USERS

Pollutants introduced into the waste water collection and treatment system by a non-domestic source (user) shall not pass through or interfere with the operation of the treatment system.

E. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with: 1) the permittee's General Application for Waste Discharge Permit, accepted for processing on June 7, 2010; 2) the terms and conditions of this permit; and 3) only from Outfall #001. Discharges of waste water from any other point source are not authorized under this permit, and shall be reported in accordance with Standard Condition B(5)(*Bypass*) of this permit.

F. NOTIFICATION REQUIREMENT

In accordance with Standard Condition D, the permittee shall notify the Department of the following.

1. Any introduction of pollutants into the waste water collection and treatment system from an indirect discharger in a primary industrial category discharging process waste water; and
2. Any substantial change in the volume or character of pollutants being introduced into the waste water collection and treatment system by a source introducing pollutants into the system at the time of permit issuance. For the purposes of this section, notice regarding substantial change shall include information on:
 - (a) the quality and quantity of waste water introduced to the waste water collection and treatment system; and
 - (b) any anticipated impact caused by the change in the quantity or quality of the waste water to be discharged from the treatment system.

SPECIAL CONDITIONS

G. WET WEATHER FLOW MANAGEMENT PLAN

The treatment facility staff shall maintain a current written Wet Weather Flow Management Plan to direct the staff on how to operate the facility effectively during periods of high flow. The Department acknowledges that the existing collection system may deliver flows in excess of the monthly average design capacity of the treatment plant during periods of high infiltration and rainfall.

The plan shall conform to Department guidelines for such plans and shall include operating procedures for a range of intensities, address solids handling procedures (including septic waste and other high strength wastes if applicable) and provide written operating and maintenance procedures during the events.

The permittee shall review their plan annually **and record any necessary changes to keep the plan up to date.**

H. OPERATION & MAINTENANCE (O&M) PLAN

This facility shall have a current written comprehensive Operation & Maintenance (O&M) Plan. The plan shall provide a systematic approach by which the permittee shall at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit.

By December 31 of each year, or within 90 days of any process changes or minor equipment upgrades, the permittee shall evaluate and modify the O&M Plan including site plan(s) and schematic(s) for the waste water treatment facility to ensure that it is up-to-date. The O&M Plan shall be kept on-site at all times and made available to Department and EPA personnel upon request.

Within 90 days of completion of new and or substantial upgrades of the waste water treatment facility, the permittee shall submit the updated O&M Plan to their Department inspector for review and comment.

I. DISPOSAL OF TRANSPORTED WASTES INTO THE TREATMENT FACILITY

The permittee is not authorized to receive or introduce transported wastes into its waste water treatment facility.

SPECIAL CONDITIONS

J. MERCURY

All mercury sampling (4/Year) required by this permit or required to determine compliance with interim limitations established pursuant to Department rule Chapter 519, shall be conducted in accordance with EPA's "clean sampling techniques" found in EPA Method 1669, Sampling Ambient Water For Trace Metals At EPA Water Quality Criteria Levels. All mercury analysis shall be conducted in accordance with EPA Method 1631, Determination of Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Fluorescence Spectrometry. See **Attachment C**, *Effluent Mercury Test Report*, of this permit for the Department's form for reporting mercury test results.

K. CHAPTER 530(2)(D)(4) CERTIFICATION

By December 31 of each calendar year, the permittee shall provide the Department with a certification describing any of the following that have occurred since the effective date of this permit [*PCS Code 95799*]: See **Attachment E** of the Fact Sheet of this permit for an acceptable certification form to satisfy this special condition.

1. Increases in the number, types and flows of industrial, commercial or domestic discharges to the facility that in the judgment of the Department may cause the receiving water to become toxic.
2. Changes in the condition or operations of the facility that may increase the toxicity of the discharge.
3. Changes in storm water collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge.
4. Increases in the type or volume of hauled wastes accepted by the facility.

The Department reserves the right to reinstate annual (surveillance level) testing or other toxicity testing if new information becomes available that indicates the discharge may cause or have a reasonable potential to cause exceedences of ambient water quality criteria/thresholds.

L. REOPENING OF PERMIT FOR MODIFICATIONS

Upon evaluation of chemical specific test results, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at anytime and with notice to the permittee, modify this permit to: (1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded; (2) require additional monitoring if results on file are inconclusive; or (3) change monitoring requirements based on new information.

SPECIAL CONDITIONS

M. MONITORING AND REPORTING

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report (DMR) forms provided by the Department and shall be postmarked by the thirteenth (13th) day of the month or hand-delivered to a Department Regional Office such that the DMRs are received by the Department by the fifteenth (15th) day of the month following the completed reporting period. A signed copy of the DMR and all other reports required herein shall be submitted, unless otherwise specified, to the Department's facility inspector at:

Department of Environmental Protection
Central Maine Regional Office
Bureau of Land and Water Quality
Division of Water Quality Management
17 State House Station
Augusta, Maine 04333

Alternatively, if you are submitting an electronic DMR (eDMR), the completed eDMR must be electronically submitted to the Department by a facility authorized DMR Signatory not later than close of business on the 15th day of the month following the completed reporting period. Hard Copy documentation submitted in support of the eDMR must be postmarked on or before the thirteenth (13th) day of the month or hand-delivered to the Department's Regional Office such that it is received by the Department on or before the fifteenth (15th) day of the month following the completed reporting period. Electronic documentation in support of the eDMR must be submitted not later than close of business on the 15th day of the month following the completed reporting period.

N. SEVERABILITY

The invalidity or unenforceability of any provision, or part thereof, of this permit shall not affect the remainder of the provision or any other provisions. This permit shall be construed and enforced in all respects as if such invalid or unenforceable provision or part thereof had been omitted

ATTACHMENT A

Maine Department of Environmental Protection
WET and Chemical Specific Data Report Form
This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

Facility Name _____ MEPDES # _____ Pipe # _____ Facility Representative Signature _____
To the best of my knowledge this information is true, accurate and complete.

Licensed Flow (MGD)
Acute dilution factor
Chronic dilution factor
Human health dilution factor
Criteria type: M(marine) or F(fresh)

Flow for Day (MGD)⁽¹⁾ _____ Flow Avg. for Month (MGD)⁽²⁾ _____
Date Sample Collected _____ Date Sample Analyzed _____

Laboratory Address _____ Telephone _____
Lab Contact _____ Lab ID # _____

FRESH WATER VERSION

ERROR WARNING ! Essential facility information is missing. Please check required entries in bold above.

Please see the footnotes on the last page.

WHOLE EFFLUENT TOXICITY		Effluent Limits, %		Receiving Water or Ambient	Effluent Concentration (ug/L or as noted)	Reporting Limit Check	Possible Exceedence ⁽⁷⁾	
		Acute	Chronic				Acute	Chronic
	Trout - Acute							
	Trout - Chronic							
	Water Flea - Acute							
	Water Flea - Chronic							
WET CHEMISTRY								
	pH (S.U.) ⁽⁹⁾			(8)				
	Total Organic Carbon (mg/L)			(8)				
	Total Solids (mg/L)							
	Total Suspended Solids (mg/L)							
	Alkalinity (mg/L)			(8)				
	Specific Conductance (umhos)							
	Total Hardness (mg/L)			(8)				
	Total Magnesium (mg/L)			(8)				
	Total Calcium (mg/L)			(8)				
ANALYTICAL CHEMISTRY ⁽³⁾								
Also do these tests on the effluent with WET. Testing on the receiving water is optional		Effluent Limits, ug/L				Reporting Limit Check	Possible Exceedence ⁽⁷⁾	
		Reporting Limit	Acute ⁽⁶⁾	Chronic ⁽⁶⁾	Health ⁽⁶⁾		Acute	Chronic
	TOTAL RESIDUAL CHLORINE (mg/L) ⁽⁹⁾	0.05						
	AMMONIA	NA			NA			
M	ALUMINUM	NA			(8)			
M	ARSENIC	5			(8)			
M	CADMIUM	1			(8)			
M	CHROMIUM	10			(8)			
M	COPPER	3			(8)			
M	CYANIDE	5			(8)			
M	LEAD	3			(8)			
M	NICKEL	5			(8)			
M	SILVER	1			(8)			
M	ZINC	5			(8)			

Maine Department of Environmental Protection
WET and Chemical Specific Data Report Form
This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

PRIORITY POLLUTANTS ⁽⁴⁾		Reporting Limit			Effluent Limits		Health ⁽⁶⁾		Reporting Limit Check	Possible Exceedence ⁽⁷⁾	
					Acute ⁽⁶⁾	Chronic ⁽⁶⁾	Health ⁽⁶⁾			Acute	Chronic
M	ANTIMONY	5									
M	BERYLLIUM	2									
M	MERCURY (5)	0.2									
M	SELENIUM	5									
M	THALLIUM	4									
A	2,4,6-TRICHLOROPHENOL	3									
A	2,4-DICHLOROPHENOL	5									
A	2,4-DIMETHYLPHENOL	5									
A	2,4-DINITROPHENOL	45									
A	2-CHLOROPHENOL	5									
A	2-NITROPHENOL	5									
A	4,6 DINITRO-O-CRESOL (2-Methyl-4,6-dinitrophenol)	25									
A	4-NITROPHENOL	20									
A	P-CHLORO-M-CRESOL (3-methyl-4-chlorophenol)+B80	5									
A	PENTACHLOROPHENOL	20									
A	PHENOL	5									
BN	1,2,4-TRICHLOROBENZENE	5									
BN	1,2-(O)DICHLOROBENZENE	5									
BN	1,2-DIPHENYLHYDRAZINE	10									
BN	1,3-(M)DICHLOROBENZENE	5									
BN	1,4-(P)DICHLOROBENZENE	5									
BN	2,4-DINITROTOLUENE	6									
BN	2,6-DINITROTOLUENE	5									
BN	2-CHLORONAPHTHALENE	5									
BN	3,3'-DICHLOROBENZIDINE	16.5									
BN	3,4-BENZO(B)FLUORANTHENE	5									
BN	4-BROMOPHENYLPHENYL ETHER	2									
BN	4-CHLOROPHENYL PHENYL ETHER	5									
BN	ACENAPHTHENE	5									
BN	ACENAPHTHYLENE	5									
BN	ANTHRACENE	5									
BN	BENZIDINE	45									
BN	BENZO(A)ANTHRACENE	8									
BN	BENZO(A)PYRENE	3									
BN	BENZO(G,H,I)PERYLENE	5									
BN	BENZO(K)FLUORANTHENE	3									
BN	BIS(2-CHLOROETHOXY)METHANE	5									
BN	BIS(2-CHLOROETHYL)ETHER	6									
BN	BIS(2-CHLOROISOPROPYL)ETHER	6									
BN	BIS(2-ETHYLHEXYL)PHTHALATE	3									
BN	BUTYLBENZYL PHTHALATE	5									
BN	CHRYSENE	3									
BN	DI-N-BUTYL PHTHALATE	5									
BN	DI-N-OCTYL PHTHALATE	5									
BN	DIBENZO(A,H)ANTHRACENE	5									
BN	DIETHYL PHTHALATE	5									
BN	DIMETHYL PHTHALATE	5									

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

[illegible]

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

[illegible]

Notes:

- (1) Flow average for day pertains to WET/PP composite sample day.
- (2) Flow average for month is for month in which WET/PP sample was taken.
- (3) Analytical chemistry parameters must be done as part of the WET test chemistry.
- (4) Priority Pollutants should be reported in micrograms per liter (ug/L).
- (5) Mercury is often reported in nanograms per liter (ng/L) by the contract laboratory, so be sure to convert to micrograms per liter on this spreadsheet.
- (6) Effluent Limits are calculated based on dilution factor, background allocation (10%) and water quality reserves (15% - to allow for new or changed discharges or non-point sources).
- (7) Possible Exceedence determinations are done for a single sample only on a mass basis using the actual pounds discharged. This analysis does not consider watershed wide allocations for fresh water discharges.
- (8) These tests are optional for the receiving water. However, where possible samples of the receiving water should be preserved and saved for the duration of the WET test. In the event of questions about the receiving water's possible effect on the WET results, chemistry tests should then be conducted.
- (9) pH and Total Residual Chlorine must be conducted at the time of sample collection. Tests for Total Residual Chlorine need be conducted only when an effluent has been chlorinated or residual chlorine is believed to be present for any other reason.

Comments:

ATTACHMENT B

**MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION
WHOLE EFFLUENT TOXICITY REPORT
FRESH WATERS**

Facility Name _____ MEPDES Permit # _____

Facility Representative _____ Signature _____

By signing this form, I attest that to the best of my knowledge that the information provided is true, accurate, and complete.

Facility Telephone # _____ Date Collected _____ Date Tested _____
mm/dd/yy mm/dd/yy

Chlorinated? _____ Dechlorinated? _____

Results	% effluent		Effluent Limitations
	water flea	trout	
A-NOEL			A-NOEL
C-NOEL			C-NOEL

Data summary	water flea			trout		
	% survival		no. young	% survival		final weight (mg)
QC standard	A>90	C>80	>15/female	A>90	C>80	> 2% increase
lab control						
receiving water control						
conc. 1 (%)						
conc. 2 (%)						
conc. 3 (%)						
conc. 4 (%)						
conc. 5 (%)						
conc. 6 (%)						
stat test used						

place * next to values statistically different from controls

for trout show final wt and % incr for both controls

Reference toxicant	water flea		trout	
	A-NOEL	C-NOEL	A-NOEL	C-NOEL
toxicant / date				
limits (mg/L)				
results (mg/L)				

Comments _____

Laboratory conducting test

Company Name _____ Company Rep. Name (Printed) _____

Mailing Address _____ Company Rep. Signature _____

City, State, ZIP _____ Company Telephone # _____

Report WET chemistry on DEP Form "ToxSheet (Fresh Water Version), March 2007."

ATTACHMENT C

Effluent Mercury Test Report

Name of Facility: _____

Federal Permit # ME _____

Pipe # _____

Purpose of this test: ☐ Initial limit determination
☐ Compliance monitoring for: year _____ calendar quarter _____
☐ Supplemental or extra test

SAMPLE COLLECTION INFORMATION

Sampling Date:

--	--	--

 Sampling time: _____ AM/PM
mm dd yy

Sampling Location: _____

Weather Conditions: _____

Please describe any unusual conditions with the influent or at the facility during or preceding the time of sample collection:

Optional test - not required but recommended where possible to allow for the most meaningful evaluation of mercury results:

Suspended Solids _____ mg/L Sample type: _____ Grab (recommended) or
_____ Composite

ANALYTICAL RESULT FOR EFFLUENT MERCURY

Name of Laboratory: _____

Date of analysis: _____ **Result:** ng/L (PPT)**Please Enter Effluent Limits for your facility**Effluent Limits: **Average** = _____ ng/L **Maximum** = _____ ng/L

Please attach any remarks or comments from the laboratory that may have a bearing on the results or their interpretation. If duplicate samples were taken at the same time please report the average.

CERTIFICATION

I certify that to the best of my knowledge the foregoing information is correct and representative of conditions at the time of sample collection. The sample for mercury was collected and analyzed using EPA Methods 1669 (clean sampling) and 1631 (trace level analysis) in accordance with instructions from the DEP.

By: _____ Date: _____

Title: _____

PLEASE MAIL THIS FORM TO YOUR ASSIGNED INSPECTOR

**MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT
AND
MAINE WASTE DISCHARGE LICENSE**

FACT SHEET

Date: **June 8, 2010**

PERMIT NUMBER: **ME0101061**
LICENSE NUMBER: **W002689-6B-F-R**

NAME AND ADDRESS OF APPLICANT:

**TOWN OF JAY
99 Main Street
Jay, Maine 04239**

COUNTY: **Franklin County**

NAME AND ADDRESS WHERE DISCHARGE OCCURS:

**North Jay Waste Water Treatment Facility
32 Jerry Street
Jay, Maine 04239**

RECEIVING WATER AND CLASSIFICATION: **Sevenmile Stream, Class B**

COGNIZANT OFFICIAL AND TELEPHONE NUMBER: **Mark Holt, Superintendent
(207) 645-4246**
e-mail: jsewer@jay-maine.org

1. APPLICATION SUMMARY

- a. Application – The Town has submitted a timely and complete application to the Department for renewal of combination Maine Pollutant Discharge Elimination System (MEPDES) permit #ME0101061 / Maine Waste Discharge License (WDL) #W002689-5L-E-R, (permit hereinafter) issued by the Department on August 2, 2005, and is due to expire on August 2, 2010. It is noted the 8/2/05 permit was modified on 12/29/08 to eliminate water quality based limits for toxic pollutants that were no longer of concern and incorporated new water quality based limitations for toxic pollutants that were of concern based on an updated statistical evaluation. The 8/2/05 permit and the 12/29/08 permit modification approved the discharge of up to a monthly average flow of 0.060 million gallons per day (MGD) of secondary treated waste waters to Sevenmile Stream, Class B, in Jay (North Jay), Maine. See **Attachment A** of this Fact Sheet for a location map.

1. APPLICATION SUMMARY

- b. Source Description: The Town of Jay's waste water treatment facility receives sanitary waste waters from approximately 120 residential and commercial users in the village of North Jay. The town maintains separate sanitary and stormwater collection systems. The collection system does not contain any combined sewer overflows (CSOs) but there is a significant increase in flow to the plant associated with wet weather. The sanitary collection system is approximately 3 miles in length with no pump stations as the entire system flows via gravity. The waste water treatment facility is not authorized to accept transported wastes from local septic haulers. There are no significant industrial users contributing to the facility's influent flow.
- c. Waste Water Treatment: The North Jay waste water treatment facility provides a secondary level of treatment via an extended air activated sludge process. A facility upgrade was completed in April of 1999 converting the facility from the original package-type treatment facility which was built in 1972, to an enlarged package-type treatment facility. All of the activated sludge treatment units are contained within a circular structure. The disinfection system is located in a separate building. The major components of the waste water treatment process include a bar screen, a coarse bubble aeration system, one secondary clarifier, and a chlorine contact chamber. The effluent is disinfected with sodium hypo-chlorite and dechlorinated with sodium bisulfite prior to being discharged to Sevenmile Stream via a 8-inch diameter outfall pipe. See **Attachment B** of this Fact Sheet for a schematic of the waste water treatment processes.

2. PERMIT SUMMARY

- a. Terms and Conditions: This permitting action is similar to the 8/2/05 permit in that it is carrying forward all the terms and conditions with the following except that this permit is eliminating the monthly average water quality based mass and concentration limitations for bis(2-ethylhexyl)phthalate.
- b. History: The most recent regulatory actions include the following:

August 26, 1994 - The Department issued a renewal of WDL #2689 with secondary limitations associated with a monthly average discharge of 0.06 MGD to Sevenmile Stream in Jay, Maine.

September 21, 1994 - The U.S. Environmental Protection Agency (USEPA) issued National Pollutant Discharge Elimination System (NPDES) permit #ME0101061 for five-year term.

February 5, 1995 - The Department issued a letter to Jay that administratively modified WDL #2689 to incorporate whole effluent toxicity (WET) and chemical specific (priority pollutant) testing pursuant to Department Regulation, Chapter 530.5, *Surface Water Toxics Control Program*.

2. PERMIT SUMMARY (cont'd)

December 8, 2000 – The Department issued WDL #W002689-5L-D-R for a five-year term.

May 23, 2000 – The Department administratively modified the 2/5/95 WDL by establishing interim mean and maximum technology based concentration limitations of 4.5 ng/L and 6.8 ng/L, respectively for mercury.

January 12, 2001 – The State of Maine received authorization from the USEPA to administer the NPDES permitting program in Maine. From that date forward the program has been referred to as the MEPDES permit program and ME0101061 remains the primary permit reference number for the facility.

August 2, 2005 – The Department issued combination MEPDES permit #ME0101061 / WDL #W002689-5L-E-R, for a five-year term.

April 10, 2006 – The Department initiated a modification of the 8/2/05 permit by incorporated the whole effluent toxicity (WET) and chemical specific testing requirements of Department rule 06-096 CMR Chapter 530, *Surface Water Toxics Control Program* promulgated on October 12, 2005.

December 29, 2008 – The Department issued a minor revision of the 8/2/05 permit by eliminating water quality based mass and concentration limits for arsenic, bis(2-ethylhexyl)phthalate and silver based on the results of 12/10/08 statistical evaluation pursuant to Chapter 530.

June 8, 2010 – The Town of Jay submitted a timely and complete application to the Department to renew the 8/2/10 MEPDES permit.

3. CONDITIONS OF PERMITS

Maine law, 38 M.R.S.A. Section 414-A, requires that the effluent limitations prescribed for discharges, including, but not limited to, effluent toxicity, require application of best practicable treatment (BPT), be consistent with the U.S. Clean Water Act, and ensure that the receiving waters attain the State water quality standards as described in Maine's Surface Water Classification System. In addition, 38 M.R.S.A., Section 420 and Department rule 06-096 CMR Chapter 530, *Surface Water Toxics Control Program*, require the regulation of toxic substances not to exceed levels set forth in Department rule 06-096 CMR Chapter 584, *Surface Water Quality Criteria for Toxic Pollutants*, and that ensure safe levels for the discharge of toxic pollutants such that existing and designated uses of surface waters are maintained and protected.

4. RECEIVING WATER QUALITY STANDARDS:

Maine law, 38 M.R.S.A., Section 467(1)(D) classifies Sevenmile Stream as a Class B waterway. Maine law 38 M.R.S.A., Section 465(3) describes standards for classification of Class B waters.

5. RECEIVING WATER QUALITY CONDITIONS

Sevenmile Stream is listed in a category entitled “*Category 2: Rivers And Streams Attaining Some Designated Uses Insufficient Information For Other Uses*”, in a document entitled, 2008 Integrated Water Quality Monitoring And Assessment Report prepared by the Department. Based on the available information collected to date, the Department has determined that Sevenmile Stream is attaining the standards of its assigned classification.

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS

- a. Flow: The monthly average flow limitation of 0.06 MGD in the previous permitting action is being carried forward in this permitting action as it remains representative of the monthly average design flow for the facility. The previous permitting action also established a daily maximum discharge flow reporting requirement that is being carried forward in this permitting action to assist the Department in evaluation of effluent data.

A review of the monthly Discharge Monitoring Report (DMR) data for the period January 2006 through November 2009 indicates the permittee has been in compliance with the flow limitation 94% of the time as values have been reported as follows:

Flow (DMRs=47)

Value	Limit (MGD)	Range (MGD)	Mean (MGD)
Monthly average	0.060	0.0130 – 0.06817	0.0460
Daily maximum	Report	0.0159 – 0.141	0.0742

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS (cont'd)

- b. Dilution Factors: The Department establishes applicable dilution factors for the discharge in accordance with freshwater protocols established in Department rule Chapter 530, *Surface Water Toxics Control Program*, October 2005. With a monthly average WDL flow limitation of 0.06 MGD, the dilution factors for the waste waters discharged from the North Jay waste water treatment facility can be calculated as follows:

$$\text{Dilution Factor} = \frac{(\text{River Flow in cfs})(\text{Conversion Factor}) + \text{Plant Flow in MGD}}{\text{Plant Flow in MGD}}$$

$$\text{Acute Dilution}^{(1)} = \frac{(1.53 \text{ cfs})(0.6464) + (0.06 \text{ MGD})}{(0.06 \text{ MGD})} = 17.5:1$$

$$\text{Chronic Dilution} = \frac{(1.8 \text{ cfs})(0.6464) + (0.06 \text{ MGD})}{(0.06 \text{ MGD})} = 20.4:1$$

$$\text{Harmonic Dilution} = \frac{(5.4 \text{ cfs})(0.6464) + (0.06 \text{ MGD})}{(0.06 \text{ MGD})} = 59:1$$

Footnote:

(1)-Chapter 530(4)(B)(1) states that analyses using numeric acute criteria for aquatic life must be based on ¼ of the 1Q10 stream design flow to prevent substantial acute toxicity within any mixing zone. The regulation goes on to say that where it can be demonstrated that a discharge achieves rapid and complete mixing with the receiving water by way of an efficient diffuser or other effective method, analyses may use a greater proportion of the stream flow, up to including all of it.

Jay has provided the Department with information as to the true mixing characteristics of the discharge, therefore the Department is utilizing the entire stream flow of 1Q10 pursuant to Chapter 530 in acute evaluations.

- c. Biochemical oxygen demand (BOD₅) and Total suspended solids (TSS): The previous permitting action established monthly and weekly average BOD and TSS concentration limits of 30 mg/L and 45 mg/L, respectively. These limits were based on secondary treatment requirements pursuant to Department rule, 06-096 CMR Chapter 525(3)(III). The previous permit established a daily maximum concentration limit of 50 mg/L, which is based on a Department best practicable treatment requirement for all publicly-owned treatment works and is also being carried forward in this permitting action. BOD and TSS mass limits are calculated using the monthly average flow limit of 0.06 MGD, monthly average, weekly average and daily maximum concentrations of 30, 45 and 50 mg/l, respectively, and a conversion factor of 8.34 lbs/gal.

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS (cont'd)

Monthly average BOD/TSS = (30mg/l)(0.06 MGD)(8.34) = 15 lbs/day.

Weekly average BOD/TSS = (45 mg/l)(0.06 MGD)(8.34) = 23 lbs/day

Daily Maximum BOD/TSS = (50 mg/l)(0.06 MGD)(8.34) = 25 lbs/day.

The previous permit also established more stringent summertime (June 15 to October 15) limits for BOD in order to meet the minimum dissolved oxygen (D.O.) standards in Sevenmile Stream, which is classified as a Class B waterway. A desktop model (developed in 1991 by the Department) calculation based on the instream D.O. standard of 7 mg/L., yielded a weekly average limit of 7.5 lb/day of BOD at the 7Q10 flow of 1.8 cfs. Back calculating from this loading to a concentration yields a weekly average concentration limit for BOD of 15 mg/L. Using the same mathematical relationships as the BPT concentrations (30, 45 and 50 mg/L), the monthly average mass and concentration limits are 5.0 lb/day and 10 mg/L, and the daily maximum mass and concentrations are 8.5 lb/day and 17 mg/L respectively. These seasonal water quality based mass and concentration for BOD are being carried forward in this permitting action. This permitting action also establishes a new requirement of 85% removal for BOD and TSS pursuant to Department rule Chapter 525(3)(III)(a&b)(3).

A review of the monthly Discharge Monitoring Report (DMR) data for the period January 2006 through November 2009 indicates the permittee has been in compliance with the BOD and TSS limitations 100% of the time as values have been reported as follows:

Warm season (June 1 – September 30)

BOD Mass (DMRs=16)

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	5.0	0.5 – 2.8	1.4
Weekly Average	7.5	0.6 – 3.0	1.5
Daily Maximum	8.5	0.6 – 3.0	1.5

BOD Concentration (DMRs= 16)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	10	4 – 8	5.9
Weekly Average	15	5 – 10	6.6
Daily Maximum	17	5 – 10	6.6

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS (cont'd)

Cold season (October 1 – May 31)

BOD Mass (DMRs=18)

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	15	0.7 – 4.6	4.0
Weekly Average	23	0.8 – 2.9	4.4
Daily Maximum	25	0.8 – 2.9	4.4

BOD Concentration (DMRs=18)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	30	4 – 14	14
Weekly Average	45	4 – 14	16
Daily Maximum	50	4 – 14	16

Year-round

TSS mass (DMRs=34)

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	15	0.1 – 3.4	1.4
Weekly Average	23	0.1 – 4.8	1.7
Daily Maximum	25	0.1 – 4.8	1.7

TSS concentration (DMRs=34)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	30	0.6 – 9.5	5.0
Weekly Average	45	0.8 – 10.2	6.3
Daily Maximum	50	0.8 – 10.2	6.3

- d. Settleable Solids: The previous permitting action established a daily maximum concentration limit of 0.3 ml/L that is being carried forward in this permitting action and is based on a Department best professional judgment of BPT. A review of the monthly Discharge Monitoring Report (DMR) data for the period January 2007 through November 2009 indicates the permittee has been in compliance with the flow limitation 100% of the time as values have been reported as follows:

Settleable solids

Value	Limit (ml/L)	Range (ml/L)	Average (ml/L)
Daily Maximum	0.3	0.0 – 0.1	0

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS (cont'd)

- e. *Escherichia coli (E. Coli) bacteria*: The previous permitting action established monthly average and daily maximum concentration limits of 64 col/100 ml (monthly average) and 427 col/100 ml (daily maximum), based on the state of Maine Water Classification Program criteria (Maine law 38 M.R.S.A., §465) for Class B waters at the time of permitting. These limits are being carried forward in this permitting action. It is noted emergency legislation was passed in June of 2005 establishing a more stringent instantaneous ambient (in-stream) water quality standard of 235 colonies/100 ml for *E. coli* bacteria. Given the available acute dilution of 17.5:1, the daily maximum limitation of 427 col/100 ml in this permitting action will not cause or contribute to a violation of the newer *E. coli* bacteria water quality standard.

A review of the monthly Discharge Monitoring Report (DMR) data for the period January 2007 through November 2009 indicates the permittee has been in compliance with the flow limitation 100% of the time as values have been reported as follows:

E. coli. bacteria (DMRs=19)

Value	Limit (col/100 ml)	Range (col/100 ml)	Mean (col/100 ml)
Monthly Average	64	0 - 21	4
Daily Maximum	427	1 - 66	10

- f. Total Residual Chlorine (TRC): The previous permitting action established monthly average and daily maximum technology based concentration limits of 0.1 mg/L and 0.3 mg/L respectively. Limits for total residual chlorine are specified to ensure attainment of the ambient water quality criteria (AWQC) for levels of chlorine and that the BPT is utilized to abate the discharge of chlorine. The more stringent of the two limitations is established permitting actions. Daily maximum (acute) and monthly average (chronic) end-of-pipe water quality based concentration limits may be calculated as follows:

Parameter	Acute (A) Criterion	Chronic (C) Criterion	A & C Dilution Factor (A) (C)	Acute Limit	Chronic Limit
Chlorine	0.019 mg/L	0.011 mg/L	17.5:1 & 20.4:1	0.33 mg/L	0.22 mg/L

To meet the water quality based limits calculated above, the permittee must dechlorinate the effluent prior to discharge. The Department has established monthly average and daily maximum BPT limitations of 0.1 mg/L and 0.3 mg/L for facilities that need to dechlorinate their effluent unless calculated water quality based limits are lower than the respective technology based limits. In the case of the Town of Jay, the calculated acute (daily maximum) water quality based threshold of 0.33 mg/L is higher than the BPT limit of 0.3 mg/L, thus the BPT limit of 0.3 mg/L is imposed. For the monthly average the calculated chronic water quality based threshold of 0.22 mg/L is higher than the BPT limit of 0.1 mg/L, thus the BPT limit of 0.1 mg/L is imposed.

6. EFFLUENT LIMITATIONS & MONITORING REQUIREMENTS: (cont'd)

A review of the monthly Discharge Monitoring Report (DMR) data for the period January 2007 through November 2009 indicates the permittee has been in compliance with the TRC limitations 100% of the time as values have been reported as follows:

Total residual chlorine (DMRs=20)

Value	Limit (mg/L)	Range (mg/L)	Mean (mg/L)
Monthly average	0.1 mg/L	0.0 – 0.013	0
Daily maximum	0.3 mg/L	0.0 – 0.018	0

- g. pH Range- The previous permitting action established a technology based pH range limitation of 6.0 –9.0 standard units pursuant to a new Department rule found at Chapter 525(3)(III)(c). The limits are considered BPT.

A review of the DMR data for the period January 2007 – November 2009 indicates the permittee has been in compliance with the pH range limitation 100% of the time as it has never reported values outside of the pH range limitation.

The monitoring frequencies established in special Condition A - *Effluent Limitations and Monitoring Requirements* of this license are based on a schedule established in a Department policy for facilities with a monthly average flow below 0.1 MGD.

- h. Whole Effluent Toxicity (WET) & Chemical-Specific Testing: Maine law, 38 M.R.S.A., Sections 414-A and 420, prohibit the discharge of effluents containing substances in amounts that would cause the surface waters of the State to contain toxic substances above levels set forth in Federal Water Quality Criteria as established by the USEPA. Department Rules, 06-096 CMR Chapter 530, *Surface Water Toxics Control Program*, and Chapter 584, *Surface Water Quality Criteria for Toxic Pollutants* set forth ambient water quality criteria (AWQC) for toxic pollutants and procedures necessary to control levels of toxic pollutants in surface waters. WET, priority pollutant and analytical chemistry testing as required by Chapter 530, is included in this permit in order to fully characterize the effluent. This permit also provides for reconsideration of effluent limits and monitoring schedules after evaluation of toxicity testing results. The monitoring schedule includes consideration of results currently on file, the nature of the wastewater, existing treatment and receiving water characteristics.

WET monitoring is required to assess and protect against impacts upon water quality and designated uses caused by the aggregate effect of the discharge on specific aquatic organisms. Acute and chronic WET tests are performed on invertebrate and vertebrate species. Priority pollutant and analytical chemistry testing is required to assess the levels of individual toxic pollutants in the discharge, comparing each pollutant to acute, chronic, and human health AWQC as established in Chapter 584.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Chapter 530 establishes four categories of testing requirements based predominately on the chronic dilution factor. The categories are as follows:

- 1) Level I – chronic dilution factor of $<20:1$.
- 2) Level II – chronic dilution factor of $\geq 20:1$ but $<100:1$.
- 3) Level III – chronic dilution factor $\geq 100:1$ but $<500:1$ or $>500:1$ and $Q \geq 1.0$ MGD
- 4) Level IV – chronic dilution $>500:1$ and $Q \leq 1.0$ MGD

Department rule Chapter 530 (1)(D) specifies the criteria to be used in determining the minimum monitoring frequency requirements for WET, priority pollutant and analytical chemistry testing. Based on the Chapter 530 criteria, the permittee's facility falls into the Level II frequency category as the facility has a chronic dilution factor of $\geq 20:1$ but $<100:1$. Chapter 530(1)(D)(1) specifies that default screening and surveillance level testing requirements are as follows:

Screening level testing – Beginning 12 months prior to permit expiration and lasting through permit expiration and every five years thereafter.

Level	WET Testing	Priority pollutant testing	Analytical chemistry
II	2 per year	1 per year	4 per year

Surveillance level testing – Beginning upon issuance of the permit and lasting through 12 months prior to permit expiration.

Level	WET Testing	Priority pollutant testing	Analytical chemistry
II	1 per year	None required	2 per year

A review of the data on file with the Department indicates that to date, the permittee has fulfilled the WET and chemical-specific testing requirements of Chapter 530. See **Attachment C** of this Fact Sheet for a summary of the WET test results and **Attachment D** of this Fact Sheet for a summary of the chemical-specific test dates.

Department rule Chapter 530(D)(3)(c) states in part, *Dischargers in Levels II may reduce surveillance testing to one WET or specific chemical series every other year provided that testing in the preceding 60 months does not indicate any reasonable potential for exceedance as calculated pursuant to section 3(E).*

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Chapter 530(3)(E) states “*For effluent monitoring data and the variability of the pollutant in the effluent, the Department shall apply the statistical approach in Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control" (USEPA Publication 505/2-90-001, March, 1991, EPA, Office of Water, Washington, D.C.) to data to determine whether water-quality based effluent limits must be included in a waste discharge license. Where it is determined through this approach that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action.*”

Chapter 530 §3 states, “*In determining if effluent limits are required, the Department shall consider all information on file and effluent testing conducted during the preceding 60 months. However, testing done in the performance of a Toxicity Reduction Evaluation (TRE) approved by the Department may be excluded from such evaluations.*”

WET evaluation

On 2/12/10, the Department conducted a statistical evaluation on the most recent 60 months of WET data that indicates that the discharge does not exceed or have a reasonable potential (RP) to exceed either the acute or chronic critical ambient water quality criteria (AWQC) thresholds (5.7% and 4.9%, respectively – mathematical inverse of the applicable dilution factors) for any of the WET species tested to date.

Given the absence of exceedences or reasonable potential to exceed critical WET thresholds, the permittee meets the surveillance level monitoring frequency reduction criteria found at Department rule Chapter 530(D)(3)(c). Therefore, reduced surveillance level WET testing requirements are being established at once per two years (1/2 Years) for the first four years of the term of the permit. Beginning 12 months prior to the expiration date of the permit and every five years thereafter, the permittee shall conduct screening level testing of twice per year (2/Year). The WET monitoring requirements are summarized as follows:

Reduced surveillance level testing – Beginning upon issuance of the permit and lasting through 12 months prior to permit expiration.

Level	WET Testing
II	1/ 2 years

Screening level testing – Beginning 12 months prior to permit expiration and lasting through permit expiration and every five years thereafter.

Level	WET Testing
II	2 per year

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

In accordance with Department rule Chapter 530(2)(D)(4) and Special Condition L of this permit, *Chapter 530(2)(D)(4) Certification*, the permittee must annually submit to the Department a written statement evaluating its current status for each of the four conditions listed.

Chemical specific evaluation –

Maine Law, 38 M.R.S.A, Sections 414-A and 420, Maine Rules Chapter 523(5)(d)(i), prohibit the discharge of effluents containing substances in amounts which would cause the surface waters of the State to contain toxic substance above levels set forth in federal ambient water quality criteria (AWQC) as established by the U.S. EPA. Accordingly, the discharge is subject to effluent monitoring requirements pursuant to Department rule 06-096 CMR Chapter 530, *Surface Water Toxics Control Program*, and ambient water quality criteria (AWQC) established in Department rule 06-096 CMR Chapter 584, *Surface Water Quality Criteria for Toxic Pollutants*, that ensure safe levels for the discharge of toxic pollutants.

Chapter 584 requires a risk level of (10⁻⁶) be utilized in determining the human health criteria for toxic pollutants believed to be carcinogenic. Permit limitations based on human health criteria have been calculated utilizing an AWQC associated with the consumption of water and organisms from the receiving water, as one of the designated uses of the Sevenmile Stream include "...a drinking water supply after treatment, fishing...."

Chapter 530 (promulgated on October 12, 2005) §4(C), states "*The background concentration of specific chemicals must be included in all calculations using the following procedures. The Department may publish and periodically update a list of default background concentrations for specific pollutants on a regional, watershed or statewide basis. In doing so, the Department shall use data collected from reference sites that are measured at points not significantly affected by point and non-point discharges and best calculated to accurately represent ambient water quality conditions. The Department shall use the same general methods as those in section 4(D) to determine background concentrations. For pollutants not listed by the Department, an assumed concentration of 10% of the applicable water quality criteria must be used in calculations.*" The Department has limited information on the background levels of metals in the water column in the Sevenmile Stream in the vicinity of the permittee's outfall. Therefore, a default background concentration of 10% of the applicable water quality criteria is being used in the calculations of this permitting action.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Chapter 530 4(E), states *"In allocating assimilative capacity for toxic pollutants, the Department shall hold a portion of the total capacity in an unallocated reserve to allow for new or changed discharges and non-point source contributions. The unallocated reserve must be reviewed and restored as necessary at intervals of not more than five years. The water quality reserve must be not less than 15% of the total assimilative quantity."* Therefore, the Department is reserving 15% of the applicable water quality criteria in the calculations of this permitting action.

Chapter 530 §(3)(E) states *"... that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action."*

Chapter 530 §4(F) states in part *"Where there is more than one discharge into the same fresh or estuarine receiving water or watershed, the Department shall consider the cumulative effects of those discharges when determining the need for and establishment of the level of effluent limits. The Department shall calculate the total allowable discharge quantity for specific pollutants, less the water quality reserve and background concentration, necessary to achieve or maintain water quality criteria at all points of discharge, and in the entire watershed. The total allowable discharge quantity for pollutants must be allocated consistent with the following principles."*

Evaluations must be done for individual pollutants of concern in each watershed or segment to assure that water quality criteria are met at all points in the watershed and, if appropriate, within tributaries of a larger river.

The total assimilative capacity, less the water quality reserve and background concentration, may be allocated among the discharges according to the past discharge quantities for each as a percentage of the total quantity of discharges, or another comparable method appropriate for a specific situation and pollutant. Past discharges of pollutants must be determined using the average concentration discharged during the past five years and the facility's licensed flow.

The amount of allowable discharge quantity may be no more than the past discharge quantity calculated using the statistical approach referred to in section 3(E) [Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control"] of the rule, but in no event may allocations cause the water quality reserve amount to fall below the minimum referred to in 4(E) [15% of the total assimilative capacity]. Any difference between the total allowable discharge quantity and that allocated to existing dischargers must be added to the reserve.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Sevenmile Stream is a tributary to the Androscoggin River. As previously cited, Chapter 530 requires that AWQC must be met at the confluence of the Sevenmile Stream and the Androscoggin River as well as at the individual discharge point on Sevenmile after taking into consideration historic discharge levels for all facilities in the watershed as well as an allocation dedicated to background (10% of AWQC) and a reserve (15% of AWQC).

See **Attachment F** of this Fact Sheet Based on Department guidance that establishes protocols for establishing waste load allocations. The guidance states that the most protective of water quality becomes the facility's allocation.

Being that the Town of Jay's discharge is the only discharger to Sevenmile Stream and the overwhelming dilution provided by the Androscoggin River at the confluence, this permitting action is utilizing the individual allocation methodology in evaluating and establishing water quality based limitations for pollutants of concern being discharged from the Town of Jay's waste water treatment facility.

As with the WET data, the Department conducted a statistical evaluation on 2/12/10 of the most recent 60 months of chemical specific data on file at the Department. The evaluation indicates the permittee has submitted a test result of 3.0 ug/L for total lead on 6/10/08 that has a reasonable potential to exceed the chronic AWQC of 0.41 ug/L for lead. Pursuant to Chapter 530 §(3)(E), monthly average water quality mass and concentration limitations for lead were derived in accordance with the following equation:

$$\text{EOP concentration} = [\text{Dilution factor} \times 0.75 \times \text{AWQC in ug/L}] + [0.25 \times \text{AWQC in ug/L}]$$

$$\text{Mass limit} = \frac{(\text{EOP concentration in ug/L})(8.34 \text{ lbs/gal})(\text{Permit flow limit in MGD})}{1000 \text{ ug/mg}}$$

Lead

Mass limitations

$$\text{Chronic AWQC} = 0.41 \text{ ug/L}$$

$$\text{Chronic dilution factor: } 20.4:1$$

$$\text{EOP concentration} = [\text{Dilution factor} \times 0.75 \times \text{AWQC}] + [0.25 \times \text{AWQC}]$$

$$\text{EOP concentration} = [(20.4 \times 0.75 \times 0.41 \text{ ug/L}) + (0.25 \times 0.41 \text{ ug/L})] = 6.4 \text{ ug/L}$$

$$\text{Mass limit} = \frac{(6.4 \text{ ug/L})(8.34 \text{ lbs/gal})(0.060 \text{ MGD})}{1000 \text{ ug/mg}} = 0.0032 \text{ lbs/day}$$

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

As for concentration, Chapter 530 §(3)(D)(1) states “For specific chemicals, effluent limits must be expressed in total quantity that may be discharged and in effluent concentration. In establishing concentration, the Department may increase allowable values to reflect actual flows that are lower than permitted flows and/or provide opportunities for flow reductions and pollution prevention provided water quality criteria are not exceeded. With regard to concentration limits, the Department may review past and projected flows and set limits to reflect proper operation of the treatment facilities that will keep the discharge of pollutants to the minimum level practicable.”

Since the adoption of Chapter 530, the Department has developed a policy for establishing equitable concentration limits in permits that are greater than calculated end-of-pipe concentrations. In general, most dischargers subject to the Chapter 530 testing requirements are discharging at or about 50% of the flow limitations established in their permits. This provides the Department with the flexibility to establish higher concentration limits in the permit while still maintaining compliance with the water quality based mass limitations. With an actual discharge flow at $\frac{1}{2}$ (0.5) of permitted flow rate, a concentration limit of two times (mathematical inverse of 0.5) the calculated end-of-pipe concentration, will maintain compliance with water quality based mass limits. Therefore, this permitting action is establishing concentration limitations that are two (2) times higher than the calculated end-of-pipe concentrations. The permittee must keep in mind, if flows greater than 50% of the permitted flow are realized, the concentration in the effluent must be reduced proportionally to maintain compliance with the mass limitations.

Concentration limitations for total lead in this permitting action were derived as follows;

Tier I

Permit concentration limit: $(6.4 \text{ ug/L})(2.0) = 12.8 \text{ ug/L}$ or 13 ug/L

Chapter 530 does not establish monitoring frequencies for parameters that exceed or have a reasonable potential to exceed AWQC. Monitoring frequencies are established on case by case basis given the timing, severity and frequency of occurrences of the exceedences or reasonable potential to exceed applicable critical water quality thresholds. Therefore, this permitting action is making a best professional judgment to establish the monitoring frequencies for the parameters of concern (lead) at the default surveillance level frequency of twice per year (2/Year) specified in Chapter 530.

As for the remaining chemical specific parameters tested to date, none of the test results in the 60-month evaluation period exceed or have a reasonable potential to exceed applicable acute, chronic or human health AWQC. Therefore, this permitting action is establishing a reduced surveillance level reporting and monitoring frequency of once every two years (1/2 Years) for analytical chemistry testing for the first four years of the

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

term of the permit. As with reduced WET testing, the permittee must file an annual certification with the Department pursuant to Chapter 530 §2(D)(3) and Special Condition L of this permit.

Beginning 12 months prior to the expiration date of the permit, the permittee shall conduct default screening level analytical chemistry testing at 1/Quarter and priority pollutant testing of 1/Year.

- i. Mercury: Pursuant to *Certain deposits and discharges prohibited*, Maine law, 38 M.R.S.A. § 420 and Waste discharge licenses, 38 M.R.S.A. § 413 and Interim Effluent Limitations and Controls for the Discharge of Mercury, 06-096 CMR 519 (last amended October 6, 2001), the Department issued a Notice of Interim Limits for the discharge of mercury to the permittee on May 23, 2000, thereby administratively modifying MEPDES #ME0101601/WDL # W002689-5L-E-R by establishing interim monthly average and daily maximum effluent concentration limits of 4.5 parts per trillion (ppt) and 6.8 ppt, respectively, and a minimum monitoring frequency requirement of four (4) tests per year for mercury. Limitations and monitoring frequencies are regulated separately through 38 M.R.S.A. § 413 and 06-096 CMR 519 and Special Condition K of this permit. The interim limitations remain in effect and enforceable and any modifications to the limits and or monitoring requirements will be formalized outside of this permitting document.

Maine law 38 M.R.S.A., §420 1-B,(B)(1) states that a facility is not in violation of the AWQC for mercury if the facility is in compliance with an interim discharge limit established by the Department pursuant to section 413, subsection 11. A review of the Department's database for the previous 60-month period indicates the permittee has been in compliance with the interim limitations for mercury as test results reported have ranged from 1.0 ppt to 6.2 ppt with an arithmetic mean (n=21) of 2.3 ppt.

7. DISCHARGE IMPACT ON RECEIVING WATER QUALITY

As permitted, the Department has determined the existing water uses will be maintained and protected and the discharge will not cause or contribute to the failure of the waterbody to meet standards for Class B classification.

8. PUBLIC COMMENTS

Public notice of this application was made in the Lewiston Sun Journal newspaper on or about June 4, 2010. The Department receives public comments on an application until the date a final agency action is taken on that application. Those persons receiving copies of draft permits shall have at least 30 days in which to submit comments on the draft or to request a public hearing, pursuant to Chapter 522 of the Department's rules.

9. DEPARTMENT CONTACTS


Additional information concerning this permitting action may be obtained from and written comments should be sent to:

Gregg Wood
Division of Water Quality Management
Bureau of Land and Water Quality
Department of Environmental Protection
17 State House Station
Augusta, Maine 04333-0017
E-mail: gregg.wood@maine.gov
Telephone: (207) 287-7693

10. RESPONSE TO COMMENTS

During the period of June 8, 2010, through the issuance date of the permit/license, the Department solicited comments on the proposed draft permit/license to be issued for the discharge(s) from the North Jay facility. The Department did not receive comments from the permittee, state or federal agencies or interested parties that resulted in any substantive change(s) in the terms and conditions of the permit. Therefore, the Department has not prepared a Response to Comments.

ATTACHMENT A



70°20'
70.33°

Contour interval
80 feet (24.4 meters)


70°15'
70.25°

MAP

ATTACHMENT B

LINE DRAWING OF FLOW THROUGH THE NORTH JAY WASTEWATER TREATMENT FACILITY

Note: Flow values indicated are averages. Tank capacities remain constant.



ATTACHMENT C

3/9/2010

WET TEST REPORT

Data for tests conducted for the period
09/Mar/2005 - 09/Mar/2010 period.



NORTH JAY		NPDES= ME010106	Effluent Limit: Acute (%) = 5.720	Chronic (%) = 4.904
Species	Test	Percent	Sample date	Exception
TROUT	A_NOEL	100	07/19/2005	5.720
	A_NOEL	100	07/19/2006	5.720
	A_NOEL	100	06/10/2008	5.720
	A_NOEL	100	10/18/2009	5.720
TROUT	C_NOEL	100	07/19/2005	4.904
TROUT	C_NOEL	100	07/19/2006	4.904
TROUT	C_NOEL	100	06/10/2008	4.904
TROUT	C_NOEL	100	10/18/2009	4.904
WATER FLEA	A_NOEL	100	07/19/2005	5.720
	A_NOEL	100	07/19/2006	5.720
	A_NOEL	100	01/23/2007	5.720
	A_NOEL	100	06/10/2008	5.720
WATER FLEA	A_NOEL	100	10/18/2009	5.720
WATER FLEA	C_NOEL	100	07/19/2005	4.904
WATER FLEA	C_NOEL	100	07/19/2006	4.904
WATER FLEA	C_NOEL	100	01/23/2007	4.904
WATER FLEA	C_NOEL	100	06/10/2008	4.904
WATER FLEA	C_NOEL	100	10/18/2009	4.904

ATTACHMENT D

PP Data for "Hits" Only

NORTH JAY

SEVEN MILE STREAM

LEAD				
MDL = 3 ug/l	Conc, ug/l	MDL	Sample Date	Date Entered
	3.000000	OK	06/10/2008	08/05/2008
	< 3.000000	OK	09/07/2004	11/09/2004
	< 3.000000	OK	07/19/2005	10/21/2005
	< 3.000000	OK	07/19/2006	10/19/2006

ATTACHMENT E

CHAPTER 530.2(D)(4) CERTIFICATION

MEPDES# _____

Facility Name _____

Since the effective date of your permit have there been:	NO	YES (Describe in Comments)
1. changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge?		
2. changes in the operation of the treatment works that may increase the toxicity of the discharge?		
3. changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge?		

COMMENTS:

Name(print) _____

Signature _____ Date _____

This document must be signed by the permittee or their legal representative.

This form may be used to meet the requirements of Chap 530.2(D)(4). This Chapter requires all dischargers having waived or reduced Toxic testing to file a statement with the Department describing changes to the waste being contributed to their system as outlined above. As an alternative the discharger may submit a signed letter containing the same information.

ATTACHMENT F

MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION

MEMORANDUM

DATE: October 2008

TO: Interested Parties

FROM: Dennis Merrill, DEP

SUBJECT: DEP's system for evaluating toxicity from multiple discharges

Following the requirements of DEP's rules, Chapter 530, section 4(F), the Department is evaluating discharges of toxic pollutants into a freshwater river system in order to prevent cumulative impacts from multiple discharges. This is being through the use of a computer program known internally as "DeTox". The enclosed package of information is intended to introduce you to this system.

Briefly, the DeTox program evaluates each wastewater facility within a watershed in three different ways in order to characterize its effluent: 1) the facility's past history of discharges, 2) its potential toxicity at the point of discharge on an individual basis, and 3) the facility's contribution to cumulative toxicity within a river segment in conjunction with other facilities. The value that is most protective of water quality becomes the value that is held in the DeTox system as an allocation for the specific facility and pollutant.

The system is not static and uses a five-year "rolling" data window. This means that, over time, old test results drop off and newer ones are added. The intent of this process is to maintain current, uniform facility data to estimate contributions to a river's total allowable pollutant loading prior to each permit renewal.

Many facilities are required to do only a relatively small amount of pollutant testing on their effluent. This means, statistically, the fewer tests done, the greater the possibility of effluent limits being necessary based on the facility's small amount of data. To avoid this situation, most facilities, especially those with low dilution factors, should consider conducting more than the minimum number of tests required by the rules.

Attached you will find three documents with additional information on the DeTox system:

- Methods for evaluating the effects of multiple discharges of toxic pollutants
- Working definitions of terms used in the DeTox system
- Reviewing DeTox Reports
- Prototype facility and pollutant reports

If you have questions as you review these, please do not hesitate to contact me at Dennis.L.Merrill@maine.gov or 287-7788.

Maine Department of Environmental Protection

Methods for evaluating the effects of multiple discharges of toxic pollutants.

Reference: DEP Rules, Chapter 530, section 4(F)

To evaluate discharges of toxic pollutants into a freshwater river system and prevent cumulative impacts from multiple discharges, DEP uses a computer program called "DeTox" that functions as a mathematical evaluation tool.

It uses physical information about discharge sources and river conditions on file with the Department, established water quality criteria and reported effluent test information to perform these evaluations. Each toxic pollutant and associated water quality criterion for acute, chronic and/or human health effects is evaluated separately.

Each facility in a river drainage area has an assigned position code. This "address" is used to locate the facility on the river segment and in relation to other facilities and tributary streams. All calculations are performed in pounds per day to allow analysis on a mass balance. Pollutants are considered to be conservative in that once in the receiving water they will not easily degrade and have the potential to accumulate.

The process begins with establishing an assimilative capacity for each pollutant and water quality criterion at the most downstream point in the river segment. This calculation includes set-aside amounts for background and reserve quantities and assumed values for receiving water pH, temperature and hardness. The resulting amount of assimilative capacity is available for allocation among facilities on the river.

Each facility is evaluated to characterize its past discharge quantities. The historical discharge, in pounds per day, is figured using the average reported concentration and the facility's permitted flow. As has been past practice, a reasonable potential (RP) factor is used as a tool to estimate the largest discharge that may occur with a certain degree of statistical certainty. The RP factor is multiplied by the historical average to determine an allocation based on past discharges. The RP factor is also multiplied by the single highest test to obtain a maximum day estimate. Finally, the direct average without RP adjustment is used to determine the facility's percent contribution to the river segment in comparison to the sum of all discharges of the pollutant. This percent multiplied by the total assimilative capacity becomes the facility's discharge allocation used in evaluations of the segment loadings.

Additionally, individual facility discharges are evaluated as single sources, as they have been in the past to determine if local conditions are more limiting than a segment evaluation.

With all of this information, facilities are evaluated in three ways. The methods are:

1. The facility's past history. This is the average quantity discharged during the past five years multiplied by the applicable RP factor. This method is often the basis for an allocation when the discharge quantity is relatively small in comparison to the water quality based allocation.
2. An individual evaluation. This assumes no other discharge sources are present and the allowable quantity is the total available assimilative capacity. This method may be used when a local condition such as river flow at the point of discharge is the limiting factor.
3. A segment wide evaluation. This involves allocating the available assimilative capacity within a river segment based on a facility's percent of total past discharges. This method would be used when multiple discharges of the same pollutant to the same segment and the available assimilative capacity is relatively limited.

The value that is most protective of water quality becomes the facility's allocation that is held in the system for the specific facility and pollutant. It is important to note that the method used for allocation is facility and pollutant specific and different facilities on the same segment for the same pollutant can have different methods used depending on their individual situations.

Discharge amounts are always allocated to all facilities having a history of discharging a particular pollutant. This does not mean that effluent limits will be established in a permit. Limits are only needed when past discharge amounts suggest a reasonable potential to exceed a water quality based allocation, either on an individual or segment basis. Similar to past practices for single discharge evaluations, the single highest test value is multiplied by a RP factor and if product is greater than the water quality allowance, an effluent limit is established. It is important to remember an allocation is "banking" some assimilative capacity for a facility even if effluent limits are not needed.

Evaluations are also done for each tributary segment with the sum of discharge quantities in tributaries becoming a "point source" to the next most significant segment. In cases where a facility does not use all of its assimilative capacity, usually due to a more limiting individual water quality criterion, the unused quantity is rolled downstream and made available to other facilities.

The system is not static and uses a five-year rolling data window. Over time, old tests drop off and newer ones are added on. These changes cause the allocations and the need for effluent limits to shift over time to remain current with present conditions. The intent is to update a facility's data and relative contribution to a river's total assimilative capacity prior to each permit renewal. Many facilities are required to do only minimal testing to characterize their effluents. This creates a greater degree of statistical uncertainty about the true long-term quantities. Accordingly, with fewer tests the RP factor will be larger and result in a greater possibility of effluent limits being necessary. To avoid this situation, most facilities, especially those with relatively low dilution factors, are encouraged to conduct more than a minimum number of tests. It is generally to a facility's long-term benefit to have more tests on file since their RP factor will be reduced.

Maine Department of Environmental Protection

Working Definitions of Terms Used in the DeTox System.

Allocation. The amount of pollutant loading set aside for a facility. Separate amounts are set for each *water quality criterion*. Each pollutant having a history of being discharged will receive an allocation, but not all allocations become *effluent limits*. Allocation may be made in three ways: *historical allocation*, *individual allocation* or *segment allocation*.

Assimilative capacity. The amount of a pollutant that river segment can safely accept from point source discharges. It is determined for the most downstream point in a river segment using the *water quality criterion* and river flow. Separate capacities are set for acute, chronic and human health criteria as applicable for each pollutant. Calculation of this capacity includes factors for *reserve* and *background* amounts.

Background. A concentration of a pollutant that is assumed to be present in a receiving water but not attributable to discharges. By rule, this is set as a rebuttable presumption at 10% of the applicable *water quality criterion*.

Effluent limit. A numeric limit in a discharge permit specifically restricting the amount of a pollutant that may be discharged. An effluent limit is set only when the highest discharge, including an adjustment for *reasonable potential*, is greater than a facility's water quality based *allocation* for a pollutant.

Historical allocation (or RP history). One of three ways of developing an *allocation*. The facility's average history of discharges, in pounds at design flow, is multiplied by the appropriate *reasonable potential* factor. An allocation using this method does not become an *effluent limit*.

Historical discharge percentage. For each pollutant, the average discharge concentration for each facility in a segment is multiplied by the permitted flow (without including a *reasonable potential* factor). The amounts for all facilities are added together and a percent of the total is figured for each facility. When a facility has no detectable concentrations, that pollutant is assumed to be not present and it receives no percentage.

Individual allocation. One of three ways of developing an *allocation*. The facility's single highest discharge on record multiplied by the appropriate *reasonable potential* factor is compared to a water quality based quantity with an assumption that the facility is the only point source to that receiving water. If the RP-adjusted amount is larger, the water quality amount may become an *effluent limit*.

Less than. A qualification on a laboratory report indicating the concentration of a pollutant was below a certain concentration. Such a result is evaluated as being one half of the Department's reporting limit in most calculations.

Reasonable potential (RP). A statistical method to determine the highest amount of a pollutant likely to be present at any time based on the available test results. The method produces a value or RP factor that is multiplied by test results. The method relies on an EPA guidance document, and considers the coefficient of variation and the number of tests. Generally, the fewer number of tests, the higher the RP factor.

Reserve. An assumed concentration of a pollutant that set aside to account for non-point source of a pollutant and to allow new discharges of a pollutant. By rule this is set at 15% of the applicable *water quality criterion*.

Segment allocation. One of three ways of developing an *allocation*. The amount is set by multiplying a facility's *historical discharge percentage* for a specific pollutant by the *assimilative capacity* for that pollutant and criterion. A facility will have different allocation percentages for each pollutant. This amount may become an *effluent limit*.

Tributary. A stream flowing into a larger one. A total pollutant load is set by adding the all facilities *allocations* on the tributary and treating this totaled amount as a "point source" to the next larger segment.

Water quality criteria. Standards for acceptable in-stream or ambient levels of pollutants. These are established in the Department's Chapter 584 and are expressed as concentrations in ug/L. There may be separate standards for acute and chronic protection aquatic life and/or human health. Each criterion becomes a separate standard. Different stream flows are used in the calculation of each.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

CONTENTS

SECTION	TOPIC	PAGE
A	GENERAL PROVISIONS	
1	General compliance	2
2	Other materials	2
3	Duty to Comply	2
4	Duty to provide information	2
5	Permit actions	2
6	Reopener clause	2
7	Oil and hazardous substances	2
8	Property rights	3
9	Confidentiality	3
10	Duty to reapply	3
11	Other laws	3
12	Inspection and entry	3
B	OPERATION AND MAINTENANCE OF FACILITIES	
1	General facility requirements	3
2	Proper operation and maintenance	4
3	Need to halt reduce not a defense	4
4	Duty to mitigate	4
5	Bypasses	4
6	Upsets	5
C	MONITORING AND RECORDS	
1	General requirements	6
2	Representative sampling	6
3	Monitoring and records	6
D	REPORTING REQUIREMENTS	
1	Reporting requirements	7
2	Signatory requirement	8
3	Availability of reports	8
4	Existing manufacturing, commercial, mining, and silvicultural dischargers	8
5	Publicly owned treatment works	9
E	OTHER PROVISIONS	
1	Emergency action - power failure	9
2	Spill prevention	10
3	Removed substances	10
4	Connection to municipal sewer	10
F	DEFINITIONS	10

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

A. GENERAL PROVISIONS

1. **General compliance.** All discharges shall be consistent with the terms and conditions of this permit; any changes in production capacity or process modifications which result in changes in the quantity or the characteristics of the discharge must be authorized by an additional license or by modifications of this permit; it shall be a violation of the terms and conditions of this permit to discharge any pollutant not identified and authorized herein or to discharge in excess of the rates or quantities authorized herein or to violate any other conditions of this permit.

2. **Other materials.** Other materials ordinarily produced or used in the operation of this facility, which have been specifically identified in the application, may be discharged at the maximum frequency and maximum level identified in the application, provided:

- (a) They are not
 - (i) Designated as toxic or hazardous under the provisions of Sections 307 and 311, respectively, of the Federal Water Pollution Control Act; Title 38, Section 420, Maine Revised Statutes; or other applicable State Law; or
 - (ii) Known to be hazardous or toxic by the licensee.
- (b) The discharge of such materials will not violate applicable water quality standards.

3. **Duty to comply.** The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of State law and the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- (a) The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act, and 38 MRSA, §420 or Chapter 530.5 for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
- (b) Any person who violates any provision of the laws administered by the Department, including without limitation, a violation of the terms of any order, rule license, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

4. **Duty to provide information.** The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

5. **Permit actions.** This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

6. **Reopener clause.** The Department reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedule of compliance or other provisions which may be authorized under 38 MRSA, §414-A(5).

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

7. Oil and hazardous substances. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under section 311 of the Federal Clean Water Act; section 106 of the Federal Comprehensive Environmental Response, Compensation and Liability Act of 1980; or 38 MRSA §§ 1301, et. seq.

8. Property rights. This permit does not convey any property rights of any sort, or any exclusive privilege.

9. Confidentiality of records. 38 MRSA §414(6) reads as follows. "Any records, reports or information obtained under this subchapter is available to the public, except that upon a showing satisfactory to the department by any person that any records, reports or information, or particular part or any record, report or information, other than the names and addresses of applicants, license applications, licenses, and effluent data, to which the department has access under this subchapter would, if made public, divulge methods or processes that are entitled to protection as trade secrets, these records, reports or information must be confidential and not available for public inspection or examination. Any records, reports or information may be disclosed to employees or authorized representatives of the State or the United States concerned with carrying out this subchapter or any applicable federal law, and to any party to a hearing held under this section on terms the commissioner may prescribe in order to protect these confidential records, reports and information, as long as this disclosure is material and relevant to any issue under consideration by the department."

10. Duty to reapply. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.

11. Other laws. The issuance of this permit does not authorize any injury to persons or property or invasion of other property rights, nor does it relieve the permittee of its obligation to comply with other applicable Federal, State or local laws and regulations.

12. Inspection and entry. The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the EPA Administrator), upon presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

B. OPERATION AND MAINTENANCE OF FACILITIES

1. General facility requirements.

- (a) The permittee shall collect all waste flows designated by the Department as requiring treatment and discharge them into an approved waste treatment facility in such a manner as to

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

maximize removal of pollutants unless authorization to the contrary is obtained from the Department.

- (b) The permittee shall at all times maintain in good working order and operate at maximum efficiency all waste water collection, treatment and/or control facilities.
- (c) All necessary waste treatment facilities will be installed and operational prior to the discharge of any wastewaters.
- (d) Final plans and specifications must be submitted to the Department for review prior to the construction or modification of any treatment facilities.
- (e) The permittee shall install flow measuring facilities of a design approved by the Department.
- (f) The permittee must provide an outfall of a design approved by the Department which is placed in the receiving waters in such a manner that the maximum mixing and dispersion of the wastewaters will be achieved as rapidly as possible.

2. Proper operation and maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

3. Need to halt or reduce activity not a defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

4. Duty to mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

5. Bypasses.

(a) Definitions.

- (i) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
- (ii) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.

(b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this section.

(c) Notice.

- (i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D(1)(f), below. (24-hour notice).
- (d) Prohibition of bypass.
 - (i) Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (C) The permittee submitted notices as required under paragraph (c) of this section.
 - (ii) The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in paragraph (d)(i) of this section.

6. Upsets.

- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (c) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (ii) The permitted facility was at the time being properly operated; and
 - (iii) The permittee submitted notice of the upset as required in paragraph D(1)(f), below. (24 hour notice).
 - (iv) The permittee complied with any remedial measures required under paragraph B(4).
- (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

C. MONITORING AND RECORDS

1. General Requirements. This permit shall be subject to such monitoring requirements as may be reasonably required by the Department including the installation, use and maintenance of monitoring equipment or methods (including, where appropriate, biological monitoring methods). The permittee shall provide the Department with periodic reports on the proper Department reporting form of monitoring results obtained pursuant to the monitoring requirements contained herein.

2. Representative sampling. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. If effluent limitations are based wholly or partially on quantities of a product processed, the permittee shall ensure samples are representative of times when production is taking place. Where discharge monitoring is required when production is less than 50%, the resulting data shall be reported as a daily measurement but not included in computation of averages, unless specifically authorized by the Department.

3. Monitoring and records.

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.
- (c) Records of monitoring information shall include:
 - (i) The date, exact place, and time of sampling or measurements;
 - (ii) The individual(s) who performed the sampling or measurements;
 - (iii) The date(s) analyses were performed;
 - (iv) The individual(s) who performed the analyses;
 - (v) The analytical techniques or methods used; and
 - (vi) The results of such analyses.
- (d) Monitoring results must be conducted according to test procedures approved under 40 CFR part 136, unless other test procedures have been specified in the permit.
- (e) State law provides that any person who tampers with or renders inaccurate any monitoring devices or method required by any provision of law, or any order, rule license, permit approval or decision is subject to the penalties set forth in 38 MRSA, §349.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

D. REPORTING REQUIREMENTS

1. Reporting requirements.

- (a) Planned changes. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - (i) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - (ii) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under Section D(4).
 - (iii) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
- (b) Anticipated noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- (c) Transfers. This permit is not transferable to any person except upon application to and approval of the Department pursuant to 38 MRSA, § 344 and Chapters 2 and 522.
- (d) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (i) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Department for reporting results of monitoring of sludge use or disposal practices.
 - (ii) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR part 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Department.
 - (iii) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Department in the permit.
- (e) Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- (f) Twenty-four hour reporting.
 - (i) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

- (ii) The following shall be included as information which must be reported within 24 hours under this paragraph.

- (A) Any unanticipated bypass which exceeds any effluent limitation in the permit.

- (B) Any upset which exceeds any effluent limitation in the permit.

- (C) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit to be reported within 24 hours.

- (iii) The Department may waive the written report on a case-by-case basis for reports under paragraph (f)(ii) of this section if the oral report has been received within 24 hours.

- (g) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (d), (e), and (f) of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (f) of this section.

- (h) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

2. Signatory requirement. All applications, reports, or information submitted to the Department shall be signed and certified as required by Chapter 521, Section 5 of the Department's rules. State law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan or other document filed or required to be maintained by any order, rule, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

3. Availability of reports. Except for data determined to be confidential under A(9), above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. As required by State law, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal sanctions as provided by law.

4. Existing manufacturing, commercial, mining, and silvicultural dischargers. In addition to the reporting requirements under this Section, all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Department as soon as they know or have reason to believe:

- (a) That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

- (i) One hundred micrograms per liter (100 ug/l);

- (ii) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

- (iii) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or

- (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (b) That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
 - (i) Five hundred micrograms per liter (500 ug/l);
 - (ii) One milligram per liter (1 mg/l) for antimony;
 - (iii) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or
 - (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

5. Publicly owned treatment works.

- (a) All POTWs must provide adequate notice to the Department of the following:
 - (i) Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA or Chapter 528 if it were directly discharging those pollutants.
 - (ii) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - (iii) For purposes of this paragraph, adequate notice shall include information on (A) the quality and quantity of effluent introduced into the POTW, and (B) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (b) When the effluent discharged by a POTW for a period of three consecutive months exceeds 80 percent of the permitted flow, the permittee shall submit to the Department a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.

E. OTHER REQUIREMENTS

1. Emergency action - power failure. Within thirty days after the effective date of this permit, the permittee shall notify the Department of facilities and plans to be used in the event the primary source of power to its wastewater pumping and treatment facilities fails as follows.

- (a) For municipal sources. During power failure, all wastewaters which are normally treated shall receive a minimum of primary treatment and disinfection. Unless otherwise approved, alternate power supplies shall be provided for pumping stations and treatment facilities. Alternate power supplies shall be on-site generating units or an outside power source which is separate and independent from sources used for normal operation of the wastewater facilities.
- (b) For industrial and commercial sources. The permittee shall either maintain an alternative power source sufficient to operate the wastewater pumping and treatment facilities or halt, reduce or otherwise control production and or all discharges upon reduction or loss of power to the wastewater pumping or treatment facilities.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

2. Spill prevention. (applicable only to industrial sources) Within six months of the effective date of this permit, the permittee shall submit to the Department for review and approval, with or without conditions, a spill prevention plan. The plan shall delineate methods and measures to be taken to prevent and or contain any spills of pulp, chemicals, oils or other contaminants and shall specify means of disposal and or treatment to be used.

3. Removed substances. Solids, sludges trash rack cleanings, filter backwash, or other pollutants removed from or resulting from the treatment or control of waste waters shall be disposed of in a manner approved by the Department.

4. Connection to municipal sewer. (applicable only to industrial and commercial sources) All wastewaters designated by the Department as treatable in a municipal treatment system will be cosigned to that system when it is available. This permit will expire 90 days after the municipal treatment facility becomes available, unless this time is extended by the Department in writing.

F. DEFINITIONS. For the purposes of this permit, the following definitions shall apply. Other definitions applicable to this permit may be found in Chapters 520 through 529 of the Department's rules

Average means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For bacteria, the average shall be the geometric mean.

Average monthly discharge limitation means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. Except, however, bacteriological tests may be calculated as a geometric mean.

Average weekly discharge limitation means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best management practices ("BMPs") means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Composite sample means a sample consisting of a minimum of eight grab samples collected at equal intervals during a 24 hour period (or a lesser period as specified in the section on monitoring and reporting) and combined proportional to the flow over that same time period.

Continuous discharge means a discharge which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or other similar activities.

Daily discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the day.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

Discharge Monitoring Report ("DMR") means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by approved States as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA's.

Flow weighted composite sample means a composite sample consisting of a mixture of aliquots collected at a constant time interval, where the volume of each aliquot is proportional to the flow rate of the discharge.

Grab sample means an individual sample collected in a period of less than 15 minutes.

Interference means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Maximum daily discharge limitation means the highest allowable daily discharge.

New source means any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:

- (a) After promulgation of standards of performance under section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

Pass through means a discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

Permit means an authorization, license, or equivalent control document issued by EPA or an approved State to implement the requirements of 40 CFR parts 122, 123 and 124. Permit includes an NPDES general permit (Chapter 529). Permit does not include any permit which has not yet been the subject of final agency action, such as a draft permit or a proposed permit.

Person means an individual, firm, corporation, municipality, quasi-municipal corporation, state agency, federal agency or other legal entity.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

Point source means any discernible, confined and discrete conveyance, including, but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation or vessel or other floating craft, from which pollutants are or may be discharged.

Pollutant means dredged spoil, solid waste, junk, incinerator residue, sewage, refuse, effluent, garbage, sewage sludge, munitions, chemicals, biological or radiological materials, oil, petroleum products or byproducts, heat, wrecked or discarded equipment, rock, sand, dirt and industrial, municipal, domestic, commercial or agricultural wastes of any kind.

Process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

Publicly owned treatment works ("POTW") means any facility for the treatment of pollutants owned by the State or any political subdivision thereof, any municipality, district, quasi-municipal corporation or other public entity.

Septage means, for the purposes of this permit, any waste, refuse, effluent sludge or other material removed from a septic tank, cesspool, vault privy or similar source which concentrates wastes or to which chemicals have been added. Septage does not include wastes from a holding tank.

Time weighted composite means a composite sample consisting of a mixture of equal volume aliquots collected over a constant time interval.

Toxic pollutant includes any pollutant listed as toxic under section 307(a)(1) or, in the case of sludge use or disposal practices, any pollutant identified in regulations implementing section 405(d) of the CWA. Toxic pollutant also includes those substances or combination of substances, including disease causing agents, which after discharge or upon exposure, ingestion, inhalation or assimilation into any organism, including humans either directly through the environment or indirectly through ingestion through food chains, will, on the basis of information available to the board either alone or in combination with other substances already in the receiving waters or the discharge, cause death, disease, abnormalities, cancer, genetic mutations, physiological malfunctions, including malfunctions in reproduction, or physical deformations in such organism or their offspring.

Wetlands means those areas that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole effluent toxicity means the aggregate toxic effect of an effluent measured directly by a toxicity test.



DEP INFORMATION SHEET

Appealing a Commissioner's Licensing Decision

Dated: May 2004

Contact: (207) 287-2811

SUMMARY

There are two methods available to an aggrieved person seeking to appeal a licensing decision made by the Department of Environmental Protection's (DEP) Commissioner: (1) in an administrative process before the Board of Environmental Protection (Board); or (2) in a judicial process before Maine's Superior Court. This INFORMATION SHEET, in conjunction with consulting statutory and regulatory provisions referred to herein, can help aggrieved persons with understanding their rights and obligations in filing an administrative or judicial appeal.

I. ADMINISTRATIVE APPEALS TO THE BOARD

LEGAL REFERENCES

DEP's *General Laws*, 38 M.R.S.A. § 341-D(4), and its *Rules Concerning the Processing of Applications and Other Administrative Matters* (Chapter 2), 06-096 CMR 2.24 (April 1, 2003).

HOW LONG YOU HAVE TO SUBMIT AN APPEAL TO THE BOARD

The Board must receive a written notice of appeal within 30 calendar days of the date on which the Commissioner's decision was filed with the Board. Appeals filed after 30 calendar days will be rejected.

HOW TO SUBMIT AN APPEAL TO THE BOARD

Signed original appeal documents must be sent to: Chair, Board of Environmental Protection, c/o Department of Environmental Protection, 17 State House Station, Augusta, ME 04333-0017; faxes are acceptable for purposes of meeting the deadline when followed by receipt of mailed original documents within five (5) working days. Receipt on a particular day must be by 5:00 PM at DEP's offices in Augusta; materials received after 5:00 PM are not considered received until the following day. The person appealing a licensing decision must also send the DEP's Commissioner and the applicant a copy of the documents. All the information listed in the next section must be submitted at the time the appeal is filed. Only the extraordinary circumstances described at the end of that section will justify evidence not in the DEP's record at the time of decision being added to the record for consideration by the Board as part of an appeal.

WHAT YOUR APPEAL PAPERWORK MUST CONTAIN

The materials constituting an appeal must contain the following information at the time submitted:

1. *Aggrieved Status.* Standing to maintain an appeal requires the appellant to show they are particularly injured by the Commissioner's decision.
2. *The findings, conclusions or conditions objected to or believed to be in error.* Specific references and facts regarding the appellant's issues with the decision must be provided in the notice of appeal.
3. *The basis of the objections or challenge.* If possible, specific regulations, statutes or other facts should be referenced. This may include citing omissions of relevant requirements, and errors believed to have been made in interpretations, conclusions, and relevant requirements.
4. *The remedy sought.* This can range from reversal of the Commissioner's decision on the license or permit to changes in specific permit conditions.

5. *All the matters to be contested.* The Board will limit its consideration to those arguments specifically raised in the written notice of appeal.
6. *Request for hearing.* The Board will hear presentations on appeals at its regularly scheduled meetings, unless a public hearing is requested and granted. A request for public hearing on an appeal must be filed as part of the notice of appeal.
7. *New or additional evidence to be offered.* The Board may allow new or additional evidence as part of an appeal only when the person seeking to add information to the record can show due diligence in bringing the evidence to the DEP's attention at the earliest possible time in the licensing process or show that the evidence itself is newly discovered and could not have been presented earlier in the process. Specific requirements for additional evidence are found in Chapter 2, Section 24(B)(5).

OTHER CONSIDERATIONS IN APPEALING A DECISION TO THE BOARD

1. *Be familiar with all relevant material in the DEP record.* A license file is public information made easily accessible by DEP. Upon request, the DEP will make the material available during normal working hours, provide space to review the file, and provide opportunity for photocopying materials. There is a charge for copies or copying services.
2. *Be familiar with the regulations and laws under which the application was processed, and the procedural rules governing your appeal.* DEP staff will provide this information on request and answer questions regarding applicable requirements.
3. *The filing of an appeal does not operate as a stay to any decision.* An applicant proceeding with a project pending the outcome of an appeal runs the risk of the decision being reversed or modified as a result of the appeal.

WHAT TO EXPECT ONCE YOU FILE A TIMELY APPEAL WITH THE BOARD

The Board will formally acknowledge initiation of the appeals procedure, including the name of the DEP project manager assigned to the specific appeal, within 15 days of receiving a timely filing. The notice of appeal, all materials accepted by the Board Chair as additional evidence, and any materials submitted in response to the appeal will be sent to Board members along with a briefing and recommendation from DEP staff. Parties filing appeals and interested persons are notified in advance of the final date set for Board consideration of an appeal or request for public hearing. With or without holding a public hearing, the Board may affirm, amend, or reverse a Commissioner decision. The Board will notify parties to an appeal and interested persons of its decision.

II. APPEALS TO MAINE SUPERIOR COURT

Maine law allows aggrieved persons to appeal final Commissioner licensing decisions to Maine's Superior Court, see 38 M.R.S.A. § 346(1); 06-096 CMR 2.26; 5 M.R.S.A. § 11001; & MRCivP 80C. Parties to the licensing decision must file a petition for review within 30 days after receipt of notice of the Commissioner's written decision. A petition for review by any other person aggrieved must be filed within 40-days from the date the written decision is rendered. The laws cited in this paragraph and other legal procedures govern the contents and processing of a Superior Court appeal.

ADDITIONAL INFORMATION

If you have questions or need additional information on the appeal process, contact the DEP's Director of Procedures and Enforcement at (207) 287-2811.

Note: The DEP provides this INFORMATION SHEET for general guidance only; it is not intended for use as a legal reference. Maine law governs an appellant's rights.
