



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION

PAUL R. LEPAGE
GOVERNOR

JAMES P. BROOKS
ACTING COMMISSIONER

May 23, 2011

VIA ELECTRONIC MAIL

Mr. Gary Stetson
City of Old Town Pollution Control
150 Brunswick Street
Old Town, Maine 04468-1497
garvstetson@myfairpoint.net

RE: Maine Pollutant Discharge Elimination System (MEPDES) Permit #ME01000471
Maine Waste Discharge License (WDL) Application #W001635-6D-D-M
Final Permit/License – Old Town Pollution Control

Dear Mr. Stetson:

Enclosed please find a copy of your **final** Maine MEPDES Permit/WDL which was approved by the Department of Environmental Protection. Please read the license and its attached conditions carefully. You must follow the conditions in the license to satisfy the requirements of law. Any discharge not receiving adequate treatment is in violation of State law and is subject to enforcement action.

Any interested person aggrieved by a Department determination made pursuant to applicable regulations, may appeal the decision following the procedures described in the attached DEP FACT SHEET entitled “*Appealing a Commissioner’s Licensing Decision.*”

If you have any questions regarding this matter, please feel free to contact me at (207) 287-7658 or at phyllis.a.rand@maine.gov.

Sincerely,

Phyllis Arnold Rand
Division of Water Quality Management
Bureau of Land and Water Quality

Enclosure

Stakeholder Service List
Frank S. Kearney, Sr., Old Town Water District, frank.otwater@roadrunner.com
Sandy Mojica, USEPA

AUGUSTA
17 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0017
(207) 287-7688 FAX: (207) 287-7826
RAY BLDG., HOSPITAL ST.

BANGOR
106 HOGAN ROAD, SUITE 6
BANGOR, MAINE 04401
(207) 941-4570 FAX: (207) 941-4584

PORTLAND
312 CANCO ROAD
PORTLAND, MAINE 04103
(207) 822-6300 FAX: (207) 822-6303

PRESQUE ISLE
1235 CENTRAL DRIVE, SKYWAY PARK
PRESQUE ISLE, MAINE 04769-2094
(207) 764-0477 FAX: (207)760-3143

- 3/31/11

Distribution List Name: Penobscot River Stakeholders

Members:

Adria Elskus	aelskus@usgs.gov
Alan Boynton	sabaocat@adelphia.net
Angie Reed	Angie.Reed@penobscotnation.org
Barbara Arter	bsarter@panax.com
Bernier, Kevin	kevin.bernier@brookfieldpower.com
Bill Taylor	wtaylor@pierceatwood.com
Bradley Moore	brad.moore@bangormaine.gov
Bruce Albert	albertbp@katahdinpaper.com
Cintya Baily	Cintya.Bailey@versopaper.com
Courtemanch, Dave L	Dave.L.Courtemanch@maine.gov
Dan Kusnierz	Dan.Kusnierz@penobscotnation.org
Darold Wooley	Lincolnsanitarydistrict@myfairpoint.net
David Mitchell	dmitchell@ensr.aecom.com.
David Van Slyke	dvanslyke@preti.com
Dennis McComb	dmccomb@lpandt.com
Dick Arnold	dick.arnold@redshieldenv.com
Frank Ruksznis	fprgssd@myfairpoint.net
Gary Brooks	gbrooks@veaziesewerdistrict.com
Gary Stetson	garystetson@myfairpoint.net
Hovell, Tanya	Tanya.Hovell@maine.gov
Jan Paul	Jan.Paul@penobscotnation.org
Jennie Bridge	bridge.jennie@epa.gov
Jim Charett	wastewater@millinocket.org
Joseph Madigan	jmadigan@adelphia.net
Kavanah, Brian W	Brian.W.Kavanah@maine.gov
Ken Gallant	kenneth.gallant@versopaper.com
Kenneth Locke	klocke@brewerme.org
Kristie Rabasca	klr@smemaine.com
Leo Robichaud	burobichaud@myfairpoint.net
Logue, Edward	Edward.Logue@Maine.gov
Lou Colburn	lcolburn@brewerme.org
Michael Stover	stover.michael@epa.gov
Mohlar, Robert C	Robert.C.Mohlar@maine.gov
Mower, Barry F	Barry.F.Mower@maine.gov
Murch, Dana P	Dana.P.Murch@maine.gov
Newkirk, Peter	Peter.Newkirk@maine.gov
Nick Bennett	nbennett@nrcm.org
Paul Wintle	paulw@Orono.org
Peter Shanahan	pshanahan@hydroanalysisinc.com
Rand, Phyllis A	Phyllis.A.Rand@maine.gov
Scott Hall	shall@pplweb.com
Tom Bouchard	bouchard@midmaine.com
Trasko, Clarissa	Clarissa.Trasko@maine.gov
Tsomides, Leon	Leon.Tsomides@maine.gov
Wood, Gregg	Gregg.Wood@maine.gov
Young, Matthew R	Matthew.R.Young@maine.gov



STATE OF MAINE
DEPARTMENT OF ENVIRONMENTAL PROTECTION
17 STATE HOUSE STATION
AUGUSTA, ME 04333

DEPARTMENT ORDER

IN THE MATTER OF

CITY OF OLD TOWN) MAINE POLLUTANT DISCHARGE
PUBLICLY OWNED TREATMENT WORKS) ELIMINATION SYSTEM PERMIT
OLD TOWN, PENOBSCOT COUNTY, MAINE) AND
ME0100471) WASTE DISCHARGE LICENSE
W001635-6D-D-R) **APPROVAL**) **RENEWAL**

Pursuant to the provisions of the Federal Water Pollution Control Act, Title 33 USC, Section 1251, et seq. and *Conditions of Licenses*, 38 M.R.S.A. Section 414-A, et seq., and applicable regulations, the Department of Environmental Protection ("Department," hereinafter) has considered the application of the CITY OF OLD TOWN ("permittee," hereinafter) with its supportive data, agency review comments, and other related material on file and finds the following facts:

APPLICATION SUMMARY

Application: The permittee has applied to the Department for renewal of combination Department Waste Discharge License (WDL) #W001635-5L-C-R/MEPDES permit #ME0100471 which was issued on May 25, 2004 and expired on May 25, 2009. The 5/25/04 WDL authorized the discharge of up to a monthly average flow of 3.50 million gallons per day (MGD) of secondary treated sanitary waste water to the Penobscot River, Class B, in Old Town, Maine. The 5/25/04 WDL also authorized the discharge of an unspecified quantity of untreated combined sanitary and storm water from three (3) combined sewer overflow (CSO) outfalls. Two CSOs discharge to the Penobscot River, Class B, and one CSO discharges to the Stillwater River, Class C.

PERMIT SUMMARY

This permitting action is similar to the 5/25/04 permitting action in that it is;

Secondary Treated Waste Water:

1. Carrying forward the monthly average, weekly average and daily maximum technology based concentration limits for biochemical oxygen demand (BOD₅) and total suspended solids (TSS).

PERMIT SUMMARY (cont'd)

Secondary Treated Waste Water:

2. Carrying forward the monthly average and weekly average technology based mass limitations for BOD₅ and TSS based on the previous monthly average flow limitation of 1.70 MGD due to potential non-attainment of dissolved oxygen standards in the Penobscot River below the permittee's waste water treatment facility. These limits are applicable June 1 – September 30 of each year.
3. Carrying forward the reporting requirement for the daily maximum mass loadings for BOD₅ and TSS.
4. Carrying forward the daily maximum technology based concentration limit for settleable solids.
5. Carrying forward the seasonal (May 15 – September 30) monthly average and daily maximum water quality based concentration limits for *E. coli* bacteria.
6. Carrying forward the daily maximum technology based concentration limit for total residual chlorine.
7. Carrying forward the screening level whole effluent toxicity (WET) and analytical chemistry testing requirements per *Surface Waters Toxics Control Program*, 06-096 CMR 530.
8. Requiring the permittee to periodically update the Operation and Maintenance (O&M) Plan and Wet Weather Management Plan for the waste water treatment facility and pump stations.

Primary Treated Waste Water:

9. Carrying forward the daily maximum water quality based limit for *E. coli* bacteria and a daily maximum technology based limit for total residual chlorine.
10. Carrying forward the monthly average and or daily maximum reporting requirements for flow, surface overflow rates, number of discharge days per month and percent removal for BOD₅ and TSS.

This permitting action is different from the 5/25/04 permitting action in that it is;

Secondary Treated Waste Water:

11. Establishing a reporting requirement for priority pollutant testing per 06-096 CMR 525.
12. Reducing settleable solids monitoring frequency from 5/Week to 3/Week based on Department BPJ.
13. Revising the seasonal (June 1 – September 30) monitoring requirements for total phosphorus based on Department BPJ.

PERMIT SUMMARY (cont'd)

Secondary Treated Waste Water:

14. Establishing monthly average water quality based mass and concentration limits for total aluminum, total copper and total lead.
15. Establishing daily maximum water quality based mass and concentration limits for total copper.
16. Revising the acute dilution factor to a modified acute dilution factor based on new information.

CONCLUSIONS

BASED on the findings in the attached Fact Sheet dated May 19, 2011, and subject to the Conditions listed below, the Department makes the following CONCLUSIONS:

Secondary and CSO Related Bypasses of Secondary Treatment

1. The discharge, either by itself or in combination with other discharges, will not lower the quality of any classified body of water below such classification.
2. The discharge, either by itself or in combination with other discharges, will not lower the quality of any unclassified body of water below the classification which the Department expects to adopt in accordance with state law.
3. The provisions of the State's antidegradation policy, 38 MRSA Section 464(4)(F), will be met, in that:
 - a. Existing in-stream water uses and the level of water quality necessary to protect and maintain those existing uses will be maintained and protected;
 - b. Where high quality waters of the State constitute an outstanding national resource, that water quality will be maintained and protected;
 - c. The standards of classification of the receiving water body are met or, where the standards of classification of the receiving water body are not met, the discharge will not cause or contribute to the failure of the water body to meet the standards of classification;
 - d. Where the actual quality of any classified receiving water body exceeds the minimum standards of the next highest classification, that higher water quality will be maintained and protected; and
 - e. Where a discharge will result in lowering the existing quality of any water body, the Department has made the finding, following opportunity for public participation, that this action is necessary to achieve important economic or social benefits to the State.
4. The discharges (including the three CSOs) will be subject to effluent limitations that require application of best practicable treatment.

ACTION

THEREFORE, the Department APPROVES the application of the CITY OF OLD TOWN to discharge up to a monthly average flow of 3.50 million gallons per day (MGD) of secondary treated sanitary waste water and an unspecified quantity of excess combined sanitary and storm water receiving primary treatment only from a municipal waste water treatment facility and untreated combined sanitary and storm water from three (3) combined sewer overflow (CSO) outfalls to the Penobscot River, Class B, and Stillwater River, Class C, in Old Town, Maine. The discharges shall be subject to the attached conditions and all applicable standards and regulations including:

1. *“Maine Pollutant Discharge Elimination System Permit Standard Conditions Applicable To All Permits,”* revised July 1, 2002, copy attached.
2. The attached Special Conditions, including any effluent limitations and monitoring requirements.
3. This permit and the authorization to discharge become effective upon the date of signature below and expire at midnight five (5) years from the effective date. If a renewal application is timely submitted and accepted as complete for processing prior to the expiration of this permit, the authorization to discharge and the terms and conditions of this permit and all modifications and minor revisions thereto remain in effect until a final Department decision on the renewal application becomes effective. [*Maine Administrative Procedure Act, 5 M.R.S.A. § 10002 and Rules Concerning the Processing of Applications and Other Administrative Matters, 06-096 CMR 2(21)(A)* (effective April 1, 2003)]

PLEASE NOTE ATTACHED SHEET FOR GUIDANCE ON APPEAL PROCEDURES

Date of initial receipt of application: May 13, 2009

Date of application acceptance: May 15, 2009

This Order prepared by PHYLLIS ARNOLD RAND, BUREAU OF LAND & WATER QUALITY

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

1. Beginning the effective date of the permit, the permittee is authorized to discharge secondary treated waste water to the Penobscot River. Such treated waste water discharges shall be limited and monitored by the permittee as specified below.

SECONDARY TREATED WASTE WATER - OUTFALL #001A⁽¹⁾

Effluent Characteristic	Discharge Limitations						Minimum Monitoring Requirements	
	Monthly Average as specified	Weekly Average as specified	Daily Maximum as specified	Monthly Average as specified	Weekly Average as specified	Daily Maximum as specified	Measurement Frequency as specified	Sample Type as specified
Flow ^[50050]	3.50 MGD ^[03]	---	Report (MGD)	---	---	---	Continuous ^[99/99]	Recorder ^[RC]
Biochemical Oxygen Demand (BOD ₅) ^[00310] (June 1 – September 30) (October 1 – May 31)	425 lbs/Day 875 lbs/Day ^[26]	638 lbs/Day 1,314 lbs/Day ^[26]	Report lbs/Day Report lbs/Day ^[26]	30 mg/L 30 mg/L ^[19]	45 mg/L 45 mg/L ^[19]	50 mg/L 50 mg/L ^[19]	3/Week 3/Week ^[03/07]	Composite Composite ^[24]
BOD ₅ % Removal ⁽²⁾ ^[81010]	---	---	---	85% ^[23]	---	---	1/Month ^[01/30]	Calculate ^[CA]
Total Suspended Solids (TSS) ^[00530] (June 1 – September 30) (October 1 – May 31)	425 lbs/Day 875 lbs/Day ^[26]	638 lbs/Day 1,314 lbs/Day ^[26]	Report lbs/Day Report lbs/Day ^[26]	30 mg/L 30 mg/L ^[19]	45 mg/L 45 mg/L ^[19]	50 mg/L 50 mg/L ^[19]	3/Week 3/Week ^[03/07]	Composite Composite ^[24]
TSS % Removal ⁽²⁾ ^[81011]	---	---	---	85% ^[23]	---	---	1/Month ^[01/30]	Calculate ^[CA]
Settleable Solids ^[00545]	---	---	---	---	---	0.3 ml/L ^[25]	3/Week ^[05/07]	Grab ^[GR]
<i>E. coli</i> Bacteria ⁽³⁾ ^[31633] (May 15 – September 30)	---	---	---	64/100 ml ⁽⁴⁾ ^[13]	---	427/100 ml ^[13]	1/Week ^[01/07]	Grab ^[GR]
pH (Std. Units) ^[00400]	---	---	---	---	---	6.0-9.0 ^[12]	5/Week ^[05/07]	Grab ^[GR]

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

SECONDARY TREATED WASTE WATER - OUTFALL #001A⁽¹⁾

Effluent Characteristic	Discharge Limitations						Minimum Monitoring Requirements	
	<u>Monthly Average</u> as specified	<u>Weekly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Monthly Average</u> as specified	<u>Weekly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Measurement Frequency</u> as specified	<u>Sample Type</u> as specified
Total Residual Chlorine <i>[50060]</i>	---	---	---	---	---	1.0 mg/L <i>[19]</i>	1/Day ⁽⁵⁾ <i>[01/01]</i>	Grab <i>[GR]</i>
<u>Total Phosphorus</u> ⁽¹⁵⁾ <i>[00665]</i> <i>(June 1 – September 30)</i>	Report lbs/Day <i>[26]</i>	Report lbs/Day <i>[26]</i>	Report lbs/Day <i>[26]</i>	Report mg/L <i>[19]</i>	Report mg/L <i>[19]</i>	Report mg/L <i>[19]</i>	2/Month <i>[02/30]</i>	Composite <i>[24]</i>
Aluminum (Total) <i>[01105]</i>	9.2 lbs/day <i>[26]</i>	---	---	640 ug/L <i>[28]</i>	---	---	1/Year <i>[01/YR]</i>	Composite <i>[24]</i>
Copper (Total) <i>[01042]</i>	2.3 lbs/day <i>[26]</i>	---	2.7 lbs/day <i>[26]</i>	158 ug/L <i>[28]</i>	---	184 ug/L <i>[28]</i>	1/Year <i>[01/YR]</i>	Composite <i>[24]</i>
Lead (Total) <i>[01051]</i>	0.08 lbs/day <i>[26]</i>	---	---	5 ug/L <i>[28]</i>	---	---	1/Year <i>[01/YR]</i>	Composite <i>[24]</i>

The italicized bracketed numeric values in the table above and tables that follow are not limitations but are code numbers used by Department personnel to code the Discharge Monitoring Reports (DMR).

FOOTNOTES: See pages 10 – 15 of this permit for applicable footnotes.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) – OUTFALL #001A⁽¹⁾

2. SCREENING LEVEL - Beginning 12 months prior to permit expiration and every five years thereafter.

Effluent Characteristic	Discharge Limitations				Minimum Monitoring Requirements	
	Monthly Average	Daily Maximum	Monthly Average	Daily Maximum	Measurement Frequency	Sample Type
<u>Whole Effluent Toxicity⁽⁶⁾</u>						
<u>Acute – NOEL</u>						
<i>Ceriodaphnia dubia</i> (Water flea) [TDA3B]	---	---	---	Report % [23]	1/Year [01/YR]	Composite [24]
<i>Salvelinus fontinalis</i> (Brook trout) [TDA6F]	---	---	---	Report % [23]	1/Year [01/YR]	Composite [24]
<u>Chronic – NOEL</u>						
<i>Ceriodaphnia dubia</i> (Water flea) [TBP3B]	---	---	---	Report % [23]	1/Year [01/YR]	Composite [24]
<i>Salvelinus fontinalis</i> (Brook trout) [TBQ6F]	---	---	---	Report % [23]	1/Year [01/YR]	Composite [24]
Analytical chemistry ^(7,8) [51477]	---	---	---	Report ug/L [28]	1/Quarter [01/90]	Composite/Grab [24]
Priority Pollutants ⁽⁸⁾ [50008]	---	---	---	Report ug/L [28]	1/Year [01/YR]	Composite/Grab [24]

The italicized bracketed numeric values in the table above and tables that follow are not limitations but are code numbers used by Department personnel to code the Discharge Monitoring Reports (DMR).

FOOTNOTES: See pages 10 – 15 of this permit for applicable footnotes.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd) – OUTFALL #002A⁽¹⁾

3. Beginning the effective date of this permit, the permittee is authorized to bypass secondary treatment. Such CSO related bypasses of secondary treatment discharges⁽⁹⁾ may only occur in response to wet weather events when the influent to the waste water treatment facility exceeds a peak hourly flow rate of 3,260 gallons per minute (4.7 MGD) or in accordance with the most current approved Wet Weather Flow Management Plan. Approval of said bypass will be reviewed and may be modified or terminated pursuant to Special Condition O, *Reopening of Permit For Modification*, if there is a substantial change in the volume or character of pollutants in the collection/treatment system, if new information regarding CSO management becomes available or if necessary for implementation of an approved CSO Master Plan. Bypasses shall be monitored and reported as specified below.

PRIMARY TREATED WASTE WATER - OUTFALL #002A

FOOTNOTES: See pages 10 – 15 of this permit for applicable footnotes.

<u>Effluent Characteristic</u>	<u>Discharge Limitations</u>				<u>Monitoring Requirements</u>	
	<u>Monthly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Monthly Average</u> as specified	<u>Daily Maximum</u> as specified	<u>Measurement Frequency</u> as specified	<u>Sample Type</u> as specified
Flow, MGD <small>[50050]</small>	Report (Total MGD) <small>[03]</small>	Report (MGD) <small>[03]</small>	---	---	Continuous ^[99/99]	Recorder _[RC]
Surface Loading Rate ⁽¹⁰⁾ <small>[50997]</small>	---	Report (gpd/sf) <small>[07]</small>	---	---	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Calculate _[CA]
Overflow Use, Occurrences ⁽¹²⁾ <small>[74062]</small>	---	---	Report (# of days) <small>[93]</small>	---	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Record Total _[RT]
BOD5 <small>[00310]</small>	---	---	---	Report mg/L <small>[19]</small>	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Composite _[24]
BOD5 % Removal ⁽¹³⁾ <small>[81010]</small>	---	---	Report (%) _[23]	---	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Calculate _[CA]
TSS <small>[00530]</small>	---	---	---	Report mg/L <small>[19]</small>	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Composite _[24]
TSS % Removal ⁽¹³⁾ <small>[81011]</small>	---	---	Report (%) _[23]	---	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Calculate _[CA]
<i>E. coli</i> Bacteria ^(3, 14) <small>[31633]</small> (May 15 – September 30)	---	---	---	427/100 ml <small>[13]</small>	1/Discharge Day ⁽¹¹⁾ <small>[01/DS]</small>	Grab _[GR]
Total Residual Chlorine ⁽¹⁴⁾ <small>[50060]</small>	---	---	--	1.0 mg/L <small>[19]</small>	1/Discharge Day ^(5,11) <small>[01/DS]</small>	Grab _[GR]

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

1. **Sampling Locations:**

Influent sampling for flow, BOD₅ and TSS for both primary and secondary treated waste water shall be sampled after screening and grit removal.

Effluent receiving secondary treatment (Outfall #001A) shall be sampled for all parameters after the chlorine contact chamber on a year-round basis. Sampling of the secondary effluent shall be conducted prior to combining with the primary treated effluent during a bypass event.

Effluent receiving primary treatment (Outfall #002A) shall be sampled (composite and grab samples) after primary clarification but before combining with the secondary treated effluent.

Any change in sampling location(s) other than those specified above must be reviewed and approved by the Department in writing.

Sampling –Sampling and analysis must be conducted in accordance with; a) methods approved in Title 40 *Code of Federal Regulations* (40 CFR) Part 136, b) alternative methods approved by the Department in accordance with the procedures in 40 CFR Part 136, or c) as otherwise specified by the Department. Samples that are sent out for analysis shall be analyzed by a laboratory certified by the State of Maine's Department of Human Services. Samples that are sent to another POTW licensed pursuant to *Waste discharge licenses*, 38 M.R.S.A. § 413 are subject to the provisions and restrictions of *Maine Comprehensive and Limited Environmental Laboratory Certification Rules*, 10-144 CMR 263 (last amended February 13, 2000).

All analytical test results shall be reported to the Department including results which are detected below the respective reporting limits (RLs) specified by the Department or as specified by other approved test methods. See **Attachment A** of this permit for a list of the Department's RLs. If a non-detect analytical test result is below the respective RL, the concentration result shall be reported as <Y where Y is the RL achieved by the laboratory for each respective parameter. Reporting a value of <Y that is greater than an established RL or reporting an estimated value ("J" flagged) is not acceptable and will be rejected by the Department. Reporting analytical data and its use in calculations must follow established Department guidelines specified in this permit or in available Department guidance documents.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

2. **Percent removal** - The treatment facility shall maintain a minimum of 85 percent removal of both BOD₅ and TSS for waste water receiving a secondary level of treatment. The percent removal shall be based on a monthly average calculation using influent and effluent concentrations. The percent removal shall be waived when the monthly average influent concentration is less than 200 mg/L. For instances when this occurs, the facility shall report “*NODI-9*” on the monthly Discharge Monitoring Report. Influent and effluent values collected during bypass conditions shall not be used in calculating the BOD₅ and TSS percent removal rates.
3. ***E. coli* bacteria** - Limits are seasonal and apply between May 15 and September 30 of each calendar year.
4. ***E. coli* bacteria** – The monthly average limitation is a **geometric mean** limitation and shall be calculated and reported as such.
5. **Total Residual Chlorine (TRC)** – TRC limits and monitoring requirements are applicable whenever elemental chlorine or chlorine-based compounds are being used to disinfect the discharge. TRC shall be tested using an EPA-approved method that is capable of bracketing the TRC concentration limitations in this permit. The Department reserves the right to require disinfection on a year-round basis to protect the health and welfare of the public.
6. **Whole effluent toxicity (WET) testing** - Definitive WET testing is a multi-concentration testing event (a minimum of five dilutions bracketing the critical modified acute and chronic dilution of 0.86% and 0.19% respectively), which provides a point estimate of toxicity in terms of No Observed Effect Level, commonly referred to as NOEL or NOEC. A-NOEL is defined as the acute no observed effect level with survival as the end point. C-NOEL is defined as the chronic no observed effect level with survival, reproduction and growth as the end points.
 - a. **Screening level testing** – Beginning twelve months prior to the expiration date of this permit and every five years thereafter, the permittee shall initiate screening level WET tests at a frequency of once per year. Testing shall be conducted on the water flea (*Ceriodaphnia dubia*) and the brook trout (*Salvelinus fontinalis*).
 - b. **Surveillance level testing** - Surveillance level WET testing has been waived pursuant to 06-096 CMR 530(2)(D)(3)(b).

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

Test results must be submitted to the Department no later than the next DMR required by the permit, provided, however, the permittee may review the toxicity reports for up to 10 business days after receiving the test results from the laboratory conducting the testing before submitting them. The permittee shall evaluate test results being submitted and identify to the Department possible exceedences of the modified critical acute and chronic water quality thresholds of 0.86% and 0.19%, respectively. See **Attachment B** of this permit for a copy of the Department's WET report form.

Toxicity tests must be conducted by an experienced laboratory approved by the Department. The laboratory must follow procedures as described in the following USEPA. methods manuals:

- a. Short Term Methods for Estimating the Chronic Toxicity of Effluent and Receiving Water to Freshwater Organisms, 4th Edition, October 2002, EPA-821-R-02-013.
- b. Methods for Measuring the Acute Toxicity of Effluent and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, 3rd Edition, October 2002, EPA-821-R-02-012.

The permittee is also required to analyze the effluent for the parameters specified in the WET chemistry section, and the parameters specified in the analytical chemistry section of the form in **Attachment A** of this permit each time a WET test is performed.

7. **Analytical Chemistry** – Refers to a suite of chemical tests listed in **Attachment A** of this permit.
 - a. **Screening level testing** – Beginning twelve months prior to the expiration date of this permit and every five years thereafter, the permittee shall conduct screening level analytical chemistry testing once per quarter (1/Quarter) for four consecutive calendar quarters
 - b. **Surveillance level testing** – With the exception of total copper, total lead and total aluminum, surveillance level analytical testing has been waived pursuant to 06-096 CMR 530 (D)(3)(b).

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

8. **Priority Pollutant Testing** – Priority pollutant testing refers to analysis for levels of priority pollutants listed in 06-096 CMR 525 Section 4.VI.
 - a. **Screening level testing** – Beginning twelve months prior to the expiration date of this permit and every five years thereafter, the permittee shall conduct screening level priority pollutant testing at a minimum frequency of once per year.
 - b. **Surveillance level testing** – Surveillance-level priority pollutant testing is not required pursuant 06-096 CMR 530 (2)(D).

Analytical chemistry and priority pollutant testing shall be conducted on samples collected at the same time as those collected for whole effluent toxicity tests, when applicable, and shall be conducted using methods that permit detection of a pollutant at existing levels in the effluent or that achieve the most current minimum reporting levels of detection as specified by the Department. See **Attachment A** of this permit for a list of the Department's most current reporting limits (RLs).

Analytical chemistry and priority pollutant test results must be submitted to the Department not later than the next Discharge Monitoring Report (DMR) required by the permit, provided, however, that the permittee may review the laboratory reports for up to 10 business days after receiving the test results from the laboratory conducting the testing before submitting them. The permittee shall evaluate test results being submitted and identify to the Department, possible exceedences of the acute, chronic or human health AWQC as established in *Surface Water Quality Criteria for Toxic Pollutants*, 06-096 CMR 584. For the purposes of DMR reporting, enter a "1" for yes, testing done this monitoring period or "NODI-9" monitoring not required this period.

9. **CSO-Related Bypasses of Secondary Treatment** – For the purposes of this permitting action, this term refers to structures and or processes at the waste water treatment facility that provide equivalent to primary treatment and disinfection of waste water that bypasses the biological treatment portion of the facility in an effort to mitigate the discharge of untreated combined sanitary waste water and storm water from the three CSOs listed in Special Condition K of this permit.
10. **Surface Loading Rate** – For the purposes of this permitting action is the average hourly rate per overflow occurrence in a discharge day. The permittee should provide this information to establish data on the effectiveness of peak flows receiving primary treatment only.
11. **Discharge Day** – A discharge day is defined as a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling.

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

12. **Overflow occurrence** – An overflow occurrence is defined as the period of time between initiation of flow from the primary bypass and cessation of the discharge from the primary bypass. Overflow occurrences are reported in discharge days.

Multiple intermittent overflow occurrences in one discharge day are reported as one overflow occurrence and are sampled according to the measurement frequency specified. One composite sample for BOD₅ and total suspended solids shall be collected per discharge day and shall be flow-proportioned from each intermittent overflow during that 24-hour period. Only one grab sample for *E. coli* bacteria and total residual chlorine is required to be collected per discharge day.

For overflow occurrences exceeding one day in duration, sampling shall be performed each day of the event according to the measurement frequency specified. For example, if an overflow occurs for all or part of three discharge days, the permittee shall take three composite samples for BOD₅ and TSS, initiating sampling at the start of the overflow and each subsequent discharge day thereafter and terminating sampling at the end of the discharge day or the end of the overflow occurrence. Samples shall be flow-proportioned.

13. **BOD₅ and TSS Removal** - The permittee shall analyze both the influent and effluent of the primary clarifiers for BOD₅ and TSS during the discharge of treated excess combined sewer waste water from Outfall #002A and report the percent (%) removal on the monthly Discharge Monitoring Report (DMR). Composite samples for BOD₅ and TSS are not required to be collected when Outfall #002A (CSO-related bypass of secondary treatment) is active for a single continuous discharge event lasting less than 60 minutes or during intermittent discharge events over a course of the 24-hour reporting period lasting less than 120 minutes. As an attachment to the DMR, the permittee shall report the individual BOD₅ and TSS test results used to calculate the percent removal rates reported. For the purpose of calculating BOD₅ and TSS percent (%) removals on the treated excess combined sewer waste water, the influent sample shall only be collected during overflow occurrences.

For facilities whose normal staffing hours do not include weekends, or whose weekend staffing time is limited to minimum facility oversight (i.e. permit-required daily grab sample analysis, setting up composite samplers, or performing routine observations of treatment plant functions), Outfall #002A BOD₅ /Total Suspended Solids composite samples collected after one hour before the end of normal staffing hours on Friday through 22 hours before normal staffing time on Monday may be held beyond the maximum holding time of twenty-four hours and analyzed as soon as possible during staffed hours on the Monday following the weekend. Composite samples with extended holding times must remain refrigerated until analyzed, and must conform to any other bypass sampling procedures as defined in this document. Any reported extended holding

SPECIAL CONDITIONS

A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Footnotes:

time composite sample results must be flagged to distinguish them from samples that were analyzed within the proper holding time.

14. **Grab Sample** – Grab samples for *E. coli* bacteria and total residual chlorine are not required when Outfall #002A is active outside of the normal wastewater treatment facility staffing hours or if during normal staffing hours for a single continuous discharge event lasting less than 60 minutes or during intermittent discharge events over a course of a 24-hour period lasting less than 120 minutes.
15. **Total Phosphorus** – There shall be at least ten (10) days between sampling events. See **Attachment C** of this permit for a Department protocol for total phosphorus.

B. NARRATIVE EFFLUENT LIMITATIONS

1. The effluent shall not contain a visible oil sheen, foam or floating solids at any time which would impair the usages designated by the classification of the receiving waters.
2. The effluent shall not contain materials in concentrations or combinations which are hazardous or toxic to aquatic life, or which would impair the usages designated by the classification of the receiving waters.
3. The discharges shall not cause visible discoloration or turbidity in the receiving waters which would impair the usages designated by the classification of the receiving waters.
4. Notwithstanding specific conditions of this permit the effluent must not lower the quality of any classified body of water below such classification, or lower the existing quality of any body of water if the existing quality is higher than the classification.

C. TREATMENT PLANT OPERATOR

The person who has the management responsibility over the wastewater treatment facility must hold a **Maine Grade IV** certificate, or a Maine Professional Engineer's license pursuant to *Sewerage Treatment Operators*, Title 32 M.R.S.A., Sections 4171 to 4182 and *Regulations for Wastewater Operator Certification*, 06-096 CMR 531 (effective May 8, 2006). All proposed contracts for facility operation by any person must be approved by the Department within two weeks of the contractor being retained by the licensee.

D. LIMITATIONS FOR INDUSTRIAL USERS

Pollutants introduced into the waste water collection and treatment system by a non-domestic source ("user") shall not pass through or interfere with the operation of the treatment system.

SPECIAL CONDITIONS

E. UNAUTHORIZED DISCHARGES

The permittee is authorized to discharge only in accordance with: 1) the permittee's General Application for Waste Discharge Permit accepted for processing on 5/15/09; 2) the terms and conditions of this permit; and 3) only from Outfalls #001A and #002A and the three (3) CSOs listed in Special Condition K, *Combined Sewer Overflows (CSOs)* of this permit. Discharges of waste water from any other point source are not authorized under this permit, and shall be reported in accordance with Standard Condition B(5)(Bypass) of this permit.

F. NOTIFICATION REQUIREMENT

In accordance with Standard Condition D, the permittee shall notify the Department of the following:

1. Any introduction of pollutants into the waste water collection and treatment system from an indirect discharger in a primary industrial category discharging process waste water; and,
2. Any substantial change in the volume or character of pollutants being introduced into the waste water collection and treatment system by a source introducing pollutants into the system at the time of permit issuance. For the purposes of this section, notice regarding substantial change shall include information on:
 - (a) the quality and quantity of waste water introduced to the waste water collection and treatment system; and
 - (b) any anticipated impact caused by the change in the quantity or quality of the waste water to be discharged from the treatment system.

G. WET WEATHER FLOW MANAGEMENT PLAN

On or before December 31, 2011 [PCS Code 96099], the treatment facility staff shall revise and maintain a Wet Weather Management Plan to direct the staff on how to operate the facility effectively during periods of high flow. The staff shall maintain a record that the plan has been reviewed annually and the changes documented, even if no changes have been made to the plan.

Within 90 days of completion of new and/or substantial upgrades of the waste water treatment facility, the permittee shall submit to the Department for review and approval, a new or revised Wet Weather Flow Management Plan which conforms to Department guidelines for such plans. The staff shall maintain a record that the plan has been reviewed annually and the changes documented, even if no changes have been made to the plan. The revised plan shall include operating procedures for a range of intensities, address solids handling procedures (including septic tank wastes and other high-strength wastes if applicable) and provide written operating and maintenance procedures during the events.

SPECIAL CONDITIONS

H. OPERATION & MAINTENANCE (O&M) PLAN

This facility shall have a current written comprehensive Operation & Maintenance (O&M) Plan. The plan shall provide a systematic approach by which the permittee shall, at all times, properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit.

By December 31 of each year, or within 90 days of any process changes or minor equipment upgrades, the permittee shall evaluate and modify the O&M Plan including site plan(s) and schematic(s) for the waste water treatment facility to ensure that it is up-to-date. The O&M Plan shall be kept on-site at all times and made available to Department and EPA personnel upon request.

Within 90 days of completion of new and/or substantial upgrades of the waste water treatment facility, the permittee shall submit the updated O&M Plan to their Department inspector for review and comment.

I. MERCURY

All mercury sampling (4/Year) required by this permit or required to determine compliance with interim limitations established pursuant to *Interim Effluent Limitations and Controls for the Discharge of Mercury*, 06-096 CMR 519, shall be conducted in accordance with EPA's "clean sampling techniques" found in EPA Method 1669, *Sampling Ambient Water For Trace Metals At EPA Water Quality Criteria Levels*. All mercury analysis shall be conducted in accordance with EPA Method 1631E, *Determination of Mercury in Water by Oxidation, Purge and Trap, and Cold Vapor Fluorescence Spectrometry*.

See **Attachment D**, *Effluent Mercury Test Report*, of this permit for the Department's form for reporting mercury test results.

J. AMBIENT WATER QUALITY MONITORING

Between July 1 and September 30 of each year, the permittee is required to participate in the monitoring of ambient water quality on the Penobscot River pursuant to a Department prepared monitoring plan. The total cost to the permittee for the monitoring program shall not exceed a five-year (term of the permit) cap of \$1,000.

K. COMBINED SEWER OVERFLOWS (CSOs)

Pursuant to *Combined Sewer Overflow Abatement*, 06-096 CMR 570, the permittee is authorized to discharge from the following locations of combined sewer overflows (CSOs) (stormwater and sanitary wastewater) subject to the conditions and requirements herein:

1. CSO locations:

<u>Outfall No./Name</u>	<u>Outfall Location</u>	<u>Receiving Water and Class</u>
002	Prentiss Street	Penobscot River, Class B
003	Gillman Falls Avenue	Penobscot River, Class B
004	Stillwater Avenue PS	Stillwater River, Class C

2. Prohibited Discharges

- a) The discharge of dry weather flows is prohibited. All such discharges shall be reported to the Department in accordance with Standard Condition D (1) of this permit.
- b) No discharge shall occur as a result of mechanical failure, improper design or inadequate operation or maintenance.
- c) No discharges shall occur at flow rates below the maximum design capacities of the wastewater treatment facility, pumping stations or sewerage system.

3. Narrative Effluent Limitations

- a) The effluent shall not contain a visible oil sheen, settled substances, foam, or floating solids at any time that impair the characteristics and designated uses ascribed to the classification of the receiving waters.
- b) The effluent shall not contain materials in concentrations or combinations that are hazardous or toxic to aquatic life; or which would impair the usage designated by the classification of the receiving waters.
- c) The discharge shall not impart color, turbidity, toxicity, radioactivity or other properties that cause the receiving waters to be unsuitable for the designated uses and other characteristics ascribed to their class.

4. CSO Master Plan (see Sections 2 & 3 of 06-096 CMR 570)

The permittee shall implement CSO control projects in accordance with an approved CSO Master Plan and abatement schedule. The CSO Master Plan update entitled *The City of Old Town, Maine CSO Master Plan Update Report*, dated **November 2009** was approved by the Department on December 21, 2009.

SPECIAL CONDITIONS

K. COMBINED SEWER OVERFLOWS (CSOs) (cont'd)

Key milestones approved in the most recent abatement schedule that the permittee is required to comply with are:

By June 30, 2011, (PCS Code 82299), the Permittee shall complete the flow monitoring of the Stillwater Avenue Area and submit to the Department for review and approval a memorandum on the results.

By June 30, 2012, (PCS Code 82299), the Permittee shall complete the Sewer System Evaluation Survey (SSES) of the Elm Street Area and submit it to the Department for review and approval.

By June 30, 2014, (PCS Code 04599), the Permittee shall complete construction of the infiltration and inflow projects identified in the Elm Street Area SSES.

To modify the dates and or projects specified above (but not dates in the Master Plan), the permittee must file an application with the Department to formally modify this permit. The work items identified in the abatement schedule may be amended from time to time based upon approval by the Department. The permittee must notify the Department in writing prior to any proposed changes to the implementation schedule.

5. Nine Minimum Controls (NMC) (see Section 5 of 06-096 CMR 570)

The permittee shall implement and follow the Nine Minimum Control documentation as approved by EPA on May 29, 1997. Work performed on the Nine Minimum Controls during the year shall be included in the annual *CSO Progress Report* (see below).

6. CSO Compliance Monitoring Program (see Section 6 of 06-096 CMR 570)

The permittee shall conduct block testing or flow monitoring according to an approved *Compliance Monitoring Program* on all CSO points, as part of the CSO Master Plan. Annual flow volumes for all CSO locations shall be determined by actual flow monitoring, or by estimation using a model such as EPA's Storm Water Management Model (SWMM).

Results shall be submitted annually as part of the annual *CSO Progress Report* (see below), and shall include annual precipitation, CSO volumes (actual or estimated) and any block test data required. Any abnormalities during CSO monitoring shall also be reported. The results shall be reported on the Department form "*CSO Activity and Volumes*" (**Attachment E** of this permit) or similar format and submitted to the Department electronically. CSO control projects that have been completed shall be monitored for volume and frequency of overflow to determine the effectiveness of the project toward CSO abatement. This requirement shall not apply to those areas where complete separation has been completed and CSO outfalls have been eliminated.

SPECIAL CONDITIONS

K. COMBINED SEWER OVERFLOWS (CSOs) (cont'd)

7. Additions of New Wastewater (see Section 8 of 06-096 CMR 570)

06-096 CMR 570 Section 8 lists requirements relating to any proposed addition of wastewater to the combined sewer system. Documentation of the new wastewater additions to the system and associated mitigating measures shall be included in the annual *CSO Progress Report* (see below). Reports must contain the volumes and characteristics of the wastewater added or authorized for addition and descriptions of the sewer system improvements and estimated effectiveness. Any sewer extensions upstream of a CSO must be reviewed and approved by the Department prior to their connection to the collection system. A Sewer Extension/Addition Reporting Form shall be completed and submitted to the Department along with plans and specifications of the proposed extension/addition.

8. Annual CSO Progress Reports (see Section 7 of 06-096 CMR 570)

By March 1 of each year (*PCS Code 11099*) the permittee shall submit *CSO Progress Reports* covering the previous calendar year (January 1 to December 31). The CSO Progress Report shall include, but is not necessarily limited to, the following topics as further described in 06-096 CMR 570: CSO abatement projects, schedule comparison, progress on inflow sources, costs, flow monitoring results, CSO activity and volumes, nine minimum controls update, sewer extensions, and new commercial or industrial flows.

The CSO Progress Reports shall be completed on a standard form *entitled "Annual CSO Progress Report,"* furnished by the Department, and submitted in electronic form to the following address:

CSO Coordinator
Department of Environmental Protection
Bureau of Land and Water Quality
Division of Water Quality Management
17 State House Station
Augusta, Maine 04333
e-mail: CSOCoordinator@maine.gov

SPECIAL CONDITIONS

K. COMBINED SEWER OVERFLOWS (CSOs) (cont'd)

9. Signs

If not already installed, the permittee shall install and maintain an identification sign at each CSO location as notification to the public that intermittent discharges of untreated sanitary wastewater occur. The sign must be located at or near the outfall and be easily readable by the public. The sign shall be a minimum of 12" x 18" in size with white lettering against a green background and shall contain the following information:

**CITY OF OLD TOWN
WET WEATHER SEWAGE DISCHARGE
CSO # AND NAME**

10. Definitions

For the purposes of this permitting action, the following terms are defined as follows:

- a. Combined Sewer Overflow - a discharge of excess waste water from a municipal or quasi-municipal sewerage system that conveys both sanitary wastes and storm water in a single pipe system and that is in direct response to a storm event or snowmelt.
- b. Dry Weather Flows - flow in a sewerage system that occurs as a result of non-storm events or are caused solely by ground water infiltration.
- c. Wet Weather Flows - flow in a sewerage system that occurs as a direct result of a storm event, or snowmelt in combination with dry weather flows.
- d. CSO-Related Bypasses of Secondary Treatment - For the purposes of this permitting action, this term refers to structures and or processes at the wastewater treatment facility that provide equivalent to primary treatment and disinfection of waste waters that bypass the biological treatment portion of the facility in an effort to mitigate the discharge of untreated combined sanitary waste waters and storm water from the three CSOs listed in Special Condition K of this permit.

L. 06-096 CMR 530(2)(D)(4) STATEMENT FOR REDUCED/WAIVED TOXICS TESTING

By December 31 of each calendar year, the permittee shall provide the Department with a certification describing any of the following that have occurred since the effective date of this permit [*PCS Code 95799*]:

- (a) Changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge;

L. 06-096 CMR 530(2)(D)(4) STATEMENT FOR REDUCED/WAIVED TOXICS TESTING (cont'd)

- (b) Changes in the operation of the treatment works that may increase the toxicity of the discharge; and
- (c) Changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge.

In addition, in the “Comments” section of the certification form, the permittee shall provide the Department with statements describing;

- (d) Changes in storm water collection or inflow/infiltration affecting the facility that may increase the toxicity of the discharge.
- (e) Increases in the type or volume of hauled wastes accepted by the facility.

The Department reserves the right to reinstate annual (surveillance level) testing or other toxicity testing if new information becomes available that indicates the discharge may cause or have a reasonable potential to cause exceedences of ambient water quality criteria/thresholds. See **Attachment F** of the Fact Sheet for an acceptable certification form to satisfy this Special Condition.

M. DISPOSAL OF TRANSPORTED WASTES IN WASTEWATER TREATMENT FACILITY

The permittee is prohibited from accepting transported waste for disposal into any part or parts of the wastewater disposal system. “Transported wastes” means any liquid non-hazardous waste delivered to a wastewater treatment facility by a truck or other similar conveyance that has different chemical constituents or a greater strength than the influent described on the facility’s application for a waste discharge license. Such wastes may include, but are not limited to septage, industrial wastes or other wastes to which chemicals in quantities potentially harmful to the treatment facility or receiving water have been added.

N. MONITORING AND REPORTING

Monitoring results obtained during the previous month shall be summarized for each month and reported on separate Discharge Monitoring Report (DMR) forms provided by the Department and **postmarked on or before the thirteenth (13th) day of the month or hand-delivered** to a Department Regional Office such that the DMR’s are received by the Department on or before the fifteenth (15th) day of the month following the completed reporting period.

SPECIAL CONDITIONS

N. MONITORING AND REPORTING (cont'd)

A signed copy of the DMR and all other reports required herein shall be submitted to the Department's compliance inspector (unless otherwise specified) at the following address:

Department of Environmental Protection
Eastern Maine Regional Office
Bureau of Land and Water Quality
Division of Water Quality Management
106 Hogan Road
Bangor, Maine 04401

Alternatively, if you are submitting an electronic Discharge Monitoring Report (eDMR), the completed eDMR must be electronically submitted to the Department by a facility authorized DMR Signatory **not later than close of business on the 15th day of the month** following the completed reporting period. **Hard Copy documentation** submitted in support of the eDMR must be **postmarked on or before the thirteenth (13th) day of the month or hand-delivered to the Department's Regional Office such that it is received by the Department on or before the fifteenth (15th) day of the month** following the completed reporting period. **Electronic documentation** in support of the eDMR must be submitted **not later than close of business on the 15th day of the month** following the completed reporting period.

Additional monthly reporting requires submitting (in electronic version preferably) a "*DEP-49-CSO Form For Use With Dedicated CSO Primary Clarifiers or DEP-49-CSO Form For Use With Non-Dedicated CSO Primary Clarifiers*" to:

CSO Coordinator
Department of Environmental Protection
Bureau of Land & Water Quality
Division of Engineering, Compliance and Technical Assistance
17 State House Station
Augusta, Maine 04333
e-mail: CSOCoordinator@state.me.us

O. REOPENING OF PERMIT FOR MODIFICATIONS

Upon evaluation of the tests results or monitoring requirements specified in Special Conditions of this permitting action, new site specific information, or any other pertinent test results or information obtained during the term of this permit, the Department may, at anytime and with notice to the permittee, modify this permit to; 1) include effluent limits necessary to control specific pollutants or whole effluent toxicity where there is a reasonable potential that the effluent may cause water quality criteria to be exceeded, (2) require additional monitoring if results on file are inconclusive; or (3) change monitoring requirements or limitations based on new information.

SPECIAL CONDITIONS

P. SEVERABILITY

In the event that any provision(s), or part thereof, of this permit is declared to be unlawful by a reviewing court, the remainder of the permit shall remain in full force and effect, and shall be construed and enforced in all aspects as if such unlawful provision, or part thereof, had been omitted, unless otherwise ordered by the court.

ATTACHMENT A

**Maine Department of Environmental Protection
WET and Chemical Specific Data Report Form**

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

Facility Name _____ MEPDES # _____ Facility Representative Signature _____
 Pipe # _____ To the best of my knowledge this information is true, accurate and complete.

Licensed Flow (MGD)
 Acute dilution factor
 Chronic dilution factor
 Human health dilution factor
 Criteria type: M(arine) or F(resh)

Flow for Day (MGD)⁽¹⁾ Flow Avg. for Month (MGD)⁽²⁾
 Date Sample Collected Date Sample Analyzed

Laboratory _____ Telephone _____
 Address _____
 Lab Contact _____ Lab ID # _____

ERROR WARNING ! Essential facility information is missing. Please check required entries in bold above.

FRESH WATER VERSION
 Please see the footnotes on the last page.

WHOLE EFFLUENT TOXICITY		Effluent Limits, %			Receiving Water or Ambient	Effluent Concentration (ug/L or as noted)	WET Result, % Do not enter % sign	Reporting Limit Check	Possible Exceedence ⁽⁷⁾		
		Acute	Chronic						Acute	Chronic	
	Trout - Acute										
	Trout - Chronic										
	Water Flea - Acute										
	Water Flea - Chronic										
WET CHEMISTRY											
	pH (S.U.) ⁽⁹⁾				(8)						
	Total Organic Carbon (mg/L)				(8)						
	Total Solids (mg/L)										
	Total Suspended Solids (mg/L)										
	Alkalinity (mg/L)				(8)						
	Specific Conductance (umhos)										
	Total Hardness (mg/L)				(8)						
	Total Magnesium (mg/L)				(8)						
	Total Calcium (mg/L)				(8)						
ANALYTICAL CHEMISTRY ⁽³⁾											
	Also do these tests on the effluent with WET. Testing on the receiving water is optional	Reporting Limit	Effluent Limits, ug/L					Reporting Limit Check	Possible Exceedence ⁽⁷⁾		
			Acute ⁽⁶⁾	Chronic ⁽⁶⁾	Health ⁽⁶⁾				Acute	Chronic	Health
	TOTAL RESIDUAL CHLORINE (mg/L) ⁽⁹⁾	0.05				NA					
	AMMONIA	NA				(8)					
M	ALUMINUM	NA				(8)					
M	ARSENIC	5				(8)					
M	CADMIUM	1				(8)					
M	CHROMIUM	10				(8)					
M	COPPER	3				(8)					
M	CYANIDE	5				(8)					
M	LEAD	3				(8)					
M	NICKEL	5				(8)					
M	SILVER	1				(8)					
M	ZINC	5				(8)					

**Maine Department of Environmental Protection
WET and Chemical Specific Data Report Form**

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

PRIORITY POLLUTANTS ⁽⁴⁾		Effluent Limits			Reporting Limit Check	Possible Exceedence ⁽⁷⁾		
	Reporting Limit	Acute ⁽⁶⁾	Chronic ⁽⁶⁾	Health ⁽⁶⁾		Acute	Chronic	Health
M	ANTIMONY	5						
M	BERYLLIUM	2						
M	MERCURY (5)	0.2						
M	SELENIUM	5						
M	THALLIUM	4						
A	2,4,6-TRICHLOROPHENOL	3						
A	2,4-DICHLOROPHENOL	5						
A	2,4-DIMETHYLPHENOL	5						
A	2,4-DINITROPHENOL	45						
A	2-CHLOROPHENOL	5						
A	2-NITROPHENOL	5						
A	4,6 DINITRO-O-CRESOL (2-Methyl-4,6-dinitrophenol)	25						
A	4-NITROPHENOL	20						
A	P-CHLORO-M-CRESOL (3-methyl-4-chlorophenol)+B80	5						
A	PENTACHLOROPHENOL	20						
A	PHENOL	5						
BN	1,2,4-TRICHLOROENZENE	5						
BN	1,2-(O)DICHLOROENZENE	5						
BN	1,2-DIPHENYLHYDRAZINE	10						
BN	1,3-(M)DICHLOROENZENE	5						
BN	1,4-(P)DICHLOROENZENE	5						
BN	2,4-DINITROTOLUENE	6						
BN	2,6-DINITROTOLUENE	5						
BN	2-CHLORONAPHTHALENE	5						
BN	3,3'-DICHLOROENZIDINE	16.5						
BN	3,4-BENZO(B)FLUORANTHENE	5						
BN	4-BROMOPHENYLPHENYL ETHER	2						
BN	4-CHLOROPHENYL PHENYL ETHER	5						
BN	ACENAPHTHENE	5						
BN	ACENAPHTHYLENE	5						
BN	ANTHRACENE	5						
BN	BENZIDINE	45						
BN	BENZO(A)ANTHRACENE	8						
BN	BENZO(A)PYRENE	3						
BN	BENZO(G,H,I)PERYLENE	5						
BN	BENZO(K)FLUORANTHENE	3						
BN	BIS(2-CHLOROETHOXY)METHANE	5						
BN	BIS(2-CHLOROETHYL)ETHER	6						
BN	BIS(2-CHLOROISOPROPYL)ETHER	6						
BN	BIS(2-ETHYLHEXYL)PHTHALATE	3						
BN	BUTYLBENZYL PHTHALATE	5						
BN	CHRYSENE	3						
BN	DI-N-BUTYL PHTHALATE	5						
BN	DI-N-OCTYL PHTHALATE	5						
BN	DIBENZO(A,H)ANTHRACENE	5						
BN	DIETHYL PHTHALATE	5						
BN	DIMETHYL PHTHALATE	5						

**Maine Department of Environmental Protection
WET and Chemical Specific Data Report Form**

This form is for reporting laboratory data and facility information. Official compliance reviews will be done by DEP.

V	ACROLEIN	NA									
V	ACRYLONITRILE	NA									
V	BENZENE	5									
V	BROMOFORM	5									
V	CARBON TETRACHLORIDE	5									
V	CHLOROBENZENE	6									
V	CHLORODIBROMOMETHANE	3									
V	CHLOROETHANE	5									
V	CHLOROFORM	5									
V	DICHLOROBROMOMETHANE	3									
V	ETHYLBENZENE	10									
V	METHYL BROMIDE (Bromomethane)	5									
V	METHYL CHLORIDE (Chloromethane)	5									
V	METHYLENE CHLORIDE	5									
V	TETRACHLOROETHYLENE (Perchloroethylene or Tetrachloroethene)	5									
V	TOLUENE	5									
V	TRICHLOROETHYLENE (Trichloroethene)	3									
V	VINYL CHLORIDE	5									

Notes:

- (1) Flow average for day pertains to WET/PP composite sample day.
- (2) Flow average for month is for month in which WET/PP sample was taken.
- (3) Analytical chemistry parameters must be done as part of the WET test chemistry.
- (4) Priority Pollutants should be reported in micrograms per liter (ug/L).
- (5) Mercury is often reported in nanograms per liter (ng/L) by the contract laboratory, so be sure to convert to micrograms per liter on this spreadsheet.
- (6) Effluent Limits are calculated based on dilution factor, background allocation (10%) and water quality reserves (15% - to allow for new or changed discharges or non-point sources).
- (7) Possible Exceedence determinations are done for a single sample only on a mass basis using the actual pounds discharged. This analysis does not consider watershed wide allocations for fresh water discharges.
- (8) These tests are optional for the receiving water. However, where possible samples of the receiving water should be preserved and saved for the duration of the WET test. In the event of questions about the receiving water's possible effect on the WET results, chemistry tests should then be conducted.
- (9) pH and Total Residual Chlorine must be conducted at the time of sample collection. Tests for Total Residual Chlorine need be conducted only when an effluent has been chlorinated or residual chlorine is believed to be present for any other reason.

Comments:

ATTACHMENT B

**MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION
WHOLE EFFLUENT TOXICITY REPORT
FRESH WATERS**

Facility Name _____ MEPDES Permit # _____
Pipe # _____

Facility Representative _____ Signature _____

By signing this form, I attest that to the best of my knowledge that the information provided is true, accurate, and complete.

Facility Telephone # _____ Date Collected _____ Date Tested _____
mm/dd/yy mm/dd/yy

Chlorinated? _____ Dechlorinated? _____

Results	% effluent		Effluent Limitations	
	water flea	trout	A-NOEL	C-NOEL
A-NOEL				
C-NOEL				

Data summary	water flea			trout		
	% survival		no. young	% survival		final weight (mg)
QC standard	A>90	C>80	>15/female	A>90	C>80	> 2% increase
lab control						
receiving water control						
conc. 1 (%)						
conc. 2 (%)						
conc. 3 (%)						
conc. 4 (%)						
conc. 5 (%)						
conc. 6 (%)						
stat test used						

place * next to values statistically different from controls

for trout show final wt and % incr for both controls

Reference toxicant	water flea		trout	
	A-NOEL	C-NOEL	A-NOEL	C-NOEL
toxicant / date				
limits (mg/L)				
results (mg/L)				

Comments _____

Laboratory conducting test

Company Name _____ Company Rep. Name (Printed) _____

Mailing Address _____ Company Rep. Signature _____

City, State, ZIP _____ Company Telephone # _____

Report WET chemistry on DEP Form "ToxSheet (Fresh Water Version), March 2007."

ATTACHMENT C

Protocol for Total Phosphorus Sample Collection and Analysis for Waste Water and Receiving Water Monitoring Required by Permits

Approved Analytical Methods: EPA 365.1 (Rev. 2.0), 365.3, 365.4; SM 4500-P B.5, 4500-P E, 4500-P F; ASTM D515-88(A), D515-88(B); USGS I-4600-85, I-4610-91; OMAAOAC 973.55, 973.56

Sample Collection: The Maine DEP is requesting that total phosphorus analysis be conducted on composite effluent samples, unless a facility's Permit specifically designates grab sampling for this parameter. Facilities can use individual collection bottles or a single jug made out of glass or polyethylene. Bottles and/or jugs should be cleaned prior to each use with dilute HCL. This cleaning should be followed by several rinses with distilled water. Commercially purchased, pre-cleaned sample containers are an acceptable alternative. The sampler hoses should be cleaned, as needed.

Sample Preservation: During compositing the sample must be at 0-6 degrees C (without freezing). If the sample is being sent to a commercial laboratory or analysis cannot be performed the day of collection then the sample must be preserved using H₂SO₄ to obtain a sample pH of <2 su and refrigerated at 0-6 degrees C (without freezing). The holding time for a preserved sample is 28 days.

Note: Ideally, Total P samples are preserved as described above. However, if a facility is using a commercial laboratory then that laboratory may choose to add acid to the sample once it arrives at the laboratory. The Maine DEP will accept results that use either of these preservation methods.

Laboratory QA/QC: Laboratories must follow the appropriate QA/QC procedures that are described in each of the approved methods.

Sampling QA/QC: If a composite sample is being collected using an automated sampler, then once per month run a blank on the composite sampler. Automatically, draw distilled water into the sample jug using the sample collection line. Let this water set in the jug for 24 hours and then analyze for total phosphorus. Preserve this sample as described above.

ATTACHMENT D

Effluent Mercury Test Report

Name of Facility: _____ Federal Permit # ME _____
 Pipe # _____

Purpose of this test: Initial limit determination
 Compliance monitoring for: year _____ calendar quarter _____
 Supplemental or extra test

SAMPLE COLLECTION INFORMATION

Sampling Date:

--	--	--

 Sampling time: _____ AM/PM
mm dd yy

Sampling Location: _____

Weather Conditions: _____

Please describe any unusual conditions with the influent or at the facility during or preceding the time of sample collection:

Optional test - not required but recommended where possible to allow for the most meaningful evaluation of mercury results:

Suspended Solids _____ mg/L Sample type: _____ Grab (recommended) or
 _____ Composite

ANALYTICAL RESULT FOR EFFLUENT MERCURY

Name of Laboratory: _____

Date of analysis: _____ **Result:** ng/L (PPT)
Please Enter Effluent Limits for your facility

Effluent Limits: **Average** = _____ ng/L **Maximum** = _____ ng/L

Please attach any remarks or comments from the laboratory that may have a bearing on the results or their interpretation. If duplicate samples were taken at the same time please report the average.

CERTIFICATION

I certify that to the best of my knowledge the foregoing information is correct and representative of conditions at the time of sample collection. The sample for mercury was collected and analyzed using EPA Methods 1669 (clean sampling) and 1631 (trace level analysis) in accordance with instructions from the DEP.

By: _____ Date: _____

Title: _____

PLEASE MAIL THIS FORM TO YOUR ASSIGNED INSPECTOR

ATTACHMENT E

**MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION
CSO ACTIVITY AND VOLUMES**

MUNICIPALITY OR DISTRICT												MEPDES / NPDES PERMIT NO.	
REPORTING YEAR												SIGNED BY:	
YEARLY TOTAL PRECIPITATION				INCHES								DATE:	
CSO EVENT NO.	START DATE OF STORM	PRECIP. DATA		FLOW DATA (GALLONS PER DAY) OR BLOCK ACTIVITY("1")								EVENT OVERFLOW GALLONS	EVENT DURATION HRS
		TOTAL INCHES	MAX. HR. INCHES	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:	LOCATION: NUMBER:		
1													
2													
3													
4													
5													
6													
7													
8													
9													
10													
11													
12													
13													
14													
15													
16													
17													
18													
19													
20													
21													
22													
23													
24													
25													
TOTALS													

Note 1: Flow data should be listed as gallons per day. Storms lasting more than one day should show total flow for each day.

Note 2: Block activity should be shown as a "1" if the block floated away.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

AND

MAINE WASTE DISCHARGE LICENSE

FACT SHEET

May 19, 2011

PERMIT NUMBER: **ME0100471**
LICENSE NUMBER: **W001635-6D-D-R**

NAME AND ADDRESS OF APPLICANT:

**City of Old Town Pollution Control
150 Brunswick Street
Old Town, Maine 04468-1497**

COUNTY: **Penobscot County**

NAME AND ADDRESS WHERE DISCHARGE OCCURS:

**298 Water Street
Old Town, Maine 04468-1947**

RECEIVING WATER/CLASSIFICATION: **Penobscot River/Class B**

COGNIZANT OFFICIAL AND TELEPHONE NUMBER: **Mr. Gary Stetson, Superintendent**
(207) 827-3970
garystetson@myfairpoint.net

1. APPLICATION SUMMARY

Application: The permittee has applied to the Department for renewal of combination Department Waste Discharge License (WDL) #W001635-5L-C-R/MEPDES permit #ME0100471 which was issued on May 25, 2004 and expired on May 25, 2009. The 5/25/04 WDL authorized the discharge of up to a monthly average flow of 3.50 million gallons per day (MGD) of secondary treated sanitary waste water to the Penobscot River, Class B, in Old Town, Maine. The 5/25/04 WDL also authorized the discharge of an unspecified quantity of untreated combined sanitary and storm water from three (3) combined sewer overflow (CSO) outfalls. Two CSOs discharge to the Penobscot River, Class B, and one CSO discharges to the Stillwater River, Class C.

2. PERMIT SUMMARY

- a. Terms and Conditions - **This permitting action is similar to the 5/25/04 WDL action in that it is:**

Secondary Treated Waste Water:

1. Carrying forward the monthly average, weekly average and daily maximum technology based concentration limits for biochemical oxygen demand (BOD₅) and total suspended solids (TSS).
2. Carrying forward the monthly average and weekly average technology based mass limitations for BOD₅ and TSS based on a historical monthly average flow limitation of 1.70 MGD due to potential non-attainment of dissolved oxygen standards in the Penobscot River below the permittee's waste water treatment facility. These limits are applicable June 1 – September 30 of each year.
3. Carrying forward the reporting requirement for the daily maximum mass loadings for BOD₅ and TSS.
4. Carrying forward the daily maximum technology based concentration limit for settleable solids.
5. Carrying forward the seasonal (May 15 – September 30) monthly average and daily maximum water quality based concentration limits for *E. coli* bacteria.
6. Carrying forward the daily maximum technology based concentration limit for total residual chlorine.
7. Carrying forward the screening level whole effluent toxicity (WET) and chemical specific (priority pollutant) testing per *Surface Waters Toxics Control Program*, 06-096 CMR 530.
8. Requiring the permittee to periodically update the Operation and Maintenance (O&M) Plan and Wet Weather Management Plan for the waste water treatment facility and pump stations.

Primary Treated Waste Water:

9. Carrying forward the daily maximum water quality based limit for *E. coli* bacteria and a daily maximum technology based limit for total residual chlorine.
10. Carrying forward monthly average and/or daily maximum reporting requirements for flow, surface overflow rates, number of discharge days per month and percent removal for BOD₅ and TSS.

2. PERMIT SUMMARY (cont'd)

This permitting action is different from the 5/25/04 WDL action in that it is:

Secondary Treated Waste Water:

11. Establishing a reporting requirement for priority pollutant testing per 06-096 CMR 525.
12. Reducing settleable solids monitoring frequency from 5/Week to 3/Week based on Department BPJ.
13. Revising the seasonal (June 1 – September 30) monitoring requirements for total phosphorus based on Department BPJ.
14. Establishing monthly average water quality based mass and concentration limits for total aluminum, total copper and total lead.
15. Establishing daily maximum water quality based mass and concentration limits for total copper.
16. Revising the acute dilution factor to a modified acute dilution factor based on new information.

b. History: The most current relevant regulatory actions include the following:

November 4, 1999 – The Department issued WDL renewal #W001635-5L-B-R for a five-year term.

February 3, 2000 – The USEPA issued NPDES permit renewal #ME0100471 for a five-year term.

May 23, 2000 – The Department administratively modified the 11/4/99 WDL by establishing interim average and maximum limitations of 18.6 ng/L and 27.8 ng/L respectively, for the discharge of mercury.

November 2000 – The City of Old Town completed a comprehensive facility evaluation and CSO Master Plan for the waste water treatment facility. Both plans were reviewed and approved by the Department on December 28, 2002.

May 25, 2004 – The Department issued combination WDL/MEPDES permit #W001635-5L-C-R/ME0100471 to the City of Old Town Pollution Control Facility for a five-year period.

April 10, 2006 – The Department issued a modification of the 5/25/04 combination MEPDES Permit/WDL that incorporated the testing requirements of Department rules Chapter 530 and Chapter 584.

2. PERMIT SUMMARY (cont'd)

b. History (cont'd):

May 13, 2009 – The permittee submitted a complete and timely application for renewal of MEPDES Permit/WDL #ME0100471/#W001635-5L-C-R.

- c. Source Description: The Old Town waste water treatment facility commenced operations in 1977. The facility receives sanitary waste water from residential and commercial users in the City of Old Town (~9,000 users) and from the Town of Milford (~3,000 users). In the past, the permittee's one significant commercial user, LaBree's Bakery, contributed process wastewater to the treatment facility. The bakery no longer discharges process wastewater to the permittee as only sanitary wastewater is conveyed to the permittee. The sewer collection system is approximately 25 miles in length, has six pump stations (four with on-site backup power and two served by a portable generator) and is 5% combined and 95% separated with three combined sewer overflow (CSO) points. Old Town has developed a CSO Master Plan to eliminate the three CSOs that were formally approved by the Department on December 28, 2002. See Special Condition K, *Combined Sewer Overflows (CSOs)* of this permit. The waste water treatment facility is not authorized to accept septage. The waste water treatment facility's outfall structure may be modified as part of a proposed Great Works Dam Removal Project being undertaken by the Penobscot River Restoration Trust.
- d. Waste Water Treatment: The Old Town facility provides a secondary level of treatment via ten rotating biological contactors (RBCs). See **Attachment A** of this Fact Sheet for a schematic of the waste water treatment process and site location maps. The City of Old Town upgraded the waste water treatment facility in order to modernize the secondary treatment process and to provide the necessary infrastructure to mitigate CSOs. The upgrade allows primary treatment (dedicated storm clarifier) and high rate disinfection for flows that exceed a flow rate of 3,260 gallons per minute (4.7 MGD), the peak hourly capacity of the secondary treatment process. Other major project components included in the upgrade are new and expanded influent pumping facilities, a new headworks building containing new screening and grit removal facilities, two new primary clarifiers (each measuring 32 feet in diameter) modifications to the RBC treatment process, upgrades to the two secondary clarifiers (each 50 feet in diameter), upgrades to the disinfection system, new process control systems and new electrical systems.

The primary treated and secondary treated waste waters are seasonally disinfected with sodium hypochlorite in a separate chlorine contact chamber and the flows are measured by an ultrasonic flow meter. The treated waste water is discharged to the Penobscot River at 9.90 feet below mean low water via a high density polyethylene (HDPE) pipe measuring 36 inches in diameter that extends out into the river approximately 250 feet. The end of the outfall pipe is fitted with a diffuser measuring 34 feet long with 20, 6-inch diameter holes spaced 18 inches on-center. The waste water treatment facility is designed for secondary treatment of an average daily flow of 3.50 MGD and a peak hourly capacity of 4.7 MGD. The facility's storm water-related peak flow design is 15.7 MGD.

3. CONDITIONS OF PERMITS

Conditions of licenses, 38 M.R.S.A. § 414-A, requires that the effluent limitations prescribed for discharges, including, but not limited to, effluent toxicity, require application of best practicable treatment (BPT), be consistent with the U.S. Clean Water Act, and ensure that the receiving waters attain the State water quality standards as described in Maine's Surface Water Classification System. In addition, *Certain deposits and discharges prohibited*,

38 M.R.S.A., §420 and *Surface Water Toxics Control Program*, 06-096 CMR 530 (effective October 9, 2005) require the regulation of toxic substances not to exceed levels set forth in, *Surface Water Quality Criteria for Toxic Pollutants*, 06-096 CMR 584 (effective October 9, 2005), and that ensure safe levels for the discharge of toxic pollutants such that existing and designated uses of surface waters are maintained and protected.

4. RECEIVING WATER STANDARDS

Maine law, 38 M.R.S.A., Section 467(7)(A)(6) indicates the Penobscot River main stem, from the Maine Central Railroad bridge in Bangor to a line extended in an east-west direction from the confluence of Reeds Brook in Hampden, is classified as a Class B waterway. The Legislature finds that the free-flowing habitat of this river segment provides irreplaceable social and economic benefits and that this use must be maintained. Maine law, 38 M.R.S.A., Section 465(3) describes standards for classification of Class B waters as follows:

Class B waters must be of such quality that they are suitable for the designated uses of drinking water supply after treatment; fishing; agriculture; recreation in and on the water; industrial process and cooling water supply; hydroelectric power generation, except as prohibited under Title 12, section 403; navigation; and as habitat for fish and other aquatic life. The habitat must be characterized as unimpaired.

The dissolved oxygen content of Class B waters may not be less than 7 parts per million or 75% of saturation, whichever is higher, except that for the period from October 1st to May 14th, in order to ensure spawning and egg incubation of indigenous fish species, the 7-day mean dissolved oxygen concentration may not be less than 9.5 parts per million and the 1-day minimum dissolved oxygen concentration may not be less than 8.0 parts per million in identified fish spawning areas. Between May 15th and September 30th, the number of Escherichia coli bacteria of human and domestic animal origin in these waters may not exceed a geometric mean of 64 per 100 milliliters or an instantaneous level of 236 per 100 milliliters. In determining human and domestic animal origin, the department shall assess licensed and unlicensed sources using available diagnostic procedures.

Discharges to Class B waters may not cause adverse impact to aquatic life in that the receiving waters must be of sufficient quality to support all aquatic species indigenous to the receiving water without detrimental changes in the resident biological community.

5. RECEIVING WATER CONDITIONS

Table Category 5-D entitled, *Rivers and Streams Impaired By Legacy Pollutants*, in a document entitled, 2008 Maine Integrated Water Quality Report, [referred to as the “305(b) Report”] published by the Department states the designated use of fishing (consumption) is impaired in a 14-mile segment of the Penobscot River in the vicinity of the permittee’s outfall due to the presence of PCBs in fish tissue. The Department is not aware of any information that indicates the discharge from the permittee is causing or contributing to the impairment.

In addition, the 305b Report lists all freshwaters in Maine in *Category 4-A: Rivers and Streams With Impaired Use, TMDL Completed*. Impairment in this context refers to the designated use of recreational fishing due to elevated levels of mercury in some fish caused by atmospheric deposition. As a result, the State has established a fish consumption advisory for all freshwaters in Maine. The Report states that a regional scale TMDL has been approved. In addition, pursuant to Maine law, 38 M.R.S.A. §420(1-B)(B), “*a facility is not in violation of the ambient criteria for mercury if the facility is in compliance with an interim discharge limit established by the Department pursuant to section 413 subsection 11.*” The Department has established interim monthly average and daily maximum mercury concentration limits for this facility. See the discussion on compliance in section 6(j) of this Fact Sheet.

In the summers of 1997, 2001 and 2007, the Department conducted ambient water quality sampling on a 103-mile segment of the Penobscot River from Millinocket to Bucksport. Reports entitled, *Penobscot River Modeling Report, Final, June 2000*, *Penobscot River Data Report May 2002*, and *Penobscot River Modeling Report Draft, March 2003*, prepared by the Department, indicate there are sections of non-attainment of dissolved oxygen standards as a result of algal blooms in portions of the Class B sections of the rivers. These sections of river have experienced measured DO non-attainment at various locations during periods of low flow and high water temperature. Measured DO non-attainment is predominantly in the early morning hours in sections of river with significant diurnal dissolved oxygen (DO) swings. These significant diurnal DO swings are caused by nutrient enrichment and resulting plant growth. The Department has issued a report entitled, *Penobscot River Phosphorus Waste Load Allocation, May 2011* stating seasonal mass based total phosphorus limitations are necessary for the four industrial dischargers on the river as well as monitoring for total phosphorus for five municipal waste water treatment facilities, including the Brewer facility. The specific eutrophication related responses that are targeted by the waste load allocation are not expected to persist into the tidally influenced portion of the Penobscot River. However, water quality improvements associated with the waste load allocation are expected to extend into the tidally influenced section of the river. The effectiveness of the nutrient load reductions will be assessed through routine ambient monitoring for total phosphorous, dissolved oxygen and biochemical oxygen demand. See Special Condition J, *Ambient Water Quality Monitoring*.

5. RECEIVING WATER CONDITIONS (cont'd)

If ambient water quality monitoring or future modeling determines that at full permitted discharge limits the permittee's discharge is causing or contributing to the non-attainment of standards, this permit will be re-opened per Special Condition O, *Reopening of Permit For Modifications*, to impose more stringent limitations to meet water quality standards.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Secondary Treated Effluent

- a. Flow: This permitting action is carrying forward the monthly average discharge flow limitation of 3.50 MGD for Outfall #001A, which is based on the average dry weather design criterion, and is carrying forward the daily maximum discharge flow reporting requirement.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Flow (n=47)

Value	Limit (MGD)	Range (MGD)	Average (MGD)	Compliance
Monthly Average	3.50	0.50 – 2.88	1.59	100%

- b. Dilution Factors - The Department established applicable dilution factors for the discharge in accordance with freshwater protocols established in *Surface Water Toxics Control Program*, 06-096 CMR 530 (effective October 1994). With a monthly average flow limit of 3.50 MGD, the dilution factors are as follows:

$$\text{Acute: } 1\text{Q}10 = 2,521 \text{ cfs}^{(1)} \Rightarrow \frac{(2,521 \text{ cfs})(0.6464) + (3.50 \text{ MGD})}{(3.50 \text{ MGD})} = 466.6:1$$

$$\text{Modified Acute} = (1/4) 466.6:1 \Rightarrow 117:1$$

$$\text{Chronic: } 7\text{Q}10 = 2,795 \text{ cfs}^{(1)} \Rightarrow \frac{(2,795 \text{ cfs})(0.6464) + (3.50 \text{ MGD})}{(3.50 \text{ MGD})} = 517:1$$

$$\text{Harmonic Mean: } 8,404 \text{ cfs}^{(2)} \Rightarrow \frac{(8,404 \text{ cfs})(0.6464) + (3.50 \text{ MGD})}{(3.50 \text{ MGD})} = 1,553:1$$

Footnotes:

(1) 7Q10 and 1Q10 critical low flow values were recalculated (lowered) in calendar year 2003 during the Department's update of the water quality model for the Penobscot River.

(2) Harmonic mean flow from 1991 study and drainage area ratio.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

- c. Biochemical Oxygen Demand (BOD5) & Total Suspended Solids (TSS): This permitting action is carrying forward monthly average and weekly average technology-based concentration limits of 30 mg/L and 45 mg/L, respectively, for BOD₅ and TSS based on the secondary treatment requirements specified at *Effluent Guidelines and Standards*, 06-096 CMR 525(3)(III) (effective January 12, 2001), and a daily maximum concentration limit of 50 mg/L, which is based on a Department best professional judgment of best practicable treatment for secondary treated municipal wastewater.

This permitting action is carrying forward seasonal monthly average and weekly average limitations based on a monthly average flow limit of 1.70 MGD during the period of June 1 – September 30 of each year and 3.50 MGD for the period of October 1 – May 31 of each year. The purpose of the seasonal limitations are: 1) The waste water treatment facility has completed an upgrade to treat more storm water flows in the non-summer months, resulting in more waste water receiving both primary only and secondary treatment, 2) Ambient water quality data collected by the Department during the summer months indicates the Penobscot River may not be attaining the Class B dissolved oxygen standards established by law. Therefore, the Department is barred from authorizing an increase in the BOD5 and TSS loading to the river during the time of the year when the river is most at risk of dissolved oxygen depletion. Should future water quality data and or modeling indicate dissolved oxygen standards are indeed being attained at the higher mass loads, the permittee may request a modification of this permit to increase the loads based on 3.5 MGD.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

BOD mass (n=47)

Value	Limit (lbs/day)	Range (Jan-Dec) (lbs/day)	Average (lbs/day)	Compliance
Monthly Average	425 (<i>June – Sept</i>) 875 (<i>Oct – May</i>)	34 – 250	124	100%

BOD concentration (n=47)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)	Compliance
Monthly Average	30	3 – 22	11	100%
Daily Maximum	50	5 – 50	15	100%

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

c. Biochemical Oxygen Demand (BOD5) & Total Suspended Solids (TSS) (cont'd):

TSS mass (n=47)

Value	Limit (lbs/day)	Range (Jan-Dec) (lbs/day)	Average (lbs/day)	Compliance
Monthly Average	425 (June – Sept) 875 (Oct – May)	18 – 154	78	100%

TSS concentration (n =47)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)	Compliance
Monthly Average	30	3 – 15	8	100%
Daily Maximum	50	5 – 36	13	100%

No daily maximum mass limitations (“report only”) for BOD5 or TSS were established in the previous permit or in this permitting action as doing so would discourage the permittee from treating as much waste water as possible through the secondary treatment system during wet weather events.

This permitting action is carrying forward a 30-day average percent removal requirement of 85 percent for BOD₅ and TSS as required pursuant to 06-096 CMR 525(3)(III)(a&b)(3) for all flows receiving secondary treatment.

Monitoring frequencies for BOD and TSS of 3/Week are being carried forward from the previous licensing action and are based on Department policy for facilities with a monthly average flow greater than 1.0 MGD but less than 5.0 MGD.

- d. Settleable Solids – This permitting action is carrying forward a daily maximum settleable solids concentration limit of 0.3 mL/L, which is considered best practicable treatment (BPT) for secondary treated wastewater.

A review of the monthly DMR data for the period May 2005 – May 2009 (n=47) indicates the daily maximum settleable solids concentration was 0.3 mL/L and the facility was in compliance 100% during that time. Due to the facility’s 100 % compliance record with the settleable solids limit, this permitting action is reducing the settleable solids monitoring frequency from 5/week to three times per week (3/Week) based on a Department best professional judgment.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

- e. *E. coli* bacteria: The monthly average and daily maximum *E. coli* bacteria limits of 64 colonies/100 mL and 427 colonies/100 mL are being carried forward in this permitting action and are based on the State of Maine Water Classification Program for Class B waters found at 38 M.R.S.A. § 465(3).

The Department has determined that end-of-pipe limitations for the instantaneous concentration standard of 427 colonies/100 mL will be achieved through available dilution of the effluent with the receiving waters and need not be revised in MEPDES permits for facilities with adequate dilution (at least 1.1:1 for facilities in Class B waters).

This permitting action is carrying forward a minimum monitoring frequency requirement of 1/Week for *E. coli* bacteria (during the applicable period) based on best professional judgment.

A review of the monthly DMR data for the period June 2004 – April 2009 indicates the following:

***E. coli* bacteria (n =20)**

Value	Limit (col/100 mL)	Range (col/100 mL)	Mean (col/100 mL)	Compliance
Monthly Average (arithmetic)	64	0 – 17	4	100%
Daily Maximum (arithmetic)	427	0 – 85	14	100%

- f. Total Residual Chlorine: The previous licensing action established a daily maximum BPT limit of 1.0 mg/L for the discharge. Limits on total residual chlorine (TRC) are specified to ensure that ambient water quality standards are maintained and that BPT technology is being applied to the discharge. The Department imposes the more stringent of the water quality- or technology-based limits in permitting actions. End-of-pipe water quality-based concentration thresholds may be calculated as follows:

Parameter	Acute Criteria	Chronic Criteria	Acute Dilution	Chronic Dilution	Acute Limit	Chronic Limit
Chlorine	0.019 mg/L	0.011 mg/L	466:1	517:1	8.8 mg/L	5.6 mg/L

Example calculation, Acute: 0.019 mg/L (466) = 8.8 mg/L

In the case of the Old Town facility, the calculated acute water quality based threshold is higher than 1.0 mg/l, thus the BPT limit of 1.0 mg/L is imposed as a daily maximum limit.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

f. Total Residual Chlorine (cont'd):

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Total Residual Chlorine (n =20)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)	Compliance
Daily Maximum	1.0	0.46 – 0.94	0.78	100%

This permitting action is carrying forward a best professional judgment minimum monitoring frequency requirement of once per day for TRC any time chlorine or chlorine-based compounds are in use for effluent disinfection.

- g. Total phosphorus: The previous permitting action established a seasonal (June – September) 1/Week monitoring and reporting requirement for total phosphorus due to the limited assimilative capacity of the Penobscot River for total phosphorus. The permittee was required to report monthly average, weekly average and daily maximum mass and concentration values for total phosphorus. Gathering such data was required to enable the Department to continually update the river model developed by the Department in calendar year 2001 to predict potential algal blooms that may lead to depressed ambient dissolved oxygen conditions.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Total Phosphorus (as P) mass (n =16)

Value	Limit (lbs/day)	Range (lbs/day)	Average (lbs/day)
Monthly Average	Report	17 – 171	60
Daily Maximum	Report	18 – 255	89

Total Phosphorus (as P) concentration (n=16)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Monthly Average	Report	3 – 17	8
Daily Maximum	Report	3 – 17	8

Based on the consistency of the data cited above, the Department is making a BPJ determination to reduce the seasonal (June 1 – September 30) total phosphorus monitoring frequency from 1/Week to 2/Month. This permitting action is carrying forward the monthly average and daily maximum reporting requirements for both mass and concentration but eliminating the weekly average reporting requirements as they are not necessary given the change in the monitoring frequency.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

- h. pH: This permitting action is carrying forward a technology-based pH limit of 6.0 – 9.0 standard units, which is based on 06-096 CMR 525(3)(III), and a minimum monitoring frequency requirement of 5/Week based on best professional judgment.

A review of the monthly DMR data for the period May 2005 – May 2009 (n=47) indicates the pH ranged from 6.7 – 7.6 standard units.

- i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing: 38 M.R.S.A., Sections 414-A and 420, prohibit the discharge of effluents containing substances in amounts that would cause the surface waters of the State to contain toxic substances above levels set forth in Federal Water Quality Criteria as established by the USEPA. 06-096 CMR 530 and 06-096 CMR 584 set forth ambient water quality criteria (AWQC) for toxic pollutants and procedures necessary to control levels of toxic pollutants in surface waters. WET, priority pollutant and analytical chemistry testing as required by 06-096 CMR 530 are included in this permit in order to fully characterize the effluent. This permit also provides for reconsideration of effluent limits and monitoring schedules after evaluation of toxicity testing results. The monitoring schedule includes consideration of results currently on file, the nature of the wastewater, existing treatment and receiving water characteristics.

WET monitoring is required to assess and protect against impacts upon water quality and designated uses caused by the aggregate effect of the discharge on specific aquatic organisms. Acute and chronic WET tests are performed on invertebrate and vertebrate species. Priority pollutant and analytical chemistry testing are required to assess the levels of individual toxic pollutants in the discharge, comparing each pollutant to acute, chronic, and human health AWQC as established in 06-096 CMR 584.

06-096 CMR 530 establishes four categories of testing requirements based predominately on the chronic dilution factor. The categories are as follows:

- 1) Level I – chronic dilution factor of <20:1.
- 2) Level II – chronic dilution factor of $\geq 20:1$ but <100:1.
- 3) Level III – chronic dilution factor $\geq 100:1$ but <500:1 or >500:1 and $Q \geq 1.0$ MGD
- 4) Level IV – chronic dilution >500:1 and $Q \leq 1.0$ MGD

06-096 CMR 530 (D)(1) specifies the criteria to be used in determining the minimum monitoring frequency requirements for WET, priority pollutant and analytical chemistry testing. Based on the 06-096 CMR 530 (D)(1) criteria, the permittee's facility falls into the Level III frequency category as the facility has a chronic dilution factor of >500:1 and a flow of ≥ 1.0 MGD. 06-096 CMR 530 (D)(1) specifies that routine screening and surveillance level testing requirements are as follows:

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

Screening level testing – Beginning 12 months prior to permit expiration and every five years thereafter.

Level	WET Testing	Priority pollutant testing	Analytical chemistry
III	1 per year	1 per year	4 per year

Surveillance level testing – Beginning upon issuance of the permit and lasting through 12 months prior to permit expiration.

Level	WET Testing	Priority pollutant testing	Analytical chemistry
III	1 per year	None required	1 per year

A review of the data on file with the Department indicates that to-date, the permittee has fulfilled the WET and chemical-specific testing requirements of 06-096 CMR 530. See **Attachment B** of this Fact Sheet for a summary of the WET test results and

Attachment C of this Fact Sheet for a summary of the chemical-specific test dates.

06-096 CMR 530 (D)(3)(b) states in part, *Dischargers in Levels III and IV may be waived from conducting surveillance testing for individual WET species or chemicals provided that testing in the preceding 60 months does not indicate any reasonable potential for exceedence as calculated pursuant to section 3(E).*

06-096 CMR 530 (3)(E) states *“For effluent monitoring data and the variability of the pollutant in the effluent, the Department shall apply the statistical approach in Section 3.3.2 and Table 3-2 of USEPA’s “Technical Support Document for Water Quality-Based Toxics Control” (USEPA Publication 505/2-90-001, March, 1991, EPA, Office of Water, Washington, D.C.) to data to determine whether water-quality based effluent limits must be included in a waste discharge license. Where it is determined through this approach that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action.”*

06-096 CMR 530(3) states, *“In determining if effluent limits are required, the Department shall consider all information on file and effluent testing conducted during the preceding 60 months. However, testing done in the performance of a Toxicity Reduction Evaluation (TRE) approved by the Department may be excluded from such evaluations.”*

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

WET evaluation

On 2/04/11, the Department conducted a statistical evaluation on the most recent 60 months of WET data that indicates the discharge does not have a reasonable potential (RP) to exceed the modified acute or chronic critical ambient water quality criteria (AWQC) thresholds (0.86% and 0.19%, respectively – mathematical inverses of the modified acute dilution factor of 117:1 and the chronic dilution factor of 517:1). As a result, this permit modification is not establishing WET limitations.

Given the absence of exceedences or reasonable potential to exceed critical WET thresholds for the brook trout or water flea, the permittee meets the surveillance level monitoring frequency waiver criteria found at 06-096 CMR 530 (D)(3)(b). This permitting action is carrying forward the requirement for the permittee to conduct screening level WET testing at a frequency of once per year (1/Year) on the brook trout and water flea. Screening level testing shall be completed in the 12-month period prior to the expiration date of this permit and every five years thereafter

In accordance with Special Condition L, *06-096 CMR 530 (2)(D)(4) Statement For Reduced/Waived Toxics Testing*, of this permit modification, the permittee must annually submit to the Department a written statement evaluating its current status for each of the conditions listed.

Chemical evaluation

06-096 CMR 530 (4)(C), states *“The background concentration of specific chemicals must be included in all calculations using the following procedures. The Department may publish and periodically update a list of default background concentrations for specific pollutants on a regional, watershed or statewide basis. In doing so, the Department shall use data collected from reference sites that are measured at points not significantly affected by point and non-point discharges and best calculated to accurately represent ambient water quality conditions. The Department shall use the same general methods as those in section 4(D) to determine background concentrations. For pollutants not listed by the Department, an assumed concentration of 10% of the applicable water quality criteria must be used in calculations.”* The Department has limited information on the background levels of metals in the water column in the Penobscot River in the vicinity of the permittee’s outfall. Therefore, a default background concentration of 10% of the applicable water quality criteria is being used in the calculations of this permitting action.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

06-096 CMR 530 (4)(E), states *“In allocating assimilative capacity for toxic pollutants, the Department shall hold a portion of the total capacity in an unallocated reserve to allow for new or changed discharges and non-point source contributions. The unallocated reserve must be reviewed and restored as necessary at intervals of not more than five years. The water quality reserve must be not less than 15% of the total assimilative quantity.”* Therefore, the Department is reserving 15% of the applicable water quality criteria in the calculations of this permitting action.

06-096 CMR 530 (3)(E) states *“... that a discharge contains pollutants or WET at levels that have a reasonable potential to cause or contribute to an exceedence of water quality criteria, appropriate water quality-based limits must be established in any licensing action.”*

06-096 CMR 530 (4)(F) states in part *“Where there is more than one discharge into the same fresh or estuarine receiving water or watershed, the Department shall consider the cumulative effects of those discharges when determining the need for and establishment of the level of effluent limits. The Department shall calculate the total allowable discharge quantity for specific pollutants, less the water quality reserve and background concentration, necessary to achieve or maintain water quality criteria at all points of discharge, and in the entire watershed. The total allowable discharge quantity for pollutants must be allocated consistent with the following principles.*

Evaluations must be done for individual pollutants of concern in each watershed or segment to assure that water quality criteria are met at all points in the watershed and, if appropriate, within tributaries of a larger river.

The total assimilative capacity, less the water quality reserve and background concentration, may be allocated among the discharges according to the past discharge quantities for each as a percentage of the total quantity of discharges, or another comparable method appropriate for a specific situation and pollutant. Past discharges of pollutants must be determined using the average concentration discharged during the past five years and the facility's licensed flow.

The amount of allowable discharge quantity may be no more than the past discharge quantity calculated using the statistical approach referred to in section 3(E) [Section 3.3.2 and Table 3-2 of USEPA's "Technical Support Document for Water Quality-Based Toxics Control"] of the rule, but in no event may allocations cause the water quality reserve amount to fall below the minimum referred to in 4(E) [15% of the total assimilative capacity]. Any difference between the total allowable discharge quantity and that allocated to existing dischargers must be added to the reserve.”

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

See **Attachment D** of this Fact Sheet for Department guidance that establishes protocols for establishing waste load allocations. The guidance states that the most protective of water quality becomes the facility's allocation. According to the 2/09/11 statistical evaluation (Report ID #342), pollutants of concern (aluminum, copper, and lead) are to be limited based on the segment allocation method.

06-096 CMR 530 (3)(D)(1) states, "*For specific chemicals, effluent limits must be expressed in total quantity that may be discharged and in effluent concentration. In establishing concentration, the Department may increase allowable values to reflect actual flows that are lower than permitted flows and/or provide opportunities for flow reductions and pollution prevention provided water quality criteria are not exceeded. With regard to concentration limits, the Department may review past and projected flows and set limits to reflect proper operation of the treatment facilities that will keep the discharge of pollutants to the minimum level practicable.*"

As not to penalize the permittee for operating at flows less than the permitted flow, the Department is establishing concentration limits based on a back calculation from the mass limit utilizing a multiplier of 2.0.

It is noted the Penobscot Indian Nation (PIN) has informally notified the Department of its intent to formally petition the Department to adopt a site specific fish consumption rate for a segment(s) of the Penobscot River for use in calculating human health based ambient water quality criteria (AWQC) specified by 06-096 CMR Department rule, Chapter 584, *Surface Water Quality Criteria For Toxic Pollutants*. Once petitioned, a formal public process as outlined in **Attachment E** of this Fact Sheet will be invoked and adhered to. Should an alternate fish consumption rate be adopted, this permit may be reopened pursuant to Special Condition O, *Reopening of Permit For Modifications*, of this permit to establish new or revised water quality based limits for pollutants that exceed or have a reasonable potential to exceed human health AWQC.

Segment allocation methodology

Historical Average:

For the segment allocation methodology, the historical average quantity (mass) for each pollutant of concern for each facility is calculated utilizing the arithmetic mean of the concentrated values reported for each pollutant, a conversion factor of 8.34 lbs/gallon and the monthly average permit limit for flow. The historical mass discharged for each pollutant for each facility is mathematically summed to determine the total mass discharged for each pollutant in the watershed. Based on the individual discharger's historical average, each discharger is assigned a percentage of the whole which is then utilized to determine the percent of the segment allocation for each pollutant for each

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

facility. For the permittee's facility, historical averages for total aluminum, total copper and total lead were calculated as follows:

Aluminum

Mass limits

Mean concentration (n=1) = 73 ug/L or 0.073 mg/L

Permit flow limit = 3.5 MGD

Historical average mass = (0.073 mg/L)(8.34)(3.5 MGD) = 2.13 lbs/day

The 2/09/11 statistical evaluation indicates the historical average mass of aluminum discharged by the permittee's facility is 0.81% of the aluminum discharged by the facilities on the Penobscot River and its tributaries. Therefore, the permittee's segment allocation for aluminum is calculated as 0.81% of the acute and chronic assimilative capacities of the river at Bangor, the most downstream facility minus the assimilative capacities assigned to the tributaries on the Penobscot River that have permitted discharges. The Department has calculated a chronic assimilative capacity of 1,126 lbs/day of aluminum at Bangor. Therefore, the mass segment allocation for aluminum for the permittee can be calculated as follows:

Monthly average (chronic) mass limitations for aluminum are calculated as follows:

Monthly average: (Chronic assimilative capacity mass)(% of total aluminum discharged)
(1,126 lbs/day)(0.0081) = 9.2 lbs/day

Since the adoption of 06-096 CMR 530, the Department has developed a policy for establishing equitable concentration limits in permits that are greater than calculated end-of-pipe concentrations. In general, most dischargers subject to the 06-096 CMR 530 testing requirements are discharging at or about 50% of the flow limitations established in their permits. This provides the Department with the flexibility to establish higher concentration limits in the permit while still maintaining compliance with the water quality based mass limitations. With an actual discharge flow at one-half (0.5) of permitted flow rate, a concentration limit of two times (mathematical inverse of 0.5) the calculated end-of-pipe concentration, will maintain compliance with water quality based mass limits. Therefore, this permitting action is establishing concentration limitations that are two (2) times higher than the calculated end-of-pipe concentrations. The permittee must keep in mind, if flows greater than 50% of the permitted flow are realized, the concentration in the effluent must be reduced proportionally to maintain compliance with the mass limitations.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

Aluminum

Concentration limits

Monthly average concentration for aluminum;

$$\frac{9.2 \text{ lbs/day}}{(3.5 \text{ MGD})(8.34 \text{ lbs/gal.})} = 0.32 \text{ mg/L}$$

$$(0.32 \text{ mg/L})(1,000 \text{ ug/mg})(2) = 640 \text{ ug/L}$$

Copper

Historical average mass

Mean concentration (n=6) = 30.7 ug/L or 0.0377 mg/L

Permit flow limit = 3.5 MGD

$$\text{Historical average mass} = (0.0377 \text{ mg/L})(8.34)(3.5 \text{ MGD}) = 1.1 \text{ lbs/day}$$

The 2/09/11 statistical evaluation indicates the historical average mass of copper discharged by the permittee is 7.49% of the copper discharged by the facilities on the Penobscot River and its tributaries. Therefore, the permittee's acute and chronic segment allocations for copper are calculated as 7.49% of the copper discharged on the Penobscot River and its tributaries. The Department has calculated an acute assimilative capacity of 35.94 lbs/day and a chronic assimilative capacity of 30.51 lbs/day of copper at Bangor, the most downstream facility on the Penobscot River. Therefore, the mass segment allocations for copper for the permittee can be calculated as follows:

$$\text{Daily maximum: (Acute assimilative capacity mass)(\% of total copper discharged)} \\ (35.94 \text{ lbs/day})(0.0749) = 2.7 \text{ lbs/day}$$

$$\text{Monthly average: (Chronic assimilative capacity mass)(\% of total copper discharged)} \\ (30.51 \text{ lbs/day})(0.0749) = 2.3 \text{ lbs/day}$$

Concentration limits:

Daily mass limit = 2.7 lbs/day

$$\frac{(2.7 \text{ lbs/day})}{(8.34 \text{ lbs/gal})(3.5 \text{ MGD})} = 0.092 \text{ mg/L}$$

$$(0.092 \text{ mg/L})(1,000 \text{ ug/mg})(2) = 184 \text{ ug/L}$$

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

Copper

Monthly average mass limit = 2.4 lbs/day

$$\frac{(2.3 \text{ lbs/day})}{(8.34 \text{ lbs/gal})(3.5 \text{ MGD})} = 0.079 \text{ mg/L}$$

$$(0.079 \text{ mg/L})(1,000 \text{ ug/mg})(2) = 158 \text{ ug/L}$$

Lead

Mass limits

Mean concentration (n=6) = 1.88 ug/L or 0.0018 mg/L

Permit flow limit = 3.5 MGD

$$\text{Historical average mass} = (0.0018 \text{ mg/L})(8.34)(3.5 \text{ MGD}) = 0.055 \text{ lbs/day}$$

The 2/09/11 statistical evaluation indicates the historical average mass of lead discharged by the permittee's facility is 1.47% of the lead discharged by the facilities on the Penobscot River and its tributaries. Therefore, permittee's segment allocation for lead is calculated as 1.47% of the chronic assimilative capacity of the river at Bangor, the most downstream facility minus the assimilative capacities assigned to the tributaries on the Penobscot River that have permitted discharges. The Department has calculated a chronic assimilative capacity of 5.33 lbs/day of lead at Bangor. Therefore, the mass segment allocation for lead for the permittee can be calculated as follows:

Monthly average mass for lead

(Chronic assimilative capacity mass)(% of total lead discharged)

$$(5.33 \text{ lbs/day})(0.0147) = 0.08 \text{ lbs/day}$$

Concentration limits

Monthly average concentration for lead;

$$\frac{0.08 \text{ lbs/day}}{(3.5 \text{ MGD})(8.34 \text{ lbs/gal.})} = 0.0027 \text{ mg/L}$$

$$(0.0027 \text{ mg/L})(1,000 \text{ ug/mg})(2) = 5.4 \text{ ug/L or } 5 \text{ ug/L}$$

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Secondary Treated Effluent

i. Whole Effluent Toxicity (WET) & Chemical-Specific Testing (cont'd):

As for the remaining chemical specific parameters tested to date, none of the test results in the 60-month evaluation period exceed or have a reasonable potential to exceed applicable acute, chronic or human health AWQC. Therefore, this permitting action is carrying forward the waived surveillance level reporting and monitoring frequency for analytical chemistry and priority pollutant testing. As with reduced WET testing, the permittee must file an annual certification with the Department pursuant to Special Condition L, *06-096 CMR 530 (2)(D)(4) Statement For Reduced/Waived Toxics Testing*, of this permit modification, the permittee must annually submit to the Department a written statement evaluating its current status for each of the conditions listed.

Beginning 12 months prior to the expiration date of the permit and every five years thereafter, the permittee shall conduct default screening level analytical chemistry testing at 1/Quarter and priority pollutant testing of 1/Year.

- j. Mercury: May 23, 2000: Pursuant to *Certain deposits and discharges prohibited*, Maine law, 38 M.R.S.A. § 420 and *Waste discharge licenses*, 38 M.R.S.A. § 413 and *Interim Effluent Limitations and Controls for the Discharge of Mercury*, 06-096 CMR 519 (last amended October 6, 2001), the Department issued a *Notice of Interim Limits for the Discharge of Mercury* to the permittee thereby administratively modifying WDL W001635-5L-B-R by establishing interim monthly average and daily maximum effluent concentration limits of 18.6 parts per trillion (ppt) and 27.8 ppt, respectively, and a minimum monitoring frequency requirement of four (4) tests per year for mercury. It is noted the limitations have not been incorporated into Special Condition A, *Effluent Limitations And Monitoring Requirements*, of this permit as limitations and monitoring frequencies are regulated separately through 38 M.R.S.A. § 413 and 06-096 CMR 519. However, the interim limitations remain in effect and enforceable and any modifications to the limits and/or monitoring requirements will be formalized outside of this permitting document.

Maine law 38 M.R.S.A., §420 1-B,(B)(1) states that a facility is not in violation of the AWQC for mercury if the facility is in compliance with an interim discharge limits established by the Department pursuant to section 413, subsection 11. A review of the Department's database for the period March 2004 through the present indicates mercury test results reported have ranged from 2.9 ppt to 7.5 ppt with an arithmetic mean (n=18) of 5.1 ppt.

Primary Treated Effluent

The applicant maintains a combined sewer system from which wet weather overflow has been documented. To address and control these events, the applicant has completed a Master Plan (Long-Term Control Plan) for its sewer systems and has considered various control options. The Department approved the Master Plan on December 28, 2002. The

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Primary Treated Effluent

plan addresses all of the relevant considerations contained in EPA’s CSO Policy, section II.C. See Federal Register, April 19, 1994. One element of the applicant’s Master Plan is to maximize existing infrastructure to convey as much excess wet weather flow to the treatment facility as practicable. However, due to the nature and volume of wet weather flows, it is not possible to provide secondary treatment for all flows that can be conveyed to the treatment plant site. Attempting to do so would cause upsets and damage to the secondary treatment process. Expansion of the secondary system would not be practicable since the facilities would be too large to effectively treat normal dry weather flows.

Given these circumstances, and consistent with EPA’s April 19, 1994 CSO Policy, section II.C.7, the Department has determined that primary treatment and disinfection (when required) is an appropriate means of best practicable treatment (BPT) for some excess CSO flows and this treatment be accomplished at the existing treatment facility site. A review of the Master Plan, the design of the existing secondary system and past operational records indicates that secondary treatment can be provided for flows up to a peak hourly flow rate of 3,260 gallons per minute (4.7 MGD) for one hour. However, to assure that the secondary treatment capacity is fully utilized, the permit contains a requirement for a High Flow Management Plan that will be updated periodically. Flows delivered to the treatment facility site in excess of that which can be given secondary treatment will receive primary treatment using a dedicated storm water clarifier and disinfection using sodium hypochlorite and dechlorinating with sodium bisulfate to achieve a daily maximum BPT limit of 1.0 mg/L. Since the flow receiving primary treatment will likely be dilute under wet weather conditions, traditional removal rates for primary treatment are not likely to be consistently achieved. Therefore, no minimum percent removal limitations have been established in this permitting action (“monitor” and “report only”) for waste water receiving primary treatment only.

- k. Flow: The monthly average and daily maximum flow reporting requirements from the previous permitting action are being carried forward in this permitting action.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Flow (n=20)

Value	Limit (MGD)	Range (MGD)	Average (MGD)
Daily Maximum	Report	0.11 – 12.8	4.8
Monthly Average	Report	0.11 – 8.74	2.6

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Primary Treated Effluent

- l. Surface Loading Rate: The daily maximum surface loading rate reporting requirement from the previous permitting action is being carried forward in this permitting action.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Surface Loading Rate (n=20)

Value	Limit (gpd/sf)	Range (gpd/sf)	Average (gpd/sf)
Daily Maximum	Report	28 – 2273	617

- m. Overflow occurrences: The monthly average overflow occurrences reporting requirement from the previous permitting action is being carried forward in this permitting action.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Overflow use, Occurrences (n=21)

Value	Limit (#days)	Range (#days)	Average (#days)
Monthly Average	Report	1 – 10	3

- n. Biochemical Oxygen Demand (BOD5) & Total Suspended Solids (TSS): This permitting action is carrying forward the daily maximum BOD5 and TSS reporting requirements from the previous permitting action.

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

BOD concentration (n=19)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Daily Maximum	Report	19 – 102	38

TSS concentration (n = 20)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)
Daily Maximum	Report	15 – 102	58

A review of the monthly DMR data for the period May 2005 – May 2009 indicate the monthly average BOD5 and TSS percent removals were 40% and 54%, respectively. This permitting action is carrying forward the monthly average reporting requirements for BOD5 and TSS percent removals.

6. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (cont'd)

Primary Treated Effluent

- o. *E. coli* and TRC: Bacterial contamination is the most direct water quality risk from wet weather discharge events and the permit contain limits for *E. coli* bacteria and total residual chlorine for those times of the year when disinfection is required to meet water quality standards. Since the primary effluent is somewhat more difficult to disinfect due to a higher organic content and flow variations, the use of a daily maximum of 64 col/100mL for *E. coli* as in the secondary effluent would be inappropriate. Using best professional judgment, the Department is carrying forward an *E. coli* daily maximum effluent concentration limitation of 427 col/100mL. Given the available dilution, this value is protective of receiving water quality. The total residual chlorine limit is being carried forward using the same considerations as for the secondary effluent (see Section 6(f) of this Fact Sheet).

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

***E. coli* bacteria (n = 2)**

Value	Limit (col/100 mL)	Range (col/100 mL)	Mean (col/100 mL)	Compliance
Daily Maximum	427	0 – 200	100	100%

A review of the monthly DMR data for the period May 2005 – May 2009 indicates the following:

Total Residual Chlorine (n = 2)

Value	Limit (mg/L)	Range (mg/L)	Average (mg/L)	Compliance
Daily Maximum	1.0	0.11 – 0.11	0.11	100%

7. DISCHARGE IMPACT ON RECEIVING WATER QUALITY

The Department acknowledges that the elimination of the three (3) remaining CSOs in the collection system and the secondary bypass (primary treated only) of sanitary waste water is a costly long term project. As Old Town’s waste water treatment facility and sewer collection system are upgraded and maintained in according to the CSO Master Plan and Nine Minimum Controls, there should be reductions in the frequency and volume of CSO activities and in the waste water receiving primary treatment only at the treatment plant and over time, improvement in the quality of the waste water discharge to the receiving waters over time. As permitted, the Department of Environmental Protection has determined the existing water uses will be maintained and protected.

The Department has made a best professional judgment via a current (2003) water quality model that the increase in BOD5 and TSS during the non-summer months as a result of the increased flow limit will not have a significant impact on ambient water quality conditions.

7. DISCHARGE IMPACT ON RECEIVING WATER QUALITY (cont'd)

If ambient water quality monitoring or future modeling determines that at full permitted discharge limits the permittee's discharge is causing or contributing to the non-attainment of standards, this permit will be re-opened per Special Condition O, *Reopening of Permit For Modifications*, to impose more stringent limitations to meet water quality standards.

8. PUBLIC COMMENTS

Public notice of this application was made in the *Penobscot Times* newspaper on or about May 7, 2009. The Department receives public comments on an application until the date a final agency action is taken on that application. Those persons receiving copies of draft permits shall have at least 30 days in which to submit comments on the draft or to request a public hearing, pursuant to *Application Processing Procedures for Waste Discharge Licenses*, 06-096 CMR 522 (effective January 12, 2001).


9. DEPARTMENT CONTACTS

Phyllis Rand
Division of Water Quality Management
Bureau of Land & Water Quality
Department of Environmental Protection
17 State House Station
Augusta, Maine 04333-0017 Telephone: (207) 287-7658 Fax: (207) 287-3435
e-mail: phyllis.a.rand@maine.gov

10. RESPONSE TO COMMENTS

During the period of March 24, 2011, through the issuance date of the permit/license, the Department solicited comments on the proposed draft permit/license to be issued for the discharge(s) from the permittee's facility. No comments were received from state or federal agencies or interested parties that resulted in any substantive change(s) in the terms and conditions of the permit. Therefore, the Department has not prepared a Response to Comments.

ATTACHMENT A




NOTES

1. REFER TO SPECIFICATIONS, SUCTION SIDE OF PUMPS MAY UTILIZE INLET PULSE ACCUMULATOR VERSUS PULSATION DAMPENER.
2. FOR LEGEND AND ADDITIONAL NOTES, REFER TO DRAWING PR-1.

INTAKE

AERATION SYSTEM

TO POST



OLD TOWN
WWTf

OLD TOWN

Great Works

Bradley

UNIV
OF MAINE

Webster

RIVER

RSCOT

B R I
A P L
E Y
B k

Stream

Otter

Oliver

Blac

2

5

4976

4975

4974

55'

4973

4972

4971

ATTACHMENT B

2/4/2011

WET TEST REPORT

Data for tests conducted for the period
04/Feb/2006 - 04/Feb/2011 period.



OLD TOWN

NPDES= ME010047

Effluent Limit: Acute (%) = 0.214

Chronic (%) = 0.193

Species	Test	Percent	Sample date	Critical %	Exception	RP
TROUT	A_NOEL	100	07/27/2008	0.214		
TROUT	C_NOEL	100	07/27/2008	0.193		
WATER FLEA	A_NOEL	35	07/27/2008	0.214		
WATER FLEA	C_NOEL	50	07/27/2008	0.193		

ATTACHMENT C

PRIORITY POLLUTANT DATA SUMMARY

Date Range: 04/Feb/2006 - 04/Feb/2011 period



Facility Name: OLD TOWN

NPDES: ME0100471

Test Date	Monthly (Flow MGD)	Daily	Total Test Number	Test # By Group						Clean	Hg
				M	V	BN	P	O	A		
03/24/2008	2.38	2.25	121	13	26	46	25	0	11	F	0
05/19/2008	1.83	1.22	121	13	26	46	25	0	11	T	0
07/27/2008	0.91	0.89	133	13	28	46	25	10	11	F	0
11/03/2008	1.85	1.22	121	13	26	46	25	0	11	F	0
03/24/2009	NR	NR	18	0	6	12	0	0	0	F	0
09/14/2009	0.79	0.86	124	13	28	46	25	1	11	F	0
09/20/2010	0.73	0.71	124	13	28	46	25	1	11	F	0

A = Acid O = Others P = Pesticides
 BN = Base Neutral M = Metals V = Volatiles

Parameter: A-BHC	Test date	Result (ug/l)	Lsthan
	09/20/2010	20.000	Y
	03/24/2008	0.200	Y
	05/19/2008	0.200	Y
	07/27/2008	0.200	Y
	11/03/2008	0.200	Y
	09/14/2009	0.200	Y
	09/20/2010	0.200	Y

Parameter: ACENAPHTHENE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: ACENAPHTHYLENE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: ACROLEIN	Test date	Result (ug/l)	Lsthan
	07/27/2008	500.000	Y
	09/14/2009	500.000	Y
	09/20/2010	500.000	Y

Parameter: ACRYLONITRILE	Test date	Result (ug/l)	Lsthan
	07/27/2008	2.000	Y
	09/14/2009	2.000	Y
	09/20/2010	2.000	Y

Parameter: A-ENDOSULFAN	Test date	Result (ug/l)	Lsthan
	03/24/2008	0.050	Y
	05/19/2008	0.050	Y
	07/27/2008	0.050	Y
	11/03/2008	0.050	Y
	09/14/2009	0.050	Y
	09/20/2010	0.050	Y

Parameter: ALDRIN	Test date	Result (ug/l)	Lsthan
	03/24/2008	0.150	Y
	05/19/2008	0.150	Y
	07/27/2008	0.150	Y
	11/03/2008	0.150	Y
	09/14/2009	0.150	Y
	09/20/2010	0.150	Y

Parameter: ALUMINUM	Test date	Result (ug/l)	Lsthan
	07/27/2008	73.000	N

Parameter: AMMONIA	Test date	Result (ug/l)	Lsthan
	07/27/2008	100.000	Y

Parameter: ANTHRACENE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y

Parameter: CHLORODIBROMOMETHAI	Test date	Result (ug/l)	Lsthan
	05/19/2008	6.000	Y
	07/27/2008	2.000	Y
	11/03/2008	6.000	Y
	09/14/2009	6.000	Y
	09/20/2010	6.000	Y

Parameter: CHLOROETHANE	Test date	Result (ug/l)	Lsthan
	03/24/2008	3.000	Y
	05/19/2008	3.000	Y
	07/27/2008	2.000	Y
	11/03/2008	3.000	Y
	09/14/2009	3.000	Y
	09/20/2010	3.000	Y

Parameter: CHLOROFORM	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: CHROMIUM	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	1.000	N
	11/03/2008	5.000	Y
	09/14/2009	0.800	N
	09/20/2010	1.000	Y

Parameter: CHRYSENE	Test date	Result (ug/l)	Lsthan
	03/24/2008	3.000	Y
	05/19/2008	3.000	Y
	07/27/2008	2.000	Y
	11/03/2008	3.000	Y
	09/14/2009	3.000	Y
	09/20/2010	3.000	Y

Parameter: COPPER	Test date	Result (ug/l)	Lsthan
	03/24/2008	3.000	Y
	05/19/2008	3.000	Y
	07/27/2008	2.000	Y
	11/03/2008	3.000	Y
	09/14/2009	3.000	Y
	09/20/2010	3.000	Y

Parameter: CYANIDE	Test date	Result (ug/l)	Lsthan
	03/24/2008	18.100	N
	05/19/2008	31.000	N
	07/27/2008	23.000	N
	11/03/2008	35.600	N
	09/14/2009	46.000	N
	09/20/2010	75.100	N

Parameter: CHLORODIBROMOMETHAI	Test date	Result (ug/l)	Lsthan
	03/24/2008	3.000	Y
	05/19/2008	3.000	Y
	07/27/2008	2.000	Y
	11/03/2008	3.000	Y
	09/14/2009	3.000	Y
	09/20/2010	3.000	Y

Parameter: CHLOROETHANE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: ISOPHORONE	Test date	Result (ug/l)	Lsthan
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: LEAD	Test date	Result (ug/l)	Lsthan
	03/24/2008	3.700	N
	05/19/2008	1.000	N
	07/27/2008	3.000	N
	11/03/2008	1.600	N
	09/14/2009	1.000	N
	09/20/2010	1.000	N

Parameter: MAGNESIUM	Test date	Result (ug/l)	Lsthan
----------------------	-----------	---------------	--------

Parameter: MERCURY	Test date	Result (ug/l)	Lsthan
	07/27/2008	7600.000	N
	03/23/2006	0.006	N
	06/22/2006	0.004	N
	09/28/2006	0.004	N
	12/21/2006	0.005	N
	03/27/2007	0.008	N
	06/28/2007	0.005	N
	09/13/2007	0.008	N
	12/26/2007	0.005	N
	03/24/2008	0.003	N
	05/19/2008	0.006	N
	07/28/2008	0.005	N
	11/03/2008	0.005	N
	03/30/2009	0.008	N
	06/30/2009	0.006	N
	09/14/2009	0.004	N
	12/23/2009	0.005	N
	03/31/2010	0.007	N
	06/29/2010	0.004	N
	09/20/2010	0.005	N
	09/29/2010	0.005	N


Parameter: METHYL BROMIDE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y
	11/03/2008	5.000	Y
	09/14/2009	5.000	Y
	09/20/2010	5.000	Y

Parameter: METHYL CHLORIDE	Test date	Result (ug/l)	Lsthan
	03/24/2008	5.000	Y
	05/19/2008	5.000	Y
	07/27/2008	2.000	Y


ATTACHMENT D

Maine Department of Environmental Protection
General Processing Steps in "DeTox"

I. Preparation




II. Segment Assimilative Capacity




Maine Department of Environmental Protection
General Processing Steps in "DeTox"

III. Evaluate History by Pollutant




IV. Determine Facility History Percentage




Maine Department of Environmental Protection
General Processing Steps in "DeTox"


V. Segment Allocation



VI. Individual Allocation




VII. Make Initial Allocation




Maine Department of Environmental Protection
General Processing Steps in "DeTox"

VIII. Evaluate Need for Effluent Limits



IX. Reallocation of Assimilative Capacity



MAINE DEPARTMENT OF ENVIRONMENTAL PROTECTION

MEMORANDUM

DATE: October 2008

TO: Interested Parties

FROM: Dennis Merrill, DEP

SUBJECT: DEP's system for evaluating toxicity from multiple discharges

Following the requirements of DEP's rules, Chapter 530, section 4(F), the Department is evaluating discharges of toxic pollutants into a freshwater river system in order to prevent cumulative impacts from multiple discharges. This is being through the use of a computer program known internally as "DeTox". The enclosed package of information is intended to introduce you to this system.

Briefly, the DeTox program evaluates each wastewater facility within a watershed in three different ways in order to characterize its effluent: 1) the facility's past history of discharges, 2) its potential toxicity at the point of discharge on an individual basis, and 3) the facility's contribution to cumulative toxicity within a river segment in conjunction with other facilities. The value that is most protective of water quality becomes the value that is held in the DeTox system as an allocation for the specific facility and pollutant.

The system is not static and uses a five-year "rolling" data window. This means that, over time, old test results drop off and newer ones are added. The intent of this process is to maintain current, uniform facility data to estimate contributions to a river's total allowable pollutant loading prior to each permit renewal.

Many facilities are required to do only a relatively small amount of pollutant testing on their effluent. This means, statistically, the fewer tests done, the greater the possibility of effluent limits being necessary based on the facility's small amount of data. To avoid this situation, most facilities, especially those with low dilution factors, should consider conducting more than the minimum number of tests required by the rules.

Attached you will find three documents with additional information on the DeTox system:

- Methods for evaluating the effects of multiple discharges of toxic pollutants
- Working definitions of terms used in the DeTox system
- Reviewing DeTox Reports
- Prototype facility and pollutant reports

If you have questions as you review these, please do not hesitate to contact me at Dennis.L.Merrill@maine.gov or 287-7788.

Maine Department of Environmental Protection

Methods for evaluating the effects of multiple discharges of toxic pollutants.

Reference: DEP Rules, Chapter 530, section 4(F)

To evaluate discharges of toxic pollutants into a freshwater river system and prevent cumulative impacts from multiple discharges, DEP uses a computer program called "DeTox" that functions as a mathematical evaluation tool.

It uses physical information about discharge sources and river conditions on file with the Department, established water quality criteria and reported effluent test information to perform these evaluations. Each toxic pollutant and associated water quality criterion for acute, chronic and/or human health effects is evaluated separately.

Each facility in a river drainage area has an assigned position code. This "address" is used to locate the facility on the river segment and in relation to other facilities and tributary streams. All calculations are performed in pounds per day to allow analysis on a mass balance. Pollutants are considered to be conservative in that once in the receiving water they will not easily degrade and have the potential to accumulate.

The process begins with establishing an assimilative capacity for each pollutant and water quality criterion at the most downstream point in the river segment. This calculation includes set-aside amounts for background and reserve quantities and assumed values for receiving water pH, temperature and hardness. The resulting amount of assimilative capacity is available for allocation among facilities on the river.

Each facility is evaluated to characterize its past discharge quantities. The historical discharge, in pounds per day, is figured using the average reported concentration and the facility's permitted flow. As has been past practice, a reasonable potential (RP) factor is used as a tool to estimate the largest discharge that may occur with a certain degree of statistical certainty. The RP factor is multiplied by the historical average to determine an allocation based on past discharges. The RP factor is also multiplied by the single highest test to obtain a maximum day estimate. Finally, the direct average without RP adjustment is used to determine the facility's percent contribution to the river segment in comparison to the sum of all discharges of the pollutant. This percent multiplied by the total assimilative capacity becomes the facility's discharge allocation used in evaluations of the segment loadings.

Additionally, individual facility discharges are evaluated as single sources, as they have been in the past to determine if local conditions are more limiting than a segment evaluation.

With all of this information, facilities are evaluated in three ways. The methods are:

1. The facility's past history. This is the average quantity discharged during the past five years multiplied by the applicable RP factor. This method is often the basis for an allocation when the discharge quantity is relatively small in comparison to the water quality based allocation.
2. An individual evaluation. This assumes no other discharge sources are present and the allowable quantity is the total available assimilative capacity. This method may be used when a local condition such as river flow at the point of discharge is the limiting factor.
3. A segment wide evaluation. This involves allocating the available assimilative capacity within a river segment based on a facility's percent of total past discharges. This method would be used when multiple discharges of the same pollutant to the same segment and the available assimilative capacity is relatively limited.

The value that is most protective of water quality becomes the facility's allocation that is held in the system for the specific facility and pollutant. It is important to note that the method used for allocation is facility and pollutant specific and different facilities on the same segment for the same pollutant can have different methods used depending on their individual situations.

Discharge amounts are always allocated to all facilities having a history of discharging a particular pollutant. This does not mean that effluent limits will be established in a permit. Limits are only needed when past discharge amounts suggest a reasonable potential to exceed a water quality based allocation, either on an individual or segment basis. Similar to past practices for single discharge evaluations, the single highest test value is multiplied by a RP factor and if product is greater than the water quality allowance, an effluent limit is established. It is important to remember an allocation is "banking" some assimilative capacity for a facility even if effluent limits are not needed.

Evaluations are also done for each tributary segment with the sum of discharge quantities in tributaries becoming a "point source" to the next most significant segment. In cases where a facility does not use all of its assimilative capacity, usually due to a more limiting individual water quality criterion, the unused quantity is rolled downstream and made available to other facilities.

The system is not static and uses a five-year rolling data window. Over time, old tests drop off and newer ones are added on. These changes cause the allocations and the need for effluent limits to shift over time to remain current with present conditions. The intent is to update a facility's data and relative contribution to a river's total assimilative capacity prior to each permit renewal. Many facilities are required to do only minimal testing to characterize their effluents. This creates a greater degree of statistical uncertainty about the true long-term quantities. Accordingly, with fewer tests the RP factor will be larger and result in a greater possibility of effluent limits being necessary. To avoid this situation, most facilities, especially those with relatively low dilution factors, are encouraged to conduct more than a minimum number of tests. It is generally to a facility's long-term benefit to have more tests on file since their RP factor will be reduced.

Maine Department of Environmental Protection

Working Definitions of Terms Used in the DeTox System.

Allocation. The amount of pollutant loading set aside for a facility. Separate amounts are set for each *water quality criterion*. Each pollutant having a history of being discharged will receive an allocation, but not all allocations become *effluent limits*. Allocation may be made in three ways: *historical allocation*, *individual allocation* or *segment allocation*.

Assimilative capacity. The amount of a pollutant that river segment can safely accept from point source discharges. It is determined for the most downstream point in a river segment using the *water quality criterion* and river flow. Separate capacities are set for acute, chronic and human health criteria as applicable for each pollutant. Calculation of this capacity includes factors for *reserve* and *background* amounts.

Background. A concentration of a pollutant that is assumed to be present in a receiving water but not attributable to discharges. By rule, this is set as a rebuttable presumption at 10% of the applicable *water quality criterion*.

Effluent limit. A numeric limit in a discharge permit specifically restricting the amount of a pollutant that may be discharged. An effluent limit is set only when the highest discharge, including an adjustment for *reasonable potential*, is greater than a facility's water quality based *allocation* for a pollutant.

Historical allocation (or RP history). One of three ways of developing an *allocation*. The facility's average history of discharges, in pounds at design flow, is multiplied by the appropriate *reasonable potential* factor. An allocation using this method does not become an *effluent limit*.

Historical discharge percentage. For each pollutant, the average discharge concentration for each facility in a segment is multiplied by the permitted flow (without including a *reasonable potential* factor). The amounts for all facilities are added together and a percent of the total is figured for each facility. When a facility has no detectable concentrations, that pollutant is assumed to be not present and it receives no percentage.

Individual allocation. One of three ways of developing an *allocation*. The facility's single highest discharge on record multiplied by the appropriate *reasonable potential* factor is compared to a water quality based quantity with an assumption that the facility is the only point source to that receiving water. If the RP-adjusted amount is larger, the water quality amount may become an *effluent limit*.

Less than. A qualification on a laboratory report indicating the concentration of a pollutant was below a certain concentration. Such a result is evaluated as being one half of the Department's reporting limit in most calculations.

Reasonable potential (RP). A statistical method to determine the highest amount of a pollutant likely to be present at any time based on the available test results. The method produces a value or RP factor that is multiplied by test results. The method relies on an EPA guidance document, and considers the coefficient of variation and the number of tests. Generally, the fewer number of tests, the higher the RP factor.

Reserve. An assumed concentration of a pollutant that set aside to account for non-point source of a pollutant and to allow new discharges of a pollutant. By rule this is set at 15% of the applicable *water quality criterion*.

Segment allocation. One of three ways of developing an *allocation*. The amount is set by multiplying a facility's *historical discharge percentage* for a specific pollutant by the *assimilative capacity* for that pollutant and criterion. A facility will have different allocation percentages for each pollutant. This amount may become an *effluent limit*.

Tributary. A stream flowing into a larger one. A total pollutant load is set by adding the all facilities *allocations* on the tributary and treating this totaled amount as a "point source" to the next larger segment.

Water quality criteria. Standards for acceptable in-stream or ambient levels of pollutants. These are established in the Department's Chapter 584 and are expressed as concentrations in ug/L. There may be separate standards for acute and chronic protection aquatic life and/or human health. Each criterion becomes a separate standard. Different stream flows are used in the calculation of each.

ATTACHMENT E

Explanatory Statement of Process DEP Will Follow in the Development of Site Specific Water Quality Criteria

References: 38 MRSA, section 420(2)(B) and DEP Rules, Chapters 2 and 584(3)(B)

The BEP has initial jurisdiction for issuance of permits that have limits based on site specific criteria ("SSC") developed pursuant to 38 MRSA, Section 420(2)(B). Typically, requests for SSC will come to the Department staff from one of two sources. A discharge source may have information from studies to indicate that statewide criteria are not appropriate for a given pollutant and location. Alternatively, third parties may have information regarding the unique or different uses of a particular water body or may have information about the relative toxicity of certain pollutants. In any event, a request for SSC must be supported by appropriate scientific studies conducted according to a plan of study approved in advance by the Department in consultation with EPA and the Bureau of Health if human health criteria are involved.

Because SSC are implemented through permit limits, they must be considered in the context of permit issuance or modification proceeding. If a permit issuance or renewal is not pending, any person can request that the Department open for modification a current permit for any cause described in 38 MRSA, Section 414-A(5). See also 38 MRSA, Section 341-D(3). Below are the steps that would likely be followed for consideration of SSC, with options for different processes depending on when and how a person intends to develop the technical information in support of the SSC request. This explanation of process is intended solely as advice to assist persons in exercising their options to request site specific criteria as part of a licensing proceeding under Chapter 584, and is not intended to be judicially enforceable.

1. Initial contact is made with DEP staff, indicating a desire to institute a Site Specific Criteria (SSC) proceeding. A petitioner must file with the Department a petition requesting that the BEP assume jurisdiction of the licensing action and making the necessary showing in support of the request for SSC, as described in 06-096 CMR Chapter 584. This will include, but is not limited to, the pollutants and/or issues of concern, and an outline of the proposed studies and process the party intends to use.
2. At the time a petition is filed with the Department, the petitioner must post a public notice in a newspaper having general circulation in the area that would be affected by the SSC. The Department will (by certified mail) notify potentially affected permitted discharge sources and interested parties of record for those permits. Any person may comment on the pending petition. A public hearing may be requested in accordance with the public notice. A service list of potentially interested parties will also be developed.
3. The DEP will prepare recommendations on whether BEP should dismiss or take up the petition. This, together with any comments received on the petition, will be forwarded to the BEP and the matter will be placed on the BEP's agenda. These materials will also be distributed to the service list.
4. The BEP will consider whether a petition includes the necessary information, as provided in Chapter 584. If the BEP grants initial approval of the petition, all permits that may be

affected by a decision to establish a SSC will be reopened for modification consideration in the same proceeding. If the petition is denied, the license that is the subject of the request, if it is being considered for renewal, will be sent back to the DEP for processing.

5. If the Board grants initial approval of the petition for SSC, the petitioner will prepare a plan of study for SSC investigations and submit it to the DEP staff. The topics to be included in the plan are described in Chapter 584(3)(B). The Department may hold pre-submission conferences with the petitioner and other interested parties. At that time, the parties will discuss issues such as the general scope of the study, the participants, existing studies, and any studies that may be proposed by other parties.
6. The DEP, EPA and, if human health criteria are involved, the Bureau of Health will review the Plan(s) of Study. The Department may approve, approve with conditions or not approve a Plan of Study. If a plan is not approved, the deficiencies and criteria for their correction will be clearly identified and opportunity provided for their correction. Department determinations on plans of study are not subject to appeal. All correspondence will be copied to the service list.
7. The approved Plan of Study will then be implemented. In order to capture seasonal variations, studies using sampling programs may continue for a year or more. Those relying on demographic surveys or literature searches may be done in less time.
8. A report of the studies will be provided to the DEP and the service list. Interested parties will be provided a time specified by the Department, but at least 30 days, in which to provide comments. DEP, EPA and, if appropriate, the Bureau of Health will review the report and comments and formulate a technical analysis.
9. The DEP will provide staff recommendations to the BEP as to whether a public hearing should be held. When requested by an affected licensee or when there is creditable conflicting technical information that a hearing will help clarify, a public hearing will be held. Copies of the study reports and all comments received will be provided to the BEP. If no hearing is recommended, the staff will provide a draft order for acceptance or denial of the SCC request.
10. The BEP will either schedule a public hearing or hear argument at a public meeting on staff recommendations.
11. If scheduled, a public hearing will be conducted pursuant to 5 MRSA, Chapter 375, Subchapter IV. Affected licensees have a right to participate in a public hearing and this constitutes their opportunity for hearing on license modifications that may result from SSC determinations. All other parties must petition to intervene in the hearing if they so desire. The Department will then prepare a summary of public comments and staff recommendations and place these on the BEP's agenda.

12. If the BEP decides to set SSC different from the state-wide criteria in Appendix A of Chapter 584, it will direct the staff to prepare permit modifications for affected discharge sources.
13. The staff will prepare draft permit modifications to each discharge source affected, and will notice EPA and other interested parties consistent with Chapter 522.
14. After receiving comments on the draft permits, the staff will prepare proposed permit modifications and place them on the BEP's agenda for consideration.
15. Once approved by the BEP, the modified permits will become valid and subject to the normal appeal provisions of law.

August 2006

ATTACHMENT F

CHAPTER 530(2)(D)(4) CERTIFICATION

MEPDES# _____ Facility Name _____

Since the effective date of your permit have there been:	NO	YES (Describe in Comments)
1. changes in the number or types of non-domestic wastes contributed directly or indirectly to the wastewater treatment works that may increase the toxicity of the discharge?		
2. changes in the operation of the treatment works that may increase the toxicity of the discharge?		
3. changes in industrial manufacturing processes contributing wastewater to the treatment works that may increase the toxicity of the discharge?		

COMMENTS:

Name(print) _____

Signature _____ Date _____

This document must be signed by the permittee or their legal representative.

This form may be used to meet the requirements of Chap 530(2)(D)(4). This Chapter requires all dischargers having waived or reduced Toxic testing to file a statement with the Department describing changes to the waste being contributed to their system as outlined above. As an alternative the discharger may submit a signed letter containing the same information.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

CONTENTS

SECTION	TOPIC	PAGE
A	GENERAL PROVISIONS	
1	General compliance	2
2	Other materials	2
3	Duty to Comply	2
4	Duty to provide information	2
5	Permit actions	2
6	Reopener clause	2
7	Oil and hazardous substances	2
8	Property rights	3
9	Confidentiality	3
10	Duty to reapply	3
11	Other laws	3
12	Inspection and entry	3
B	OPERATION AND MAINTENANCE OF FACILITIES	
1	General facility requirements	3
2	Proper operation and maintenance	4
3	Need to halt reduce not a defense	4
4	Duty to mitigate	4
5	Bypasses	4
6	Upsets	5
C	MONITORING AND RECORDS	
1	General requirements	6
2	Representative sampling	6
3	Monitoring and records	6
D	REPORTING REQUIREMENTS	
1	Reporting requirements	7
2	Signatory requirement	8
3	Availability of reports	8
4	Existing manufacturing, commercial, mining, and silvicultural dischargers	8
5	Publicly owned treatment works	9
E	OTHER PROVISIONS	
1	Emergency action - power failure	9
2	Spill prevention	10
3	Removed substances	10
4	Connection to municipal sewer	10
F	DEFINITIONS	10

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

A. GENERAL PROVISIONS

1. General compliance. All discharges shall be consistent with the terms and conditions of this permit; any changes in production capacity or process modifications which result in changes in the quantity or the characteristics of the discharge must be authorized by an additional license or by modifications of this permit; it shall be a violation of the terms and conditions of this permit to discharge any pollutant not identified and authorized herein or to discharge in excess of the rates or quantities authorized herein or to violate any other conditions of this permit.

2. Other materials. Other materials ordinarily produced or used in the operation of this facility, which have been specifically identified in the application, may be discharged at the maximum frequency and maximum level identified in the application, provided:

- (a) They are not
 - (i) Designated as toxic or hazardous under the provisions of Sections 307 and 311, respectively, of the Federal Water Pollution Control Act; Title 38, Section 420, Maine Revised Statutes; or other applicable State Law; or
 - (ii) Known to be hazardous or toxic by the licensee.
- (b) The discharge of such materials will not violate applicable water quality standards.

3. Duty to comply. The permittee must comply with all conditions of this permit. Any permit noncompliance constitutes a violation of State law and the Clean Water Act and is grounds for enforcement action; for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application.

- (a) The permittee shall comply with effluent standards or prohibitions established under section 307(a) of the Clean Water Act, and 38 MRSA, §420 or Chapter 530.5 for toxic pollutants within the time provided in the regulations that establish these standards or prohibitions, even if the permit has not yet been modified to incorporate the requirement.
- (b) Any person who violates any provision of the laws administered by the Department, including without limitation, a violation of the terms of any order, rule license, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

4. Duty to provide information. The permittee shall furnish to the Department, within a reasonable time, any information which the Department may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit or to determine compliance with this permit. The permittee shall also furnish to the Department upon request, copies of records required to be kept by this permit.

5. Permit actions. This permit may be modified, revoked and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition.

6. Reopener clause. The Department reserves the right to make appropriate revisions to this permit in order to establish any appropriate effluent limitations, schedule of compliance or other provisions which may be authorized under 38 MRSA, §414-A(5).

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

7. Oil and hazardous substances. Nothing in this permit shall be construed to preclude the institution of any legal action or relieve the permittee from any responsibilities, liabilities or penalties to which the permittee is or may be subject under section 311 of the Federal Clean Water Act; section 106 of the Federal Comprehensive Environmental Response, Compensation and Liability Act of 1980; or 38 MRSA §§ 1301, et. seq.

8. Property rights. This permit does not convey any property rights of any sort, or any exclusive privilege.

9. Confidentiality of records. 38 MRSA §414(6) reads as follows. "Any records, reports or information obtained under this subchapter is available to the public, except that upon a showing satisfactory to the department by any person that any records, reports or information, or particular part or any record, report or information, other than the names and addresses of applicants, license applications, licenses, and effluent data, to which the department has access under this subchapter would, if made public, divulge methods or processes that are entitled to protection as trade secrets, these records, reports or information must be confidential and not available for public inspection or examination. Any records, reports or information may be disclosed to employees or authorized representatives of the State or the United States concerned with carrying out this subchapter or any applicable federal law, and to any party to a hearing held under this section on terms the commissioner may prescribe in order to protect these confidential records, reports and information, as long as this disclosure is material and relevant to any issue under consideration by the department."

10. Duty to reapply. If the permittee wishes to continue an activity regulated by this permit after the expiration date of this permit, the permittee must apply for and obtain a new permit.

11. Other laws. The issuance of this permit does not authorize any injury to persons or property or invasion of other property rights, nor does it relieve the permittee of its obligation to comply with other applicable Federal, State or local laws and regulations.

12. Inspection and entry. The permittee shall allow the Department, or an authorized representative (including an authorized contractor acting as a representative of the EPA Administrator), upon presentation of credentials and other documents as may be required by law, to:

- (a) Enter upon the permittee's premises where a regulated facility or activity is located or conducted, or where records must be kept under the conditions of this permit;
- (b) Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit;
- (c) Inspect at reasonable times any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this permit; and
- (d) Sample or monitor at reasonable times, for the purposes of assuring permit compliance or as otherwise authorized by the Clean Water Act, any substances or parameters at any location.

B. OPERATION AND MAINTENANCE OF FACILITIES

1. General facility requirements.

- (a) The permittee shall collect all waste flows designated by the Department as requiring treatment and discharge them into an approved waste treatment facility in such a manner as to

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- maximize removal of pollutants unless authorization to the contrary is obtained from the Department.
- (b) The permittee shall at all times maintain in good working order and operate at maximum efficiency all waste water collection, treatment and/or control facilities.
 - (c) All necessary waste treatment facilities will be installed and operational prior to the discharge of any wastewaters.
 - (d) Final plans and specifications must be submitted to the Department for review prior to the construction or modification of any treatment facilities.
 - (e) The permittee shall install flow measuring facilities of a design approved by the Department.
 - (f) The permittee must provide an outfall of a design approved by the Department which is placed in the receiving waters in such a manner that the maximum mixing and dispersion of the wastewaters will be achieved as rapidly as possible.

2. Proper operation and maintenance. The permittee shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the permittee to achieve compliance with the conditions of this permit. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of back-up or auxiliary facilities or similar systems which are installed by a permittee only when the operation is necessary to achieve compliance with the conditions of the permit.

3. Need to halt or reduce activity not a defense. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit.

4. Duty to mitigate. The permittee shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this permit which has a reasonable likelihood of adversely affecting human health or the environment.

5. Bypasses.

- (a) Definitions.
 - (i) Bypass means the intentional diversion of waste streams from any portion of a treatment facility.
 - (ii) Severe property damage means substantial physical damage to property, damage to the treatment facilities which causes them to become inoperable, or substantial and permanent loss of natural resources which can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production.
- (b) Bypass not exceeding limitations. The permittee may allow any bypass to occur which does not cause effluent limitations to be exceeded, but only if it also is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions of paragraphs (c) and (d) of this section.
- (c) Notice.
 - (i) Anticipated bypass. If the permittee knows in advance of the need for a bypass, it shall submit prior notice, if possible at least ten days before the date of the bypass.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (ii) Unanticipated bypass. The permittee shall submit notice of an unanticipated bypass as required in paragraph D(1)(f), below. (24-hour notice).
- (d) Prohibition of bypass.
 - (i) Bypass is prohibited, and the Department may take enforcement action against a permittee for bypass, unless:
 - (A) Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage;
 - (B) There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass which occurred during normal periods of equipment downtime or preventive maintenance; and
 - (C) The permittee submitted notices as required under paragraph (c) of this section.
 - (ii) The Department may approve an anticipated bypass, after considering its adverse effects, if the Department determines that it will meet the three conditions listed above in paragraph (d)(i) of this section.

6. Upsets.

- (a) Definition. Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the permittee. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation.
- (b) Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of paragraph (c) of this section are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review.
- (c) Conditions necessary for a demonstration of upset. A permittee who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs, or other relevant evidence that:
 - (i) An upset occurred and that the permittee can identify the cause(s) of the upset;
 - (ii) The permitted facility was at the time being properly operated; and
 - (iii) The permittee submitted notice of the upset as required in paragraph D(1)(f) , below. (24 hour notice).
 - (iv) The permittee complied with any remedial measures required under paragraph B(4).
- (d) Burden of proof. In any enforcement proceeding the permittee seeking to establish the occurrence of an upset has the burden of proof.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

C. MONITORING AND RECORDS

1. General Requirements. This permit shall be subject to such monitoring requirements as may be reasonably required by the Department including the installation, use and maintenance of monitoring equipment or methods (including, where appropriate, biological monitoring methods). The permittee shall provide the Department with periodic reports on the proper Department reporting form of monitoring results obtained pursuant to the monitoring requirements contained herein.

2. Representative sampling. Samples and measurements taken as required herein shall be representative of the volume and nature of the monitored discharge. If effluent limitations are based wholly or partially on quantities of a product processed, the permittee shall ensure samples are representative of times when production is taking place. Where discharge monitoring is required when production is less than 50%, the resulting data shall be reported as a daily measurement but not included in computation of averages, unless specifically authorized by the Department.

3. Monitoring and records.

- (a) Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity.
- (b) Except for records of monitoring information required by this permit related to the permittee's sewage sludge use and disposal activities, which shall be retained for a period of at least five years, the permittee shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this permit, and records of all data used to complete the application for this permit, for a period of at least 3 years from the date of the sample, measurement, report or application. This period may be extended by request of the Department at any time.
- (c) Records of monitoring information shall include:
 - (i) The date, exact place, and time of sampling or measurements;
 - (ii) The individual(s) who performed the sampling or measurements;
 - (iii) The date(s) analyses were performed;
 - (iv) The individual(s) who performed the analyses;
 - (v) The analytical techniques or methods used; and
 - (vi) The results of such analyses.
- (d) Monitoring results must be conducted according to test procedures approved under 40 CFR part 136, unless other test procedures have been specified in the permit.
- (e) State law provides that any person who tampers with or renders inaccurate any monitoring devices or method required by any provision of law, or any order, rule license, permit approval or decision is subject to the penalties set forth in 38 MRSA, §349.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

D. REPORTING REQUIREMENTS

1. Reporting requirements.

- (a) Planned changes. The permittee shall give notice to the Department as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required only when:
 - (i) The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in 40 CFR 122.29(b); or
 - (ii) The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants which are subject neither to effluent limitations in the permit, nor to notification requirements under Section D(4).
 - (iii) The alteration or addition results in a significant change in the permittee's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan;
- (b) Anticipated noncompliance. The permittee shall give advance notice to the Department of any planned changes in the permitted facility or activity which may result in noncompliance with permit requirements.
- (c) Transfers. This permit is not transferable to any person except upon application to and approval of the Department pursuant to 38 MRSA, § 344 and Chapters 2 and 522.
- (d) Monitoring reports. Monitoring results shall be reported at the intervals specified elsewhere in this permit.
 - (i) Monitoring results must be reported on a Discharge Monitoring Report (DMR) or forms provided or specified by the Department for reporting results of monitoring of sludge use or disposal practices.
 - (ii) If the permittee monitors any pollutant more frequently than required by the permit using test procedures approved under 40 CFR part 136 or as specified in the permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Department.
 - (iii) Calculations for all limitations which require averaging of measurements shall utilize an arithmetic mean unless otherwise specified by the Department in the permit.
- (e) Compliance schedules. Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this permit shall be submitted no later than 14 days following each schedule date.
- (f) Twenty-four hour reporting.
 - (i) The permittee shall report any noncompliance which may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the permittee becomes aware of the circumstances. A written submission shall also be provided within 5 days of the time the permittee becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance.

(ii) The following shall be included as information which must be reported within 24 hours under this paragraph.

(A) Any unanticipated bypass which exceeds any effluent limitation in the permit.

(B) Any upset which exceeds any effluent limitation in the permit.

(C) Violation of a maximum daily discharge limitation for any of the pollutants listed by the Department in the permit to be reported within 24 hours.

(iii) The Department may waive the written report on a case-by-case basis for reports under paragraph (f)(ii) of this section if the oral report has been received within 24 hours.

(g) Other noncompliance. The permittee shall report all instances of noncompliance not reported under paragraphs (d), (e), and (f) of this section, at the time monitoring reports are submitted. The reports shall contain the information listed in paragraph (f) of this section.

(h) Other information. Where the permittee becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Department, it shall promptly submit such facts or information.

2. Signatory requirement. All applications, reports, or information submitted to the Department shall be signed and certified as required by Chapter 521, Section 5 of the Department's rules. State law provides that any person who knowingly makes any false statement, representation or certification in any application, record, report, plan or other document filed or required to be maintained by any order, rule, permit, approval or decision of the Board or Commissioner is subject to the penalties set forth in 38 MRSA, §349.

3. Availability of reports. Except for data determined to be confidential under A(9), above, all reports prepared in accordance with the terms of this permit shall be available for public inspection at the offices of the Department. As required by State law, effluent data shall not be considered confidential. Knowingly making any false statement on any such report may result in the imposition of criminal sanctions as provided by law.

4. Existing manufacturing, commercial, mining, and silvicultural dischargers. In addition to the reporting requirements under this Section, all existing manufacturing, commercial, mining, and silvicultural dischargers must notify the Department as soon as they know or have reason to believe:

(a) That any activity has occurred or will occur which would result in the discharge, on a routine or frequent basis, of any toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":

(i) One hundred micrograms per liter (100 ug/l);

(ii) Two hundred micrograms per liter (200 ug/l) for acrolein and acrylonitrile; five hundred micrograms per liter (500 ug/l) for 2,4-dinitrophenol and for 2-methyl-4,6-dinitrophenol; and one milligram per liter (1 mg/l) for antimony;

(iii) Five (5) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or

(iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

- (b) That any activity has occurred or will occur which would result in any discharge, on a non-routine or infrequent basis, of a toxic pollutant which is not limited in the permit, if that discharge will exceed the highest of the following "notification levels":
- (i) Five hundred micrograms per liter (500 ug/l);
 - (ii) One milligram per liter (1 mg/l) for antimony;
 - (iii) Ten (10) times the maximum concentration value reported for that pollutant in the permit application in accordance with Chapter 521 Section 4(g)(7); or
 - (iv) The level established by the Department in accordance with Chapter 523 Section 5(f).

5. Publicly owned treatment works.

- (a) All POTWs must provide adequate notice to the Department of the following:
- (i) Any new introduction of pollutants into the POTW from an indirect discharger which would be subject to section 301 or 306 of CWA or Chapter 528 if it were directly discharging those pollutants.
 - (ii) Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of issuance of the permit.
 - (iii) For purposes of this paragraph, adequate notice shall include information on (A) the quality and quantity of effluent introduced into the POTW, and (B) any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW.
- (b) When the effluent discharged by a POTW for a period of three consecutive months exceeds 80 percent of the permitted flow, the permittee shall submit to the Department a projection of loadings up to the time when the design capacity of the treatment facility will be reached, and a program for maintaining satisfactory treatment levels consistent with approved water quality management plans.

E. OTHER REQUIREMENTS

1. Emergency action - power failure. Within thirty days after the effective date of this permit, the permittee shall notify the Department of facilities and plans to be used in the event the primary source of power to its wastewater pumping and treatment facilities fails as follows.

- (a) For municipal sources. During power failure, all wastewaters which are normally treated shall receive a minimum of primary treatment and disinfection. Unless otherwise approved, alternate power supplies shall be provided for pumping stations and treatment facilities. Alternate power supplies shall be on-site generating units or an outside power source which is separate and independent from sources used for normal operation of the wastewater facilities.
- (b) For industrial and commercial sources. The permittee shall either maintain an alternative power source sufficient to operate the wastewater pumping and treatment facilities or halt, reduce or otherwise control production and or all discharges upon reduction or loss of power to the wastewater pumping or treatment facilities.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

2. Spill prevention. (applicable only to industrial sources) Within six months of the effective date of this permit, the permittee shall submit to the Department for review and approval, with or without conditions, a spill prevention plan. The plan shall delineate methods and measures to be taken to prevent and or contain any spills of pulp, chemicals, oils or other contaminants and shall specify means of disposal and or treatment to be used.

3. Removed substances. Solids, sludges trash rack cleanings, filter backwash, or other pollutants removed from or resulting from the treatment or control of waste waters shall be disposed of in a manner approved by the Department.

4. Connection to municipal sewer. (applicable only to industrial and commercial sources) All wastewaters designated by the Department as treatable in a municipal treatment system will be cosigned to that system when it is available. This permit will expire 90 days after the municipal treatment facility becomes available, unless this time is extended by the Department in writing.

F. DEFINITIONS. For the purposes of this permit, the following definitions shall apply. Other definitions applicable to this permit may be found in Chapters 520 through 529 of the Department's rules

Average means the arithmetic mean of values taken at the frequency required for each parameter over the specified period. For bacteria, the average shall be the geometric mean.

Average monthly discharge limitation means the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month. Except, however, bacteriological tests may be calculated as a geometric mean.

Average weekly discharge limitation means the highest allowable average of daily discharges over a calendar week, calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Best management practices ("BMPs") means schedules of activities, prohibitions of practices, maintenance procedures, and other management practices to prevent or reduce the pollution of waters of the State. BMPs also include treatment requirements, operating procedures, and practices to control plant site runoff, spillage or leaks, sludge or waste disposal, or drainage from raw material storage.

Composite sample means a sample consisting of a minimum of eight grab samples collected at equal intervals during a 24 hour period (or a lesser period as specified in the section on monitoring and reporting) and combined proportional to the flow over that same time period.

Continuous discharge means a discharge which occurs without interruption throughout the operating hours of the facility, except for infrequent shutdowns for maintenance, process changes, or other similar activities.

Daily discharge means the discharge of a pollutant measured during a calendar day or any 24-hour period that reasonably represents the calendar day for purposes of sampling. For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the average measurement of the pollutant over the day.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

Discharge Monitoring Report ("DMR") means the EPA uniform national form, including any subsequent additions, revisions, or modifications for the reporting of self-monitoring results by permittees. DMRs must be used by approved States as well as by EPA. EPA will supply DMRs to any approved State upon request. The EPA national forms may be modified to substitute the State Agency name, address, logo, and other similar information, as appropriate, in place of EPA's.

Flow weighted composite sample means a composite sample consisting of a mixture of aliquots collected at a constant time interval, where the volume of each aliquot is proportional to the flow rate of the discharge.

Grab sample means an individual sample collected in a period of less than 15 minutes.

Interference means a Discharge which, alone or in conjunction with a discharge or discharges from other sources, both:

- (1) Inhibits or disrupts the POTW, its treatment processes or operations, or its sludge processes, use or disposal; and
- (2) Therefore is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation) or of the prevention of sewage sludge use or disposal in compliance with the following statutory provisions and regulations or permits issued thereunder (or more stringent State or local regulations): Section 405 of the Clean Water Act, the Solid Waste Disposal Act (SWDA) (including title II, more commonly referred to as the Resource Conservation and Recovery Act (RCRA), and including State regulations contained in any State sludge management plan prepared pursuant to subtitle D of the SWDA), the Clean Air Act, the Toxic Substances Control Act, and the Marine Protection, Research and Sanctuaries Act.

Maximum daily discharge limitation means the highest allowable daily discharge.

New source means any building, structure, facility, or installation from which there is or may be a discharge of pollutants, the construction of which commenced:

- (a) After promulgation of standards of performance under section 306 of CWA which are applicable to such source, or
- (b) After proposal of standards of performance in accordance with section 306 of CWA which are applicable to such source, but only if the standards are promulgated in accordance with section 306 within 120 days of their proposal.

Pass through means a discharge which exits the POTW into waters of the State in quantities or concentrations which, alone or in conjunction with a discharge or discharges from other sources, is a cause of a violation of any requirement of the POTW's NPDES permit (including an increase in the magnitude or duration of a violation).

Permit means an authorization, license, or equivalent control document issued by EPA or an approved State to implement the requirements of 40 CFR parts 122, 123 and 124. Permit includes an NPDES general permit (Chapter 529). Permit does not include any permit which has not yet been the subject of final agency action, such as a draft permit or a proposed permit.

Person means an individual, firm, corporation, municipality, quasi-municipal corporation, state agency, federal agency or other legal entity.

MAINE POLLUTANT DISCHARGE ELIMINATION SYSTEM PERMIT

STANDARD CONDITIONS APPLICABLE TO ALL PERMITS

Point source means any discernible, confined and discrete conveyance, including, but not limited to, any pipe, ditch, channel, tunnel, conduit, well, discrete fissure, container, rolling stock, concentrated animal feeding operation or vessel or other floating craft, from which pollutants are or may be discharged.

Pollutant means dredged spoil, solid waste, junk, incinerator residue, sewage, refuse, effluent, garbage, sewage sludge, munitions, chemicals, biological or radiological materials, oil, petroleum products or byproducts, heat, wrecked or discarded equipment, rock, sand, dirt and industrial, municipal, domestic, commercial or agricultural wastes of any kind.

Process wastewater means any water which, during manufacturing or processing, comes into direct contact with or results from the production or use of any raw material, intermediate product, finished product, byproduct, or waste product.

Publicly owned treatment works ("POTW") means any facility for the treatment of pollutants owned by the State or any political subdivision thereof, any municipality, district, quasi-municipal corporation or other public entity.

Septage means, for the purposes of this permit, any waste, refuse, effluent sludge or other material removed from a septic tank, cesspool, vault privy or similar source which concentrates wastes or to which chemicals have been added. Septage does not include wastes from a holding tank.

Time weighted composite means a composite sample consisting of a mixture of equal volume aliquots collected over a constant time interval.

Toxic pollutant includes any pollutant listed as toxic under section 307(a)(1) or, in the case of sludge use or disposal practices, any pollutant identified in regulations implementing section 405(d) of the CWA. Toxic pollutant also includes those substances or combination of substances, including disease causing agents, which after discharge or upon exposure, ingestion, inhalation or assimilation into any organism, including humans either directly through the environment or indirectly through ingestion through food chains, will, on the basis of information available to the board either alone or in combination with other substances already in the receiving waters or the discharge, cause death, disease, abnormalities, cancer, genetic mutations, physiological malfunctions, including malfunctions in reproduction, or physical deformations in such organism or their offspring.

Wetlands means those areas that are inundated or saturated by surface or ground water at a frequency and duration sufficient to support, and that under normal circumstances do support, a prevalence of vegetation typically adapted for life in saturated soil conditions. Wetlands generally include swamps, marshes, bogs, and similar areas.

Whole effluent toxicity means the aggregate toxic effect of an effluent measured directly by a toxicity test.



DEP INFORMATION SHEET

Appealing a Commissioner's Licensing Decision

Dated: May 2004

Contact: (207) 287-2811

SUMMARY

There are two methods available to an aggrieved person seeking to appeal a licensing decision made by the Department of Environmental Protection's (DEP) Commissioner: (1) in an administrative process before the Board of Environmental Protection (Board); or (2) in a judicial process before Maine's Superior Court. This INFORMATION SHEET, in conjunction with consulting statutory and regulatory provisions referred to herein, can help aggrieved persons with understanding their rights and obligations in filing an administrative or judicial appeal.

I. ADMINISTRATIVE APPEALS TO THE BOARD

LEGAL REFERENCES

DEP's *General Laws*, 38 M.R.S.A. § 341-D(4), and its *Rules Concerning the Processing of Applications and Other Administrative Matters* (Chapter 2), 06-096 CMR 2.24 (April 1, 2003).

HOW LONG YOU HAVE TO SUBMIT AN APPEAL TO THE BOARD

The Board must receive a written notice of appeal within 30 calendar days of the date on which the Commissioner's decision was filed with the Board. Appeals filed after 30 calendar days will be rejected.

HOW TO SUBMIT AN APPEAL TO THE BOARD

Signed original appeal documents must be sent to: Chair, Board of Environmental Protection, c/o Department of Environmental Protection, 17 State House Station, Augusta, ME 04333-0017; faxes are acceptable for purposes of meeting the deadline when followed by receipt of mailed original documents within five (5) working days. Receipt on a particular day must be by 5:00 PM at DEP's offices in Augusta; materials received after 5:00 PM are not considered received until the following day. The person appealing a licensing decision must also send the DEP's Commissioner and the applicant a copy of the documents. All the information listed in the next section must be submitted at the time the appeal is filed. Only the extraordinary circumstances described at the end of that section will justify evidence not in the DEP's record at the time of decision being added to the record for consideration by the Board as part of an appeal.

WHAT YOUR APPEAL PAPERWORK MUST CONTAIN

The materials constituting an appeal must contain the following information at the time submitted:

1. *Aggrieved Status.* Standing to maintain an appeal requires the appellant to show they are particularly injured by the Commissioner's decision.
2. *The findings, conclusions or conditions objected to or believed to be in error.* Specific references and facts regarding the appellant's issues with the decision must be provided in the notice of appeal.
3. *The basis of the objections or challenge.* If possible, specific regulations, statutes or other facts should be referenced. This may include citing omissions of relevant requirements, and errors believed to have been made in interpretations, conclusions, and relevant requirements.
4. *The remedy sought.* This can range from reversal of the Commissioner's decision on the license or permit to changes in specific permit conditions.

5. *All the matters to be contested.* The Board will limit its consideration to those arguments specifically raised in the written notice of appeal.
6. *Request for hearing.* The Board will hear presentations on appeals at its regularly scheduled meetings, unless a public hearing is requested and granted. A request for public hearing on an appeal must be filed as part of the notice of appeal.
7. *New or additional evidence to be offered.* The Board may allow new or additional evidence as part of an appeal only when the person seeking to add information to the record can show due diligence in bringing the evidence to the DEP's attention at the earliest possible time in the licensing process or show that the evidence itself is newly discovered and could not have been presented earlier in the process. Specific requirements for additional evidence are found in Chapter 2, Section 24(B)(5).

OTHER CONSIDERATIONS IN APPEALING A DECISION TO THE BOARD

1. *Be familiar with all relevant material in the DEP record.* A license file is public information made easily accessible by DEP. Upon request, the DEP will make the material available during normal working hours, provide space to review the file, and provide opportunity for photocopying materials. There is a charge for copies or copying services.
2. *Be familiar with the regulations and laws under which the application was processed, and the procedural rules governing your appeal.* DEP staff will provide this information on request and answer questions regarding applicable requirements.
3. *The filing of an appeal does not operate as a stay to any decision.* An applicant proceeding with a project pending the outcome of an appeal runs the risk of the decision being reversed or modified as a result of the appeal.

WHAT TO EXPECT ONCE YOU FILE A TIMELY APPEAL WITH THE BOARD

The Board will formally acknowledge initiation of the appeals procedure, including the name of the DEP project manager assigned to the specific appeal, within 15 days of receiving a timely filing. The notice of appeal, all materials accepted by the Board Chair as additional evidence, and any materials submitted in response to the appeal will be sent to Board members along with a briefing and recommendation from DEP staff. Parties filing appeals and interested persons are notified in advance of the final date set for Board consideration of an appeal or request for public hearing. With or without holding a public hearing, the Board may affirm, amend, or reverse a Commissioner decision. The Board will notify parties to an appeal and interested persons of its decision.

II. APPEALS TO MAINE SUPERIOR COURT

Maine law allows aggrieved persons to appeal final Commissioner licensing decisions to Maine's Superior Court, see 38 M.R.S.A. § 346(1); 06-096 CMR 2.26; 5 M.R.S.A. § 11001; & MRCivP 80C. Parties to the licensing decision must file a petition for review within 30 days after receipt of notice of the Commissioner's written decision. A petition for review by any other person aggrieved must be filed within 40-days from the date the written decision is rendered. The laws cited in this paragraph and other legal procedures govern the contents and processing of a Superior Court appeal.

ADDITIONAL INFORMATION

If you have questions or need additional information on the appeal process, contact the DEP's Director of Procedures and Enforcement at (207) 287-2811.

Note: The DEP provides this INFORMATION SHEET for general guidance only; it is not intended for use as a legal reference. Maine law governs an appellant's rights.
