III. Discharge Monitoring Data Suggested Format

Operator XYZ, ABC Company, Any City, Massachusetts
Operator email and telephone number
Remediation General Permit Site, 123 Street, Any City, Massachusetts – MAG910000
Effluent Outfall Number 001
Large Freshwater Receiving Water

Sample Date	Effluent Flow	TSS	Chloride	Ammonia	Arsenic	Copper	Iron	Nickel	Zinc	pH minimum	pH maximum
	MGD	mg/L	mg/L	mg/L	µg/L	µg/L	µg/L	µg/L	µg/L	SU	SU
	meter	Method 160.2	Method 300.0	Method 8083	Method 200.9	Method 200.9	Method 200.8	Method 200.7	Method 200.7	Method 4500-H^+-B 2000	Method 4500-H^+-B 2000
9/10/15	0.035	**31**	150	*<0.1*	*<20*	*<15*	1,100	140	*<15*	6.8	6.9
10/4/15	0.048	15.3	240	*<0.1*	*<20*	*<15*	2,000	*<20*	*<15*	6.5	6.8
11/8/15	C	C	C	C	C	C	C	C	C	C	C
12/15/15	0.4	8.4	207	*<0.1*	32	*<15*	4,000	*<20*	21.4	6.5	6.8
1/2/16	0.055	*<5*	197	*<0.1*	*<20*	17.2	950	*<20*	*<15*	**6.4**	6.8
2/6/16	0.034	*<5*	166	*<0.1*	*<20*	*<15*	1,300	*<20*	*<15*	6.7	7.0
3/19/16	0.011	7.2	202	*<0.1*	*<20*	*<15*	2,350	210	*<15*	6.5	6.8
4/30/16	0.02	9.5	121	0.19	*<20*	24.6	**5,200**	442	39	6.5	6.8
5/6/16	0.053	12.1	81	*<0.1*	*<20*	16	3,300	*<20*	*<15*	6.7	6.8
6/12/16	0.047	6.3	97	0.34	*<20*	*<15*	1,400	87	41	6.7	7.1
Permit Limits	**1.0**	**30**	**Report**	**Report**	**104**	**242**	**5,000**	**1,450**	**420**	**6.5**	**8.3**
Min	0.011	<5	81	<0.1	<20	<15	950	<20	<15	6.4	6.8
Max	0.4	31	240	0.34	32	24.6	5200	442	41	6.8	7.1
Avg	0.0781	12.8	162	0.27	32	19.3	2400	220	34	6.6	6.9
# of measurements	9	9	9	9	9	9	9	9	9	9	9