



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

Region 1

**5 Post Office Square, Suite 100
BOSTON, MA 02109-3912**

CERTIFIED MAIL

March 2, 2011

William C Beyer,
Principal Hydrogeologist
Fay Spofford & Thorndike
5 Burlington Woods Drive
Burlington, MA 01803

Re: Authorization to discharge under the Remediation General Permit (RGP) –
MAG910000. Reserved Channel Sewer Separation Project site located at 980 Harrison
Street, Boston, MA 02119, Suffolk County; Authorization # MAG910471

Dear Mr. Beyer:

Based on the review of a Notice of Intent (NOI) submitted on behalf of the Boston Water and Sewer Commission (BWSC) by the firm Fay, Spofford & Thorndike, for the site referenced above, the U.S. Environmental Protection Agency (EPA) hereby authorizes you, as the named Operator, to discharge in accordance with the provisions of the RGP at that site. Your authorization number is listed above.

The checklist enclosed with this RGP authorization indicates the pollutants for which you are required to monitor. Also indicated on the checklist are the effluent limits, test methods and minimum levels (MLs) for each pollutant. Please note that the checklist does not represent the complete requirements of the RGP. Operators must comply with all of the applicable requirements of this permit, including influent and effluent monitoring, narrative water quality standards, record keeping, and reporting requirements, found in Parts I and II, and Appendices I – VIII of the RGP. See EPA's website for the complete RGP and other information at:
<http://www.epa.gov/region1/npdes/mass.html#dgp>.

Please note the list of pollutants authorized includes pollutants found in excess of the RGP Appendix III limits, and others you have marked "Believed Present" in the NOI application for the BWSC site.


Also, please note that the metals arsenic, lead, iron included on the list are dilution dependent pollutants and subject to limitations based on a dilution factor range (DFR). With the absence of dilution for discharges to tidal water, EPA determined that the DFR for each parameter is in the one and five (1-5) range. (See the RGP Appendix IV for Massachusetts facilities) Therefore, the limits for arsenic of 36ug/L, lead of 8.5ug/L, and iron of 1,000ug/L, are required to achieve permit compliance at your site.

Finally, please note the list of pollutants attached to this authorization is subject to a recertification if the operations at the site result in a discharge lasting longer than six months. A recertification can be submitted to EPA within six (6) to twelve (12) months of operations in accordance with the 2010 RGP regulations.

This general permit and authorization to discharge will expire on September 9, 2015. You have reported that this project will terminate on 01/31/2013. If for any reason the discharge terminates sooner you are required to submit a Notice of Termination (NOT) to the attention of the contact person indicated below within 30 days of project completion.

Thank you in advance for your cooperation in this matter. Please contact Victor Alvarez at 617-918-1572 or Alvarez.Victor@epa.gov, if you have any questions.

Sincerely,



David M. Webster, Chief
Industrial Permits Branch

Enclosure

cc: Kathleen Keohane, MassDEP

**2010 Remediation General Permit
Summary of Monitoring Parameters^[1]**

NPDES Authorization Number:	MAG910471
Date Authorization Issued:	March, 2011
Facility/Site Name:	Reserved Channel Sewer Separation Project
Facility/Site Address:	980 Harrison Street, Boston, MA 02119, Suffolk County
	Email address of owner: Same as the site; Phone n: Not provided.
Legal Name of Operator:	D'Allessandro Corporation
Operator contact name, title, and Address:	David Gall, Operator, D'Allessandro Coporation 840 Summer Street, Boston, MA 02127
	Email :Not Provided
Estimated Date of Completion:	01/13/2013
Category and Sub-Category:	Category I- Petroleum Related Site Discharges. Sub-category C. Petroleum Discharges with Additional Contamination
Receiving Water:	The Boston Reserved Channel in South Boston, MA

Monitoring & Limits are applicable if checked. All samples are to be collected as grab samples

	<u>Parameter</u>	<u>Effluent Limit/Method#/ML</u> (All Effluent Limits are shown as Daily Maximum Limit, unless denoted by a **, in that case it will be a Monthly Average Limit)
✓	1. Total Suspended Solids (TSS)	30 milligrams/liter (mg/L) **, 50 mg/L for hydrostatic testing **, Me#60.2/ML 5ug/L
	2. Total Residual Chlorine (TRC) ¹	Freshwater = 11 ug/L ** Saltwater = 7.5 ug/L **/ Me#330.5/ML 20ug/L
✓	3. Total Petroleum Hydrocarbons (TPH)	5.0 mg/L/ Me# 1664A/ML 5.0mg/L
	4. Cyanide (CN) ^{2, 3}	Freshwater = 5.2 ug/l ** Saltwater = 1.0 ug/L **/ Me#335.4/ML 5ug/L
✓	5. Benzene (B)	5ug/L /50.0 ug/L for hydrostatic testing only/ Me#8260C/ML 2 ug/L
✓	6. Toluene (T)	(limited as ug/L total BTEX)/ Me#8260C/ML 2ug/L
✓	7. Ethylbenzene (E)	(limited as ug/L total BTEX) Me#8260C/ML 2ug/L
✓	8. (m,p,o) Xylenes (X)	(limited as ug/L total BTEX) Me#8260C/ML 2ug/L
✓	9. Total Benzene, Toluene, Ethyl Benzene, and Xylenes (BTEX) ⁴	100 ug/L/ Me#8260C/ ML 2ug/L

	Parameter	Effluent Limit/Method#/ML (All Effluent Limits are shown as Daily Maximum Limit, unless denoted by a **, in that case it will be a Monthly Average Limit)
	10. Ethylene Dibromide (EDB) (1,2- Dibromoethane)	0.05 ug/l/ Me#8260C/ ML 10ug/L
	11. Methyl-tert-Butyl Ether (MtBE)	70.0 ug/l /Me#8260C/ ML 10ug/L
	12.tert-Butyl Alcohol (TBA) (TertiaryButanol)	Monitor Only (ug/L)/ Me#8260C/ ML 10ug/L
	13. tert-Amyl Methyl Ether (TAME)	Monitor Only (ug/L) /Me#8260C/ ML 10ug/L
✓	14. Naphthalene ⁵	20 ug/L /Me#8260C/ ML 2ug/L
	15. Carbon Tetrachloride	4.4 ug/L /Me#8260C/ ML 5ug/L
	16. 1,2 Dichlorobenzene (o-DCB)	600 ug/L /Me#8260C/ ML 5ug/L
	17. 1,3 Dichlorobenzene (m-DCB)	320 ug/L /Me#8260C/ ML 5ug/L
	18. 1,4 Dichlorobenzene (p-DCB)	5.0 ug/L /Me#8260C/ ML 5ug/L
	18a. Total dichlorobenzene	763 ug/L - NH only /Me#8260C/ML5ug/L
	19. 1,1 Dichloroethane (DCA)	70 ug/L /Me#8260C/ ML 5ug/L
	20. 1,2 Dichloroethane (DCA)	5.0 ug/L /Me#8260C/ ML 5ug/L
	21. 1,1 Dichloroethene (DCE)	3.2 ug/L/Me#8260C/ ML 5ug/L
✓	22. cis-1,2 Dichloroethene (DCE)	70 ug/L/Me#8260C/ ML 5ug/L
	23. Methylene Chloride	4.6 ug/L/Me#8260C/ ML 5ug/L
	24. Tetrachloroethene (PCE)	5.0 ug/L/Me#8260C/ ML 5ug/L
	25. 1,1,1 Trichloro-ethane (TCA)	200 ug/L/Me#8260C/ ML 5ug/L
	26. 1,1,2 Trichloro-ethane (TCA)	5.0 ug/L /Me#8260C/ ML 5ug/L
	27. Trichloroethene (TCE)	5.0 ug/L /Me#8260C/ ML 5ug/L
	28. Vinyl Chloride (Chloroethene)	2.0 ug/L /Me#8260C/ ML 5ug/L
	29. Acetone	Monitor Only(ug/L)/Me#8260C/ML 50ug/L
	30. 1,4 Dioxane	Monitor Only /Me#1624C/ML 50ug/L
	31. Total Phenols	300 ug/L Me#420.1&420.2/ML 2 ug/L/ Me# 420.4 /ML 50ug/L
	32. Pentachlorophenol (PCP)	1.0 ug/L /Me#8270D/ML5ug/L,Me#604 &625/ML 10ug/L
	33. Total Phthalates (Phthalate esters) ⁶	3.0 ug/L ** /Me#8270D/ML 5ug/L, Me#606/ML 10ug/L& Me#625/ML 5ug/L
	34. Bis (2-Ethylhexyl) Phthalate [Di- (ethylhexyl) Phthalate]	6.0 ug/L /Me#8270D/ML 5ug/L,Me#606/ML 10ug/L & Me#625/ML 5ug/L
✓	35. Total Group I Polycyclic Aromatic Hydrocarbons (PAH)	10.0 ug/L
✓	a. Benzo(a) Anthracene ⁷	0.0038 ug/L /Me#8270D/ ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L

	<u>Parameter</u>	<u>Effluent Limit/Method#/ML</u> (All Effluent Limits are shown as Daily Maximum Limit, unless denoted by a **, in that case it will be a Monthly Average Limit)
✓	b. Benzo(a) Pyrene ⁷	0.0038 ug/L /Me#8270D/ ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L
✓	c. Benzo(b)Fluoranthene ⁷	0.0038 ug/L /Me#8270D/ ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L
✓	d. Benzo(k)Fluoranthene ⁷	0.0038 ug/L /Me#8270D/ ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L
✓	e. Chrysene ⁷	0.0038 ug/L /Me#8270D/ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L
✓	f. Dibenzo(a,h)anthracene ⁷	0.0038 ug/L /Me#8270D/ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML 5ug/L
✓	g. Indeno(1,2,3-cd) Pyrene ⁷	0.0038 ug/L /Me#8270D/ML 5ug/L, Me#610/ML 5ug/L& Me#625/ML5ug/L
✓	36. Total Group II Polycyclic Aromatic Hydrocarbons (PAH)	100 ug/L
✓	h. Acenaphthene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	i. Acenaphthylene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	j. Anthracene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	k. Benzo(ghi) Perylene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	l. Fluoranthene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	m. Fluorene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
	n. Naphthalene ⁵	20 ug/l / Me#8270/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	o. Phenanthrene	X/Me#8270D/ML 5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
✓	p. Pyrene	X/Me#8270D/ML5ug/L, Me#610/ML 5ug/L & Me#625/ML 5ug/L
	37. Total Polychlorinated Biphenyls (PCBs) ^{8, 9}	0.000064 ug/L/Me# 608/ ML 0.5 ug/L
✓	38. Chloride	Monitor only/Me# 300.0/ ML 0.1ug/L

	<u>Metal parameter</u>	<u>Total Recoverable Metal Limit @ H ¹⁰ = 50 mg/l CaCO3 for discharges in Massachusetts (ug/l)</u> ¹¹	
		<u>Freshwater</u>	<u>Saltwater</u>
	39. Antimony	5.6/ML 10	
✓	40. Arsenic **		36/ML 20

	Metal parameter	Total Recoverable Metal Limit @ H¹⁰ = 50 mg/l CaCO₃ for discharges in Massachusetts (ug/l) 11	
		Freshwater	Saltwater
	41. Cadmium **		8.9/ML 10
	42. Chromium III (trivalent) **		100/ML 15
	43. Chromium VI (hexavalent) **		50.3/ML 10
	44. Copper **		3.7/ML 15
√	45. Lead **		8.5/ML 20
	46. Mercury **		1.1/ML 0.2
	47. Nickel **		8.2/ML 20
	48. Selenium **		71/ML 20
	49. Silver		2.2/ML 10
	50. Zinc **		85.6/ML 15
√	51. Iron	1,000/ML 20	

	Other Parameters	Limit
√	52. Instantaneous Flow	Site specific in CFS
√	53. Total Flow	Site specific in CFS
	54. pH Range for Class A & Class B Waters in MA	6.5-8.3; 1/Month/Grab ¹³
√	55. pH Range for Class SA & Class SB Waters in MA	6.5-8.3; 1/Month/Grab ¹³
	56. pH Range for Class B Waters in NH	6.5-8; 1/Month/Grab ¹³
	57. Daily maximum temperature - Warm water fisheries	83°F; 1/Month/Grab ¹⁴
	58. Daily maximum temperature - Cold water fisheries	68°F; 1/Month/Grab ¹⁴
	59. Maximum Change in Temperature in MA - Any Class A water body	1.5°F; 1/Month/Grab ¹⁴
	60. Maximum Change in Temperature in MA - Any Class B water body- Warm Water	5°F; 1/Month/Grab ¹⁴
	61. Maximum Change in Temperature in MA - Any Class B water body - Cold water and Lakes/Ponds	3°F; 1/Month/Grab ¹⁴
	62. Maximum Change in Temperature in MA - Any Class SA water body - Coastal	1.5°F; 1/Month/Grab ¹⁴
	63. Maximum Change in Temperature in MA - Any Class SB water body - July to September	1.5°F; 1/Month/Grab ¹⁴
	64. Maximum Change in Temperature in MA - Any Class SB water body - October to June	4°F; 1/Month/Grab ¹⁴

¹ Although the maximum values for TRC are 11ug/l and 7.5 ug/l for freshwater, and saltwater respectively, the compliance limits are equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., Method 330.5, 20 ug/l).

² Limits for cyanide are based on EPA's water quality criteria expressed as micrograms per liter. There is currently no EPA approved test method for free cyanide. Therefore, total cyanide must be reported.

³ Although the maximum values for cyanide are 5.2 ug/l and 1.0 ug/l for freshwater and saltwater, respectively, the compliance limits are equal to the minimum level (ML) of the Method 335.4 as listed in Appendix VI (i.e., 10 ug/l).

⁴ BTEX = sum of Benzene, Toluene, Ethylbenzene, and total Xylenes.

⁵ Naphthalene can be reported as both a purgeable (VOC) and extractable (SVOC) organic compound. If both VOC and SVOC are analyzed, the highest value must be used unless the QC criteria for one of the analyses is not met. In such cases, the value from the analysis meeting the QC criteria must be used.

⁶ The sum of individual phthalate compounds(not including the #34, Bis (2-Ethylhexyl) Phthalate . The compliance limits are equal to the minimum level (ML) of the test method used as listed in Appendix VI.

Total values calculated for reporting on NOIs and discharge monitoring reports shall be calculated by adding the measured concentration of each constituent. If the measurement of a constituent is less than the ML, the permittee shall use a value of zero for that constituent. For each test, the permittee shall also attach the raw data for each constituent to the discharge monitoring report, including the minimum level and minimum detection level for the analysis.

⁷ Although the maximum value for the individual PAH compounds is 0.0038 ug/l, the compliance limits are equal to the minimum level (ML) of the test method used as listed in Appendix VI.

⁸ In the November 2002 WQC, EPA has revised the definition of Total PCBs for aquatic life as total PCBs is the sum of all homologue, all isomer, all congener, or all "Orochlor analyses."Total values calculated for reporting on NOIs and discharge monitoring reports shall be calculated by adding the measured concentration of each constituent. If the measure of a constituent is less than the ML, the permittee shall use a value of zero for that constituent. For each test, the permittee shall also attach the raw data for each constituent to the discharge monitoring report, including the minimum level and minimum detection level for the analysis.

⁹Although the maximum value for total PCBs is 0.000064 ug/l, the compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., 0.5 ug/l for Method 608 or 0.00005 ug/l when Method 1668a is approved).

¹⁰ Hardness. Cadmium, Chromium III, Copper, Lead, Nickel, Silver, and Zinc are Hardness Dependent.

¹¹ For a Dilution Factor (DF) from 1 to 5, metals limits are calculated using DF times the base limit for the metal. See Appendix IV. For example, iron limits are calculated using DF x 1,000ug/L (the iron base limit). Therefore DF is 1.5, the iron limit will be 1,500 ug/L; DF 2, then iron limit =1,000 x 2 =2,000 ug/L., etc. not to exceed the DF=5.

¹² Minimum Level (ML) is the lowest level at which the analytical system gives a recognizable signal and acceptable calibration point for the analyte. The ML represents the lowest concentration at which an analyte can be measured with a known level of confidence. The ML is calculated by multiplying the laboratory-determined method detection limit by 3.18 (see 40 CFR Part 136, Appendix B).

¹³ pH sampling for compliance with permit limits may be performed using field methods as provided for in EPA test Method 150.1.

14 Temperature sampling per Method 170.1

1. Although the maximum value for TPC and TSC are listed in Appendix VI (i.e., Method 170.1, 20 ug/L) of the test method used as listed in Appendix VI (i.e., Method 170.1, 20 ug/L), the compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., Method 170.1, 20 ug/L).

2. Limits for cyanide are based on EPA's water quality criteria document as listed in Appendix VI (i.e., Method 170.1, 20 ug/L). There is currently no EPA approved test method for cyanide. Therefore, total cyanide must be reported.

3. Although the maximum values for cyanide are 2.2 ug/L and 1.9 ug/L for freshwater and saltwater, respectively, the compliance limit is equal to the minimum level (ML) of the Method 170.1 as listed in Appendix VI (i.e., 20 ug/L).

4. BTEX = sum of Benzene, Toluene, Ethylbenzene, and total Xylenes.

5. Regulations can be reported as both a separate (VOC) and combined (SVOC) organic compound. If both VOC and SVOC are analyzed, the highest value must be used unless the QC criteria for one of the analytes is not met. In such cases, the value from the analysis meeting the QC criteria must be used.

6. The sum of individual pesticides compounds including the 734 B1 (2-Ethylhexyl) Pthalate. The compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI.

7. This value calculated for reporting as VOC and discharge monitoring reports shall be calculated by adding the measured concentration of each constituent. If the measurement of a constituent is less than the ML, the permittee shall use a value of zero for that constituent. For each test, the permittee shall also attach the raw data for each constituent to the discharge monitoring report, including the minimum level and maximum detection level for the analyte.

8. Although the maximum value for the individual PAH compounds is 0.0005 ug/L, the compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI.

9. In the November 2002 WQC, EPA has revised the definition of Total PCBs for aquatic life as total PCBs is the sum of all homologous, all isomers, all congeners, or all "other" analytes. Total values calculated for reporting on BODs and discharge monitoring reports shall be calculated by adding the measured concentration of each constituent. If the measure of a constituent is less than the ML, the permittee shall use a value of zero for that constituent. For each test, the permittee shall also attach the raw data for each constituent to the discharge monitoring report, including the minimum level and maximum detection level for the analyte.

10. Although the maximum value for total PCBs is 0.0005 ug/L, the compliance limit is equal to the minimum level (ML) of the test method used as listed in Appendix VI (i.e., 0.2 ug/L for Method 1631 or 0.0005 ug/L when Method 1631a is approved).

11. Hazardous Chemicals (HC) (Copper, Lead, Nickel, Silver, and Zinc are Hazardous Chemicals).

12. For a Discharge Report (DR) from 1 to 2, metals limits are calculated using DR times the base limit for the metal. See Appendix IV. For example, iron limits are calculated using DR x 1.0000 (the iron base limit). Therefore DR x 1.2, the iron limit will be 1.200 ug/L. DR 1.0 then iron limit = 1.200 x 1 = 1.200 ug/L, etc. not to exceed the DR x 2.

13. Minimum level (ML) is the lowest level at which the analytical system gives a recognizable signal and acceptable detection limit for the analyte. The ML represents the lowest concentration at which an analyte can be measured with a stated level of confidence. The ML is calculated by multiplying the laboratory-determined method detection limit by 2.13 (see 40 CFR Part 136, Appendix B).

14. All sampling for compliance with water limits may be performed using the methods as provided in EPA test method 170.1.

B. Suggested Form for Notice of Intent (NOI) for the Remediation General Permit

1. General facility/site information. Please provide the following information about the site:

a) Name of facility/site: Reserved Channel Sewer Separation		Facility SIC code(s):		Street: 840 Summer Street	
Location of facility/site: longitude: -71.025 latitude: 42.342		Town: South Boston		State: MA	
b) Name of facility/site owner:		Town: South Boston		Zip: 02127	
Email address of facility/site owner: jdoherly@fstinc.com		State: MA		County: Suffolk	
Telephone no. of facility/site owner: 617.268.2046		Owner is (check one): 1. Federal <input type="radio"/> 2. State/Tribal <input type="radio"/> 3. Private <input checked="" type="radio"/> 4. Other <input type="radio"/> if so, describe: Municipal Commission			
Fax no. of facility/site owner: 617.268.2198		Address of owner (if different from site):			
Street: 680 Harrison		Town: Boston		State: MA	
Town: Boston		Zip: 02127		County: Suffolk	
c) Legal name of operator:		Operator telephone no.: 508-559-6400			
D'Allesandro Corp		Operator fax no.: 508-559-6432		Operator email: info@dallesandro.com	
Operator contact name and title: John Bauld, Senior Project Manager		Address of operator (if different from owner):			
Town: Avon		Street: 41 Ledin Drive P.O. Box 245		State: MA	
State: MA		Zip: 02322		County: Norfolk	

<p>d) Check Y for "yes" or N for "no" for the following:</p> <p>1. Has a prior NPDES permit exclusion been granted for the discharge? Y <input type="radio"/> N <input checked="" type="radio"/>, if Y, number: <input type="text"/></p> <p>2. Has a prior NPDES application (Form 1 & 2C) ever been filed for the discharge? Y <input type="radio"/> N <input checked="" type="radio"/>, if Y, date and tracking #: <input type="text"/></p> <p>3. Is the discharge a "new discharge" as defined by 40 CFR 122.2? Y <input checked="" type="radio"/> N <input type="radio"/></p> <p>4. For sites in Massachusetts, is the discharge covered under the Massachusetts Contingency Plan (MCP) and exempt from state permitting? Y <input checked="" type="radio"/> N <input type="radio"/></p>	
<p>e) Is site/facility subject to any State permitting, license, or other action which is causing the generation of discharge? Y <input type="radio"/> N <input checked="" type="radio"/></p> <p>If Y, please list:</p> <p>1. site identification # assigned by the state of NH or MA: <input type="text"/></p> <p>2. permit or license # assigned: <input type="text"/></p> <p>3. state agency contact information: name, location, and telephone number: <input type="text"/></p>	
<p>g) Is the site/facility located within or does it discharge to an Area of Critical Environmental Concern (ACEC)? Y <input type="radio"/> N <input checked="" type="radio"/></p>	
<p>h) Based on the facility/site information and any historical sampling data, identify the sub-category into which the potential discharge falls.</p>	
<p>Activity Category</p>	<p>Activity Sub-Category</p>
<p>I - Petroleum Related Site Remediation</p>	<p>A. Gasoline Only Sites <input type="checkbox"/></p> <p>B. Fuel Oils and Other Oil Sites (including Residential Non-Business Remediation Discharges) <input type="checkbox"/></p> <p>C. Petroleum Sites with Additional Contamination <input type="checkbox"/></p>
<p>II - Non Petroleum Site Remediation</p>	<p>A. Volatile Organic Compound (VOC) Only Sites <input type="checkbox"/></p> <p>B. VOC Sites with Additional Contamination <input type="checkbox"/></p> <p>C. Primarily Heavy Metal Sites <input type="checkbox"/></p>
<p>III - Contaminated Construction Dewatering</p>	<p>A. General Urban Fill Sites <input checked="" type="checkbox"/></p> <p>B. Known Contaminated Sites <input checked="" type="checkbox"/></p>

IV - Miscellaneous Related Discharges

A. Aquifer Pump Testing to Evaluate Formerly Contaminated Sites
 B. Well Development/Rehabilitation at Contaminated/Formally Contaminated Sites
 C. Hydrostatic Testing of Pipelines and Tanks
 D. Long-Term Remediation of Contaminated Sumps and Dikes
 E. Short-term Contaminated Dredging Drain Back Waters (if not covered by 401/404 permit)

2. Discharge information. Please provide information about the discharge, (attaching additional sheets as necessary) including:

a) Describe the discharge activities for which the owner/applicant is seeking coverage:

Dewatering for construction of outfalls for sewer and stormwater

b) Provide the following information about each discharge:

1) Number of discharge points: 4	2) What is the maximum and average flow rate of discharge (in cubic feet per second, ft ³ /s)? Max. flow 0.2 Average flow (include units) 0.15	Is maximum flow a design value? Y <input type="checkbox"/> N <input checked="" type="radio"/>	Is average flow a design value or estimate? Estimate
----------------------------------	---	---	--

3) Latitude and longitude of each discharge within 100 feet:

pt.1: lat 42.34	long -71.042	pt.2: lat 42.339	long -71.04
pt.3: lat 42.242	long -71.036	pt.4: lat 42.342	long -71.0252
pt.5: lat	long	pt.6: lat	long
pt.7: lat	long	pt.8: lat	long
			etc.

4) If hydrostatic testing, total volume of the discharge (gals)

5) Is the discharge intermittent or seasonal ?
 Is discharge ongoing? Y N

c) Expected dates of discharge (mm/dd/yy): start Mar 14, 2011 end Mar 16, 2012

d) Please attach a line drawing or flow schematic showing water flow through the facility including:
 1. sources of intake water, 2. contributing flow from the operation, 3. treatment units, and 4. discharge points and receiving waters(s)

B. Suggested Form for Notice of Intent (NOI) for the Remediation General Permit

1. General facility/site information. Please provide the following information about the site:

a) Name of facility/site: Reserved Channel Sewer Separation		Facility SIC code(s):		Street: 840 Summer Street	
Location of facility/site: longitude: -71.025 latitude: 42.342		Town: South Boston		State: MA	
b) Name of facility/site owner:		Town: South Boston		State: MA	
Email address of facility/site owner: jdoherthy@fstinc.com		Zip: 02127		County: Suffolk	
Telephone no. of facility/site owner: 617.268.2046		Owner is (check one): 1. Federal <input type="radio"/> 2. State/Tribal <input type="radio"/> 3. Private <input checked="" type="radio"/> 4. Other <input type="radio"/> if so, describe: Municipal Commission			
Fax no. of facility/site owner: 617.268.2198		Address of owner (if different from site):			
Street: 680 Harrison		Street: 41 Ledin Drive			
Town: Boston		State: MA		P.O. Box 245	
Zip: 02127		County: Suffolk		Town: Avon	
c) Legal name of operator:		Operator telephone no.: 508-559-6400		State: MA	
D'Allesandro Corp		Operator fax no.: 508-559-6432		Zip: 02322	
Operator contact name and title: John Bauld, Senior Project Manager		Operator email: info@dallesandro.com		County: Norfolk	
Address of operator (if different from owner):		Street: 41 Ledin Drive			
Town: Avon		State: MA		P.O. Box 245	

3. Contaminant information.

a) Based on the sub-category selected (see Appendix III), indicate whether each listed chemical is **believed present** or **believed absent** in the potential discharge. Attach additional sheets as needed.

Parameter *	CAS Number	Believed Absent	Believed Present	# of Samples	Sample Type (e.g., grab)	Analytical Method Used (method #)	Minimum Level (ML) of Test Method	Maximum daily value		Average daily value	
								concentration (ug/l)	mass (kg)	concentration (ug/l)	mass (kg)
1. Total Suspended Solids (TSS)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SM2540-D	4000	20000	2.4	10000	1.2
2. Total Residual Chlorine (TRC)		<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	HACH 8167	200	ND			
3. Total Petroleum Hydrocarbons (TPH)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	8100M	750	20000	2.4	6650	0.8
4. Cyanide (CN)	57125	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SM 4500	19.7	ND		ND	
5. Benzene (B)	71432	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	EPA 8260	2	10	0.0012	ND	
6. Toluene (T)	108883	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	EPA 8260	2	10	0.0012	ND	
7. Ethylbenzene (E)	100414	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	EPA 8260	2	10	0.0012	ND	
8. (m,p,o) Xylenes (X)	108883; 106423; 95476; 1330207	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	EPA 8260	2	10	0.0012	ND	
9. Total BTEX ²	n/a	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1				20	0.0024	ND	
10. Ethylene Dibromide (EDB) (1,2-Dibromoethane) ³	106934	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SIM	0.02	ND			
11. Methyl-tert-Butyl Ether (MtBE)	1634044	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
12. tert-Butyl Alcohol (TBA) (Tertiary-Butanol)	75650	<input checked="" type="checkbox"/>	<input type="checkbox"/>								

* Numbering system is provided to allow cross-referencing to Effluent Limits and Monitoring Requirements by Sub-Category included in Appendix III, as well as the Test Methods and Minimum Levels associated with each parameter provided in Appendix VI.

² BTEX = Sum of Benzene, Toluene, Ethylbenzene, total Xylenes.

³ EDB is a groundwater contaminant at fuel spill and pesticide application sites in New England.

Parameter *	CAS Number	Believed Absent	Believed Present	# of Samples	Sample Type (e.g., grab)	Analytical Method Used (method #)	Minimum Level (ML) of Test Method	Maximum daily value		Average daily value	
								concentration (ug/l)	mass (kg)	concentration (ug/l)	mass (kg)
13. tert-Amyl Methyl Ether (TAME)	9940508	<input checked="" type="checkbox"/>	<input type="checkbox"/>								
14. Naphthalene	91203	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8260	10	1000	1.2	10	0.012
15. Carbon Tetrachloride	56235	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
16. 1,2-Dichlorobenzene (o-DCB)	95501	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
17. 1,3-Dichlorobenzene (m-DCB)	541731	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
18. 1,4-Dichlorobenzene (p-DCB)	106467	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
18a. Total dichlorobenzene		<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
19. 1,1-Dichloroethane (DCA)	75343	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
20. 1,2-Dichloroethane (DCA)	107062	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1		SW8260	2	ND			
21. 1,1-Dichloroethene (DCE)	75354	<input type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
22. cis-1,2-Dichloroethene (DCE)	156592	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8260	2	10	0.012	2.77	0.003
23. Methylene Chloride (PCE)	75092	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	5	ND			
24. Tetrachloroethene (PCE)	127184	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
25. 1,1,1-Trichloro-ethane (TCA)	71556	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
26. 1,1,2-Trichloro-ethane (TCA)	79005	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
27. Trichloroethene (TCE)	79016	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			

Parameter *	CAS Number	Believed Absent	Believed Present	# of Samples	Sample Type (e.g., grab)	Analytical Method Used (method #)	Minimum Level (ML) of Test Method	Maximum daily value		Average daily value	
								concentration (ug/l)	mass (kg)	concentration (ug/l)	mass (kg)
28. Vinyl Chloride (Chloroethene)	75014	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
29. Acetone	67641	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
30. 1,4 Dioxane	123911	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8260	2	ND			
31. Total Phenols	108952	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
32. Pentachlorophenol (PCP)	87865	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	2.56	ND			
33. Total Phthalates (Phthalate esters) ¹		<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
34. Bis (2-Ethylhexyl) Phthalate [Di-(ethylhexyl) Phthalate]	117817	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8270C	1.03	ND			
35. Total Group I Polycyclic Aromatic Hydrocarbons (PAH)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	5000	0.6	10	0.0012
a. Benzo(a) Anthracene	56553	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
b. Benzo(a) Pyrene	50328	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
c. Benzo(b)Fluoranthene	205992	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
d. Benzo(k)Fluoranthene	207089	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
e. Chrysene	21801	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
f. Dibenzo(a,h)anthracene	53703	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
g. Indeno(1,2,3-cd) Pyrene	193395	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
36. Total Group II Polycyclic Aromatic Hydrocarbons (PAH)		<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	5000	0.6	10	0.0012

¹The sum of individual phthalate compounds.

Parameter *	CAS Number	Believed Absent	Believed Present	# of Samples	Sample Type (e.g., grab)	Analytical Method Used (method #)	Minimum Level (MIL) of Test Method	Maximum daily value		Average daily value	
								concentration (ug/l)	mass (kg)	concentration (ug/l)	mass (kg)
h. Acenaphthene	83329	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	5000	0.6	10	0.0012
i. Acenaphthylene	208968	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	0.103	1000	0.12	10	0.0012
j. Anthracene	120127	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
k. Benzofluoranthene	191242	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
l. Fluoranthene	206440	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
m. Fluorene	86737	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
n. Naphthalene	91203	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
o. Phenanthrene	85018	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
p. Pyrene	129000	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW8270C	1.03	1000	0.12	10	0.0012
37. Total Polychlorinated Biphenyls (PCBs)	85687; 84742; 117840; 84662; 131113; 117817.	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW8082	0.674	ND			
38. Chloride	16887006	<input type="checkbox"/>	<input type="checkbox"/>								
39. Antimony	7440360	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	E200.9	1	ND			
40. Arsenic	7440382	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	E200.9	1	20	0.0024	11.8	0.0014
41. Cadmium	7440439	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW6010B	4	ND			
42. Chromium III (trivalent)	16065831	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	E200.7	60	ND			
43. Chromium VI (hexavalent)	18540299	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW3500	50	ND			
44. Copper	7440508	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW6010B	15	ND			
45. Lead	7439921	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW6010B	10	60	7.2	30	3.6
46. Mercury	7439976	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	E245.1	0.5	ND			
47. Nickel	7440020	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW6010B	100	ND			
48. Selenium	7782492	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW6010B	50	ND			
49. Silver	7440224	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	E200.7	7	ND			
50. Zinc	7440666	<input checked="" type="checkbox"/>	<input type="checkbox"/>	1	G	SW6010B	180	ND			
51. Iron	7439896	<input type="checkbox"/>	<input checked="" type="checkbox"/>	1	G	SW6010B	60	15000	2	7280	0.87
Other (describe):		<input type="checkbox"/>	<input type="checkbox"/>								

Parameter *	CAS Number	Believed Absent	Believed Present	# of Samples	Sample Type (e.g., grab)	Analytical Method Used (method #)	Minimum Level (ML) of Test Method	Maximum daily value	Average daily value	mass (kg)
								concentration (ug/l)	concentration (ug/l)	
		<input type="checkbox"/>	<input type="checkbox"/>							
		<input type="checkbox"/>	<input type="checkbox"/>							

b) For discharges where **metals** are believed present, please fill out the following (attach results of any calculations):

<p><i>Step 1:</i> Do any of the metals in the influent exceed the effluent limits in Appendix III (i.e., the limits set at zero dilution)? Y <input type="radio"/> N <input checked="" type="radio"/></p> <p><i>Step 2:</i> For any metals which exceed the Appendix III limits, calculate the dilution factor (DF) using the formula in Part I.A.3.c (step 2) of the NOI instructions or as determined by the State prior to the submission of this NOI. What is the dilution factor for applicable metals?</p> <p>Metal: _____ DF: _____</p> <p>Metal: _____ DF: _____</p> <p>Metal: _____ DF: _____</p> <p>Metal: _____ DF: _____</p> <p>Etc.</p>	<p>If yes, which metals?</p> <p>Look up the limit calculated at the corresponding dilution factor in Appendix IV. Do any of the metals in the influent have the potential to exceed the corresponding effluent limits in Appendix IV (i.e., is the influent concentration above the limit set at the calculated dilution factor)?</p> <p>Y <input type="radio"/> N <input checked="" type="radio"/> If Y, list which metals:</p>
--	---

4. Treatment system information. Please describe the treatment system using separate sheets as necessary, including:

a) A description of the treatment system, including a schematic of the proposed or existing treatment system:

See Attached Figure

b) Identify each applicable treatment unit (check all that apply):	Frac. tank <input checked="" type="checkbox"/>	Air stripper <input type="checkbox"/>	Oil/water separator <input type="checkbox"/>	Equalization tanks <input type="checkbox"/>	Bag filter <input checked="" type="checkbox"/>	GAC filter <input checked="" type="checkbox"/>
	Chlorination <input type="checkbox"/>	De-chlorination <input type="checkbox"/>	Other (please describe):			

c) Proposed **average** and **maximum flow rates** (gallons per minute) for the discharge and the **design flow rate(s)** (gallons per minute) of the treatment system:

Average flow rate of discharge gpm Maximum flow rate of treatment system gpm
 Design flow rate of treatment system gpm

d) A description of chemical additives being used or planned to be used (attach MSDS sheets):

--

5. Receiving surface water(s). Please provide information about the receiving water(s), using separate sheets as necessary:

a) Identify the discharge pathway:	Direct to receiving water <input type="checkbox"/>	Within facility (sewer) <input type="checkbox"/>	Storm drain <input checked="" type="checkbox"/>	Wetlands <input type="checkbox"/>	Other (describe): <input style="width: 90%;" type="text"/>
------------------------------------	--	--	---	-----------------------------------	---

b) Provide a narrative description of the discharge pathway, including the name(s) of the receiving waters:
 Storm drain to Reserved channel in Boston Harbor

c) Attach a detailed map(s) indicating the site location and location of the outfall to the receiving water:
 1. For multiple discharges, number the discharges sequentially.
 2. For indirect discharges, indicate the location of the discharge to the indirect conveyance and the discharge to surface water
 The map should also include the location and distance to the nearest sanitary sewer as well as the locus of nearby sensitive receptors (based on USGS topographical mapping), such as surface waters, drinking water supplies, and wetland areas.

d) Provide the state water quality classification of the receiving water
 e) Provide the reported or calculated seven day-ten year low flow (7Q10) of the receiving water cfs
 Please attach any calculation sheets used to support stream flow and dilution calculations.

f) Is the receiving water a listed 303(d) water quality impaired or limited water? Y N If yes, for which pollutant(s)?
 Is there a final TMDL? Y N If yes, for which pollutant(s)?

8. Signature Requirements: The Notice of Intent must be signed by the operator in accordance with the signatory requirements of 40 CFR Section 122.22, including the following certification:

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, I certify that the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I certify that I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Facility/Site Name:	RESERVED ANALYSE SEPARATION PROJECT
Operator signature:	
Printed Name & Title:	William A. Berger, Reverse Hydrogeologist, LSP
Date:	2/11/11