



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
Region 1
5 Post Office Square, Suite 100
BOSTON, MA 02109-3912

VIA EMAIL

July 26, 2017

Katherine Mason
Charter Contracting Company
500 Harrison Avenue, Suite 4R
Boston, MA 02118
kmason@charter.us

Re: Authorization to discharge under the Remediation General Permit (RGP) – Authorization # MAG910721, for the Boston Convention & Exhibition Center Phase II site located in Boston, MA

Dear Ms. Mason:

Based on the review of a Notice of Intent (NOI) dated June 26, 2017 submitted by Haley & Aldrich, Inc. for the site referenced above, the U.S. Environmental Protection Agency, Region 1 (EPA) hereby authorizes Charter Contracting Company, as the named operator, to discharge in accordance with the provisions of the RGP from this site via the City of Boston storm sewer system¹ to the Fort Point Channel. The authorization number is listed above. The effective date of coverage is the date of this authorization letter.

Enclosed with this RGP authorization to discharge is a summary of the applicable parameters and effluent limitations for your activity category III, contaminated site dewatering discharge. A dilution factor of zero (i.e., 1:1), was used in calculating effluent limits applicable to the proposed discharge from this site. Please note that this summary does not represent the complete requirements of the RGP. Operators must comply with all of the applicable requirements of the RGP, including influent and effluent monitoring, record keeping, and reporting requirements. Please ensure that sufficiently sensitive test methods are used for all sample analyses conducted for this permit. For the complete general permit, see EPA's RGP website.²

This EPA general permit and authorization to discharge will expire on **April 8, 2022**, or upon Notice of Termination (NOT), whichever occurs first. However, in accordance with Part 5.3 of the general permit, your permit coverage will be administratively continued until issuance of a new RGP. Please note that you must submit a NOT within thirty (30) days of the termination of the discharge. You have reported your discharges will terminate in September 2017. Because your discharge is not expected to last twelve (12) months or more, EPA expects you will not to be subject to NetDMR reporting requirements. See

¹ The operator is responsible for obtaining permission to discharge to this system, prior to initiating discharges. EPA's authorization to discharge does not convey any such permission.


² <http://www.epa.gov/region1/npdes/rgp.html>.

Part 4.6 and 5.2 of the RGP, and Appendix IV, Part 3 for more information regarding reporting requirements.

Please ensure that sufficiently sensitive test methods are used for all sample analyses conducted for this permit. To be considered sufficiently sensitive, test methods must achieve minimum levels for analysis for a given parameter that is no greater than the effluent limitation for that parameter, unless otherwise specified in the RGP for that parameter. Where no effluent limitation applies, EPA has provided the ML required with the enclosed summary. Where a compliance level applies, EPA has provided the compliance level with the enclosed summary.

Thank you in advance for your cooperation in this matter. Please contact Shauna Little at (617) 918-1989 or little.shauna@epa.gov, if you have any questions.

Sincerely,



Thelma Murphy, Chief
Storm Water and Construction Permits Section

Enclosure

cc: Kenneth N. Alepidis, Haley & Aldrich, Inc., via email
Michael Cronan, LSP, Haley & Aldrich, Inc., via email
John Donahue, Massachusetts Convention Center Authority, via email
Cathy Vakalopoulos, MassDEP, via email
Boston Water & Sewer Commission, via email

GENERAL PERMIT FOR REMEDIATION ACTIVITY DISCHARGES

Table 1: Authorization Information

Permit Number	MAG910721
Receiving Water	Fort Point Channel
Outfall Number	Outfall 001 to City of Boston CSO071
Monitoring Frequency	See Part 4.1.2 of the RGP
Reporting Requirement	See Part 4.6.1 of the RGP; NetDMR not required

Table 2: Chemical-Specific Effluent Limitations and Monitor-Only Requirements¹

Parameter	Effluent Limitation
A. Inorganics	
Ammonia ²	Report mg/L
Chloride ³	Report µg/L
Total Suspended Solids	30 mg/L
Antimony ⁴	206 µg/L
Arsenic ⁴	36 µg/L
Cadmium ⁴	10.2 µg/L
Chromium III ⁴	323 µg/L
Chromium VI ⁴	323 µg/L
Copper ⁴	3.7 µg/L
Iron ⁴	5,000 µg/L
Lead ⁴	8.5 µg/L
Mercury ⁴	0.739 µg/L
Nickel ⁴	8.3 µg/L
Selenium ⁴	235.8 µg/L
Silver ⁴	35.1 µg/L
Zinc ⁴	86 µg/L
Cyanide ⁵	1.0 µg/L
B. Non-Halogenated Volatile Organic Compounds	
Total BTEX	100 µg/L
Benzene	5.0 µg/L
C. Halogenated Volatile Organic Compounds	
1,3-Dichlorobenzene	320 µg/L
1,4-Dichlorobenzene	5.0 µg/L
D. Non-Halogenated Semi-Volatile Organic Compounds	
Total Group I Polycyclic Aromatic Hydrocarbons ⁶	1.0 µg/L
Benzo(a)anthracene ⁶	0.0038 µg/L
Benzo(a)pyrene ⁶	0.0038 µg/L
Benzo(b)fluoranthene ⁶	0.0038 µg/L
Benzo(k)fluoranthene ⁶	0.0038 µg/L
Chrysene ⁶	0.0038 µg/L
Dibenzo(a,h)anthracene ⁶	Report µg/L
Indeno(1,2,3-cd)pyrene ⁶	0.0038 µg/L

E. Halogenated Semi-Volatile Organic Compounds	
Total Polychlorinated Biphenyls (PCBs) ⁷	0.000064 µg/L

Table 2 Notes:

¹ The following abbreviations are used in Table 2, above:

^a mg/L = milligrams per liter

^b µg/L = micrograms per liter

² The minimum level (ML) for analysis of ammonia must be less than or equal to 0.1 mg/L.

³ The ML for analysis of chloride must be less than or equal to 230 mg/L.

⁴ The limitation for this parameter is on the basis of total recoverable metal in the water column.

⁵ The compliance level for total cyanide is 5.0 µg/L. The ML for analysis of total cyanide must be less than or equal to 5.0 µg/L.

⁶ The ML for analysis of group I PAHs must be less than or equal to 0.1 µg/L.

⁷ The compliance level for total PCBs is 0.5 µg/L. The ML for analysis of total PCBs must be less than or equal to 0.5 µg/L.

Table 3: Effluent Flow Limitation

Effluent Flow	Effluent Limitation
	0.144 MGD

Table 3 Notes

¹ The following abbreviations are used in Table 3, above:

^a MGD = million gallons per day

Table 4: pH Limitations for Discharges in Massachusetts

Receiving Water Class	Effluent Limitation
Saltwater	6.5 to 8.5 SU

Table 4 Notes

¹ The following abbreviations are used in Table 4, above:

^a SU = standard units