



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

Region 1

5 Post Office Square, Suite 100
BOSTON, MA 02109-3912

VIA EMAIL

August 29, 2017

Matt Young
Cumberland Farms, Inc.
165 Flanders Road
Westborough, MA 01581
myoung@cumberlandfarms.com

Re: Notice of Change under the Remediation General Permit (RGP) – Authorization #
MAG910729, for the Cumberland Farms, Inc. #2439 site located in Attleboro, MA

Dear Mr. Young:

Based on the review of a Notice of Change (NOC) dated August 21, 2017 submitted by ATC Group Services, LLC. for the site referenced above, the U.S. Environmental Protection Agency, Region 1 (EPA) hereby provides written approval for the following changes:

1. Request for change in site-specific effluent flow limitation. The effluent flow limitation is increased from 0.144 million gallons per day (MGD) to 0.288 MGD.

The effective date of these changes is the date of this letter, unless otherwise stated.

Enclosed with this letter is a revised summary of the applicable parameters and effluent limitations for your activity category I, petroleum-related site remediation discharge. Please note that the remaining requirements of the authorization to discharge issued on August 18, 2017 remain unchanged. For the complete general permit, see EPA's RGP website.¹

Thank you in advance for your cooperation in this matter. Please contact me at (617) 918-1989 or little.shauna@epa.gov, if you have any questions.

Sincerely,

A handwritten signature in blue ink, reading "Thelma Murphy", is positioned above the typed name.

Thelma Murphy, Chief
Storm Water and Construction Permits Section

¹ <http://www.epa.gov/region1/npdes/rgp.html>.

Enclosure

cc: Keith Sullivan, LSP, ATC Group Services, LLC., via email
Rachel Stevens, ATC Group Services, LLC., via email
Cathy Vakalopoulos, MassDEP, via email
City of Attleboro Department of Public Works

GENERAL PERMIT FOR REMEDIATION ACTIVITY DISCHARGES

Table 1: Authorization Information

Permit Number	MAG910729
Receiving Water	Unnamed tributary to Bungay River
Outfall Number	Outfall 001 to City of Attleboro
Monitoring Frequency	See Part 4.1.2 of the RGP
Reporting Requirement	See Part 4.6.1 of the RGP; NetDMR not required

Table 2: Chemical-Specific Effluent Limitations and Monitor-Only Requirements¹

Parameter	Effluent Limitation
A. Inorganics	
Ammonia ²	Report mg/L
Chloride ³	Report µg/L
Total Suspended Solids	30 mg/L
Antimony ⁴	206 µg/L
Arsenic ⁴	104 µg/L
Cadmium ⁴	10.2 µg/L
Chromium III ⁴	323 µg/L
Chromium VI ⁴	323 µg/L
Copper ⁴	242 µg/L
Iron ⁴	5,000 µg/L
Lead ⁴	160 µg/L
Mercury ⁴	0.739 µg/L
Nickel ⁴	1,450 µg/L
Selenium ⁴	235.8 µg/L
Silver ⁴	35.1 µg/L
Zinc ⁴	420 µg/L
B. Non-Halogenated Volatile Organic Compounds	
Total BTEX	100 µg/L
Benzene	5.0 µg/L
Acetone	7.97 mg/L
Phenol	1,080 µg/L
C. Halogenated Volatile Organic Compounds	
1,1 Dichloroethylene	3.2 µg/L
Trichloroethylene	5.0 µg/L
Tetrachloroethylene	5.0 µg/L
Cis-1,2 Dichloroethylene	70 µg/L
Vinyl Chloride	2.0 µg/L
D. Non-Halogenated Semi-Volatile Organic Compounds	
Total Group I Polycyclic Aromatic Hydrocarbons ⁵	Report µg/L
Benzo(a)anthracene ⁵	Report µg/L
Benzo(a)pyrene ⁵	Report µg/L
Benzo(b)fluoranthene ⁵	Report µg/L
Benzo(k)fluoranthene ⁵	Report µg/L

Chrysene ⁵	Report µg/L
Dibenzo(a,h)anthracene ⁵	Report µg/L
Indeno(1,2,3-cd)pyrene ⁵	Report µg/L
Total Group II Polycyclic Aromatic Hydrocarbons	100 µg/L
Naphthalene	20 µg/L
F. Fuels Parameters	
Total Petroleum Hydrocarbons	5.0 mg/L
tert-Butyl Alcohol	120 µg/L

Table 2 Notes:

¹ The following abbreviations are used in Table 2, above:

^a mg/L = milligrams per liter

^b µg/L = micrograms per liter

² The minimum level (ML) for analysis of ammonia must be less than or equal to 0.1 mg/L.

³ The ML for analysis of chloride must be less than or equal to 230 mg/L.

⁴ The limitation for this parameter is on the basis of total recoverable metal in the water column.

⁵ The ML for analysis of group I PAHs must be less than or equal to 0.1 µg/L.

Table 3: Effluent Flow Limitation

Effluent Flow	Effluent Limitation
	0.288 MGD

Table 3 Notes

¹ The following abbreviations are used in Table 3, above:

^a MGD = million gallons per day

Table 4: pH Limitations for Discharges in Massachusetts

Receiving Water Class	Effluent Limitation
Freshwater	6.5 to 8.3 SU

Table 4 Notes

¹ The following abbreviations are used in Table 4, above:

^a SU = standard units