



State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095

603-271-3503 FAX 603-271-2867

TDD Access: Relay NH 1-800-735-2964



July 1, 1996

R. G. Chevalier, Vice President
Northeast Utilities
PO Box 270
Hartford, CT 06141-0270

Subject: National Pollutant Discharge Elimination System (NPDES) Permit
PSNH-Schiller Station
Permit #NH0001473

Dear Mr. Chevalier:

On May 1, 1996, I conducted an NPDES Compliance Evaluation Inspection (CEI) at Schiller Station. The inspection consisted of the completion of an inspection checklist and a discussion of effluent limit violations. The objectives of a CEI include determining permittee compliance with permit self-monitoring requirements, effluent limits, and compliance schedules. Following is a report of that inspection, a copy of which will be forwarded to the Environmental Protection Agency with EPA form 3560-3 (attached).

Individuals present during the inspection were:

John Brackett - Chemical Department Supervisor, PSNH
Dave Corliss - Working Foreman Chemical, PSNH
Allan Palmer - Sr. Engineer, PSNH
Stephanie Larson - Environmental Inspector, NHDES

The following are items discussed during the inspection, including comments and recommendations:

A. Effluent Limit Violations

1. One "Delta T" exceedence occurred in August 1995 at outfall 003. The temperature violation occurred for four hours while Unit 5 was reaching full load. The violation was due to the failure of an operator to properly respond to an alarm condition in the control room. This violation is not expected to recur. This was the only effluent violation that occurred in 1995.

AIR RESOURCES DIV.
64 No. Main Street
P.O. Box 2033
Concord, N.H. 03302-2033
Tel. 603-271-1370
FAX 603-271-1381

WASTE MANAGEMENT DIV.
6 Hazen Drive
Concord, N.H. 03301
Tel. 603-271-2900
FAX 603-271-2456

WATER RESOURCES DIV.
64 No. Main Street
P.O. Box 2008
Concord, N.H. 03302-2008
Tel. 603-271-3406
FAX 603-271-7894

WATER SUPPLY & POLLUTION CONTROL DIV.
P.O. Box 95
Concord, N.H. 03302-0095
Tel. 603-271-3503
FAX 603-271-2181

