

Attachment E - List of Eligible Facilities  
MAG580000

Current Permit Number	Facility Name	Watershed	Class	Expiration Date	Address	City or Town	State	Design Flow (MGD)	2021/2022 Upstream 7Q10 Flow (cfs)	2021/2022 Dilution Factor	Modified Limit(s)	New limit(s)	Bacteria Season
MA0100196	Upton WWTP	Blackstone (Unnamed tributary to West River)	B	4/30/2018	43 MAPLE AVENUE	UPTON	MA	0.4	0.012	1.02	Al: 542 µg/L (daily max); Cd: 1.1 µg/L (daily max); Cu: 26.2 µg/L (daily max), 18.5 µg/L (monthly ave); Pb: 1.6 µg/L (monthly ave); Zn: 75.9 µg/L (daily max & monthly ave); Ammonia: 4.4 mg/L (monthly ave, Oct-May), 1.4 mg/L (monthly ave, June-Sept); TP: 0.1 mg/L (monthly ave, April-Oct)		Seasonal (Apr-Oct)
MA0102202	Hopedale WWTP	Blackstone (Mill River)	B	9/30/2018	JUNCTION ROUTE 16 AND MENDON STREET	HOPEDALE	MA	0.588	0.75	1.8	Al: 0.91 mg/L (daily max), 418 µg/L (monthly ave); Cu: 11.4 µg/L (daily max), 7.5 µg/L (monthly ave); Ammonia: 8.6 mg/L (monthly ave, Nov-April), 2.7 mg/L (monthly ave, May)		Seasonal (Apr-Oct)
MA0101095	Douglas WWTP	Blackstone River	B	4/30/2012	CHARLES STREET	EAST DOUGLAS	MA	0.6	6.9	8.5		Al: 146.8 µg/L (monthly ave)-WET C-NOEC: 12%	Seasonal (Apr-Oct)
MA0090433	USCG Boston Light	Boston Harbor	SA	2/28/2023	LITTLE BREWSTER ISLAND	BOSTON	MA	0.0005	N/A	1.6M			Seasonal (Apr-Oct)
MA0102253	MCI Norfolk-Walpole WWTF	Charles River (Stop River)	B	11/30/2013	10 OLD CAMPBELL STREET	NORFOLK	MA	0.484	0.2	1.26	Ammonia: 5.3 mg/L (monthly ave, Nov-April), 1.7 mg/L (monthly ave, May)		Seasonal (Mar-Nov)
MA0102113	Wrentham Development Center	Charles River	B	2/28/2017	NORTH ST	WRENTHAM	MA	0.454	0	1			Seasonal (Apr-Oct)
MA0102245	MCI - Concord	Concord (Assabet River)	B	10/31/2021	965 ELM STREET	CONCORD	MA	0.31	11.65	25.3	Al: 142.3 µg/L, 194 µg/L (monthly ave); TRC: 0.28 mg/L (monthly ave) and 0.48 mg/L (daily max)		Year-Round
MA0102466	Middlesex School	Concord (Spencer Brook)	B	1/31/2017	1400 LOWELL ROAD	CONCORD	MA	0.052	0.11	2.4	TP: 0.16 mg/L (monthly ave, April-Oct)	Cd: 0.5 µg/L (monthly ave)	Year-Round
MA0039853	Wayland WWMDC	Concord (wetland/Sudbury R)	B	11/30/2013	185 ELISSA AVE.	WAYLAND	MA	0.052	77.51	969.9			Year-Round
MA0101061	North Brookfield WWTP	Connecticut (Forget-Me-Not Brook, trib to Quahog River)	B	3/30/2024	59 EAST BROOKFIELD ROAD	NORTH BROOKFIELD	MA	0.76	0.05	1.04	Al: 290 µg/L (daily max), 170 µg/L (monthly ave); Ammonia: 4.5 mg/L (monthly ave, Nov-April)		Seasonal (Apr-Oct)
MA0032573	Northfield Mt Hermon School	Connecticut River	B	2/29/2024	206 MAIN STREET	GILL	MA	0.45	1781	2545			Seasonal (Mar-Oct)
MA0100099	Hadley Indian Hill WWTP	Connecticut River	B	11/30/2016	266 MIDDLE STREET	HADLEY	MA	0.54	2125	2531			Seasonal (Apr-Oct)
MA0100200	Northfield WWTF	Connecticut River	B	10/31/2013	104 MEADOW STREET	NORTHFIELD	MA	0.275	1779	4138			Seasonal (Apr-Oct)
MA0101290	Hatfield	Connecticut River	B	2/28/2017	260 MAIN STREET	HATFIELD	MA	0.5	2101	2730			Seasonal (Apr-Oct)
MAG580005	Sunderland WWTF	Connecticut River	B	7/5/2016	113 RIVER RD	SUNDERLAND	MA	0.5	2093	2719			Seasonal (Apr-Oct)
MAG580004	South Deerfield WWTP	Connecticut River	B	7/5/2016	STATE HIGHWAY 116	SOUTH DEERFIELD	MA	0.85	2093	1587			Seasonal (Apr-Oct)
MA0100102	Hardwick Gilbertville	Connecticut (Ware River)	B	1/31/2018	OLD MILL ROAD	GILBERTVILLE	MA	0.23	12.87	36.8		Al: 87 µg/L (monthly ave); Pb: 0.3 µg/L (monthly ave) [compliance level: 0.5 µg/L]	Seasonal (Apr-Oct)
MA0102431	Hardwick Wheelwright	Connecticut (Ware River)	B	1/31/2018	PINE STREET	WHEELWRIGHT	MA	0.043	8.93	128.6			Seasonal (Apr-Oct)
MA0103152	Barre WWTP	Connecticut (Ware River)	B	5/31/2018	411 WHEELWRIGHT ROAD	BARRE	MA	0.3	8.31	19.1			Seasonal (Apr-Oct)
MAG580001	Old Deerfield WWTP	Connecticut (Deerfield River)	B	7/5/2016	55 LITTLE MEADOW ROAD	DEERFIELD	MA	0.25	200	514			Seasonal (Apr-Oct)
MAG580002	Shelburne Falls WWTF	Connecticut (Deerfield River)	B	7/5/2016	GARDNER FALLS ROAD	BUCKLAND	MA	0.25	200	514			Seasonal (Apr-Oct)
MAG580003	Charlemont Sewer District WWTP	Connecticut (Deerfield River)	B	7/5/2016	20 FACTORY ROAD	CHARLEMONT	MA	0.05	143.76	1798			Seasonal (Apr-Oct)
MA0100188	Monroe WWTF	Connecticut (Deerfield River)	B	11/30/2015	MILL STREET	MONROE BRIDGE	MA	0.015	57	2851			Seasonal (Apr-Oct)
MA0100340	Templeton WWTP	Connecticut (Otter River)	B	3/31/2026	33 RESERVOIR ROAD	TEMPLETON	MA	0.6	4.67	6	Al: 396 µg/L (monthly ave); Cu: 28 µg/L (daily max); Ammonia: 7.8 mg/L (monthly ave, June-Oct)		Seasonal (Apr-Oct)
MA0100161	Royalston WWTP	Connecticut (Millers River)	B	10/31/2014	15 BLOSSOM STREET	SOUTH ROYALSTON	MA	0.039	21.03	351.5			Seasonal (Apr-Oct)
MA0102776	Erving POTW #3	Connecticut (Millers River)	B	11/30/2013	BRIDGE STREET VILLAGE OF FARLEY	ERVING	MA	0.01	41.39	2071			Seasonal (Apr-Oct)
MA0023027	Renaissance Manor of Westfield	Connecticut (Westfield River)	B	5/31/2013	37 FEEDING HILLS ROAD	WESTFIELD	MA	0.0125	70.23	3512.5			Seasonal (Apr-Oct)
MA0100960	Russell WWTF	Connecticut (Westfield River)	B	11/8/2010	RUSSELL VILLAGE	RUSSELL	MA	0.24	46.77	127.4			Seasonal (Apr-Oct)
MA0101265	Huntington	Connecticut (Westfield River)	B	10/31/2021	ROUTE 112	HUNTINGTON	MA	0.2	8.09	27.1		Al: 87 µg/L (monthly ave)	Seasonal (Apr-Oct)
MA0103233	Woronoco Village	Connecticut (Westfield River)	B	11/8/2010	TEKOA AVENUE/BRIDGE ROAD	RUSSELL	MA	0.02	49.74	1659			Seasonal (Apr-Oct)
MA0101141	Charlton WWTP	Quinebaug (Cady Brook)	B	1/31/2016	JUNCTION ROUTES 20 AND 169	CHARLTON	MA	0.45	0.05	1.07	Al: 0.607 mg/L (daily max), 285 µg/L (monthly ave); Cd: 2.2 µg/L (daily max); Cu: 27.4 µg/L (daily max), 19.3 µg/L (monthly ave); Pb: 96.7 ug/l (daily max); Zn: 136.6 µg/L (daily max & monthly ave), Ammonia: 4.3 mg/L (monthly ave, Nov-April), 1.4 mg/L (monthly ave, May and June-Oct)		Seasonal (Apr-Oct)
MA0100170	Oxford - Rochdale	Thames (French River)	B	7/31/2015	28 COMINS RD	OXFORD	MA	0.5	1.13	2.5	TRC: 0.027 mg/L (monthly ave) and 0.047 mg/L (daily max); WET C-NOEC: 40%	Al: 123 µg/L (monthly ave)	Seasonal (Apr-Oct)
MA0101796	Leicester Water Supply District	Thames (French River)	B	9/30/2015	124 PINE STREET	LEICESTER	MA	0.35	0.33	1.6	TP: 0.16 mg/L (monthly ave, April-Oct); Ammonia: 9.2 mg/L and 26.9 lb/day (monthly ave, April only)		Seasonal (Apr-Oct)
MA0103110	West Stockbridge	Housatonic (Williams River)	B	8/31/2015	MOSCOW ROAD	WEST STOCKBRIDGE	MA	0.076	3.66	31.5			Seasonal (Apr-Oct)
MA0101087	Stockbridge WWTP	Housatonic River	B	12/31/2015	ONE WEST STOCKBRIDGE ROAD	STOCKBRIDGE	MA	0.46	60.6	86.4			Seasonal (Apr-Oct)
MA0101150	Merrimac WWTP	Merrimack River	SB	9/30/2020	50 FEDERAL WAY	MERRIMAC	MA	0.45	892.8	1276			Year-Round
MA0102237	MCI Bridgewater	Taunton (Sawmill Brook)	B	8/31/2020	CONANT STREET	BRIDGEWATER	MA	0.55	0.2	1.24	Cu: 11.4 µg/L (daily max), 7.9 µg/L (monthly ave); Zn: 0.102 mg/L (daily max & monthly ave); Ammonia: 1.4 mg/L (monthly ave, Apr-Oct)		Year-Round
MA0032433	Oak Point Retirement Community	Taunton River	B	7/31/2008	RIVER STREET	MIDDLEBOROUGH	MA	0.185	26.6	94			Year-Round
MA0100871	Manchester-by-the-Sea WWTF	North Coastal (Manchester Bay)	SA	6/30/2025	12 CHURCH STREET	MANCHESTER-BY-THE SEA	MA	0.67	N/A	202		Cu: 5.8 µg/L (daily max), 3.7 µg/L (monthly ave)	Year-Round
MA0100145	Rockport	North Coastal (Sandy Bay)	SB	7/31/2025	46 PLEASANT STREET	ROCKPORT	MA	0.8	N/A	24	Enterococci: 130 cfu/100 (daily max)		Year-Round
MA0027391	Shore Cliff - Deaconess Retirement Home	North Coastal	SB	8/8/2010	14 CLIFF AVENUE	GLOUCESTER	MA	0.004	0	1			Year-Round
MA0031658	Battle Road Farm	Shawsheen (wetlands at headwaters Shawsheen R)	B	8/31/2020	39 INDIAN CAMP LANE	LINCOLN	MA	0.033	0	1			Year-Round
MA0100285	Cohasset WWTP	South Coastal	SA	8/31/2012	43 ELM ST	COHASSET	MA	0.45	N/A	30			Year-Round for Fecal Coliform; Seasonal (June-Sept) for Enterococci

Attachment E - List of Eligible Facilities  
NHG58000

Current Permit Number	Facility Name	Watershed	Class	Expiration Date	Address	City or Town	State	Design Flow (MGD)	2021/2022 Upstream 7Q10 Flow (cfs)	2021/2022 Dilution Factor	Modified Limit(s)	New limit(s)	Bacteria Season
NH0020966	Wallis Sands State Park	Atlantic Ocean	B (tidal)	6/30/2020	WALLIS SANDS STATE PARK	RYE	NH	0.01	N/A	1.0		Cu: 5.8 µg/L (daily max), 3.7 µg/L (monthly ave); Ni: 8.3 µg/L (monthly ave); Ammonia: 1.21 mg/L (monthly ave, May-Oct); WET: LC50 100%, C-NOEC 100% (once in 4th year, 3rd quarter)	Year-Round
NHG580927	Gorham WWTF	Androscoggin River	B	7/5/2016	8 MAIN ST	GORHAM	NH	0.75	1191.6	925		WET LC50: ≥ 50%	Year-Round
NH0101150	West Swanzey WWTP	Connecticut (Ashuelot River)	B	11/30/2011	DENMAN THOMPSON HIGHWAY	SWANZEY	NH	0.16	26.6	97.0	WET LC50: 100%	Al: 87 µg/L (monthly ave), Cu: 3.1 µg/L (daily max) 2.4 µg/L (monthly ave)	Year-Round
NH0100382	Hinsdale WWTP	Connecticut (Ashuelot River)	B	12/31/2020	120 RIVER ROAD	HINSDALE	NH	0.3	36.7	72.0		Al: 87 µg/L (monthly ave); TRC: 0.79 mg/l (monthly ave)	Year-Round
NH0101052	Troy WWTF	Connecticut (Ashuelot River)	B	11/30/2018	151 DORT STREET	TROY	NH	0.265	0.29	1.5	Ammonia: 4.2 mg/L and 9.3 lb/day (monthly ave, May-Sept); TRC: 0.017 mg/L (monthly ave) and 0.029 mg/L (daily max); WET C-NOEC: 65%	Year-Round	
NHG580404	Winchester WWTP	Connecticut (Ashuelot River)	B	7/5/2016	64 DUSO ROAD	WINCHESTER	NH	0.28	33.8	71	TRC: 0.78 mg/L (monthly ave)	Year-Round	
NH0100510	Whitefield WWTP	Connecticut (Johns River)	B	11/30/2019	PARKER RD	WHITEFIELD	NH	0.185	2.1	7.5	Cu: 18.5 µg/L (monthly ave); Cu: 27.2 µg/L (daily max)	Year-Round	
NH0101168	Meriden Village Water District	Connecticut (Bloods Brook)	B	8/31/2019	90 BONNER ROAD	MERIDEN	NH	0.08	6.1	4.1	TRC: 0.045 mg/L (monthly ave) and 0.077 mg/L (daily max); WET C-NOEC: 25%	Year-Round	
NHG580226	Groveton WWTP	Connecticut (Upper Ammonoosuc R)	B	7/5/2016	3 STATE STREET	GROVETON	NH	0.367	43.7	70.1	TRC: 0.77 mg/L (monthly ave)	Year-Round	
NH0101392	Bethlehem Village WWTP	Connecticut (Ammonoosuc River)	B	8/31/2023	359 MAPLE STREET	BETHLEHEM	NH	0.34	29.6	51.7		Year-Round	
NHG580421	Town of Lisbon; Co-permittee: Landaff	Connecticut (Ammonoosuc River)	B	7/5/2016	636 BATH RD	LISBON	NH	0.32	48.9	89		Year-Round	
NHG581249	Lancaster Grange WWTP	Connecticut River (Otter Brook)	B	7/5/2016	GRANGE RD	LANCASTER	NH	0.0035	1.9	309		Year-Round	
NH0100544	Sunapee WWTF; Co-permittee: New London Sewer Commission	Connecticut (Sugar River)	B	10/31/2022	TREATMENT PLANT ROAD (ROUTE 11)	SUNAPEE	NH	0.64	7.19	7.44		Cu: 18.2 µg/L (monthly ave); Ammonia: 7.1 mg/L (monthly ave, May-Oct)	Year-Round
NHG580315	Colebrook WWTF	Connecticut River	B	7/5/2016	99 LYNCH DRIVE	COLEBROOK	NH	0.45	175.3	228		Year-Round	
NHG580391	Cheshire County Complex	Connecticut River	B	7/5/2016	201 RIVER ROAD	WESTMORELAND	NH	0.04	1491.2	21690		Year-Round	
NHG580536	Stratford Village System	Connecticut River	B	7/5/2016	23 CROSS ST	NORTH STRATFORD	NH	0.056	296.9	3085		Year-Round	
NHG580378	Woodsville WWTF	Connecticut River	B	7/5/2016	9 ARMORY LANE	WOODSVILLE	NH	0.33	921.5	1626		Year-Round	
NHG581206	Northumberland Village WWTF	Connecticut River	B	7/5/2016	10 STATION SQUARE	GROVETON	NH	0.06	391.3	3795		Year-Round	
NHG581214	Stratford-Mill House	Connecticut River	B	7/5/2016	1774 US ROUTE 3	NORTH STRATFORD	NH	0.024	297	7200		Year-Round	
NH0100102	Henniker WWTF	Merrimack (Contoocook R)	B	4/30/2011	RAMSDALL ROAD	HENNIKER	NH	0.51	27.8	33.0		Cu: 3.1 µg/L (daily max), 2.4 µg/L (monthly ave); TP: 2.3 mg/L (monthly ave, April-Oct)	Year-Round
NH0100650	Peterborough WWTF	Merrimack (Contoocook R)	B	11/30/2021	110 PHEASANT ROAD	PETERBOROUGH	NH	0.62	9.42	9.7	Al: 87 µg/L (monthly ave); Pb: 0.4 µg/L (monthly ave); Ammonia: 13.7 mg/L (monthly ave, June-Oct); TRC: 0.18 mg/L (daily max), 0.11 mg/L (monthly ave)	WET C-NOEC: 10%	Year-Round
NH0100111	Hillsborough MTP	Merrimack (Contoocook R)	B	10/31/2024	40 NORTON DR	HILLSBOROUGH	NH	0.6	29.9	29.8	TRC: 0.33 mg/L (monthly ave) and 0.57 mg/L (daily max)	Year-Round	
NHG580561	Antrim Water & Sewer Dept	Merrimack (Contoocook R)	B	7/5/2016	DEPOT STREET	ANTRIM	NH	0.21	15.1	43.8	TRC: 0.48 mg/L (monthly ave) and 0.83 mg/L (daily max)	Pb: 0.4 µg/L (monthly ave) [compliance level: 0.5 µg/L]	Year-Round
NHG580579	Town of Hopkinton WWTP	Merrimack (Contoocook R)	B	7/5/2016	210 PUBLIC WORKS RD.	HOPKINGTON	NH	0.12	32.8	159		Year-Round	
NH0100919	Greenville WWTF	Merrimack (Souhegan R)	B	2/28/2014	109 OLD WILTON ROAD	GREENVILLE	NH	0.233	1.2	3.9	TP: 0.39 mg/L; Cu: 9.2 µg/L (monthly ave); Cu: 12.5 µg/L (daily max); TRC: 0.043 mg/L (monthly ave) and 0.074 mg/L (daily max); WET C-NOEC: 26%	Year-Round	
NH0100293	Woodstock WWTP	Merrimack (Pemigewasset River)	B	4/30/2011	ROUTE 175	NORTH WOODSTOCK	NH	0.34	55.1	95		Cu: 9.6 µg/L (daily max), 2.4 µg/L (monthly ave)	Year-Round
NH0100986	Pittsfield WWTF	Merrimack (Suncook River)	B	3/31/2020	127 SOUTH MAIN STREET	PITTSFIELD	NH	0.4	1.52	3.1	Cu: 6.2 µg/L (monthly ave); Ammonia: 4.4 mg/L (June-Oct, monthly ave); TP: 1.0 lb/day (April-Oct, monthly ave); TRC: 34 µg/L (monthly ave), 59 µg/L (daily max); WET C-NOEC: ≥ 32%	Pb: 0.5 µg/L (monthly ave); Al: 87 µg/L (monthly ave)	Year-Round
NH0100498	Warner WWTF	Merrimack (Warner R)	B	8/31/2020	RFD #1 JOPPA ROAD	WARNER	NH	0.11	4.7	25.5		Year-Round	
NHG580021	Town of Bristol WWTF	Merrimack River	B	7/5/2016	180 AYRES ISLAND RD	BRISTOL	NH	0.5	134	156		Year-Round	
NHG580242	Plymouth Village WWTF	Merrimack River	B	7/5/2016	GREEN STREET	PLYMOUTH	NH	0.7	127.7	109		Year-Round	
NHG580935	Merrimack County Nursing Home	Merrimack River	B	7/5/2016	325 DANIEL WEBSTER HGHWY	BOSCAWEN	NH	0.08	473.3	3442		Year-Round	
NH0100854	Farmington WWTP	Piscataqua (Cocheco River)	B	6/30/2012	14 BALDWIN WAY	FARMINGTON	NH	0.35	2.2	5.1	Ammonia: 22.2 mg/L (monthly ave, Nov-April), 7.0 mg/L (monthly ave, May-Oct); TP: 0.46 mg/L (monthly ave, Apr-Oct)	Year-Round	
NHG581141	Town of Newington	Piscataqua River	B (tidal)	7/5/2016	115 GOSLING ROAD	NEWINGTON	NH	0.29	N/A	100		Year-Round	
NH0100609	Rockingham County Complex	Piscataqua (Ice Pond Br)	B	11/30/2008	116 North Road	BRENTWOOD	NH	0.084	0.28	2.8		Year-Round	
NH0100251	Rollinsford	Piscataqua (Salmon Falls R)	B	8/31/2005	5 LOWER MILL ROAD	ROLLINSFORD	NH	0.15	25	98	WET LC50: 100%	Year-Round	
NH0100676	Milton	Piscataqua (Salmon Falls R)	B	8/31/2005	ROUTE 125	MILTON	NH	0.1	20.7	121		Year-Round	
NH0101192	Newfields WWTF	Piscataqua (Squamscott R)	B (tidal)	2/29/2012	HERVEY COURT	NEWFIELDS	NH	0.117	N/A	100		Year-Round	
NH0100692	Epping	Piscataqua (Lamprey R)	B	3/31/2005	LAGOON ROAD	EPHING	NH	0.5	1.85	3	TP: 0.26 mg/L; TRC: 0.033 mg/L (monthly ave) and 0.057 mg/L (daily max); WET C-NOEC: 33%	Zn: 195 µg/L (monthly ave and daily max)	Year-Round
NH0100196	Newmarket	Piscataqua (Lamprey R)	B (tidal)	1/31/2008	YOUNG LANE	NEWMARKET	NH	0.85	N/A	32.8	TRC: 0.22 mg/L (monthly ave) and 0.38 mg/L (daily max)	Year-Round	