# Storm Hydrographs

# IP-STAT-04

Flowlink 4 for Windows




sampler initiated @ 6:30pm

> Start @ 3rd bottle ~2130

Go to 10th bottle (0630am)

Total = 10 bottles

# IP-STAT-08

Flowlink 4 for Windows




sampler enabled ~ 9:45 pm

Start @ 1st bottle ~ 2145 to 8th bottle ~ 0445 am

Total = 8 bottles

Sample Program: 200ml sample every 50,000 cf.




Auto Sampler Initiated on 5/12/02 at 5:30 pm

5/15/02 1142 - sampler stopped.

Sample Program: 200ml Sample every 50,000 CF




Auto Sampler initiated at ~2:30pm on 5/13/02

Auto Sampler stopped at 1300 on 5/15/02

Sample Program: 200 ml every 30,000 cf.
Sample




Auto Sampler Initiated on 5/13/02 at ~3:00pm.

5/15/02 Arrive at Sampler at 1330 - Sampler Complete

Sampler Completed at 9:21 AM On 5/15/02 - See attached sheet

Sample Program = 800ml Sample every hour - beginning at Sampler Trigger initiation. (0.07 rise in level in 1/hr).




Auto Sampler Initiated at 5:41 pm on 5/12/02

5/15/02 Sampler Stopped on 5/15/02 at 9:45AM.

Sample Program: 200ml Sample every 8,000 CF.




Auto Sampler initiated at ~3:00pm on 5/13/02

5/15/02 Arrive at Station 5 @ 1400 - program Completed

Sample Program: 200ml Sample every 80,000cf




Auto Sampler Initiated at ~3:00pm on 5/13/02

5/15/02 Arrive at Station 6 at 1616 Sample Program Complete.

Sample Hogram: 200ml Sample every 1.46 Mgal.




Auto Sampler Initiated at ~3:00pm on 5/13/02

5/15/02 Sampler Stopped at 1440 - on bottle #1

Sample Program: 800ml Sample every hour - beginning at Sample Trigger = Phonecall



Sample Program: 200 ml sample every hour.




Auto Sampler initiated at ~3:00pm on 5/13/02

Note: no level readings - Level not monitored at this Station

Sampler Stopped on 5/15/02 at 1517

Sample Program: 200ml Sample every 1.46 mgal.




Auto Sampler Initiated on 5/13/02 at ~3:00pm

5/15/02 Arrived at Station 10 C152B Sample Program Complete.

# IP-STAT-01

Flowlink 4 for Windows




0212
9/23/02
Sampler enabled

0824
9/25/02
Sampler Disabled

# IP-STAT-02

Flowlink 4 for Windows



CLICK TO CONTINUE

# IP-STAT-03

Flowlink 4 for Windows




0924
9/23/02
program
enabled.

0717
9/25/02
program
disabled