

From: Sneeringer, Paul J NAE
To: ["William Walshrogalski"](#)
Cc: ["Ann Williams"](#); [Cynthia Catri](#); [Elaine T Stanley](#); [Mike Marsh](#)
Subject: RE: New Bedford South Terminal - Floodplain Management Review (UNCLASSIFIED)
Date: Friday, June 15, 2012 11:38:00 AM

Classification: UNCLASSIFIED
Caveats: NONE

Bill:

If the work at Marsh Island and the Steamship Authority properties involves the excavation of material and/or the removal of obstructions that allows for additional flood storage at elevations between 2.0 and 6.0 feet NGVD then this could be counted as floodplain mitigation.

However, you need to consider the following questions:

Were these projects implemented/funded as part of either the New Bedford Harbor Superfund or the State Enhanced Remedy programs, such that they could be considered mitigation for the Superfund and/or State Enhanced Remedy Program?

Were these projects pursued as an individual municipal or private project? and

Were these projects completed as mitigation for other undertakings?

Feel free to contact me if you have any questions about this e-mail. Thanks.

Paul Sneeringer
(978) 505-9216

-----Original Message-----

From: William Walshrogalski [<mailto:Walshrogalski.William@epamail.epa.gov>]

Sent: Friday, June 15, 2012 8:54 AM

To: Sneeringer, Paul J NAE

Subject: RE: New Bedford South Terminal - Floodplain Management Review (UNCLASSIFIED)

Paul:

I know I asked you this question when I spoke with you yesterday, but my notes were hurried and incomplete.

I asked whether the work done at Marsh Island and the Steamship area could be counted for floodplain mitigation. Could you please give me another quick explanation?

Thanks
Bill

Classification: UNCLASSIFIED
Caveats: NONE