



August 10, 2010



SDMS DocID 470817

Richard W. Hull
Remedial Project Manager
U.S. Environmental Protection Agency
5 Post Office Square - Suite 100
Mail code OSRR 07-1
Boston, MA 02109 - 3912

Superfund Records Center
SA/PSF MHA/CE/PPC WELL 002
7.6
470817

Re: Savage Well Superfund Site
Consent Decree Docket No. 94-174
July Progress Report

Dear Mr. Hull:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT

Manu Sharma, P.E.
Principal

Enclosures

cc: R. Mongeon
J. Peltenon, Esq.
G. Smith, Esq.
B. Rand

MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: July 2010

MONTHLY PROGRESS REPORT #188
DATE: August 10, 2010

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during July 2010.

PROGRESS DURING REPORTING PERIOD

ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:

The OU-2 groundwater remediation system continued to operate in July with a total average extraction rate of approximately 373 gpm. Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface injection rate was approximately 320 gpm (IW-1 at approximately 95 gpm, IW-2 at approximately 115 gpm, and IW-3 at approximately 110 gpm). Extraction rates were lower during this reporting period because the system was shut down between July 24th and July 27th due to a power outage. The balance of the treated water was discharged to the Souhegan River surface water discharge structure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:

- None.

WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED

- None.

MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- None

PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:

- None.

SITE ACCESS

- None.

MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: July 2010

MONTHLY PROGRESS REPORT #188
DATE: August 10, 2010

PROGRESS PLANNED FOR NEXT SIX WEEKS

COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:

- None.

ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:

- Repairs to monitoring wells MW-14R, MW-115A/B, and MW-120B and the re-installation of monitoring well MW-10C are planned to commence on Monday, August 16th, pending EPA approval.
- Monitoring wells MW-118A/B do not need to be re-installed because field personal recently located them. Due to the removal of trees formerly located adjacent to these wells field personnel were initially unable to locate them and these wells were mistakenly presumed destroyed.

UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:

- None.

ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- None.

COMMUNITY RELATIONS PLAN ACTIVITIES:

- None