



Januray 11, 2011

Richard W. Hull
Remedial Project Manager
U.S. Environmental Protection Agency
5 Post Office Square - Suite 100
Mail code OSRR 07-1
Boston, MA 02109 - 3912

Superfund Records Center
SITE: Savage Municipal Wells 002
REF: 7-6
ID: 478654 RECAPABLE



SDMS DocID **478654**

Re: Savage Well Superfund Site
Consent Decree Docket No. 94-174
December Progress Report

Dear Mr. Hull:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT

Manu Sharma, P.E.
Principal

Enclosures

cc: R. Mongeon
J. Peltenon, Esq.
G. Smith, Esq.
B. Rand

MONTHLY PROGRESS REPORT



**SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: December 2010**

**MONTHLY PROGRESS REPORT #193
DATE: January 7, 2011**

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during December 2010.

PROGRESS DURING REPORTING PERIOD

ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:

The OU-2 groundwater remediation system continued to operate in December with a total monthly average extraction rate of approximately 236 gpm. Extraction rates were lower during this period because extraction well EW-1 has been offline since November 15 because of a failed pump motor that needs to be replaced and the required part was on back order until January. This well remains off-line and is anticipated to become operational in early January.

Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface monthly average injection rate was approximately 219 gpm (IW-1 at approximately 66 gpm, IW-2 at approximately 77 gpm, and IW-3 at approximately 76 gpm). The balance of the treated water was discharged to the Souhegan River surface water discharge structure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

The annual groundwater sampling was completed during the first week of December.

VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:

- None.

WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED

- None.

MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- None

PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:

- None.

MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: December 2010

MONTHLY PROGRESS REPORT #193
DATE: January 7, 2011

SITE ACCESS

- None.

PROGRESS PLANNED FOR NEXT SIX WEEKS

COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:

- None.

ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:

- None.

UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:

- None.

ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- None.

COMMUNITY RELATIONS PLAN ACTIVITIES:

- None