



September 10, 2010

Superfund Records Center  
SITE: SAVAGE WELL  
BREAK: \_\_\_\_\_  
OTHER: 1-17

Richard W. Hull  
Remedial Project Manager  
U.S. Environmental Protection Agency  
5 Post Office Square - Suite 100  
Mail code OSRR 07-1  
Boston, MA 02109 - 3912

Re: Savage Well Superfund Site  
Consent Decree Docket No. 94-174  
August Progress Report

Dear Mr. Hull:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT

A handwritten signature in black ink, appearing to read "Manu", with several horizontal lines extending to the right.

Manu Sharma, P.E.  
Principal

Enclosures

cc: R. Mongeon  
J. Peltenon, Esq.  
G. Smith, Esq.  
B. Rand

## MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE  
DOCKET #94-174  
REPORTING PERIOD: August 2010

MONTHLY PROGRESS REPORT #189  
DATE: September 9, 2010

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during August 2010.

### PROGRESS DURING REPORTING PERIOD

#### ***ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:***

The OU-2 groundwater remediation system continued to operate in August with a total average extraction rate of approximately 404 gpm. Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface injection rate was approximately 342 gpm (IW-1 at approximately 100 gpm, IW-2 at approximately 125 gpm, and IW-3 at approximately 117 gpm). The balance of the treated water was discharged to the Souhegan River surface water discharge structure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

#### ***VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:***

- None.

#### ***WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED***

- None.

#### ***MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:***

- None

#### ***PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:***

- None.

#### ***SITE ACCESS***

- None.

## MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE  
DOCKET #94-174  
REPORTING PERIOD: August 2010

MONTHLY PROGRESS REPORT #189  
DATE: September 9, 2010

### PROGRESS PLANNED FOR NEXT SIX WEEKS

#### *COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:*

- None.

#### *ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:*

- None.

#### *UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:*

- None.

#### *ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:*

- None.

#### *COMMUNITY RELATIONS PLAN ACTIVITIES:*

- None