



August 11, 2009

Richard Goehlert  
Remedial Project Manager  
U.S. Environmental Protection Agency  
One Congress Street, Suite 1100  
Boston, MA 02144-2023

Superfund Records Center  
SITE: SAVAGE WELL  
BREAK: 7.6  
OTHER: \_\_\_\_\_

Re: Savage Well Superfund Site  
Consent Decree Docket No. 94-174  
July Progress Report

Dear Mr. Goehlert:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT CORPORATION

A handwritten signature in black ink, appearing to read 'Manu Sharma', written over the printed name.

Manu Sharma, P.E.  
Principal

Enclosures

cc: R. Mongeon  
J. Peltenon, Esq.  
G. Smith, Esq.  
B. Rand



## MONTHLY PROGRESS REPORT

**SAVAGE WELL SUPERFUND SITE**  
**DOCKET #94-174**  
**REPORTING PERIOD: July 2009**

**MONTHLY PROGRESS REPORT #176**  
**DATE: August 10, 2009**

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during July 2009.

### **PROGRESS DURING REPORTING PERIOD**

#### ***ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:***

The OU-2 groundwater remediation system continued to operate in July with a total average extraction rate of approximately 410 gpm. Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface injection rate was approximately 355 gpm (IW-1 at approximately 113 gpm, and IW-2 and IW-3 both at approximately 121 gpm). The balance of the treated water was discharged to the Souhegan River surface water discharge structure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

#### ***VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:***

- None.

#### ***WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED***

- A work plan was prepared and approved by the EPA to remove an abandoned stream gauging station (WLR 5) from the Souhegan River. This work will likely be performed in early September.

#### ***MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:***

- None.

#### ***PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:***

- None.

#### ***SITE ACCESS***

- None.

## MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE  
DOCKET #94-174  
REPORTING PERIOD: July 2009

MONTHLY PROGRESS REPORT #176  
DATE: August 10, 2009

### PROGRESS PLANNED FOR NEXT SIX WEEKS

#### *COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:*

- None.

#### *ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:*

- Removal of an abandoned stream gauging station (WLR 5) from the Souhegan River in early September.

#### *UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:*

- None.

#### *ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:*

- None.

#### *COMMUNITY RELATIONS PLAN ACTIVITIES:*

- None