



October 12, 2011


SDMS DocID 496167

Richard W. Hull
Remedial Project Manager
U.S. Environmental Protection Agency
5 Post Office Square - Suite 100
Mail code OSRR 07-1
Boston, MA 02109 - 3912

Superfund Records Center
SITE: Savage Wells
BREAK: 7.6
OTHER: 496167

Re: Savage Well Superfund Site
Consent Decree Docket No. 94-174
September Progress Report


Dear Mr. Hull:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT



Manu Sharma, P.E.
Principal

Enclosures

cc: R. Mongeon
J. Peltenon, Esq.
G. Smith, Esq.
B. Rand

MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: September 2011

MONTHLY PROGRESS REPORT #202
DATE: October 7, 2011

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during September 2011.

PROGRESS DURING REPORTING PERIOD

ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:

The OU-2 groundwater remediation system continued to operate in September, with a monthly average extraction rate of approximately 327 gpm. Extraction rates were lower during this period because EW-1 was taken off line on August 24th, after the discovery of a stress crack in a PVC fitting for a portion of the conveyance line located inside the treatment plant building. EW-1 remained off line through September 14th, when repairs were completed.

Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface monthly average injection rate was approximately 283 gpm (IW-1 at approximately 85 gpm, IW-2 at approximately 100 gpm, and IW-3 at approximately 98 gpm). The balance of the treated water was discharged to the Souhegan River surface water discharge structure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:

- None

WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED

- None

MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- None

PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:

- None

MONTHLY PROGRESS REPORT



SAVAGE WELL SUPERFUND SITE
DOCKET #94-174
REPORTING PERIOD: September 2011

MONTHLY PROGRESS REPORT #202
DATE: October 7, 2011

SITE ACCESS

- None

PROGRESS PLANNED FOR NEXT SIX WEEKS

COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:

- None

ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:

- None

UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:

- None

ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:

- Continue discussions with EPA regarding a shallow groundwater investigation to support the EPA's vapor intrusion investigation at Milhaven Park.

COMMUNITY RELATIONS PLAN ACTIVITIES:

- None