



May 9, 2011



SDMS DocID 496172

Richard W. Hull  
Remedial Project Manager  
U.S. Environmental Protection Agency  
5 Post Office Square - Suite 100  
Mail code OSRR 07-1  
Boston, MA 02109 - 3912

Superfund Records Center  
SITE: SAVAGE WELLS  
PAGE: 7.6  
REF: 496172

Re: Savage Well Superfund Site  
Consent Decree Docket No. 94-174  
April Progress Report

Dear Mr. Hull:

In accordance with the Savage Well Site Consent Decree and your correspondence of September 17, 1996, the Settling Parties hereby submit four copies of the monthly progress report as required by Article XI of the Consent Decree.

If you have any questions, please do not hesitate to call.

Yours truly,

GRADIENT

Manu Sharma, P.E.  
Principal

Enclosures

cc: R. Mongeon  
J. Peltenon, Esq.  
G. Smith, Esq.  
B. Rand

201057  
Transmittal Letter

## MONTHLY PROGRESS REPORT



**SAVAGE WELL SUPERFUND SITE**  
**DOCKET #94-174**  
**REPORTING PERIOD: April 2011**

**MONTHLY PROGRESS REPORT #197**  
**DATE: May 10, 2011**

This report is being submitted pursuant to Section XI, Paragraph 34 of the Consent Decree (CD). This progress report summarizes the work performed by the Settling Parties during April 2011.

### **PROGRESS DURING REPORTING PERIOD**

#### ***ACTIONS TAKEN TOWARD ACHIEVING COMPLIANCE WITH CD:***

The OU-2 groundwater remediation system continued to operate in May, with a monthly average extraction rate of approximately 366 gpm. Treated water continues to be discharged to the subsurface and the Souhegan River. The cumulative subsurface monthly average injection rate was approximately 283 gpm (IW-1 at approximately 80 gpm, IW-2 at approximately 106 gpm, and IW-3 at approximately 97 gpm). The balance of the treated water was discharged to the Souhegan River surface water discharge structure. Flow rates were somewhat lower in April because the system was shut down for three days from April 1 through April 3 due to a power failure. The metals treatment system continues to effectively treat metals (metals generally non-detect in system effluent), being compliant with both surface water effluent discharge limits established by NHDES and design requirements of the system.

#### ***VALIDATED DATA/RESULTS AND TESTS RECEIVED OR GENERATED:***

- None.

#### ***WORK PLANS, PLANS AND OTHER DELIVERABLES SUBMITTED***

- A draft vapor intrusion evaluation work plan was submitted on April 22, 2011.

#### ***MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:***

- None

#### ***PROBLEMS/UNRESOLVED DELAYS ENCOUNTERED AND ACTIONS TAKEN:***

- None.

#### ***SITE ACCESS***

- None.

## MONTHLY PROGRESS REPORT



**SAVAGE WELL SUPERFUND SITE**  
**DOCKET #94-174**  
**REPORTING PERIOD: April 2011**

**MONTHLY PROGRESS REPORT #197**  
**DATE: May 10, 2011**

### PROGRESS PLANNED FOR NEXT SIX WEEKS

#### ***COMMUNITY RELATIONS SUPPORT PLAN ACTIVITIES:***

- None.

#### ***ACTIONS SCHEDULED AND PROGRESS OF CONSTRUCTION:***

- Prepare and issue annual remedy performance monitoring report for 2010.
- Prepare to implement vapor intrusion evaluation work plan following US EPA approval.

#### ***UNRESOLVED DELAYS ANTICIPATED, AND ACTIONS TO BE TAKEN:***

- None.

#### ***ANTICIPATED MODIFICATIONS TO WORK PLANS OR OTHER SCHEDULES:***

- None.

#### ***COMMUNITY RELATIONS PLAN ACTIVITIES:***

- None