

AUTHORIZATION TO DISCHARGE TO WATERS OF THE UNITED STATES,
NPDES PERMIT NO. NM0024848.

The applicant's mailing address is:

Village of Cuba
P.O. Box 426
Cuba, NM 87013

The discharger is a publicly owned treatment works (POTW). The site is located approximately 1.3 miles south of State Highway 197- Rio Puerco Bridge in Sandoval County, New Mexico. The facility discharge is to the Rio Puerco (designated as 20.6.4.99) between Arroyo Chijuilla and the northern boundary of Cuba, between Water Quality Segment number 20.6.4.105 and 20.6.4.109 of the Rio Grande Basin. The single outfall of the facility is to the Rio Puerco at:

Latitude 35E 59' 35" North, Longitude 106E 59' 13" West

The facility has a design flow capacity of 0.144 million gallons per day (MGD). A statement of basis is available.

There are significant changes of permit conditions from the existing permit issued October 31, 2005, and expired November 30, 2009:

- (i) Add effluent limitations and monitoring requirements for total nitrogen, total phosphorus, and total ammonia consistent with State's approved TMDL;
- (ii) Establish seasonal discharge limitations;
- (iii) Change critical dilution for WET tests;
- (iv) Change effluent limitation for TRC from 11 µg/l to 19 µg/l;
- (v) Add monitoring requirements for dissolved aluminum; and
- (vi) Delete effluent limitations and monitoring requirements for fecal coliform.