

NPDES authorization to discharge to waters of the United States, Permit No. NM0027863

The applicant's mailing address is:

Sandia Peak Ski & Tramway
10 Tramway Loop N.E.
Albuquerque, NM 87122

The facility is authorized to discharge from a facility located 13 miles northwest of San Antonito, Bernalillo County, New Mexico, from Outfall 001 located at Latitude 35° 11' 43" North and Longitude 106° 25' 59" West. Discharges from the facility for the described activities are to an unclassified reach of Cañon de Domingo Baca, thence to Arroyo de Domingo Baca thence to a classified reach of the Rio Grande in Segment 20.6.4.105 of the Rio Grande Basin.

Under the Standard Industrial Classification Code 7999, the applicant operates an aerial tramway including tramway terminal building and a restaurant. The design flow for this private domestic wastewater treatment plant is 0.0075 MGD.

This is a renewal of a permit issued January 24, 2005, with an effective date of March 1, 2005, and an expiration date of February 28, 2010.

Changes from the previous permit are:

- A. Permit limits for E. coli have been added.
- B. Fecal coliform limits have been eliminated.
- C. Limits for pH have been made more stringent.
- D. WET testing requirements have been added.

A fact sheet is available.