

MONTH/ YEAR	FLOW	FLOW	ARSENIC	ARSENIC	AMMONIA, TOTAL	AMMONIA, TOTAL	BOD	BOD	TSS	TSS	FECAL COLIFORM BACTERIA	FECAL COLIFORM BACTERIA	TRC	pH	pH	DO
LIMITS	Report	Report	0.0117	0.0175	0.57	0.86	10	15	15	23	100	200	0.011	6.0	9.0	Report
	AVG	MAX	AVG	MAX	AVG	MAX	AVG	MAX	AVG	MAX	AVG cfu/ 100 ml	MAX cfu/ 100 ml	MAX	MIN	MAX	MIN
	MGD	MGD	ug/l	ug/l	mg/l	mg/l	mg/l	mg/l	mg/l	mg/l	100 ml	100 ml	mg/l	su	su	mg/l
1/08	4.038	4.228	15.4	15.4	0.34	0.44	7.53	8.83	10.94	13.23	24.35	110	ND	7.12	8.23	3.75
2/08	3.779	3.932			0.31	0.45	5.11	5.83	7.47	7.93	8.36	93	ND	7.18	7.51	4.72
3/08	3.437	3.753	8.6	8.6	0.62	1.3	5.4	6.1	7.15	8.27	4.82	22	ND	7.21	7.62	4.33
4/08	2.919	3.021	12	12	0.31	0.38	4.77	5.63	9.2	12.27	3.2	14	ND	7.27	7.51	4.11
5/08	2.745	2.975			0.2	0.21	3.57	3.8	5.27	6.27	6.21	580	ND	7.43	7.76	3.12
6/08	2.487	2.614			0.21	0.21	3.84	4.23	7.9	8.33	8.6	104	ND	7.41	7.62	2.79
7/08	2.853	3.309	12	12	0.2	0.22	2.31	2.57	4.95	6.67	14.79	60	ND	7.33	7.71	3.42
8/08	2.793	3.038	14	14	0.21	0.22	2.83	3.43	5.83	6.67	13.04	52	ND	7.34	7.54	3.79
9/08	2.946	3.268	17	17	0.23	0.31	3.15	4.2	4.29	5.07	20.9	58	ND	7.16	7.57	2.8
10/08	3.362	3.574	12.4	12.4	0.2	0.21	2.6	4.5	4.12	5.2	14.07	92	ND	7.21	7.44	2.83
11/08	3.43	3.609	10.4	10.4	0.3	0.6	3.36	4.47	7.27	14.07	16.94	49	ND	7.24	7.9	3.96
12/08	3.864	4.104	15	15	0.53	1.05	5.46	6.7	9.68	13.47	18.19	45	ND	7.06	7.67	3.87
1/09	3.893	4.144	12	12	0.72	0.99	5.55	6.9	7.75	10.47	29.49	150	ND	7.32	7.47	3.74
2/09	3.495	3.669	10	10	0.89	1.47	8.59	11.4	10.58	15.47	43.59	73	ND	7.3	8.07	4.13
3/09	3.195	3.572	8	8	0.23	0.31	6.61	9.17	8.44	11.07	36.18	100	ND	7.17	7.5	3.05
4/09	3.269	3.537	7	7	0.2	0.21	4.53	4.83	6.33	7.53	39.55	120	ND	7.34	7.55	3.41
5/09	3.046	3.372	10	10	0.23	0.34	5.35	6.47	7.83	8.47	9.6	34	ND	7.27	7.54	4.21
6/09	2.964	2.988	22	22	0.29	0.64	5.67	8.21	6.6	8.97	8.19	29.5	ND	7.3	7.72	3.96
7/09	2.823	3.29	8	8	0.29	0.55	3.55	4.37	4.78	5.33	6.24	36	ND	7.4	7.64	2.8
8/09	2.913	3.244	8	8	0.2	0.21	4.26	6.7	5.4	7.4	8.73	88	ND	7.43	7.7	3.18
9/09	3.144	3.615	6	6	0.25	0.32	5.2	6.37	7.95	8.87	9.19	99	ND	7.33	7.61	2.97
10/09	3.237	3.65	5	5	0.2	0.2	3.6	4.5	5.22	7.67	5.11	13.44	ND	7.25		3.1
11/09	3.74	3.915	6	6	0.2	0.2	4.85	5.1	7.08	8.13	5.38	12.5	ND	7.19	7.53	3.51
12/09	4.224	4.244	8	8	0.2	0.2	7	8	10	12	6	18	ND	7.2	7.4	4.16