



**Region 6**  
**1445 Ross Avenue**  
**Dallas, Texas 75202-2733**

NPDES Permit No. **NM0029041**

---

**AUTHORIZATION TO DISCHARGE UNDER THE  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM**

In compliance with the provisions of the Clean Water Act, as amended, (33 U.S.C. 1251 et. seq; the "Act"),

Village of Pecos  
P.O. Box 337  
54 South Main Street  
Pecos, NM 87552

is authorized to discharge from the Village of Pecos Wastewater Treatment Plant located 42 Lagoon Lane, in San Miguel County, New Mexico,

to the Pecos River in Segment 20.6.4.217 of the Pecos River Basin, from a point located approximately

Outfall 001: Latitude 35° 34' 0.17" North, Longitude 105° 40' 20.6" West

in accordance with effluent limitations, monitoring requirements and other conditions set forth in Parts I, II, III, and IV hereof.

This permit shall become effective on

This permit and the authorization to discharge shall expire at midnight,

Issued on

Prepared by

---

William K. Honker  
Acting Director  
Water Quality Protection Division (6WQ)

---

Isaac Chen  
Environmental Engineer  
Permits Section (6WQ-PP)

BLANK PAGE

## PART I

### SECTION A. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

#### Outfall 001

During the period beginning on the effective date of this permit and lasting through the expiration date of this permit, the permittee is authorized to discharge from outfall serial number 001. Such discharges shall be limited and monitored by the permittee as specified below:

| <u>Effluent Characteristics</u>                  | <u>Discharge Limitations</u>                     |               |  |                     | <u>Monitoring Requirements</u> |                 |
|--|--|---------------|--|---------------------|--------------------------------|-----------------|
|  | Mass<br>(lbs/day, unless<br>otherwise specified) |               | Concentration<br>(mg/l, unless<br>otherwise specified) |                     | Frequency                      | Sample Type     |
|  | 30-Day<br>Avg.                                   | 7-Day<br>Avg. | 30-Day<br>Avg.   | 7-Day<br>Avg.       |                                |                 |
| Flow   | N/A  | N/A           | Report<br>(MGD)  | Report<br>(MGD)     | Daily                          | Instantaneous   |
| Biochemical Oxygen Demand<br>(BOD <sub>5</sub> ) | 38   | 56            | 30   | 45                  | 2/Month                        | 24-hr composite |
| Total Suspended Solids (TSS)                     | 38   | 56            | 30   | 45                  | 2/Month                        | 24-hr composite |
| BOD <sub>5</sub> % Removal <sup>(1)</sup>        | 85%  | N/A           | N/A  | N/A                 | 2/Month                        | Calculation     |
| TSS % Removal <sup>(1)</sup>                     | 85%  | N/A           | N/A  | N/A                 | 2/Month                        | Calculation     |
| Total Residual Chlorine <sup>(2)</sup> (TRC)     | N/A  | N/A           | 0.019<br>(Instantaneous Max)                           |                     | Daily                          | Grab            |
| E. coli (colonies/100 ml)                        | N/A  | N/A           | 126  | 235<br>(Daily Max)  | 2/Month                        | Grab            |
| pH   | N/A  | N/A           | 6.6 s.u.<br>Minimum                                    | 8.8 s.u.<br>Maximum | Daily                          | Grab            |

| <u>EFFLUENT CHARACTERISTICS</u>                                  | <u>DISCHARGE MONITORING</u> |                          | <u>MONITORING REQUIREMENTS</u>   |                    |
|--|-----------------------------|--------------------------|----------------------------------|--------------------|
| <u>WHOLE EFFLUENT LETHALITY<br/>(48-Hr. NOEC) <sup>(3)</sup></u> | <u>30-DAY AVG</u>           | <u>48-HR<br/>MINIMUM</u> | <u>MEASUREMENT<br/>FREQUENCY</u> | <u>SAMPLE TYPE</u> |
| Limitation   | 15%                         | 15%                      |                                  |                    |
| Daphnia pulex  | Report                      | Report                   | 1/6 months                       | 24-hr composite    |
| Pimephales promelas  | Report                      | Report                   | 1/6 months                       | 24-hr composite    |

**FOOTNOTES:**

1. % Removal = (Inflow Concentration – Effluent Concentration) / Inflow Concentration.
2. Monitor only after usage of chlorine product to the process. The effluent shall contain NO MEASURABLE total residual chlorine (TRC) at any time. NO MEASURABLE will be defined as no detectable concentration of TRC as determined by any approved method established in 40 CFR 136. If during the term of this permit the minimum quantification level for TRC becomes less than 19 ug/l, then 19 ug/l shall become the effluent limitation. The effluent limitation for TRC is the instantaneous maximum and can not be averaged for reporting purposes. Report NA if chlorine product is not used for the reporting period.
3. See Part II.D, Whole Effluent Toxicity Limit Requirements for additional WET monitoring and reporting conditions.

There shall be no discharge of oils, scum, grease and other floating materials that would cause the formation of a visible sheen or visible deposits on the bottom or shoreline, or would damage or impair the normal growth, function or reproduction of human, animal, plant or aquatic life.

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge from the final treatment unit prior to the discharge into the receiving stream from the following approximate location:

Outfall 001: Latitude: 35° 34' 0.17" North, Longitude: 105° 40' 20.6" West

---

**SECTION B. MONITORING AND REPORTING**

## 1. Monitoring and Reporting

- a. The permittee shall effectively monitor the operation and efficiency of all treatment and control facilities and the quantity and quality of the treated discharge.
- a. Monitoring information shall be reported in accordance with Part III.D.4 of this permit and shall be submitted quarterly. Each quarterly submittal shall include separate forms for each month of the reporting period.
- b. Reporting periods shall end on the last day of the months March, June, September, and December.
- c. The permittee is required to submit regular quarterly reports as described above postmarked no later than the 28<sup>th</sup> day of the month following each reporting period.
- e. **NO DISCHARGE REPORTING**

If there is no discharge at Outfall 001 during the sampling month, place an "X" in the NO DISCHARGE box located in the upper right corner of the Discharge Monitoring Report.

2. If any 7-day average or 30-day average value exceeds the effluent limitations specified in Part I.A, the permittee shall report the excursion in accordance with the requirements of Part III.D.
3. Any 7-day average or 30-day average value reported in the required Discharge Monitoring Report which is in excess of the effluent limitation specified in Part I.A shall constitute evidence of violation of such effluent limitation and of this permit.
4. Other measurements of oxygen demand (e.g., TOC and COD) may be substituted for the five-day Biochemical Oxygen Demand (BOD<sub>5</sub>), or for the five-day Carbonaceous Biochemical Oxygen Demand (CBOD<sub>5</sub>), as applicable, where the permittee can demonstrate long-term correlation of the method with BOD<sub>5</sub> or CBOD<sub>5</sub> values, as applicable. Details of the correlation procedures used must be submitted and prior approval granted by the permitting authority for this procedure to be acceptable. Data reported must also include evidence to show that the proper correlation continues to exist after approval.
5. **Overflow Reporting:**

The permittee shall report all overflows with the Discharge Monitoring Report submittal. These reports shall be summarized and reported in a tabular format. The summaries shall

include: the date, time, duration, location, estimated volume, and cause of the overflow; observed environmental impacts from the overflow; action taken to address the overflow; and ultimate discharge location if not contained (e.g., storm sewer system, ditch, tributary).

Overflows which endanger health or the environment shall be orally reported to EPA at (214) 665-6595, and to the NMED Surface Water Quality Bureau at (505) 827-0187 within 24 hours from the time the permittee becomes aware of the circumstance. A written report of overflows which endanger health or the environment shall be provided within five (5) days of the time the permittee becomes aware of the circumstance. The written reports shall be sent to both EPA, and the NMED Surface Water Quality Bureau.

7. Copy of Application to NMED

The permittee shall send a copy of application for permit renewal to New Mexico Environment Department at the mailing address listed in Part III of the permit.

## **PART II - OTHER CONDITIONS**

### **A. PERMIT REOPENER CLAUSE**

1. In accordance with 40 CFR 122.62, the permit may be reopened and modified during the life of the permit if relevant portions of State of New Mexico Water Quality Standards and/or State Water Quality Management Plans are revised, new water quality standards are established and/or remanded and any other policy, or if procedures and implementation guidelines are adopted by the State that change applicable water quality standards and permit implementation.
2. In accordance with 40 CFR Part 122.62, the permit may be reopened and modified if new information is received that was not available at the time of permit issuance that would have justified the application of different permit conditions at the time of permit issuance.
3. If a TMDL is established for the Pecos River, the permit may be reopened, and new limitations based on the TMDL may be incorporated into the permit.

### **B. CONTRIBUTING INDUSTRIES**

1. The following pollutants may not be introduced into the treatment facility:
  - a. Pollutants which create a fire or explosion hazard in the publicly owned treatment works (POTW), including, but not limited to, wastestreams with a closed cup flashpoint of less than 140 degrees Fahrenheit or 60 degrees Centigrade using the test methods specified in 40 CFR 261.21;
  - b. Pollutants which will cause corrosive structural damage to the POTW, but in no case discharges with pH lower than 5.0, unless the works are specifically designed to accommodate such discharges;
  - c. Solid or viscous pollutants in amounts which will cause obstruction to the flow in the POTW, resulting in Interference;
  - d. Any pollutant, including oxygen demanding pollutants (e.g., BOD), released in a discharge at a flow rate and/or pollutant concentration which will cause Interference with the POTW;
  - e. Heat in amounts which will inhibit biological activity in the POTW resulting in Interference but in no case heat in such quantities that the temperature at the POTW treatment plant exceeds 40 degrees Centigrade (104 degrees Fahrenheit) unless the Approval Authority, upon request of the POTW, approves alternate temperature limits;
  - f. Petroleum oil, non-biodegradable cutting oil, or products of mineral oil origin in amounts that will cause interference or pass through;
  - g. Pollutants which result in the presence of toxic gases, vapors, or fumes within the POTW in a quantity that may cause acute worker health and safety problems; and
  - h. Any trucked or hauled pollutants, except at discharge points designated by the POTW.

**C. POLLUTION PREVENTION REQUIREMENTS**

The permittee shall continue a program directed towards optimizing the efficiency and extending the useful life of the facility. The permittee shall consider the following items in the program:

- a. The influent loadings, flow and design capacity;
- b. The effluent quality and plant performance;
- c. The age and expected life of the wastewater treatment facility=s equipment;
- d. Bypasses and overflows of the tributary sewerage system and treatment works;
- e. New developments at the facility;
- f. Operator certification and training plans and status;
- g. The financial status of the facility;
- h. Preventative maintenance programs and equipment conditions and;
- i. An overall evaluation of conditions at the facility.

**D. WHOLE EFFLUENT TOXICITY LIMITS (48-HOUR ACUTE NOEC FRESHWATER)**

*It is unlawful and a violation of this permit for a permittee or his designated agent, to manipulate test samples in any manner, to delay sample shipment, or to terminate or to cause to terminate a toxicity test. Once initiated, all toxicity tests must be completed unless specific authority has been granted by EPA Region 6 or the State NPDES permitting authority.*

**1. SCOPE AND METHODOLOGY**

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S): 001

REPORTED ON DMR AS FINAL OUTFALL: 001

CRITICAL DILUTION (%): 15

EFFLUENT DILUTION SERIES (%): 6%, 8%, 11%, 15%, 20%

COMPOSITE SAMPLE TYPE: Defined at PART I

TEST SPECIES/METHODS: 40 CFR Part 136

Daphnia pulex acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in each effluent dilution of this test.

- b. The NOEC (No Observed Lethal Effect Concentration) is defined as the greatest effluent dilution at and below which lethality that is statistically different from the control (0% effluent) at the 95% confidence level does not occur. Acute test failure is defined as a demonstration of a statistically significant lethal effect at test completion to a test species at or below the critical dilution.
- c. The conditions of this item are effective beginning with the effective date of the WET limit. When the testing frequency stated above is less than monthly and the effluent fails the survival endpoint at or below the critical dilution, the permittee shall be considered in violation of this permit limit and the frequency for the affected species will increase to monthly until such time compliance with the Lethal No Observed Effect Concentration (NOEC) effluent limitation is demonstrated for a period of three consecutive months, at which time the permittee may return to the testing frequency stated in PART I of this permit. During the period the permittee is out of compliance, test results shall be reported on the DMR for that reporting period.  
The purpose of additional tests (also referred to as 'retests' or confirmation tests) is to determine the duration of a toxic event. A test that meets all test acceptability criteria and demonstrates significant toxic effects does not need additional confirmation. Such testing cannot confirm or disprove a previous test result.
- d. This permit may be reopened to require chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.

## 2. REQUIRED TOXICITY TESTING CONDITIONS

### a. TEST ACCEPTANCE

The permittee shall repeat a test, including the control and all effluent dilutions, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.
- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for the Daphnia pulex survival test and fathead minnow survival test.
- iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution unless significant lethal effects are exhibited for the Daphnia pulex survival test and/or the fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. STATISTICAL INTERPRETATION

For the Daphnia pulex survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods fEPA-821-R-02-012 or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 2.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration and all lower dilution concentrations, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the DMR reporting requirements found in Item 3 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be receiving water collected as close to the point of discharge as possible but unaffected by the discharge. The permittee shall substitute synthetic dilution water of similar pH, hardness, and alkalinity to the closest downstream perennial water where the receiving stream is classified as intermittent or where the receiving stream has no flow due to zero flow conditions.
- ii. If the receiving water is unsatisfactory as a result of instream toxicity (fails to fulfill the test acceptance criteria of Item 2.a), the permittee may substitute synthetic dilution water for the receiving water in all subsequent tests provided the unacceptable receiving water test met the following stipulations:
  - (A) a synthetic dilution water control which fulfills the test acceptance requirements of Item 2.a was run concurrently with the receiving water control;
  - (B) the test indicating receiving water toxicity has been carried out to completion (i.e., 48 hours);
  - (C) the permittee includes all test results indicating receiving water toxicity with the full report and information required by Item 3.a below; and
  - (D) the synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. SAMPLES AND COMPOSITES

- i. The permittee shall collect two flow-weighted composite samples from the outfall(s) listed at Item 1.a above.
- ii. The permittee shall collect a second composite sample for use during the 24-hour renewal of each dilution concentration for both tests. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.
- iii. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 3 of this section.

3. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA-821-R-02-012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.3 of this permit. The permittee shall submit full reports upon the specific request of the Agency. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. The permittee shall report the Whole Effluent Lethality values for the 30-Day Average Minimum and the 48-Hr. Minimum under Parameter No. 22414 on the DMR for that reporting period in accordance with PART III.D.4 of this permit.

If more than one valid test for a species was performed during the reporting period, the test NOECs will be averaged arithmetically and reported as the DAILY AVERAGE MINIMUM NOEC for that reporting period.

If more than one species is tested during the reporting period, the permittee shall report the lowest 30-Day Average Minimum NOEC and the lowest 48-Hr. Minimum NOEC for Whole Effluent Lethality.

A valid test for each species must be reported on the DMR during each reporting period specified in PART I of this permit. Only ONE set of biomonitoring data for each species is to be recorded on the DMR for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached to the DMR for EPA review.

- c. The permittee shall submit the results of the valid toxicity test on the DMR for that reporting period in accordance with PART III.D.4 of this permit, as follows below. Submit retest information clearly marked as such with the following month's DMR. Only results of valid tests are to be reported on the DMR.

i. Pimephales promelas (Fathead minnow)

- (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
- (B) Report the NOEC value for survival, Parameter No. TOM6C.
- (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.

ii. Daphnia pulex

- (A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.
- (B) Report the NOEC value for survival, Parameter No. TOM3D.
- (C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

4. MONITORING FREQUENCY REDUCTION

This section does not apply to any species for which the permit establishes whole effluent toxicity (WET) limits. For the first five years after the effective date of a WET limit, the minimum monitoring frequency for the affected species is once per quarter.

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first four consecutive quarters of testing for a test species, with no lethal or sub-lethal effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for that test species may be reduced to not less than once per year for the less sensitive species (usually the Fathead minnow) and not less than twice per year for the more sensitive test species (usually the *Daphnia pulex*).
- b. **CERTIFICATION** - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for lethal effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.
- c. **SURVIVAL FAILURES** - If any test fails the survival endpoint at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per quarter until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.
- d. This monitoring frequency reduction applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per quarter until the permit is re-issued.