

NPDES authorization to discharge to waters of the United States, Permit No. NM0029602

The applicant's mailing address is:

City of Rio Rancho
Utility Operation Division
3200 Civic Center Circle NE
Rio Rancho, NM 87144

The discharge from this facility is located at 1605 Riverside Drive, Rio Rancho, Sandoval County, New Mexico. Under the SIC code 4952, the applicant operates City of Rio Rancho WWTP #3, which has a design flow of 0.85 MGD along with Rio Rancho WWTP #2 providing sanitary services for approximately 91,956-population in total. The facility has been offline since 2003, but with the population increasing it's expected this facility will be needed for future growth. Effluent is UV-disinfected before discharged to the Rio Grande River, Middle Rio Grande River Basin (Segment No.20.6.4.106 NMAC). Designated uses of the receiving water are stated in the Fact Sheet.

This is a renewal of a permit issued on on September 24, 2010, with an effective date of November 1, 2010, and an expiration date of October 31, 2015.

Changes from the previous permit are:

- Removal percentage for BOD₅ and TSS has been established.
- Monitoring frequency for pH has been reduced to 5/week from daily.
- Monitoring of adjusted gross alpha have been added.
- Samples analysis for TDS, chlorides and sulfates have been added.

A fact sheet is available.

State Certification

This Notice also serves as Public Notice of the intent of the New Mexico Environment Department, Surface Water Quality Bureau to consider issuing Clean Water Act (CWA) Section 401 Certification. The purpose of such certification is to reasonably ensure that the permitted activities will be conducted in a manner that will comply with applicable New Mexico water quality standards, including the antidegradation policy, and the statewide water quality management plan. The NPDES permit will not be issued until the certification requirements of Section 401 have been met.

If you want to comment on State Certification submit written comments within the 30 day period to:

Bruce Yurdin, Program Manager
Surface Water Quality Bureau
New Mexico Environment Department

P.O. Box 5469
1190 Saint Francis Drive
Santa Fe, NM 87502-5469
Phone (505) 827-2795
Fax (505) 827-0160
bruce.yurdin@state.nm.us