



REGION 6
1445 ROSS AVENUE
DALLAS, TEXAS 75202-2733

NPDES Permit No NM0031135

AUTHORIZATION TO DISCHARGE UNDER THE NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

In compliance with the provisions of the Clean Water Act, as amended, (33 U.S.C. 1251 et. seq; the "Act"),

Farmington Electric Utility System - Bluffview Power Plant
101 N. Browning Parkway
Farmington, NM 87401

is authorized to discharge from the Bluffview Power Plant located at 755 W. Murray Dr., Farmington, San Juan County, New Mexico, to receiving waters named San Juan River in Waterbody Segment Code 20.6.4.401, of the San Juan Basin, the discharge located on that water at the following coordinates:

Outfall 001: Latitude 36° 42' 56" North, Longitude 108° 13' 20" West

in accordance with this cover page and the effluent limitations, monitoring requirements, and other conditions set forth in Part I, Part II, and Part III hereof.

This permit shall become effective on

This permit and the authorization to discharge shall expire at midnight

Issued on

Prepared by

William K. Honker
Director
Water Quality Protection Division (6WQ)

Isaac Chen
Environmental Engineer
Permits & Technical Section (6WQ-PP)

(This page intentionally left blank)

PART I – REQUIREMENTS FOR NPDES PERMITS

SECTION A. LIMITATIONS AND MONITORING REQUIREMENTS

1. OUTFALL 001 Effluent Limits

During the period beginning the effective date of the permit and lasting through the expiration date of the permit (unless otherwise noted), the permittee is authorized to discharge cooling tower blowdown, Reverse Osmosis (RO) waste, evaporator coolant (summer only), and various floor drains to San Juan River, in Segment Number 20.6.4.401, from Outfall 001. Such discharges shall be limited and monitored by the permittee as specified below:

EFFLUENT CHARACTERISTICS		DISCHARGE LIMITATIONS		MONITORING REQUIREMENTS	
		Standard Units			
POLLUTANT	STORET CODE	MINIMUM	MAXIMUM	MEASUREMENT FREQUENCY	SAMPLE TYPE
pH	00400	6.6	9.0	Daily	Grab

EFFLUENT CHARACTERISTICS	DISCHARGE LIMITATIONS				MONITORING REQUIREMENTS	
	lbs/day, unless noted		mg/l, unless noted (*2)		MEASUREMENT FREQUENCY	SAMPLE TYPE
POLLUTANT	30-DAY AVG	DAILY MAX	30-DAY AVG	DAILY MAX		
Flow	Report MGD	Report MGD	***	***	Continuous	Record
Total Dissolved Solids (TDS)	Report	<2,000	Report	3,475	Once/Month	12-Hr Composite
Total Suspended Solids (TSS)	17.26	57.55	30	100	Once/Month	Grab
Oil & Grease (O&G)	8.63	11.51	15	20	Once/Month	Grab
Total Residual Chlorine (TRC)	N/A	N/A	N/A	19 ug/l	Daily	Grab (*1)
Total Aluminum	N/A	N/A	1.701	1.701	Once/Quarter	Grab

EFFLUENT CHARACTERISTICS	DISCHARGE MONITORING		MONITORING REQUIREMENTS	
	30-DAY AVG	48-HOUR	MEASUREMENT	SAMPLE TYPE
Whole Effluent Toxicity Testing (48-Hour Static Renewal) (*2)	MINIMUM	MINIMUM	FREQUENCY	
Daphnia pulex	Report	Report	Once/Six Months	24-Hr Composite
Pimephales promelas	Report	Report	Once/Six Months	24-Hr Composite

Footnotes:

- *1 The maximum total residual chlorine (TRC) shall be monitored by grab sample once per day and analyzed within 15 minutes of collection. The effluent limitation for TRC is the instantaneous maximum and cannot be averaged for reporting purposes.
- *2 Monitoring and reporting requirements begin on the effective date of this permit. See Part II, Whole Effluent Toxicity Testing Requirements for additional WET monitoring and reporting conditions.

SAMPLE LOCATIONS

Samples taken in compliance with the monitoring requirements specified above shall be taken at the discharge after the final treatment unit and prior to the receiving stream.

B. SCHEDULE OF COMPLIANCE

NONE

C. MONITORING AND REPORTING (MINOR DISCHARGERS)

Monitoring results must be reported either using the electronic or paper Discharge Monitoring Report (DMR) approved formats to EPA. If using paper DMR forms, the report shall be also sent to NMED and shall be submitted quarterly. Each quarterly submittal shall include separate forms for each month of the reporting period. See Part III, D.4 of the permit.

1. Reporting periods shall end on the last day of the months March, June, September, and December.
2. The permittee is required to submit regular quarterly reports as described above postmarked no later than the 28th day of the month following each reporting period.

D. PROHIBITIONS**1. TRANSFORMER FLUID DISCHARGE**

There shall be no discharge of transformer fluid containing polychlorinated biphenyl (PCB) compounds.

2. METAL CLEANING WASTE

The term "metal cleaning waste" means any wastewater resulting from cleaning (with or without chemical cleaning compounds) any metal process equipment including, but not limited to, boiler tube cleaning, boiler fireside cleaning, and air preheater cleaning.

The term "chemical metal cleaning wastes" means any wastewater resulting from the cleaning of any metal process equipment with chemical compounds, including, but not limited to, boiler tube cleaning.

There shall be no discharges of metal cleaning wastes or chemical metal cleaning wastes.

3. COOLING TOWER MAINTENANCE CHEMICALS

If cooling tower maintenance chemicals are required, the permittee must demonstrate through engineering calculations that the 126 priority pollutants (listed at 40CFR423,

Appendix A) contained in chemicals are limited to "no detectable amount," in the discharge, except total chromium (0.2 mg/l) and total zinc (1.0 mg/l).

The use of chemical additives which may contain any of the 126 priority pollutants or may adversely impact aquatic lives is not authorized unless approval is obtained and limitations are established on a case-by-case basis.

PART II - OTHER CONDITIONS

A. MINIMUM QUANTIFICATION LEVEL (MQL)

See list of MQL's at Appendix A of Part II below. For pollutants listed on Appendix A of Part II below with MQL's, analyses must be performed to the listed MQL. If any individual analytical test result is less than the MQL listed, a value of zero (0) may be used for that pollutant result for the Discharge Monitoring Report (DMR) calculations and reporting requirements.

In addition, any additional pollutant sampling for purposes of this permit, including renewal applications or any other reporting, shall be tested to the MQL shown on the attached Appendix A of Part II.

B. 24-HOUR ORAL REPORTING: DAILY MAXIMUM LIMITATION VIOLATIONS

Under the provisions of Part III.D.7.b.(3) of this permit, violations of daily maximum limitations for the following pollutants shall be reported orally to EPA Region 6, Compliance and Assurance Division, Water Enforcement Branch (6EN-W), Dallas, Texas, and NMED within 24 hours from the time the permittee becomes aware of the violation followed by a written report in five days.

Total Recoverable Aluminum
TRC
TSS
Oil & Grease
TDS

C. PERMIT MODIFICATION AND REOPENER

In accordance with 40 CFR Part 122.44(d), the permit may be reopened and modified during the life of the permit if relevant portions of New Mexico's Water Quality Standards for Interstate and Intrastate Streams are revised, or new water quality standards are established and/or remanded.

In accordance with 40 CFR Part 122.62(a)(2), the permit may be reopened and modified if new information is received that was not available at the time of permit issuance that would have justified the application of different permit conditions at the time of permit issuance.

D. WHOLE EFFLUENT TOXICITY TESTING (48 HOUR ACUTE NOEC FRESHWATER)

It is unlawful and a violation of this permit for a permittee or his designated agent, to manipulate test samples in any manner, to delay sample shipment, or to terminate or to cause to terminate a toxicity test. Once initiated, all toxicity tests must be completed unless specific authority has been granted by EPA Region 6 or the State NPDES permitting authority.

1. SCOPE AND METHODOLOGY

- a. The permittee shall test the effluent for toxicity in accordance with the provisions in this section.

APPLICABLE TO FINAL OUTFALL(S):	001
REPORTED ON DMR AS FINAL OUTFALL:	001
CRITICAL DILUTION:	0.24%
COMPOSITE SAMPLE TYPE:	Defined at PART I; Grab
TEST SPECIES/METHODS:	40 CFR Part 136

Daphnia pulex acute static renewal 48 hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in the Critical Dilution (CD) concentration.

Pimephales promelas (Fathead minnow) acute static renewal 48-hour definitive toxicity test using EPA-821-R-02-012, or the latest update thereof. A minimum of five (5) replicates with eight (8) organisms per replicate must be used in the control and in the CD concentration.

- b. This permit may be reopened to require whole effluent toxicity limits, chemical specific effluent limits, additional testing, and/or other appropriate actions to address toxicity.
- c. This permit does not establish requirements to automatically increase the WET testing frequency after a test failure, or to begin a toxicity reduction evaluation (TRE). However, upon failure of a WET test, the permittee must report the test results to EPA, in writing, within 5 business days of notification of the test failure. EPA will review the test results and determine the appropriate action necessary, if any.

2. REQUIRED TOXICITY TESTING CONDITIONS

- a. Test Acceptance

The permittee shall repeat a test, including the control and the CD concentration, if the procedures and quality assurance requirements defined in the test methods or in this permit are not satisfied, including the following additional criteria:

- i. Each toxicity test control (0% effluent) must have a survival equal to or greater than 90%.

- ii. The percent coefficient of variation between replicates shall be 40% or less in the control (0% effluent) for: *Daphnia pulex* survival test; and Fathead minnow survival test.
- iii. The percent coefficient of variation between replicates shall be 40% or less in the critical dilution, unless significant lethal effects are exhibited for: *Daphnia pulex* survival test; and Fathead minnow survival test.

Test failure may not be construed or reported as invalid due to a coefficient of variation value of greater than 40%. A repeat test shall be conducted within the required reporting period of any test determined to be invalid.

b. Statistical Interpretation

For the *Daphnia pulex* survival test and the Fathead minnow survival test, the statistical analyses used to determine if there is a statistically significant difference between the control and the critical dilution shall be in accordance with the methods for determining the No Observed Effect Concentration (NOEC) as described in EPA-821-R-02-012 Section 11.3.6, SINGLE CONCENTRATION TEST, or the most recent update thereof.

If the conditions of Test Acceptability are met in Item 2.a above and the percent survival of the test organism is equal to or greater than 90% in the critical dilution concentration, the test shall be considered to be a passing test, and the permittee shall report an NOEC of not less than the critical dilution for the reporting requirements found in Item 3 below.

c. Dilution Water

- i. Dilution water used in the toxicity tests will be synthetic dilution water. The synthetic dilution water shall have a pH, hardness, and alkalinity similar to that of the receiving water or closest downstream perennial water not adversely affected by the discharge, provided the magnitude of these parameters will not cause toxicity in the synthetic dilution water.

d. Samples and Composites

- i. The permittee shall collect two flow weighted composite samples from the outfall(s) listed at Item 1.a above.
- ii. The permittee shall collect a second composite sample for use during the 24 hour renewal of the critical dilution concentration for both tests. The permittee must collect the composite samples so that the maximum holding time for any effluent sample shall not exceed 36 hours. The permittee must have initiated the toxicity test within 36 hours after the collection of the last portion of the first composite sample. Samples shall be chilled to 6 degrees Centigrade during collection, shipping, and/or storage.

- iii. The permittee must collect the composite samples such that the effluent samples are representative of any periodic episode of chlorination, biocide usage or other potentially toxic substance discharged on an intermittent basis.
- iv. If the flow from the outfall(s) being tested ceases during the collection of effluent samples, the requirements for the minimum number of effluent samples, the minimum number of effluent portions and the sample holding time are waived during that sampling period. However, the permittee must collect an effluent composite sample volume during the period of discharge that is sufficient to complete the required toxicity tests with daily renewal of effluent. When possible, the effluent samples used for the toxicity tests shall be collected on separate days. The effluent composite sample collection duration and the static renewal protocol associated with the abbreviated sample collection must be documented in the full report required in Item 3 of this section.

3. REPORTING

- a. The permittee shall prepare a full report of the results of all tests conducted pursuant to this Part in accordance with the Report Preparation Section of EPA-821-R-02-012, for every valid or invalid toxicity test initiated, whether carried to completion or not. The permittee shall retain each full report pursuant to the provisions of PART III.C.3 of this permit. The permittee shall submit full reports upon the specific request of the Agency. For any test which fails, is considered invalid or which is terminated early for any reason, the full report must be submitted for agency review.
- b. A valid test for each species must be reported during each reporting period specified in PART I of this permit unless the permittee is performing a TRE which may increase the frequency of testing and reporting. Only ONE set of biomonitoring data for each species is to be recorded for each reporting period. The data submitted should reflect the LOWEST Survival results for each species during the reporting period. All invalid tests, repeat tests (for invalid tests), and retests (for tests previously failed) performed during the reporting period must be attached for EPA review.
- c. The permittee shall report the following results of each valid toxicity test. Submit retest information, if required, clearly marked as such. Only results of valid tests are to be reported.
 - i. *Pimephales promelas* (Fathead minnow)
 - (A) If the No Observed Effect Concentration (NOEC) for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM6C.
 - (B) Report the NOEC value for survival, Parameter No. TOM6C.

(C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM6C.

ii. *Daphnia pulex*

(A) If the NOEC for survival is less than the critical dilution, enter a "1"; otherwise, enter a "0" for Parameter No. TEM3D.

(B) Report the NOEC value for survival, Parameter No. TOM3D.

(C) Report the highest (critical dilution or control) Coefficient of Variation, Parameter No. TQM3D.

4. MONITORING FREQUENCY REDUCTION

- a. The permittee may apply for a testing frequency reduction upon the successful completion of the first two consecutive 6 month periods of testing for one or both test species, with no effects demonstrated at or below the critical dilution. If granted, the monitoring frequency for either or both test species may be reduced to not less than once per year.
- b. CERTIFICATION - The permittee must certify in writing that no test failures have occurred and that all tests meet all test acceptability criteria in item 3.a. above. In addition the permittee must provide a list with each test performed including test initiation date, species, NOECs for the effects and the maximum coefficient of variation for the controls. Upon review and acceptance of this information the agency will issue a letter of confirmation of the monitoring frequency reduction. A copy of the letter will be forwarded to the agency's Permit Compliance System section to update the permit reporting requirements.
- c. If any test fails at any time during the life of this permit, three monthly retests are required and the monitoring frequency for the affected test species shall be increased to once per 6 months until the permit is re-issued. Monthly retesting is not required if the permittee is performing a TRE.

Any monitoring frequency reduction granted applies only until the expiration date of this permit, at which time the monitoring frequency for both test species reverts to once per 6 months until the permit is re-issued