

NPDES authorization to discharge to waters of the United States, Permit No. TX0005886
 The applicant's mailing address is:

ONEOK Hydrocarbons Southwest, L.L.C.
 P.O. Box 550
 Mont Belvieu, TX 77580

The discharges from this facility are as described in the table below:

Outfall Reference Number	Discharge Coordinates: Latitude Deg° Min' Sec'' Longitude Deg° Min' Sec''	Type of Discharge	Discharge Volume MGD	Receiving Water	Water Body Segment
001	29° 50' 54" N 94° 56' 35" W	Non-process wastewater, including cooling, blowdown and washdown waters	0.253	Cedar Bayou above Tidal	0902 of the Trinity-San Jacinto River Basin
002	29° 51' 24" N 94° 54' 38" W	Hydrostatic test water, storm water runoff and fire water	0.167	Unnamed ditch, thence to Cedar Bayou above Tidal	0902 of the Trinity-San Jacinto River Basin

The facility is an existing discharger and EPA proposes a renewal on the existing permit issued on April 14, 2009, with an effective date of June 1, 2009, and an expiration date of May 31, 2014. A Fact Sheet is available, and describes the rationale for the permit renewal. Under the SIC Code 1321, the applicant operates a natural gas liquid plant. Proposed changes from the previous permit are as follow:

- Mass limits have been established at Outfall 001.
- TSS, copper, selenium, and mercury limitations have been established at Outfall 001.
- Temperature monitoring has been established at Outfall 001.
- TRC limit has been changed from 33 ug/l to 11 ug/l and monitoring frequency has been increased to 2/month from 1/month.
- 3-hour composite sample type has been changed from grab type at Outfall 001.
- Aluminum limit has been changed to 9.5 mg/l for daily max. at outfall 001.
- BTEX has been established at Outfall 002.