

NPDES authorization to discharge to waters of the United States, Permit No. TX0067687  
The applicant's mailing address is:

XTO Energy, Inc.  
P.O. Box 2789  
Kilgore, TX 75663

The discharges from this facility are as described in the table below:

Outfall Reference Number	Discharge Coordinates: Latitude Deg° Min' Sec'' Longitude Deg° Min' Sec''	Type of Discharge	Discharge Volume MGD	Receiving Water	Water Body Segment
001	32° 36' 25" N 95° 11' 54" W	Non-process wastewater	0.504	Rodgers Creek, thence to Sabine River	0506 of the Sabine River Basin

The facility is an existing discharger and EPA proposes a renewal on the existing permit issued on July 17, 2009, with an effective date of September 1, 2009, and an expiration date of August 31, 2014. A Fact Sheet is available, and describes the rationale for the permit renewal. Under the SIC Code 1321, the applicant operates a natural gas liquid plant. Proposed changes from the previous permit are as follow:

- Mass limits have been established for BOD.
- Discharge flow has changed to 0.504 MGD.
- New limitation/monitoring for TSS, TDS, BTEX, cadmium, copper and mercury has been established.
- TRC limit has been changed from 33 ug/l to 11 ug/l.
- Monitoring frequencies have been changed for BOD and TRC.
- 3-hour composite sample type has been changed from grab type.
- Limit for WET testing has been established.