

NPDES authorization to discharge to waters of the United States, Permit No. TX0125067  
 The applicant's mailing address is:

Golden Pass LNG Terminal, LLC  
 P.O. Box 302  
 Sabine Pass, TX 77655

The discharges from this facility are as described in the table below:

Outfall Reference Number	Discharge Coordinates: Latitude Deg° Min' Sec'' Longitude Deg° Min' Sec''	Type of Discharge	Discharge Volume	Receiving Water	Water Body Segment
001	29° 45' 47.05" N 93° 55' 6.64" W	Non-process wastewater	0.12 MG/week	Sabine-Neches Canal Tidal Waterway	Neches-Trinity Coastal Basin (0703)
002 & 003	29° 45' 42" N 93° 55' 23" W; 29° 45' 40" N 93° 55' 37" W	Non-process wastewater	Incidental	Sabine-Neches Canal Tidal Waterway	Neches-Trinity Coastal Basin (0703)

The facility is an existing discharger and EPA proposes a renewal on the existing permit modified on October 20, 2010, with an effective date of November 1, 2010, and an expiration date of December 31, 2014. A Fact Sheet is available, and describes the rationale for the permit renewal. Under the SIC Code 4922, the applicant operates a natural gas liquid plant. Proposed changes from the previous permit are as follow:

- Additional Outfalls 002&003 and applicable limits have been established.
- TRC has been removed at Outfall 001.
- pH limit has been changed to 6.5-9.0 s.u. from 6.0-9.0 s.u.
- Measurement frequency has been changed to weekly from daily at Outfall 001.