

DATE: 9 January 1995

SUBJECT: Request for Clarification of Data Inputs for CTDM+
(Merrimack Generating Station, Bow NH)

FROM: Brian Hennessey, Regional Modeling Contact
Air Permits & Assessment Section, Region I EPA

TO: Dennis Doll, Model Clearinghouse Coordinator
Air Quality Modeling Group, EMAD, OAQPS

This is a request for Model Clearinghouse concurrence with the approval of a CTDM+ modeling protocol under the stipulation that a 1-hour averaging time be used for the required σ_p input.

Public Service Company of New Hampshire (PSNH) must identify design emission/configuration combinations which will protect National Ambient Air Quality Standards from SO₂ emissions of the two cyclone units of its Merrimack Station. PSNH plans to model downwash on simple terrain using ISCST2 and on-site data, and impacts on complex terrain with CTDM+. As the company noted on p. 11 of its meteorological monitoring protocol (enclosure 5), absent final guidance from EPA, σ_p values on both 15-minute and 1-hour averaging times were archived for possible use in estimating neutral and stable plume spread in CTDM+. Page 13 of the draft modeling protocol (enclosure 3) does not specify which of the two data sets would be used for refined CTDM+ modeling.

Enclosure 1 presents draft comments by Region I and NH Air Resources Division concerning the modeling protocol and other items submitted by PSNH. We ask your concurrence with comment B.(4), which stipulates that PSNH use a 1-hour averaging time for the σ_p input, not the 15-minute averaging time recommended to select a Pasquill-Gifford curve. Because the protocol marks our first regulatory (as opposed to training) application of CTDM+, we would welcome any other comments you can provide on the technical merits of PSNH's modeling protocol.

Enclosures:

- (1) Draft "New Hampshire DAR and U.S. EPA Joint Comments..."
- (2) Letter from PSNH regarding "Meteorological Data Gap", 30 September 1994.
- (3) "Proposed Modeling Protocol for PSNH's Merrimack Generating Station", 29 April 1994.
- (4) "Meteorological Data Comparison Merrimack Station Meteorological Tower vs. Doppler Acoustic Sounder".
- (5) "Protocol for On-site Meteorological Monitoring Program at Merrimack Generating Station", Revised 20 August 1993.

FY-95 MODEL CLEARINGHOUSE MEMORANDA

<u>Date</u>	<u>Region</u>	<u>Subject</u>
11/04/94	V	Model Clearinghouse Review of Modeling Approaches in the Stuebenville-Follansbee Area
01/17/95	I	Request for Clarification on CTDMPPLUS Model Inputs (Merrimack Generating Station, BOW NH)