

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

State(s): FLORIDA
Pollutant(s): SO2
Regulation(s): PSD
Source(s): Sugar Mill
Model(s): ISC3
 PRIME
Subject(s): Technical Credibility of Nonguideline Techniques
Urban/Rural: Rural Only
Oral/Written: Oral
Terrain: Essentially Flat Terrain
Guideline: Non-guideline
Database: Off-site
Involvement: Review and Comment
Record Comments:

Issue: Region IV has developed a draft of its evaluation of U.S. Sugar's proposed use of the ISC -PRIME model for a PSD analysis. The Region asked the C/H to provide comments on the draft. Below is 1) the Region IV request to the C/H with the draft evaluation, 2) The C/H Comments on the draft, 3) a copy of Region X's April 29, 1998 approval of ISC-PRIME for a source in AK, which is reference by Region IV and by the C/H comments and, 4) a copy of Region IV's final approval letter to the State of FL regarding the U.S. Sugar proposal.

1) Region IV request to the C/H
Attached is a draft of Region IV documentation on a case-by-case evaluation of the non-guideline model ISC-PRIME for application to the US Sugar facility in Florida. We would appreciate the C/H review comments and specific suggestions concerning:
1) Proper procedure for regional case-by-case approval of this non-guideline model
2) Other evaluation items to considered in the approval
3) Any text changes to improve letter/evaluation documentation.
Because Florida DEP issued their Preliminary Determination early in

October, we needs to provide our determination of the acceptability of
of
ISC-PRIME for this application by early next week. Therefore, I
would

appreciate your comments by the end of this week,
Note: I will be out of the office Thursday and Friday of this week
(10/28-29/99).

Let me know if you have any questions.

Thanks...sjk

CC: RTPMAINHUB.INTERNET(JOHNSON-BRENDA)
Mr. A. A. Linero, P.E.
Florida Department of Environmental Protection

Date: 07/31/00

Page: 1

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:

Name: U.S. Sugar--Oct 99
12/20/99

Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

SUBJ: Use of ISC-PRIME
PSD Permit Application
U.S. Sugar Corporation Clewiston Mill
Clewiston, Florida

Dear Mr. Linero:

Thank you for providing the PSD permit application for the U.S. Sugar
Corporation - Clewiston
Mill dated June 1999 (received 7 July 1999). This application for an
increase
operation of the
sugar refinery and Boiler No. 4. Our review comments excluding the air
quality
impact
assessment were provided in our 20 September 1999 letter. The purpose
of this
letter is to
provide our evaluation and determination associated with the use of the
none-guideline ISC-
PRIME dispersion and transport model for the assessment of ambient air
impact
assessments
resulting from the proposed Clewiston mill PSD permit modifications.
The PSD U.S. Sugar Clewiston Mill PSD permit application....[To Be
Completed]

Evaluation of ISC-PRIME For Application To
U.S. Sugar Corporation Clewiston Mill's
Air Quality Impact Assessment

Introduction

The Florida Department of Environmental Protection (FDEP) has reviewed
the
Prevention of

Significant Deterioration (PSD) permit application for a modification of the U.S. Sugar Corporation (U.S. Sugar) Clewiston Mill. One of FDEP's concern was the application of the non-guideline ISC-PRIME dispersion and transport model to the ambient air quality assessment provided in the PSD application. The use of the guideline ISCST3 dispersion and transport model for the U.S. Sugar Clewiston Mill emission sources reveals very large predicted SO2 and PM10 concentrations at the site boundary - concentrations that exceed the PM10 and SO2 National Ambient Air Quality Standards (NAAQS). The ISC-PRIME model run with the same input emission and receptor values also predict large concentrations but none exceeded the applicable PSD increments nor NAAQS. The ISC-PRIME model has been submitted to United State Environmental Protection Agency's (USEPA) Office of Air Quality Planning and Standards (OAQPS) for consideration as a guideline model. OAQPS has reviewed and tested this model. It was also reviewed at the

Date: 07/31/00
Page: 2

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

1998
Regional/State/Local Agency modelers workshop. With a few restrictions, the Workshop participants recommended ISC-PRIME be included as a guideline air quality model in the next revision to the Guideline on Air Quality Models (GAQM). Although OAQPS will propose ISC-PRIME for inclusion as a guideline model, it has not official been proposed and public comment solicited. Therefore, ISC-PRIME is still a non-guideline model that must be evaluated and approved for application on a case-by-

case
basis. The U.S.
Sugar PSD application is the first time the ISC-PRIME model has been
used in a
regulatory
application in USEPA Region 4. The provides a summary of Region 4's
appropriateness and
acceptability evaluation of ISC-PRIME for the assessment of ambient air
impacts
for U.S. Sugar
Clewiston Mill's PSD application.
Reviewed Documents - ISC-Prime and U.S. Sugar Corporation
The following documents were reviewed in the case-by-case determination
of the
appropriateness
and acceptability of the non-guideline ISC-PRIME dispersion and
transport model
for the PSD air
quality impact assessment for the modification of U.S. Sugar Clewiston,
Florida
facility.

1. Hastings, Janis; "Review of the ISC-PRIME model,
GVEA
Healy Power Plant
Air Quality Control No. X049"; Letter from U.S. Environmental
Protection
Agency Region 10 to Alaska Department of Environmental
Conservation;
29
April 1998.
2. Paine, Robert J., and Frances Lew; "Project Prime:
Evaluation of Building
Downwash Models Using Field and Wind Tunnel Data"; Undated
article
and
presentation slides developed by ENSR Corporation for
Electric Power
Research
Institute (EPRI Project RP 3527-02).
3. Paine, Robert J., and Frances Lew; "Results of the
Independent Evaluation of
ISCST3 and ISC-PRIME"; Final Report; Electric Power Research
Institute;
November 1997.
4. Shulman, Loyd L., David G. Strimaitis, and Joseph
S.
Scire; "Development and
Evaluation of the Prime Plume Rise and Building Downwash
Model";
Undated
draft journal article by Earth Tech, Concord, MA.

Date: 07/31/00
Page: 3

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last

Update:

Name: U.S. Sugar--Oct 99
12/20/99

5. Staff Report; "Consequences Analysis of Using ISC-PRIME Over the Industrial Source Complex Short Term Model" (Draft); U.S. Environmental Protection Agency; April 1998.

6. U.S. Sugar Corporation; "Information Submittal No. 3 - PSD Permit Application for Boiler No. 4 and the Sugar Refinery at the Clewiston Mill"; 13 September 1999.

7. U.S. Sugar Corporation; "PSD Permit Application for United States Sugar Corporation Clewiston Boiler No. 4 and Sugar Refinery", prepared by Golder Associates Inc.; June 1999.

Basis of Evaluation

The evaluation criteria for a case-by-case approval of the use of a non-guideline model is given in Section 3.2 of 40 CFR Part 51, Appendix W - Guideline on Air Quality Models (GAQM). In

general, a preferred model must be shown to be not appropriate, and a non-guideline model or procedure shown to be available, more appropriate, and applicable for the application. The points that need to be addressed include:

Proposed model is more technically appropriate for the application.

Adequate data bases are available to perform the modeling analysis.

Performance evaluations of the model are in similar circumstances and show the model not to be bias towards underestimates of concentrations.

Proposed model shows superior performance when compared to reference model.

Technical Evaluation

The ISC-PRIME model was developed to improve the downwash algorithms of the

ISCST3

regulatory model. Two important short comings of the ISCST3 downwash treatment are the

inability to predict concentrations in the building cavity (near wake)

and to assess the affects of stack location relative to the influencing downwash structure. In addition, the downwash routines of ISCST3 were developed largely from data representing neutral stability, moderate-to-high wind speeds, winds perpendicular to the building face, with non- or low-buoyant plumes. These limitations were addressed in the development of ISC-PRIME. Of major concern at the Clewiston Sugar Mill are emissions from the boiler

Date: 07/31/00
Page: 4

Model Clearinghouse Information Storage and Retrieval System
Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:
Name: U.S. Sugar--Oct 99
12/20/99

stacks. These stacks are located between 3 and 5 building lengths from the buildings controlling downwash. Although EPA studies of the effects of building downwash within wakes show reduction as the stack's distance from the controlling building is increased, ISCST3 uses the full downwash effects independent of stack location in the wake region. Thus, ISCST3 modeling of the Clewiston emissions is expected to produce less realistic estimates of wake dispersion than ISC-PRIME. The results of modeling using these two models for the Clewiston facility confirmed the expected: ISC-PRIME produces smaller concentrations in the wake region. In terms of the basis of the downwash algorithms in the ISCST3 and ISC-PRIME models, both models' algorithm are semi-empirical - based on wind tunnel experiments. The empirical data used for ISC-PRIME were largely from extensive series of USEPA performed wind tunnel experiments in 1992 and 1993. The ISCST3 downwash algorithms pre-date these experiments.

Because ISC-PRIME is based on more extensive wind tunnel data sets, it has stronger technical base than ISCST3. On a theoretical basis, ISC-PRIME uses the conservation equations of mass, momentum, and energy. This model accounts for the streamline ascent over structure and descent in the wake region. Also the wind shear effects about and downwind of structures are accounted for in ISC-PRIME. Therefore, the theoretical basis of ISC-PRIME is technically more sophisticated than ISCST3 which should provided more realistic estimates of plume rise, dispersion, and transport conditions in the wake region - a condition applicable to the Clewiston application.

Performance Evaluation

Adequate Data Bases

The data bases used in the development of ISC-PRIME included wind tunnel studies, numerical model results, and both short-term tracer and long-term field measurement programs. An independent evaluation of the completed model was performed by an EPRI contractor using four data bases. This was an independent evaluation as it was: 1) Conducted by a contractor not involved with model development, and 2) Data bases used in evaluation were not used in the model development. A number of performance measures were considered and

Date: 07/31/00

Page: 5

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

statistical tests

performed to determine the significance of performance differences observed.

Thus, adequate

data bases exist for both the development and evaluation of model performance.

In terms of the data needed to run ISC-PRIME, the input data requirements are the same as

ISCST3 with the exception of building dimensions. Similar to the BPIP program providing building information for ISCST3 running, a complimentary program **** has been developed to provide the needed building information for ISC-PRIME. Therefore, adequate input data exist to perform ISC-PRIME model analysis.

Bias of Model

In the assessment of ISC-PRIME model performance, meteorological conditions that produce the highest ground-level concentrations were used (e.g., near-neutral stability and moderate to high wind speeds). Evaluation of both ISCST3 and ISC-PRIME against the independent data bases show that for these downwash producing meteorological conditions, the two models's performances were comparable with ISC-PRIME performing slightly better than ISCST3.

Site specific data from the Clewiston facility site would provide the most relevant basis for model performance evaluation. These data were not available so a review of the similarity of the emission, plant, and receptor conditions used in the ISC-PRIME model evaluation was performed to determine applicability of the evaluation to the Clewiston model application.

Of the evaluation data bases used for ISC-PRIME, the Bowline Point and the Lee Power Plant data are most similar to the boilers at the Clewiston facility in terms of stack heights (87 and 65 meters respectively) and stack to building ratios (1.3 and 1.5 respectively). The buoyant and momentum fluxes are expected to be representative of those at Clewiston. Although the data bases used for ISC-PRIME performance evaluation were not from onsite nor closely similar facilities, they are believed to be representative of the type of conditions experienced at U.S. Sugar Clewiston.

The performance evaluations of ISC-PRIME and ISCST3 models demonstrates generally as well or better performance of ISC-PRIME for the prediction of maximum concentrations during

downwash conditions. ISC-PRIME did not demonstrate a bias toward under predictions. Thus,

Date: 07/31/00

Page: 6^v

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

the independent contractor and independent data bases evaluations demonstrated

ISC-PRIME

overall performance as good as, or better than ISCST3.

Comparison With Reference Model

The previous section discussion of under prediction bias included comparison of

ISCST3 and

ISC-PRIME model results to independent concentration data bases. As indicated,

the

independent evaluations showed the ISC-PRIME model as well as or better than the

ISCST3

model in predicting maximum concentrations.

USEPA performed its own consequence analysis of the ISC-PRIME software and EPRI

reports.

This consisted of verifying that ISCST3 and ISC-PRIME produced the same results

when no

building dimensions were included, confirming the independent modeling results,

and determining

the consequences of using ISC-PRIME for building downwash applications.

The results of this consequence analysis showed

both

models produced the same

results when run without building input data. The PRIME

algorithms

do not

interfere with no downwash function of ISCST3.

The three field studies used in the EPRI

independent

evaluation showed ISC-

PRIME tends to be less conservative than ISCST3 but more

conservative

(i.e.,

produce larger concentrations) than the observed values.

For cavity analyses, output differences between

ISCST3 and

ISC-PRIME were

dependent on stack location, stack to building height ratios,

urban/rural setting,

and downwind distances. ISC-PRIME and ISCST3 converge on common concentrations beyond 1 km and are the same beyond 10 km. In summary, ISC-PRIME provides overall conservative estimates of concentrations that are better than those provided by ISCST3.

Conclusion and Recommendation

Based on the superior technical features contained in ISC-PRIME and the more current and complete data basis used in its development and evaluation, it is concluded that ISC-PRIME is a technically better model than ISCST3 and that it is expected to be at least as good, if not better, at predicting the maximum impacts during downwash conditions. In terms of application to the U.S. Sugar Clewiston facility, it appears that ISC-PRIME should provide a more realistic but conservative estimate of the maximum downwash concentrations from this facility.

Therefore,

Date: 07/31/00
Page: 7

Model Clearinghouse Information Storage and Retrieval System
Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:
Name: U.S. Sugar--Oct 99
12/20/99

ISC-PRIME is considered applicable and appropriate for application to air quality impact assessment for the U.S. Sugar Company's Clewiston Sugar Mill.

2) C/H Comments:
Comments on 10/25/99 draft material supporting the use of ISC-PRIME for U.S. Sugar Clewiston PSD air quality analysis.
D. Wilson
10/26/99

In general, the supporting material is very good and there is no doubt the use of ISC-PRIME is the more appropriate model for the PSD analysis. The comments below are intended primarily to clarify the language on the relationship of the supporting material to Guideline on Air Quality Models language.

1. In the cover letter to the State of FL, which is I understand is

still being developed, Region IV should try to include the points that Region X included in their 4/29/98 letter to AK on the use of the ISC-PRIME model for the GVEA facility.

2. Under the Basis for the Evaluation, it is good that reference is made to Section 3.2 of the Guideline. This clearly provides the authority for selecting the nonguideline model. As we discussed on the phone, the material in Section 3.2 is a little bit confusing in regard to what exactly applies in the U.S. Sugar situation. My take is that in paragraph a of Section 3.2, alternative (2) is what really applies here. The preferred ISC3 model is appropriate; otherwise it would not be the Guideline. The point is that PRIME is more appropriate. With that thought, you might want to change fuzzy up your wording that states that the preferred model is not appropriate.

3. The "adequate data bases" requirement, seems to come from Section 3.2 e ii in the Guideline, which I take to mean the data bases needed to run the model in the application, and not the data bases used in the off-site performance evaluation. If you agree, then you might want to address that issue in a statement separate from your section on performance evaluations. Probably the only points you would need to make is that the data needed to run ISC-PRIME is the same as the data needed to run ISC3 with the exception that more detailed information on stack geometry is needed for ISC-PRIME; such data are available for U.S. Sugar. The "adequate data bases" subtitle under "performance evaluations" could just be

Date: 07/31/00

Page: 8^v

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99

12/20/99

re-titled "data
bases."

4. The "Performance Evaluations" section might be better if it were labeled "Off-site Performance Evaluations." Then an introductory statement or two to that section could explain that there are no on-site data bases available at U.S. Sugar but that performance evaluations in similar circumstances do exist. Then point out that the Guideline allows the use of off-site performance evaluations in such circumstances. Maybe you could use some language from the Region X letter, in their 3rd paragraph under performance evaluations. Maybe this could be done better than I have suggested, but the important point is to clearly state that an on site evaluation is not possible but that allowable off site evaluations provide the requisite support.

5. As we discussed on the telephone, in the last sentence of the second paragraph under Bias of the Model, it would be better if we could remove the phrase "nor closely similar facilities."

3) Region X April 29, 1998 approval of use of ISC-PRIME
April 29, 1998
OEA-095

Robert W. Hughes
Manager, Permits and Compliance
Alaska Department of Environmental Conservation
410 Willoughby Avenue, Suite 105
Juneau, Alaska 99801-1795
Re- Review of the ISC-PRIME model, GVEA Healy Power Plant Air
Quality Control No- X049

Dear Mr. Hughes;

This is in response to your February 4, 1998 request that EPA approve the use of the ISC-PRIME model (version 97224) to assess the ambient air quality impact of the Golden Valley Electric Association (GVEA) Healy Power Plant in Healy, Alaska.

We have reviewed the documentation supplied to us by GVEA in support of their use of a non-Guideline model, i.e. a model not currently recommended in EPA's Guideline on Air Quality Models (40 CFR 51, Appendix W). Our evaluation (summary enclosed) of their submittal has shown that ISC-PRIME is technically superior to the EPA-recommended model,

ISCST3.

Moreover, ISC-PRIME appears to perform as well or better than the ISCST3 model in comparisons of the model predictions to observed concentrations. These performance evaluations

Date: 07/31/00

Page: 9

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

show that ISC-PRIME is not significantly biased toward under-estimation of maximum concentrations. Therefore, we believe ISC-PRIME is appropriate for this application.

We hereby grant approval for the use of the ISC-PRIME model for assessment of air quality impacts of the Healy Power Plant for this application for a permit revision. In accordance with our Agency's division of responsibilities with respect to non-Guideline model approval, this approval by EPA Region X is a case-specific approval and should not be construed to imply approval for applications of ISC-PRIME to other sources. EPA's Office of Air Quality Planning and Standards is currently considering generic approval of the ISC-PRIME model, and, if appropriate, OAQPS will propose the approval of the generic application of ISC-PRIME later this year.

Please note that in your process for revision of the Healy Power Plant air quality control permit, you must give public notice of this case-specific use and approval of the ISC-PRIME model as the basis for this permit revision, and give opportunity for a public hearing on this matter.

If you have any questions, or if we can be of further assistance, please contact Rob Wilson

of my staff at (206) 553-1531.
Sincerely,
Janis Hastings, Director
Office of Environmental Assessment
enclosure

copies w/ enclosure to;
Bud Rolofson, National Park Service, Denver
Joan Darnell National Park Service, Anchorage
Michele Brown, Commissioner, ADEC, Juneau
John M. Stone ADEC, Juneau
James Baumgartner, ADEC, Juneau
Kathryn Lamal, (GVEA, Fairbanks
Joseph A. Tikvart, EPA/OAQPS, Research Triangle Park NC

Summary Evaluation of the Golden Valley Electric Association
Proposal for Use of the ISC-PRIME Model
Robert B. Wilson
U.S. Environmental Protection Agency, Region 10
April 29, 1998
Introduction

In a letter dated February 4, 1998, the Alaska Department of
Environmental Conservation

Date: 07/31/00
Page: 10

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

(ADEC) requested EPA Region 10 approval of the use of a model, ISC-
PRIME, which
is not
currently recommended a EPA's Guideline on Air Quality Models (40 CFR
51,
Appendix W. The
Golden Valley Electric Association has employed the ISC-PRIME model in
its
request to ADEC
for a revision to its operating permit for its power plant in Healy,
Alaska.
Specifically, GVEA is
seeking higher limits on the short-term emissions of sulfur dioxide
(SO₂) from
Unit I of the Healy
Power Plant. The use of the ISC-PRIME model, in lieu of the EPA
recommended
ISCST3
model, indicates that additional amounts of SO₂ can be emitted from the
Healy
Unit I stack
without causing exceedances of the National Ambient Air Quality
Standards.

The ISC-PRIME model was developed by the Electric Power

Research
Institute (EPRI)
and its contractors over the past approximately four years. GVEA has
been one of
several
sponsors of this effort. EPRI and its contractors have compared the
ISC-PRIME
model to EPA's
ISC3 model, and evaluated the performance of the two models against
observed
concentrations.
The technical reports of EPRI's form the basis for GVEA's requested
approval of
the use of the
ISC-PRIME model.

This submittal of ISC-PRIME to EPA Region 10 is the first time
the
model has been
considered for approval in a regulatory action. EPA Region 10's
evaluation of
GVEA's submittal
is presented below. EPRI has subsequently submitted the ISC-PRIME model
to EPA's
Office of
Air Quality Planning and Standards (OAQPS), requesting that ISC-PRIME be
listed
as a
generically recommended model in EPA's Guideline on Air Quality Models.
If
appropriate,
OAQPS will formally propose ISC-PRIME for Guideline status later this
year.

Documents Reviewed

1) "Air Quality Construction Permit Application," submitted to
Alaska Department of Environmental Conservation, Air Quality Control
Permit to
Operate, No 9431-AA001, for the Healy Power Plant, submitted from Golden
Valley
Electric
Association, Inc., Fairbanks, Alaska, December 24, 1997, which includes:
a) Cover letter from Kathryn Lamal, GVEA, to John Stone, ADEC,
dated December 24, 1997.
b) "Air Quality Dispersion Modeling Report to Support Request for
Modification
of Air Quality
Control Permit to Operate No. 9431-AA001 for the Golden Valley Electric
Association, Inc
Healy Power Plant, submitted to the ADEC, prepared for Alaska Industrial

Date: 07/31/00

Page: 11

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

Development and Export Authority and GVEA, prepared by RTP Environmental Associates, Inc., Boulder, Colorado, and Steigers Corporation, Englewood, Colorado, December 1997.

c) ADEC Air Quality Control Permit to Operate No. 9431-AA001, May 12, 1994, and cover letter from Leonard Verelli, ADEC, to Frank Abogg, GVEA, dated May 12, 1994.

d) ADEC Final Supplemental Technical Analysis Report, May 6, 1994, for Healy Power Plant.

e) Electronic files Containing the ISC-PRIME model and associated programs, input, and output files, developed in support of the modeling documented in Item b above.

f) Results of the Independent Evaluation of ISCST3 and ISC-PRIME," prepared by Robert Paine and Frances Lew, ENSR, Electric Power Research Institute Report TR-2460026, W03527-02, November 1997, including Appendices A through EE

2) "Consequence Analysis for ISC-Prime," prepared by Robert J. Paine and Frances Lew, ENSR, Electric Power Research: Institute Report TR-2460026, W03527-02, November 1997, including Appendices A through EE.

3) PRIME Model & Documentation, CD-ROM, EPRI, January 16, 1992, and PRIME Model & Documentation - Addendum Diskette, ~ January 20, 1998.

4) Letter from Kathryn Lamal, GVEA, to James Baumgartner, ADEC, dated February 18, 1998, regarding revision to GVEA's Air Quality Construction Permit to Amend Alaska Air Quality Permit to Operate 9431-AA001 for the Healy Power Plant, Healy, Alaska.

5). "Development and Evaluation of the PRIME Plume Rise and Building Downwash Model," by Lloyd L. Schulman, et al., Earth Tech, Concord, Massachusetts, undated, draft journal article submitted to Atmospheric Environment, EPA Region 10 Review Copy, received March 1998.

Evaluation Criteria

The evaluation of the ISC-PRIME model, in comparison to the ISCST3 model, centers on two basic elements. The first is the technical basis of the model i.e. assessing which model is superior from a theoretical standpoint. The second is model performance, i.e., determining whether ISC-PRIME performs as well or better than the ISCST3 model in

comparisons of the models' predictions to observed concentrations. An important feature of a regulatory model's performance is the avoidance of a bias toward significant under-prediction.

Technical Evaluation

Two important capabilities offered by the ISC-PRIME model (and not offered by the ISCST3 model) are the ability to predict concentrations in the building cavity

Date: 07/31/00

Page: 12^v

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

region, and the ability to assess the affects of actual stack location relative to the building.

This second capability is especially important for the Healy case, where the Unit 1 stack is both separate and upwind from the Unit 2 boiler building during critical downwash conditions. The Unit 2 boiler building is the primary determinant of the near-field dispersion of the Unit 1 plume. The ISCST3 model is not able to explicitly account for the stack-building separation. Thus, ISCST3 would be expected to produce a less realistic simulation of near-field dispersion for the Healy case, in comparison with the ISC-PRIME model.

The downwash algorithms in both the ISC-PRIME model and the ISCST3 model are semi-empirical and therefore, the technical underpinnings of both models are based on the measurements of laboratory experiments (wind tunnel tests). The semi-empirical aspects of ISC-PRIME are based largely on an extensive series of wind tunnel experiments performed by EPA at its fluid modeling facility during 1992 and 1993. The development of the

downwash
algorithm in ISCST3 preceded the availability of these data sets, and it
therefore does not reflect
the broader technical basis offered by these more recent wind tunnel
data.

Because ISC-PRIME is
based on more extensive wind tunnel data sets, the technical basis for
the
ISC-PRIME downwash
algorithm is stronger than that for the- ISCST3 model.

The plume rise algorithm in ISC-PRIME is based on numerical
integration of theoretical
equations for conservation of mass, momentum, and energy. The model
accounts for
streamline

ascend over the building, and streamline decent in the lee of the
obstruction

ISC-PRIME also
accounts for vertical wind shear effects caused by the wind flow about
the
building; in particular.

the wind speed deficit in the lee of the building is modified as a
function of
downwind distance.

These features of ISC-PRIME compose a more sophisticated treatment of
the

physics associated
with downwash when compared to the simpler analytical treatments in the
ISCST3

model. These
factors should allow ISC-PRIME to produce a more realistic simulation of
plume

rise and
dispersion from short stacks, such as, the Unit I stack at the Healy
Power
Plant.

Performance Evaluation

Date: 07/31/00

Page: 13^v

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:

Name: U.S. Sugar--Oct 99
12/20/99

Several data bases, including observations from wind tunnel
studies,
numerical model
results, and both short-term tracer and long-term operational field
measurement
programs, were
employed by EPRI's contractors in the development and evaluation of ISC-
PRIME.
Four data

bases were retained to perform an independent evaluation of the model after completion of the development phase. The evaluation was independent in that the data bases were not used in the model development and the effort was conducted by a contractor who was not the model developer. Model performance was evaluated against the four independent data bases according to a protocol previously reviewed by EPA Region 10. A number of performance measures were used in the evaluation, and statistical tests were employed to determine the significance of differences observed in model performance. Results of the independent evaluation demonstrated that the overall performance of the ISC- PRIME model is as good or better than the ISCST3 model.

Meteorological conditions of near-neutral stability and moderate or higher wind speeds are traditionally considered most conducive to producing building wake effects (plume downwash conditions) and associated high ground-level concentrations. The occurrence of these conditions in the Healy area is not uncommon, and, in fact, both the ISCST3 and the ISC-PRIME model were consistent in producing the maximum 24-hour average concentrations during such near-neutral, moderate-to-high wind speed conditions. Thus, the performance of the models is most relevant under these downwash conditions as compared to other types of meteorological conditions. The evaluation of the models against the independent evaluation data bases showed that for near-neutral, moderate-to-high wind speed conditions, the two models' performances were comparable, with ISC-PRIME perhaps performing slightly better than ISCST3.

A site-specific data base from the Healy Power Plant, which would prove the most relevant basis to evaluate model performance, does not exist. Therefore, the similarity of the circumstances at the Healy Power Plant to the circumstances associated with the

evaluation
data bases is a factor
in this evaluation. A comparison of stack parameters (buoyancy flux and
momentum
flux) shows

Date: 07/31/00
Page: 14

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

that the Healy Unit 1 stack compares favorably with the stacks in two of
the
four independent
evaluation data bases, namely, the Bowline Point and the Lee Power Plant
data
bases. [Note that
since the Healy Unit 1 stack emissions were the only significant
contributor to
maximum modeled
concentrations, the Healy Unit 2 stack is not considered in this
comparison.] A
comparison of
stack height to building height ratios shows that the Healy case (Unit 1
stack
height to building
height ratio of 0.77) is comparable to the lower stacks in the AGA data
base
(ratios of 0.80, 0.86,
and 2.00). None of the other three independent data bases had stack
height to
building height
ratios less than one. Unfortunately, the AGA stack parameters (buoyancy
and
momentum fluxes)
are an order of magnitude less than the corresponding Healy Unit 1
parameters.
Thus, none of the independent evaluation data bases are closely similar
to the
Healy case for
both stack parameters and stack/building geometry. To summarize the data
bases
against
which ISCST3 and ISC-PRIME were tested, we can classify them in three
categories. in order of
decreasing technical primacy: on-site, closely similar, and other
downwash data
bases. Relative to
the Healy case, all of the independent evaluation data bases fall into
the last
category, and the
model performance evaluation can not be as technically compelling as if

the data bases were developed from data obtained at the Healy site, or at plant sites that are more closely similar to the Healy site.

The performance evaluations of the ISC-PRIME and ISCST3 models demonstrate that 'SC-PRIME generally performs as well or better than ISCST3 for predicting maximum impacts during downwash conditions, with no apparent bias toward under-prediction. However, because the data bases employed in the evaluations are not closely similar to the Healy site, the evaluation results are only suggestive (rather than conclusive) evidence that ISC-PRIME would be expected to perform better than ISCST3 for the Healy application.

Additional Notes

Some sensitivity testing of the ISC-PRIME model was performed by EPA Region 10 for the Healy application. Several of the inputs to ISC-PRIME for the Unit 1 source (including stack height, stack temperature, and exit velocity), and for the Unit 2 building dimensions, were

Date: 07/31/00
Page: 15

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:
Name: U.S. Sugar--Oct 99
12/20/99

modified both slightly and significantly to investigate the sensitivity of the maximum concentration estimates to these changes. The observed model sensitivity was judged to be physically reasonable. Receptor spacing was also investigated in the area of maximum predicted concentrations along the northwest plant boundary. By increasing the number of receptors in the maximum impact area, maximum concentrations were identified that were slightly higher than

those reported by GVEA.

In addition to being submitted to EPA Region 10 for the Healy application, the ISC-PRIME model has been submitted to EPA's Office of Air Quality Planning and Standards (OAQPS) for their review and consideration of proposing the model as a preferred model the Guideline on Air Quality Models (40 CFR 51, Appendix W). In their review, OAQPS identified a coding error in the model, such that, when certain low wind speed, stable conditions are encountered, the model ceases to operate. This error has apparently been corrected by the model developer, and a revised version of the model will soon be available. These revisions to the model are not expected to cause substantive changes in the model predictions for the conditions that are critical to the permitting decision for the Healy case. This should, however, be verified by re-running the Healy case with the revised ISC-PRIME model when it becomes available.

Conclusions and Recommendations

On the strength of the data bases employed during the development of the ISC-PRIME model, and because of the improved and more physically realistic capabilities of the model, it is concluded that ISC-PRIME is technically superior to the JSCST3 model in this circumstance. While there is no conclusive evidence from the performance evaluations that ISC-PRIME would be expected to be a more accurate predictor of maximum impacts for the Healy application, the performance evaluations with the independent data bases do suggest that ISC-PRIME is generally as good or better than the ISCST3 model for predicting maximum impacts during downwash conditions. Furthermore, while both the difficulties in modeling the complexities of plume downwash and the limitations of available data bases lead to uncertainties in the assessment of model performance for this application, it appears that ISC-PRIME has no

Date: 07/31/00

Page: 16

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

significant bias
toward under-prediction of maximum impacts. Therefore, it is
recommended that
the
ISC-PRIME model, in lieu of the ISCST3 model, be considered acceptable
for
application to the
Healy case

4) Final Region IV approval letter for U.S. Sugar
November 4, 1999

4APT-ARB
Mr. A. A. Linero, P.E.
Administrator/New Source Review Section
Florida Department of Environmental Protection
Twin Towers Office Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

SUBJ: Use of ISC-PRIME
PSD Permit Application
U.S. Sugar Corporation Clewiston Mill
Clewiston, Florida

Dear Mr. Linero:

Thank you for providing the Prevention of Significant Deterioration
(PSD)

permit
application for the U.S. Sugar Corporation - Clewiston Mill, dated June
1999.

This application
requests an increase in the operation of the sugar refinery and Boiler
No. 4.

Our review
comments excluding the air quality impact assessment were provided in
our
September 20, 1999,
letter. The purpose of this letter is to provide our evaluation of the
appropriateness of the use of
the none-guideline ISC-PRIME dispersion and transport model for the
ambient air
impact
assessments resulting from the proposed Clewiston Mill modifications.

The justification for the use of the non-guideline model [i.e.,
model not
recommended in
the United States Environmental Protection Agency's (EPA) Guideline on
Air

Quality Models (40 C.F.R. 51, Appendix W)] was provided in the U.S. Sugar Clewiston Mill PSD permit application.

This justification, combined with available articles and documents on the development and performance of the ISC-PRIME model, were the basis of our review and evaluation.

The reviewed articles and development documents reported ISC-PRIME to perform as well as or better than ISCST3 when predicted maximum concentrations are compared to observed measurements. ISC-PRIME was also found not to be significantly biased toward under-

Date: 07/31/00

Page: 17

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

estimation of maximum concentrations. A summary of our case-by-case evaluation of ISC-PRIME for the U.S. Sugar Clewiston application is provided as an attachment.

Based on our evaluation of ISC-PRIME, EPA concurs with the use of this model for the Clewiston Mill air impact assessment. In accordance with EPA's division of responsibility with respect to non-guideline model approval, this EPA Region 4 case-by-case approval for the U.S. Sugar Clewiston application is not an endorsement for use by any other source. EPA's Office of Air Quality Planning and Standards (OAQPS) is currently considering a generic approval of ISC-PRIME. If generically approved, ISC-PRIME may become a guideline model for general application.

It should be noted that any public notice of this project must include the fact that the air quality impact assessment was performed using a case-specific approved

non-guideline ISC-PRIME model. The public must be provided an opportunity to comment and have a public hearing on this matter.

Thank you again for the opportunity to review and comment on this PSD application. If you have any questions, or if we can be of further assistance, please contact Mr. Stan Krivo of the EPA Region 4 staff at (404) 562-9123.

Sincerely,
R. Douglas Neeley
Chief
Air and Radiation Technology Branch
Air, Pesticides and Toxics
Management Division

Attachment

cc: Joseph A. Tikuart, EPA/OAQPS
Cleve Holladay, FDEP
Tom Rogers, FDEP

Evaluation of ISC-PRIME For Application To
U.S. Sugar Corporation Clewiston Mill
Air Quality Impact Assessment

Introduction

The Florida Department of Environmental Protection (FDEP) has reviewed the Prevention of Significant Deterioration (PSD) permit application for a modification of U.S. Sugar Corporation (U.S. Sugar) Clewiston Mill. One of FDEP's concern is the application of the non-guideline ISC-PRIME dispersion and transport model to the ambient air quality assessment. The use of the

Date: 07/31/00
Page: 18

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:
Name: U.S. Sugar--Oct 99
12/20/99

guideline ISCST3 dispersion and transport model for the U.S. Sugar
Clewiston
Mill emission
sources reveals very large predicted SO2 and PM10 concentrations at the
site
boundary -
concentrations that exceed the PM10 and SO2 National Ambient Air Quality
Standards

(NAAQS). Use of the ISC-PRIME model with the same input emission and receptor values also predicts large concentrations but none that exceed the applicable PSD increments nor NAAQS. The ISC-PRIME model has been submitted to United State Environmental Protection Agency's (EPA) Office of Air Quality Planning and Standards (OAQPS) for consideration as a guideline model. OAQPS have reviewed and tested this model. It was also reviewed at the 1998 Regional/State/Local Agency modelers workshop. With a few restrictions, the Workshop participants recommended ISC-PRIME be included as a guideline air quality model in the next revision to the Guideline on Air Quality Models (GAQM). Although OAQPS may propose ISC-PRIME for inclusion as a guideline model, this has not officially been proposed and public comment solicited. Therefore, ISC-PRIME remains a non-guideline model that must be evaluated and approved for application on a case-by-case basis. The U.S. Sugar PSD application is the first time the ISC-PRIME model has been used in a regulatory application in EPA Region 4. The following is a summary of EPA Region 4's review of U.S. Sugar's justification of the appropriateness of ISC-PRIME for the assessment of ambient air impacts.

Reviewed Documents - ISC-Prime and U.S. Sugar Corporation
The following documents were reviewed in the case-by-case justification for the use of the non-guideline ISC-PRIME dispersion and transport model for the PSD air quality impact assessment of planned modifications of U.S. Sugar Clewiston, Florida facility.

1. Hastings, Janis; "Review of the ISC-PRIME model, GVEA Healy Power Plant Air Quality Control No. X049"; Letter from U.S. Environmental Protection Agency Region 10 to Alaska Department of Environmental Conservation; April 29, 1998.
2. Paine, Robert J., and Frances Lew; "Project Prime: Evaluation of Building Downwash Models Using Field and Wind Tunnel Data"; Undated article and presentation

slides

developed by ENSR Corporation for Electric Power Research Institute
(EPRI)

Date: 07/31/00
Page: 19

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:

Name: U.S. Sugar--Oct 99
12/20/99

Project RP

3527-02.

3. Paine, Robert J., and Frances Lew; "Results of the Independent
Evaluation of ISCST3 and

ISC-PRIME"; Final Report; Electric Power Research Institute;
November 1997.

4. Shulman, Loyd L., David G. Strimaitis, and Joseph S. Scire;
"Development and

Evaluation of the Prime Plume Rise and Building Downwash Model";
Undated
draft

journal article by Earth Tech, Concord, MA.

5. Staff Report; "Consequences Analysis of Using ISC-PRIME Over
the

Industrial Source

Complex Short Term Model" (Draft); U.S. Environmental Protection
Agency;
April 1998.

6. U.S. Sugar Corporation; "Information Submittal No. 3 - PSD
Permit
Application for

Boiler No. 4 and the Sugar Refinery at the Clewiston Mill"; 13
September
1999.

7. U.S. Sugar Corporation; "PSD Permit Application for United
States
Sugar Corporation

Clewiston Boiler No. 4 and Sugar Refinery," prepared by Golder
Associates
Inc.; June
1999.

Basis of Evaluation

The evaluation criteria for a case-by-case approval of an alternate or
non-guideline model are

given in Section 3.2 of 40 CFR Part 51, Appendix W - Guideline on Air
Quality

Models

(GAQM). Section 3.2 presents three separate conditions under which an
alternate
model can be

approved. The second condition is the basis for the justification of
ISC-PRIME

(i.e., statistical

performance evaluation using measured air quality data results in the alternate model having better performance than a comparable guideline model). The issues addressed in Region 4's evaluation

of the appropriateness and applicability of ISC-PRIME for the U.S. Sugar application include:

Technical appropriateness of the model for the application.
Appropriate data bases available to perform the modeling

analysis.

Model performance evaluations appropriate to U.S. Sugar and demonstrate no bias

toward underestimates of concentrations.

Better model performance when compared to reference guideline model.

Technical Consideration

The ISC-PRIME model was developed to improve the downwash algorithms of the

ISCST3

regulatory guideline model. Two important shortcomings of the ISCST3 downwash

treatment

are the inability to predict concentrations in the building cavity (near wake)

Date: 07/31/00

Page: 20

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

and to assess the effects of stack location relative to the influencing downwash structure. In addition, the downwash routines of ISCST3 were developed largely from ambient data representing neutral stability, moderate-to-high wind speeds, winds perpendicular to the building face, with non- or low-buoyant plumes. These limitations were addressed in the development of ISC-PRIME.

Of major concern at the Clewiston Mill are emissions from the boiler stacks.

These stacks are located between 3 and 5 building lengths from the buildings controlling downwash. Although

EPA studies of the effects of building downwash within wakes show reduction as

the stack's

distance from the controlling building is increased, ISCST3 uses the

full
downwash effects
independent of stack location in the wake region. Thus, ISCST3 modeling
of the
Clewiston
emissions may produce less realistic estimates of wake dispersion than
ISC-PRIME. Ambient
concentrations from these two models for the Clewiston facility show,
ISC-PRIME
with smaller
concentrations in the wake region.
In terms of the basis of the downwash algorithms in the ISCST3 and ISC-
PRIME
models, both
models' algorithm are semi-empirical. The empirical data used for ISC-
PRIME
were largely from
extensive series of USEPA performed wind tunnel experiments in 1992 and
1993.
The ISCST3
downwash algorithms pre-date these experiments. Because ISC-PRIME is
based on
more
extensive wind tunnel data sets, it has a stronger technical base than
ISCST3.
On a theoretical basis, ISC-PRIME uses the conservation equations of
mass,
momentum, and
energy. This model accounts for the streamline ascent over structure
and descent
in the wake
region. Also the wind shear effects about and downwind of structures
are
accounted for in ISC-
PRIME. Therefore, the theoretical basis of ISC-PRIME is technically
more
sophisticated than
ISCST3 and may provide more realistic estimates of plume rise,
dispersion, and
transport
conditions in the wake region - a condition applicable to the Clewiston
application.
In terms of the data needed to run ISC-PRIME, the input data
requirements are
the same as
ISCST3 with the exception of building and stack configurations and
dimensions.
Similar to the
BPIP program providing building information for ISCST3 running, a
supplementary

Date: 07/31/00
Page: 21

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last
Update:

Name: U.S. Sugar--Oct 99
12/20/99

program

BPIPPRM has been developed to provide the needed building information for the running of

ISC-PRIME. Therefore, adequate input data exist to perform ISC-PRIME model

analysis for

U.S. Sugar Clewiston.

Data Bases For Model Development And Performance

The data bases used in the development of ISC-PRIME included wind tunnel studies, numerical

model results, and both short-term tracer and long-term field measurement

programs. An

independent evaluation of the completed model was performed by an EPRI contractor using four

data bases. This was an independent evaluation as it was: 1) Conducted by a

contractor not

involved with model development, and 2) Data bases used in evaluation were not

used in the

model development. A number of performance measures were considered and statistical tests

performed to determine the significance of performance differences observed.

Thus, adequate

data bases exist for both the development and evaluation of model performance.

Performance Evaluations

Comparison With Data Bases

In the assessment of ISC-PRIME model performance, meteorological conditions that

produce the

highest ground-level concentrations were used (e.g., near-neutral stability and

moderate to high

wind speeds). Comparison of both ISCST3 and ISC-PRIME predicted concentrations

against the

independent data bases show that for these downwash producing meteorological

conditions, the

two models' performances were comparable with ISC-PRIME performing slightly

better (i.e.,

better agreement with observations) than ISCST3.

Site specific data from the Clewiston facility site would provide the most

relevant basis for model

performance evaluation. These data were not available so a review of the

similarity of the

emissions, plant configuration, and receptor conditions used in the ISC-PRIME

model evaluation

was performed to determine applicability of the evaluation to the Clewiston application. Of the evaluation data bases used, the Bowline Point and the Lee Power Plant data were the most similar to the boilers at the Clewiston facility in terms of stack heights (87 and 65 meters respectively) and stack to building ratios (1.3 and 1.5 respectively). The buoyant and momentum fluxes for these power plants are expected to be representative of those at Clewiston.

Date: 07/31/00
Page: 22

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

Although the evaluation and development data bases were not obtained under the same plant configuration as U.S. Sugar Clewiston, they are believed to relevant and representative of the U.S. Sugar Clewiston.

Comparison With Reference Model

The performance evaluation comparisons of ISC-PRIME and ISCST3 models demonstrated ISC-PRIME with generally as well or better agreement with observed maximum concentrations during downwash conditions. ISC-PRIME did not demonstrate a bias toward under predictions. Thus, an independent evaluation demonstrated ISC-PRIME with an overall performance as good as, or better than ISCST3 in downwash conditions. EPA performed its own consequence analysis of the ISC-PRIME software and EPRI reports.

This consisted of verifying that ISCST3 and ISC-PRIME produced the same results when no building dimensions were included, confirming the independent modeling results, and determining the consequences of using ISC-PRIME for building downwash applications.

The consequence analysis showed that both models produced the same results when run

without building input data. The PRIME downwash algorithms do not interfere with the proper operation of the model under no downwash conditions.

The three field studies used in the EPRI independent evaluation showed

ISC-PRIME

tends to be less conservative than ISCST3 but more conservative (i.e., produce larger concentrations) than the observed values.

For cavity analyses, output differences between ISCST3 and ISC-PRIME were dependent

on stack location, stack to building height ratios, urban/rural setting, and downwind

distances. ISC-PRIME and ISCST3 converge on common concentrations beyond 1 km

and are the same beyond 10 km.

In summary, ISC-PRIME provides overall conservative estimates of concentrations that are more

realistic than those provided by ISCST3.

Conclusion and Recommendation

Based on the application of Section 3.2 of 40 CFR Part 51, Appendix W (Guideline

on Air

Quality Models) for the evaluation of the use of an alternate model,

ISC-PRIME

appears

appropriate and applicable for the U.S. Sugar Clewiston air quality impact

assessment. ISC-

Date: 07/31/00

Page: 23

Model Clearinghouse Information Storage and Retrieval System

Record Information Report

Record Number: 00-IV -02 Fiscal Year: 1900 Region: 04 Last Update:

Name: U.S. Sugar--Oct 99
12/20/99

PRIME appears to be technically better than ISCST3 and is better at predicting maximum concentrations during downwash conditions. In terms of application to the U.S.

Sugar Clewiston

facility, it appears that ISC-PRIME would provide a more realistic but conservative estimate of

the maximum downwash concentrations from this facility while also providing

concentrations

equal to ISCST3 predictions beyond the wake region. Therefore, ISC-