

**EPA PM<sub>2.5</sub> CHEMICAL SPECIATION NETWORK  
CARBON SAMPLER REPLACEMENT PROGRAM  
PHASE I**

Prepared for

**EPA OAQPS  
Implementation of URG 3000N Samplers  
at EPA PM<sub>2.5</sub> Chemical Speciation Network (CSN) Sites  
Under National Park Service Contracts C2350010850 & C2350064025**

Prepared by

**AIR RESOURCE SPECIALISTS, INC.**  
1901 Sharp Point Drive, Suite E  
Fort Collins, Colorado 80525  
Telephone: 970-484-7941  
Fax: 970-484-3423

**August 1, 2007**

## TABLE OF CONTENTS

<b><u>Section</u></b>		<b><u>Page</u></b>
1.0	INTRODUCTION	1-1
1.1	EPA Role	1-1
1.2	ARS Role	1-2
2.0	DEVIATIONS	2-1
3.0	CALIBRATION FORMS	3-1
4.0	SITE PHOTOS	4-1
5.0	SUMMARY	5-1
APPENDIX A	MASTER CONTACT LIST	A-1

## LIST OF FIGURES

<b><u>Figure</u></b>		<b><u>Page</u></b>
1-1	CSN Carbon Install Sites Map	1-3

## LIST OF TABLES

<b><u>Table</u></b>		<b><u>Page</u></b>
1-1	Timeline	1-4
1-2	Installation Schedule	1-9

## 1.0 INTRODUCTION

In April 2005, the Clean Air Scientific Advisory Committee gave strong general support for making changes to the EPA PM<sub>2.5</sub> Chemical Speciation Network (CSN) to improve comparability with the rural Interagency Monitoring of Protected Visual Environments (IMPROVE) PM<sub>2.5</sub> carbon concentration data. The CSN currently includes about 185 sites and monitors PM<sub>2.5</sub> including mass, ions, elements, and carbon species. The program's objectives are to:

- Provide data to support the development of modeling tools.
- Assess the effectiveness of emission reduction strategies.
- Support other air quality programs and the National Ambient Air Quality Standards (NAAQS).
- Support research studies.

The EPA process, designed to achieve this comparability, includes replacing the CSN carbon sampling channel with an IMPROVE-like sampler and using the IMPROVE carbon Thermal Optical Reflectance (TOR) analysis method, instead of the Thermal Optical Transmittance (TOT) method. In addition, the EPA requested the manufacturer of the IMPROVE sampler, URG (Chapel Hill, NC) to modify the IMPROVE sampler to incorporate mass flow control versus fixed-orifice flow control. The result is a new instrument, the URG-3000N Sequential Particulate Speciation System.

The carbon sampler replacement project will occur in three phases. Phase I, the subject of this report, resulted in the replacement of 57 samplers and two collocated samplers for a total of 59 samplers at 56 sites. 53 sites received a single URG 3000N sampler, two sites received collocated samplers and one site received two single samplers.

### 1.1 EPA ROLE

The Environmental Protection Agency (EPA) is responsible for the coordination of the national PM<sub>2.5</sub> Chemical Speciation Network (CSN). The measurement of ambient carbon species is an important component of this network. To achieve national consistency in carbon measurements, the EPA has decided to replace the existing carbon sampling and analysis methods with the modified IMPROVE Version II Module C sampler, the URG 3000N. This change in sampling technology and the associated filter analysis techniques will provide the national consistency the EPA and other monitoring agencies desire.

The objective of this proposed effort is to procure and install URG 3000N samplers at 56 selected CSN sites. The Scope of Work for this modification consists of the following two (2) subtasks.

Subtask 1: Procure URG 3000N Samplers and Support Systems

Subtask 2: Install URG 3000N at 56 EPA-Selected Sites

This effort required a cooperative working dynamic among the EPA, other federal and state agencies, URG, RTI, and ARS. EPA provided ARS with a list of sites and a contact list of oversight personnel for each site. EPA initially contacted the oversight personnel to alert the site stakeholders of the required activities and stakeholders roles to accomplish the installations on schedule.

## **1.2 ARS ROLE**

ARS procured 57 URG 3000N samplers and two (2) collocated URG 3000N samplers and support systems through URG Corporation. The support systems included; calibration/audit cartridges, leak check/flow assemblies, sampler operator manuals and five BGI TriCal flow calibrators.

ARS acceptance tested all samplers to resolve any operational issues directly with URG whenever possible. In early March 2007 when the delivery date and the installation date were too close to allow comprehensive acceptance testing, then only completeness inspections occurred. Table 1-1 lists time line details.

The samplers were installed by an ARS Field Specialist, generally in groups of 3 to 6 samplers. ARS assigned four (4) field specialists to support this project. The installation groups are indicated in Figure 1-1 and are detailed in Appendix A. ARS coordinated the installation, occasional field repairs, sampler calibrations, and operator training.

For the installations to occur efficiently, local agency site personnel were contacted by ARS to determine in advance of the installation trip where the unit was to be mounted, to identify any pre-visit preparation required (i.e. verify that an electrical outlet is available), and to be available during installation to receive training. Installations began on February 28, 2007 and were completed on May 3, 2007. The sampling program began on May 3 for 1-in-3 day sites and May 6 for 1-in-6 day sites.

ARS completed a Site Installation Summary Form for each installation that includes a completed installation log sheet, calibration values, and cardinal direction digital photographs when possible. Some sites were not prepared on time or were not operational at the time of installation and were not calibrated or photographed by ARS. Missing photo sites: Akron and Steubenville, OH; Duwamish, WA; and Commerce City, CO. Missing calibration form sites: Winston-Salem, NC; Greensburg, PA; Commerce City, CO; Amtrak, Philadelphia, PA.

The EPA upgraded all URG 3000N samplers with a mass flow controller. The flow controller enhanced the ability to more accurately calibrate the unit and to sustain the desired flow. This factory upgrade was performed by URG, with programming under subcontract to ARS.




Figure 1-1. Installation Groups of EPA CSN Carbon Sampler Sites, April 2, 2007.

Table 1-1

Time Line Leading to the Installation of the URG 3000N

February 2006	ARS provided a preliminary cost estimate for installing, calibrating and training for the project.
March 23, 2006	ARS provided a Cost Estimate for planning purposes.
April 2006	A revised cost estimate was provided by ARS to EPA to investigate possible installation cost savings resulting from reorganizing the site list into select installation groups across the country.
May 2006	A brief meeting at RTP, North Carolina took place between EPA, URG, UCD, RTI and ARS to discuss initial challenges in manufacturing and implementing the IMPROVE Sampler. Participant roles were defined. ARS-software creation, installation, coordination; URG-design and manufacturing of instrument and support equipment; RTI-filter handling related assistance; EPA-project guidance and QA guidance; UCD-informal assistance and consultation, primarily with programming software.
May-June 2006	ARS wrote software to accommodate the Speciation Network with cooperation from URG. Software was based on existing, second generation (Compact Flash memory card based) IMPROVE sampler code, but was significantly enhanced to handle and record calibrations and fix persistent data corruption problems, among other things.
June 20, 2006	EPA decided to require Active Mass Flow Control, thus replacing original critical orifice control concept; other changes included a self-supporting stand, Compact Flash memory card technology, calibration methods, etc.
July 2006	ARS began rewrite of software for the renamed, mass-flow controlled URG 3000N with URG's cooperation abandoning the magnehelic flow calibration method. No detailed software specifications were provided and no MFC-based URG 3000N sampler was available during software development. ARS built a test MFC platform to simulate the URG 3000N. The test platform used a similar, but not identical MFC.
August 8, 2006	The first data file was generated for RTI review.

Table 1-1 (continued)

Time Line Leading to the Installation of the URG 3000N

September 2006	ARS met with EPA at the IMPROVE meeting in Kentucky to discuss changes that were required to assure the URG 3000N met sampling requirements of the Speciation Network. The stack height was questioned and determined to conflict with CSN requirements. URG 3000N inlets were made to match the inlet height of the routine CSN samplers.
September 20, 2006	RTI sent comments to ARS to refine the filter data files on the Compact Flash memory cards. ARS made the necessary software changes.
November 2006	An automated leak check method was conceived of and supported in software by ARS and hardware/theory by URG.
November 10, 2006	ARS received its first three URG 3000N's to test the software.
November 15, 2006	Testing began.
November 2006	ARS participated in a conference call with EPA and state representatives in Region 5. Discussions began between EPA and ARS regarding final list of sites. EPA decided on "final list of sites." EPA sent ARS the contact list for all sites.
December 2006	Leak check procedure was further changed. Automated audits, leak checks, and calibrations were refined in software.
December 12, 2006	Marks the first completely successful 24-hour run complete with Compact Flash card data, audits and calibration.
December 2006	ARS discovered a vacuum leak problem around the temperature probe and shares its findings with URG. URG corrected the problem.
December 19, 2006	ARS left a 3000N with Colorado Department of Public Health and Environment, CDPHE, for prototype testing in Denver Colorado.
January 4, 2007	URG and CDPHE found no problems with the software, and the first installation group in California was scheduled.

Table 1-1 (continued)

Time Line Leading to the Installation of the URG 3000N

January 2007	EPA QA group received its first URG 3000N. Testing in cooperation with RTI resulted in a list, requests for changes in the software, and identified a vacuum leak problem. The reason for the leak was isolated to poor cassettes and is no longer an issue. EPA sampler review based on pre-draft manual from URG. In the future, more leaks may be traced to bad O-rings.
January 25, 2007	ARS received final prioritized EPA/RTI software change requests and began modifications. January 30, the latest software version was completed and e-mailed to URG for subsequent transfer to EPROM and delivery to RTI for evaluation.
January 31, 2007	Software functional flow diagram completed by ARS for use by field installation staff.
February 5, 2007	Scheduling began, no further objections from EPA were received. Missing parts to a complete URG 3000N installation include: <ul style="list-style-type: none"><li>• Leak Check Kits</li><li>• Filter Cassettes / Audit Cassettes</li><li>• Instrument Manual</li></ul>
February 28, 2007	The first installation, Winston-Salem, NC occurred. ARS installed a URG 3000N close to Research Triangle Park so EPA staff could attend easily.
March 5, 2007	Group I installations began. ARS found a problem with the 1-in-6 day schedule. New EPROMs with the repair were successfully issued.
March 8, 2007	The Washington, DC and Essex, NJ sites were installed by ARS. The visit was linked to other ARS travel in the area to reduce the size of Group II and increasing the chances of completing Group II in one business week.
March 15, 2007	Audit cassettes arrived in batches of 10-20 per week. ARS decided to wait to distribute to sites until all have arrived. All but 10 leak check assemblies were received.
March 20, 2007	Group IX Utah sites were installed. The Bountiful site experienced problems and manufacturer repairs were required. UT staff installed the repaired unit on April 4, 2007.

Table 1-1 (continued)

Time Line Leading to the Installation of the URG 3000N

March 19, 2007	Group III was installed by ARS. The Naperville & Northbrook sites required manufacturer sampler repair. Repaired parts were reinstalled by the operator.
March 26, 2007	Group II was installed. The Philadelphia Ritner Street site sampler failed and was reinstalled by ARS on April 26, 2007.
April 4, 2007	UT staff reinstalled repaired sampler at Bountiful, UT in Group IX. See March 20, 2007 entry.
April 9, 2007	Group VII was installed successfully.
April 16, 2007	Group V was installed. The Bonne Terre, MO site was not ready for installation. The assembled sampler was left with MO staff for subsequent installation. Indianapolis sampler required manufacturer repair. The operator calibrated sampler upon return from URG.
April 16, 2007	Group VI was installed. The Steubenville, OH site was not ready for installation, the sampler was assembled and calibrated in the local office and left for staff to install.
April 20, 2007	ARS installed the Meridian, ID site in Group VIII while on other travel in the area.
April 23, 2007	ARS installed Group IV successfully.
April 26, 2007	ARS reinstalled the Philadelphia, PA Ritner Street site. See March 26 <sup>th</sup> entry.
April 26, 2007	The Commerce City, CO site of Group IX was installed by ARS. The controller failed and was sent back to URG. URG discovered a poorly crimped wire in a mass flow controller connector and issued an email for CSN distribution on how to inspect and/or repair the problem. Another trip to reinstall and calibrate the sampler by ARS was unsuccessful because the operator removed the flow audit adapter from the site. The operator eventually calibrated the sampler.
May 1, 2007	ARS broke Group VIII into two groups to meet the deadline of 1 in 3 day sampling on May 3. Samplers were installed and calibrated to meet the May 3, 2007 start date.

Table 1-1 (continued)

Time Line Leading to the Installation of the URG 3000N

May 1, 2007	<p data-bbox="532 338 1378 415">Five EPA-owned BGI TriCal flow calibrators were purchased on the project. The locations of each are:</p> <ul data-bbox="581 436 1144 583" style="list-style-type: none"><li data-bbox="581 436 1144 472">• Ohio EPA – 2 TriCals</li><li data-bbox="581 472 1144 508">• Greensburg, PA – 1 TriCal</li><li data-bbox="581 508 1144 543">• Indianapolis, IN – 1 TriCal</li><li data-bbox="581 543 1144 583">• ARS – 1 TriCal</li></ul>
May 2, 2007	<p data-bbox="532 611 1378 714">All cassettes were received at ARS and sent to the sites. After a couple of shipping address issues, all cassettes are delivered and accounted for.</p>

Table 1-2

## Installation Schedule

<b>AQS</b>	<b>Install Group</b>	<b>City Name</b>	<b>State</b>	<b>Final Install Date</b>
01-073-2003	7	Birmingham	AL	4/10/2007
01-113-0001	7	Phenix City	AL	4/9/2007
06-029-0014	1	Bakersfield(2)	CA	3/7/2007
06-037-1103	1	Los Angeles	CA	3/7/2007
06-065-8001	1	Rubidoux (2)	CA	3/6/2007
06-073-0003	1	El Cajon	CA	3/5/2007
06-073-1002	1	Escondido	CA	3/5/2007
06-099-0005	1	Modesto	CA	3/8/2007
06-107-2002	1	Visalia	CA	3/8/2007
08-001-0006	9	Commerce City	CO	4/26/2007
10-003-2004	2	Wilmington	DE	3/30/2007
11-001-0043	2	Near Washington	DC	3/8/2007
13-021-0007	7	Macon	GA	4/12/2007
13-115-0011	7	Columbus	GA	4/11/2007
16-001-0010	8	Near Boise, Meridian	ID	4/20/2007
17-031-0057	3	Chicago, Springfield	IL	3/21/2007
17-031-0076	3	Chicago, ComEd	IL	3/21/2007
17-031-4201	3	Northbrook	IL	3/20/2007
17-043-4002	3	Naperville	IL	3/20/2007
17-119-2009	5	Alton	IL	4/16/2007
18-089-0022	3	Gary	IN	3/22/2007
18-089-2004	3	Hammond	IN	3/22/2007
18-097-0078	5	Indianapolis, Washington Park	IN	4/18/2007
21-111-0043	5	Louisville	KY	4/19/2007
24-005-3001	2	Essex	MD	3/9/2007
26-161-0008	4	Ypsilanti	MI	4/23/2007
26-163-0033	4	Dearborn	MI	4/23/2007
27-053-0963	3	Minneapolis, Philips (2)	MN	3/19/2007
29-186-0005	5	Bonne Terre	MO	5/3/2007
29-510-0085	5	St. Louis	MO	4/17/2007
30-063-0031	8	Missoula	MT	5/2/2007
34-007-0003	2	Camden	NJ	3/29/2007
36-005-0110	2	Bronx	NY	3/26/2007
36-061-0134	2	Manhattan, New York	NY	3/26/2007
37-067-0022	6	Winston-Salem	NC	2/28/2007
39-035-0038	4	Cleveland,	OH	4/25/2007
39-049-0081	4	Columbus, Maple Canyon	OH	4/26/2007
39-061-0040	5	Cincinnati, Taft	OH	4/20/2007
39-081-0017	6	Steubenville	OH	4/16/2007
39-093-3002	4	Sheffield, Lorain	OH	4/24/2007

Table 1-2

## Installation Schedule

<b>AQS</b>	<b>Install Group</b>	<b>City Name</b>	<b>State</b>	<b>Final Install Date</b>
39-153-0023	4	Akron, 5 Points	OH	4/26/2007
41-051-0080	8	Portland	OR	5/1/2007
42-003-0064	6	Liberty	PA	4/17/2007
42-101-0004	2	Philadelphia	PA	4/26/2007
42-101-0136	2	Philadelphia	PA	4/26/2007
42-125-5001	6	East of Pittsburgh	PA	4/18/2007
42-129-0008	6	Greensburg	PA	4/17/2007
47-093-1020	7	Knoxville	TN	4/13/2007
49-011-0004	9	Bountiful	UT	4/4/2007
49-035-3006	9	Salt Lake City	UT	3/21/2007
49-049-4001	9	Lindon	UT	3/20/2007
53-033-0057	8	Duwamish	WA	5/1/2007
53-033-0080	8	Beacon Hill	WA	5/1/2007
53-053-0029	8	Tacoma	WA	5/2/2007
54-039-0011	6	Charleston	WV	4/19/2007
54-039-1005	6	Charleston	WV	4/19/2007

## 2.0 DEVIATIONS

Several installation trip changes occurred during the February 28 to May 3, 2007 period that deserve explanation. Changes in sampler and support hardware delivery dates, site stakeholder requirements and the desired sampler startup date required flexibility and a number of installation visit changes listed below:

- Group II was modified during the continuous site selection process by the EPA and was therefore subdivided removing the Washington DC (AQS 11-001-0043) and Essex (AQS 24-005-3001) sites and installing those two sites on a separate trip. This made it feasible to install the remaining sites on a single business week.
- The Winston-Salem (AQS 37-067-0022) site was installed first and alone to provide an opportunity for EPA OAQPS project personnel to observe and approve of the installation, calibration and training process.
- A return trip was conducted at the Philadelphia, PA (AQS 42-101-0136) site after the scheduled installation because of multiple sampler component failures.
- A return trip was conducted at the Commerce City, CO (AQS 08-001-0006) site after the scheduled installation because of multiple sampler component failures.
- The Meridian, ID (AQS 16-001-0010) site was installed alone when ARS was already in the area on other work.
- The final installations occurred in Group VIII. To meet the project start date of May 3, the group was divided into two trips. The Washington state group was installed by one technician and the Portland, OR (AQS 45-051-0080) and Missoula, MT (AQS 30-063-0031) sites were installed by a second technician.

### **3.0 CALIBRATION FORMS**

Whenever possible, ARS conducted a post installation temperature and barometric sensor calibration, system leak check and flow rate calibration. The sampler was initialized for site specific operations including setting the sampler AQS and POC number, the sampler date and local standard time, the sample frequency and duration, and the initial stacked filter configuration.

Missing calibration forms occurred for a number of reasons. In order of frequency, the causes were: the installed sampler malfunctioned, the flow calibrator malfunctioned and at one site the flow adaptor was taken off-site by the operator.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: N. Birmingham, AL AQS #: 01-073-0023  
 Controller S/N: 3N-B0160 Date/Time: 4/10/2007  
 Sampler Module S/N: 3N-B0263 Technician: Martin H Valvur  
 Pump Box S/N: 3N-B0219 Site Operator(s): Randy Dillard

Flow Transfer Standard Model: TriCal S/N: 000263-1 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics S/N: 304019 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 000263-1 Cal. Date: 1/31/2007

	Max	Min	Diff		
Leak Check Results:	<u>381</u>	<u>274</u>	<u>107</u>	mmHg in	<u>35 seconds</u> <u>PASS</u>

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1405</u>	<u>27</u>	<u>18.1</u>	<u>18.1</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3295</u>	<u>26</u>	<u>744</u>	<u>744</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3228</u>	<u>19.66</u>	<u>19.70</u>
<u>22.00</u>	<u>3579</u>	<u>21.80</u>	<u>21.70</u>
<u>24.00</u>	<u>3937</u>	<u>24.05</u>	<u>23.72</u>

New gain= 5.459 , offset= 1.85 , correlation= 0.999

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.94</u>	<u>22.14</u>	<u>0.20</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Phenix City, AL AQS #: 01-113-0001  
 Controller S/N: 3N-B0277 Date/Time: 4/9/2007 14:00  
 Sampler Module S/N: 3N-B0260 Technician: Martin H Valvur  
 Pump Box S/N: 3N-B0228 Site Operator(s): Toby Mallory

Flow Transfer Standard Model: TriCal S/N: 00263-1 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics S/N: 304019 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 000263-1 Cal. Date: 1/31/2007

	Max	Min	Diff		
Leak Check Results:	<u>380</u>	<u>328</u>	<u>53</u>	mmHg in <u>35</u> seconds	<u>PASS</u>

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1446</u>	<u>37</u>	<u>621.6</u>	<u>14.9</u>	<u>1.5</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3355</u>	<u>35</u>	<u>757.2</u>	<u>754</u>	<u>7</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3318</u>	<u>19.98</u>	<u>21.24</u>
<u>22.00</u>	<u>3682</u>	<u>27.19</u>	<u>23.45</u>
<u>24.00</u>	<u>4054</u>	<u>24.40</u>	<u>25.72</u>

New gain= 6.089 , offset= 0.96 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.94</u>	<u>22.26</u>	<u>0.32</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Bakersfield AQS #: 06-029-0014  
 Controller S/N: 3N-B0113 Date/Time: 3/7/2007  
 Sampler Module S/N: 3N-B0114 Technician: MS  
 Pump Box S/N: 3N-B0115 Site Operator(s): Debbie Hensen

Flow Transfer Standard Model: Tri-Cal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>315</u>	<u>65</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1435</u>	<u>10</u>	<u>22.4</u>	<u>22.4</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3329</u>	<u>52</u>	<u>746</u>	<u>746</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3330</u>	<u>20.51</u>	<u>17.78</u>
<u>22.00</u>	<u>3610</u>	<u>22.41</u>	<u>19.41</u>
<u>24.00</u>	<u>3924</u>	<u>24.41</u>	<u>21.18</u>

New gain= 5.109 , offset= 0.36 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.98</u>	<u>22.21</u>	<u>-0.23</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station:	<u>Bakersfield Co-Located</u>	AQS #:	<u>06-029-0014</u>
Controller S/N:	<u>3N-B0113</u>	Date/Time:	<u>3/7/2007</u>
Sampler Module S/N:	<u>3N-B0118</u>	Technician:	<u>MS</u>
Pump Box S/N:	<u>3N-B0120</u>	Site Operator(s):	<u>Debbie Hensen</u>

Flow Transfer Standard Model:	<u>Tri-Cal</u>	S/N:	<u>000190</u>	Cal. Date:	<u>1/31/2007</u>
Temperature Transfer Standard Model:	<u>Eutechnics 4400</u>	S/N:	<u>305454</u>	Cal. Date:	<u>1/12/2007</u>
Barometric Pressure Transfer Standard Model:	<u>Tri-Cal</u>	S/N:	<u>W12537</u>	Cal. Date:	<u>1/31/2007</u>

	<u>Max</u>	<u>Min</u>	<u>Diff</u>		
Leak Check Results:	<u>381</u>	<u>324</u>	<u>57</u>	mmHg in <u>35</u> seconds	<u>PASS</u>

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1435</u>	<u>10</u>	<u>22.4</u>	<u>22.4</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3329</u>	<u>52</u>	<u>746</u>	<u>746</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3223</u>	<u>17.67</u>	<u>17.67</u>
	<u>22.00</u>	<u>3560</u>	<u>19.48</u>	<u>19.48</u>
	<u>24.00</u>	<u>3905</u>	<u>21.28</u>	<u>21.28</u>

New gain= 4.947 , offset= 1.24 , correlation= 1.000

**Flow Rate Audit**

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	<u>22.00</u>	<u>21.97</u>	<u>22.02</u>	<u>-0.03</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station:	<u>Los Angeles, CA</u>	AQS #:	<u>06-0371103 POC 5 Schedule 1 in 6</u>
Controller S/N:	<u>3N-B0142</u>	Date/Time:	<u>3/7/2007 10:00</u>
Sampler Module S/N:	<u>3N-B0143</u>	Technician:	<u>Dave Beichley</u>
Pump Box S/N:	<u>3N-B0129</u>	Site Operator(s):	<u>Brian Vlasich</u>

Flow Transfer Standard Model:	<u>TriCal</u>	S/N:	<u>000263</u>	Cal. Date:	<u>10/12/2006</u>
Temperature Transfer Standard Model:	<u>Eutechnics 4600</u>	S/N:	<u>101611</u>	Cal. Date:	<u>1/12/2007</u>
Barometric Pressure Transfer Standard Model:	<u>TriCal</u>	S/N:	<u>W12537</u>	Cal. Date:	<u>10/12/2006</u>

Leak Check Results:	<u>Max</u>	<u>Min</u>	<u>Diff</u>	mmHg in	<u>35 seconds</u>	<u>PASS</u>
	<u>381</u>	<u>289</u>	<u>92</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1526</u>	<u>58</u>	<u>26.7</u>	<u>26.7</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3336</u>	<u>24</u>	<u>753</u>	<u>753</u>	<u>0</u>	<u>Pass</u>

Flow Rate Calibration

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>2285</u>	<u>20.35</u>	<u>19.31</u>
	<u>22.00</u>	<u>3642</u>	<u>22.55</u>	<u>21.33</u>
	<u>24.00</u>	<u>4001</u>	<u>24.81</u>	<u>23.38</u>

New gain= 5.488 , offset= 0.68 , correlation= 1.000

Flow Rate Audit

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	<u>22.00</u>	<u>21.90</u>	<u>21.94</u>	<u>-0.04</u>

PASS

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?       Attendance

Notes:  
 Missing 2nd roof rain guard (rubber). No manual. Filter change: set to 3/10/07 (1 in 6). On site SASS is running.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Rubidoux AQS #: 06-065-8001-6  
 Controller S/N: 3N-B0154 Date/Time: 3/6/2007  
 Sampler Module S/N: 3N-B0288 Technician: MS, DB  
 Pump Box S/N: 3N-B0132 Site Operator(s): Don / Ricardo

Flow Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: SN99FL01611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>303</u>	<u>78</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1507</u>	<u>38</u>	<u>26.8</u>	<u>26.8</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3281</u>	<u>28</u>	<u>741</u>	<u>741</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3165</u>	<u>19.90</u>	<u>19.87</u>
<u>22.00</u>	<u>3489</u>	<u>21.80</u>	<u>21.80</u>
<u>24.00</u>	<u>3832</u>	<u>23.97</u>	<u>23.97</u>

New gain= 5.58 , offset= 1.16 , correlation= 0.999

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.90</u>	<u>22.02</u>	<u>-0.12</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:

Cardinal Photos?

Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Rubidoux Co-located AQS #: 06-065-8001-6  
 Controller S/N: 3N-B0154 Date/Time: 3/6/2007  
 Sampler Module S/N: 3N-B0155 Technician: MS, DB  
 Pump Box S/N: 3N-B0138 Site Operator(s): Don / Ricardo

Flow Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 99F101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>345</u>	<u>35</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1507</u>	<u>38</u>	<u>26.8</u>	<u>26.8</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3251</u>	<u>28</u>	<u>741</u>	<u>741</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3108</u>	<u>18.96</u>	<u>18.96</u>
<u>22.00</u>	<u>3429</u>	<u>21.07</u>	<u>21.07</u>
<u>24.00</u>	<u>3777</u>	<u>23.14</u>	<u>23.14</u>

New gain= 5.763 , offset= -0.3 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.93</u>	<u>21.95</u>	<u>0.02</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resources.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: El Cajon AQS #: 06-073-0003  
 Controller S/N: 3N-B0145 Date/Time: 3/5/2007 8:30  
 Sampler Module S/N: 3N-B0152 Technician: Dave B/Mike Slate  
 Pump Box S/N: 3N-B0177 Site Operator(s): Noel Seefeldt, David Bowers, Victor Padilla

Flow Transfer Standard Model: TriCal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics S/N: 90769 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: W12537 Cal. Date: 1/31/2007

	<u>Max</u>	<u>Min</u>	<u>Diff</u>		
Leak Check Results:	<u>381</u>	<u>369</u>	<u>12</u>	mmHg in <u>35</u> seconds	<u>PASS</u>

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1452</u>	<u>24</u>	<u>22.7</u>	<u>22.7</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3321</u>	<u>24</u>	<u>750</u>	<u>750</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3194</u>	<u>20.15</u>	<u>20.54</u>
	<u>22.00</u>	<u>3599</u>	<u>22.31</u>	<u>22.47</u>
	<u>24.00</u>	<u>3954</u>	<u>24.52</u>	<u>24.57</u>

New gain= 5.493 , offset= 2.02 , correlation= 0.999

**Flow Rate Audit**

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	<u>22.00</u>	<u>21.89</u>	<u>22.11</u>	<u>-0.22</u>

PASS

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?  Attendance

Notes:  
 Module C is on the East side.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Escondido AQS #: 06-073-1002  
 Controller S/N: 3N-B0148 Date/Time: 3/5/2007  
 Sampler Module S/N: 3N-B0149 Technician: Dave B/Mike Slate  
 Pump Box S/N: 3N-B0126 Site Operator(s): Garnet West, Nancy Burgeson

Flow Transfer Standard Model: Tri-Cal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics S/N: 90769 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>299</u>	<u>82</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1504</u>	<u>22</u>	<u>28.1</u>	<u>28.1</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3292</u>	<u>29</u>	<u>743</u>	<u>743</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3165</u>	<u>20.93</u>	<u>20.14</u>
<u>22.00</u>	<u>3570</u>	<u>23.19</u>	<u>23.19</u>
<u>24.00</u>	<u>3921</u>	<u>24.58</u>	<u>25.41</u>

New gain= 6.125 , offset= 0.35 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.88</u>	<u>21.76</u>	<u>0.17</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?  Attendance

Notes:  
 Initial leak check failed - swapped out cyclones with a spare cyclone and unit passed.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Modesto AQS #: 06-099-0005  
 Controller S/N: 3N-B0116 Date/Time: 3/8/2007  
 Sampler Module S/N: 3N-B0117 Technician: Mike Slate  
 Pump Box S/N: 3N-B0119 Site Operator(s): Diane Arnold

Flow Transfer Standard Model: Tri-Cal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4900 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>279</u>	<u>101</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1434</u>	<u>12</u>	<u>22.1</u>	<u>22.1</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3367</u>	<u>51</u>	<u>754</u>	<u>754</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3253</u>	<u>16.84</u>	<u>16.84</u>
22.00	<u>3604</u>	<u>18.57</u>	<u>18.57</u>
24.00	<u>3968</u>	<u>20.43</u>	<u>20.43</u>

New gain= 4.884 , offset= 0.69 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>22.01</u>	<u>22.43</u>	<u>-0.46</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Visalia AQS #: 06-107-2002  
 Controller S/N: 3N-B0151 Date/Time: 3/8/2007  
 Sampler Module S/N: 3N-B0146 Technician: MS  
 Pump Box S/N: 3N-B0171 Site Operator(s): George Jung

Flow Transfer Standard Model: Tri-Cal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: W12537 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>330</u>	<u>50</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1385</u>	<u>56</u>	<u>12.8</u>	<u>12.85</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3360</u>	<u>63</u>	<u>750</u>	<u>750</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3385</u>	<u>17.17</u>	<u>17.17</u>
22.00	<u>3741</u>	<u>18.91</u>	<u>18.91</u>
24.00	<u>4111</u>	<u>20.21</u>	<u>20.21</u>

New gain= 4.777 , offset= 1.21 , correlation= 0.999

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>22.01</u>	<u>22.24</u>	<u>-0.25</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Commerce City, CO</u>	<b>AQS #:</b>	<u>08-001-0006 POC 5</u>
<b>Controller S/N:</b>	<u>3N-B0211</u>	<b>Date/Time:</b>	<u>4/20/2007 10:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0209</u>	<b>Technician:</b>	<u>M. Tigges</u>
<b>Pump Box S/N:</b>	<u>3N-B0165</u>	<b>Site Operator(s):</b>	<u>Bradley Rink</u>

<b>Flow Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>263</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>101611</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>263</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>380</u>	<u>342</u>	<u>38</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1394</u>	<u>-2</u>	<u>19.2</u>	<u>19.6</u>	<u>0.4</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>2720</u>	<u>23</u>	<u>623</u>	<u>628</u>	<u>5</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>          </u>	<u>          </u>	<u>          </u>
	<u>22.00</u>	<u>          </u>	<u>          </u>	<u>          </u>
	<u>24.00</u>	<u>          </u>	<u>          </u>	<u>          </u>

New gain=           , offset=           , correlation=           

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>          </u>	<u>          </u>	<u>          </u>

PASS/FAIL

**Auditor's Signature:** \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Wilmington</u>	<b>AQS #:</b>	<u>10-003-2004-5</u>
<b>Controller S/N:</b>	<u>3N-B0217</u>	<b>Date/Time:</b>	<u>3/30/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0128</u>	<b>Technician:</b>	<u>Dave Beichley</u>
<b>Pump Box S/N:</b>	<u>3N-B0150</u>	<b>Site Operator(s):</b>	<u>Ted Allen, Carl Dyer</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>101611</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>W12537</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>380</u>	<u>145</u>	<u>234</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1371</u>	<u>33</u>	<u>13.7</u>	<u>13.7</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3414</u>	<u>24</u>	<u>769</u>	<u>769</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3488</u>	<u>20.31</u>	<u>18.46</u>
<u>22.00</u>	<u>3798</u>	<u>22.20</u>	<u>20.02</u>
<u>24.00</u>	<u>4180</u>	<u>24.40</u>	<u>22.01</u>

**New gain=** 5.205 , **offset=** 0.84 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.00</u>	<u>22.10</u>	<u>-0.11</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?     
  Attendance     

**Notes:**

Initial leak check failed within 15 seconds. Tried several more before it passed by a slim margin (readjusted cyclone, tighten connection on flow adaptors). Also had mysterious problem with display and instrument resetting for no apparent reasons while doing flow calibrations. Rechecked cable and wire connections, checked flash card. Problem stopped after 3 or 4 instances for no apparent reason.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Washington, DC AQS #: 11-001-0043  
 Controller S/N: 3N-B0136 Date/Time: 3/8/2007  
 Sampler Module S/N: 3N-B0167 Technician: I. Rennat  
 Pump Box S/N: 3N-B0204 Site Operator(s): Winston Thuang

Flow Transfer Standard Model: BGI TriCal S/N: 00263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 00263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>311</u>	<u>70</u>

 mmHg in 35 seconds Pass

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1437</u>	<u>33</u>	<u>20.5</u>	<u>20.4</u>	<u>0.1</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3379</u>	<u>18</u>	<u>762.5</u>	<u>763</u>	<u>0.5</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3345</u>	<u>19.95</u>	<u>18.66</u>
<u>22.00</u>	<u>3719</u>	<u>22.15</u>	<u>20.71</u>
<u>24.00</u>	<u>4085</u>	<u>24.38</u>	<u>22.71</u>

New gain= 5.491, offset= 0.41, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.00</u>	<u>21.96</u>	<u>0.04</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Macon, GA</u>	<b>AQS #:</b>	<u>13-021-0007</u>
<b>Controller S/N:</b>	<u>3N-B0184</u>	<b>Date/Time:</b>	<u>4/12/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0203</u>	<b>Technician:</b>	<u>Martin H Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0225</u>	<b>Site Operator(s):</b>	<u>Alison Ray</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>380</u>	<u>308</u>	<u>72</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1455</u>	<u>37</u>	<u>21.8</u>	<u>21.6</u>	<u>0.2</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3330</u>	<u>43</u>	<u>755</u>	<u>748</u>	<u>7</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3207</u>	<u>19.80</u>	<u>19.40</u>
<u>22.00</u>	<u>3564</u>	<u>21.93</u>	<u>21.63</u>
<u>24.00</u>	<u>3918</u>	<u>24.18</u>	<u>23.69</u>

**New gain=** 5.915 , **offset=** -0.07 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.02</u>	<u>22.09</u>	<u>-0.09</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Cusseta Road School, Columbus, GA</u>	<b>AQS #:</b>	<u>13-215-0011</u>
<b>Controller S/N:</b>	<u>3N-B0166</u>	<b>Date/Time:</b>	<u>4/11/2007 11:15</u>
<b>Sampler Module S/N:</b>	<u>3N-B0239</u>	<b>Technician:</b>	<u>Martin H Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0246</u>	<b>Site Operator(s):</b>	<u>Ernesto / Ken Buckley</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>380</u>	<u>240</u>	<u>140</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1409</u>	<u>37</u>	<u>17.1</u>	<u>17.1</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3306</u>	<u>19</u>	<u>748</u>	<u>747</u>	<u>1</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	
	<u>19.80</u>	<u>3547</u>	<u>20.00</u>	<u>19.51</u>	
	<u>22.00</u>	<u>3676</u>	<u>22.30</u>	<u>21.54</u>	
	<u>24.00</u>	<u>4048</u>	<u>24.45</u>	<u>23.61</u>	
<b>New gain=</b>	<u>5.511</u>	<b>offset=</b>	<u>1.12</u>	<b>correlation=</b>	<u>1.000</u>

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.95</u>	<u>22.06</u>	<u>-0.12</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Meridian, ID AQS #: 16-001-0105 POC 5  
 Controller S/N: 3N-B0205 Date/Time: 4/20/2007  
 Sampler Module S/N: 3N-B0272 Technician: Mark Tigges  
 Pump Box S/N: 3N-B0189 Site Operator(s): Becky Goehring

Flow Transfer Standard Model: BIOS DC2 S/N: H2185 Cal. Date: 3/16/2007  
 Temperature Transfer Standard Model: BGI S/N: 000229 Cal. Date: 12/4/2006  
 Barometric Pressure Transfer Standard Model: BGI S/N: 000229 Cal. Date: 12/4/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>328</u>	<u>53</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1371</u>	<u>56</u>	<u>11.5</u>	<u>11.5</u>	<u>0</u>	<u>PASS</u>
Barometric Pressure Calibration	<u>3020</u>	<u>38</u>	<u>686</u>	<u>686</u>	<u>0</u>	<u>PASS</u>

**Flow Rate Calibration**

	Set Point	Raw	Sampler Flow	Reference Flow
	<u>19.80</u>	<u>N/A</u>	<u>19.80</u>	<u>19.30</u>
	<u>22.00</u>	<u>N/A</u>	<u>22.00</u>	<u>21.80</u>
	<u>24.00</u>	<u>N/A</u>	<u>24.00</u>	<u>23.80</u>

New gain= 5.108, offset= 2.22, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.00</u>	<u>22.00</u>	<u>0.00</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Springfield</u>	<b>AQS #:</b>	<u>17-031-0057</u>
<b>Controller S/N:</b>	<u>3N-B0175</u>	<b>Date/Time:</b>	<u>3/21/2007 9:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0197</u>	<b>Technician:</b>	<u>MAS</u>
<b>Pump Box S/N:</b>	<u>3N-B0156</u>	<b>Site Operator(s):</b>	<u>Bob Sanford</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>305454</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>381</u>	<u>370</u>	<u>11</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	1315	27	8.85	8.85	0	Pass
Barometric Pressure Calibration	3312	20	749	749	0	Pass

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
19.80	3401	19.97	19.28
22.00	3774	22.23	21.22
24.00	4150	24.43	23.26

New gain= 5.346 , offset= 1.35 , correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
22.00	21.94	22.07	-0.13

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Chicago Com-Ed</u>	<b>AQS #:</b>	<u>17-031-0076</u>
<b>Controller S/N:</b>	<u>3N-B0241</u>	<b>Date/Time:</b>	<u>3/21/2007 11:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0137</u>	<b>Technician:</b>	<u>MAS</u>
<b>Pump Box S/N:</b>	<u>3N-B0162</u>	<b>Site Operator(s):</b>	<u>BQ</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>305454</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>380</u>	<u>337</u>	<u>44</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1390</u>	<u>51</u>	<u>14.2</u>	<u>138</u>	<u>0.4</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3313</u>	<u>41</u>	<u>745</u>	<u>745</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3345</u>	<u>19.93</u>	<u>19.50</u>
<u>22.00</u>	<u>3719</u>	<u>22.15</u>	<u>21.56</u>
<u>24.00</u>	<u>4085</u>	<u>24.39</u>	<u>23.71</u>

**New gain=** 5.705, **offset=** 0.51, **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.15</u>	<u>22.56</u>	<u>0.41</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Northbrook AQS #: 17-031-4201 POC5  
 Controller S/N: 3N-B0232 Date/Time: 3/20/2007 10:00  
 Sampler Module S/N: 3N-B0194 Technician: MAS  
 Pump Box S/N: 3N-B0135 Site Operator(s): Jeff Flick

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>313</u>	<u>67</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1446</u>	<u>48</u>	<u>19.7</u>	<u>19.7</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3362</u>	<u>36</u>	<u>756</u>	<u>756</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3291</u>	<u>19.81</u>	<u>19.67</u>
<u>22.00</u>	<u>3653</u>	<u>22.03</u>	<u>21.18</u>
<u>24.00</u>	<u>4020</u>	<u>24.22</u>	<u>23.92</u>

New gain= 5.774 , offset= 0.59 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.96</u>	<u>22.15</u>	<u>-0.19</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Naperville AQS #: 17-043-4002 POC5  
 Controller S/N: 3N-B0139 Date/Time: 3/20/2007 15:20  
 Sampler Module S/N: 3N-B0173 Technician: MAS  
 Pump Box S/N: 3N-B0154 Site Operator(s): Jeff Flick, Glen Johnson

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>125</u>	<u>255</u>

 mmHg in 11 seconds FAIL

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1395</u>	<u>38</u>	<u>19.5</u>	<u>15.65</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3343</u>	<u>36</u>	<u>759</u>	<u>752</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3362</u>	<u>19.96</u>	<u>18.52</u>
<u>22.00</u>	<u>3739</u>	<u>22.16</u>	<u>20.32</u>
<u>24.00</u>	<u>4115</u>	<u>24.45</u>	<u>22.31</u>

New gain= 5.212, offset= 1.11, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.01</u>	<u>22.16</u>	<u>-0.15</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Alton, IL</u>	<b>AQS #:</b>	<u>17-119-2009</u>
<b>Controller S/N:</b>	<u>3N-B0262</u>	<b>Date/Time:</b>	<u>4/16/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0248</u>	<b>Technician:</b>	<u>I. Rennat</u>
<b>Pump Box S/N:</b>	<u>3N-B0249</u>	<b>Site Operator(s):</b>	<u>Jay Turner</u>

<b>Flow Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>000190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>304020</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>000190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>380</u>	<u>270</u>	<u>110</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1426</u>	<u>0</u>	<u>22.6</u>	<u>22.6</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3314</u>	<u>17</u>	<u>753.6</u>	<u>750</u>	<u>3.6</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3220</u>	<u>19.69</u>	<u>19.76</u>
<u>22.00</u>	<u>3575</u>	<u>21.86</u>	<u>21.87</u>
<u>24.00</u>	<u>3935</u>	<u>24.08</u>	<u>23.95</u>

**New gain=** 5.71, **offset=** 1.02, **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.07</u>	<u>22.18</u>	<u>-0.11</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Gary AQS #: 18-084-0022  
 Controller S/N: 3N-B0223 Date/Time: 3/22/2007 10:00  
 Sampler Module S/N: 3N-B0158 Technician: MAS  
 Pump Box S/N: 3N-B0183 Site Operator(s): Scott

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>322</u>	<u>9</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1460</u>	<u>45</u>	<u>26.1</u>	<u>26.8</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3289</u>	<u>27</u>	<u>743</u>	<u>748</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3217</u>	<u>19.90</u>	<u>22.58</u>
<u>22.00</u>	<u>3576</u>	<u>22.05</u>	<u>25.09</u>
<u>24.00</u>	<u>3941</u>	<u>24.30</u>	<u>27.53</u>

New gain= 6.776 , offset= 0.17 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.02</u>	<u>21.59</u>	<u>0.43</u>

PASS

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?  Attendance

Notes:  
 Online manual? 2 more copies.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Purdue AQS #: 18-089-2004  
 Controller S/N: 3N-B0199 Date/Time: 3/22/2007 12:00  
 Sampler Module S/N: 3N-B0200 Technician: MAS  
 Pump Box S/N: 3N-B0141 Site Operator(s): Eric Courtright

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>336</u>	<u>45</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1467</u>	<u>64</u>	<u>20.7</u>	<u>20.8</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3227</u>	<u>14</u>	<u>746</u>	<u>743</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>32.75</u>	<u>20.10</u>	<u>22.73</u>
<u>22.00</u>	<u>36.32</u>	<u>22.33</u>	<u>25.62</u>
<u>24.00</u>	<u>39.93</u>	<u>24.55</u>	<u>28.27</u>

New gain= 7.64 , offset= -2.78 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.74</u>	<u>21.65</u>	<u>0.09</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Indianapolis, IN</u>	<b>AQS #:</b>	<u>18-097-0078</u>
<b>Controller S/N:</b>	<u>3N-B0226</u>	<b>Date/Time:</b>	<u>4/18/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0284</u>	<b>Technician:</b>	<u>I. Rennat</u>
<b>Pump Box S/N:</b>	<u>3N-B0258</u>	<b>Site Operator(s):</b>	<u>Dan Short</u>

<b>Flow Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>000190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>304020</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>BGI TriCal</u>	<b>S/N:</b>	<u>000190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>14 seconds</u>	<b>FAIL</b>
	<u>380</u>	<u>1357</u>	<u>225</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1357</u>	<u>27</u>	<u>13</u>	<u>12.94</u>	<u>0.06</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3249</u>	<u>31</u>	<u>734</u>	<u>734</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3261</u>	<u>19.78</u>	<u>19.14</u>
	<u>22.00</u>	<u>3647</u>	<u>22.13</u>	<u>21.16</u>
	<u>24.00</u>	<u>4007</u>	<u>24.30</u>	<u>23.17</u>

New gain= 5.35 , offset= 1.46 , correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.06</u>	<u>21.96</u>	<u>0.10</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?     
  Attendance     

**Notes:**  
 This unit would not pass the leak check. Returned to URG for repair.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Louisville, KY AQS #: 21-111-0043  
 Controller S/N: 3N-B0124 Date/Time: 4/19/2007  
 Sampler Module S/N: 3N-B0251 Technician: I. Rennat  
 Pump Box S/N: 3N-B0289 Site Operator(s): Susan Bowman

Flow Transfer Standard Model: BGI TriCal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 304020 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 000190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>300</u>	<u>80</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1473</u>	<u>37</u>	<u>23.6</u>	<u>21.9</u>	<u>1.7</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3312</u>	<u>35</u>	<u>746</u>	<u>746</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3268</u>	<u>20.06</u>	<u>20.55</u>
22.00	<u>3621</u>	<u>22.23</u>	<u>22.94</u>
24.00	<u>3979</u>	<u>24.43</u>	<u>25.09</u>

New gain= 6.006 , offset= 0.64 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>21.97</u>	<u>22.15</u>	<u>-0.20</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Essex, MD AQS #: 24-005-3001  
 Controller S/N: 3N-B0190 Date/Time: 3/9/2007  
 Sampler Module S/N: 3N-B0176 Technician: I. Rennat  
 Pump Box S/N: 3N-B0210 Site Operator(s): Ryan Auvic

Flow Transfer Standard Model: BGI TriCal S/N: 00263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 00263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>285</u>	<u>95</u>

 mmHg in 35 seconds Pass

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1260</u>	<u>0</u>	<u>6</u>	<u>2.52</u>		
Barometric Pressure Calibration	<u>3443</u>	<u>-2</u>	<u>780.2</u>	<u>772</u>		

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3599</u>	<u>19.94</u>	<u>17.91</u>
<u>22.00</u>	<u>3991</u>	<u>22.17</u>	<u>19.74</u>
<u>24.00</u>	<u>4383</u>	<u>24.37</u>	<u>21.71</u>

New gain= 5.141, offset= 0.87, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.04</u>	<u>22.19</u>	<u>-0.16</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Ypsilanti, MI</u>	<b>AQS #:</b>	<u>26-161-0008</u>
<b>Controller S/N:</b>	<u>3N-B0253</u>	<b>Date/Time:</b>	<u>4/23/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0227</u>	<b>Technician:</b>	<u>M.H. Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0213</u>	<b>Site Operator(s):</b>	<u>Matt Nowak</u>

<b>Flow Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>EUTECHNICS</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/19/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>381</u>	<u>371</u>	<u>10</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1481</u>	<u>33</u>	<u>24.5</u>	<u>24.5</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3241</u>	<u>-8</u>	<u>734</u>	<u>734</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3482</u>	<u>19.45</u>	<u>20.34</u>
<u>22.00</u>	<u>3511</u>	<u>22.12</u>	<u>20.55</u>
<u>24.00</u>	<u>3869</u>	<u>24.34</u>	<u>24.68</u>

**New gain=** 5.813 , **offset=** 1.04 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.95</u>	<u>21.80</u>	<u>0.15</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Dearborn, MI</u>	<b>AQS #:</b>	<u>26-163-0033</u>
<b>Controller S/N:</b>	<u>3N-B0259</u>	<b>Date/Time:</b>	<u>4/23/2007 10:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0242</u>	<b>Technician:</b>	<u>M.H. Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0267</u>	<b>Site Operator(s):</b>	<u>Brian Lomerson / Peter DeHart</u>

<b>Flow Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>EUTECHNICS</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>381</u>	<u>314</u>	<u>67</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1493</u>	<u>62</u>	<u>23</u>	<u>23</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3280</u>	<u>32</u>	<u>746</u>	<u>740</u>	<u>6</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3249</u>	<u>19.75</u>	<u>19.75</u>
	<u>22.00</u>	<u>3595</u>	<u>21.79</u>	<u>21.79</u>
	<u>24.00</u>	<u>3948</u>	<u>23.88</u>	<u>23.88</u>

**New gain=** 5.584 , **offset=** 0.91 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.85</u>	<u>21.97</u>	<u>-0.12</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance



**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Minneapolis AQS #: 27-053-0963 POC 5  
 Controller S/N: 3N-B0256 Date/Time: 3/19/2007 10:10  
 Sampler Module S/N: 3N-B0140 Technician: MAS  
 Pump Box S/N: 3N-B0195 Site Operator(s): Don Bock

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 305454 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>306</u>	<u>74</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1328</u>	<u>43</u>	<u>8.3</u>	<u>8.3</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3259</u>	<u>26</u>	<u>737</u>	<u>737</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3402</u>	<u>20.14</u>	<u>18.50</u>
<u>22.00</u>	<u>3775</u>	<u>22.01</u>	<u>20.35</u>
<u>24.00</u>	<u>4140</u>	<u>24.56</u>	<u>22.92</u>

New gain= 5.08, offset= 1.45, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.08</u>	<u>22.18</u>	<u>-0.11</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Arnold Tenbrook & Tenbrook, near St.      AQS #: 29-099-0012  
 Controller S/N: 3N-B0202      Date/Time: \_\_\_\_\_  
 Sampler Module S/N: 3N-B0218      Technician: \_\_\_\_\_  
 Pump Box S/N: 3N-B0264      Site Operator(s): Robert Nilges

Flow Transfer Standard Model: BGI TriCal      S/N: 000190      Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400      S/N: 304020      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal      S/N: 000190      Cal. Date: 1/31/2007

Leak Check Results:      Max      Min      Diff      mmHg in \_\_\_\_\_ seconds

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	_____	_____	_____	_____	_____	_____
Barometric Pressure Calibration	_____	_____	_____	_____	_____	_____

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	19.80	_____	_____	_____
	22.00	_____	_____	_____
	24.00	_____	_____	_____

New gain= \_\_\_\_\_, offset= \_\_\_\_\_, correlation= \_\_\_\_\_

**Flow Rate Audit**

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	22.00	_____	_____	_____

Auditor's Signature: \_\_\_\_\_

Notes:       Cardinal Photos?       Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: St. Louis, Blair Street, MO      AQS #: 29-510-0085  
 Controller S/N: 3N-B0268      Date/Time: 4/17/2007  
 Sampler Module S/N: 3N-B0266      Technician: I. Rennat  
 Pump Box S/N: 3N-B0273      Site Operator(s): Robert Berri

Flow Transfer Standard Model: BGI TriCal      S/N: 000190      Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400      S/N: 304020      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal      S/N: 000190      Cal. Date: 1/31/2007

Leak Check Results:      Max      Min      Diff  
    374      340      34      mmHg in 35 seconds      PASS

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1442</u>	<u>24</u>	<u>21.7</u>	<u>21.64</u>	<u>0.06</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3310</u>	<u>-6</u>	<u>754.2</u>	<u>754</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	19.80	<u>3230</u>	<u>19.85</u>	<u>20.29</u>
	22.00	<u>3575</u>	<u>22.01</u>	<u>22.41</u>
	24.00	<u>3940</u>	<u>24.25</u>	<u>24.61</u>

New gain= 5.89 , offset= 0.8 , correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
22.00	<u>22.03</u>	<u>22.04</u>	<u>0.02</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?     
  Attendance     

Notes:  
 Wood base for sampler to be constructed at a later date by onsite personnel.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Missoula, MT AQS #: 30-063-0031 POC 5  
 Controller S/N: 3N-B0244 Date/Time: 5/2/2007  
 Sampler Module S/N: 3N-B0275 Technician: Mike Slate  
 Pump Box S/N: 3N-B0252 Site Operator(s): Eric Englebert

Flow Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
380	354	27

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	1422	38	18.4	19.08	0	Pass
Barometric Pressure Calibration	2916	28	666.9	668	0	Pass

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	2963	20.10	19.08
22.00	3275	22.32	21.21
24.00	3595	24.52	23.24

New gain= 5.626 , offset= 0.24 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	22.00	22.04	-0.16

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Camden, NJ AQS #: 34-007-0003-5  
 Controller S/N: 3N-B0214 Date/Time: 3/29/2007  
 Sampler Module S/N: 3N-B0188 Technician: Dave Beichley  
 Pump Box S/N: 3N-B0186 Site Operator(s): Paul, Toppin, Tom McKenna, Jim Oxley

Flow Transfer Standard Model: TriCal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>128</u>	<u>6</u>	<u>122</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1328</u>	<u>26</u>	<u>10.1</u>	<u>10.1</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3428</u>	<u>28</u>	<u>771</u>	<u>771</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3523</u>	<u>20.07</u>	<u>18.06</u>
22.00	<u>3908</u>	<u>22.32</u>	<u>19.96</u>
24.00	<u>4294</u>	<u>24.55</u>	<u>21.85</u>

New gain= 5.136, offset= 0.93, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>22.01</u>	<u>22.14</u>	<u>-0.14</u>

PASS

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?    
  Attendance    

Notes:  
 Pump did not work on start up. Manually turned pump fan blades before it started working.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Bronx, NY AQS #: 36-005-0110-5  
 Controller S/N: 3N-B0172 Date/Time: 3/26/2007  
 Sampler Module S/N: 3N-B0164 Technician: Dave Beichley  
 Pump Box S/N: 3N-B0198 Site Operator(s): Rich Colas

Flow Transfer Standard Model: TriCal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>363</u>	<u>295</u>	<u>68</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1387</u>	<u>60</u>	<u>12.6</u>	<u>12.6</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3411</u>	<u>35</u>	<u>766</u>	<u>766</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3415</u>	<u>19.91</u>	<u>17.69</u>
<u>22.00</u>	<u>3818</u>	<u>22.12</u>	<u>19.52</u>
<u>24.00</u>	<u>4203</u>	<u>24.39</u>	<u>21.40</u>

New gain= 5.025 , offset= 1.04 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>21.94</u>	<u>22.23</u>	<u>-0.29</u>

**PASS**

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?    
  Attendance    

Notes:  
 Tried 2 other Module C units before passing the leak check. Slope seems too low.  
 Site also moved from original area. Now located on top of junior high school.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>New York</u>	<b>AQS #:</b>	<u>36-061-0134-5</u>
<b>Controller S/N:</b>	<u>3N-B0220</u>	<b>Date/Time:</b>	<u>3/26/2007 10:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0134</u>	<b>Technician:</b>	<u>Dave Beichley</u>
<b>Pump Box S/N:</b>	<u>3N-B0192</u>	<b>Site Operator(s):</b>	<u>Emanuel Joseph</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>101611</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>W12537</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>Pass</b>
	<u>372</u>	<u>355</u>	<u>17</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1297</u>	<u>23</u>	<u>7.3</u>	<u>7.3</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3416</u>	<u>31</u>	<u>768</u>	<u>768</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3460</u>	<u>19.82</u>	<u>17.05</u>
<u>22.00</u>	<u>3849</u>	<u>22.07</u>	<u>18.93</u>
<u>24.00</u>	<u>4238</u>	<u>24.25</u>	<u>20.87</u>

**New gain=** 5.163 , **offset=** -0.02 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.00</u>	<u>22.29</u>	<u>-0.29</u>

**Pass**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?       Attendance

Notes:  
 Site moved from Canal St. to an Elementary school.  
 Initial leak check failed, installed new module.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Audit Form**

Station: Winston-Salem AQS #: 37-067-0110 POC 5  
 Controller S/N: 3N-B0127 Date/Time: 2/28/2007 10:00  
 Sampler Module S/N: 3N-B0191 Technician: M Tigges - ARS  
 Pump Box S/N: 3N-B0207 Site Operator(s): Pat Reaga

Flow Transfer Standard Model: BGI TriCal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Futechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 000263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>306</u>	<u>74</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	_____	_____	_____	_____	_____	_____
Barometric Pressure Calibration	_____	_____	_____	_____	_____	_____

Flow Rate Calibration

Set Point	Raw	Sampler Flow	Reference Flow
19.80	_____	_____	_____
22.00	_____	_____	_____
24.00	_____	_____	_____

New gain= \_\_\_\_\_ 5364 , offset= \_\_\_\_\_ 0.88 , correlation= \_\_\_\_\_ 1.000

Flow Rate Audit

Set Point	Sampler Flow	Reference Flow	Difference
22.00	_____	_____	_____

PASS/FAIL

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?  Attendance

Notes:

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Cleveland, OH</u>	<b>AQS #:</b>	<u>39-035-0038</u>
<b>Controller S/N:</b>	<u>3N-B0250</u>	<b>Date/Time:</b>	<u>4/25/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0257</u>	<b>Technician:</b>	<u>M.H. Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0144</u>	<b>Site Operator(s):</b>	<u>Mike Becker / Frank Reed</u>

<b>Flow Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>EUTECHNICS</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>381</u>	<u>377</u>	<u>4</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1476</u>	<u>41</u>	<u>24</u>	<u>24</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3258</u>	<u>6</u>	<u>738</u>	<u>738</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3222</u>	<u>20.15</u>	<u>20.61</u>
	<u>22.00</u>	<u>3578</u>	<u>22.36</u>	<u>22.82</u>
	<u>24.00</u>	<u>3924</u>	<u>24.58</u>	<u>24.75</u>

**New gain=** 5.994 , **offset=** 0.47 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.89</u>	<u>21.72</u>	<u>0.17</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**       Cardinal Photos?       Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Columbus, Maple Canyon, OH      AQS #: 39-049-0081  
 Controller S/N: 3N-B0169      Date/Time: 4/26/2007  
 Sampler Module S/N: 3N-B0281      Technician: M H Valvur  
 Pump Box S/N: 3N-B0234      Site Operator(s): Rob Twynham / Chris Hussey

Flow Transfer Standard Model: TRI-CAL      S/N: 000263-1      Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: EUTECHNICS      S/N: 304019      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TRI-CAL      S/N: 000263-1      Cal. Date: 1/31/2007

Leak Check Results:      Max      Min      Diff  
    380      307      73      mmHg in 35 seconds      PASS

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	1440	0	20	20	0	Pass
Barometric Pressure Calibration	3233	1	730	730	0	Pass

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
19.80	3150	19.77	20.28
22.00	3489	20.01	22.36
24.00	3843	24.20	24.54

New gain= 5.751, offset= 1.26, correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
22.00	21.96	21.76	0.20

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:       Cardinal Photos?       Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Cincinnati, OH AQS #: 39-061-0040  
 Controller S/N: 3N-B0271 Date/Time: 4/20/2007  
 Sampler Module S/N: 3N-B0182 Technician: I. Rennat  
 Pump Box S/N: 3N-B0279 Site Operator(s): Ofori Bandoh

Flow Transfer Standard Model: BGI TriCal S/N: 000190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 304020 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 000190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>262</u>	<u>118</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1339</u>	<u>8</u>	<u>13.9</u>	<u>13.01</u>	<u>0.9</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3297</u>	<u>34</u>	<u>743</u>	<u>743</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3269</u>	<u>19.59</u>	<u>19.94</u>
22.00	<u>3615</u>	<u>21.76</u>	<u>22.11</u>
24.00	<u>3963</u>	<u>23.89</u>	<u>24.19</u>

New gain= 5.915, offset= 0.62, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>22.08</u>	<u>22.22</u>	<u>-0.14</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Steubenville, OH / Logan, OH      AQS #: 39-081-0017  
 Controller S/N: 3N-B0245      Date/Time: 4/16/07  
 Sampler Module S/N: 3N-B0130      Technician: Mitch Walker  
 Pump Box S/N: 3N-B0255      Site Operator(s): Mike Murphy

Flow Transfer Standard Model: BGI TriCal      S/N: 263      Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600      S/N: 99F101611      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal      S/N: 263      Cal. Date: 10/12/2006

Leak Check Results:      Max      Min      Diff  
    381      375      6      mmHg in 35 seconds      PASS

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	1303	41	23.1	23.1	0	Pass
Barometric Pressure Calibration	3221	38	737	737	0	Pass

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
19.80	3181	19.36	19.36
22.00	3783	21.54	21.54
24.00	4152	23.68	23.68

New gain= 5.863 , offset= -0.58 , correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
22.00	21.93	21.81	0.12

**PASS**

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?     
  Attendance     

Notes:  
 Not installed, operator will do this later...no photos.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Barr School, Sheffield, Lorraine, OH      AQS #: 39-093-3002  
 Controller S/N: 3N-B0178      Date/Time: 4/24/2007  
 Sampler Module S/N: 3N-B0287      Technician: M H Valvur  
 Pump Box S/N: 3N-B0231      Site Operator(s): Rick Smith

Flow Transfer Standard Model: TRI-CAL      S/N: 000263-1      Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: EUTECHNICS      S/N: 304019      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TRI-CAL      S/N: 000263-1      Cal. Date: 1/31/2007

Leak Check Results:      Max      Min      Diff  
    380      334      46      mmHg in 35 seconds      PASS

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1467</u>	<u>51</u>	<u>21.5</u>	<u>21.5</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3313</u>	<u>36</u>	<u>746</u>	<u>746</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3253</u>	<u>20.20</u>	<u>19.70</u>
	<u>22.00</u>	<u>3621</u>	<u>22.22</u>	<u>21.75</u>
	<u>24.00</u>	<u>3986</u>	<u>24.38</u>	<u>24.15</u>

New gain= 5.578 , offset= 1.06 , correlation= 1.000

**Flow Rate Audit**

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	<u>22.00</u>	<u>21.95</u>	<u>22.03</u>	<u>-0.08</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:       Cardinal Photos?       Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Akron, OH</u>	<b>AQS #:</b>	<u>39-153-0023</u>
<b>Controller S/N:</b>	<u>3N-B0187</u>	<b>Date/Time:</b>	<u>4/26/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0254</u>	<b>Technician:</b>	<u>M.H. Valvur</u>
<b>Pump Box S/N:</b>	<u>3N-B0216</u>	<b>Site Operator(s):</b>	<u>Alan Richardson</u>

<b>Flow Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>EUTECHNICS</u>	<b>S/N:</b>	<u>304019</u>	<b>Cal. Date:</b>	<u>1/19/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TRI-CAL</u>	<b>S/N:</b>	<u>000263-1</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>381</u>	<u>320</u>	<u>61</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1389</u>	<u>50</u>	<u>15</u>	<u>15</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3221</u>	<u>-1</u>	<u>735</u>	<u>735</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3443</u>	<u>19.84</u>	<u>18.85</u>
	<u>22.00</u>	<u>3625</u>	<u>22.12</u>	<u>20.88</u>
	<u>24.00</u>	<u>3987</u>	<u>24.35</u>	<u>21.35</u>

**New gain=** 5.426 , **offset=** 0.87 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.95</u>	<u>21.79</u>	<u>0.16</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

**Notes:**  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Portland, OR AQS #: 41-051-0080 POC 6  
 Controller S/N: 3N-B0238 Date/Time: 5/1/2007  
 Sampler Module S/N: 3N-B0131 Technician: Mike Slate  
 Pump Box S/N: 3N-B0261 Site Operator(s): Christopher McGarry

Flow Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: Tri-Cal S/N: 000263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>238</u>	<u>143</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1415</u>	<u>29</u>	<u>18.6</u>	<u>18.16</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3342</u>	<u>37</u>	<u>751.7</u>	<u>752</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3305</u>	<u>19.80</u>	<u>18.34</u>
<u>22.00</u>	<u>3063</u>	<u>22.00</u>	<u>20.30</u>
<u>24.00</u>	<u>4032</u>	<u>24.19</u>	<u>22.29</u>

New gain= 5.458, offset= 0.31, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.02</u>	<u>22.10</u>	<u>0.08</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Liberty, PA AQS #: 42-003-0064  
 Controller S/N: 3N-B0133 Date/Time: 4/17/07 10:30 AM  
 Sampler Module S/N: 3N-B0179 Technician: Mitch Walker  
 Pump Box S/N: 3N-B0290 Site Operator(s): Darrell Stern

Flow Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>325</u>	<u>55</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1302</u>	<u>43</u>	<u>5.8</u>	<u>5.9</u>	<u>0.1</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3219</u>	<u>35</u>	<u>727.1</u>	<u>727</u>	<u>0.1</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3610</u>	<u>12.10</u>	<u>19.15</u>
<u>22.00</u>	<u>4210</u>	<u>21.45</u>	<u>21.45</u>
<u>24.00</u>	<u>4603</u>	<u>23.18</u>	<u>23.21</u>

New gain= 5.41, offset= 6.56, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.10</u>	<u>22.10</u>	<u>0.00</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Philadelphia AMS Lab AQS #: 42-101-0004-7  
 Controller S/N: 3N-B0157 Date/Time: 3/27/2007  
 Sampler Module S/N: 3N-B0161 Technician: Dave Beichley  
 Pump Box S/N: 3N-B0168 Site Operator(s): Kia Hence, Kyle Robinson, Robert Thomas, Thom

Flow Transfer Standard Model: TriCal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>368</u>	<u>13</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1443</u>	<u>47</u>	<u>19.5</u>	<u>19.5</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3376</u>	<u>35</u>	<u>759</u>	<u>759</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3340</u>	<u>19.80</u>	<u>18.75</u>
22.00	<u>3682</u>	<u>22.26</u>	<u>20.65</u>
24.00	<u>4042</u>	<u>24.41</u>	<u>22.54</u>

New gain= 5.207 , offset= 1.34 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>21.98</u>	<u>22.10</u>	<u>-0.12</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>24th &amp; Ritner, Philadelphia, PA</u>	<b>AQS #:</b>	<u>42-101-0004</u>
<b>Controller S/N:</b>	<u>3N-B0283</u>	<b>Date/Time:</b>	<u>4/26/2007</u>
<b>Sampler Module S/N:</b>	<u>3N-B0230</u>	<b>Technician:</b>	<u>Mike Slate</u>
<b>Pump Box S/N:</b>	<u>3N-B0243</u>	<b>Site Operator(s):</b>	<u>Loretta Hyden</u>

<b>Flow Transfer Standard Model:</b>	<u>BIOS Base</u>	<b>S/N:</b>	<u>Base: B295, Cell: 1461</u>	<b>Cal. Date:</b>	<u>4/12/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>305454</u>	<b>Cal. Date:</b>	<u>3/7/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>BIOS</u>	<b>S/N:</b>	<u>Base: B295, Cell: 1461</u>	<b>Cal. Date:</b>	<u>4/12/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<u>PASS</u>
	<u>380</u>	<u>320</u>	<u>60</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1409</u>	<u>37</u>	<u>17.2</u>	<u>15.87</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3387</u>	<u>35</u>	<u>761.3</u>	<u>761</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>3382</u>	<u>19.83</u>	<u>20.09</u>
	<u>22.00</u>	<u>3761</u>	<u>22.04</u>	<u>22.27</u>
	<u>24.00</u>	<u>4129</u>	<u>24.22</u>	<u>24.45</u>

**New gain=** 5.965 , **offset=** 0.35 , **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.00</u>	<u>22.11</u>	<u>0.11</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?     Attendance   

**Notes:**  
 Training completed on previous trip.



**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Florence, PA AQS #: 42-125-5001  
 Controller S/N: 3N-B0265 Date/Time: 4/18/07  
 Sampler Module S/N: 3N-B0221 Technician: Mitch Walker  
 Pump Box S/N: 3N-B0237 Site Operator(s): Rob Valentich

Flow Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>381</u>	<u>361</u>	<u>20</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1328</u>	<u>53</u>	<u>7.5</u>	<u>7.5</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3216</u>	<u>42</u>	<u>725</u>	<u>725</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
<u>19.80</u>	<u>3368</u>	<u>20.19</u>	<u>18.14</u>
<u>22.00</u>	<u>3744</u>	<u>22.36</u>	<u>20.15</u>
<u>24.00</u>	<u>4103</u>	<u>24.66</u>	<u>22.07</u>

New gain= 5.37, offset= 0.07, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.00</u>	<u>22.12</u>	<u>0.12</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance



**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Springhill/Knoxville, TN      AQS #: 47-093-1020  
 Controller S/N: 3N-B0193      Date/Time: 4/13/2007 8:00  
 Sampler Module S/N: 3N-B0224      Technician: Martin H Valvur  
 Pump Box S/N: 3N-B0285      Site Operator(s): Amber Talgo, Kelly Vaughn

Flow Transfer Standard Model: TriCal      S/N: 000263-1      Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics      S/N: 304019      Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal      S/N: 000263-1      Cal. Date: 1/31/2007

Leak Check Results:      Max      Min      Diff  
    381      284      97      mmHg in 35 seconds      PASS

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	1318	0	11.8	11.7	0.1	Pass
Barometric Pressure Calibration	3275	2	745	739	6	Pass

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
19.80	3006	19.53	19.43
22.00	3627	21.80	21.29
24.00	3990	23.98	23.55

New gain= 5.652 , offset= 0.92 , correlation= 0.998

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
22.00	22.02	22.16	-0.14

**PASS**

Auditor's Signature: \_\_\_\_\_

Notes:       Cardinal Photos?       Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Bountiful - Utah AQS #: 49-011-0004  
 Controller S/N: 3N-B0235 Date/Time: 4/4/2007 12:00  
 Sampler Module S/N: 3N-B0215 Technician: Neal Olson  
 Pump Box S/N: 3N-B0180 Site Operator(s): Neal Olson

Flow Transfer Standard Model: TriCal S/N: 000263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: W12537 Cal. Date: 10/12/2006

Leak Check Results: 

Max	Min	Diff
<u>380</u>	<u>319</u>	<u>61</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1400</u>	<u>1</u>	<u>19.8</u>	<u>19.8</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>2847</u>	<u>37</u>	<u>651</u>	<u>651</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>2778</u>	<u>19.62</u>	<u>19.56</u>
22.00	<u>3091</u>	<u>21.71</u>	<u>21.68</u>
24.00	<u>3391</u>	<u>23.88</u>	<u>23.88</u>

New gain= 5.965, offset= 0.11, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>22.04</u>	<u>21.89</u>	<u>0.15</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance



**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Lindon, Utah</u>	<b>AQS #:</b>	<u>49-049-4001-5</u>
<b>Controller S/N:</b>	<u>3N-B0247</u>	<b>Date/Time:</b>	<u>3/20/2007 13:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0206</u>	<b>Technician:</b>	<u>Dave Beichley</u>
<b>Pump Box S/N:</b>	<u>3N-B0174</u>	<b>Site Operator(s):</b>	<u>Neal Olson</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>000263</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics</u>	<b>S/N:</b>	<u>101611</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>W12537</u>	<b>Cal. Date:</b>	<u>10/12/2006</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>381</u>	<u>363</u>	<u>17</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1429</u>	<u>8</u>	<u>22.0</u>	<u>22.0</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>2766</u>	<u>29</u>	<u>636.0</u>	<u>636.0</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
	<u>19.80</u>	<u>2770</u>	<u>20.06</u>	<u>18.82</u>
	<u>22.00</u>	<u>3056</u>	<u>22.20</u>	<u>20.81</u>
	<u>24.00</u>	<u>3361</u>	<u>24.45</u>	<u>22.92</u>

**New gain=** 5.611 , **offset=** 0.04 , **correlation=** 1.000

**Flow Rate Audit**

	<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
	<u>22.00</u>	<u>21.86</u>	<u>22.18</u>	<u>-0.32</u>

**Pass**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?       Attendance

**Notes:**  
 Unit performed well, all phases checked out good.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

<b>Station:</b>	<u>Duwamish/Yakima, WA</u>	<b>AQS #:</b>	<u>53-033-0057</u>
<b>Controller S/N:</b>	<u>3N-B0181</u>	<b>Date/Time:</b>	<u>5/1/2007 3:00</u>
<b>Sampler Module S/N:</b>	<u>3N-B0125</u>	<b>Technician:</b>	<u>I. Rennat</u>
<b>Pump Box S/N:</b>	<u>3N-B0282</u>	<b>Site Operator(s):</b>	<u>Anthony Leo</u>

<b>Flow Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>
<b>Temperature Transfer Standard Model:</b>	<u>Eutechnics 4400</u>	<b>S/N:</b>	<u>90735</u>	<b>Cal. Date:</b>	<u>1/12/2007</u>
<b>Barometric Pressure Transfer Standard Model:</b>	<u>TriCal</u>	<b>S/N:</b>	<u>190</u>	<b>Cal. Date:</b>	<u>1/31/2007</u>

<b>Leak Check Results:</b>	<u>Max</u>	<u>Min</u>	<u>Diff</u>	<b>mmHg in</b>	<u>35 seconds</u>	<b>PASS</b>
	<u>381</u>	<u>297</u>	<u>83</u>			

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
<b>Temperature Calibration</b>	<u>1404</u>	<u>31</u>	<u>17.2</u>	<u>17.24</u>	<u>0</u>	<u>Pass</u>
<b>Barometric Pressure Calibration</b>	<u>3314</u>	<u>27</u>	<u>748</u>	<u>748</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3312</u>	<u>20.10</u>	<u>20.48</u>
<u>22.00</u>	<u>3670</u>	<u>22.31</u>	<u>22.87</u>
<u>24.00</u>	<u>4035</u>	<u>24.54</u>	<u>25.07</u>

**New gain=** 6.197, **offset=** -0.24, **correlation=** 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>21.95</u>	<u>21.94</u>	<u>0.01</u>

**PASS**

**Auditor's Signature:** \_\_\_\_\_

Cardinal Photos?       Attendance     

**Notes:**

Operator indicated that this sampler probably would be installed in Yakima at a later date. This unit was assembled, calibrated, and audited along with the Tacoma sampler at Washington State Dept. of Ecology Office in Bellvue, WA.

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Beacon Hill, WA AQS #: 53-033-0080  
 Controller S/N: 3N-B0286 Date/Time: 5/1/2007  
 Sampler Module S/N: 3N-B0233 Technician: I. Rennat  
 Pump Box S/N: 3N-B0276 Site Operator(s): Anthony Leo

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 90735 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>379</u>	<u>218</u>	<u>162</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>4999</u>	<u>3659</u>	<u>13.9</u>	<u>13.9</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>4095</u>	<u>803</u>	<u>749</u>	<u>749</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

Set Point	Raw	Sampler Flow	Reference Flow
19.80	<u>3372</u>	<u>19.93</u>	<u>19.38</u>
22.00	<u>3740</u>	<u>22.12</u>	<u>21.84</u>
24.00	<u>4106</u>	<u>24.28</u>	<u>24.04</u>

New gain= 6.078 , offset= -0.59 , correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
22.00	<u>21.96</u>	<u>22.09</u>	<u>-0.07</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

**Air Resource Specialists, Inc.**  
 1901 Sharp Point Drive, Suite E  
 Fort Collins, CO 80525  
 Phone: 970-484-7941  
 www.air-resource.com

**URG 3000N Carbon Sampler  
 Installation Form**

Station: Tacoma, WA AQS #: 53-053-0029  
 Controller S/N: 3N-B0208 Date/Time: 5/2/2007 11:00  
 Sampler Module S/N: 3N-B0185 Technician: I. Rennat  
 Pump Box S/N: 3N-B0201 Site Operator(s): Anthony Leo

Flow Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007  
 Temperature Transfer Standard Model: Eutechnics 4400 S/N: 90735 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: TriCal S/N: 190 Cal. Date: 1/31/2007

Leak Check Results: 

Max	Min	Diff
<u>368</u>	<u>318</u>	<u>50</u>

 mmHg in 35 seconds PASS

	Raw	Offset	Sampler	Reference	Difference	Pass/Fail
Temperature Calibration	<u>1384</u>	<u>9</u>	<u>17.4</u>	<u>17.4</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>3318</u>	<u>31</u>	<u>748</u>	<u>748</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

	Set Point	Raw	Sampler Flow	Reference Flow
	<u>19.80</u>	<u>3282</u>	<u>19.82</u>	<u>19.75</u>
	<u>22.00</u>	<u>3648</u>	<u>22.07</u>	<u>21.89</u>
	<u>24.00</u>	<u>4010</u>	<u>24.27</u>	<u>24.00</u>

New gain= 5.731, offset= 0.8, correlation= 1.000

**Flow Rate Audit**

Set Point	Sampler Flow	Reference Flow	Difference
<u>22.00</u>	<u>22.01</u>	<u>22.04</u>	<u>-0.03</u>

PASS

Auditor's Signature: \_\_\_\_\_

Cardinal Photos?  Attendance

Notes:  
 Sampler was installed but not connected to AC power due to:  
 \*No dedicated circuits available (4) 20 amp circuits - all used  
 \*Operator could not supply extension cord.  
 \*ALSO - Inlet approx. 3-4 ft. from building air conditioner.



**URG 3000N Carbon Sampler  
 Installation Form**

Station: Library, Charleston, WV AQS #: 54-039-1005  
 Controller S/N: 3N-B0196 Date/Time: 4/19/07  
 Sampler Module S/N: 3N-B0236 Technician: Mitch Walker  
 Pump Box S/N: 3N-B0270 Site Operator(s): Mark Drake, Matt Kemper, Derek Hancock, Joel A

Flow Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006  
 Temperature Transfer Standard Model: Eutechnics 4600 S/N: 101611 Cal. Date: 1/12/2007  
 Barometric Pressure Transfer Standard Model: BGI TriCal S/N: 263 Cal. Date: 10/12/2006

Leak Check Results: 

<u>Max</u>	<u>Min</u>	<u>Diff</u>	mmHg in <u>35</u> seconds	<u>PASS</u>
<u>380</u>	<u>350</u>	<u>30</u>		

	<u>Raw</u>	<u>Offset</u>	<u>Sampler</u>	<u>Reference</u>	<u>Difference</u>	<u>Pass/Fail</u>
Temperature Calibration	<u>1351</u>	<u>19</u>	<u>13.1</u>	<u>13.1</u>	<u>0</u>	<u>Pass</u>
Barometric Pressure Calibration	<u>2280</u>	<u>32</u>	<u>740</u>	<u>740</u>	<u>0</u>	<u>Pass</u>

**Flow Rate Calibration**

<u>Set Point</u>	<u>Raw</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>
<u>19.80</u>	<u>3311</u>	<u>19.89</u>	<u>18.62</u>
<u>22.00</u>	<u>3670</u>	<u>22.12</u>	<u>20.53</u>
<u>24.00</u>	<u>4050</u>	<u>24.34</u>	<u>22.47</u>

New gain= 5.276 , offset= 1.10 , correlation= 1.000

**Flow Rate Audit**

<u>Set Point</u>	<u>Sampler Flow</u>	<u>Reference Flow</u>	<u>Difference</u>
<u>22.00</u>	<u>22.00</u>	<u>22.16</u>	<u>0.16</u>

PASS

Auditor's Signature: \_\_\_\_\_

Notes:  Cardinal Photos?  Attendance

#### **4.0 SITE PHOTOS**

ARS took five photographs at each site. Four were taken in the cardinal directions and one good documentation image that showed all instrumentation in relation to the station after each installation. Missing images occurred for a number of reasons. In order of frequency, the causes were: the ARS field technician had trouble with a camera or forgot to photograph the site, the site was not prepared for installation and was left in a temporary storage location, and at one site ARS was informed that photography was not allowed.



View from the east – Birmingham, AL



View from the west – Birmingham, AL



View from the north – Birmingham, AL



View from the south – Birmingham, AL



View overall – Birmingham, AL



View from the east – Phenix City, AL



View from the west – Phenix City, AL



View from the north – Phenix City, AL



View from the south – Phenix City, AL



View overall – Phenix City, AL



View from the east – Bakersfield



View from the west – Bakersfield



View from the north – Bakersfield



View from the south – Bakersfield



View overall from northwest – Bakersfield



View overall – Bakersfield



View looking east – LA Central, CA



View looking west – LA Central, CA



View looking north – LA Central, CA



View looking south – LA Central, CA



View overall – LA Central, CA



View from the east – Rubidoux, CA



View from the west – Rubidoux, CA



View from the north – Rubidoux, CA



View from the south – Rubidoux, CA




View from the southeast – Rubidoux, CA



View overall – Rubidoux, CA



View looking east – El Cajon, CA



View looking west – El Cajon, CA



View looking north – El Cajon, CA



View looking south – El Cajon, CA



View from the east – Escondido, CA



View from the west – Escondido, CA



View from the north – Escondido, CA



View from the south – Escondido, CA



View overall – Escondido, CA



View from the east – Modesto, CA



View from the west – Modesto, CA



View from the north – Modesto, CA



View from the south – Modesto, CA



View overall – Modesto, CA



View overall with tower – Modesto, CA



View from the east – Visalia, CA



View from the west – Visalia, CA



View from the north – Visalia, CA



View from the south – Visalia, CA



View overall – Visalia, CA



View looking east – Wilmington, DE



View looking west – Wilmington, DE



View looking north – Wilmington, DE



View looking south – Wilmington, DE



View overall – Wilmington, DE



View to the east – Washington, DC



View to the west – Washington, DC



View to the north – Washington, DC



View to the south – Washington, DC



View overall – Washington, DC



View from the east – Macon, GA



View from the west – Macon, GA



View from the north – Macon, GA



View from the south – Macon, GA



View overall – Macon, GA



View from the east – Columbus, GA



View from the west – Columbus, GA



View from the north – Columbus, GA

AQS #13-215-0011



View from the south – Columbus, GA



View overall – Columbus, GA



View from the east – Meridian, ID



View from the west – Meridian, ID



View from the north – Meridian, ID



View from the south – Meridian, ID



View overall – Meridian, ID



View from the east – Springfield Chicago, IL



View from the west – Springfield Chicago, IL



View from the north – Springfield Chicago, IL

AQS #17-031-0057



View from the south – Springfield Chicago, IL



View overall with pumping station behind – Springfield Chicago, IL



View looking east – Com Ed, Chicago, IL



View looking south – Com Ed, Chicago, IL



View from the east – Water Plant, Northbrook, IL



View from the west – Water Plant, Northbrook, IL



View from the north – Water Plant, Northbrook, IL



View from the south – Water Plant, Northbrook, IL



View overall – Water Plant, Northbrook, IL



View base – Water Plant, Northbrook, IL



View from the east – City Hall Naperville, IL



View from the west – City Hall Naperville, IL



View from the north – City Hall Naperville, IL



View from the south – City Hall Naperville, IL



View overall – City Hall Naperville, IL



View from the east – Alton, IL



View from the west – Alton, IL



View from the north – Alton, IL



View from the south – Alton, IL



View from the east – IITRI, Gary, IN



View from the west – IITRI, Gary, IN



View from the north – IITRI, Gary, IN



View from the south – IITRI, Gary, IN



View overall – IITRI, Gary, IN



View looking east – Purdue Hammond, IN



View looking west – Purdue Hammond, IN



View looking north – Purdue Hammond, IN



View looking south – Purdue Hammond, IN



View from the east – Indianapolis, IN



View from the west – Indianapolis, IN



View from the north – Indianapolis, IN



View from the south – Indianapolis, IN



View overall – Indianapolis, IN



View from the east – Louisville, KY



View from the west – Louisville, KY



View from the north – Louisville, KY



View from the south – Louisville, KY



View overall – Louisville, KY



View to the east – Essex, MD



View to the west – Essex, MD



View to the north – Essex, MD



View to the south – Essex, MD



View overall – Essex, MD



View from the east – Ypsilanti, MI



View from the west – Ypsilanti, MI



View from the south – Ypsilanti, MI



View from overall – Ypsilanti, MI



View from the east – Dearborn, MI



View from the west – Dearborn, MI



View from the north – Dearborn, MI



View from the south – Dearborn, MI



View overall – Dearborn, MI



View from the east – Anderson School, Minneapolis, MN



View from the west – Anderson School, Minneapolis, MN



View from the north – Anderson School, Minneapolis, MN



View from the south – Anderson School, Minneapolis, MN



View behind – Anderson School, Minneapolis, MN



View overall – Anderson School, Minneapolis, MN



View from the east – Bonne Terre, MO



View from the northwest – Bonne Terre, MO



View from the northeast – Bonne Terre, MO



View from the east – St. Louis, MO




View from the west – St. Louis, MO



View from the north – St. Louis, MO



View from the south – St. Louis, MO



View overall – St. Louis, MO



View looking east – Missoula, MT



View looking west – Missoula, MT



View looking north – Missoula, MT



View looking south – Missoula, MT



View overall – Missoula, MT



View looking east – Camden, NJ



View looking west – Camden, NJ



View looking north – Camden, NJ



View looking south – Camden, NJ



View overall – Camden, NJ



View looking east – Bronx



View looking west – Bronx



View looking north – Bronx



View looking south – Bronx



View from the east – New York City, NY



View from the west – New York City, NY



View from the north – New York City, NY



View from the south – New York City, NY



View overall – New York City, NY



View looking east – Winston-Salem



View looking west – Winston-Salem



View looking north – Winston-Salem



View looking south – Winston-Salem



View overall – Winston-Salem



View from the east – Cleveland, OH



View from the west – Cleveland, OH



View from the north – Cleveland, OH



View from the south – Cleveland, OH



View overall – Cleveland, OH



View from the east – Columbus, OH



View from the west – Columbus, OH



View from the north – Columbus, OH

AQS #39-049-0081



View from the south – Columbus, OH



View overall – Columbus, OH



View from the east – Columbus, OH



View from the west – Columbus, OH



View from the north – Columbus, OH




View from the south – Columbus, OH



View overall – Columbus, OH



View from the east – Sheffield, Lorain, OH



View from the west – Sheffield, Lorain, OH



View from the north – Sheffield, Lorain, OH



View from the south – Sheffield, Lorain, OH



View from the southeast – Sheffield, Lorain, OH



View overall – Sheffield, Lorain, OH



View looking east – Portland, OR



View looking west – Portland, OR



View looking north – Portland, OR



View looking south – Portland, OR



View overall – Portland, OR



View from the east – Liberty, PA



View from the west – Liberty, PA



View from the north – Liberty, PA



View from the south – Liberty, PA



View from the east – AMS Building, Philadelphia, PA



View from the west – AMS Building, Philadelphia, PA



View from the north – AMS Building, Philadelphia, PA



View from the south – AMS Building, Philadelphia, PA



View overall – AMS Building, Philadelphia, PA



View looking east – 24<sup>th</sup> & Ritner, Philadelphia, PA



View looking west – 24<sup>th</sup> & Ritner, Philadelphia, PA



View looking north – 24<sup>th</sup> & Ritner, Philadelphia, PA



View looking south – 24<sup>th</sup> & Ritner, Philadelphia, PA



View overall – 24<sup>th</sup> & Ritner, Philadelphia, PA



View looking east – Amtrak, Philadelphia, PA



View looking west – Amtrak, Philadelphia, PA



View looking north – Amtrak, Philadelphia, PA



View looking south – Amtrak, Philadelphia, PA



View overall – Amtrak, Philadelphia, PA



View from the east – Florence, PA



View from the west – Florence, PA



View from the north – Florence, PA



View from the south – Florence, PA



View from the east – Greensburg, PA



View from the west – Greensburg, PA



View from the north – Greensburg, PA



View from the south – Greensburg, PA



View from the east – Knoxville, TN



View from the west – Knoxville, TN



View from the north – Knoxville, TN



View from the south – Knoxville, TN



View overall – Knoxville, TN



View looking east – Bountiful, UT



View looking north – Bountiful, UT



View looking south – Bountiful, UT



View overall – Bountiful, UT



View looking east – Salt Lake City, UT



View looking west – Salt Lake City, UT



View looking south – Salt Lake City, UT



View overall – Salt Lake City, UT



View from the east – Lindon, UT



View from the west – Lindon, UT



View from the north – Lindon, UT



View from the northeast – Lindon, UT



View from the south – Lindon, UT



View overall – Lindon, UT



View from the east – Beacon Hill, WA



View from the west – Beacon Hill, WA



View from the north – Beacon Hill, WA



View from the south – Beacon Hill, WA



View overall – Beacon Hill, WA



View from the east – Tacoma, WA



View from the west – Tacoma, WA



View from the north – Tacoma, WA



View from the south – Tacoma, WA



View overall – Tacoma, WA



View from the east – Guthrie, WV



View from the west – Guthrie, WV



View from the north – Guthrie, WV



View from the south – Guthrie, WV



View overall – Guthrie, WV



View from the east – Library, Charleston, WV



View from the west – Library, Charleston, WV



View from the north – Library, Charleston, WV



View from the south – Library, Charleston, WV

## 5.0 SUMMARY

A number of challenges were overcome during the active phase of this project. In general, good cooperation from the stakeholders was responsible for the success of the project. It is significant to point out that the sampler bears little resemblance to the original concept of a wall-mounted Module C Improve Sampler with critical orifice flow control. Challenges included sampler hardware design changes, sampler firmware changes resulting from hardware changes, firmware changes resulting from QA requirements, and schedule changes. The schedule changes can be summarized into two categories. The first cause was site readiness and acceptance of the requested sampler changes. Siting changes occurred as late as three weeks before the scheduled May 3<sup>rd</sup> start date. EPA OAQPS managed site selection and negotiations. ARS managed the site visit scheduling. The second cause of the schedule change was the iterative process required to complete the sampler. The addition of the mass flow controller, MFC, the firmware changes required supporting the MFC, the RTI data storage requirements, and the EPA QA group requirements all took time to integrate.

All of us at ARS appreciated the trust and confidence you showed us in letting us help you in Phase I of this project. We eagerly anticipate working with OAQPS in Phase II of the Carbon Sampler Replacement Program. If you have any questions regarding the project or this report, please don't hesitate to contact Dave or me.

David Dietrich or Mark Tigges  
**Air Resource Specialists, Inc.**  
1901 Sharp Point Drive, Suite E  
Fort Collins, Colorado 80525  
Telephone: 970-484-7941  
Fax: 970-484-3423

Dave Email: [DDietrich@air-resource.com](mailto:DDietrich@air-resource.com)  
Mark Email: [MTigges@air-resource.com](mailto:MTigges@air-resource.com)

## **APPENDIX A**

**STN Carbon Master Contact List  
As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/ Sampler/ Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
7	4/10/2007	01-073-0023 3009 28th St. No. Birmingham, AL	Birmingham SCHED: 3-Day POC: 5	AL	3N-B0160 3N-B0263 3N-B0219	Randy Dillard Greg Noah	Field Contact Oversight	205-930-1281 205-960-7817 cell 706-355-8635	<a href="mailto:Randy.dillard@jcdh.org">Randy.dillard@jcdh.org</a> <a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a>
7	4/9/2007	01-113-0001 County Health Dept. 1320 Broad St.	Phenix City SCHED: 6-Day POC: 5	AL	3N-B0277 3N-B0260 3N-B0228	Mike Malaier Tobey Malory Greg Noah	Field Contact Oversight	334-260-2747 334-260-2789 ADEM 706-355-8635	<a href="mailto:mml@adem.state.al.us">mml@adem.state.al.us</a> <a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a>
1	3/7/2007	06-029-0014 Flat Terrain, Oil Refinery 1.3 mi NNW, Train 1.4 mi N, Freeway 1.3 mi E	Bakersfield(2) California Ave. SCHED: 3-day POC: 5, 6	CA	3N-B0113 3N-B0114 3N-B0115 3N-B0118 3N-B0120	Ken Stroud Debbie Henson	Oversight Field Contact	916-445-3745 661-334-3992 661-747-3131 cell	<a href="mailto:kstroud@arb.ca.gov">kstroud@arb.ca.gov</a> <a href="mailto:dhenson@arb.ca.gov">dhenson@arb.ca.gov</a>
1	3/7/2007	06-037-1103 1630 N. Main Street	Los Angeles SCHED: 6-Day POC: 5	CA	3N-B0142 3N-B0143 3N-B0129	Phillip Fine Rene Bermudez	Oversight Field Contact	909-396-2239 310-486-4295 cell 909-396-2136 909-967-6179 cell	<a href="mailto:pmfine@aqmd.gov">pmfine@aqmd.gov</a> <a href="mailto:rbermudez@aqmd.gov">rbermudez@aqmd.gov</a>
1	3/6/2007	06-065-8001 5888 Mission Boulevard	Rubidoux (2) SCHED: 3-Day POC: 5, 6	CA	3N-B0154 3N-B0288 3N-B0132 3N-B0155 3N-B0138	Phillip Fine Rene Bermudez	Oversight Field Contact	909-396-2239 310-486-4295 cell 909-396-2136 909-967-6179 cell	<a href="mailto:pmfine@aqmd.gov">pmfine@aqmd.gov</a> <a href="mailto:rbermudez@aqmd.gov">rbermudez@aqmd.gov</a>
1	3/5/2007	06-073-0003 1155 Redwood Ave.	El Cajon SCHED: 3-Day POC: 5	CA	3N-B0145 3N-B0152 3N-B0177	Mahmood Hossain David Craig	Division Chief Sec. Mgr. Field	858-586-2760 858-586-2785	<a href="mailto:mahmood.hossain@sdcounty.ca.gov">mahmood.hossain@sdcounty.ca.gov</a> <a href="mailto:dcraig@sdapcd.org">dcraig@sdapcd.org</a>
1	3/5/2007	06-073-1002 600 E. Valley Parkway	Escondido SCHED: 6-Day POC: 5	CA	3N-B0148 3N-B0149 3N-B0126	Mahmood Hossain David Craig	Division Chief Sec. Mgr. Field	858-586-2760 858-586-2785	<a href="mailto:mahmood.hossain@sdcounty.ca.gov">mahmood.hossain@sdcounty.ca.gov</a> <a href="mailto:dcraig@sdapcd.org">dcraig@sdapcd.org</a>

**STN Carbon Master Contact List  
As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/Sampler/Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
<b>1</b>	3/8/2007	<b>06-099-0005</b> 814 14 <sup>th</sup> Street	<b>Modesto</b> SCHED: 6-Day POC: 5	<b>CA</b>	3N-B0116 3N-B0117 3N-B0119	Ken Stroud Diane Arnold	Oversight Field Contact	916-445-3745 209-576-6253 209-988-0004 cell	<a href="mailto:kstroud@arb.ca.gov">kstroud@arb.ca.gov</a> <a href="mailto:darnold@arb.ca.gov">darnold@arb.ca.gov</a>
<b>1</b>	3/8/2007	<b>06-107-2002</b> 310 N. Church Street	<b>Visalia</b> SCHED: 6-Day POC: 5	<b>CA</b>	3N-B0151 3N-B0146 3N-B0171	Ken Stroud George Jung	Oversight Field Contact	916-445-3745 559-734-0659 559-288-3379 cell	<a href="mailto:kstroud@arb.ca.gov">kstroud@arb.ca.gov</a> <a href="mailto:gjung@arb.ca.gov">gjung@arb.ca.gov</a>
<b>9</b>	4/26/2007	<b>08-001-0006</b> 7101 Birch Street	<b>Commerce City</b> SCHED: 1-in-3 POC: 5	<b>CO</b>	3N-B0211 3N-B0209 3N-B0165	Pat McGraw Bradley Rink		303-692-3235 303-692-3225	<a href="mailto:Pat.McGraw@state.co.us">Pat.McGraw@state.co.us</a> <a href="mailto:Bradley.rink@state.co.us">Bradley.rink@state.co.us</a>
<b>2</b>	3/30/2007	<b>10-003-2004</b> MLK Blvd. & Justison Street	<b>Wilmington</b> SCHED: 6-Day POC: 5	<b>DE</b>	3N-B0217 3N-B0128 3N-B0150	Joe Martini Ted Allen	Oversight Oversight	302-323-4542 302-324-2028	<a href="mailto:joseph.martini@state.de.us">joseph.martini@state.de.us</a> <a href="mailto:ted.allen@state.de.us">ted.allen@state.de.us</a>
<b>2</b>	3/8/2007	<b>11-001-0043</b> Station 43 PAMS, Open Field SE end of McMillian Reservoir	<b>Near Washington</b> SCHED: 3-Day POC: 5	<b>DC</b>	3N-B0136 3N-B0167 3N-B0204	Winston Thaung	Oversight	202-535-2987 202-369-3594 cell	<a href="mailto:winston.thaung@dc.gov">winston.thaung@dc.gov</a>
<b>7</b>	4/12/2007	<b>13-021-0007</b> Allied Chemical 600 Guy Paine Road	<b>Macon</b> SCHED: 6-Day POC: 5	<b>GA</b>	3N-B0184 3N-B0203 3N-B0225	Greg Noah Susan Zimmer-Dauphinee Victor Barr	Oversight Field Contact	706-355-8635 404-363-7004 404-362-4862	<a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a> <a href="mailto:Susan_Zimmer-Dauphinee@dnr.state.ga.us">Susan_Zimmer-Dauphinee@dnr.state.ga.us</a>
<b>7</b>	4/11/2007	<b>13-215-0011</b> Cusseta Road	<b>Columbus</b> SCHED: 6-Day POC: 5	<b>GA</b>	3N-B0166 3N-B0239 3N-B0246	Greg Noah Susan Zimmer-Dauphinee Victor Barr	Oversight Field Contact	706-355-8635 404-363-7004 404-362-4862	<a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a> <a href="mailto:Susan_Zimmer-Dauphinee@dnr.state.ga.us">Susan_Zimmer-Dauphinee@dnr.state.ga.us</a>

**STN Carbon Master Contact List**  
**As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/Sampler/Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
<b>8</b>	4/20/2007	<b>16-001-0010</b>  520 S. Eagle Rd	<b>Near Boise, Meridian</b>  SCHED: 3-Day POC: 5	<b>ID</b>	3N-B0205 3N-B0272 3N-B0189	Bruce Louks Rebecca Goehring Keith Rose	Field Contact Field Contact Oversight	208-373-0294 208-863-3563 cell 206-553-1949	<a href="mailto:bruce.louks@deq.idaho.gov">bruce.louks@deq.idaho.gov</a> <a href="mailto:Rebecca.Goehring@deq.idaho.gov">Rebecca.Goehring@deq.idaho.gov</a> <a href="mailto:rose.keith@epa.gov">rose.keith@epa.gov</a>
<b>3</b>	3/21/2007	<b>17-031-0057</b>  Springfield Pump Station 1745 N. Springfield	<b>Chicago, Springfield</b>  SCHED: 6-Day POC: 5	<b>IL</b>	3N-B0175 3N-B0197 3N-B0156	Bob Swinford Terry Sweitzer Jeff Flick	Field Manager Oversight Field Operator	217-782-9323 217-782-7438 847-366-8769	<a href="mailto:Bob.swinford@illinois.gov">Bob.swinford@illinois.gov</a> <a href="mailto:EPA2204@epa.state.il.us">EPA2204@epa.state.il.us</a>
<b>3</b>	3/21/2007	<b>17-031-0076</b>  Com Ed Maint. Bldg. 7801 Lawndale	<b>Chicago, ComEd</b>  SCHED: 3-Day POC: 5	<b>IL</b>	3N-B0241 3N-B0137 3N-B0162	Bob Swinford Terry Sweitzer Jeff Flick	Field Manager Oversight Field Operator	217-782-9323 217-782-7438 847-366-8769	<a href="mailto:Bob.swinford@illinois.gov">Bob.swinford@illinois.gov</a> <a href="mailto:EPA2204@epa.state.il.us">EPA2204@epa.state.il.us</a>
<b>3</b>	3/20/2007	<b>17-031-4201</b>  Northbrook Water Plant 750 Dundee Rd.	<b>Northbrook</b>  SCHED: 6-Day POC: 5	<b>IL</b>	3N-B0232 3N-B0194 3N-B0135	Bob Swinford Terry Sweitzer Jeff Flick	Field Manager Oversight Field Operator	217-782-9323 217-782-7438 847-366-8769	<a href="mailto:Bob.swinford@illinois.gov">Bob.swinford@illinois.gov</a> <a href="mailto:Terry.sweitzer@illinois.gov">Terry.sweitzer@illinois.gov</a>
<b>3</b>	3/20/2007	<b>17-043-4002</b>  City Hall 400 S. Eagle St.	<b>Naperville</b>  SCHED: 6-Day POC: 5	<b>IL</b>	3N-B0139 3N-B0173 3N-B0159	Bob Swinford Terry Sweitzer Jeff Flick	Field Manager Oversight Field Operator	217-782-9323 217-782-7438 847-366-8769	<a href="mailto:Bob.swinford@illinois.gov">Bob.swinford@illinois.gov</a> <a href="mailto:Terry.sweitzer@illinois.gov">Terry.sweitzer@illinois.gov</a>
<b>5</b>	4/16/2007	<b>17-119-2009</b>  SIU Dental Clinic 1700 Annex St.	<b>Alton</b>  SCHED: 1 in 6 POC: 5	<b>IL</b>	3N-B0262 3N-B0248 3N-B0249	Bob Swinford Terry Sweitzer Jim Henry	Field Contact Oversight Field Contact	217-782-9323 217-782-7438 618-920-5571 cell 618-346-5120	<a href="mailto:bob.swinford@illinois.gov">bob.swinford@illinois.gov</a> <a href="mailto:epa2204@epa.state.il.us">epa2204@epa.state.il.us</a> <a href="mailto:Jim.Henry@Illinois.gov">Jim.Henry@Illinois.gov</a>
<b>3</b>	3/22/2007	<b>18-089-0022</b>  IITRI Bunker 201 Mississippi Street	<b>Gary</b>  SCHED: 6-Day POC: 5	<b>IN</b>	3N-B0223 3N-B0158 3N-B0183	John Wicker Steve Lengerich	Field Contact Oversight	317-308-3257 317-308-3264	<a href="mailto:jwicker@idem.in.gov">jwicker@idem.in.gov</a> <a href="mailto:slengeri@idem.in.gov">slengeri@idem.in.gov</a> <a href="mailto:slengeri@idem.in.gov">slengeri@idem.in.gov</a>
<b>3</b>	3/22/2007	<b>18-089-2004</b>  Purdue Univ. Calumet-Powers Bldg. 6937 Woodmar Avenue	<b>Hammond</b>  SCHED: 6-Day POC: 5	<b>IN</b>	3N-B0199 3N-B0200 3N-B0141	John Wicker Steve Lengerich	Field Contact Oversight	317-308-3257 317-308-3264	<a href="mailto:jwicker@idem.in.gov">jwicker@idem.in.gov</a> <a href="mailto:slengeri@idem.in.gov">slengeri@idem.in.gov</a>

**STN Carbon Master Contact List  
As of June 18, 2007**

Install Group	Install Date	SiteID/Site Location	City Name/RTI Name, EPA Schedule, & POC	State	Controller/Sampler/Pump Serial #s	Contact Name(s)	Contact Title(s)	Contact Phone(s)	Contact E-mail(s)
5	4/18/2007	18-097-0078 Parking Lot, next to Police Station  3120 E. 30th	Indianapolis, Washington Park  SCHED: 3-Day  POC: 5	IN	3N-B0226	Steve Lengerich	Oversight	317-308-3264	<a href="mailto:slengeri@idem.in.gov">slengeri@idem.in.gov</a>
					3N-B0284	John Wicker	Field Contact	317-308-3257	<a href="mailto:jwicker@idem.in.gov">jwicker@idem.in.gov</a>
					3N-B0258	David Moore		317-327-2276 317-223-8727 cell	
						Aaron Childs	Field Contact	317-327-2359	
5	4/19/2007	21-111-0043  37th & Southern Ave.	Louisville  SCHED: 6-Day POC: 5	KY	3N-B0124	Cynthia Lee	Field Contact	502-574-7217	<a href="mailto:cynthia.lee@louisvilleky.gov">cynthia.lee@louisvilleky.gov</a>
					3N-B0251	Greg Noah	Oversight	706-355-8635	<a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a>
					3N-B0289	Arthur Chang	Field Contact	502-574-7278	<a href="mailto:arthur.chang@louisvilleky.gov">arthur.chang@louisvilleky.gov</a>
						Tina Oakes	Field Contact	502-574-7294	<a href="mailto:Tina.Oakes@louisvilleky.gov">Tina.Oakes@louisvilleky.gov</a>
						Ron Jacobs		502-574-8032	
						Terry Canby		502-574-7250	
2	3/9/2007	24-005-3001 Woodward & Franklin Roads	Essex  SCHED: 3-Day POC:5	MD	3N-B0190	Ryan Auvil	Field Contact	410-537-3961	<a href="mailto:rauvil@mde.state.md.us">rauvil@mde.state.md.us</a>
					3N-B0176			410-971-6968 cell	<a href="mailto:dkrask@mde.state.md.us">dkrask@mde.state.md.us</a>
					3N-B0210	David Krask	Oversight	410-537-3756	
4	4/23/2007	26-161-0008 555 Towner St.	Ypsilanti  SCHED: 6-Day POC: 5	MI	3N-B0253	Dan Ling	Field Contact	517-335-6679	<a href="mailto:lingd@michigan.gov">lingd@michigan.gov</a>
					3N-B0227	Maryann Heindorf	Oversight	517-373-2151	<a href="mailto:heindorm@michigan.gov">heindorm@michigan.gov</a>
					3N-B0213	Craig Fitzner	Oversight	517-373-7044	<a href="mailto:fitzner@michigan.gov">fitzner@michigan.gov</a>
4	4/23/2007	26-163-0033 Public School Property 2842 Wyoming	Dearborn  SCHED: 6-Day POC: 5	MI	3N-B0259	Dan Ling	Field Contact	517-335-6679	<a href="mailto:lingd@michigan.gov">lingd@michigan.gov</a>
					3N-B0242	Maryann Heindorf	Oversight	517-373-2151	<a href="mailto:heindorm@michigan.gov">heindorm@michigan.gov</a>
					3N-B0267	Craig Fitzner	Oversight	517-373-7044	<a href="mailto:fitzner@michigan.gov">fitzner@michigan.gov</a>
3	3/19/2007	27-053-0963  Anderson School, Phillips Neighborhood 2727 10th Street	Minneapolis, Philips (2)  SCHED: 3-Day POC: 5	MN	3N-B0256	Don Bock	Field	651-296-7329 office	<a href="mailto:donald.bock@pca.state.mn.us">donald.bock@pca.state.mn.us</a>
					3N-B0140			651-260-2317 cell	<a href="mailto:rick.strassman@pca.state.mn.us">rick.strassman@pca.state.mn.us</a>
					3N-B0195	Rick Strassman	Oversight	651-296-7754	
					3N-B0163				
					3N-B0170				
					3N-B0147				
5	5/3/2007	29-186-0005  east of Hwy D, outside of Bonne Terre	Bonne Terre  SCHED: 1 in 3 POC: 5	MO	3N-B0202	Celeste Koon	Oversight	573-526-3363	<a href="mailto:celeste.koon@dnr.mo.gov">celeste.koon@dnr.mo.gov</a>
					3N-B0218				
					3N-B0264				
5	4/17/2007	29-510-0085  Blair Street	St. Louis  SCHED: 1 in 3 POC: 6	MO	3N-B0268	Bob Berri	Field Contact	314-641-8615	<a href="mailto:berrib@stlouiscity.com">berrib@stlouiscity.com</a>
					3N-B0266	Tom Wiese	Back-up	314-613-7300	<a href="mailto:wieset@stlouiscity.com">wieset@stlouiscity.com</a>
					3N-B0273				

**STN Carbon Master Contact List  
As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/Sampler/Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
<b>8</b>	5/2/2007	<b>30-063-0031</b> Health Dept. 301 West Alder	<b>Missoula</b> SCHED: 3-Day POC: 5	<b>MT</b>	3N-B0244 3N-B0275 3N-B0252	Eric Englebert		406-258-3642	<a href="mailto:englebete@ho.missoula.mt.us">englebete@ho.missoula.mt.us</a>
<b>2</b>	3/29/2007	<b>34-007-0003</b> Trailer Camden Lab Copewood & E. Davis St.	<b>Camden</b> SCHED: 3-Day POC: 5	<b>NJ</b>	3N-B0214 3N-B0188 3N-B0186	Jim Oxley Tom McKenna	Field Contact Back-up	609-633-1468 office 609-462-1562 cell 609-530-4012	<a href="mailto:Jim.Oxley@DEP.State.NJ.US">Jim.Oxley@DEP.State.NJ.US</a> <a href="mailto:Tom.McKenna@dep.state.nj.us">Tom.McKenna@dep.state.nj.us</a>
<b>2</b>	3/26/2007	<b>36-005-0110</b> 681 Kelly Street	<b>Bronx</b> SCHED: 1 in 3 POC: 5	<b>NY</b>	3N-B0172 3N-B0164 3N-B0198	Dirk Felton Dave Wheeler	Oversight Field	518-402-8502 718-482-6333	<a href="mailto:hdfelton@gw.dec.state.ny.us">hdfelton@gw.dec.state.ny.us</a>
<b>2</b>	3/26/2007	<b>36-061-0134</b> 40 Division Street	<b>Manhattan, New York</b> SCHED: 1 in 3 POC: 5	<b>NY</b>	3N-B0220 3N-B0134 3N-B0192	Dirk Felton Dave Wheeler	Oversight Field	518-402-8502 718-482-6333	<a href="mailto:hdfelton@gw.dec.state.ny.us">hdfelton@gw.dec.state.ny.us</a>
<b>6</b>	2/28/2007	<b>37-067-0022</b> 1300 Block Hattie Avenue	<b>Winston-Salem</b> SCHED: 6-Day POC: 5	<b>NC</b>	3N-B0127 3N-B0191 3N-B0207	Pat Reagan	Oversight	336-703-2447 CP 336-703-2453	<a href="mailto:reaganpa@forsyth.cc">reaganpa@forsyth.cc</a>
<b>4</b>	4/25/2007	<b>39-035-0038</b> 2547 St. Kikhon	<b>Cleveland, St. Theo</b> SCHED: 6-Day POC: 6	<b>OH</b>	3N-B0250 3N-B0257 3N-B0144	George Young	Field Contact	216-664-7444	<a href="mailto:gyoung@city.cleveland.oh.us">gyoung@city.cleveland.oh.us</a>
<b>4</b>	4/26/2007	<b>39-049-0081</b> 5750 Maple Canyon	<b>Columbus, Maple Canyon</b> SCHED: 6-Day POC: 6	<b>OH</b>	3N-B0169 3N-B0281 3N-B0234	Rob Twynham	Field Contact	614-561-5620 cell	<a href="mailto:rtwynham@columbus.rr.com">rtwynham@columbus.rr.com</a>
<b>5</b>	4/20/2007	<b>39-061-0040</b> HC-Does Office 250 William Howard Taft	<b>Cincinnati, Taft</b> SCHED: 6-Day POC: 5	<b>OH</b>	3N-B0271 3N-B0182 3N-B0279	Ana Kelley Ofori Bandoh Jim Hopkins	Oversight Field Contact Field Contact	513-946-7725 513-946-7720 513-946-7750	<a href="mailto:anna.kelley@hamilton-co.org">anna.kelley@hamilton-co.org</a> <a href="mailto:Ofori.bandoh@hamilton-co.org">Ofori.bandoh@hamilton-co.org</a> <a href="mailto:Jim.Hopkins@hamilton-co.org">Jim.Hopkins@hamilton-co.org</a>

**STN Carbon Master Contact List  
As of June 18, 2007**

Install Group	Install Date	SiteID/Site Location	City Name/RTI Name, EPA Schedule, & POC	State	Controller/Sampler/Pump Serial #s	Contact Name(s)	Contact Title(s)	Contact Phone(s)	Contact E-mail(s)
6	4/16/2007	39-081-0017 618 Logan St.	Steubenville SCHED: 6-Day POC: 5	OH	3N-B0245 3N-B0130 3N-B0255	Mike Murphy Randy Hock Gary Engler	Field Contact	740 385 8501	<a href="mailto:Mike.murphy@epa.state.oh.us">Mike.murphy@epa.state.oh.us</a> <a href="mailto:randy.hock@epa.state.oh.us">randy.hock@epa.state.oh.us</a> <a href="mailto:gary.engler@epa.state.oh.us">gary.engler@epa.state.oh.us</a>
4	4/24/2007	39-093-3002 2180 Lake Breeze	Sheffield, Lorain SCHED: 6-Day POC: 5	OH	3N-B0178 3N-B0287 3N-B0231	Randy Hock Gary Engler Richard Smith	Oversight Data Contact Field Contact	614-644-3619 614-644-3623? 330-963-1229 330-608-7670 cell	<a href="mailto:randy.hock@epa.state.oh.us">randy.hock@epa.state.oh.us</a> <a href="mailto:gary.engler@epa.state.oh.us">gary.engler@epa.state.oh.us</a> <a href="mailto:ricksmith@epa.state.oh.us">ricksmith@epa.state.oh.us</a>
4	4/26/2007	39-153-0023 Roof of Head Start Center 660 W. Exchange St.	Akron, 5 Points SCHED: 6-Day POC: 5	OH	3N-B0187 3N-B0254 3N-B0216	Alan Richardson	Field Contact	330-375-2480 x3950	<a href="mailto:richaal@ci.akron.oh.us">richaal@ci.akron.oh.us</a>
8	5/1/2007	41-051-0080 5824 SE Lafayette	Portland SCHED: 3-Day POC: 6	OR	3N-B0238 3N-B0131 3N-B0261	Christopher McGarry Keith Rose	Field Contact Oversight	503-229-5983 x235 503-708-8744 cell 206-553-1949	<a href="mailto:Mcgarry.christopher@deq.state.or.us">Mcgarry.christopher@deq.state.or.us</a> <a href="mailto:rose.keith@epa.gov">rose.keith@epa.gov</a>
6	4/17/2007	42-003-0064 2743 Washington Blvd. Mckeesport; S. Allegheny HS	Liberty SCHED: 6-Day POC: 6	PA	3N-B0133 3N-B0179 3N-B0290	Darrell Stern		412-578-8143	<a href="mailto:dstern@achd.net">dstern@achd.net</a>
2	3/27/2007	42-101-0004 AMS Lab 1501 E. Lycoming St.	Philadelphia SCHED: 3-Day POC: 7	PA	3N-B0157 3N-B0161 3N-B0168	Loretta Hyden	Oversight	215-685-1040	<a href="mailto:loretta.hyden@phila.gov">loretta.hyden@phila.gov</a>
2	4/26/2007	42-101-0136 24th & W. Ritner St.	Philadelphia SCHED: 6-Day POC: 5	PA	3N-B0283 3N-B0230 3N-B0243	Loretta Hyden	Oversight	215-685-1040	<a href="mailto:loretta.hyden@phila.gov">loretta.hyden@phila.gov</a>
6	4/18/2007	42-125-5001 Hillman State Park, Kings Creek Road	East of Pittsburgh, Florence SCHED: 6-Day POC: 5	PA	3N-B0265 3N-B0221 3N-B0237	George Mentzer Rob Valentich		717-783-9477 724-544-8232 cell	<a href="mailto:gmentzer@state.pa.us">gmentzer@state.pa.us</a> <a href="mailto:rvalentich@state.pa.us">rvalentich@state.pa.us</a>

**STN Carbon Master Contact List  
As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/Sampler/Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
<b>6</b>	4/17/2007	<b>42-129-0008</b> Donohoe Rd., Penn DOT Maint. Dist., Bldg., Trailer	<b>Greensburg</b> SCHED: 6-Day POC: 5	<b>PA</b>	3N-B0280 3N-B0269 3N-B0222	George Mentzer Rob Valentich		717-783-9477 724-544-8232 cell	<a href="mailto:gmentzer@state.pa.us">gmentzer@state.pa.us</a> <a href="mailto:rvalentich@state.pa.us">rvalentich@state.pa.us</a>
<b>7</b>	4/13/2007	<b>47-093-1020</b> 4624 Mildred Drive	<b>Knoxville</b> SCHED: 6-Day POC: 5	<b>TN</b>	3N-B0193 3N-B0224 3N-B0285	Kelly Vaughn Greg Noah Amber Talgo	Field Contact Oversight Field Contact	865-215-5944 706-355-8635 865-215-5942	<a href="mailto:kwvaughn@aqm.co.knox.tn.us">kwvaughn@aqm.co.knox.tn.us</a> <a href="mailto:noah.greg@epa.gov">noah.greg@epa.gov</a>
<b>9</b>	4/4/2007	<b>49-011-0004</b> 171 West 1370 North	<b>Bountiful</b> SCHED: 6-Day POC: 5	<b>UT</b>	3N-B0235 3N-B0215 3N-B0180	Robert (Neal) Olson		801-887-0760	<a href="mailto:rolson@utah.gov">rolson@utah.gov</a>
<b>9</b>	3/21/2007	<b>49-035-3006</b> 1675 South 600 East	<b>Salt Lake City</b> SCHED: 3-Day POC: 5	<b>UT</b>	3N-B0229 3N-B0212 3N-B0153	Robert (Neal) Olson		801-887-0760	<a href="mailto:rolson@utah.gov">rolson@utah.gov</a>
<b>9</b>	3/20/2007	<b>49-049-4001</b> 30 North Main Street	<b>Lindon</b> SCHED: 6-Day POC: 5	<b>UT</b>	3N-B0247 3N-B0206 3N-B0174	Robert (Neal) Olson		801-887-0760	<a href="mailto:rolson@utah.gov">rolson@utah.gov</a>
<b>8</b>	5/1/2007	<b>53-033-0057</b> 4401 E Marginal Way S. Seattle, WA	<b>Duwamish</b> SCHED: 6-Day POC: 6	<b>WA</b>	3N-B0181 3N-B0125 3N-B0282	John Williamson Keith Rose	Field Contact Oversight	425-649-7118 206-553-1949	<a href="mailto:jwil461@ecy.wa.gov">jwil461@ecy.wa.gov</a> <a href="mailto:rose.keith@epa.gov">rose.keith@epa.gov</a>
<b>8</b>	5/1/2007	<b>53-033-0080</b> Beacon Hill Reservoir 4103 Beacon Hills Seattle, WA	<b>Beacon Hill</b> SCHED: 3-Day POC: 6	<b>WA</b>	3N-B0286 3N-B0233 3N-B0276	John Williamson Keith Rose	Field Contact Oversight	425-649-7118 206-553-1949	<a href="mailto:jwil461@ecy.wa.gov">jwil461@ecy.wa.gov</a> <a href="mailto:rose.keith@epa.gov">rose.keith@epa.gov</a>
<b>8</b>	5/2/2007	<b>53-053-0029</b> S. Tacoma Community Ctr 7802 South L Street	<b>Tacoma</b> SCHED: 6-Day POC: 5	<b>WA</b>	3N-B0208 3N-B0185 3N-B0201	John Williamson Keith Rose Anthony Leo	Field Contact Oversight Field Contact	425-649-7118 206-553-1949 425-941-1655 cell 425-649-7119	<a href="mailto:jwil461@ecy.wa.gov">jwil461@ecy.wa.gov</a> <a href="mailto:rose.keith@epa.gov">rose.keith@epa.gov</a>

**STN Carbon Master Contact List  
As of June 18, 2007**

<b>Install Group</b>	<b>Install Date</b>	<b>SiteID/Site Location</b>	<b>City Name/RTI Name, EPA Schedule, &amp; POC</b>	<b>State</b>	<b>Controller/Sampler/Pump Serial #s</b>	<b>Contact Name(s)</b>	<b>Contact Title(s)</b>	<b>Contact Phone(s)</b>	<b>Contact E-mail(s)</b>
<b>6</b>	4/19/2007	<b>54-039-0011</b>  Guthrie Ag. Center 4900 Brenda Ln, Bldg 14	<b>Charleston</b>  SCHED: 3-Day POC: 5	<b>WV</b>	3N-B0274 3N-B0278 3N-B0240	Tim Carroll  Joel Maddy Jason Thomas	Oversight  Oversight Field Contact	304-926-0499 x 1248 304-926-3634 304-926-0499 x 1249 304-558-4323 304-389-7531 cell	<a href="mailto:tcarroll@wvdep.org">tcarroll@wvdep.org</a>  <a href="mailto:jmaddy@wvdep.org">jmaddy@wvdep.org</a> <a href="mailto:jthomas@wvdep.org">jthomas@wvdep.org</a>
<b>6</b>	4/19/2007	<b>54-039-1005</b>  Public Library 312 4th Ave.	<b>Charleston</b>  SCHED: 6-Day POC: 5	<b>WV</b>	3N-B0196 3N-B0236 3N-B0270	Tim Carroll  Joel Maddy Jason Thomas	Oversight  Oversight Field Contact	304-926-0499 x 1248 304-926-3634 304-926-0499 x 1249 304-558-4323 304-389-7531 cell	<a href="mailto:tcarroll@wvdep.org">tcarroll@wvdep.org</a>  <a href="mailto:jmaddy@wvdep.org">jmaddy@wvdep.org</a> <a href="mailto:jthomas@wvdep.org">jthomas@wvdep.org</a>