

## **RICE NESHAP Summary of Requirements<sup>1</sup>**

Spark Ignition 4-Stroke Rich Burn  $\leq$ 500 HP

New & Reconstructed Stationary Engine

Located at Major Source of HAP, constructed on or after June 12, 2006

**Requirements:** Engines are subject to 40 CFR part 60 [subpart JJJJ](#) (Standards of Performance for Stationary Spark Ignition Internal Combustion Engines).

---

<sup>1</sup> Disclaimer: The content provided in this software tool is intended solely as assistance for potential reporters to aid in assessing requirements for compliance under the reciprocating internal combustion engines (RICE) National Emissions Standards for Hazardous Air Pollutants, 40 CFR Part 63 Subpart ZZZZ. Any variation between the rule and the information provided in this tool is unintentional, and, in the case of such variations, the requirements of the rule govern. Use of this tool does not constitute an assessment by EPA of the applicability of the rule to any particular facility. In any particular case, EPA will make its assessment by applying the law and regulations to the specific facts of the case.