STAPPA/ALAPCO
2.5

Logged 5/27/86 7 9
(#02)

Interpoll Inc.
2982 North Cleveland Avenue
St. Paul, Minnesota 55113

Telephone (612) 636-6866
Telex 297095

Note: This material is related to a section in *AP42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources.* AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.

RESULTS OF THE OCTOBER 24, 1980 PARTICULATE EMISSION COMPLIANCE TEST ON THE NO. 4 SLUDGE INCINERATOR WET SCRUBBER STACK AT THE MWCC ST. PAUL WASTEWATER TREATMENT PLANT IN ST. PAUL, MINNESOTA

Submitted to:

THE METROPOLITAN WASTE CONTROL COMMISSION
2400 Childs Road
St. Paul, Minnesota 55106

Attention: Wilbur Blain
Plant Manager

Approved by:

Perry Lounes

Perry Lounes, Ph.D.
Director of Environmental
Measurements Section

Report Number 0-871
November 3, 1980
bjr

TABLE OF CONTENTS

	SYMBOLS AND ABBREVIATIONS	iii
1	INTRODUCTION	1
2	SUMMARY AND DISCUSSION	3
3	RESULTS	5
	3.1 Results of Gas Analyses	
	3.1.1 Incinerator Outlet (Scrubber Inlet)	7
	3.1.2 Scrubber Stack (Scrubber Outlet)	8
	3.2 Results of Particulate Loading Determinations	9
	3.3 Results of Opacity Observations	

APPENDICES:

A - Results of Preliminary Measurements and Incinerator Outlet Flow Determinations

B - Location of Test Ports and Traverse Points

C - Method 5 Field Data Sheets

D - Method 9 Field Data Sheets

E - Laboratory Data Sheets

F - Operational Data for the Incinerator and Wet Scrubber

G - Procedures

H - Calculation Equations

I - Adjustment of Particulate Concentrations to 12% CO_2 Calculations

J - Sampling Train Calibration Data

SYMBOLS AND ABBREVIATIONS

ACFM	actual cubic feet per minute
DSCFM	standard cubic foot of dry gas per minute
DEG-F	degrees Fahrenheit
FT/SEC	feet per second
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g	gram
HRS	hours
IN.	inches
IN. H.G.	inches of mercury
IN. W.C.	inches of water
LB	pound
LB/HR	pounds per hour
LB/10^6BTU	million British Thermal Units heat input
microns (μm)	micrometer
MIN	minutes
SQ. FT.	square feet
v/v	percent by volume
mg/DSCM	milligrams per dry standard cubic meter
LB/DSCF	pounds per dry standard cubic foot
MWH	megawatt hours
ohm-cm	ohm-centimeter
HP	horsepower
PSI	pounds per square inch
w/w	percent by weight

Standard conditions are defined as 68 ^{o}F (20 ^{o}C) and 29.92 in. of mercury pressure.

1 INTRODUCTION

On October 24, 1980, Interpoll Inc. personnel conducted particulate emission compliance tests on the No. 1 Sludge Incinerator wet scrubber stack at the Metropolitan Waste Control Commission (MWCC) Wastewater Treatment Plant located in St. Paul, Minnesota. The objective of this test was to establish compliance status with respect to Minnesota Air Pollution Regulation APC-7 which restricts particulate emissions from incinerators of this type and size to 0.1 GR/DSCF (adjusted to 12% CO_2). On-site testing was performed by a four-man team under the direction of E. Trowbridge. Coordination between incinerator and wet scrubber operation and testing activities was provided by N. Shamat of the MWCC. The tests were witnessed by Marty Osborne of the Minnesota Pollution Control Agency (MPCA).

The No. 1 Sludge Incinerator is a Nicols Herreshoff eight hearth incinerator which was installed about 1938. This incinerator fires oil as a supplementary fuel. The original rated capacity of this incinerator was 8 WET TONS/HR. This rating was based on combustion of sludge with a higher volatile content than is presently fired and thus the current capacity is substantially less. Particulate emissions from this incinerator are controlled by a Heil impingement wet scrubber which was installed in the Spring of 1979. Cleaned flue gas is exhausted to the atmosphere by a radial steel stack which has an internal diameter of three feet.

Particulate evaluations were performed in accordance with EPA Methods 1-5, CFR Title 40, Part 60, Appendix A (Revised July 1, 1979) and APC-7. A preliminary determination of the gas linear velocity profile was made in the stack before the first particulate run to allow selection of the appropriate nozzle diameter required for isokinetic sample withdrawal. An Interpoll sampling train which meets or exceeds specifications in the above-cited reference is used to extract particulate samples by means of a heated glass-lined probe.

Testing at the scrubber outlet was conducted from two test ports oriented at 90° on the stack. These ports are 19 feet downstream of the I.D. fan inlet and three feet upstream of the stack outlet. A 36-point traverse was used to extract representative particulate samples. Each traverse point was sampled two minutes to give a total sampling time of 72 minutes per run. Visible emissions were also read by a currently-certified observer during the particulate determinations. Integrated flue gas samples were also collected at the inlet to the scrubber (incinerator outlet) simultaneously to those collected at the stack test location during each of the particulate runs so that the particulate concentration could be adjusted to 12% CO_2 as prescribed in APC-7. Two volumetric flow rate determinations and one moisture content determination were also performed at the inlet to the scrubber during each particulate run to provide additional data required to correct particulate concentrations to 12% CO_2.

The important results of the test are summarized in Section 2. Detailed results are presented in Section 3. Results of preliminary measurements, field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The important results of the particulate emission compliance test on the No. 1 Incinerator wet scrubber stack are summarized in Table 1. As will be noted, the particulate concentration adjusted to 12% CO_2 ranged from .067 to .085 GR/DSCF**. These concentrations were measured when the sludge burning rate ranged from 6.5 to 6.9 DRY TONS/HR. The corresponding supplemental fuel burning rate (oil) ranged from 34.5 to 52.6 GPH.

No difficulties were encountered in the field or in the laboratory evaluation of the flue gas and particulate samples. On the basis of this fact, and a complete review of the entire data and results it is our opinion that the particulate concentrations and emission rates reported herein are accurate and closely reflect the actual values which existed at the time the test was conducted.

Table 1. Summary of the Results of the October 24, 1980 Particulate Emission Compliance Test on the No. 4 Sludge Incinerator Wet Scrubber Stack at the Metropolitan Waste Control Commission St. Paul Wastewater Treatment Plant.

ITEM	PRELIMINARY	RUN 1	RUN 2	RUN 3
Date of test	10-24-80	10-24-80	10-24-80	10-24-80
Time of test (HRS)	0900	0940-1057	1235-1349	1535-1650
Sludge burning rate				
DRY (TONS/HR)		6.9	6.5	6.7
WET (TONS/HR)		2.0	1.9	1.9
Oil burning rate (GPH)		34.5	41.7	52.6
Volumetric flow				
ACTUAL (ACFM)	17700	17900	16800	17100
STANDARD (DSCFM)	16200	16400	15100	15300
Gas temperature (DEG-F)	82	83	89	89
Gas moisture content (% v/v)	4.18	3.93	4.09	4.54
Gas composition (% v/v, dry)				
INCINERATOR OUTLET				
carbon dioxide		6.21	7.67	8.54
oxygen		13.31	11.54	10.65
nitrogen		80.48	80.79	80.81
STACK				
carbon dioxide		5.11	5.92	6.31
oxygen		14.71	14.34	12.61
nitrogen		80.18	79.74	81.08
Isokinetic variation (%)		98.5	98.5	98.8
Particulate emission rate (LB/HR)		2.83	3.44	4.17
Particulate concentration				
ACTUAL (GR/ACF)		.019	.024	.029
STANDARD (GR/DSCF)		.020	.027	.032
(GR/DSCF @ 12% CO_2)*		.058	.078	.075
(GR/DSCF @ 12% CO_2)**		.067	.075	.085

*EPA-Alternate Method (Excess Air) of Adjusting to 12% CO_2 (See Appendix I)
**MPCA Method of Adjusting to 12% CO_2 (See Appendix I)

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition results are presented first, followed by the computer printout of particulate emission data and results of visible emission determinations. Preliminary measurements including traverse point description are given in Appendix A and B.

The results have been calculated on a DEC PDP-11 Computer using standard Fortran programs. EPA-published equations have been used as the basis of the calculation techniques in these programs. It should be noted in interpreting these results that the particulate emission rates have been calculated by both the "concentration x flow" and the "ratio of areas" methods and the average reported. The average is the best estimate of the true value, since the bias introduced by an isokinetic sampling is approximately equal but of opposite sign in the two calculation techniques and thus cancels in the average.

3.1 Results of Orsat and Moisture Analyses

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

3.1.1 TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF ORSAT & MOISTURE ANALYSES -- METHOD 3 & 4 (% V/V)

	RUN 1	RUN 2	RUN 3
DATE OF RUN	10/24/80	10/24/80	10/24/80
DRY BASIS (ORSAT)			
CARBON DIOXIDE	6.21	7.67	8.54
OXYGEN	13.31	11.54	10.65
CARBON MONOXIDE	0.00	0.00	0.00
NITROGEN	80.48	80.79	80.81
WET BASIS (ORSAT)			
CARBON DIOXIDE	5.22	6.04	6.77
OXYGEN	11.19	9.09	8.44
CARBON MONOXIDE	0.00	0.00	0.00
NITROGEN	67.64	63.63	64.02
MOISTURE CONTENT	15.96	21.24	20.77
DRY MOLECULAR WEIGHT	29.53	29.69	29.79
WET MOLECULAR WEIGHT	27.69	27.21	27.34
SPECIFIC GRAVITY (RELATIVE TO AIR)	0.9564	0.9398	0.9445
FO	1.22	1.22	1.20

JOB: METROPOLITIAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

3.1.2 TEST NO. 1 NO. 1 INCINERATOR SCRUBBER STACK

RESULTS OF ORSAT & MOISTURE ANALYSES -- METHOD 3 & 4 (% V/V)

	RUN 1	RUN 2	RUN 3
DATE OF RUN	10/24/80	10/24/80	10/24/80
DRY BASIS (ORSAT)			
CARBON DIOXIDE	5.11	5.92	6.31
OXYGEN	14.71	14.34	12.61
CARBON MONOXIDE	0.00	0.00	0.00
NITROGEN	80.18	79.74	81.08
WET BASIS (ORSAT)			
CARBON DIOXIDE	4.91	5.68	6.02
OXYGEN	14.13	13.75	12.04
CARBON MONOXIDE	0.00	0.00	0.00
NITROGEN	77.03	76.48	77.40
MOISTURE CONTENT	3.93	4.09	4.54
DRY MOLECULAR WEIGHT	29.41	29.52	29.51
WET MOLECULAR WEIGHT	28.96	29.05	28.99
SPECIFIC GRAVITY (RELATIVE TO AIR)	1.0003	1.0035	1.0014
VELOCITY WEIGHTED AND TIME-AVERAGED OXYGEN DURING METHOD 5 RUNS	14.63	13.38	12.65

** CONDENSED WATER VAPOR IN GAS STREAM; MOISTURE CONTENT CALCULATED FROM AVERAGE STACK GAS TEMPERATURE ASSUMING SATURATION.

FO 1.21 1.11 1.31

JOB: METROPOLITIAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR SCRUBBER STACK

3.2 RESULTS OF PARTICULATE LOADING DETERMINATIONS -- METHOD 5(BE)

	RUN 1	RUN 2	RUN 3
DATE OF RUN	10/24/80	10/24/80	10/24/80
TIME RUN START/END(HRS)	940/1057	1235/1349	1535/1650
PITOT TUBE COEFFICIENT	0.862	0.862	0.862
WATER IN SAMPLE			
CONDENSATE (ML)	20.0	28.0	38.0
SILICA GEL (GRAMS)	30.0	17.0	13.0
TOTAL PARTICULATE MATERIAL COLLECTED(GRAMS) *	0.0709	0.0861	0.1045
VOLUME THROUGH GAS METER			
AT METER CONDITIONS (CF)	53.45	50.40	51.32
STANDARD CONDITIONS (SCF)	53.85	49.74	50.53
TOTAL SAMPLING TIME (MIN)	72.0	72.0	72.0
NOZZLE DIAMETER (IN)	0.245	0.245	0.245
AVERAGE STACK GAS TEMPERATURE DURING DETERMINATION (DEG-F)	83.	89.	89.
VOLUMETRIC FLOW**			
ACTUAL ..... (ACFM)	17928.	16773.	17085.
DRY STANDARD ... (DSCFM)	16373.	15121.	15332.
ISOKINETIC VARIATION (%)	98.5	98.5	98.8
PARTICLE CONCENTRATION			
ACTUAL ..... (GR/ACF)	0.0186	0.0242	0.0287
DRY STANDARD ... (GR/DSCF)	0.0203	0.0267	0.0319
PARTICLE MASS FLOW (LB/HR)	2.83	3.44	4.17

* DRY CATCH ONLY

** CALCULATED ON THE BASIS OF VELOCITY PRESSURES MEASURED DURING THIS PARTICULATE DETERMINATION.

TEST NO. 2 SOURCE: No. 1 Incinerator Stack

3.3 RESULTS OF OPACITY OBSERVATIONS - EPA METHOD 9

PERCENT OPACITY	OPTICAL DENSITY	RELATIVE FREQUENCY (%)
0	0	25.00
5	.0223	41.00
10	.0458	33.00
15	.0706	1.00
20	.0969	0
25	.1249	0
30	.1549	0
35	.1871	0
40	.2219	0
45	.2596	0
50	.3010	0
55	.3468	0
60	.3979	0
65	.4559	0
70	.5229	0
75	.6021	0
80	.6990	0
85	.8239	0
90	1.000	0
95	1.301	0
100		0
5.50	0.0249	TIME AVERAGE

OBSERVER: N. Christ

CERTIFICATION DATE: 9-9-80

DATE OF OBSERVATION: 10-24-80

TIME OF OBSERVATION: 12:35-1:35

APPENDIX A

RESULTS OF PRELIMINARY MEASUREMENTS AND INCINERATOR OUTLET FLOW DETERMINATIONS

JOB: METROPOLITIAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR SCRUBBER STACK

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	900 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.862
NUMBER OF SAMPLING PORTS	2
TOTAL NUMBER OF POINTS SAMPLED	36
DUCT OR STACK DIAMETER (IN.)	36.000
CROSS SECTIONAL AREA (SQ.FT)	7.07
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	82.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	4.18
AVERAGE LINEAR VELOCITY (FT/SEC)	41.8
(STANDARD DEVIATION, FT/SEC)	5.3
VOLUMETRIC FLOW	
ACTUAL (ACFM)	17731.
DRY STANDARD (DSCFM)	16188.
MASS FLOW OF GAS - WET (LB/HR)	76361.

was 26% '80 in June

JOB: METROPOLITIAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. O-871

TEST NO. 1 NO. 1 INCINERATOR SCRUBBER STACK

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	82	37.2
A/ 2	82	39.5
A/ 3	82	39.5
A/ 4	82	41.6
A/ 5	82	41.6
A/ 6	82	43.3
A/ 7	82	43.3
A/ 8	82	44.1
A/ 9	82	41.6
A/10	82	42.5
A/11	82	43.3
A/12	82	43.3
A/13	82	43.3
A/14	82	41.6
A/15	82	41.6
A/16	82	40.8
A/17	82	39.9
A/18	82	39.1
B/ 1	82	37.2
B/ 2	82	39.5
B/ 3	82	47.5
B/ 4	82	52.7
B/ 5	82	52.7
B/ 6	82	53.3
B/ 7	82	52.7
B/ 8	82	49.3
B/ 9	82	45.6
B/10	82	40.8
B/11	82	38.2
B/12	82	37.2
B/13	82	37.2
B/14	82	36.3
B/15	82	35.3
B/16	82	37.2
B/17	82	33.3
B/18	82	32.2

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	925 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1059.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	15.96
AVERAGE LINEAR VELOCITY (FT/SEC)	25.7
(STANDARD DEVIATION, FT/SEC)	6.1
VOLUMETRIC FLOW	
ACTUAL (ACFM)	37995.
DRY STANDARD (DSCFM)	10859.
MASS FLOW OF GAS - WET (LB/HR)	55757.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1010	18.3
A/ 2	1015	21.9
A/ 3	1019	25.0
A/ 4	1043	26.1
A/ 5	1061	27.2
A/ 6	1073	26.4
A/ 7	1080	21.2
A/ 8	1089	14.2
B/ 1	1040	22.1
B/ 2	1043	26.1
B/ 3	1060	28.1
B/ 4	1065	33.0
B/ 5	1070	32.3
B/ 6	1085	35.4
B/ 7	1089	34.8
B/ 8	1095	18.8
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	1100 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1063.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	15.96
AVERAGE LINEAR VELOCITY (FT/SEC)	27.7
(STANDARD DEVIATION, FT/SEC)	3.2
VOLUMETRIC FLOW	
ACTUAL (ACFM)	40978.
DRY STANDARD (DSCFM)	11680.
MASS FLOW OF GAS - WET (LB/HR)	59972.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1025	24.1
A/ 2	1030	26.0
A/ 3	1030	26.0
A/ 4	1056	28.1
A/ 5	1060	29.8
A/ 6	1075	30.0
A/ 7	1080	28.3
A/ 8	1085	21.3
B/ 1	1040	24.2
B/ 2	1047	28.0
B/ 3	1060	28.1
B/ 4	1063	29.8
B/ 5	1075	31.6
B/ 6	1087	33.3
B/ 7	1093	30.1
B/ 8	1097	24.6
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	1220 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1064.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	21.24
AVERAGE LINEAR VELOCITY (FT/SEC)	25.8
(STANDARD DEVIATION, FT/SEC)	5.1
VOLUMETRIC FLOW	
ACTUAL (ACFM)	38168.
DRY STANDARD (DSCFM)	10186.
MASS FLOW OF GAS - WET (LB/HR)	54841.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1015	18.5
A/ 2	1030	23.3
A/ 3	1043	25.8
A/ 4	1050	26.4
A/ 5	1061	28.4
A/ 6	1073	26.6
A/ 7	1089	22.6
A/ 8	1040	18.6
B/ 1	1047	24.5
B/ 2	1061	25.6
B/ 3	1070	26.6
B/ 4	1073	28.5
B/ 5	1085	31.2
B/ 6	1092	33.6
B/ 7	1098	35.2
B/ 8	1098	17.6
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	1355 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1060.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	21.24
AVERAGE LINEAR VELOCITY (FT/SEC)	25.6
(STANDARD DEVIATION, FT/SEC)	4.9
VOLUMETRIC FLOW	
ACTUAL (ACFM)	37808.
DRY STANDARD (DSCFM)	10115.
MASS FLOW OF GAS - WET (LB/HR)	54458.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1015	17.1
A/ 2	1025	21.0
A/ 3	1037	26.3
A/ 4	1053	26.5
A/ 5	1060	27.5
A/ 6	1079	26.7
A/ 7	1087	22.6
A/ 8	1090	18.9
B/ 1	1020	22.1
B/ 2	1035	24.4
B/ 3	1049	26.4
B/ 4	1065	29.3
B/ 5	1073	31.5
B/ 6	1089	32.8
B/ 7	1090	34.3
B/ 8	1098	21.5
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	1520 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1066.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	20.77
AVERAGE LINEAR VELOCITY (FT/SEC)	25.8
(STANDARD DEVIATION, FT/SEC)	4.3
VOLUMETRIC FLOW	
ACTUAL (ACFM)	38152.
DRY STANDARD (DSCFM)	10229.
MASS FLOW OF GAS - WET (LB/HR)	55022.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1020	19.7
A/ 2	1029	19.8
A/ 3	1035	21.0
A/ 4	1057	26.4
A/ 5	1063	26.5
A/ 6	1076	27.5
A/ 7	1080	23.6
A/ 8	1085	21.4
B/ 1	1045	24.4
B/ 2	1057	26.4
B/ 3	1068	26.5
B/ 4	1078	28.5
B/ 5	1085	29.4
B/ 6	1090	33.5
B/ 7	1092	34.3
B/ 8	1096	23.7
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

RESULTS OF FLOW DETERMINATION -- METHOD 2

TIME AND DATE	1650 HRS, 10/24/80
BAROMETRIC PRESSURE (UNCOMPENSATED IN.HG.)	29.30
PITOT TUBE COEFFICIENT	0.849
NUMBER OF SAMPLING PORTS	3
TOTAL NUMBER OF POINTS SAMPLED	24
DUCT DIMENSIONS (IN.)	71.0X 50.0
CROSS SECTIONAL AREA (SQ.FT)	24.65
DIRECTION OF FLOW	VERTICAL,UP
STATIC PRESSURE (IN.WC.)	-0.32
AVERAGE GAS TEMPERATURE (DEG-F)	1070.
ABSOLUTE GAS PRESSURE (IN.HG.)	29.28
AVERAGE MOISTURE CONTENT (V/V)	20.77
AVERAGE LINEAR VELOCITY (FT/SEC)	24.7
(STANDARD DEVIATION, FT/SEC)	5.7
VOLUMETRIC FLOW	
ACTUAL (ACFM)	36598.
DRY STANDARD (DSCFM)	9788.
MASS FLOW OF GAS - WET (LB/HR)	52647.

JOB: METROPOLITAN WASTE CONTROL COMM.

INTERPOLL REPORT NO. 0-871

TEST NO. 1 NO. 1 INCINERATOR OUTLET

APPENDIX A -- POINT VELOCITY AND TEMPERATURE DATA

PORT/POINT	GAS TEMPERATURE (DEG-F)	LINEAR VELOCITY (FT/SEC)
A/ 1	1030	18.5
A/ 2	1042	21.1
A/ 3	1051	25.4
A/ 4	1067	26.5
A/ 5	1070	26.5
A/ 6	1077	22.5
A/ 7	1085	21.4
A/ 8	1090	16.0
B/ 1	1050	21.1
B/ 2	1060	22.4
B/ 3	1068	26.5
B/ 4	1070	29.3
B/ 5	1080	34.1
B/ 6	1090	32.7
B/ 7	1092	34.3
B/ 8	1096	17.5
C/ 1	****	****
C/ 2	****	****
C/ 3	****	****
C/ 4	****	****
C/ 5	****	****
C/ 6	****	****
C/ 7	****	****
C/ 8	****	****