

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

STAPPA/ALAFCC

'2.5'

logged 4/28/86

#06

15

RECEIVED

OCT 1 1982

AIR QUALITY
PERMITS & OPERATIONS

RECEIVED
S.P.F.O.

SEP 29 1982

AIR QUALITY
SECTION

SOURCE SAMPLING EVALUATION FOR
 ROCKY RIVER WASTEWATER TREATMENT PLANT
 CONCORD, N. C.
PREPARED ESPECIALLY FOR:
 PAUL J. CARDINAL MANAGEMENT COMPANY
 SAN FRANCISCO, CALIFORNIA
 JULY 20, 1982

~~This Report was Reviewed~~

by: _____

Date: _____

and found to be

Satisfactory:

Unsatisfactory:

~~This Report was Reviewed~~

by: Jus

Date: 2/3/83

and found to be


Satisfactory:

Unsatisfactory:

Remarks: None

MOGUL

CONSULTING ENGINEERING SERVICES



SOURCE SAMPLING EVALUATION FOR:

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

PREPARED ESPECIALLY FOR:

PAUL J. CARDINAL MANAGEMENT COMPANY
SAN FRANCISCO, CALIFORNIA

BY

THE MOGUL CORPORATION
CHARLOTTE, NORTH CAROLINA

JULY 20, 1982

TABLE OF CONTENTS

Page	Title
	Narrative
Appendix I	TEST DATA SUMMARY
Appendix II	Analytical Report Sheets
Appendix III	Stack Diagrams and Point Locations
Appendix IV	Analytical Methods/Regulations
Appendix V	Test Equipment and Calibration
Appendix VI	Raw Data

TEST DESCRIPTION

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINATEST DESCRIPTION

On July 20, 1982, personnel from the Professional Services Division of the Mogul Corporation, conducted a source sampling evaluation at the Rocky River Wastewater Treatment facilities in Concord, North Carolina. The purpose of this evaluation, performed at the request of the Paul J. Cardinal Management Company, was to determine the emission levels of particulate emitted from the main exhaust stack. Also included in the program was an analysis of sludge samples composited during the testing period.

A summary of the process tested is as follows: dewatered sludge is conveyed and dropped into a Nichols Herreshoff incinerator. Following incineration, the furnace exhaust travels through a Venturi scrubber and continues into an impingement tray scrubber. An induced draft fan removes the exhaust to the main outlet stack where it is mixed with hot air vented from the furnace and released into the atmosphere.

Sampling took place in the round, twenty-seven (27) inch inner diameter main exhaust stack from the rooftop of the facility. Two (2) sampling ports, three (3) inches in diameter, located ninety (90) degrees to each other at a point 2.96 diameters (80 inches) downstream from the nearest flow obstruction and 2.72 diameters (73.5 inches) from the top of the stack served as actual sampling sites. Particulate concentrations were determined by testing procedures based on the Environmental Protection Agency Method 5. A sampling run

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

of eighty (80) minutes length consisted of a twenty (20) point traverse in each port, sampling for a time of two (2) minutes at each port.

All sampling methods, equipment, and sample analysis confirmed to the specifications set forth in the FEDERAL REGISTER, Volume 42, Number 160, Methods 1 through 5, August, 1977. Sampling equipment was manufactured by the Research Appliance Company (RAC) and Nutech Corporation and is diagrammed in Appendix V of this report.

In addition to the determination of particulate concentration in the outlet stack, the wastewater treatment plant sludge was analyzed for mercury. Sampling was conducted by Rocky River Wastewater Treatment Plant personnel with assistance from the Mogul Corporation. The specifications for sampling the sludge conformed to those described in Volume 40 of the CODE OF FEDERAL REGULATIONS, Part 61, Subpart E. The sludge was sealed and delivered to the Mogul Corporation's Chagrin Falls, Ohio laboratory for analysis by means of the Environmental Protection Agency Method 105.

Those individuals present during the testing period were:

Mr. Paul Cardinal	Paul Cardinal Management Company
Mr. Michael Landis	N.C. Department of Natural Resources and Community Development
Mr. Stan Faires	The Mogul Corporation
Mr. Keith Freeman	The Mogul Corporation

MOGUL **enviro**/serviceROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NC

DATA SUMMARY

RUN #	<u>1</u>	<u>2</u>	<u>3</u>	
DATE	7/20/82	7/20/82	7/20/82	
TIME START	9:00	11:17	13:45	
TIME STOP	10:23	12:44	15:08	
AVERAGE STACK TEMPERATURE (degrees.F)	141.6	136.2	182.2	153.3
PERCENT MOISTURE (by volume)	5.94	5.18	4.64	
AVERAGE STACK VELOCITY - STACK CONDITIONS (feet/minute)	1795	1447	2041	1761 29.35 ps
STACK VOLUME at STANDARD CONDITIONS (standard cubic feet/ minute)	5763	4725	6223	
DRY GAS SAMPLE VOLUME at STANDARD CONDITIONS (cubic feet)	39.66	33.89	42.80	
PERCENT ISOKINETIC	100.05	104.27	100.55	
PARTICULATE CONCENTRATIONS (lbs./Tons dry sludge)	0.5037 1.395	0.3876 1.374	0.5201 1.524	(1.4106) (1.4107)
ALLOWABLE PARTICULATE EMISSIONS* (lbs./Tons dry sludge)	1.30 ✓	1.30	1.30	
	35.29	40.32	47.04	3122

	<u>COMPOSITE # 1</u>	<u>COMPOSITE # 2</u>	<u>COMPOSITE # 3</u>	
PERCENT MOISTURE	7/20/82 17.285 55.9	7/20 2000-0687 55.9	7/20 0900-1600 55.9	
MERCURY CONCENTRATIONS (Grams/day)	35.60	44.71	45.45	41.92
ALLOWABLE MERCURY EMISSIONS** (Grams/day)	3200 ✓	3200	3200	

*REFERENCES: CODE OF FEDERAL REGULATIONS (CFR) Title 40, Protection of Environment
Parts 53 - 80, Revised July 1, 1980, Chapter 1, Part 60, Subpart 0.
60.152

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NC

****REFERENCE:** CODE OF FEDERAL REGULATIONS(CFR), Title 40, Protection of Environment,
Parts 53 - 80 Revised July 1, 1980, Chapter 1, Part 61,
Subpart E, 61.52.

SUMMARY

SUMMARY OF TEST DATA

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

DATE: 7/20/82

RUN NO: 1, 2 & 3SUMMARY OF TEST DATA
PARTICULATE SAMPLING TRAIN

		1	2	3
1) Sampling nozzle diameter, in.	D _{av}	.250	.250	.250
2) Sampling time, min.	T _{aw}	80	80	80
3) Sample gas volume - meter condition, cf	V _{ac}	43.341	37.028	46.129
4) Average orifice pressure drop, in. H ₂ O	P _{af}	0.799	.566	.911
5) Average meter temperature, °F.	T _{af}	105.0	114.5	97.3
6) Particulate collected - probe & cyclone, mg.	W _{aj}	36.9	41.5	36.7
7) Particulate collected - probe, cyclone & filter, mg	W _{ak}	46.3	42.5	57.1
8) Particulate collected - total, mg	W _{aj}	46.3	42.5	57.1

VELOCITY TRAVERSE DURING TEST - BURNER AND WASTE

1) Stack area, in. ²	S _{dd}	572.56 [✓]	572.56	572.56
2) Average stack pressure, in. Hg (absolute)	P _{di}	29.157	29.162	29.152
3) Average stack temperature, °F	T _{df}	141.6	136.2	182.2
4) Average $\sqrt{\text{velocity head} \times \text{stack temperature}}$	S _{de}	11.99	9.68	13.56

STACK MOISTURE CONTENT

1) Total water collected by train, ml	V _{ce}	52.8	39.0	43.9
---------------------------------------	-----------------	------	------	------

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

DATE: 7/20/82

RUN NO: 1, 2 & 3

STACK MOISTURE CONTENT DATA AND CALCULATIONS FOR TEST

		<u>1</u>	<u>2</u>	<u>3</u>
1) H ₂ O condensed in impingers = V _{cb} , ml	V _{cb}	39.4	23.0	31.4
2) H ₂ O absorbed by silica gel = V _{cd} , ml	V _{cd}	13.4	16.0	12.5
3) Total H ₂ O collected = V _{ce} = V _{cb} + V _{cd} , ml	V _{cc}	52.8	39.0	43.8
4) Vol. of H ₂ O vapor @ 70° F & 29.92 in. Hg = 0.0474 x V _{ce} = V _{cf} , cf	V _{cg}	2.503	1.850	2.081
5) Moisture in stack gas = V _{cg} , % = $\frac{100 \times V_{cf}}{V_{ab} + V_{cf}}$	V _{cg}	5.94	5.18	4.64
6) Mole fraction dry gas, = M _{ch} = $\frac{100 - V_{cg}}{100}$	M _{ch}	.9406	.9480	.9536
7) Molecular weight of stack gas = M _{ca} = M _{bj} x M _{ch} + 1B (1 - M _{ch})	M _{ca}	28.97	29.05	28.64

8) Orsat analysis and average molecular weight of dry gas:

	<u>ANALYSIS</u>			<u>x = MOLE WT.</u>	<u>WT/MOLE (DRY)</u>		
	<u>1</u>	<u>2</u>	<u>3</u>		<u>1</u>	<u>2</u>	<u>3</u>
CO ₂ (V _{bf}), % Vol (dry)	7.0	7.0	3.0	44/100	3.08	3.08	1.32
CO (V _{bg}), % Vol (dry)	0.0	0.0	0.0	28/100	+ 0.00	0.00	0.00
O ₂ (V _{bh}), % Vol (dry)	13.5	13.5	17.0	32/100	+ 4.32	4.32	5.44
N ₂ (V _{bi}), % Vol (dry)	79.5	79.5	80.0	28/100	+22.26	22.26	22.40

M_{bj} = Avg. molecular wt of dry gas
29.66 29.66 29.16

$$\% \text{ isokinetic} = \frac{1032 \times (T_{df} + 460) \times V_{ab}}{V_{dh} \times T_{aw} \times P_{df} \times M_{ch} \times (D_{av})^2} = \frac{1}{100.048} \quad \frac{2}{104.27} \quad \frac{3}{100.547}$$

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

DATE: 7/20/82

RUN NO: 1, 2 & 3

Stack volume & standard conditions, scfm

$$= 0.123 \times \frac{V_{dh} \times S_{dd} \times M_{ch} \times P_{dj}}{(T_{df} + 460)} = V_{db} \quad \begin{matrix} \underline{1} \\ 5763.0 \end{matrix} \quad \begin{matrix} \underline{2} \\ 4725.0 \end{matrix} \quad \begin{matrix} \underline{3} \\ 6223.0 \end{matrix}$$

Dry gas sample volume @ standard conditions, cf =

$$17.7 \times V_{ac} \times P_{ad} + \frac{P_{af}}{13.6} = V_{ab} \quad \begin{matrix} 39.66 \end{matrix} \quad \begin{matrix} 33.89 \end{matrix} \quad \begin{matrix} 42.80 \end{matrix}$$

(T_{ai} + 460)

LABORATORY DATA

Particulate - probe & cyclone (W _{aj}), mg =	36.9	41.5	36.7
Particulate - probe, cyclone & filter (W _{ak}), mg =	46.3	42.5	57.1

PARTICULATE CONCENTRATION CALCULATIONS

In grains/scf

Particulate - probe & cyclone, grains/scf

$$C_{am} = 0.0154 \times \frac{W_{aj}}{V_{ab}} \quad C_{am} \quad \begin{matrix} 0.0143 \end{matrix} \quad \begin{matrix} 0.0189 \end{matrix} \quad \begin{matrix} 0.0132 \end{matrix}$$

Particulate - probe, cyclone & filter, grains/scf

$$C_{an} = \frac{0.0154 \times W_{ak}}{V_{ab}} \quad C_{an} \quad \begin{matrix} 0.0180 \end{matrix} \quad \begin{matrix} 0.0193 \end{matrix} \quad \begin{matrix} 0.0205 \end{matrix}$$

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

DATE: 7/20/82

RUN NO: 1, 2 & 3

PARTICULATE CONCENTRATION CALCULATIONS (cont'd)

In grains/cf @ stack conditions

Particulate - probe & cyclone, grains/cf @ stack conditions

$$C_{as} = \frac{17.7 \times C_{am} \times P_{dj} \times M_{ch}}{(T_{df} + 460)} = C_{as} \quad \frac{1}{0.0116} \quad \frac{2}{0.01795} \quad \frac{3}{0.0101}$$

Particulate - probe, cyclone & filter, grains/cg @ stack conditions

$$C_{at} = \frac{17.7 \times C_{an} \times P_{dj} \times M_{ch}}{(T_{df} + 460)} = C_{at} \quad 0.0145 \quad 0.01584 \quad 0.0157$$

in lb/hr

Particulate - probe & cyclone, lb/hr

$$C_{av} = 0.00857 \times C_{am} \times V_{db} = C_{av} \quad 0.7061 \quad 0.7652 \quad 0.7039$$

Particulate - probe, cyclone & filter, lb/hr

$$C_{aw} = 0.00857 \times C_{an} \times V_{db} = C_{aw} \quad 0.8888 \quad 0.7814 \quad 1.0932$$

Stack velocity @ P_{dj} and P_{df} (stack conditions), fpm

$$= 4350 \times S_{de} \times \frac{1}{P_{dj} \times M_{ca}} = V_{dh} \quad 1795.0 \quad 1447.0 \quad 2041.0$$

APPENDIX II
ANALYTICAL
REPORT SHEETS

APPENDIX III
STACK DIAGRAMS AND
POINT LOCATIONS

APPENDIX IV
ANALYTICAL METHODS/
REGULATIONS

APPENDIX V
TEST EQUIPMENT
AND CALIBRATION

APPENDIX VI
RAW DATA

ANALYTICAL REPORT SHEETS

PARTICULATE DATA

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

PARTICULATE DATA

RUN #	FILTER #/ BEAKER #	FINAL WEIGHT (grams)	TARE WEIGHT (grams)	BLANK CORRECTED	NET WEIGHT (milligrams)
Filters					
1	28	0.5167	0.5073	-	9.4
2	41	0.5077	0.5067	-	1.0
3	33	0.5234	0.5030	-	20.4
Probe Wash					
1	RRA	98.4535	98.4121	0.0369	36.9
2	RRB	95.6144	95.5684	0.0415	41.5
3	RRC	95.3696	95.3284	0.0367	36.7
Blank	RRD	96.3646	96.3601	0.000	0.0
Total Particulate collected					
RUN #	TOTAL COLLECTED FILTERS (milligrams)	TOTAL COLLECTED PROBE WASH (milligrams)			NET TOTAL PARTICULATE (milligrams)
1	9.4	+	36.9	=	46.3
2	1.0	+	41.5	=	42.5
3	20.4	+	36.7	=	57.1

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

PARTICULATE EMISSION DISCHARGE

$$C_{ds} = (2000) (C_{aw}/S_D)$$

C_{ds} = particulate emission discharge, lb/ton dry sludge

C_{aw} = particulate matter mass emissions, lb/hr

S_w = average wet sludge charging rate during the run, lb/hr

NOTE: This data provided by customer.

S_D = average dry sludge charging rate during the run, lb/hr

$$= S_w - \% \text{ moisture}$$

% moisture = 55.9

RUN # 1

$$C_{ds} = 2000 \frac{(0.888 \text{ lb./hr})}{3529 \text{ lb/hr}}$$

= 0.5037 lb/ton dry sludge

$$S_w = 8003 \text{ lb/hr}$$

$$S_D = 3529 \text{ lb/hr}$$

53800 ... Revised

RUN # 2

$$C_{ds} = 2000 \frac{(0.7814 \text{ lb/hr})}{4032 \text{ lb/hr dry sludge}}$$

= 0.3876 lb/Ton dry sludge

$$S_w = 9142 \text{ lb/hr}$$

$$S_D = 4032 \text{ lb/hr}$$

9150

RUN # 3

$$C_{ds} = 2000 \frac{(1.0932 \text{ lb/hr})}{4204 \text{ lb/hr}}$$

= 0.5201 lb/ton dry sludge

$$S_w = 9533 \text{ lb/hr}$$

$$S_D = 4204 \text{ lb/hr}$$

REFERENCE: CODE OF FEDERAL REGULATIONS (CFR)
Title 40 Protection of Environment
Parts 53 - 80 Revised July 1, 1980
Chapter 1 Part 60, Subpart 0, 60.154

MERCURY EMISSIONS DATA

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

MERCURY EMISSIONS DATA

Three (3) composite sludge samples were collected during the 24-hour operating period between 5:00 p.m. on 7/19/82 and 4:00 pm on 7/20/82. Grab samples were collected from the conveyor before incineration at a rate of one (1) per hour. Each of the composites consisted of eight (8) grab samples with each grab sample having at least a volume of 200 milliliters but not more than 400 milliliters.

COMPOSITE # 1 7/19/82		COMPOSITE #2 7/20/82		COMPOSITE # 3 7/20/82	
GRAB SAMPLE #	TIME COLLECTED	GRAB SAMPLE #	TIME COLLECTED	GRAB SAMPLE #	TIME COLLECTED
1	5 pm	9	1 am	17	9 am
2	6 pm	10	2 am	18	10 am
3	7 pm	11	3 am	19	11 am
4	8 pm	12	4 am	20	12 pm
5	9 pm	13	5 am	21	1 pm
6	10 pm	14	6 am	22	2 pm
7	11 pm	15	7 am	23	3 pm
8	12 am	16	8 am	24	4 pm

$$E_{Hg} = 1 \times 10^{-3} cQ$$

E_{Hg} = mercury emissions, g/day

c = mercury concentration of sludge on a dry solids basis, $\mu\text{g/g}$ (ppm)

Q = sludge charging rate, kg/day

MOGUL **enviro**service

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NC

MERCURY CONCENTRATION - (c)

COMPOSITE #	DRY SAMPLE ANALYZED (grams)	ppm Hg Detected	c or ug/g
1	0.4557	0.38	0.8339 = $\frac{.38 \text{ ppm}}{.4557 \text{ g}}$
2	0.4106	0.43	1.0472
3	0.4509	0.48	1.0645

SLUDGE CHARGING RATE - (Q)

RUN #	PROCESS DRY WEIGHT (lb/hr)	AVERAGE WEIGHT (lb/hr)	CHARGING RATE (kg/day)
1	3529		
2	4032	3922 ✓	42,696* $42,696 \text{ kg/day}$
3	4204		

*Conversion Factors:

- 1. 24 hours = 1 day
- 2. 1 pound = 0.4536 kg

MERCURY EMISSIONS (E_{Hg})

$$E_{Hg} = 1 \times 10^{-3} cQ$$

COMPOSITE #	MERCURY CONCENTRATION (c)	SLUDGE CHARGING RATE (Q)	MERCURY EMISSIONS (E_{Hg})
1	0.8339	42,696	35.60 ✓
2	1.0472	42,696	44.71 ✓
3	1.0645	42,696	45.45

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

Allowable Emissions - <3200g/day

REFERENCE: CODE OF FEDERAL REGULATIONS (CFR)
Title 40 Protection of Environment
Parts 53 to 80, Revised July 1, 1980
Chapter 1, Part 61, Subpart E 61.52

PL 11701A-11
**STACK DIAGRAMS AND
POINT LOCATIONS**

STACK DIAGRAM AND POINT LOCATIONS


REGULATIONS

AMULCATION

SKETCH OF SAMPLE PORT LOCATION

AND SAMPLE POINTS


ROCKY RIVER WASTEWATER TREATMENT
PLANT
CONCORD, NORTH CAROLINA



LOCATION OF NEAREST UPSTREAM
OBSTRUCTION OR CONFIGURATION
CHANGE:

DIAMETER UPSTREAM 2.72
 DIAMETER DOWNSTREAM 2.96
 STACK AREA (SQ. IN.) 572.56
 STACK DIAMETER (IN.) 27

Point	% of Stack Diameter	Inches from inside wall
1,21	1.3	.35
2,22	3.9	1.05
3,23	6.7	1.80
4,24	9.7	2.62
5,25	12.9	3.48
6,26	16.5	4.46
7,27	20.4	5.50
8,28	25.0	6.75
9,29	30.6	8.26
10,30	38.8	10.48
11,31	61.2	16.52
12,32	69.4	18.74
13,33	75.0	20.25
14,34	79.6	21.49
15,35	83.5	22.55
16,36	87.1	23.52
17,37	90.3	24.38
18,38	93.3	25.19
19,39	96.1	25.95
20,40	98.7	26.65



ANALYTICAL METHODS AND REGULATIONS

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINASTATEMENT OF METHODS USED TO DETERMINE PARTICULATE EMISSION
RATE OF STATIONARY SOURCES

METHOD 1: SAMPLE AND VELOCITY TRAVERSES FOR STATIONARY SOURCES

Principle

To aid in the representative measurement of pollutant emission and/or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these areas.

Applicability

The method is applicable to flowing gas streams in ducts, stacks and flues. The method cannot be used when: (i) flow is cyclonic or swirling (see section 2.4), (ii) a stack is smaller than about 0.30 meters (12 inches) in diameter, or 0.071 meters³ (113 inches²) in cross-sectional area, or (iii) the measurement site is less than two stack or duct diameters downstream or less than a half diameter upstream from a flow disturbance. The requirements of this method must be considered before construction of a new facility from which emissions will be measured; failure to do so may require subsequent alterations to the stack or deviation from the standard procedure. Cases involving variants are subject to approval by the Administrator, U. S. Environmental Protection Agency.

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINAMETHOD 2: DETERMINATION OF STACK GAS VELOCITY AND VOLUMETRIC FLOW RATE
(Type S Pitot Tube)Principle

The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type 5 (Slausscheibe or reverse type) pitot tube.

Applicability

This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow. This procedure is not applicable at measurement sites which fail to meet the criteria of Method 1, Section 2.1. Also, the method cannot be used for direct measurement in cyclonic or swirling gas streams; section 2.4 of Method 1 shows how to determine cyclonic or swirling flow conditions. When unacceptable conditions exist, alternative procedures, subject to the approval of the Administrator, U. S. Environmental Protection Agency, must be employed to make accurate flow rate determinations, examples of such alternative procedures are: (i) install straightening vanes, (ii) to calculate the total volumetric flow rate stoichiometrically, or (iii) to move to another measurement site at which the flow is acceptable.

METHOD 3: GAS ANALYSIS FOR CARBON DIOXIDE, OXYGEN, EXCESS AIR AND DRY
MOLECULAR WEIGHTPrinciple

A gas sample is extracted from a stack by one of the following methods, (i) single point, grab sampling, or (ii) single point integrated sampling, or (iii) multi point, integrated sampling. The gas sample is analyzed for

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

percent carbon dioxide (CO_2), percent oxygen (O_2), and if necessary, percent carbon monoxide (CO). If a dry molecular weight determination is to be made, either an Orsat or a Fyrite analyzer may be used for the analysis for excess air or emission rate correction factor determination or Orsat analyzer must be used.

Applicability

This method is applicable for determining CO_2 and O_2 concentrations, excess air, and dry molecular weight of a sample from a gas stream of fossil fuel combustion process. The method may also be applicable to other process where it has been determined that compounds other than CO_2 , O_2 , CO , and nitrogen (N_2) are not present in concentrations sufficient to affect the results. Other methods, as well as modifications to the procedure described herein, are also applicable for some or all of the above determinations. Examples of specific methods and modifications include: (i) a multi point sampling method using an Orsat analyzer to analyze individual grab samples obtained at each point, (ii) a method using CO_2 or O_2 and stoichiometric calculations to determine dry molecular weight and excess air, (iii) assigning a value of 30.0 for dry molecular weight in lieu of actual measurements, for processes burning natural gas, coal or oil. These methods and modifications may be used, but are subject to the approval of the Administrator.

METHOD 4: DETERMINATION OF MOISTURE CONTENT IN STACK GASESPrinciple

A gas sample is extracted at a constant rate from the sources, moisture is

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

removed from the sample stream and determined either volumetrically or gravimetrically.

Applicability

This method is applicable for determining the moisture content of stack gas. Two procedures are given. The first is a reference method for accurate determinations of moisture content (such as are needed to calculate emission data). The second is an approximation method, which provides estimates of percent moisture to aid in setting isokinetic sampling rates prior to a pollutant emission measurement run. The approximation method described herein is only a suggested approach, alternative means for approximating the moisture content, e.g., drying tubes, wet bulb-dry bulb techniques, condensation techniques, stoichiometric calculations, previous experience, etc., are also acceptable. The reference method is often conducted simultaneously with a pollutant emission measurement run, when it is, calculation of percent isokinetic, pollutant emission rate, etc., for the run shall be based upon the results of the approximation method, unless the approximation method is shown to the satisfaction of the Administrator, U. S. Environmental Protection Agency, to be capable of yielding results within one percent H_2O of the reference method.

NOTE: The procedure described in Method 5 for determining moisture content is acceptable as a reference method.

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINAMETHOD 2: DETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCESPrinciple

Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter maintained at a temperature in the range of 120+14°C (248+ 25°F) or such other temperatures as specified by an applicable subpart of the standards or approved by the Administrator, U. S. Environmental Protection Agency, for a particular application. The particulate mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically after removal of uncombined water.

Applicability

This method is applicable for the determination of particulate emissions from stationary sources.

FEDERAL REGISTER, Volume 42, Number 160, Standards of Performance for New Stationary Sources, Revision of Reference Method 1-8, August 18, 1977.

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

METHOD 105: DETERMINATION OF MERCURY IN WASTEWATER TREATMENT
PLANT SEWAGE SLUDGES

Principle

A weighed portion of the sewage sludge sample is digested in aqua regia for two (2) minutes at 94°C followed by oxidation with potassium permanganate. Mercury in the digested sample is then measured by the conventional spectrophotometer cold vapor technique.

Applicability

This method is applicable for the determination of total organic and inorganic mercury content in sewage sludges, soils, sediments, and bottom-type materials.

CODE OF FEDERAL REGULATIONS, Title 40, Protection of Environment, Pages 60 - 97

Revised as of July 1, 1978 Chapter 1, Appendix B

DESCRIPTION OF VARIABLES USED

- A - Stack area, sq. in.
- AN - Sampling nozzle diameter, in.
- CP - Pitot tube coefficient
- ΔH - Average orifice pressure drop, in. water
- ΔP - Average velocity head, in. water
- PBAR - Barometric pressure, in. mercury
- PG - Average stack pressure (gauge), in. water
- TM - Average meter temperature, °F
- TS - Average stack temperature, °F
- UPR - Unit heat production rate, lb./million BTU
- VBF - % CO₂ in stack gas (by volume)
- VRG - % CO in stack gas (by volume)
- VBH - % O₂ in stack gas (by volume)
- VBI - % N₂ in stack gas (by volume)
- VCB - Water condensed, ml
- VCD - Water absorbed, ml
- VM - Sample gas volume at meter conditions, scf
- WAK - Particulate collected - probe, cyclone & filter - mg
- YAK - Particulate collected - impingers - mg
- WAL - Particulate collected - total - mg
- Y - Calibration factor
- θ - Total sampling time, min.

EQUATIONS USED IN STACK TESTING PROGRAM

$$\text{Average Stack Pressure, } PS = \frac{PG}{13.6} + PBAR$$

$$\text{Dry Gas Sample Volume at Std. Conditions, } VMSTD = \frac{17.64 \times VM \times Y \times \left(\frac{\Delta H}{PBAR + 13.6} \right)}{TM + 460}$$

$$\text{Water Collected in Impingers \& Silica Gel, } VLC = VCB + VCD$$

$$\text{Volume of Water Vapor at Std. Conditions, } VWSTD = (.04707 \times VCB) + (.04715 \times VCD)$$

$$\text{Percent Moisture by Volume, } BWG = \frac{100 \times VWSTD}{VMSTD + VWSTD}$$

$$\text{Mole Fraction of Dry Gas, } MCH = \frac{100 - BWG}{100}$$

$$\begin{aligned} \text{Avg. Molecular Weight of Dry Stack Gas,} \\ MD = (VBF \times .44) + (VBG \times .28) + (VBH \times .32) + (VBI \times .28) \end{aligned}$$

$$\text{Molecular Weight, Wet Basis, } MS = (MD \times MCH) + (18 \times (1 - MCH))$$

$$\text{Average Stack Velocity, } VS = \frac{85.49 \times CP \times \sqrt{\Delta P} \times \sqrt{TS + 460} \times 60}{\sqrt{PS} \times MS}$$

$$\text{Stack Flow Rate, Dry, Std. Conditions, } QSD = VS + \frac{A}{144} \times MCH \times \frac{PS}{29.92} \times \frac{528}{TS + 460}$$

$$\text{Actual Stack Flow Rate, } VDA = VS \times \frac{A}{144}$$

$$\% \text{ Isokinetic, } IAX = \frac{100 \times (TS+460) \times \left((.002669 \times VLC) + \frac{VM}{TM+460} \right) \times \left(\frac{\Delta H}{PBAR + 13.6} \right)}{\theta \times VS \times PS \times \left(\frac{AN}{24} \right)^2 \times 3.14159}$$

$$\text{Excess Air, } EXAIR = \frac{(VBH - (.5 \times VBG)) \times 100}{(.264 \times VBI) + (.5 \times VBG) - VBH}$$

PARTICULATE CONCENTRATIONS

In grains per dscf

$$\text{Probe, cyclone \& filters} = \frac{.0154 \times \text{WAK}}{\text{VMSTD}}$$

$$\text{Impingers} = \frac{.0154 \times \text{YAK}}{\text{VMSTD}}$$

$$\text{Total} = \frac{.0154 \times \text{WAL}}{\text{VMSTD}}$$

In pounds per hour

$$\text{Probe, cyclone \& filters} = \frac{.00857 \times .0154 \times \text{WAK} \times \text{QSD}}{\text{VMSTD}}$$

$$\text{Impingers} = \frac{.00857 \times .0154 \times \text{YAK} \times \text{QSD}}{\text{VMSTD}}$$

$$\text{Total} = \frac{.00857 \times .0154 \times \text{WAL} \times \text{QSD}}{\text{VMSTD}}$$

In pounds per million BTU

$$\text{Probe, cyclone \& filters} = \frac{.00857 \times .0154 \times \text{WAK} \times \text{QSD}}{\text{VMSTD} \times \text{UHPR}}$$

$$\text{Impingers} = \frac{.00857 \times .0154 \times \text{YAK} \times \text{QSD}}{\text{VMSTD} \times \text{UHPR}}$$

$$\text{Total} = \frac{.00857 \times .0154 \times \text{WAL} \times \text{QSD}}{\text{VMSTD} \times \text{UHPR}}$$

In grains per dscf, adjusted to 12% CO₂

$$\text{Probe, cyclone \& filters} = \frac{.0154 \times \text{WAK} \times 12}{\text{VMSTD} \times \text{VBF}}$$

$$\text{Impingers} = \frac{.0154 \times \text{YAK} \times 12}{\text{VMSTD} \times \text{VBF}}$$

$$\text{Total} = \frac{.0154 \times \text{WAL} \times 12}{\text{VMSTD} \times \text{VBF}}$$

PARTICULATE CONCENTRATIONS (Cont'd)

In pounds per hour, adjusted to 12% CO₂

$$\text{Probe, cyclone \& filters} = \frac{.00857 \times .0154 \times \text{WAK} \times \text{QSD} \times 12}{\text{VMSTD} \times \text{VBF}}$$

$$\text{Impingers} = \frac{.00857 \times .0154 \times \text{YAK} \times \text{QSD} \times 12}{\text{VMSTD} \times \text{VBF}}$$

$$\text{Total} = \frac{.00857 \times .0154 \times \text{WAL} \times \text{QSD} \times 12}{\text{VMSTD} \times \text{VBF}}$$

ALLOWABLE EMISSIONS

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

ALLOWABLE EMISSIONS

REFERENCE: CODE OF FEDERAL REGULATIONS (CFR) Title 40
Protection of Environment Parts 60 - 98
Revised July 1, 1978 Chapter 1

Subpart 0, 60.152 standard for particulate matter
Section a,

No owner or operator of any sewage sludge incinerator
subject to the provisions of this subpart shall dis-
charge or cause the discharge into the atmosphere of:

- (1) Particulate matter at a rate in excess of 0.65 g/kg dry sludge
input (1.30 lb/ton dry sludge input).


REFERENCE: CODE OF FEDERAL REGULATIONS (CFR) Title 40
Protection of Environment Parts 60 - 99
Revised July 1, 1978 Chapter 1

Subpart E - National Emission Standards for Mercury
61.52 Emission standard. paragraph b

Emissions to the atmosphere from sludge incinerator plants, sludge
drying plants, or a combination of these that process wastewater
plant sludges shall not exceed 3200 grams of mercury per 24-hour
period.

**APPENDIX V
TEST EQUIPMENT
AND CALIBRATION**

EQUIPMENT DESCRIPTION



Glass Sampling Train: 1 cyclone, 1 flask, 1 filter holder (2.5", 64 mm), 4 impinger-bubbler units* (500 ml), 3 "U" connectors, 1 elbow (all with ball-joint connections: 28/15 inlets & 28/12 outlets); 12 metal clamps.

*Ice bath & sampling train are designed to accommodate 6 impinger-bubbler units.

PITUBE ASSEMBLY

Combines heated probe & detachable pitot tube; 3', 5' & 10' effective lengths; stainless steel construction; ball-joint & quick-disconnect attachments; 3' & 5' units with Pyrex glass or stainless steel liners; 10' with stainless steel liner only.

Sampling Nozzles: 1/4", 3/8" & 1/2" ID stainless steel units supplied with pitobe; other optional sizes & materials are available.

UMBILICAL CORD


Contains pitot & sample lines plus power cable, all with quick disconnects; also contains leads for 2-way intercom; supplied in modular 25', 50' & 100' lengths that weigh 10 lbs per 25' section; custom lengths to 300' available on special order.

ELECTRICAL

System operates on 115 v, 60 Hz, 13.6 amps (total) in steady running; all connections are twist-lock 3-wire grounding type.


RAC Slaksampr Schematic of EPA Particulate Sampling Train (Method 5)

Same basic configuration used to sample Beryllium & Mercury Vapor (Federal Register, Vol. 36, Nos. 234 (Be, Hg) & 247)



Configuration of Sample Case for sampling SO₂, SO, & H₂SO₄ MIST (Method 8)

Heated area is by-passed; particulate filter positioned between 1st & 2nd impingers; all other sampling components same as for particulate sampling. (Federal Register, Vol. 36, No. 247)



CALIBRATION DATA

ROCKY RIVER WASTEWATER TREATMENT PLANT
CONCORD, NORTH CAROLINA

EXPLANATION OF MOGUL STAKSAMPLER
CALIBRATION SHEETS

ΔH is the same as on the EPA sheet.

Wet test meter volume is the same.

Dry gas meter volume is the same.

Wet test meter temperature is the average of the temperatures taken at the beginning and the end of the calibration run.

WTMT + 460 is the absolute temperature of average temperature of wet test meter in degrees R.

Temperature dry gas plus gas meter:

- A. temperature of intake at beginning of run
- B. temperature of intake at end of run
- C. temperature of outlet at beginning of run
- D. temperature of outlet at end of run.

Temperature Dry Gas = $A + B + C + D$

Average Temperature = $\frac{A + B + C + D}{4}$ = average temperature of intake and outlet of dry gas meter.

Temperature 460 = $\frac{A + B + C + D}{4} + 460$ = absolute temperature

Time = length of run.

SAMPLE CALCULATIONRun #3, $\Delta H = 6$ 1. γ

$$\frac{(W)(Pb)(td + 460)}{V_D(Pb + \frac{\Delta H}{13.6})(tw + 460)}$$

2.

$$\frac{(19.059)(30.29)(549)}{(19.834)(30.29 + \frac{6}{13.6})(520.35)}$$

3. $\gamma = .999$

Time = 0; length of run.

Date 7/12/82

Box Serial No. Nutech - SD

Barometric Pressure 29.250 "Hg

$\gamma = .9922$
 $\Delta H_e = 1.719$

Run #	ΔH	Wet Test		Dry Test		WTMT	WTMT + 460	Temp. Dry Gas Meter				Average Temp. Dry Gas + 460		Time
		Meter Volume	Meter Volume	in A	in B			out C	out D	Dry Gas	Dry Gas			
1	.5	4.301	4.509	73.0	533.0		94.0				94.0	94.0	554.0	10
2	1.0	5.820	6.155	73.0	533.0		102.0				97.0	99.5	559.5	10
3	2.0	7.805	8.196	73.0	533.0		97.0				99.0	98.0	558.0	10
4	4.0	11.216	11.729	73.0	533.0		99.0				103.0	101.0	561.0	10
5	5.0	12.261	12.874	73.0	533.0		102.0				104.0	103.0	563.0	10
6	6.0	13.532	13.978	73.0	533.0		93.0				95.0	94.0	554.0	10
7														
8														

.5 .9902 1.502
 1.0 .9900 1.624
 2.0 .9924 1.810
 4.0 .9960 1.745
 5.0 .9935 1.818
 6.0 .9912 1.820

Calibrated by: S. Faires
 The Mogul Corporation

RAW FIELD DATA

NAME ROCKY RIVER WASTEWATER

ADDRESS CONCORD, N.C.

JOB NO. _____ CUSTOMER NO. _____ LOCATION INCINERATOR OUTLET

RUN NO. 1 DATE OF TEST 7/20/82

Impinger Box # RAC #3
 Filter Paper # 28
 Meter Box # Nutall

PBAR 29.150, VM 43.341, PG .1

VCB 39.4, VCD 13.4

VBF 3.00, VBG 0.0, VBH 4.32, VBI 22.26

A 5.229, CP 8.1, Y 80 minutes

WAK 46.3, YAJ 0.0, WAL 46.3

AW 250, E 80, WIT _____

UPR _____, (COMBUSTION ONLY)

Process English Units
 Combustion Metric Units
 Incinerator

Static - .1

CLOCK TIME	POINT	GM READING	STACK PRESS. VAC	PITOT	STACK TEMP.	ORIFICE ACT.	METER	
				$\Delta P.$	TS	ΔH	T _{in} TAD.	T _{out} TAE.
9.00	1	51.777	.1	.284	133	.80	80	
	2	53.785		.29	140	.96		
	3	54.600	.1	.29	141	.96	90	65
	4	55.700		.25	142	.81		
	5	56.900		.27	142	.90	91	
	6	57.875	.1	.24	142	.80		
	7	59.266		.24	142	.80	91	
	8	60.213		.22	141	.72		67
	9	61.430	.1	.22	140	.72	95	
	10	62.050		.21	140	.70		
	11	63.075		.22	141	.72		
	12	64.420	.1	.22	142	.72	100	68
	13	65.270		.22	144	.72		
	14	66.185		.23	145	.77	102	
	15	67.225		.22	146	.72		
	16	68.250	.1	.21	146	.70		
	17	69.155		.21	146	.70	105	
	18	70.300		.20	146	.67		
	19	71.380	.1	.20	146	.67		66
END 9:40	20	72.560		.21	147	.70	107	
START 9:43	21	73.333		.24	134	.80		
	22	74.535		.24	135	.80	108	

NAME: INDUSTRIAL

ADDRESS: INDUSTRIAL

JOB NO. _____ CUSTOMER NO. _____

LOCATION: INDUSTRIAL

RUN NO. 2 DATE OF TEST 7/20/82

Impinger Box # 2
 Filter Paper # 41
 Meter Box # 11000

PBAR 29.155, VM 37.028, PG 1

VCB 230, VCD 160

VBF 308, VBG 00, VBH 432, VBI 2020

A 572.86, CP. 8.1, Y 80 mm

WAK 425, YAJ 0.0, WAL 425

AN 250, E 80 mm, WTT _____

UPR _____, (COMBUSTION ONLY)

Process English Units
 Combustion Metric Units
 Incinerator

O₂ 13.5
 CO₂ 7.0

CLOCK TIME	POINT	GM READING	STACK PRESS.	PITOT		ORIFICE ACT.	METER	
				Δ P.	TS		T _{in}	T _{out}
				<u>.14</u>		<u>.49</u>		<u>115°</u>
	<u>23</u>	<u>117.825</u>	<u>1"</u>	<u>.14</u>	<u>141</u>	<u>.49</u>		<u>115°</u>
	<u>24</u>	<u>118.601</u>		<u>.14</u>	<u>139</u>	<u>.49</u>		
	<u>25</u>	<u>119.532</u>		<u>.14</u>	<u>141</u>	<u>.49</u>		
	<u>26</u>	<u>120.750</u>		<u>.15</u>	<u>140</u>	<u>.54</u>		<u>110°</u>
	<u>27</u>	<u>121.600</u>	<u>1"</u>	<u>.15</u>	<u>139</u>	<u>.54</u>		
	<u>28</u>	<u>122.610</u>		<u>.14</u>	<u>139</u>	<u>.49</u>		
	<u>29</u>	<u>123.400</u>		<u>.14</u>	<u>137</u>	<u>.49</u>		
	<u>30</u>	<u>124.35</u>		<u>.13</u>	<u>135</u>	<u>.46</u>		<u>117</u>
	<u>31</u>	<u>125.230</u>		<u>.13</u>	<u>134</u>	<u>.46</u>		
	<u>32</u>	<u>126.972</u>		<u>.13</u>	<u>134</u>	<u>.46</u>		<u>117</u>
	<u>33</u>	<u>127.135</u>		<u>.14</u>	<u>133</u>	<u>.49</u>		
	<u>34</u>	<u>127.990</u>	<u>1"</u>	<u>.13</u>	<u>133</u>	<u>.46</u>		
	<u>35</u>	<u>128.990</u>		<u>.13</u>	<u>132</u>	<u>.46</u>		
	<u>36</u>	<u>130.000</u>		<u>.15</u>	<u>132</u>	<u>.54</u>		<u>118°</u>
	<u>37</u>	<u>130.355</u>		<u>.14</u>	<u>132</u>	<u>.49</u>		
	<u>38</u>	<u>131.225</u>	<u>1"</u>	<u>.14</u>	<u>133</u>	<u>.49</u>		
	<u>39</u>	<u>132.240</u>		<u>.15</u>	<u>132</u>	<u>.54</u>		<u>119°</u>
	<u>40</u>	<u>133.530</u>		<u>.14</u>	<u>132</u>	<u>.49</u>		
		FINAL CHECK	<u>.009</u>					
		at 5"						
STOP								
	<u>12:44</u>			<u>(.2962)</u>	<u>1361</u>	<u>.5575</u>		<u>110.9</u>

NAME John W. ... ADDRESS ...

JOB NO. _____ CUSTOMER NO. _____ LOCATION _____

RUN NO. 3 DATE OF TEST 7/20/82

Impinger Box # None
 Filter Paper # 33
 Meter Box # None

PBAR 29.115, VM 46.129, PG 1

VCB 3.4, VCD 12.5

VBF 1.32, VBG 0.0, VBH 5.44, VBI 22.40

A 572.51, CP .84, Y 992.2

WAK 57.1, YAJ 0.0, WAL 57.1

AN 250, E 80, WTT _____

UPR _____ (COMBUSTION ONLY)

Process English Units
 Combustion Metric Units
 Incinerator

CLOCK TIME	POINT	GM READING	STACK PRESS.	PITOT		ORIFICE ACT.	METER	
				ΔP	TS		T _{in}	T _{out}
				ΔH		TAD.	TAE.	
				.27	190	.84		
	23	157.600		.27	190	.84		
	24	160.550		.26	188	.80		95
	25	161.000		.28	189	.86		
	26	162.915		.23	184	.71		
	27	163.900		.26	187	.80		95
	28	165.950		.28	190	.86		
	29	166.100		.30	194	.92		
	30	167.045	2.5"	.31	194	.96		
	31	168.520		.31	194	.96		95
	32	169.850		.30	195	.92		
	33	171.008		.31	197	.96		
	34	171.973	2.5"	.33	196	1.03		
	35	173.265		.28	188	.86		98
	36	174.385		.30	189	.92		
	37	175.680		.31	188	.90		
	38	176.910		.33	196	1.05		
	39	177.505		.32	196	.98		105
	40	179.746		.32	194	.98		106
STDC	3.08	FINNE 1.0 CR .009		.5366	176.7	.9108		96.95

THE MOGUL CORPORATION

Consulting Engineering Services

Arlington, TX • Chagrin Falls, OH • Charlotte, NC
Los Angeles, CA • Minneapolis, MN • Portland, OR