

Table 3.1-1 (Metric Units). EMISSION FACTORS FOR LARGE UNCONTROLLED GAS TURBINES<sup>a</sup>

Pollutant	EMISSION FACTOR RATING <sup>b</sup>	Natural Gas (SCC 2-01-002-01)		Fuel Oil (Distillate) (SCC 2-01-001-01)	
		g/kW-hr <sup>c</sup> (power output)	ng/J (fuel input)	g/kW-hr <sup>c</sup> (power output)	ng/J (fuel input)
NO <sub>x</sub>	C	2.15	190	3.41	300
CO	D	0.52	46	0.233	20.6
CO <sub>2</sub> <sup>d</sup>	B	546	48,160	799	70,520
TOC (as methane)	D	0.117	10.32	0.083	7.31
SO <sub>x</sub> (as SO <sub>2</sub> ) <sup>e</sup>	B	4.57S	404S	4.92S	434.3S
PM-10					
Solids	E	0.094	8.30	0.185	16.3
Condensables	E	0.11	9.72	0.113	9.89
Sizing %					
< 0.05 μm	D	15%	15%	16%	16%
< 0.10 μm	D	40%	40%	48%	48%
< 0.15 μm	D	63%	63%	72%	72%
< 0.20 μm	D	78%	78%	85%	85%
< 0.25 μm	D	89%	89%	93%	93%
< 1 μm	D	100%	100%	100%	100%

<sup>a</sup> References 1-8. SCC = Source Classification Code. PM-10 = particulate matter less than or equal to 10 micrometers (μm) aerodynamic diameter, and sizing % is expressed in μm.

<sup>b</sup> Ratings reflect limited data and/or a lack of documentation of test results, may not apply to specific facilities or populations, and should be used with care.

<sup>c</sup> Calculated from ng/J assuming an average heat rate of 11,318 kJ/kW-hr.

<sup>d</sup> Based on 100% conversion of the fuel carbon to CO<sub>2</sub>. CO<sub>2</sub> [ng/J] = 3.67\*C/E, where C = carbon content of the fuel by weight (0.75), and E = energy content of fuel, 55.6 kJ/g. The uncontrolled CO<sub>2</sub> emission factors are also applicable to controlled gas turbines.

<sup>e</sup> All sulfur in the fuel is assumed to be converted to SO<sub>2</sub>. S = % sulfur in fuel.

Table 3.1-2 (English Units). EMISSION FACTORS FOR LARGE UNCONTROLLED GAS TURBINES<sup>a</sup>

Pollutant	EMISSION FACTOR RATING <sup>b</sup>	Natural Gas (SCC 2-01-002-01)		Fuel Oil (Distillate) (SCC 2-01-001-01)	
		lb/hp-hr <sup>c</sup> (power output)	lb/MMBtu (fuel input)	lb/hp-hr <sup>c</sup> (power output)	lb/MMBtu (fuel input)
NO <sub>x</sub>	C	3.53 E-03	0.44	5.60 E-03	0.698
CO	D	8.60 E-04	0.11	3.84 E-04	0.048
CO <sub>2</sub> <sup>d</sup>	B	0.897	112	1.31	164
TOC (as methane)	D	1.92 E-04	0.024	1.37 E-04	0.017
SO <sub>x</sub> (as SO <sub>2</sub> ) <sup>e</sup>	B	7.52 E-03S	0.94S	8.09 E-03S	1.01S
PM-10					
Solids	E	1.54 E-04	0.0193	3.04 E-04	0.038
Condensables	E	1.81 E-04	0.0226	1.85 E-04	0.023
Sizing %					
<0.05 μm	D	15%	15%	16%	16%
<0.10 μm	D	40%	40%	48%	48%
<0.15 μm	D	63%	63%	72%	72%
<0.20 μm	D	78%	78%	85%	85%
<0.25 μm	D	89%	89%	93%	93%
<1 μm	D	100%	100%	100%	100%

<sup>a</sup> References 1-8. SCC = Source Classification Code. PM-10 = particulate matter less than or equal to 10 μm aerodynamic diameter, and sizing % is expressed in μm. Condensables are also PM-10 and all PM from oil and gas fired turbines is less than 1 μm in size and therefore are considered PM-10.

<sup>b</sup> Ratings reflect limited data and/or a lack of documentation of test results, may not apply to specific facilities or populations, and should be used with care.

<sup>c</sup> Calculated from lb/MMBtu assuming an average heat rate of 8,000 Btu/hp-hr.

<sup>d</sup> Based on 100% conversion of the fuel carbon to CO<sub>2</sub>. CO<sub>2</sub> [lb/MMBtu] = 3.67\*C/E, where C = carbon content of fuel by weight (0.75), and E = energy content of fuel, (0.0239 MMBtu/lb). The uncontrolled CO<sub>2</sub> emission factors are also applicable to controlled gas turbines.

<sup>e</sup> All sulfur in the fuel is assumed to be converted to SO<sub>2</sub>. S = % sulfur in fuel. When sulfur content is not available, 0.6 lb/10<sup>6</sup> ft<sup>3</sup> (0.0006 lb/MMBtu) can be used; however, the equation is more accurate.

Table 3.1-3 (Metric Units). EMISSION FACTORS FOR LARGE GAS-FIRED CONTROLLED GAS TURBINES<sup>a</sup>

EMISSION FACTOR RATING: C

Pollutant	Water Injection (0.8 water/fuel ratio)		Steam Injection (1.2 water/fuel ratio)		Selective Catalytic Reduction (with water injection)
	g/kW-hr (power output)	ng/J (fuel input)	g/kW-hr (power output)	ng/J (fuel input)	ng/J (fuel input)
NO <sub>x</sub>	0.66	61	0.59	52	3.78 <sup>b</sup>
CO	1.3	120	0.71	69	3.61
TOC (as methane)	ND	ND	ND	ND	6.02
NH <sub>3</sub>	ND	ND	ND	ND	2.80
NMHC	ND	ND	ND	ND	1.38
Formaldehyde <sup>c</sup>	ND	ND	ND	ND	1.16

<sup>a</sup> References 3,10-15. Source Classification Code 2-01-002-01. All data are averages of a limited number of tests and may not be typical of those reductions that can be achieved at a specific location. NMHC = nonmethane hydrocarbons. ND = no data.

<sup>b</sup> An SCR catalyst reduces NO<sub>x</sub> by an average of 78%.

<sup>c</sup> Hazardous air pollutant listed in the *Clean Air Act*.

Table 3.1-4 (English Units). EMISSION FACTORS FOR LARGE GAS-FIRED CONTROLLED GAS TURBINES<sup>a</sup>

EMISSION FACTOR RATING: C

Pollutant	Water Injection (0.8 water/fuel ratio)		Steam Injection (1.2 water/fuel ratio)		Selective Catalytic Reduction (with water injection)
	lb/hp-hr (power output)	lb/MMBtu (fuel input)	lb/hp-hr (power output)	lb/MMBtu (fuel input)	lb/MMBtu (fuel input)
NO <sub>x</sub>	1.10 E-03	0.14	9.70 E-04	0.12	0.03 <sup>b</sup>
CO	2.07 E-03	0.28	1.17 E-03	0.16	0.0084
TOC (as methane)	ND	ND	ND	ND	0.014
NH <sub>3</sub>	ND	ND	ND	ND	0.0065
NMHC	ND	ND	ND	ND	0.0032
Formaldehyde <sup>c</sup>	ND	ND	ND	ND	0.0027

<sup>a</sup> References 3,10-15. Source Classification Code 2-01-002-01. All data are averages of a limited number of tests and may not be typical of those reductions that can be achieved at a specific location. NMHC = nonmethane hydrocarbons. ND = no data.

<sup>b</sup> An SCR catalyst reduces NO<sub>x</sub> by an average of 78%.

<sup>c</sup> Hazardous air pollutant listed in the *Clean Air Act*.