



January 7, 1994

Mr. David P. Howekamp A-3-3
Division Director
Air and Toxics Division
U. S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105

Dear Mr. Howekamp:

Attached is a copy of the annual compliance test that was performed on the Cogeneration I facility by Titon Environmental (EPA Permit No. SE82-02), (Kern County APCD Permit No. 1004077A). Testing was performed on December 8, 1993 and was witnessed by Steve Beyn with the Kern County A.P.C.D.

As shown in the Summary of Source Test Results on pages 5 & 6, all emission parameters were well within the compliance limits.

If you or your staff have any questions or comments, please don't hesitate to call me at (619) 762-7311.

Sincerely,

C. M. Kirby
Sr. Environmental Engineer

csm
Attachment

cc: Mr. Thomas Paxson, P.E.
Director, Kern County APCD
2700 "M" St., Suite 290
Bakersfield, CA 93301

Mr. James J. Morgester
Chief, Compliance Division
California Air Resources Board
P. O. Box 2815
Sacramento, CA 95812

RECEIVED
JAN 10 1994

KERN COUNTY AIR
QUALITY CONTROL DISTRICT

**Kern County Air Pollution Control District
and
Environmental Protection Agency (EPA)
Compliance Source Test Report**

for

**U.S. Borax & Chemical Corporation
Boron Facility
48 MW Cogeneration Facility**

Permit Numbers:

**KCAPCD 1004077A
EPA NSR 4-4-11 SE 82-02**

**Determination of Concentrations and Emissions of
Particulate Matter, NO_x, CO, O₂
and Non-Methane Hydrocarbons (NMHC)**

Prepared by

**Titan Environmental
Project 450-039**

Tested On December 8, 1993

Table of Contents

| | | |
|-------|--|----|
| i. | Project Information | 2 |
| ii. | Certification | 3 |
| I. | Summary of Results | 4 |
| II. | Introduction | 7 |
| III. | EPA Method 5; Particulate Matter | 9 |
| IV. | EPA Methods 3A, 7E and 10; O ₂ , NO _x , CO | 13 |
| V. | EPA Method 18; NMHC | 20 |
| VI. | Fuel Analysis | 22 |
| VII. | Methods and Equations | 24 |
| VIII. | Raw Data | 41 |
| | A. Field Data | 42 |
| | B. Lab Analysis Data | 46 |
| | C. Orsat Analysis | 47 |
| | D. NMHC Chromatograms | 48 |
| IX. | Strip Charts | 52 |
| X. | Quality Assurance | 55 |
| | A. Instrument Quality Assurance Checklist | 56 |
| | B. Meter Calibration | 57 |
| | C. Calibration Gas Certifications | 58 |
| | D. Method 18 Quality Assurance | 62 |
| | E. Method 5 Quality Assurance | 70 |
| | F. Chain of Custody | 72 |
| XI. | Source Test Protocol | 73 |

RECEIVED
JAN 10 1994
KERN COUNTY AIR
POLLUTION CONTROL DISTRICT

Project Information

Company:

U.S. Borax & Chemical Corporation
14486 Borax Road
Boron, CA 93516
(619) 762-7000 FAX (619) 762-7335

Attention: Mike Kirby

Source(s):

Turbine/Cogeneration Facility
KCAPCD Permit No. 1004077A
EPA Permit No. NSR 4-4-11 SE 82-02

Source Description:

The unit tested is one Westinghouse frame W-251 48-MW gas turbine equipped with 210 MMBtu/hr duct burners; heat recovery steam generator (HRSG); and a 48-MW electric generator.

Independent Contractor:

Titan Environmental
18828 Highway 65
Bakersfield, CA 93308
(805) 391-0112 FAX (805) 391-0153

Attention: Tim Brennan

Agency:

Kern County Air Pollution Control District
2700 "M" Street, Suite 290
Bakersfield, CA 93301
(805) 861-2593 FAX (805) 861-2595

Attention: Thomas Paxson, P.E.

TITAN ENVIRONMENTAL

18828 Highway 65
Bakersfield, CA 93308
(805) 391-0112 FAX (805) 391-0153


CERTIFICATION

December 29, 1993

Mike Kirby
U.S. Borax & Chemical Corporation
14486 Borax Road
Boron, CA 93516


Dear Mr. Kirby:

Regarding Project 450-039, referred to in this report, I, Scott Davis, as Project Supervisor and on-site director of the testing program described in this report, do hereby certify the sampling, analytical procedures, and results presented in this report are authentic and accurate according to the methods and procedures used.



Scott A. Davis

Regarding Project 450-039, referred to in this report, I certify that I have reviewed the sampling, analytical procedures, and results reported herein, and have found them to be accurate and true according to the methods and procedures used.



Tim Brennan

Summary of Results

TITAN ENVIRONMENTAL

SUMMARY OF SOURCE TEST RESULTS

COMPANY: U.S. BORAX & CHEMICAL CORPORATION

PROJECT : 450-039

UNIT: COGENERATION FACILITY

DECEMBER 8, 1993

APCD #: 1004077A

| EMISSIONS | gr/scf | gr/scf @ 12% CO2 | ppm | ppm @ 15% O2 | lb/ MMBtu | lb/hr | Permit Limits |
|-------------------------------|--------------|---------------------|---------------|-----------------|--------------|---------------|---|
| NOx | | | 41.5 | 39.4 | 0.144 | 75.46 | 96 ppm @15% O2 268 lb/hr |
| | | | 39.5 | 37.8 | 0.1381 | 71.84 | |
| | | | 38.6 | 36.7 | 0.1339 | 70.24 | |
| | Mean: | | | 39.9 | 38.0 | 0.1387 | |
| CO | | | 6.0 | 5.7 | 0.0128 | 6.69 | 446 lb/hr |
| | | | 6.5 | 6.3 | 0.0139 | 7.23 | |
| | | | 6.7 | 6.3 | 0.0141 | 7.39 | |
| | Mean: | | | 6.4 | 6.1 | 0.0136 | |
| NMHC | | | < 0.1 | | < 0.06 | 0.00 | 2.9 lb/hr |
| | | | < 0.1 | | < 0.06 | 0.00 | |
| | | | < 0.1 | | < 0.06 | 0.00 | |
| | Mean: | | | < 0.1 | < 0.06 | 0.00 | |
| FUEL SULFUR as SO2 | | | non detect | | | non detect | 146 lb/hr as SO2 |
| | Mean: | | < 1.0 | | | < 2.79 | |
| Comments: _____ | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

SUMMARY OF SOURCE TEST RESULTS FOR EPA

**U.S. BORAX & CHEMICAL CORPORATION
COGENERATION FACILITY**

PERMIT: NSR 4-4-11 SE 82-02

LOCATION: BORON CA.

| Pollutant | Method | Test Date | Test Results | Permit Limits |
|------------------|---------------|------------------|--------------------------------|-------------------------------|
| Particulate | EPA Method 5 | 8 DEC 93 | .531 lbs/hr | 14.0 lbs/hr |
| NOx as NO2 | EPA Method 7E | 8 DEC 93 | 72.53 lbs/hr .1384 lb/MMBtu | 268.2 lbs/hr 0.57 lb/MMBtu |
| Carbon Monoxide | EPA Method 10 | 8 DEC 93 | 7.11 lbs/hr | 446 lbs/hr |
| Sulfur Content | GC-FPD | 8 DEC 93 | nd < 1.0 ppm | N/A |

*Emissions are corrected to EPA standard conditions (68°F and 29.92 inches of Hg) in the units stated in the EPA permit.

Prepared by: SCOTT DAVIS

Title: PROJECT SUPERVISOR

Date: November 5, 1993

Introduction

Introduction

On December 8, 1993 Titan Environmental performed a compliance source test for U.S. Borax at their Boron Cogeneration Facility. One 48-MW gas turbine was tested for emissions of NOx, CO, NMHC and Fuel Sulfur to satisfy KCAPCD requirements. The same unit was tested for emissions of Particulate, NOx, CO and Sulfur content to satisfy EPA requirements. Testing was performed under normal operating conditions. The following methodology was used.

Table I - General Approach

| Parameter | Method | Analysis Method | Test Runs Per Unit | Permit Limits | |
|----------------|----------------------|---|--------------------|------------------------------|---|
| | | | | EPA | KCAPCD |
| PM | EPA Method 5 | Gravimetric analysis of front half | 1 6 Hour | 14.0 lb/hr | N/A |
| NOx | EPA Method 7E | TECO Model 10; Chemiluminescent | 3 40 Minute | 268.2 lb/hr 0.57 lb/MMBtu | 268 lb/hr 96ppm @ 15% O ₂ |
| CO | EPA Method 10 | TECO Model 48; Gas Filter Correlation | 3 40 Minute | 446 lb/hr | 446 lb/hr |
| O ₂ | EPA Method 3A | Teledyne Model 320AR; Micro Fuel Cell | 3 40 Minute | N/A | N/A |
| NMHC | EPA Method 18 | GC-FID Analysis for C ₁ - C ₆ + | 3 | N/A | 2.9 lb/hr |
| Volume Flow | EPA Methods 2, 3, 4 | Pitot Tube Traverse/ Condensation Train Simultaneous w/Method 5 | 1 6 Hour | N/A | N/A |
| Fuel Sulfur | Tedlar Bag Sample | GC-FPD analysis for Total Sulfur | 1 | N/A | 146 lb/hr SO ₂ |
| Fuel Sample | Stainless Steel Bomb | GC-FID/TCD analysis for C ₁ -C ₆ +, O ₂ , CO ₂ , N ₂ | 1 | N/A | N/A |

All testing was conducted by Scott Davis, Randall Kastner and Robert Ernst of Titan Environmental. Operation of the units was supervised by Mike Kirby of U.S. Borax.

EPA Method 5

METHOD 1-5
FIELD DATA @ 60° F & 29.92 "Hg.

| DATA INPUT | |
|--|------------|
| Run #: | 1 |
| Time : | 9:11-15:28 |
| Vm, dry gas volume sampled, ft3 | 284.81 |
| Y, meter calibration factor | 0.983223 |
| P bar, Barometric pressure, "Hg | 27.68 |
| P static, stack pressure, " H2O | -0.6 |
| Delta H, differential meter press, " H2O | 1.01 |
| Tm, meter temperature, R° | 529 |
| Vol H2O, grams condensed | 571 |
| % CO2, percent volume dry | 2.7 |
| % O2, percent volume dry | 15.1 |
| % N2, percent volume dry | 82.2 |
| Cp, pitot tube coefficient | 0.84 |
| Avg. square root delta-p, "H2O | 0.90 |
| Temp. stack, R° | 767 |
| Stack area, ft2 | 113.70 |
| Area noz, ft2 | 3.25E-04 |

| CALCULATED RESULTS | |
|--------------------------------------|--------|
| Run #: | 1 |
| Vm(std); dscf, sample volume | 255.34 |
| Bws; H2O vapor, fractional percent | 0.0941 |
| MF; moisture factor, 1-Bws | 0.9059 |
| Md; MW stk gas dry, lb/lb-mole | 29.04 |
| Ms; MW stk gas wet, lb/lb-mole | 28.00 |
| Vs; fps, gas velocity | 64.63 |
| Q-acfm; actual volume flow | 440860 |
| Qstd-dscfm; dry standard volume flow | 250088 |
| Sample time; minutes | 360 |
| % Isokinetic Sample Rate | 99.3 |

METHOD 1-5
FIELD DATA @ 68° F & 29.92 "Hg.

| DATA INPUT | |
|---|------------|
| Run #: | 1 |
| Time : | 9:11-15:28 |
| Vm, dry gas volume sampled, ft ³ | 284.81 |
| Y, meter calibration factor | 0.983223 |
| P bar, Barometric pressure, "Hg | 27.68 |
| P static, stack pressure, " H ₂ O | -0.6 |
| Delta H, differential meter press, " H ₂ O | 1.01 |
| Tm, meter temperature, R° | 529 |
| Vol H ₂ O, grams condensed | 571 |
| % CO ₂ , percent volume dry | 2.7 |
| % O ₂ , percent volume dry | 15.1 |
| % N ₂ , percent volume dry | 82.2 |
| Cp, pitot tube coefficient | 0.84 |
| Avg. square root delta-p, "H ₂ O | 0.904 |
| Temp. stack, R° | 767 |
| Stack area, ft ² | 113.7 |
| Area noz, ft ² | 3.25E-04 |

| CALCULATED RESULTS | |
|---|--------|
| Run #: | 1 |
| Vm(std); dscf, sample volume | 259.27 |
| Bws; H ₂ O vapor, fractional percent | 0.0941 |
| MF; moisture factor, 1-Bws | 0.9059 |
| Md; MW stk gas dry, lb/lb-mole | 29.04 |
| Ms; MW stk gas wet, lb/lb-mole | 28 |
| Vs; fps, gas velocity | 64.63 |
| Q-acfm; actual volume flow | 440906 |
| Qstd-dscfm; dry standard volume flow | 253967 |
| Sample time; minutes | 360 |
| % Isokinetic Sample Rate | 99.3 |

EPA METHOD 5 DATA
 @ 68°F & 29.92 "Hg

| PARTICULATE GRAVIMETRIC RESULTS | | | | | |
|---------------------------------|------------|----------------|----------------|----------------------|--------------|
| RUN #1 | net mg | gr/dscf | gr/scf | gr/dscf @ 12% CO2 | lbs/hr |
| Probe & Nozzle Wash: | 3.2 | 0.00019 | 0.00017 | 0.00084 | 0.414 |
| Filter: | 0.9 | 0.00005 | 0.00005 | 0.00024 | 0.116 |
| TOTAL, front half | 4.1 | 0.00024 | 0.00022 | 0.00108 | 0.531 |

| SUPPORTING DATA | | | | | | | |
|-----------------|-------|--------|------|------|------|---------|--------|
| Run # | Time | | %O2 | %CO2 | %H2O | Vm(std) | DSCFM |
| | start | finish | | | | | |
| 1 | 9:11 | 15:28 | 15.1 | 2.7 | 9.41 | 259.27 | 253967 |

EPA Methods 3A, 7E and 10

RUN #1
NOx/CO/O2
@ 60° F
EMISSION DATA

| 10:02 AM -- 10:42 AM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @ 15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|-------------------|-------|----------|
| NOx emissions | 14.69 | 41.5 | 119.6 | 39.4 | 75.46 | 0.1440 |
| CO emissions | 14.69 | 6.0 | 17.4 | 5.7 | 6.69 | 0.0128 |
| Fuel F factor 8508 DSCFM/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 250088 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|-------------|-------------|----------------|--------------|-------------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | — | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 10:02 AM | — | 10:12 AM | 69.2 | 51.5 | 15.1 | 14.72 | 41.52 | 5.91 |
| 10:12 AM | — | 10:22 AM | 69.3 | 51.5 | 15.2 | 14.72 | 41.52 | 5.96 |
| 10:22 AM | — | 10:32 AM | 69.2 | 51.5 | 15.4 | 14.67 | 41.52 | 6.12 |
| 10:32 AM | — | 10:42 AM | 69.2 | 51.4 | 15.5 | 14.65 | 41.41 | 6.17 |
| Averages | | | 69.2 | 51.5 | 15.3 | 14.69 | 41.49 | 6.04 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.3 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.5 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | 0.20 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | 0.20 |
| INITIAL span, %fs | | | | | | 94 | 93 | 90 |
| FINAL span, %fs | | | | | | 94.5 | 93 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 0.50 | 0.00 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.12 | 0.00 | 0.00 |

RUN #2
NOx/CO/O2
@ 60° F
EMISSION DATA

| 10:53 AM - 11:33 AM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|------------------|-------|----------|
| NOx emissions | 14.74 | 39.5 | 114.7 | 37.8 | 71.84 | 0.1381 |
| CO emissions | 14.74 | 6.5 | 19.0 | 6.3 | 7.23 | 0.0139 |
| Fuel F factor 8508 DSCF/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 250088 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|-------------|-------------|----------------|--------------|-------------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | - | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 10:53 AM | - | 11:03 AM | 69.8 | 50.8 | 15.7 | 14.76 | 40.77 | 6.37 |
| 11:03 AM | - | 11:13 AM | 69.9 | 49.3 | 16.0 | 14.74 | 39.17 | 6.70 |
| 11:13 AM | - | 11:23 AM | 70.1 | 49.3 | 15.8 | 14.73 | 39.08 | 6.52 |
| 11:23 AM | - | 11:33 AM | 70.2 | 49.3 | 15.8 | 14.71 | 38.99 | 6.54 |
| Averages | | | 70.0 | 49.7 | 15.8 | 14.74 | 39.50 | 6.53 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.5 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | -0.10 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | -0.10 |
| INITIAL span, %fs | | | | | | 94.5 | 93 | 90 |
| FINAL span, %fs | | | | | | 95.7 | 93.8 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 1.20 | 0.80 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.30 | 0.80 | 0.00 |

RUN #3
NOx/CO/O2
@ 60° F
EMISSION DATA

| 11:39 AM - 12:19 PM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|------------------|-------|----------|
| NOx emissions | 14.69 | 38.6 | 111.2 | 36.7 | 70.24 | 0.1339 |
| CO emissions | 14.69 | 6.7 | 19.2 | 6.3 | 7.39 | 0.0141 |
| Fuel F factor 8508 DSCF/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 250088 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|------|------|----------------|---------|--------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | - | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 11:39 AM | - | 11:49 AM | 69.0 | 49.0 | 15.9 | 14.66 | 38.64 | 6.65 |
| 11:49 AM | - | 11:59 AM | 69.2 | 49.0 | 15.8 | 14.66 | 38.62 | 6.55 |
| 11:59 AM | - | 12:09 PM | 69.5 | 49.0 | 16.0 | 14.69 | 38.61 | 6.76 |
| 12:09 PM | - | 12:19 PM | 69.8 | 49.0 | 16.0 | 14.73 | 38.60 | 6.76 |
| Averages | | | 69.4 | 49.0 | 15.9 | 14.69 | 38.62 | 6.68 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | 0.00 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | 0.00 |
| INITIAL span, %fs | | | | | | 94 | 93.8 | 90 |
| FINAL span, %fs | | | | | | 95 | 93.9 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 1.00 | 0.10 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.25 | 0.10 | 0.00 |

RUN #1
NOx/CO/O2
@ 68° F
EMISSION DATA

| 10:02 AM - 10:42 AM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|------------------|-------|----------|
| NOx emissions | 14.69 | 41.5 | 119.6 | 39.4 | 75.47 | 0.1497 |
| CO emissions | 14.69 | 6.0 | 17.4 | 5.7 | 6.69 | 0.0127 |
| Fuel F factor 8637 DSCF/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 253967 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|-------------|-------------|----------------|--------------|-------------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | - | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 10:02 AM | - | 10:12 AM | 69.2 | 51.5 | 15.1 | 14.72 | 41.52 | 5.91 |
| 10:12 AM | - | 10:22 AM | 69.3 | 51.5 | 15.2 | 14.72 | 41.52 | 5.96 |
| 10:22 AM | - | 10:32 AM | 69.2 | 51.5 | 15.4 | 14.67 | 41.52 | 6.12 |
| 10:32 AM | - | 10:42 AM | 69.2 | 51.4 | 15.5 | 14.65 | 41.41 | 6.17 |
| Averages | | | 69.2 | 51.5 | 15.3 | 14.69 | 41.49 | 6.04 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.3 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.5 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | 0.20 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | 0.20 |
| INITIAL span, %fs | | | | | | 94 | 93 | 90 |
| FINAL span, %fs | | | | | | 94.5 | 93 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 0.50 | 0.00 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.12 | 0.00 | 0.00 |

RUN #2
NOx/CO/O2
@ 68° F
EMISSION DATA

| 10:53 AM - 11:33 AM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @ 15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|-------------------|-------|----------|
| NOx emissions | 14.74 | 39.5 | 114.7 | 37.8 | 71.85 | 0.1378 |
| CO emissions | 14.74 | 6.5 | 19.0 | 6.3 | 7.23 | 0.0139 |
| Fuel F factor 8637 DSCF/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 253967 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|-------------|-------------|----------------|--------------|-------------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | - | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 10:53 AM | - | 11:03 AM | 69.8 | 50.8 | 15.7 | 14.76 | 40.77 | 6.37 |
| 11:03 AM | - | 11:13 AM | 69.9 | 49.3 | 16.0 | 14.74 | 39.17 | 6.70 |
| 11:13 AM | - | 11:23 AM | 70.1 | 49.3 | 15.8 | 14.73 | 39.08 | 6.52 |
| 11:23 AM | - | 11:33 AM | 70.2 | 49.3 | 15.8 | 14.71 | 38.99 | 6.54 |
| Averages | | | 70.0 | 49.7 | 15.8 | 14.74 | 39.50 | 6.53 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.5 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | -0.10 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | -0.10 |
| INITIAL span, %fs | | | | | | 94.5 | 93 | 90 |
| FINAL span, %fs | | | | | | 95.7 | 93.8 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 1.20 | 0.80 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.30 | 0.80 | 0.00 |

RUN #3
NOx/CO/O2
@ 68° F
EMISSION DATA

| 11:39 AM - 12:19 PM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @15% O2 | lb/hr | lb/MMBtu |
|---|-------|------|------------------|------------------|-------|----------|
| NOx emissions | 14.69 | 38.6 | 111.2 | 36.7 | 70.25 | 0.1337 |
| CO emissions | 14.69 | 6.7 | 19.2 | 6.3 | 7.40 | 0.0141 |
| Fuel F factor 8637 DSCF/MMBtu (See Fuel Analysis Section) | | | | | | |
| DSCFM 253967 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|---|----------|--------------|-------------|-------------|----------------|--------------|-------------|
| TIME INTERVAL | | | % FULL SCALE | | | CONCENTRATIONS | | |
| BEGIN | - | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm |
| 11:39 AM | - | 11:49 AM | 69.0 | 49.0 | 15.9 | 14.66 | 38.64 | 6.65 |
| 11:49 AM | - | 11:59 AM | 69.2 | 49.0 | 15.8 | 14.66 | 38.62 | 6.55 |
| 11:59 AM | - | 12:09 PM | 69.5 | 49.0 | 16.0 | 14.69 | 38.61 | 6.76 |
| 12:09 PM | - | 12:19 PM | 69.8 | 49.0 | 16.0 | 14.73 | 38.60 | 6.76 |
| Averages | | | 69.4 | 49.0 | 15.9 | 14.69 | 38.62 | 6.68 |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | | O2 | NOx | CO |
| FULL SCALE RANGE | | | | | | 25 | 100 | 100 |
| CALIBRATION GAS VALUE | | | | | | 20.9 | 83.03 | 82.51 |
| INITIAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| FINAL zero, %fs | | | | | | 10 | 10 | 9.4 |
| ZERO DRIFT % fs | | | | | | 0.00 | 0.00 | 0.00 |
| ZERO DRIFT ppm or % | | | | | | 0.00 | 0.00 | 0.00 |
| INITIAL span, %fs | | | | | | 94 | 93.8 | 90 |
| FINAL span, %fs | | | | | | 95 | 93.9 | 90 |
| CALIBRATION DRIFT % fs | | | | | | 1.00 | 0.10 | 0.00 |
| CALIBRATION DRIFT ppm or % | | | | | | 0.25 | 0.10 | 0.00 |

EPA Method 18

EPA METHOD 18, HYDROCARBON RESULTS

| SAMPLE # | C1 Methane | C2 Ethane(s) | C3 Propane(s) | C4 Butane(s) | C5 Pentane(s) | C6 + Hexane(s) | Total | Total Non Methane |
|-------------------------|---------------|-----------------|------------------|-----------------|------------------|-------------------|-------|----------------------|
| Run #1: | | | | | | | | |
| ppm | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| ppm @ 3% O2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| ppm as Methane | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr as Methane | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Run #2: | | | | | | | | |
| ppm | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| ppm @ 3% O2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| ppm as Methane | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr as Methane | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| Run #3: | | | | | | | | |
| ppm | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| ppm @ 3% O2 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| ppm as Methane | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| lb/hr as Methane | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| METHOD BLANK, | | | | | | | | |
| ppm | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 | 0.0 |
| DETECTION LIMIT, ppm | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |

SUPPORTING DATA

| | Run #1 | Run #2 | Run #3 |
|-------|--------|--------|--------|
| %O2 | 15.1 | 15.1 | 15.1 |
| DSCFM | 250088 | 250088 | 250088 |

Fuel Analysis

PACIFIC GAS TECHNOLOGY



2122 G Street
 Bakersfield, California 93301
 805/324-1317
 Fax: 805/324-2746

GAS ANALYSIS BY CHROMATOGRAPH

TITAN ENVIRONMENTAL
 18828 HIGHWAY 65
 BAKERSFIELD, CA 93308

SAMPLED: 8-Dec-93

SUBMITTED: 9-Dec-93

ATTENTION: TIM BRENNEN

REPORTED: 16-Dec-93

LAB # 93-6856-1

Sample ID : US BORAX
 COGEN

PURCHASE

PROJECT # : 450-040

ORDER #: 0002288

ANALYZED GAS

| | MOLE % | WT % | CHONS | WT % |
|------------------|--------|-------|-----------|---------|
| OXYGEN | 0.08 | 0.15 | CARBON | 73.05 |
| NITROGEN | 1.24 | 1.99 | HYDROGEN | 23.52 |
| CARBON DIOXIDE | 0.70 | 1.77 | OXYGEN | 1.43 |
| HYDROGEN | ND | 0.00 | NITROGEN | 1.99 |
| CARBON MONOXIDE | ND | 0.00 | SULFUR | 0.00 |
| HYDROGEN SULFIDE | ND | 0.00 | | |
| METHANE | 91.87 | 84.61 | EPA | |
| ETHANE | 5.18 | 8.94 | F FACTOR: | 8637.36 |
| PROPANE | 0.75 | 1.90 | 68 DEG F | |
| iso-BUTANE | 0.07 | 0.23 | 1 atm | |
| n-BUTANE | 0.07 | 0.23 | F FACTOR: | 8507.80 |
| iso-PENTANE | 0.02 | 0.08 | 60 DEG F | |
| n-PENTANE | 0.01 | 0.04 | 1 atm | |
| HEXANE + | 0.01 | 0.05 | | |
| TOTAL : | 100.00 | | | |

| | | | |
|--------------------------------|--------------------|---------------|-------|
| SPECIFIC GRAVITY * : | 0.602 | TOTAL * DRY : | 1045 |
| | | BTU/cu ft | |
| SPECIFIC VOLUME : | 21.83 cu ft/lb | WET : | 1027 |
| | | BTU/lb | 22808 |
| Sample ID : TEDLAR BAG PUC GAS | | NET * DRY : | 942 |
| Lab No. : 6856-1 | | BTU/cu ft | |
| TOTAL SULFUR as | | WET : | 926 |
| Hydrogen Sulfide : | ND < 1 ppm(GC\FPD) | BTU/lb | 20562 |

* CALCULATED ACCORDING TO : ASTM D-3588



Methods and Equations

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS)

*Reference: State of California Air Resources Board, Test Methods 1-100, June 1979
EPA CFR Title 40, Pt. 60, Appendix A, Method 3A, 6C, 7E, 10 and 20.*

Instrument Summary

A constant sample of flue gas was extracted, dried, filtered and delivered to an instrument manifold system for distribution to one or more analyzers. Instrument results were recorded on an analog strip chart recorder. System calibration checks were performed as well as calibration checks at the beginning and end of each test run. Final data reduction includes zero and calibration drift corrections.

Sample Conditioning System

The sample conditioning system consists of a borosilicate glass tube or 316 grade stainless steel probe fitted with a sintered stainless steel or pyrex glass wool particulate filter. The probe was fitted with a teflon (TFE) sample line which connects to a water condensation system located at the source. The condensation system consisted of three 500-ml short stem glass impingers connected in a series, immersed in an ice bath. The gas was delivered to the instrument trailer with a diaphragm pump. The sample system was leak checked prior to sampling by plugging the end of the sample probe and adjusting the sample pump to its maximum rate (approximately 22" Hg). A zero leak condition was indicated by the sampling flow rotometers dropping to zero.

Manifold System

The sample gas was delivered to each analyzer through a five way valve and regulated with a needle valve flow rotometer. Manifold pressure was controlled by a back pressure regulator which is typically set at three psi. Zero gas (N₂) and calibrated gases were delivered to the analyzers using the same five way valve and flow meter. All manifold parts are glass, stainless steel, or teflon materials.

Analog Strip Chart Data Reduction

Analog recordings consist of averaged time increments as shown on the data pages (typically 5, 10, or 20 minute increments). Data for each increment were recorded at an average percent of full scale. The readings were then compared with the zero and calibration readings for calculation of the average concentration for each time increment. Any deviation of the zero and calibration readings from the start to the end of a test period was corrected by calculating apparent zero and calibration readings for the mid-point of each time increment. The average concentrations were calculated from the sample readings and the apparent zero and span readings.

SAMPLING AND ANALYTIC PROCEDURES


Method(s) 1-4 and 5

Reference: EPA Code of Federal Regulations, Title 40, Part 60, Appendix A; Methods 1, 2, 3, 4, and 5.

Sampling Apparatus

The sampling apparatus consisted of a nozzle, a heater-wrapped probe, and a heated filter holder (the data sheets indicated the type of nozzle, probe and filter). The filter was connected to a heated teflon filter-to-impinger line. A series of impingers (data sheets indicated the type and contents) were connected in tandem and immersed in an ice bath. Following the absorption train, was a gas pump, dry gas meter, and a calibrated restriction orifice fitted with a magnehelic differential pressure gauge. A type "S" pitot tube and temperature probe was then positioned alongside the probe terminating at the sample nozzle, for the purpose of monitoring duct conditions throughout the test.

Sampling Diagram



EPA Method 1: Sampling and Velocity Traverses for Stationary Sources

Prior to the source testing, a site assessment was performed to determine the sample points that obtained the best representative measurements of pollution concentrations and volumetric flow rates. EPA Method 1 takes into account duct area, straight run and cyclonic, or stratified flow patterns.

SAMPLING AND ANALYTIC PROCEDURES

Method(s) 1-4 and 5

(Continued)

EPA Method 2: Velocity and Volumetric Flow Rates

A computer was used in selection of suitable sample/traverse points. The calibrated pitot tube was connected to a magnehelic gauge and leak checked. A temperature and ΔP was then recorded at each traverse point and a duct static pressure was also measured and recorded. A volume flow rate was calculated from the measured traverse points.

EPA Method 3: % CO₂, % O₂, Dry Molecular Weight

Concurrent with each particulate sampling, an integrated gas sample was withdrawn from the summation of the traverse points, through the train and collected at the outlet of the meter into a sample bag. The contents of the sample bladder was analyzed by Orsat for fixed gas composition.

EPA Method 4: Percent Water

Tare weights of the charged individual impingers were recorded prior to sampling. After sampling, the final weights were recorded and percent water calculated from the weight of water collected and the dry gas volume sampled.

EPA Method 5: Particulate Emissions

A series of preliminary measurements were made prior to conducting the particulate test. EPA Methods 1, 2, and 3 were performed to determine location and number of traverse points, average gas velocity, and pressure and gas molecular weight. Percent water was determined by a psychometric chart or from combustion analysis of the fixed gases. The results of these measurements were entered into the field computer for the purpose of determining an appropriate nozzle size for isokinetic sampling.

The Method 5 apparatus was then prepared on-site in the mobile laboratory. The absorption train was charged with freshly prepared chemicals, weighted on a calibrated digital balance to the nearest 0.1 grams, and assembled. The probe was brushed out and rinsed with distilled water and acetone, then the filter holder was charged. The sampling apparatus was sealed and transported to the sampling site where it was assembled and leak tested at 15 inches mercury vacuum.

The probe, filter and impinger line heaters were set at 250 degrees F and the probe was positioned into the duct at the first traverse point with the nozzle out of the flow.

The nozzle was positioned into the gas flow and the vacuum pump was started immediately and adjusted to obtain an isokinetic sample rate. A complete traverse was performed while sampling at a minimum of two minutes per sample point.

SAMPLING AND ANALYTIC PROCEDURES

Method(s) 1-4, and 5

(Continued)

EPA Method 5 (Continued):

Upon completion of the traverse, the vacuum pump was turned off and the probe transferred into the next sample EPA port where an identical sample-traverse was then performed. Duct conditions (temperature, ΔP) and sampling conditions (meter temperature, volume and pressure, probe, filter, sample line, impinger temperatures, and absorption train vacuum) was monitored and recorded regularly for each sample point.

Upon completion of sampling, the apparatus was leak tested at a vacuum greater than the highest observed vacuum. The leak was recorded and the apparatus was then sealed and transported to the mobile laboratory. The heated filter-to-impinger line was rinsed with a known amount of distilled water into the first impinger.

The filter and any loose particulate was carefully removed from the filter holder with tweezers. It was then placed in a labeled petri dish and transported to the laboratory. The nozzle, probe, and filter top housing was rinsed and brushed three times with distilled water and acetone. The sample fractions were combined, bottled, labeled, and the fluid level marked for transportation to the laboratory. Aliquots of distilled water and acetone were similarly treated for blank analysis.

The absorption train was inspected for abnormalities and disassembled. The impingers were weighed on a digital balance for a percent moisture determination. The contents of the impingers were quantitatively transferred into separate bottles, sealed, labeled, and fluid level marked for transportation to the laboratory for analysis, if required. Aliquots of the reagent grade impinger contents will be saved for blank analysis.

The filter was transferred to an oven and heated at 105° F for 2-3 hours and then placed in a desiccator for 24 hours. The filter was then weighed on a Mettler digital balance to the nearest 0.01mg. Additional six hour desiccations and weighings were then performed until the difference between consecutive weighings were less than 0.5 mg or one percent of the total filtrate weight (weighed to a constant weight).

The nozzle/probe/filter top wash was examined for any leakage during transportation and transferred to a tared evaporation dish. The wash was then evaporated at an elevated temperature, below the boiling point of the wash, with occasional swirling. The dish and wash residue was then desiccated and weighed to a constant weight.

The net weight of particulate was calculated from the two fractions (three fractions including the impinger contents, if required). Concentrations (gr/DSCF) and emissions (lbs/hr) or other applicable units were then calculated and reported.

EPA Method 18 Hydrocarbon Emissions Testing FID Analysis

Reference: EPA Code of Federal Regulations, Title 40, Part 60 Appendix A, Method 18; Measurement of Gaseous Organic Compound Emissions by Gas Chromatography.

Sampling Procedures

The sample was drawn via an evacuated canister through a stainless steel/teflon probe into a tedlar bag. Each sample was evacuated and then filled.


The sampling apparatus consisted of a stainless steel probe, teflon sample line, and a two liter tedlar bag housed in a rigid, air-tight container (evacuated canister). The container was connected to a vacuum pump/rotameter/dry gas meter assembly.

The sampling apparatus was transported to the sampling site, set up, and leak tested by observing a zero reading on the rotameter. The sample probe/teflon line was purged with stack gas and the three-way valve opened to initiate the sampling. Sampling was conducted over a twenty minute period, at the end of which a final leak test was performed and the bag recovered from the sample container.

The samples were stored out of the sunlight, packaged and delivered to the analytical laboratory for analysis of $C_1 - C_6+$ by flame ionization detector.

A bag blank (zero grade nitrogen) was included with each sample set.

Sampling Diagram



INTEGRATED BAG SAMPLING TRAIN

EPA Method 18
Hydrocarbon Emissions Testing
FID Analysis (Continued)

Analytical Procedures

The contents of the tedlar bag were analyzed by gas chromatography. The gas chromatograph was calibrated with an appropriate standard for each carbon number, both before and after each set of samples were analyzed. The sample is speciated by carbon number - C₁, C₂, C₃, C₄, C₅, and C₆ + backflush.

Symbol Identification

- i = Carbon number; i = 1 through 6+
- s = Refers to standard for the indicated carbon number
- Rx_i = Response factor for C_i
- MW = Molecular Weight - g/mole
- DSCFM = Average volume flow rate of unit tested

Equations

$$Rx_i = \frac{\text{Area std}}{\text{ppm std}}$$

$$\text{Sample ppm}_i = \frac{1}{Rx_i} \times \text{Area}_i$$

$$\text{Sample ppm (as C}_1) = \text{Sample ppm} \times \# \text{ of Carbons}$$

$$\frac{\text{lbs}}{\text{hr}_i} = \text{ppm}_i \times MW_i \times \text{DSCFM} \times 1.581 \times 10^{-7}$$

$$\text{Total non-methane } \frac{\text{lbs}}{\text{hr}} = \sum_{i=2}^{6+} \frac{\text{lbs}}{\text{hr}_i}$$

Note 1: If lbs/hr as methane is required, MW will equal 16.0 (MW of methane, CH₄)

Note 2: Number of carbons: ethane = 2, propane = 3, etc.

EQUATIONS

EPA Method 2 Stack Gas Velocity and Volumetric Flowrate

Average Stack Gas Velocity

Equation 2-1

$$P_g = \frac{\text{Static Pressure, H}_2\text{O}}{13.6}$$

$$P_s = P_{bar} + P_g$$

Equation 2-2

$$V_s = K_p C_p (\sqrt{\Delta P}) \text{ avg} \sqrt{\frac{T_{s \text{ (avg)}}}{P_s M_s}}$$

Average Stack Gas Volumetric Flow Rate

Equation 2-3

$$Q_{std} = 60 (1 - B_{ws}) V_s A \left[\frac{T_{std}}{T_{s \text{ (avg)}}} \right] \left[\frac{P_s}{P_{std}} \right]$$

$$\frac{Q_{std}}{MF} = \text{SCFM}$$

EQUATIONS

EPA Method 3 Dry Molecular Weight of Stack Gas

Equation 3-1

$$M_d = 0.44 (\% \text{CO}_2) + 0.320 (\% \text{O}_2) + 0.280 (\% \text{N}_2 + \% \text{CO})$$

Wet Molecular Weight of Stack Gas

Equation 3-2

$$M_s = M_d(1 - B_{ws}) + 18(B_{ws})$$

Equations

EPA Method 3 Orsat Analysis

Dry Molecular Weight of Stack Gas

Equation 3-3

$$M_d = 0.440 (\% \text{CO}_2) + 0.320 (\% \text{O}_2) + 0.280 (\% \text{N}_2 + \% \text{CO})$$

Wet Molecular Weight of Stack Gas

Equation 3-4

$$M_s = M_d (1 - B_{ws}) + 18 (B_{ws})$$

EQUATIONS

EPA Method 4 Determination of Moisture Content in Stack Gases

Volume of Water Vapor Condensed

Equation 4-1

$$V_{wc (std)} = \frac{(V_f - V_i) \rho_w RT_{std}}{P_{std} M_w} = K_1 (V_f - V_i)$$

Where : $K_1 = 0.04646 \frac{ft^3}{ml} @ 520^\circ R$

Volume of Water Vapor Collected in Silica Gel

Equation 4-2

$$V_{wsg (std)} = \frac{(W_f - W_i) RT_{std}}{P_{std} M_w (453.6 \text{ g/lb})}$$
$$= K_2 (W_f - W_i)$$

Where : $K_2 = 0.04651 \frac{ft^3}{g} @ 520^\circ R$

EQUATIONS

EPA Method 4 Determination of Moisture Content in Stack Gases (Continued)

Sample Gas Volume

Equation 4-3

$$\begin{aligned}V_{m (std)} &= V_m Y \left[\frac{(P_m) (T_{std})}{(P_{std}) (T_m)} \right] \\ &= K_3 Y \frac{V_m P_m}{T_m}\end{aligned}$$

$$\text{Where: } K_3 = 17.38 \frac{^{\circ}R}{\text{"Hg}} @ 520^{\circ} R$$

Moisture Content

Equation 4-4

$$B_{ws} = \frac{V_{wc (std)} + V_{wsg (std)}}{V_{wc (std)} + V_{wsg (std)} + V_m (std)}$$

$$B_{ws} \times 100 = \% H_2O \text{ in gas stream}$$

$$MF = 1 - B_{ws}$$

**EPA METHOD 5
DETERMINATION OF PARTICULATE EMISSIONS FROM STATIONARY SOURCES**

Use in Method 5 and 8 combinations runs

Dry Gas Volume
Eq. 5-1

$$\begin{aligned}
 V_{m(std)} &= V_m Y \left(\frac{T_{std}}{T_m} \right) \left[P_{bar} + \frac{\Delta H}{13.6} \right] \\
 &= K_1 V_m Y \left[\frac{P_{bar} + \frac{\Delta H}{13.6}}{T_m} \right] \\
 &= K_1 = 17.38 \frac{^\circ R}{in.Hg} @ 520 ^\circ R
 \end{aligned}$$

*In case of leak rate beyond allowable limits, correct Eq. 5-1 as follows:

Case 1 - No component changes made during run.

$$V_m = V_m - (L_p - L_a) \theta$$

Case 2 - One or more component changes made during run.

$$V_m = \left[V_m - (L_1 - L_a) \theta_1 - \sum_{i=2}^n (L_i - L_a) \theta_i - (L_p - L_a) \theta_p \right]$$

EPA METHOD 5
(con't)

Volume of Water Vapor
Eq. 5-2

$$V_{wc (std)} = V_{1c} \left(\frac{\rho_w}{M_w} \right) \left(\frac{RT_{std}}{P_{std}} \right)$$
$$= K_2 V_{1c}$$

Where: $K_2 = 0.04646 \frac{ft^3}{ml} @ 60^\circ F$

Moisture Content
Eq. 5-3

$$B_{ws} = \frac{V_{wc (std)}}{V_{m (std)} + V_{wc (std)}}$$

Acetone Blank Concentration
Eq. 5-4

$$C_a = \frac{M_a}{V_a \rho_a}$$

Acetone Wash Blank
Eq. 5-5

$$W_a = C_a V_{aw} \rho_a$$

**EPA METHOD 5
(con't)**

**Particulate Concentration
Eq. 5-6**

$$C_s = \frac{gr}{dscf} = \left(0.001 \frac{g}{mg} \right) \left(\frac{M_n}{V_{m(std)}} \right) (15.432)$$

$$gr/dscf (MF) = \frac{gr}{scf}$$

Corrected to 12 % CO₂

$$\frac{gr}{dscf} @ 12\% CO_2 = \frac{\frac{gr}{dscf} \times 12\% CO_2}{\% CO_2 (dry)}$$

Isokinetic Variation

Eq. 5-7 and 5-8

$$\% I = 100 \times \frac{T_s \left[V_{1c} K_3 + \frac{V_m}{T_m} \left(P_b + \frac{\Delta H}{13.6} \right) \right]}{60 \theta A_n V_s P_s}$$

Where: $K_3 = 0.002669$

Mass Emission Rate

$$\frac{lbs}{hr} = \frac{gr}{dscf} \times dscfm \times 60 \frac{m}{hr} \times \frac{1 lb}{7000 gr}$$

NOMENCLATURE

- A** = Cross-sectional area of stack (ft²)
A_n = Cross-sectional area of nozzle, (ft²)
B_{wa} = Proportion of water vapor, by volume, in the gas stream
C_a = Acetone blank residue concentration, (mg/g)
C_p = Pitot tube coefficient, dimensionless
C_s = Concentration of particulate matter in stack gas, dry basis corrected to standard conditions, (gr/dscf)
C_{SO2} = Concentration of sulfur dioxide dry basis corrected to standard conditions, (lb/dscf)
C_{H2SO4} = Sulfuric acid (including SO₃) concentration, corrected to standard conditions, (lb/dscf)
ΔH = Average pressure differential across the orifice meter, (in H₂O)
K_p = Pitot tube constant, $85.49 \frac{\text{ft} \left[\frac{(\text{lb}/\text{lb-mole})(\text{in Hg}) \right]^{1/2}}{\text{sec} \left[\text{°R} \right] (\text{in H}_2\text{O})}$
L_p = Leakage rate observed during the post-test leak check, (cfm)
L_a = Maximum acceptable leakage rate, (0.02 cfm or 4% of average sampling rate, whichever is less)
L = Individual leakage rate observed during the leak check conducted prior to the "ith" component change, (cfm)
M_a = Mass of residue of acetone after evaporation, mg
M_g = Molecular weight of stack gas, dry basis, (lb/lb-mole)
M_n = Total weight of particulate matter collected, mg
M_s = Molecular weight of stack gas, wet basis, (lb/lb-mole)
M_w = Molecular weight of water, 18 lb/lb-mole
N = Normality of barium perchlorate titrant, (milliequivalents/ml)
ΔP = Velocity head of stack gas, (in H₂O)
P_{bar} = Barometric pressure at measurement site (in Hg)
P_g = Stack static pressure, (in Hg)
P_m = Absolute pressure at the dry gas meter, (P_{bar} + ΔH/13.6)
P_s = Absolute stack gas pressure, (inches Hg)
P_(std) = Standard absolute pressure, 29.92 in Hg
Q_(std) = Dry volumetric stack gas flow rate, standard conditions, (dscfm)
R = Ideal gas constant, 21.85 (in Hg) (ft³)/(lb-mole)(°R)
t_s = Stack temperature, (°F)
T_m = Absolute temperature at meter, (°R)
T_(std) = Standard absolute temperature, (520°R)
T_s = Absolute stack temperature, (460° + t_s)
V_a = Volume of sample aliquot titrated, (ml)
V_{ab} = Volume of acetone blank, ml
V_m = Dry gas volume measured by dry gas meter, (dcf)
V_{m(std)} = Dry gas volume measured by dry gas meter, corrected to standard conditions, (dscf)
V_{wc(std)} = Volume of water vapor condensed corrected to standard conditions, (scf)
V_{wsg(std)} = Volume of water vapor collected in silica gel corrected to standard conditions (scf)

NOMENCLATURE

(continued)

- V_{ic} = Volume of water vapor condensed in impingers and silica gel, (ml)
 V_f = Final volume of condensed water, ml
 V_i = Initial volume of condensed water, ml
 v_s = Average stack gas velocity, (ft/sec)
 V_{soln} = Total volume of solution in which the sulfur dioxide sample is contained (ml)
 V_t = Volume of barium perchlorate titrant used for the sample, (ml)
 V_{tb} = Volume of barium perchlorate titrant used for the blank, (ml)
 W_f = Final weight of silica gel or silica gel plus impinger, (g)
 W_i = Initial weight of silica gel or silica gel plus impinger, (g)
 Y = Dry gas meter calibration factor
 ρ_w = Density of water, (0.002202 lb/ml @ 60°F)
 ρ_a = Density of acetone, (g/ml)(see bottle label)
MF = Moisture factor
%CO₂ = Percent CO₂ by volume (dry basis)
%O₂ = Percent O₂ by volume (dry basis)
%CO = Percent CO by volume (dry basis)
%N₂ = Percent N₂ by volume (dry basis)
0.264 = Ratio of O₂ to N₂ in air v/v
0.280 = Molecular weight of N₂ or CO, divided by 100
0.320 = Molecular weight of O₂, divided by 100
0.440 = Molecular weight of CO₂, divided by 100
60 = Conversion factor, (sec/min)
18.0 = Molecular weight of water, (lb/lb-mole)
32.03 = Equivalent weight of sulfur dioxide
 θ = Total sampling time (min)
 θ_i = Sampling time interval, between two successive component changes, beginning with the interval between the first and second changes, (min)
 θ_1 = Sampling time interval, from the run beginning until first component change, (min)
 θ_p = Sampling time interval, from the final (nth) component change until the end of the sampling run, (min)

Raw Data

TITAN ENVIRONMENTAL ON-SITE DATA SHEET

COMPANY : US Borax
 UNIT : Cogen #2
 PROJECT : 458 - 039

RUN #: 1
 DATE: 12-8-93
 TIME: 911-1524

V_m, Dry sampled gas volume, dcf 284.81
Y, Meter calibration factor (Met# C001) ,983223
P_{bar}, Barometric Pressure, "Hg 27.68
P_{static}, Stack static pressure, "Hg -0.60
 ΔH , Differential meter pressure, "H2O 1.01
T_m, Meter temperature, °F 69

| CONTENTS | RUN # | | | RUN # | | | RUN # | | |
|--|-------|-------|-------|-------|------|-----|-------|------|-----|
| | FINAL | TARE | NET | FINAL | TARE | NET | FINAL | TARE | NET |
| H ₂ O | 847.4 | 565.0 | 282.4 | | | | | | |
| H ₂ O | 845.5 | 558.5 | 287.0 | | | | | | |
| DM | 481.0 | 475.0 | 6.0 | | | | | | |
| DM | 469.1 | 466.2 | 2.9 | | | | | | |
| Silica | 832.0 | 787.5 | 44.5 | | | | | | |
| XW | 81.1 | 29.3 | 51.8 | | | | | | |
| <i>V_c</i> , volume of H ₂ O, gms | | | 571.0 | | | | | | |

CO₂, % Dry Volume 2.7
O₂, % Dry Volume 15.1
N₂, % Dry Volume _____
C_p, Pitot Tube Coefficient (# 5' #2) .84
 Δp , Avg P, "H2O .817
T_s, Stack temperature, °F 307
A_s, Stack Area, sq.ft. 113.7
D_s, Stack diameter, inches 144.38
D_n, Nozzle diameter, inches .244
D_{ur}, Sampling time, min 360
 % ISO, Mini iso _____

Filter # 36
 Filter tare weights, gms 58723

Comments: _____

TITAN ENVIRONMENTAL
FIELD DATA SHEET

METHOD 5 RUN # 1 CONT.


COMPANY: U.S. Borax
 UNIT: TYRONE QUARRY
 DATE: 12-8-93
 PROJECT: 450-039
 TECH: RJK
 PUMP #: 6AST.
 METER BOX #: C001 (1.00)
 METER COEFF: 0.983223
 PROBE #: P555-2 Cp: 0.84

PRE POST TEST LEAK CHECK
 LEAK RATE: < 0.003 cfm
 VACUUM: 2" Hg

AMBIENT TEMP. °F: 53°
 Pbar: 27.66 27.68
 STATIC PRESSURE ("Hg): -0.60
 ASSUMED MOISTURE, %: 8% 17W 27.5
 NOZZLE ID #: 4-1
 AVG. CALIB. NOZZLE DIAM. ("): 0.244
 PROBE LINER MATERIAL: SS
 FILTER #:

| TRAVERSE PT. NUMBER | TIME (e) min. / s / pt. | VACUUM "Hg | STACK TEMP (Ts) °F | VELOCITY HEAD (Δ P) in. H2O | PRESSURE DIFFERENTIAL, "H2O | | GAS SAMPLE VOLUME (cu. ft) | GAS SAMPLE TEMP. | | FILTER HOLDER 4 TEMP. °F | 3 TEMP OF GAS EXIT CONDENSER OR LAST IMPINGER | |
|---------------------|-------------------------|------------|--------------------|-----------------------------|-----------------------------|------|----------------------------|------------------|------------|--------------------------|---|----|
| | | | | | RATE | Δ H | | INLET, °F | OUTLET, °F | | | |
| S.W. | | | | | | | | | | | | |
| 5 | 12:20 | 5 | 327 | 1.05 | 0.922 | 1.23 | 816.5 | 81 | 81 | 250 | 249 | 57 |
| 4 | 12:38 | 5 | 324 | 1.05 | 0.922 | 1.24 | 833.1 | 82 | 78 | 246 | 256 | 56 |
| 3 | 12:56 | 5 | 325 | 1.00 | 0.899 | 1.18 | 849.7 | 82 | 78 | 246 | 255 | 56 |
| 2 | 13:14 | 5 | 325 | 0.95 | 0.872 | 1.12 | 865.8 | 79 | 76 | 248 | 254 | 57 |
| 1 | 13:32 | 5 | 323 | 0.75 | 0.776 | 0.90 | 881.6 | 78 | 77 | 249 | 253 | 58 |
| N.W. | 13:50 | | | | | | 895.7 | | | | | |
| 5 | 13:58 | 5 | 323 | 1.00 | 0.888 | 1.17 | 895.7 | 74 | 72 | 248 | 252 | 59 |
| 4 | 14:16 | 5 | 320 | 0.95 | 0.820 | 1.00 | 911.6 | 74 | 71 | 249 | 253 | 56 |
| 3 | 14:34 | 5 | 321 | 0.95 | 0.866 | 1.11 | 926.5 | 73 | 72 | 250 | 254 | 56 |
| 2 | 14:52 | 5 | 321 | 0.90 | 0.842 | 1.06 | 942.1 | 73 | 71 | 249 | 253 | 57 |
| 1 | 15:10 | 5 | 321 | 0.75 | 0.770 | 0.89 | 957.3 | 73 | 72 | 249 | 252 | 58 |
| END | 15:28 | | | | | | 971.01 | | | | | |
| | | | | | | | 161 = 284.81 | | | | | |
| | | | | | | | 159 = 98.62 | | | | | |
| | | | | | | | 161.75 = 65.21 | | | | | |
| AVG | | | 307 | 0.817 | | 1.91 | | | | | | 69 |

TITAN ENVIRONMENTAL
VELOCITY TRAVERSE



COMPANY: US BORAX
 UNIT: TURBINE OUTLET
 DATE: 12-7-93
 PROJECT: 450-039
 TECH: RJK + RTE
 PUMP #: GAST
 METER BOX#: C001
 METER COEFF: 0.983223 (1.00)
 PROBE #: P555#2 Cp: 0.84

TOTAL 12' 7.875
 COUPLING 19.5"
 DIAMETER 147.38"
 AREA 113.70

163.88'

TRAVERSE POINTS Port: N.E.

| W/O | W/COUP | NO. | Ts, °F | Δ P | Port: | Ts, °F | Δ P |
|------|--------|---------------|--------|------|-------|--------|-----|
| 3.7 | 23.2 | 1 | 323 | 0.70 | | | |
| 11.8 | 31.3 | 2 | 325 | 0.85 | | | |
| 21.1 | 40.6 | 3 | 326 | 0.95 | | | |
| 32.6 | 52.1 | 4 | 326 | 1.00 | | | |
| 49.4 | 68.9 | 5 | 325 | 0.90 | | | |
| | | 6 | | | | | |
| | | 7 | | | | | |
| | | 8 | | | | | |
| | | 9 | | | | | |
| | | 10 | | | | | |
| | | 11 | | | | | |
| | | 12 | | | | | |
| | | 13 | | | | | |
| | | 14 | | | | | |
| | | 15 | | | | | |
| | | 16 | | | | | |
| | | 17 | | | | | |
| | | 18 | | | | | |
| | | 19 | | | | | |
| | | 20 | | | | | |
| | | 21 | | | | | |
| | | 22 | | | | | |
| | | 23 | | | | | |
| | | 24 | | | | | |
| | | 25 | | | | | |
| | | 26 | | | | | |
| | | 27 | | | | | |
| | | 28 | | | | | |
| | | 29 | | | | | |
| | | 30 | | | | | |

VELOCITY DATA

| | |
|----------------------|----------|
| Rated Total MMBtu/HR | Vel |
| Δ P 0.877 | DSCFM |
| Ts 325 | MMBtu/hr |
| Static -0.60 | % Thr |
| Pbar 27.62 | |
| MW(wet) 27.5 | |
| %H2O 16 | |
| %O2 | |
| °F, (@ 60°) | |

Additional Data:
 0.250 = 0.818
 1/2 - 2 @ 244 =

Diameters before disturbance _____ Diameters after disturbance _____
 Total number of traverse points _____

**TITAN ENVIRONMENTAL
LABORATORY ANALYSIS**

METHOD 5 - GRAVIMETRIC ANALYSIS

COMPANY: US BORAX PROJECT: 450-030
 UNIT: Cogen ANALYSIS DATE: 12-12-93
 TEST DATE: 12-8-93 RUN #: meth5 #1

| PROBE AND NOZZLE WASH | | | | |
|-----------------------|---------|----------|----|---------|
| DISH #: 15 | | ALIQUOT: | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 71.4186 | 71.4186 | | 71.4186 |
| INITIAL WEIGHT (gm) | 71.4154 | 71.4153 | | 71.4154 |
| NET WEIGHT (gm) | | | | 0.0032 |

| FILTER | | | | |
|---------------------|---------|----------|----|---------|
| FILTER #: 36 | | ALIQUOT: | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 0.58812 | 0.58813 | | 0.58813 |
| INITIAL WEIGHT (gm) | 0.58723 | | | 0.58723 |
| NET WEIGHT (gm) | | | | 0.00090 |

| CONDENSABLES - AQUEOUS | | | | |
|-----------------------------------|---------------|---------------------|---------------|--------------------|
| DISH #: | | ALIQUOT: | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | | | | |
| INITIAL WEIGHT (gm) | | | | |
| NET WEIGHT (gm) | | | | |

| CONDENSABLES - ORGANIC | | | | |
|-----------------------------------|---------------|---------------------|---------------|--------------------|
| DISH #: | | ALIQUOT: | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | | | | |
| INITIAL WEIGHT (gm) | | | | |
| NET WEIGHT (gm) | | | | |

COMMENTS: _____

 12/16
 ANALYST SIGNATURE

**TITAN ENVIRONMENTAL
OPERATING DATA SHEET**

COMPANY : US Borax
 UNIT : Cogen
 DATE : 12-8-93
 PROJECT : 450-039

OISAT DATA


| Bag # | 1 | 2 | 3 | | | |
|-----------------------|------|------|---|--|--|--|
| | | | | | | |
| CO ₂ Final | 2.6 | 2.8 | | | | |
| Initial | 0.0 | 0.0 | | | | |
| | | | | | | |
| % CO ₂ | 2.6 | 2.8 | | | | |
| | | | | | | |
| | | | | | | |
| O ₂ Final | 17.7 | 17.3 | | | | |
| Initial | 2.6 | 2.8 | | | | |
| | | | | | | |
| % O ₂ | 15.1 | 14.5 | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |
| | | | | | | |

US BORAX
450-039
TURBINE, METH 18, METHOD BLANK

93/12/10

11:05:18


⊕ Shimadzu



CHROMATOGRAM 27 MEMORIZED
WARNING NO PEAK

US BORAX
450-039
TURBINE, METH 18, RUN 1
93/12/10

11:23:00




CHROMATOGRAM 27 MEMORIZED
WARNING NO PEAK

1 2 3

223-02037-02

US BORAX
450-039
TURBINE, METH 18, RUN 2
93/12/10

11:41:07




CHROMATOGRAM 27 MEMORIZED
WARNING NO PEAK

⊕ Shimadzu


US BORAX
450-039
TURBINE, METH 18, RUN 3
93/12/10

11:59:35




CHROMATOGRAM 27 MEMORIZED
WARNING NO PEAK
93/12/10

13:20:03



CHROMATOGRAM 27 MEMORIZED
WARNING NO PEAK
93/12/10

13:27:44



12
4


223-02037-02

Shimo

| CHROMATOGRAM | 27 | MEMORIZED | | | | |
|--------------|--------|-----------|----|------|----------|------|
| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
| 1 | 3.234 | 299285 | | 6 | 106.5815 | C-6+ |
| 2 | 3.808 | 43718 | V | 1 | 97.9515 | C-1 |
| 3 | 4.301 | 88234 | V | 2 | 99.493 | C-2 |
| 4 | 5.282 | 131494 | | 3 | 100.0859 | C-3 |
| 5 | 7.542 | 174663 | | 4 | 100.4333 | C-4 |
| 6 | 12.572 | 175752 | | 5 | 95.0893 | C-5 |
| TOTAL | | 913145 | | | 599.6343 | |

| GROUP(NAME) | CONC |
|-------------|----------|
| C-1 | 97.9515 |
| C-2 | 99.493 |
| C-3 | 100.0859 |
| C-4 | 100.4333 |
| C-5 | 95.0893 |
| C-6+ | 106.5815 |

Strip Charts



O₂ 0-25 (10.9, 4.12)
 NO_x 0-100 (83.03, 41.47)
 CO 0-100 (82.5, 41.24)

450-039
 US Borax
 Cognex
 12/7/93 Setup day

Titan Environmental
 P.S. SA DAVIS
 Tech RJ Kastner
 RT Ernst

Quality Assurance

INSTRUMENTATION QA CHECKLIST

DATE 12-7-93

| CONSTITUENT | <u>O₂</u> | <u>NO_x</u> | <u>CO</u> | |
|-----------------------------------|-------------------------|-------------------------|-------------------------|-------------------------|
| <u>INSTRUMENT</u> | | | | |
| MAKE | <u>Teledyne</u> | <u>Teco</u> | <u>Teco</u> | |
| MODEL | <u>320 A2</u> | <u>105</u> | <u>48</u> | |
| SERIAL NUMBER | | | | |
| RANGE | <u>0-25</u> | <u>0-100</u> | <u>0-100</u> | |
| <u>CYLINDER#/GAS VALUE</u> | <u>NO. VALUE</u> | <u>NO. VALUE</u> | <u>NO. VALUE</u> | <u>NO. VALUE</u> |
| CYLINDER 1 | <u>CC48271 0</u> | <u>CC48271 0</u> | <u>CC48271 0</u> | |
| CYLINDER 2 | <u>CC4932 4.12</u> | <u>AAL7386 41.47</u> | <u>AAL7386 41.24</u> | |
| CYLINDER 3 | <u>- 20.9</u> | <u>ALM 12206 83.03</u> | <u>ALM 12200 82.51</u> | |
| CYLINDER 4 | | | | |
| <u>SYSTEM BIAS %fs</u> | <u>zero cal</u> | <u>zero cal</u> | <u>zero cal</u> | <u>zero cal</u> |
| INTERNAL | <u>9.5 93</u> | <u>10 93.2</u> | <u>10.0 92.1</u> | |
| EXTERNAL | <u>9.5 94.5</u> | <u>10.2 93</u> | <u>9.9 92</u> | |
| INTERNAL | | | | |
| EXTERNAL | | | | |
| <u>LINEARITY</u> | | | | |
| OBSERVED/ACTUAL | <u>0 0</u> | <u>0 0</u> | <u>0</u> | |
| OBSERVED/ACTUAL | <u>4.1 4.12</u> | <u>41.3 41.47</u> | <u>41.24</u> | |
| OBSERVED/ACTUAL | <u>21.3 20.9</u> | <u>84 83.03</u> | <u>82.51</u> | |
| OBSERVED/ACTUAL | | | | |

Did all Instruments pass a System Bias Check (+\ - 5%) ?

yes

Did all Instruments pass Linearities (+\ - 2%) ?

yes

What was the Initial and Final leak check readings ?

< 0.01 @ 24 in Hg

What portion of the Exhaust gas NO_x was NO₂ (%) ?

> 5%

Was a NO_x:NO Conversion Check performed?

yes

Were all Calibration Gases In Cert (18 months) ?

yes

Misc notes _____

**TITAN ENVIRONMENTAL
DRY GAS METER CALIBRATION**

| | | | |
|--------------------|----------------|-------------------------|------------------|
| DATE: | 11-3-93 | AMBIENT TEMP °F: | 57 |
| TECH: | RJK | BAROMETRIC Pbar: | 29.86 |
| METER I.D.# | COO1 | TEST METER ID#: | 93U766141 |
| | | TEST METER Mcf: | 1.0000 |

| APPROXIMATE CFM | | 0.75 | 0.50 | 0.30 |
|--|----------------|----------|----------|----------|
| STD TEST METER VOLUME CF | INITIAL | 0.000 | 0.000 | 0.000 |
| | FINAL | 7.260 | 14.170 | 8.480 |
| | TOTAL | 7.260 | 14.170 | 8.480 |
| FIELD GAS METER VOLUME CF | INITIAL | 286.10 | 243.70 | 233.10 |
| | FINAL | 293.51 | 258.22 | 241.81 |
| | TOTAL | 7.41 | 14.52 | 8.71 |
| STD TEST METER TEMP (°F) | | 72.0 | 64.0 | 60.0 |
| FIELD GAS METER TEMP (°F) | IN | 82.0 | 72.0 | 65.0 |
| | OUT | 73.0 | 65.0 | 60.0 |
| | AVERAGE | 77.5 | 68.5 | 62.5 |
| STD TEST METER PRESSURE ("H2O) | | -0.05 | -0.05 | -0.01 |
| FIELD GAS METER PRESSURE ("H2O) | | 0.75 | 0.30 | 0.09 |
| FIELD GAS METER, Mcf | | 0.988061 | 0.983550 | 0.978058 |

| | | | |
|---------------------------|-----------------|------------|---------------|
| FIELD AVERAGE Mcf: | 0.983223 | H@: | 0.7954 |
|---------------------------|-----------------|------------|---------------|



Special Gases
An operating unit of the BOC Group, Inc.

569789

680 N. Baldwin Park Blvd.
P.O. Box 868
City of Industry, CA 91749
Telephone: 818-369-1035
FAX: 818-333-1629

ANALYTICAL REPORT

To: Bakersfield Welding Supply
2701 Fruitvale Avenue
Bakersfield, CA 93308

Date Reported: 07-08-93
Test Number: 43942
Fill Date: 07-08-93
Product Vol: 142 cf

Material Submitted: Nitrogen UHP, Grade 5.0

Specification Number: Airco Specifications, Minimum Purity: 99.999%

Method of Analysis: Trace Oxygen Analyzer, Total Hydrocarbon Analyzer,
Moisture Monitor

Source Container No: 43941

Result of Investigation: Cylinder No. CC48771 Size 152

| <u>Component</u> | <u>Specification</u> | <u>Concentration</u> |
|--------------------|----------------------|----------------------|
| Oxygen | 1 ppm | < 1 ppm |
| Total Hydrocarbons | 0.5 ppm | <0.5 ppm |
| Moisture | 1 ppm | < 1 ppm |
| Nitric Oxide | | <0.1 ppm |
| Carbon Monoxide | | <0.1 ppm |
| Nitrogen | Balance | Balance |

By *Ronald J. Garcia*
Check for OEE SPEC result.
Authorized Signature



Special Gases

An operating unit of the BOC Group, Inc.

569791

680 N. Baldwin Park Blvd.
P.O. Box 868
City of Industry, CA 91749
Telephone: 818-369-1035
FAX: 818-333-1629

ANALYTICAL REPORT

To: Bakersfield Welding Supply
2701 Fruitvale Avenue
Bakersfield, CA 93308

Date Reported: 07-13-93
Test Number: 48738
Fill Date: 07-07-93
Product Vol: 140 cf

Material Submitted: 4% Oxygen, Balance Nitrogen

Specification Number: Airco Specifications

Method of Analysis: Percent Oxygen Analyzer

Result of Investigation: Cylinder No. CC4932 Size 152

| <u>Component</u> | <u>Specification</u> | <u>Concentration</u> |
|------------------|----------------------|----------------------|
| Oxygen | 4% | 4.12 % |
| Nitrogen | Balance | Balance |

By 
Authorized Signature



Scott Specialty Gases, Inc.

2600 CAJON BOULEVARD, SAN BERNARDINO, CA 92411

(909) 887-2571 FAX: (909) 887-0549

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TITAN ENVIRONMENTAL
SCOTT DAVID
18828 HIGHWAY 65
BAKERSFIELD, CA 93308

Assay Laboratory
Scott Specialty Gases
2600 Cajon Boulevard
San Bernardino, CA 92411

Purchase Order 2127
Project # 26497.005

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure #G1, Section Number 3.0.4

Cylinder Number AAL7380
Cylinder Pressure 1900 psig

Certification Date 07-28-93

GENERAL Date 01-28-94

ACID RAIN DATE:

ANALYZED CYLINDER

Components

CARBON MONOXIDE
NITRIC OXIDE
SULFUR DIOXIDE

Certified Concentration

41.24 PPM
41.40 PPM
40.19 PPM

Analytical Uncertainty*

± 1 % NIST Traceable

Balance Gas: Nitrogen
NOX

41.47 PPM

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

| Type | Expiration Date | Cylinder Number | Concentration |
|------|-----------------|-----------------|---------------|
| GMIS | 06-94 | ALM026614 | 96.23 ppm |
| GMIS | 09-94 | ALM033883 | 99.12 ppm |
| GMIS | 06-94 | ALM025735 | 48.52 ppm |

INSTRUMENTATION

| Instrument/Model/Serial # | Last Date Calibrated | Analytical Principle |
|------------------------------|----------------------|----------------------|
| Horiba / OPE-135D / 56565502 | 07-12-93 | NDIR |
| TECO / 10AR / 38644-258 | 05-11-93 | Chemi-Luminescent |
| Horiba / OPE-135D / 56463601 | 07-01-93 | NDIR |

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

| Components | First Triad Analysis | Second Triad Analysis | Calibration Curve |
|-----------------|---|---|---|
| Carbon Monoxide | <p>Date: 07-20-93 Response Units: mv</p> <p>Z1= 0.00 R1= 97.0 T1= 42.7 R2= 97.0 Z2= 0.00 T2= 42.7 Z3= 0.00 T3= 42.7 R3= 97.0</p> <p>Avg. Conc. of Cust Cyl. 41.16 ppm</p> | <p>Date: 07-28-93 Response Units: mv</p> <p>Z1= 0.00 R1= 97.0 T1= 42.8 R2= 97.0 Z2= 0.00 T2= 42.9 Z3= 0.00 T3= 42.9 R3= 97.0</p> <p>Avg. Conc. of Cust Cyl. 41.32 ppm</p> | <p>Concentration= Ax^2+Bx+C</p> <p>A = 0.0005081 B = 0.9438 C = -0.07474</p> |
| Nitric Oxide | <p>Date: 07-20-93 Response Units: mv</p> <p>Z1= 0.00 R1= 95.7 T1= 40.1 R2= 95.8 Z2= 0.00 T2= 40.1 Z3= 0.00 T3= 40.1 R3= 95.8</p> <p>Avg. Conc. of Cust Cyl. 41.50 ppm</p> | <p>Date: 07-27-93 Response Units: mv</p> <p>Z1= 0.00 R1= 96.5 T1= 40.2 R2= 96.5 Z2= 0.00 T2= 40.2 Z3= 0.00 T3= 40.2 R3= 96.5</p> <p>Avg. Conc. of Cust Cyl. 41.29 ppm</p> | <p>Concentration= Ax^2+Bx+C</p> <p>A = -0.0005080 B = 1.054 C = -0.1090</p> |
| Sulfur Dioxide | <p>Date: 07-20-93 Response Units: mv</p> <p>Z1= 0.00 R1= 97.0 T1= 80.1 R2= 97.0 Z2= 0.00 T2= 80.2 Z3= 0.00 T3= 80.2 R3= 97.0</p> <p>Avg. Conc. of Cust Cyl. 40.18 ppm</p> | <p>Date: 07-28-93 Response Units: mv</p> <p>Z1= 0.00 R1= 97.0 T1= 80.2 R2= 97.0 Z2= 0.00 T2= 80.2 Z3= 0.00 T3= 80.2 R3= 97.0</p> <p>Avg. Conc. of Cust Cyl. 40.20 ppm</p> | <p>Concentration= $Ax + B$</p> <p>A = 0.5010 B = 0.007534</p> |

SPECIAL NOTES: IF THIS PRODUCT IS USED FOR ACID RAIN COMPLIANCE, THE ACID RAIN EXPIRATION DATE NOTED ABOVE APPLIES PER 40 CFR PART 75, APPENDIX H. OTHERWISE THE GENERAL EXPIRATION DATE APPLIES.

Joseph De La Torre
Analyst Joseph De La Torre



Scott Specialty Gases, Inc.

2600 CAJON BOULEVARD, SAN BERNARDINO, CA 92411

(909) 887-2571 FAX: (909) 887-0549

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS

Customer
TITAN ENVIRONMENTAL
SCOTT DAVID
18828 HIGHWAY 65
BAKERSFIELD, CA 93308

Assay Laboratory
Scott Specialty Gases
2600 Cajon Boulevard
San Bernardino, CA 92411

Purchase Order 2127
Project # 26497.012

ANALYTICAL INFORMATION

Certified to exceed the minimum specifications of EPA Protocol 1 Procedure #G1, Section Number 3.0.4

Cylinder Number ALM012200
Cylinder Pressure 1950 psig

Certification Date 07-28-93

GENERAL Date 07-28-95

ACID RAIN DATE

ANALYZED CYLINDER

Components

CARBON MONOXIDE

Certified Concentration

82.51 PPM

Analytical Uncertainty*

± 1 % NIST Traceable

NITRIC OXIDE

82.77 PPM

SULFUR DIOXIDE

82.10 PPM

Balance Gas: Nitrogen

83.03 PPM

NOX

*Analytical uncertainty is inclusive of usual known error sources which at least includes reference standard error & precision of the measurement processes.

REFERENCE STANDARD

Type **Expiration Date**
GMIS 06-94
GMIS 09-94
GMIS 06-94

Cylinder Number
ALM026614
ALM033883
AAL1977

Concentration
96.23 ppm
99.12 ppm
236.8 ppm

INSTRUMENTATION

Instrument/Model/Serial #
Horiba / OPE-135D / 56565502
TECO / 10AR / 38644-258
Horiba / OPE-135D / 56463601

Last Date Calibrated
07-12-93
05-11-93
07-01-93

Analytical Principle
NDIR
Chemi-Luminescent
NDIR

ANALYZER READINGS (Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

Components

First Triad Analysis

Second Triad Analysis

Calibration Curve

Carbon Monoxide

Date: 07-21-93 **Response Units: mv**
Z1= 0.00 R1= 97.0 T1= 83.8
R2= 97.0 Z2= 0.00 T2= 83.8
Z3= 0.00 T3= 83.8 R3= 97.0
Avg. Conc. of Cust Cyl. 82.59 ppm

Date: 07-28-93 **Response Units: mv**
Z1= 0.00 R1= 97.0 T1= 83.6
R2= 97.0 Z2= 0.00 T2= 83.7
Z3= 0.00 T3= 83.6 R3= 97.0
Avg. Conc. of Cust Cyl. 82.42 ppm

Concentration= Ax^2+Bx+C
A = -0.0005081
B = -0.9438
C = -0.07474

Nitric Oxide

Date: 07-20-93 **Response Units: mv**
Z1= 0.00 R1= 96.4 T1= 80.5
R2= 96.4 Z2= 0.00 T2= 80.5
Z3= 0.00 T3= 80.5 R3= 96.4
Avg. Conc. of Cust Cyl. 82.77 ppm

Date: 07-27-93 **Response Units: mv**
Z1= 0.00 R1= 96.7 T1= 80.7
R2= 96.8 Z2= 0.00 T2= 80.8
Z3= 0.00 T3= 80.8 R3= 96.7
Avg. Conc. of Cust Cyl. 82.76 ppm

Concentration= Ax^2+Bx+C
A = -0.0005080
B = -1.054
C = -0.1090

Sulfur Dioxide

Date: 07-21-93 **Response Units: mv**
Z1= 0.00 R1= 97.0 T1= 35.0
R2= 97.0 Z2= 0.00 T2= 35.0
Z3= 0.00 T3= 35.0 R3= 97.0
Avg. Conc. of Cust Cyl. 81.90 ppm

Date: 07-28-93 **Response Units: mv**
Z1= 0.00 R1= 97.0 T1= 35.1
R2= 97.0 Z2= 0.00 T2= 35.2
Z3= 0.00 T3= 35.2 R3= 97.0
Avg. Conc. of Cust Cyl. 82.30 ppm


Concentration= Ax^2+Bx+C
A = 0.001592
B = 2.287
C = -0.1186

SPECIAL NOTES: IF THIS PRODUCT IS USED FOR ACID RAIN COMPLIANCE, THE ACID RAIN EXPIRATION DATE NOTED ABOVE APPLIES PER 40 CFR PART 75, APPENDIX H. OTHERWISE THE GENERAL EXPIRATION DATE APPLIES.

Joseph De La Torre
Analyst Joseph De La Torre

Initial Cal, 100 ppm

223-02037-02



Shimadzu

| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|--------|--------|----|------|------|------|
| 1 | 3.226 | 280804 | | 6 | | C-6+ |
| 2 | 3.782 | 44632 | V | 1 | | C-1 |
| 3 | 4.252 | 88684 | V | 2 | | C-2 |
| 4 | 5.223 | 131381 | | 3 | | C-3 |
| 5 | 7.474 | 173910 | | 4 | | C-4 |
| 6 | 12.441 | 184828 | | 5 | | C-5 |
| TOTAL | | 904238 | | | | |

CALIBRATION MADE IN IDENTIFICATION FILE 1
MODE# 101 WINDOW 3


| IDNO | NAME | TIME | FACTOR | CONC |
|------|------|-------|-------------|------|
| 1 | C-1 | 3.77 | 0.00224054 | 100 |
| 2 | C-2 | 4.24 | 0.00112761 | 100 |
| 3 | C-3 | 5.22 | 0.000761144 | 100 |
| 4 | C-4 | 7.47 | 0.000575011 | 100 |
| 5 | C-5 | 12.44 | 0.000541043 | 100 |
| 6 | C-6+ | 3.22 | 0.000356121 | 100 |
| 7 | C-3 | 6.13 | 0.000807318 | 100 |
| 8 | C-4 | 7.13 | 0.000613256 | 100 |
| 9 | C-5 | 11.8 | 0.000599231 | 100 |

| IDNO | NAME | TIME | FACTOR | CONC |
|------|------|-------|-------------|------|
| 1 | C-1 | 3.77 | 0.00224054 | 100 |
| 2 | C-2 | 4.24 | 0.00112761 | 100 |
| 3 | C-3 | 5.22 | 0.000761144 | 100 |
| 4 | C-4 | 7.47 | 0.000575011 | 100 |
| 5 | C-5 | 12.44 | 0.000541043 | 100 |
| 6 | C-6+ | 3.22 | 0.000356121 | 100 |
| 7 | C-3 | 6.13 | 0.000761144 | 100 |
| 8 | C-4 | 7.13 | 0.000575011 | 100 |
| 9 | C-5 | 11.8 | 0.000541043 | 100 |

ANALYSIS PARAMETER FILE 1

| | | | |
|---------|------|----------|------|
| WIDTH | 5 | SLOPE | 1000 |
| DRIFT | 20 | MIN.AREA | 200 |
| T.DBL | 0 | STOP.TM | 15 |
| ATTEN | 3 | SPEED | 5 |
| METHOD# | 0424 | FORMAT# | 2201 |
| SPL.WT | 100 | IS.WT | 1 |

100 ppm, Duplicate Cal




| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|--------|--------|----|------|----------|------|
| 1 | 3.226 | 286678 | | 6 | 102.0919 | C-6+ |
| 2 | 3.785 | 44522 | V | 1 | 99.7543 | C-1 |
| 3 | 4.255 | 88999 | V | 2 | 100.3556 | C-2 |
| 4 | 5.226 | 131828 | | 3 | 100.3402 | C-3 |
| 5 | 7.479 | 174506 | | 4 | 100.343 | C-4 |
| 6 | 12.449 | 185817 | | 5 | 100.5349 | C-5 |
| TOTAL | | 912350 | | | 603.4199 | |

| GROUP (NAME) | CONC |
|--------------|----------|
| C-1 | 99.7543 |
| C-2 | 100.3556 |
| C-3 | 100.3402 |
| C-4 | 100.343 |
| C-5 | 100.5349 |
| C-6+ | 102.0919 |

INITIAL CAL, 15 PPM

93/12/10

10:14:53



| PKNO | TIME | MEMORIZED AREA | MK | IDNO | CONC | NAME |
|-------|-------|----------------|----|------|---------|------|
| 1 | 3.217 | 42004 | | 6 | 14.9586 | C-6+ |
| 2 | 3.767 | 7343 | V | 1 | 16.4513 | C-1 |
| 3 | 4.259 | 14461 | V | 2 | 16.3069 | C-2 |
| 4 | 5.231 | 20976 | V | 3 | 15.9655 | C-3 |
| 5 | 7.467 | 27439 | | 4 | 15.778 | C-4 |
| 6 | 12.46 | 27010 | | 5 | 14.6136 | C-5 |
| TOTAL | | 139233 | | | 94.0739 | |

| GROUP(NAME) | CONC |
|-------------|---------|
| C-1 | 16.4513 |
| C-2 | 16.3069 |
| C-3 | 15.9655 |
| C-4 | 15.778 |
| C-5 | 14.6136 |
| C-6+ | 14.9586 |

12 1


223-02037-02

⊕ Shimadzu

INITIAL CAL, 1000 PPM

93/12/10

10:37:22



| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|-------|---------|----|------|-----------|------|
| 1 | 3.234 | 2886382 | | 6 | 1027.9011 | C-6+ |
| 2 | 3.788 | 463501 | V | 1 | 1038.4932 | C-1 |
| 3 | 4.259 | 938381 | V | 2 | 1058.1275 | C-2 |
| 4 | 5.23 | 1340545 | | 3 | 1020.3473 | C-3 |
| 5 | 6.919 | 2836 | | 8 | 1.6305 | C-4 |
| 6 | 7.483 | 1777184 | V | 4 | 1021.9004 | C-4 |
| 7 | 12.45 | 1931076 | | 5 | 1044.795 | C-5 |
| 8 | 13.6 | 2218 | V | | | |
| TOTAL | | 9342121 | | | 6213.1943 | |

| GROUP (NAME) | CONC |
|--------------|-----------|
| C-1 | 1038.4932 |
| C-2 | 1058.1275 |
| C-3 | 1020.3473 |
| C-4 | 1023.5308 |
| C-5 | 1044.795 |
| C-6+ | 1027.9011 |


12 2

223-02037-02

93/12/10

13:27:44

302037-02



Shimadzu


| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|--------|--------|----|------|----------|------|
| 1 | 3.234 | 299285 | | 6 | 106.5815 | C-6+ |
| 2 | 3.808 | 43718 | Y | 1 | 97.9515 | C-1 |
| 3 | 4.301 | 88234 | Y | 2 | 99.493 | C-2 |
| 4 | 5.282 | 131494 | | 3 | 100.0859 | C-3 |
| 5 | 7.542 | 174663 | | 4 | 100.4333 | C-4 |
| 6 | 12.572 | 175752 | | 5 | 95.0893 | C-5 |
| TOTAL | | 913145 | | | 599.6343 | |

| GROUP(NAME) | CONC |
|-------------|----------|
| C-1 | 97.9515 |
| C-2 | 99.493 |
| C-3 | 100.0859 |
| C-4 | 100.4333 |
| C-5 | 95.0893 |
| C-6+ | 106.5815 |

FINAL CAL, 15 PPM

93/12/10

13:49:04



| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|--------|--------|----|------|---------|------|
| 1 | 3.229 | 42016 | | 6 | 14.9628 | C-6+ |
| 2 | 3.742 | 7682 | V | 1 | 17.2116 | C-1 |
| 3 | 4.208 | 14944 | V | 2 | 16.8506 | C-2 |
| 4 | 5.175 | 21412 | V | 3 | 16.2977 | C-3 |
| 5 | 7.436 | 27935 | | 4 | 16.0631 | C-4 |
| 6 | 12.386 | 28936 | | 5 | 15.6555 | C-5 |
| TOTAL | | 142925 | | | 97.0414 | |

| GROUP (NAME) | CONC |
|--------------|---------|
| C-1 | 17.2116 |
| C-2 | 16.8506 |
| C-3 | 16.2977 |
| C-4 | 16.0631 |
| C-5 | 15.6555 |
| C-6+ | 14.9628 |

125


223-02037-02

⊕ Shimadzu

FINAL CAL, 1000 PPM, ATTEN 7

93/12/10

14:22:46



⊕ Shimadzu

| PKNO | TIME | AREA | MK | IDNO | CONC | NAME |
|-------|--------|---------|----|------|-----------|------|
| 1 | 3.229 | 2855105 | | 6 | 1016.7626 | C-6+ |
| 2 | 3.763 | 471087 | V | 1 | 1055.489 | C-1 |
| 3 | 4.23 | 948851 | V | 2 | 1069.9334 | C-2 |
| 4 | 5.195 | 1356034 | | 3 | 1032.1367 | C-3 |
| 5 | 6.872 | 2916 | | | | |
| 6 | 7.433 | 1797092 | V | 4 | 1033.3474 | C-4 |
| 7 | 12.376 | 2013772 | | 5 | 1089.5372 | C-5 |
| 8 | 13.508 | 2227 | V | | | |
| TOTAL | | 9447081 | | | 6297.2055 | |

| GROUP (NAME) | CONC |
|--------------|-----------|
| C-1 | 1055.489 |
| C-2 | 1069.9334 |
| C-3 | 1032.1367 |
| C-4 | 1033.3474 |
| C-5 | 1089.5372 |
| C-6+ | 1016.7626 |

**TITAN ENVIRONMENTAL
LABORATORY ANALYSIS**

METHOD 5 - GRAVIMETRIC ANALYSIS

COMPANY: US Borax PROJECT: 450-040
 UNIT: _____ ANALYSIS DATE: 12-11-91
 TEST DATE: 12-9-93 RUN #: _____

| PROBE AND NOZZLE WASH - SPIKE 100 ml _s | | | | |
|---|----------|---------|----|----------|
| DISH #: <u>19</u> | ALIQUOT: | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 71.4287 | 71.4284 | | 71.42866 |
| INITIAL WEIGHT (gm) | 71.4064 | | | 71.4064 |
| NET WEIGHT (gm) | | | | 0.02226 |

| FILTER BLANK | | | | |
|---------------------|---------|---------|----|---------|
| FILTER #: <u>31</u> | | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 0.58938 | 0.58933 | | 0.58936 |
| INITIAL WEIGHT (gm) | 0.58935 | | | 0.58935 |
| NET WEIGHT (gm) | | | | 0.00001 |

| CONDENSABLES - AQUEOUS H ₂ O BLANK | | | | |
|---|------------------------------------|---------|----|---------|
| DISH #: <u>6</u> | ALIQUOT: <u>100 ml_s</u> | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 71.6819 | 71.6818 | | 71.6819 |
| INITIAL WEIGHT (gm) | 71.6814 | 71.6814 | | 71.6814 |
| NET WEIGHT (gm) | | | | 0.00050 |

| CONDENSABLES - ORGANIC | | | | |
|------------------------|----------|----|----|---------|
| DISH #: | ALIQUOT: | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | | | | |
| INITIAL WEIGHT (gm) | | | | |
| NET WEIGHT (gm) | | | | |

COMMENTS: Spike = 100 ml_s * 218.9 mg/l = 21.89 ∴ 101.7 % recovery

J (12/16)
ANALYST SIGNATURE

**TITAN ENVIRONMENTAL
LABORATORY ANALYSIS**

METHOD 5 - GRAVIMETRIC ANALYSIS

COMPANY: US BORAX PROJECT: 450-040
 UNIT: _____ ANALYSIS DATE: 12-11-91
 TEST DATE: 12-9-93 RUN #: QA Method Blank


| PROBE AND NOZZLE WASH #1 | | | | |
|--------------------------|---------|---------|----|---------|
| DISH #: | 9 | | | |
| | ALIQOT: | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 72.3893 | 72.3890 | | 72.3892 |
| INITIAL WEIGHT (gm) | 72.3867 | 72.3866 | | 72.3867 |
| NET WEIGHT (gm) | | | | 0.00250 |

| FILTER | | | | |
|--------------------------------|---------------|---------------|---------------|--------------------|
| FILTER #: | | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | | | | |
| INITIAL WEIGHT (gm) | | | | |
| NET WEIGHT (gm) | | | | |

| CONDENSABLES - AQUEOUS #1 | | | | |
|---------------------------|-----------------|---------|----|---------|
| DISH #: | 24 | | | |
| | ALIQOT: 200/400 | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | 68.5640 | 68.5642 | | 68.5641 |
| INITIAL WEIGHT (gm) | 68.5633 | 68.5633 | | 68.5633 |
| NET WEIGHT (gm) | | | | 0.00080 |

| CONDENSABLES - ORGANIC | | | | |
|------------------------|---------|----|----|---------|
| DISH #: | | | | |
| | ALIQOT: | | | |
| WEIGHT: | #1 | #2 | #3 | AVERAGE |
| FINAL WEIGHT (gm) | | | | |
| INITIAL WEIGHT (gm) | | | | |
| NET WEIGHT (gm) | | | | |

COMMENTS: _____

 12/16
 ANALYST SIGNATURE

Source Test Protocol

**Kern County Air Pollution Control District
and
Environmental Protection Agency (EPA)**

Source Test Protocol

for

**U.S. Borax & Chemical Corporation
Boron Facility**

48 MW Cogeneration Facility

Prepared by

Titan Environmental

Project 450-039

Submitted November 17, 1993

Table of Contents

| | | |
|------|-------------------------------------|----|
| I. | Source Test Protocol | 2 |
| | A. Project Information | 3 |
| | B. General Approach | 4 |
| | C. Testing Specifics | 5 |
| II. | Source Test Methods | 6 |
| III. | Source Test Reporting Formats | 13 |
| IV. | Permits to Operate | 20 |

Source Test Protocol

Project Information

Company: U.S. Borax & Chemical Corporation
14486 Borax Road
Boron, CA 93516
(619) 762-7000 FAX (619) 762-7335

Attention: Mike Kirby

Source(s): Turbine/Cogeneration Facility
KCAPCD Permit No. 1004077A
EPA Permit No. NSR 4-4-11 SE 82-02

Source Description: The unit to be tested is one Westinghouse frame W-251 48-MW gas turbine equipped with 210 MMBtu/hr duct burners; heat recovery steam generator (HRSG); and a 48-MW electric generator.

Operating Parameters: The unit will be tested at normal operating conditions, approximately 45 MW.

Independent Contractor: Titan Environmental
18828 Highway 65
Bakersfield, CA 93308
(805) 391-0112 FAX (805) 391-0153

Attention: Tim Brennan

Testing Objective: The objective of the testing is to document compliance with EPA and KCAPCD permit conditions for annual source testing.

Test Date: December 8, 1993

Testing Parameters

Testing is to determine concentrations (gr/DSCF), ppm) and emissions (lb/hr) of particulate matter (PM), NO_x, CO and NMHC from the exhaust of one 48-MW cogeneration facility. PM, NO_x and CO will be sampled to satisfy EPA permit conditions. NO_x, CO, NMHC and fuel sulfur will be sampled to satisfy Kern County APCD permit conditions. The following methods will be used.

Table 1 - General Approach

| Parameter | Method | Analysis Method | Test Runs Per Unit | Permit Limits | |
|-----------------|----------------------|---|--------------------|------------------------------|--|
| | | | | EPA | SJVUA |
| PM | EPA Method 5 | Gravimetric analysis of front half | 1 6 Hour | 14.0 lb/hr | N/A |
| NO _x | EPA Method 7E | TECO Model 10; Chemiluminescent | 3 40 Minute | 268.2 lb/hr 0.57 lb/MMBtu | 268 lb/hr 90ppm @ 15% O ₂ |
| CO | EPA Method 10 | TECO Model 48; Gas Filter Correlation | 3 40 Minute | 446 lb/hr | 446 lb/hr |
| O ₂ | EPA Method 3A | Teledyne Model 320AR; Micro Fuel Cell | 3 40 Minute | N/A | N/A |
| NMHC | EPA Method 18 | GC-FID Analysis for C ₁ - C ₆ + | 3 | N/A | 2.9 lb/hr |
| Volume Flow | EPA Methods 2, 3, 4 | Pitot Tube Traverse/ Condensation Train Simultaneous w/Method 5 | 1 6 Hour | N/A | N/A |
| Fuel Sulfur | Tedlar Bag Sample | GC-FPD analysis for Total Sulfur | 1 | N/A | 146 lb/hr SO ₂ |
| Fuel Sample | Stainless Steel Bomb | GC-FID/TCD analysis for C ₁ -C ₆ +, O ₂ , CO ₂ , N ₂ | 1 | N/A | N/A |

Testing Parameters (Continued)

Table II - Testing Specifics

| Parameter | Analytical Lab | Units of Measurement | Minimum Detection Limit | Anticipated Range |
|-----------------|------------------------|-----------------------------------|-------------------------|-------------------|
| PM | Titan Environmental | gr/DSCF, lb/hr | 0.0002 gr/DSCF | 0.002 gr/DSCF |
| NO _x | Titan Environmental | ppm, ppm @ 15% lb/hr, lb/MMBtu | 1 ppm | 0 - 100 ppm |
| CO | Titan Environmental | ppm, ppm @ 15% lb/hr, lb/MMBtu | 1 ppm | 0 - 100 ppm |
| O ₂ | Titan Environmental | % | 0.1% vol dry | 15% vol dry |
| NMHC | Titan Environmental | ppm, lb/hr | 1 ppm | < 10 ppm |
| Volume Flow | Titan Environmental | DSCFM; MMBtu/hr | N/A | N/A |
| Fuel Sulfur | Pacific Gas Technology | H ₂ S ppm | 1 ppm | < 5 ppm |
| Fuel Sample | Pacific Gas Technology | CHONS Btu/lb | N/A | N/A |



Source Test Methods

CONTINUOUS EMISSIONS MONITORING SYSTEM (CEMS)

*Reference: State of California Air Resources Board, Test Methods 1-100, June 1979
EPA CFR Title 40, Pt. 60, Appendix A, Method 3A, 6C, 7E, 10 and 20.*

Instrument Summary

A constant sample of flue gas will be extracted, dried, filtered and delivered to an instrument manifold system for distribution to one or more analyzers. Instrument results will be recorded on an analog strip chart recorder. System calibration checks will be performed as well as calibration checks at the beginning and end of each test run. Final data reduction includes zero and calibration drift corrections.

Sample Conditioning System

The sample conditioning system consists of a borosilicate glass tube or 316 grade stainless steel probe fitted with a sintered stainless steel or pyrex glass wool particulate filter. The probe will be fitted with a teflon (TFE) sample line which connects to a water condensation system located at the source. The condensation system will consist of three 500-ml short stem glass impingers connected in a series, immersed in an ice bath. The gas will be delivered to the instrument trailer with a diaphragm pump. The sample system will be leak checked prior to sampling by plugging the end of the sample probe and adjusting the sample pump to its maximum rate (approximately 22" Hg). A zero leak condition will be indicated by the sampling flow rotometers dropping to zero.

Manifold System

The sample gas will be delivered to each analyzer through a five way valve and regulated with a needle valve flow rotometer. Manifold pressure will be controlled by a back pressure regulator which is typically set at three psi. Zero gas (N₂) and calibrated gases will be delivered to the analyzers using the same five way valve and flow meter. All manifold parts are glass, stainless steel, or teflon materials.

Analog Strip Chart Data Reduction

Analog recordings consists of averaged time increments as shown on the data pages (typically 5, 10, or 20 minute increments). Data for each increment will be recorded at an average percent of full scale. The readings will then be compared with the zero and calibration readings for calculation of the average concentration for each time increment. Any deviation of the zero and calibration readings from the start to the end of a test period will be corrected by calculating apparent zero and calibration readings for the mid-point of each time increment. The average concentrations will be calculated from the sample readings and the apparent zero and span readings.

EPA Method 18
Hydrocarbon Emissions Testing
FID Analysis (Continued)

Analytical Procedures

The contents of the tedlar bag will be analyzed by gas chromatography. The gas chromatograph will be calibrated with an appropriate standard for each carbon number, both before and after each set of samples are analyzed. The sample is speciated by carbon number - C₁, C₂, C₃, C₄, C₅, and C₆ + backflush.

Symbol Identification

- i = Carbon number; i = 1 through 6+
- s = Refers to standard for the indicated carbon number
- R_{x_i} = Response factor for C_i
- MW = Molecular Weight - g/mole
- DSCFM = Average volume flow rate of unit tested

Equations

$$R_{x_i} = \frac{\text{Area std}}{\text{ppm std}}$$

$$\text{Sample ppm}_i = \frac{1}{R_{x_i}} \times \text{Area}_i$$

$$\text{Sample ppm (as C}_1\text{)} = \text{Sample ppm} \times \# \text{ of Carbons}$$

$$\frac{\text{lbs}}{\text{hr}_i} = \text{ppm}_i \times \text{MW}_i \times \text{DSCFM} \times 1.581 \times 10^{-7}$$

$$\text{Total non-methane } \frac{\text{lbs}}{\text{hr}} = \sum_{i=2}^{6+} \frac{\text{lbs}}{\text{hr}_i}$$

Note 1: If lbs/hr as methane is required, MW will equal 16.0 (MW of methane, CH₄)

Note 2: Number of carbons: ethane = 2, propane = 3, etc.

SAMPLING AND ANALYTIC PROCEDURES


Method(s) 1-4, and 5

Reference: EPA Code of Federal Regulations, Title 40, Part 60, Appendix A; Methods 1, 2, 3, 4 and 5.

Sampling Apparatus

The sampling apparatus will consist of a nozzle, a heater-wrapped probe, and a heated filter holder (the data sheets will indicate the type of nozzle, probe and filter). The filter will be connected to a heated teflon filter-to-impinger line. A series of impingers will be connected in tandem and immersed in an ice bath. Following the absorption train, will be a gas pump, dry gas meter, and a calibrated restriction orifice fitted with a magnehelic differential pressure gauge. A type "S" pitot tube and temperature probe will then be positioned alongside the probe terminating at the sample nozzle for the purpose of monitoring duct conditions throughout the test.

Sampling Diagram



EPA Method 1: Sampling and Velocity Traverses for Stationary Sources

Prior to the source testing, a site assessment will be performed to determine the sample points that will obtain the best representative measurements of pollution concentrations and volumetric flow rates. EPA Method 1 takes into account duct area, straight run and cyclonic, or stratified flow patterns.

SAMPLING AND ANALYTIC PROCEDURES

Method(s) 1-4 and 5

(Continued)

EPA Method 2: Velocity and Volumetric Flow Rates

A computer will be used in selection of suitable sample/traverse points. The calibrated pitot tube will be connected to a magnehelic gauge and leak checked. A temperature and $-P$ will then be recorded at each traverse point and a duct static pressure will also be measured and recorded. A volume flow rate will be calculated from the measured traverse points.

EPA Method 3: % CO₂, % O₂, Dry Molecular Weight

Concurrent with each particulate sampling, an integrated gas sample will be withdrawn from the summation of the traverse points, through the train and collected at the outlet of the meter into a sample bag. The contents of the sample bladder will be analyzed by Orsat for fixed gas composition.

EPA Method 4: Percent Water

Tare weights of the charged individual impingers are recorded prior to sampling. After sampling, the final weights will be recorded and percent water calculated from the weight of water collected and the dry gas volume sampled.

EPA Method 5: Particulate Emissions

A series of preliminary measurements will be made prior to conducting the particulate test. EPA Methods 1, 2, and 3 will be performed to determine location and number of traverse points, average gas velocity, and pressure and gas molecular weight. Percent water will be determined by a psychrometric chart or from combustion analysis of the fixed gases. The results of these measurements will be entered into the field computer for the purpose of determining an appropriate nozzle size for isokinetic sampling.

The Method 5 apparatus will then be prepared on-site in the mobile laboratory. The absorption train will be charged with freshly prepared chemicals, weighted on a calibrated digital balance to the nearest 0.1 grams, and assembled. The probe will be brushed out and rinsed with distilled water and acetone, then the filter holder will be charged. The sampling apparatus will be sealed and transported to the sampling site where it will be assembled and leak tested at 15 inches mercury vacuum.

The probe, filter and impinger line heaters will be set at 250 degrees F and the probe will be positioned into the duct at the first traverse point with the nozzle out of the flow.

The nozzle is to be positioned into the gas flow and the vacuum pump will be started immediately and adjusted to obtain an isokinetic sample rate. A complete traverse will be performed while sampling at a minimum of two minutes per sample point.

SAMPLING AND ANALYTIC PROCEDURES

Method(s) 1-4 and 5

(Continued)

EPA Method 5 (Continued):

Upon completion of the traverse, the vacuum pump will be turned off and the probe transferred into the next sample EPA port where an identical sample-traverse will then be performed. Duct conditions (temperature, delta-P) and sampling conditions (meter temperature, volume and pressure, probe, filter, sample line, impinger temperatures, and absorption train vacuum) will be monitored and recorded regularly for each sample point.

Upon completion of sampling, the apparatus will be leak tested at a vacuum greater than the highest observed vacuum. The leak will be recorded and the apparatus will then be sealed and transported to the mobile laboratory. The heated filter-to-impinger line will be rinsed with a known amount of distilled water into the first impinger.

The filter and any loose particulate will be carefully removed from the filter holder with tweezers. It will then be placed in a labeled petri dish and transported to the laboratory. The nozzle, probe, and filter top housing will be rinsed and brushed three times with distilled water and acetone. The sample fractions will be combined, bottled, labeled, and the fluid level marked for transportation to the laboratory. Aliquots of distilled water and acetone will be similarly treated for blank analysis.

The absorption train will be inspected for abnormalities and disassembled. The impingers will be weighed on a digital balance for a percent moisture determination. The contents of the impingers will be quantitatively transferred into separate bottles, sealed, labeled, and fluid level marked for transportation to the laboratory for analysis, if required. Aliquots of the reagent grade impinger contents will be saved for blank analysis.

The filter will be transferred to an oven and heated at 105 degrees F for 2-3 hours and then placed in a desiccator for 24 hours. The filter will then be weighed on a Mettler digital balance to the nearest 0.01mg. Additional six hour desiccations and weighings will then be performed until the difference between consecutive weighings are less than 0.5 mg or one percent of the total filtrate weight (weighed to a constant weight).

The nozzle/probe/filter top wash will be examined for any leakage during transportation and transferred to a tared evaporation dish. The wash will then be evaporated at an elevated temperature, below the boiling point of the wash, with occasional swirling. The dish and wash residue will then be desiccated and weighed to a constant weight.

The net weight of particulate will be calculated from the two fractions (three fractions including the impinger contents, if required). Concentrations (gr/DSCF) and emissions (lbs/hr) or other applicable units will then be calculated and reported.

EPA Method 18 Hydrocarbon Emissions Testing FID Analysis

Reference: EPA Code of Federal Regulations, Title 40, Part 60 Appendix A, Method 18; Measurement of Gaseous Organic Compound Emissions by Gas Chromatography.

Sampling Procedures

The sample will be drawn via an evacuated canister through a stainless steel/teflon probe into a tedlar bag. Each sample will be evacuated and then filled.


The sampling apparatus will consist of a stainless steel probe, teflon sample line, and a two liter tedlar bag housed in a rigid, air-tight container (evacuated canister). The container will be connected to a vacuum pump/rotameter/dry gas meter assembly.

The sampling apparatus will be transported to the sampling site, set up, and leak tested by observing a zero reading on the rotameter. The sample probe/teflon line will be purged with stack gas and the three-way valve will be opened to initiate the sampling. Sampling will be conducted over a twenty minute period, at the end of which a final leak test will be performed and the bag recovered from the sample container.

The samples will be stored out of the sunlight, packaged and delivered to the analytical laboratory for analysis of $C_1 - C_6+$ by flame ionization detector.

A bag blank (zero grade nitrogen) will be included with each sample set.

Sampling Diagram



Source Test Reporting Formats

TITAN ENVIRONMENTAL

SUMMARY OF SOURCE TEST RESULTS

COMPANY: XXX
UNIT: YYY
APCD #: ZZZ

PROJECT : BBB
TEST DATE : AAA

| EMISSIONS | gr/scf | gr/scf @ 12% CO2 | ppm | ppm @ 15% O2 | lb/ MMBtu | lb/hr | Permit Limits |
|------------------------|--------------|---------------------|------|-----------------|--------------|-------|------------------|
| NOx | | | 33.2 | 37.3 | | 0.122 | |
| | | | 35.1 | 33.5 | | 0.139 | |
| | | | 32.9 | 34.9 | | 0.269 | |
| | Mean: | | 33.7 | 35.2 | 0.0590 | 0.177 | |
| CO | | | 33.2 | 37.3 | | 0.122 | |
| | | | 35.1 | 33.5 | | 0.139 | |
| | | | 32.9 | 34.9 | | 0.269 | |
| | Mean: | | 33.7 | 35.2 | 0.0237 | 0.177 | |
| NMHC | | | 33.2 | 37.3 | | 0.122 | |
| | | | 35.1 | 33.5 | | 0.139 | |
| | | | 32.9 | 34.9 | | 0.269 | |
| | Mean: | | 33.7 | 35.2 | 0.0167 | 0.177 | |
| Comments: _____ | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

SUMMARY OF SOURCE TEST RESULTS FOR EPA

COMPANY: AAA

PERMIT: ZZZ

UNIT# : BBB

LOCATION: QQQ

| Pollutant | Method | Test Date | Test Results | Permit Limits |
|-----------------|--------|-----------|--------------|---------------|
| Particulate | EPA 5 | WWW | | |
| NOx as NO2 | EPA 7E | WWW | | |
| Carbon monoxide | EPA 10 | WWW | | |

*Emissions are corrected to EPA standard conditions (68°F and 29.92 inches of Hg) in units of EPA's permit.

Prepared by: TIM BRENNAN

Title: PROJECT SUPERVISOR

Date: MMM

COMPANY:
UNIT :

PROJECT
DATE :

RUN #1
NOx/CO/O2

EMISSION DATA

| 12:35 PM - 01:35 PM | %O2 | ppm | ppm @ @ 3% O2 | ppm @ @15% O2 | lb/hr |
|---|------|------|------------------|------------------|-------|
| NOx emissions | 4.50 | 40.0 | 43.7 | 14.4 | 2.44 |
| CO emissions | 4.50 | 40.0 | 43.7 | 14.4 | 1.49 |
| DSCFM = 8400 (Average of Method 2 Pitot Tube Velocity Profiles) | | | | | |

SUPPORTING DATA

| Incremental Readings, Stack Gas Measurement Data | | | | | | | | |
|--|----------|--------------|------|------|----------------|---------|--------|--|
| TIME INTERVAL | | % FULL SCALE | | | CONCENTRATIONS | | | |
| BEGIN | END | O2 | NOx | CO | O2 % | NOx ppm | CO ppm | |
| 12:35 PM | 12:45 PM | 50.0 | 50.0 | 50.0 | 4.08 | 40.00 | 40.00 | |
| 12:45 PM | 12:55 PM | 50.0 | 50.0 | 50.0 | 4.25 | 40.00 | 40.00 | |
| 12:55 PM | 01:05 PM | 50.0 | 50.0 | 50.0 | 4.42 | 40.00 | 40.00 | |
| 01:05 PM | 01:15 PM | 50.0 | 50.0 | 50.0 | 4.58 | 40.00 | 40.00 | |
| 01:15 PM | 01:25 PM | 50.0 | 50.0 | 50.0 | 4.75 | 40.00 | 40.00 | |
| 01:25 PM | 01:35 PM | 50.0 | 50.0 | 50.0 | 4.92 | 40.00 | 40.00 | |
| Averages | | 50.0 | 50.0 | 50.0 | 4.50 | 40.0 | 40.0 | |
| Calibration Data and Instrument Drift | | | | | | | | |
| | | | | | O2 | NOx | CO | |
| FULL SCALE RANGE | | | | | 10 | 100 | 100 | |
| CALIBRATION GAS VALUE | | | | | 4 | 40 | 40 | |
| INITIAL zero, %fs | | | | | 10 | 10 | 10 | |
| FINAL zero, %fs | | | | | 0 | 10 | 10 | |
| ZERO DRIFT % fs | | | | | -10.00 | 0.00 | 0.00 | |
| ZERO DRIFT ppm or % | | | | | -1.00 | 0.00 | 0.00 | |
| INITIAL span, %fs | | | | | 50 | 50 | 50 | |
| FINAL span, %fs | | | | | 40 | 50 | 50 | |
| CALIBRATION DRIFT % fs | | | | | -10.00 | 0.00 | 0.00 | |
| CALIBRATION DRIFT ppm or % | | | | | -1.00 | 0.00 | 0.00 | |

COMPANY:
UNIT :

DATE :
PROJECT

METHOD 1-5
FIELD DATA @ 60° F & 29.92 "Hg.

| DATA INPUT | | | |
|---|-----------|-----------|-----------|
| Run #: | 1 | 2 | 3 |
| Time : | 1112-1233 | 1339-1409 | 1512-1613 |
| Vm, dry gas volume sampled, ft ³ | 118.86 | 118.6 | 118.59 |
| Y, meter calibration factor | 1.008784 | 1.008784 | 1.008784 |
| P bar, Barometric pressure, "Hg | 28.95 | 28.95 | 28.95 |
| P static, stack pressure, " H ₂ O | -0.5 | -0.5 | -0.5 |
| Delta H, differential meter press, " H ₂ O | 1.38 | 1.52 | 1.52 |
| Tm, meter temperature, R° | 521.6 | 530 | 527 |
| Vol H ₂ O, grams condensed | 160.2 | 152.5 | 149.4 |
| % CO ₂ , percent volume dry | 2.3 | 2.2 | 2.3 |
| % O ₂ , percent volume dry | 16.9 | 16.9 | 16.9 |
| % N ₂ , percent volume dry | 80.8 | 80.9 | 80.8 |
| Cp, pitot tube coefficient | 0.805 | 0.805 | 0.805 |
| Avg. square root delta-p, "H ₂ O | 1.07 | 1.11 | 1.12 |
| Temp. stack, R° | 781 | 781 | 781 |
| Stack area, ft ² | 76.91 | 76.91 | 76.91 |
| Area noz, ft ² | 3.25E-04 | 3.25E-04 | 3.25E-04 |

| CALCULATED RESULTS | | | | |
|---|--------|--------|--------|---------|
| Run #: | 1 | 2 | 3 | AVERAGE |
| Vm(std); dscf, sample volume | 116.07 | 114.02 | 114.66 | na |
| Bws; H ₂ O vapor, fractional percent | 0.0603 | 0.0585 | 0.0571 | 0.0586 |
| MF; moisture factor, 1-Bws | 0.9397 | 0.9415 | 0.9429 | 0.9414 |
| Md; MW stk gas dry, lb/lb-mole | 29.04 | 29.03 | 29.04 | 29.04 |
| Ms; MW stk gas wet, lb/lb-mole | 28.38 | 28.38 | 28.41 | 28.39 |
| Vs; fps, gas velocity | 72.00 | 74.76 | 75.02 | 73.93 |
| Q-acfm; actual volume flow | 332268 | 344999 | 346199 | 341155 |
| Qstd-dscfm; dry standard volume flow | 200901 | 208989 | 210033 | 206641 |
| Sample time; minutes | 126 | 120 | 120 | na |
| % Isokinetic Sample Rate | 108.6 | 107.7 | 107.7 | na |

COMPANY
UNIT

DATE
PROJECT

EPA METHOD 5 DATA
@ 68°F & 29.92 "Hg

| PARTICULATE GRAVIMETRIC RESULTS | | | | | |
|---------------------------------|--------|---------|---------|----------------------|--------|
| RUN #1 | net mg | gr/dscf | gr/scf | gr/dscf @ 12% CO2 | lbs/hr |
| Probe & Nozzle Wash: | 1.6 | 0.00035 | 0.00032 | 0.00130 | 0.744 |
| Filter: | 3.5 | 0.00076 | 0.00070 | 0.00285 | 1.628 |
| TOTAL, front half | 5.1 | 0.00111 | 0.00102 | 0.00415 | 2.372 |

| SUPPORTING DATA | | | | | | | |
|-----------------|-------|--------|------|------|------|---------|--------|
| Run # | TIME | | %O2 | %CO2 | %H2O | Vm(std) | DSCFM |
| | start | finish | | | | | |
| 1 | 1115 | 1230 | 15.7 | 3.2 | 7.47 | 71.01 | 250000 |

PROJECT XXX-YYY
DECEMBER ZZ, 1993

EPA METHOD 18, HYDROCARBON RESULTS

| Run #1: | C1 Methane | C2 Ethane(s) | C3 Propane(s) | C4 Butane(s) | C5 Pentane(s) | C6+ Hexane(s) | Total | Non Methane | Total |
|---------------|---------------|-----------------|------------------|-----------------|------------------|------------------|-------|-------------|-------|
| ppm | 24.1 | 7.2 | 6.2 | 5.1 | 1.5 | 0.8 | 44.9 | 20.8 | 20.8 |
| ppm @ 3% O2 | 28.8 | 8.6 | 7.4 | 6.1 | 1.8 | 1.0 | 53.6 | 24.8 | 24.8 |
| lb/hr | 0.75 | 0.42 | 0.53 | 0.58 | 0.21 | 0.13 | 2.6 | 1.9 | 1.9 |
| Run #2: | | | | | | | | | |
| ppm | 22.7 | 8.2 | 5.5 | 4.2 | 1.3 | 0.7 | 42.6 | 19.9 | 19.9 |
| ppm @ 3% O2 | 26.9 | 9.7 | 6.5 | 5.0 | 1.5 | 0.8 | 50.5 | 23.6 | 23.6 |
| lb/hr | 0.75 | 0.51 | 0.50 | 0.50 | 0.19 | 0.12 | 2.6 | 1.8 | 1.8 |
| Run #3: | | | | | | | | | |
| ppm | 21.9 | 8.3 | 5.1 | 3.3 | 1.2 | 18.1 | 57.9 | 36.0 | 36.0 |
| ppm @ 3% O2 | 25.6 | 9.7 | 6.0 | 3.9 | 1.4 | 21.2 | 67.7 | 42.1 | 42.1 |
| lb/hr | 0.78 | 0.55 | 0.50 | 0.42 | 0.19 | 3.45 | 5.9 | 5.1 | 5.1 |
| METHOD BLANK, | | | | | | | | | |
| ppm | 0.2 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.7 | 0.5 | 0.5 |
| DETECTION | | | | | | | | | |
| LIMIT, ppm | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 | | | |

SUPPORTING DATA

| | Run #1 | Run #2 | Run #3 |
|-------|--------|--------|--------|
| FSC | 0830 | 0930 | 1015 |
| Time | 5.9 | 5.8 | 5.6 |
| %O2 | 12300 | 13000 | 14000 |
| DSCFM | | | |

Permit to Operate

PERMIT TO OPERATE

2700 'M' STREET, SUITE 200
 BAKERSFIELD, CA. 93301-2323
 BAKERSFIELD: (805) 861-2993
 MOJAVE: (805) 824-4631, Ext. 237

Number: 1004077(A)

PERMIT TO OPERATE IS HEREBY GRANTED TO: U.S. BORAX, INC.
 FOR EQUIPMENT LOCATED AT: Sec. 24, T11N, R08W, Boron, CA
 EQUIPMENT OR PROCESS DESCRIPTION: Co-Generation Facility I
 OPERATIONAL CONDITIONS LISTED BELOW.

THIS PERMIT BECOMES VOID UPON ANY CHANGE OF OWNERSHIP OR LOCATION, OR ANY ALTERATION.

NOTE: The permittee may be required to provide adequate sampling and testing facilities. Equipment modification requires a new permit.

THOMAS PAXSON, P.E.
 DIRECTOR APCD

REVOCABLE: This permit does not authorize the emission of air contaminants in excess of those allowed by the Rules and Regulations of the K.C.A.P.C.D.

By: 

For Period: 01-31-93 TO 01-31-94

CONDITIONAL APPROVAL:

Compliance with all conditions of approval imposed by any applicable Authority to Construct is required for life of this equipment unless modified by application.

EQUIPMENT DESCRIPTION: Cogeneration Facility I (Topping Cycle with Secondary Fuel,
 including the following equipment:

- a. Electric generator driver - one Westinghouse frame W-251 gas turbine engine with a maximum heat input rating of 550 million Btu/hr (LHV) designed to burn either gaseous or liquid fuel and equipped with:
1. Water injection oxides of nitrogen control system:
 - a. One 3,000 gal. caustic tank.
 - b. One 6,000 gal. sulfuric acid tank (see #1004078).
 - c. One 3,500 gal. neutralization tank.
 - d. Two 40 hp electric water injection pumps with water injection rate control system.
 - e. One 20,000 gal. injection water storage tank.
 2. One 20,000 gal. injection water storage tank.
 3. One inlet air filtering and conditioning system with silencer.
- b. One Co-Gen 210 million Btu/hr exclusively gas-fired duct burner with 8 rows of 20 flame stabilizers located downstream of gas turbine exhaust.
- c. Heat recovery steam generator (HSRG) - rated at 412,000 lbm/hr of 175 psig saturated steam and equipped with bypass damper and exhaust stack.
- d. Electric generator.

OPERATIONAL CONDITIONS:

1. Fuel oil sulfur content shall not exceed 0.25% by weight. (Rule 210.1 LAER requirement)
2. At rated load, water to fuel ratio shall be maintained at no less than 0.82 lbm/hr for gas firing and 0.90 lbm/lbm for oil firing (Rule 210.1 LAER requirement). These values are subject to revision upon mutual agreement by U.S. Borax and KCAPCD that lower rates are necessary to maintain reasonable levels of maintenance and equipment availability.
3. Gas turbine exhaust gas NOx concentration corrected to 15% O2 on a dry basis shall not exceed 96 ppmv for gas firing and 114 ppmv for oil firing (Rule 422 NSPS limits).
4. Exhaust stack emission rates shall not exceed the following : 268 lbm/hr for NOx, 149 lbm/hr for SOx, 446 lbm/hr for CO, 14 lbm/hr for PM and 2.9 lbm/hr for HC (Rule 210.1 dispersion modeling).
5. Combustion contaminant emissions shall not exceed 0.1 gr/scf @ 12% CO2. (Rule 407.2)

Cogen I

U.S. ENVIRONMENTAL PROTECTION AGENCY
815 FREMONT STREET
SAN FRANCISCO, CA 94105

In Reply. A-3-1
Refer to: NSR 4-4-11
SE 82-02

EPA
PTO # →

20 DEC 1982

Mr. G.M. Pepper
Principal Engineer
U.S. Borax & Chemical Corp.
P.O. Box 75128
Stanford Station
Los Angeles, CA 90075

Dear Mr. Pepper:

In accordance with provisions of the Clean Air Act, as amended (42 U.S.C. 7401 et seq.), the Environmental Protection Agency has reviewed the application submitted by the U.S. Borax and Chemical Corporation.

A request for public comment regarding EPA's proposed action on the above application has been published. After consideration of the expressed views of all interested persons (including State and local agencies), and pertinent Federal statutes and regulations, the EPA hereby issues the enclosed Approval to Construct/Modify a Stationary Source for the facilities described above. This action does not constitute a significant change from the proposed action set forth and offered for public comment.

This Approval to Construct/Modify shall take effect immediately.

Sincerely yours,

Original Signed by:

David P. Howekamp
Acting Director
Air Management Division

Enclosures

cc: CA Air Resources Board
Kern County APCD

APPROVAL TO CONSTRUCT/MODIFY
A STATIONARY SOURCE

In compliance with provisions of the Clean Air Act, as amended (42 U.S.C. 7401 et seq.), the U.S. Borax and Chemical Corporation is granted approval to construct a combustion gas turbine facility in accordance with the plans submitted with the application and with the Federal regulations governing the Prevention of Significant Air Quality Deterioration (40 CFR 52.21) and other conditions attached to this document and made a part of this approval.

Failure to comply with any condition or term set forth in this approval will be considered grounds for enforcement action pursuant to Section 113 of the Clean Air Act.

This Approval to Construct/Modify a stationary source grants no relief from the responsibility for compliance with any other applicable provision of 40 CFR Parts 52, 60 and 61 or any applicable Federal, State, or local air quality regulations.

This approval shall supersede the Approval to Construct/Modify a stationary source issued to U.S. Borax and Chemical Corporation on April 27, 1982 (NSR 4-4-11, SE 81-04) and shall become effective immediately.

Dated: 16 DEC 1982

Original Signed by:

Acting Director
Air Management Division

PJ d 41/Final 12-3-82/SLAMOVICH/U.S Borax

Permit Conditions

I. Permit Expiration

This Approval to Construct/Modify shall become invalid (1) if construction is not commenced (as defined in 40 CFR 52.21(b)(8)) within 18 months after the approval takes effect, (2) if construction is discontinued for a period of 18 months or more, or (3) if construction is not completed within a reasonable time.

II. Notification of Commencement of Construction and Startup

The Regional Administrator shall be notified in writing of the anticipated date of initial start-up (as defined in 40 CFR 60.2(o)) of each facility of the source not more than sixty (60) days nor less than thirty (30) days prior to such date and shall be notified in writing of the actual date of commencement of construction and start-up within fifteen (15) days after such date.

III. Facilities Operation

All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of this Approval to Construct/Modify shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions.

IV. Malfunction

The Regional Administrator shall be notified by telephone within 48 hours following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section IX of these conditions. In addition, the Regional Administrator shall be notified in writing within fifteen (15) days of any such failure. This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section IX of these conditions, and the methods utilized to restore normal operations. Compliance with this malfunction notification provision shall not excuse or otherwise constitute a defense to any violations of this permit or of any law or regulations which such malfunction may cause.

V. Right to Entry

The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted:

- A. to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of this Approval to Construct/Modify; and
- B. at reasonable times to have access to and copy any records required to be kept under the terms and conditions of this Approval to Construct/Modify; and
- C. to inspect any equipment, operation, or method required in this Approval to Construct/Modify; and
- D. to sample emissions from the source.

VI. Transfer of Ownership

In the event of any changes in control or ownership of facilities to be constructed or modified, this Approval to Construct/Modify shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of this Approval to Construct/Modify and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency.

VII. Severability

The provisions of this Approval to Construct/Modify are severable, and, if any provision of this Approval to Construct/Modify is held invalid, the remainder of this Approval to Construct/Modify shall not be affected thereby.

VIII. Other Applicable Regulations

The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60 and 61 and all other applicable Federal, State and local air quality regulations.

IX. Special Conditions

A. Certification

U.S. Borax shall notify the EPA (attn: A-3-3) in writing of compliance with Special Condition E. below and shall make such notification within fifteen (15) days of such compliance. This letter must be signed by a responsible representative of U.S. Borax.

B. Fuel Usage and Sulfur Content

1. The 45 MW gas turbine shall consume no more than 4,150 gallons per hour of No. 2 fuel oil or 615,500 SCFH of natural gas.
2. The duct burner unit shall consume no more than 221,000 SCFM of natural gas.
3. The sulfur content of the fuel oil shall be no greater than 0.25 percent by weight as determined by ASTM Methods D-129 or D-1552, or the most current method promulgated by ASTM, or by equivalent methods approved by EPA.
4. The amount of fuel oil/gas consumed per hour by the turbine and the duct burner unit; and the sulfur content of the fuel oil consumed by the turbine shall be recorded in a permanent record and shall be available for periodic inspection by the Kern County Air Pollution Control District, the California Air Resources Board, and the EPA.
5. When the gas turbine is in operation, the total heating value of the fuel consumed by the turbine, duct burner and Boilers 1 through 7 shall not exceed 1.11×10^9 BTU/hr.

C. Emission Limits

1. On and after the date of startup of the gas turbine/duct burner unit, U.S. Borax shall not discharge, or cause the discharge into the atmosphere from the heat recovery steam generator (HRSG) stack, pollutants in excess of the following specified limits:

| <u>Pollutant</u> | <u>Maximum Emission Limit (lbs/hr)</u> |
|--------------------|--|
| Particulate Matter | 14.0 |
| Carbon Monoxide | 446.0 |

2. On and after the date of startup of the gas turbine/duct burner unit, U.S. Borax shall not discharge, or cause the discharge into the atmosphere from the HRSG stack nitrogen oxides in excess of the following limits:

- a. Maximum emission limit: 268.2 pounds per hour
- b. Average emission limit: 0.57 pounds per MMBTU

3. On and after the date of startup of the gas turbine, U.S. Borax shall not discharge, or cause the discharge into the atmosphere from the HRSG exhaust any gases which exhibit greater than 20 percent opacity.

D. Performance Tests

1. Within 60 days after achieving the maximum production rate of the gas turbine/duct burner unit, but no later than 180 days after initial startup (as defined in 40 CFR 60.2(o)) of the facility and at such times as may be specified by EPA, U.S. Borax shall conduct or cause to be conducted performance tests (as defined in 40 CFR 50.8) for NO_x, CO and particulate matter (PM) on the exhaust stack gases from the HRSG. U.S. Borax shall furnish the Kern County Air Pollution Control District and the EPA (Attn: A-3-3) a written report of the results of such tests. All performance tests shall be conducted at the maximum operating capacity of the emissions unit being tested. The performance tests shall be conducted on at least an annual basis. Upon prior written request and supporting justification, EPA may waive a specific annual test and/or allow for testing to be done at less than the maximum operating capacity. Such requests must be submitted (Attn: A-3-3) no later than 60 days prior to the annual test date.
2. Performance tests for the emissions of NO_x, CO and PM shall be conducted and results reported in accordance with the test methods set forth in 40 CFR 60, Part 60.8 and Appendix A. The following test methods shall be used:

- a. Performance tests for the emissions of NO_x shall be conducted using EPA Methods 1-4 and 7 procedures.
- b. Performance tests for the emissions of CO shall be conducted using EPA Methods 1-4 and 10 procedures.
- c. Performance tests for PM shall be conducted using EPA Methods 1-4 and 5 procedures.

At least 30 days prior to actual testing, U.S. Borax shall submit to the EPA (Attn: A-3-3) (1) a quality assurance project plan detailing methods and procedures to be used and (2) a quality assurance test plan. Such a plan shall conform to EPA document "Guidelines for Developing a Quality Assurance Project Plan," QAMS 005/80. A test plan or quality assurance plan that does not have EPA approval may be grounds to invalidate any test and require a retest. In lieu of the above mentioned test methods, equivalent methods may be used with prior approval from the EPA.

3. For performance test purposes, sampling ports, platforms, and access shall be provided by U.S. Borax on the turbine exhaust stack in accordance with 40 CFR 60.8(e).

E. Continuous Monitoring

1. NO_x and Opacity Continuous Monitoring

Prior to the date of startup and thereafter, U.S. Borax shall install, maintain and operate the following continuous monitoring system in the exhaust stack of the HRSG:

- a. A continuous monitoring system to measure stack gas NO_x concentration. The system shall meet EPA monitoring performance specifications (40 CFR 60.13 and 40 CFR 60, Appendix B, Performance Specification 2).
- b. A transmissometer system for continuous measurement of the opacity of stack emissions. The system shall meet EPA monitoring requirements performance specifications (40 CFR 60.13 and 40 CFR 60, Appendix B, Performance Specification 1).
- c. A continuous monitoring system to measure stack gas volumetric flow rates. The system shall meet EPA monitoring requirements performance specifications (40 CFR Part 52, Appendix E).

2. U.S. Borax shall notify EPA (Attn: A-3-3) of the date upon which demonstration of the continuous monitoring systems performance commences (40 CFR 60.13(c)).
3. U.S. Borax shall submit a written report of all excess emissions to EPA (Attn: A-3-3) for every calendar quarter. The report shall include the following:
 - a. The magnitude of excess emissions computed in accordance with 40 CFR 60.13(h), any conversion factors(s) used, and the date and time of commencement and completion of each time period of excess emissions.
 - b. Specific identification of each period of excess emissions that occurs during startups, shutdowns, and malfunctions of the gas turbine. The nature and cause of any malfunction (if known) and the corrective action taken or preventative measures adopted shall also be reported.
 - c. The date and time identifying each period during which the continuous monitoring system was inoperative except for zero and span checks and the nature of the system repairs or adjustments.
 - d. When no excess emissions have occurred or the continuous monitoring system has not been inoperative, repaired, or adjusted, such information shall be stated in the report.

Excess emissions shall be defined as:

- (1) any consecutive three-hour period during which the average emissions of NO_x , as measured by the continuous monitoring system, exceeds the maximum emission limits set forth in IX.C.2. above.
- (2) any consecutive 24-hour period during which the average emissions of NO_x , as measured by the continuous monitoring system, exceeds the average emission limit set forth in IX.C.2.
- (3) any 6-minute average, as measured by the continuous monitoring system, which exceeds an opacity of 20 percent, except for one 6-minute period per hour of not more than 25 percent opacity.

4. U.S. Borax shall maintain a file of all measurements, including continuous monitoring system, monitoring device, and performance testing measurements; all continuous monitoring system performance evaluations; all continuous monitoring system or monitoring device calibration checks adjustments and maintenance performed on these systems or devices; and all other information required by 40 CFR 60 recorded in a permanent form suitable for inspection. The file shall be retained for at least two years following the date of such measurements, maintenance, reports and records.
5. Not less than 90 days prior to the date of startup, U.S. Borax shall submit to the EPA (Attn: A-3-3) a quality assurance project plan for the certification and operation of the continuous emission monitors. Such a plan shall conform to the EPA document "Guidelines for Developing a Quality Assurance Project Plan" (QAMS 005/80). Continuous emission monitoring may not begin until the quality assurance project plan has been approved by EPA Region 9.

F. By-Pass Recordkeeping

U.S. Borax shall maintain a record of the date(s), time(s), and duration(s) of those periods when the exhaust stream of the gas turbine or the duct burner unit, is vented through the by-pass stack.

X. Agency Notifications

All correspondence as required by this Approval to Construct/Modify shall be forwarded to:

- A. Director, Air Management Division (Attn: A-3-3)
EPA Region 9
215 Fremont Street
San Francisco CA 94105
- B. Chief, Regional Programs Division
California Air Resources Board
P. O. Box 2815
Sacramento CA 95814
- C. Air Pollution Control Officer
Kern County Air Pollution Control District
1601 H Street, Suite 250
Bakersfield CA 93301

READFILE: Connie Final 10/27/82
Slamovich: NSS-6/US Borax
transferred to d/Old aagirs
Copies run 12/14/82 CB