

U.S. Environmental Protection Agency  
EMB Report 78-NHF-1

108  
*DRAFT*  
EMISSION TESTING

Facility B

at an

BR CRUDES

AMMONIUM SULFATE MANUFACTURING PLANT

Dow-Badische, Inc.  
Freeport, Texas  
October 3 and 4, 1978

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

Prepared for the

U.S. Environmental Protection Agency  
Emission Measurement Branch  
Research Triangle Park, North Carolina 27711

Prepared by

Clayton Environmental Consultants, Inc.  
25711 Southfield Road  
Southfield, Michigan 48075

EMB REPORT NO. 78-NHF-1

Work Assignments 5 and 6

Contract No. 68-02-2817

November, 1978

## TABLE OF CONTENTS

	<u>Page</u>
I. Introduction	1
II. Summary and Discussion of Results	5
III. Process Description and Operation	10
IV. Location of Sampling Points	11
V. Sampling and Analytical Procedures	14

## APPENDICES

- A. Project Participants
- B. Field Data Sheets
  - B-1. Particulate Test Data Sheets
  - B-2. Sampling Summary Data
  - B-3. Particle Sizing Data Sheet
  - B-4. Visible Emissions Data Sheets
- C. Summary of Particulate Weight by Fraction and Caprolactam Determinations by Fraction
- D. Ammonium Sulfate Determinations and Percent Moistures
- E. Summary of Visible Emissions
- F. Gas Chromatograph Data Summary
- G. Example Calculations
- H. Calibration Data

## LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1.1	Fluidized Bed Dryer and Control System	3
1.2	Control System Schematic/Sampling Locations	4
4.1	Scrubber Inlet Port and Sampling Point Locations	16
4.2	Scrubber Outlet Port and Sampling Point Locations	17
5.1	Particulate Sampling Train-Venturi Scrubber Inlet	20
5.2	Particulate Sampling Train-Venturi Scrubber Outlet	21

## LIST OF TABLES

<u>Table</u>	<u>Page</u>
2.1 Summary of Filterable Particulate Concentrations and Emission Rates	6
2.2 Summary of Total Particulate Concentrations and Emission Rates	8
2.3 Particulate Removal Efficiency	9
2.4 Summary of Filterable Caprolactam Concentrations and Emission Rates	10
2.5 Summary of Total Caprolactam Concentrations and Emission Rates	11
2.6 Particle Size Distribution	13

## I. INTRODUCTION

The U.S. Environmental Protection Agency (EPA) retained Clayton Environmental Consultants, Inc. to perform a particulate and caprolactam emission study of the venturi scrubber at the Dow-Badische plant in Freeport, Texas. The objective of this study was to determine the mass loading rates and the mass control efficiency of the scrubber which controls emissions from the fluidized bed salt dryer. The results of this study will be used in research and development efforts for supporting national New Source Performance Standards. This study was commissioned as Project No. 78-NHF-1, Contract No. 68-02-2817, Work Assignments 5 and 6.

The testing program, conducted on October 3 and 4, 1978, included the following:

- 1) triplicate particulate samples acquired simultaneously at the inlet to and outlet of the venturi scrubber;
- 2) a single determination of the particle size distribution of the gas stream at the scrubber inlet;
- 3) moisture contents of six ammonium sulfate samples (three taken from the inlet and three from the outlet of the salt dryer);

- 4) three scrubber water samples to be analyzed for percent ammonium sulfate; and,
- 5) visible emission observations at the outlet of the venturi scrubber for the duration of each particulate sample run.

Auxiliary data included exhaust gas velocities, temperatures, and flowrates, as determined from the traverses.

Figures 1.1 and 1.2 present schematics of the process/control system layout as tested.




Figure 1.1. Fluidized bed dryer and control system




Figure 1.2. Control system schematic/sampling locations

## II. SUMMARY AND DISCUSSION OF RESULTS

### Particulate Emissions

Results of the particulate emission study are presented in Tables 2.1, 2.2, and 2.3. Tables 2.1 and 2.2 present the concentrations and emission rates for filterable and total particulate, respectively. Concentrations are expressed as grains per dry standard cubic foot (gr/DSCF) and metrically as milligrams per dry standard cubic meter ( $\text{mg/DSM}^3$ ). Emission rates are expressed as pounds per hour (lb/hr) and metrically as kilograms per hour (kg/hr). Averages are presented for each sampling location. Table 2.3 presents the particulate removal efficiency of the venturi scrubber based on the total particulate emission rate. Removal efficiencies are expressed as a percent.

From Table 2.1, it is seen that the filterable concentrations at the inlet ranged from 16.5 to 17.7 gr/DSCF (37,700 to 40,400  $\text{mg/DSM}^3$ ) and averaged 17.2 gr/DSCF (39,400  $\text{mg/DSM}^3$ ). Concentrations at the outlet ranged from 0.008 to 0.032 gr/DSCF (19.1 to 74.1  $\text{mg/DSM}^3$ ) and averaged 0.019 gr/DSCF (44.1  $\text{mg/DSM}^3$ ). Emission rates at the inlet ranged from 5970 to 6440 lb/hr (2710 to 2920 kg/hr) and averaged 6270 lb/hr (2850 kg/hr). Emission rates at the outlet ranged from 3.58 to 14.2 lb/hr (1.63 to 6.42 kg/hr) and averaged 8.43 lb/hr (3.82 kg/hr). The data at both locations generally show good reproducibility.

Table 2.1. Summary of Filterable Particulate Concentrations and Emission Rates

Sampling Location	Sample No.	Stack Gas Conditions		Concentration		Emission Rate	
		Flowrate (DSCFM)	Temp. (°F)	(gr/DSCF)	(mg/DSM <sup>3</sup> )	(lb/hr)	(kg/hr)
Inlet	P-1	43,000	182	17.5	40,000	6440	2920
	P-2	42,300	188	16.5	37,700	5970	2710
	P-3	42,300	188	17.7	40,400	6410	2910
Average		42,500	186	17.2	39,400	6270	2850
Outlet	P-1	51,100	105	0.017	39.2	7.50	3.40
	P-2	50,200	110	0.008	19.1	3.58	1.63
	P-3	51,000	104	0.032	74.1	14.2	6.42
Average		50,800	106	0.019	44.1	8.43	3.82

Total particulate concentrations and emission rates at the inlet (Table 2.2) were identical to those for the filterable particulate fraction at the same location. Concentrations averaged 17.2 gr/DSCF (39,400 mg/DSM<sup>3</sup>) and emission rates averaged 6270 lb/hr (2850 kg/hr). Total concentrations at the outlet ranged from 0.010 to 0.036 gr/DSCF (22.0 to 82.4 mg/DSM<sup>3</sup>) and averaged 0.021 gr/DSCF (48.7 mg/DSM<sup>3</sup>). Total emission rates at the outlet ranged from 4.13 to 15.7 lb/hr (1.87 to 7.14 kg/hr) and averaged 9.26 lb/hr (4.21 kg/hr).

Table 2.3 presents the particulate removal efficiencies. The removal efficiency averaged 99.9 percent for the three tests.

Tables 2.4 and 2.5, respectively, present summaries of filterable and total Caprolactam concentrations and emission rates. Inlet filterable concentrations averaged 3.29 ppm (10,900 µg/DSM<sup>3</sup>), while filterable emission rates averaged 2.46 lb/hr and 1.12 kg/hr. Outlet filterable concentrations averaged 0.201 ppm (948 µg/DSM<sup>3</sup>), while filterable emission rates averaged 0.181 lb/hr (0.082 kg/hr).

Table 2.5 reveals that the majority of the Caprolactam in the gas stream was present in the vapor phase. Total concentrations at the inlet averaged 57.8 ppm (272,000 µg/DSM<sup>3</sup>) and emission rates averaged 43.3 lb/hr (19.6 kg/hr). At the outlet, total concentrations averaged 6.92 ppm (32,600 µg/DSM<sup>3</sup>) and emission rates averaged 6.20 lb/hr (2.81 kg/hr).

Table 2.2. Summary of Total Particulate Concentrations and Emission Rates

Sampling Location	Sample No.	Stack Gas Conditions		Concentration		Emission Rate	
		Flowrate (DSCFM)	Temp. (°F)	(gr/DSCF)	(mg/DSM <sup>3</sup> )	(lb/hr)	(kg/hr)
Inlet	P-1	43,000	182	17.5	40,000	6440	2920
	P-2	42,300	188	16.5	37,700	5970	2710
	P-3	42,300	188	17.7	40,400	6410	2910
Average		42,500	186	17.2	39,400	6270	2850
Outlet	P-1	51,100	105	0.018	41.6	7.96	3.61
	P-2	50,200	110	0.010	22.0	4.13	1.87
	P-3	51,000	104	0.036	82.4	15.7	7.14
Average		50,800	106	0.021	48.7	9.26	4.21

Table 2.3 Particulate Removal Efficiency

1978 Sampling Date	Sample No.	Percent Removal Efficiency
10/3	P-1	99.9
10/4	P-2	99.9
10/4	P-3	99.8
Average		99.9

Table 2.4 Summary of Filterable Caprolactam Concentrations and Emission Rates

Sampling Location	Sample No.	Stack Gas Conditions		Concentration		Emission Rate	
		Flowrate (DSCFM)	Temp. (°F)	ppm	(μg/DSM <sup>3</sup> )	(lb/hr)	(kg/hr)
Inlet	P-1	43,000	182	1.90	8,960	1.44	0.655
	P-2	42,300	188	4.67	22,000	3.48	1.58
	P-3	42,300	188	< 0.350	<1,650	< 0.261	< 0.118
Average		42,500	186	3.29	10,900	2.46	1.12
Outlet	P-1	51,100	105	0.201	948	0.181	0.082
	P-2	50,200	110	< 0.257	<1,210	< 0.227	< 0.103
	P-3	51,000	104	< 0.277	<1,305	< 0.249	< 0.113
Average		50,800	106	0.201	948	0.181	0.082

Table 2.5 Summary of Total Caprolactam Concentrations and Emission Rates

Sampling Location	Sample No.	Stack Gas Conditions		Concentration		Emission Rate	
		Flowrate (DSCFM)	Temp. (°F)	ppm	(μg/DSM <sup>3</sup> )	(lb/hr)	(kg/hr)
Inlet	P-1	43,000	182	49.9	235,000	37.8	17.1
	P-2	42,300	188	60.3	284,000	45.0	20.4
	P-3	42,300	188	63.3	298,000	47.2	21.4
Average		42,500	186	57.8	272,000	43.3	19.6
Outlet	P-1	51,100	105	5.64	26,600	5.09	2.31
	P-2	50,200	110	6.89	32,500	6.10	2.77
	P-3	51,000	104	8.23	38,800	7.40	3.36
Average		50,800	106	6.92	32,600	6.20	2.81

Therefore, approximately 94.3 percent of the Caprolactam was in the vapor phase at the inlet and 97.1 percent was vapor at the outlet. Detailed summaries of the Caprolactam analyses (by GC methods) are presented in Appendix F.

The single sample taken at the scrubber inlet to determine particle size distribution resulted in the size distribution by weight data presented in Table 2.6. Virtually all particles sized were greater than 2.74  $\mu\text{m}$  with about 99.3 percent of the material greater than 8.04  $\mu\text{m}$ . The analyses showed that no material was captured on impactor stages 2 through 5.

The ammonium sulfate drier resulted in an average 91.8 percent reduction in moisture content of the ammonium sulfate material, from analyses of inlet and outlet samples (Appendix D). Analyses of the scrubber water samples (also presented in Appendix D) resulted in an average 356 gm/l concentration of ammonium sulfate.

Table 2.6 Particle Size Distribution

Brink Impactor Fraction	Characteristic Diameter of Particles ( $\mu$ )	Weight (mg)	Size Distribution by Weight	
			Percent	Cumulative Percent
Cyclone	>8.04	289.2	99.3	100
Stage 1	2.74-8.04	2.0	0.7	0.7
Stage 2	1.62-2.74	<0.1	<0.1	<0.1
Stage 3	1.10-1.62	<0.1	<0.1	<0.1
Stage 4	0.58-1.10	<0.1	<0.1	<0.1
Stage 5	0.36-0.58	0.1	<0.1	<0.1
Back-Up Filter	<0.36	0.06	<0.1	<0.1
TOTAL		291.4	100	

III. PROCESS DESCRIPTION AND OPERATION

To be supplied by E.P.A.

]



#### IV. LOCATION OF SAMPLING POINTS

The inlet sampling location was a 54 inch (137.2 cm) I.D. duct leading from the ammonium sulfate dryer to the venturi scrubber. Two three-inch ports, facing west and south and approximately 45 feet (13.7 meters) above ground level, were accessed for sampling. This sampling location was approximately 7.8 duct diameters downstream from the fan and two duct diameters upstream from a 180 degree bend. The duct is represented schematically in Figure 1.2.

The scrubber outlet is a 54 inch (137.2 cm) duct with the sampling platform 45 feet (13.7 meters) above ground level. Two three-inch ports, facing west and south, were accessed for sampling. This sampling location was approximately two duct diameters downstream of the mist eliminator and approximately two duct diameters upstream from the outlet. This duct is also shown schematically in Figure 1.2.


Velocity pressures and temperatures were measured at 40 sampling points at both the inlet and outlet sampling locations. Figures 4.1 and 4.2 respectively, are diagrams of the inlet and outlet sampling locations showing each of the traverse points and their respective distances from the stack wall.

The ammonium sulfate samples, acquired at the inlet and outlet of the ammonium sulfate dryer, were taken by plant process engineers. Samples of the scrubber water effluent were acquired in the same manner.



Points	Distance	
	(inches)	(centimeters)
1	0.7	1.78
2	2.1	5.33
3	3.6	9.14
4	5.2	13.2
5	7.0	17.8
6	8.9	22.6
7	11.0	27.9
8	13.5	34.3
9	16.5	41.9
10	21.0	53.3
11	33.0	83.8
12	37.5	95.2
13	40.5	103.
14	43.0	109.
15	45.1	115.
16	47.0	119.
17	48.8	124.
18	50.4	128.
19	51.9	132.
20	53.3	135.

Figure 4.1. Scrubber inlet port and sampling point locations



Points	Distance	
	(inches)	(centimeters)
1	0.7	1.78
2	2.1	5.33
3	3.6	9.14
4	5.2	13.2
5	7.0	17.8
6	8.9	22.6
7	11.0	27.9
8	13.5	34.3
9	16.5	41.9
10	21.0	53.3
11	33.0	83.8
12	37.5	95.2
13	40.5	103.
14	43.0	109.
15	45.1	115.
16	47.0	119.
17	48.8	124.
18	50.4	128.
19	51.9	132.
20	53.3	135.

Figure 4.2. Scrubber outlet port and sampling point locations

## V. SAMPLING AND ANALYTICAL PROCEDURES

### Particulate Emissions

TriPLICATE two hour particulate samples were extracted simultaneously from the inlet and outlet of the venturi scrubber system. Exhaust gases were withdrawn isokinetically for three minutes at each of 40 sampling points. During each test, the probe, Pitot-tube, and impinger assembly were moved to each sampling point, the velocity pressure and temperature of the exhaust gas were measured, and isokinetic sampling flow rates were adjusted accordingly using an orifice-type meter to indicate instantaneous flow rates. All field data sheets are included in Appendix B.

The sampling trains at both sites were checked for leaks before and after each test in accordance with the requirement that the initial leak rate shall not exceed 0.02 ft<sup>3</sup> per minute at 15 inches of mercury vacuum and the final leak rate shall not exceed 0.02 ft<sup>3</sup> per minute at the greatest vacuum occurring during the test.

At both locations, an EPA Method 5 sampling train was used. The sampling train consisted of a sharp, tapered, stainless steel sampling nozzle, a heated glass-lined probe, a heated pre-weighed 110 mm Type A glass-fiber filter, a modified Greenburg-Smith impinger containing 100 ml of distilled water, a standard Greenburg-Smith impinger containing 100 ml of distilled water, an empty modified Greenburg-Smith impinger, a modified Greenburg-Smith impinger containing approximately 300 grams of silica gel, a leakless pump with vacuum gauge, a calibrated dry gas meter equipped with

bimetallic inlet and outlet thermometers, and a calibrated orifice-type flow meter that was connected to a zero to ten inch range inclined (water gauge) manometer. At the scrubber inlet sampling location, a cyclone was inserted into the sampling train between the probe and the glass-fiber filter.

The impinger trains were immersed in an ice bath to maintain the temperature in the last impingers at 70°F or less. All of the sampling train glassware was connected by ground glass joints, sealed with stopcock grease, and clamped to prevent leakage. A calibrated S-type Pitot tube was connected to the sampling probe and velocity pressures were read on the inclined manometer. An iron-constantan (I/C) thermocouple, attached to the Pitot-probe assembly, was connected to a calibrated pyrometer. During the course of testing, the filter temperature was kept below 250°F, but greater than the stack temperature to prevent filter blinding. Schematic diagrams of the sampling trains used at the scrubber inlet and outlet locations are presented in Figures 5.1 and 5.2, respectively.

At the end of each 120 minute test period, the sampling train was transferred to a dust free clean-up area. The volumes of the impinger solutions were measured and volume increases recorded. The solutions were placed in glass sample bottles and sealed with Teflon<sup>®</sup>-lined caps. The silica gel was weighed to determine the weight gain




Figure 5.1 Particulate sampling train - Venturi scrubber inlet




Figure 5.2 Particulate sampling train - Venturi scrubber outlet

(as condensate). The probe and nozzle assembly was thoroughly washed with water, and the rinsings were collected in a glass sample bottle with a Teflon<sup>®</sup>-lined cap. Following the water wash, the probe and nozzle assembly was then rinsed with acetone, and the rinsings transferred to a glass sample bottle and sealed with a Teflon<sup>®</sup>-lined cap. The impinger assembly was thoroughly washed with water, and these water washings were placed with the impinger solutions. Following the water wash of the impingers, the entire impinger assembly was then rinsed with acetone and these rinsings were placed in a glass sample bottle and sealed with a Teflon<sup>®</sup>-lined cap.

After each particulate test, therefore, five sample fractions had been collected (summary presented in Appendix C):

- (1) water rinsings of probe and nozzle assembly;
- (2) acetone rinsings of probe and nozzle assembly;
- (3) 110 mm Type A glass-fiber filter;
- (4) impinger contents and distilled water rinsings; and,
- (5) acetone rinsings of impingers.

In the laboratory, Fractions 1, 2, 4, and 5 were placed into beakers. Fraction 3 was vacuum dessicated and weighed on an analytical balance.

Following the weight determination, Fraction 3 was placed in a known volume of water, stirred, and decanted. This leachate and aliquots of Fractions 1 and 4 were analyzed for caprolactam on a Hewlett-Packard Model 5702A

gas chromatograph equipped with a flame ionization detector. The column chosen for this analysis was a 5% Carbowax 20-TPA in Chromosorb W-AW, six feet x 1/4 inches, maintained at 200°C. A Hewlett-Packard Model 3352B Laboratory Data System was employed to determine the areas under the peaks. A four-point calibration for linearity with caprolactam in water standards was performed in the laboratory. A summary of the GC data along with the calibration curve are presented in Appendix F.

The remainders of Fractions 1 and 4 were evaporated to residues at 105°C and weighed. Fractions 2 and 5 were dried with circulating air at 22°C until reaching a constant weight, and weighed. All weight determinations were performed on an analytical balance having a sensitivity of 0.1 milligrams.

#### Particle Size Distribution

A single particle size distribution sample was extracted from the scrubber inlet. Exhaust gases were withdrawn isokinetically for six minutes at the stack centerline. A Monsanto Brinks Cascade Impactor was used for the sampling of particulate for particle size distribution determination.

The cascade impactor, which was held in-stack, has five in-line stages arranged in series, each of which has a jet incorporating a collection cup as an impaction plate. When the incoming gas stream is drawn through a

jet, those particles with sufficient inertia impact and remain against a cup. Those particles with insufficient inertia will pass through annular slots surrounding the cup periphery and enter the next jet. The smallest particles which are not impacted on any plate are caught on a back-up Type A glass-fiber filter. The particle size distribution results may be found in Table 2.6.

APPENDIX A

PROJECT PARTICIPANTS

PROJECT PARTICIPANTS

Clayton Environmental Consultants, Inc.

N. Steve Walsh	Director, Air Resource Engineering
Timothy V. Mattson	(Acting) Group Leader, Emissions Measurement
Richard G. Keller	Environmental Chemist
George M. Santorilla	Environmental Control Specialist
Dusanka Lazarevic	Environmental Data Specialist
Donna L. Schick	Environmental Data Specialist
Katherine H. Berry	Environmental Chemist
Cheryl R. Kluk	Laboratory Technician
Gloria J. Kerszykowski	Laboratory Technician
Sandra L. King	Laboratory Technician

Dow-Badische

James Martin

U.S. Environmental Protection Agency

Dennis P. Holzschuh

APPENDIX B

FIELD DATA SHEETS

- B-1. Particulate Test Data Sheets
- B-2. Sampling Summary Data
- B-3. Particle Sizing Data Sheet
- B-4. Visible Emissions Data Sheets

APPENDIX B-1

PARTICULATE TEST DATA SHEETS

## SAMPLING TRAIN DATA

$$3.17 \frac{T_m}{T_s} H = \Delta$$

Company: \_\_\_\_\_

Source Designation: Inlet Scrubber

Date: 10-3-78

Filter Heater Setting: \_\_\_\_\_

Test Number: P-1

Probe Heater Setting: \_\_\_\_\_

Field Person: DLS

Nozzle Number: 14, Dia. (in.): 0.249

Filter Number: \_\_\_\_\_

Pitot Tube No. 23, Corr. Factor: 0.82

Barometric Pressure ("Hg): 29.81

Meter Box No. RAE3, Corr. Factor: 1.99

Stack Static Pressure ("H<sub>2</sub>O): +.74

Meter Isokinetic Factor: \_\_\_\_\_

Stack Dimensions: 4'6" ID

Assumed Moisture (%): 11.70

Plume Appearance: \_\_\_\_\_

Condensate Volume (ml): \_\_\_\_\_

Ambient Temperature (°F): \_\_\_\_\_

Silica Gel Weight Gain (g): \_\_\_\_\_

Record all Data Every 3 Minutes

Leak Rate 0.0 CFM at 15 "Hg

84 X 4

6 → 8

Trav- erse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet				
5-2	0	1600	0.75	186	154.109	86	84	2.01	240	70
5-3	3	1603	0.74	185	157.15	86	88	1.99	240	70
5-4	6	1606	0.82	184	159.38	90	87	2.21	240	70
5-5	9	1609	0.75	184	161.52	92	88	2.03	240	70
5-6	12	1612	0.80	184	163.70	94	99	2.17	240	70
5-7	15	1615	0.79	184	166.1	97	90	2.15	240	70
5-8	18	1618	0.83	184	168.51	99	90	2.27	240	70
5-9	21	1621	0.84	184	171.18	101	91	2.3	230	70
5-10	24	1624	0.81	184	173.71	102	92	2.2	230	70
5-11	27	1627	0.86	184	176.0	104	92	2.36	230	70
5-12	30	1630	0.87	184	178.9	105	93	2.39	230	72
5-13	33	1633	0.90	182	181.51	105	94	2.49	230	72
5-14	36	1636	0.95	182	184.30	107	95	2.63	230	74
5-15	39	1639	1.0	182	187.08	107	96	2.77	230	74
5-16	42	1642	1.0	182	189.93	108	96	2.77	230	74
5-17	45	1645	1.0	182	192.90	109	97	2.78	230	74
5-18	48	1648	0.97	182	195.69	110	98	2.70	230	74

AVERAGE (TOTAL)

## SAMPLING TRAIN DATA

217  
155  
8/2

Company: \_\_\_\_\_  
 Source Designation: \_\_\_\_\_  
 Date: \_\_\_\_\_  
 Test Number: P-1 page 2  
 Field Person: DLS  
 Filter Number: \_\_\_\_\_  
 Barometric Pressure ("Hg): \_\_\_\_\_  
 Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_  
 Stack Dimensions: \_\_\_\_\_  
 Plume Appearance: \_\_\_\_\_  
 Ambient Temperature (°F): \_\_\_\_\_  
 Record all Data Every \_\_\_\_\_ Minutes      Leak Rate \_\_\_\_\_ CFM at \_\_\_\_\_ "Hg

Trav- erse Point No.	Time		Velocity Pressure (H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter			Orifice Pressure Differ- ential (H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure (Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet	Temp (°F)				
S-19	51	1651	0.93	181	198.00	112	98	2.60	210	73	
S-19	54	1654	0.95	181	201.28	112	99	2.10	210	73	
W-2	57	1657	0.95	182	204.01	112	99	2.65	210	73	
W-2	30	1654	0.84	182	204.08	100	100	2.32	215	74	
W-2	63	1719	0.80	182	209.7	105	100	2.22	215	68	
W-3	64	1720	0.90	182	212.24	108	100	2.51	215	68	
W-4	69	1723	0.83	182	215.09	110	100	2.32	215	68	
W-5	72	1726	0.93	195	217.62	111	101	2.55	215	68	
W-6	75	1809	0.9	185	219.03	92	92	2.44	120	70	
W-7	78	1802	0.96	181	222.74	94	92	2.63	210	66	
W-8	81	1806	0.94	181	225.53	98	94	2.58	230	68	
W-9	84	1809	0.94	181	228.31	102	94	2.59	230	68	
W-10	87	1842	0.92	181	231.11	104	95	2.55	230	68	
W-11	90	1815	0.9	178	233.88	106	95	2.51	230	68	
W-12	93	1818	0.9	178	235.0	108	98	2.52	230	68	
W-13	96	1821	0.78	183	239.39	108	96	2.16	230	72	
W-14	99	1824	0.70	180	241.96	109	96	1.95	230	72	
W-15	102	1827	0.72	186	244.41	109	97	2.01	230	72	

AVERAGE (TOTAL)

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_  
 Source Designation: \_\_\_\_\_  
 Date: \_\_\_\_\_ Filter Heater Setting: \_\_\_\_\_  
 Test Number: P-1 page 3 Probe Heater Setting: \_\_\_\_\_  
 Field Person: DLS Nozzle Number: \_\_\_\_\_, Dia. (in.): \_\_\_\_\_  
 Filter Number: A-236-12, Pitot Tube No. \_\_\_\_\_, Corr. Factor: \_\_\_\_\_  
 Barometric Pressure ("Hg): \_\_\_\_\_ Meter Box No. \_\_\_\_\_, Corr. Factor: \_\_\_\_\_  
 Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_ Meter Isokinetic Factor: \_\_\_\_\_  
 Stack Dimensions: \_\_\_\_\_ Assumed Moisture (%): \_\_\_\_\_  
 Plume Appearance: \_\_\_\_\_ Condensate Volume(ml): 52  
 Ambient Temperature(°F): \_\_\_\_\_ Silica Gel Weight Gain(g): 24.7  
 Record all Data Every \_\_\_\_\_ Minutes Leak Rate \_\_\_\_\_ CFM at \_\_\_\_\_ "Hg

Trav- erse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet Temp (°F)				
W-16	105	1830	0.69	190	246.84	108	98	1.92	220	74
W-17	108	1833	0.71	176	249.26	108	98	1.99	220	74
W-18	111	1836	0.68	176	251.66	108	98	1.91	225	76
W-19	114	1839	0.68	174	254.02	108	99	1.91	225	76
W-19	117	1842	0.66	176	256.41	108	99	1.85	225	74
	120	1845			258.755					
AVERAGE (TOTAL)				182 ( )	23.74	99	average 15	2.34		

$90^\circ = 350$   
 $40^\circ = 340$

## SAMPLING TRAIN DATA

$\Delta H = 3.69 \frac{\text{ft}}{\text{ft}^3}$

Company: EPA - Task 6

Source Designation: Scrubber - Inlet

Date: 10/4/78

Test Number: P-2

Field Person: DL / RCL

Filter Number: P-2163-15

Barometric Pressure ("Hg): 29.85

Stack Static Pressure ("H<sub>2</sub>O): +.7 Hg

Stack Dimensions: 4'6"

Plume Appearance: 1

Ambient Temperature (°F): 80

Record all Data Every 3 Minutes

Filter Heater Setting:

Probe Heater Setting:

Nozzle Number: 1/2, Dia. (in.):

Pitot Tube No. 23, Corr. Factor: .23

Meter Box No. Reg-3, Corr. Factor: 6.49

Meter Isokinetic Factor:

Assumed Moisture (%): 45

Condensate Volume (ml): 56 ml

Silica Gel Weight Gain (g): 28.3

Leak Rate 0.0 CFM at 15 "Hg

40

Trav- erse Point No.	Time Samp- ling (min)	Velocity Clock	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
				Inlet Volume (ft <sup>3</sup> )	Temp (°F)				
				Outlet ("H <sub>2</sub> O)					
W-2	0	07:50	0.7	269.17	58	2.17	210	64	2.0
	2		0.85	280	261.68	60	34	2.59	210
	3		0.92	278.0	263.32	92	36	2.91	210
	6		0.96	180	266.15	78	88	3.06	210
	9		0.96	180	267.06	102	88	3.06	210
	12		0.94	180	267.06	102	88	3.06	210
	15		0.90	180	272.9	102	96	2.89	215
	18		0.95	180	276.3	104	96	3.05	215
	21		0.96	180	278.73	104	96	2.89	220
	24		0.94	180	281.56	106	92	3.03	2.0
	27		0.92	180	284.45	106	92	2.97	1
	30		0.89	185	287.32	106	94	2.85	1
	33		0.85	180	290.16	106	94	2.74	1
	36		0.82	180	292.92	106	94	2.65	1
	39		0.79	185	295.15	107	96	2.74	220
	42		0.73	185	298.31	106	96	2.34	1.5
	45		0.69	185	300.86	106	96	2.21	2.0
	48		0.69	185	303.31	106	96	2.21	2.0
AVERAGE (TOTAL)				( )					

## SAMPLING TRAIN DATA

Company: Dow Chemical - SPA Task L  
 Source Designation: Scrubber - Inlet  
 Date: 10/4/78  
 Test Number: F-2 M-2 cont.  
 Field Person: NL (cont)  
 Filter Number: P-2L3-15  
 Barometric Pressure ("Hg): 29.85  
 Stack Static Pressure ("H<sub>2</sub>O):  
 Stack Dimensions: 4'6"  
 Plume Appearance:  
 Ambient Temperature (°F): 75  
 Record all Data Every 3 Minutes  
 Leak Rate \_\_\_\_\_ CFM at \_\_\_\_\_ "Hg

Filter Heater Setting:  
 Probe Heater Setting:  
 Nozzle Number: , Dia. (in.):  $\frac{1}{2}$   
 Pitot Tube No. 25, Corr. Factor:  
 Meter Box No. 100-3, Corr. Factor:  
 Meter Isokinetic Factor:  
 Assumed Moisture (%):  
 Condensate Volume (ml):  
 Silica Gel Weight Gain (g):  
 Leak Rate \_\_\_\_\_ CFM at \_\_\_\_\_ "Hg

Trav- erse Point No.	Time		Velocity Pressure (H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet Temp (°F)				
14	51		0.66	185	305.85	106	96	2.12	275	
14	54		0.64	185	306.37	106	96	2.05	270	74
14	57		0.65	190	310.64	106	92	2.08		
	60	0950	—	190	313.07	106	92	2.03		
<i>Summ. Pt 2</i>										
2-1	60	10:55	0.75	190	313.23	100	91	2.58		
2-2	63		0.80	195	315.55	103	98	2.52		
2-3	66		0.72	190	318.27	106	98	2.46		
2-4	69		0.76	190	320.81	108	100	2.43		2.0
2-5	72		0.77	190	323.50	110	102	2.42		
2-6	75		0.73	195	326.14	106	100	2.34		
2-7	78		0.76	190	328.77	112	102	2.44	210	79
2-8	81		0.75	190	331.34	112	102	2.41		
2-9	84		0.76	195	333.95	112	102	2.43		
2-10	87		0.76	190	336.59	112	104	2.45	205	77
2-11	90		0.74	190	339.23	112	104	2.55		
2-12	93		0.75	195	341.93	112	104	2.42		
AVERAGE (TOTAL)					( )					

## SAMPLING TRAIN DATA

Company: EPA - Task 63 Due Badische

Source Designation: Schulte - Unit

Date: 10/4/78

Filter Heater Setting:

Test Number: P-2 of 2 cont

Probe Heater Setting:

Field Person: DL/KR

Nozzle Number: , Dia. (in.):

Filter Number: 7-263-15

Pitot Tube No. 23, Corr. Factor:

Barometric Pressure ("Hg): 29.85

Meter Box No. 140-3, Corr. Factor:

Stack Static Pressure ("H<sub>2</sub>O): -0.7

Meter Isokinetic Factor:

Stack Dimensions: 14" ID

Assumed Moisture (%):

Plume Appearance:

Condensate Volume (ml):

Ambient Temperature (°F): 75

Silica Gel Weight Gain (g):

Record all Data Every 2 Minutes

Leak Rate CFM at "H<sub>2</sub>O

Trav- erse Point No.	Time		Velocity ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)				
	Inlet	Outlet								
S-13	96		0.87	195	344.71	114	104	2.79		2.0
S-14	99		0.95	195	347.56	114	105	3.05		2.0
S-15	102		1.00	195	350.48	115	105	3.25		2.0
S-16	105		0.98	195	353.45	116	106	3.06		2.0
S-17	108	1046	0.96	195	356.40	115	105	3.08	210	75
S-18	111		0.97	195	359.35	115	105	3.11		2.0
S-19	114		0.92	195	362.31	116	106	2.96		2.0
S-19	117		0.89	195	365.20	115	105	2.87		
	120	-	-	-	368.05	-	-	-		
AVERAGE (TOTAL)			1.00	( )	103	92	2.65			

## SAMPLING TRAIN DATA

3.69

Company: EPA Task 1e

Source Designation: Inlet

Date: 10-4-78

Filter Heater Setting:

Test Number: P-3

Probe Heater Setting:

Field Person: DLS

Nozzle Number: 1/4, Dia. (in.): 0.249

Filter Number:

Pitot Tube No. 23, Corr. Factor:

Barometric Pressure ("Hg): 29.85

Meter Box No. PA03, Corr. Factor: 0.90

Stack Static Pressure ( $\frac{\text{in. H}_2\text{O}}{\text{in.}}$ ): 0.7 Hg

Meter Isokinetic Factor:

Stack Dimensions:

Assumed Moisture (%): 40

Plume Appearance:

Condensate Volume (ml): 60.0

Ambient Temperature (°F):

Silica Gel Weight Gain (g): 31.1

Record all Data Every 3 Minutes

Leak Rate 0.01 CFM at "H

Trav- erse Point No.	Time		Velocity Pressure ( $"\text{H}_2\text{O}$ )	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ( $"\text{H}_2\text{O}$ )	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Samplin Train Static Pressur ( $"\text{Hg}$ )
	Samp- ling (min)	Clock			Volume ( $\text{ft}^3$ )	Temp (°F) Inlet      Outlet				
	2	0	1415	0.77	185	368.440	90      90	2.42	210	82
2	3	1418	0.79	187	370.99	91      90	2.48	210	78	
3	6	1421	0.84	190	373.62	92      90	2.63	210	73	
4	9	1424	0.89	190	376.40	91      90	2.80	215	73	
5	12	1427	0.90	195	279.28	100      91	2.82	215	73	
6	15	1430	0.89	195	382.10	102      92	2.79	215	73	
7	18	1433	0.90	195	385.98	103      92	2.83	222	76	
8	21	1436	0.92	195	388.40	104      94	2.90	222	76	
9	24	1439	0.92	193	390.7	105      95	2.91	222	76	
10	27	1442	0.94	193	393.59	106      96	2.98	222	76	
11	30	1445	0.95	191	396.56	107      96	3.03	222	76	
12	33	1448	0.87	190	399.41	110      97	2.78	230	76	
13	36	1451	0.85	187	402.24	110      98	2.73	230	76	
14	39	1454	0.74	184	405.11	110      99	2.39	230	77	
15	42	1457	0.80	200	408.0	108      99	2.50	230	78	
16	45	1535	0.73	190	410.42	100      96	2.31	230	80	
17	48	1538	0.70	186	413.20	108      101	2.24	230	80	
AVERAGE (TOTAL)					( )					

## SAMPLING TRAIN DATA

Company: EPA Task C  
 Source Designation: scrubber outlet  
 Date: 10-4-78  
 Test Number: P-3 over 1  
 Field Person: DLS 10  
 Filter Number:  
 Barometric Pressure ("Hg): 29.85  
 Stack Static Pressure ("H<sub>2</sub>O): 0.74  
 Stack Dimensions: 4 1/2" ID 8"  
 Plume Appearance:  
 Ambient Temperature (°F):  
 Record all Data Every 3 Minutes

Filter Heater Setting: \_\_\_\_\_  
 Probe Heater Setting: \_\_\_\_\_  
 Nozzle Number: \_\_\_\_\_, Dia. (in.): \_\_\_\_\_  
 Pitot Tube No. \_\_\_\_\_, Corr. Factor: \_\_\_\_\_  
 Meter Box No. \_\_\_\_\_, Corr. Factor: \_\_\_\_\_  
 Meter Isokinetic Factor: \_\_\_\_\_  
 Assumed Moisture (%): \_\_\_\_\_  
 Condensate Volume (ml): \_\_\_\_\_  
 Silica Gel Weight Gain (g): \_\_\_\_\_  
 Leak Rate \_\_\_\_\_ CFM at \_\_\_\_\_ "Hg

Trav- erse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Train Gas Temp (°F)	Samplin g Train Static Pressur ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F) Inlet      Outlet				
18	51	1541	0.68	186	4116.1	109 101	2.19	230	80	
519	54	1544	0.660	184	418.2	110 101	2.14	230	80	
519	67	1547	0.67	183	420.74	111 102	2.18	230	80	
W2	60	1556	0.7	184	423.28	105 100	2.26	230	80	
2	103	1553	0.72	184	425.89	110 103	2.34	230	80	
3	64	1556	0.74	184	428.46	110 103	2.40	220	80	
4	69	1559	0.78	186	431.30	113 104	2.27	220	80	
5	72	1605	0.75	184	433.72	110 104	2.44	220	80	
6	75	1608	0.72	184	436.36	112 104	2.34	220	80	
7	18	1611	0.71	182	438.97	114 105	2.52	220	80	
8	81	1614	0.75	183	441.56	115 105	2.45	205	77	
9	84	1617	0.80	183	444.21	115 106	2.62	205	77	
10	81	1620	0.85	185	447.0	116 106	2.78	205	77	
11	93	1623	0.90	185	449.79	116 106	2.94	205	77	
12	93	1626	0.98	188	453.41	116 106	3.19	205	77	
13	96	1629	0.94	188	455.17	116 106	3.06	205	77	
14	99	1632	0.96	188	458.82	117 106	3.12	205	77	
AVERAGE (TOTAL)					( )					



## SAMPLING TRAIN DATA

$$\Delta m = 1.24 \frac{T_a}{T_s} \cdot H$$

Company:

Source Designation: Outlet (scrubber)Date: 10-3-78Filter Heater Setting: 60Test Number: P-1Probe Heater Setting: 50Field Person: (-MS / TVMNozzle Number: 3/16, Dia. (in.): 0.1875Filter Number: -11Pitot Tube No. 38, Corr. Factor: 1.028Barometric Pressure ("Hg): 29.81Meter Box No. RAC 4, Corr. Factor: 1.02Stack Static Pressure ("H<sub>2</sub>O): + .75 H<sub>2</sub>OMeter Isokinetic Factor: 1575Stack Dimensions: 4.5' ØAssumed Moisture (%): 490

Plume Appearance:

Condensate Volume (ml):

Ambient Temperature (°F):

Silica Gel Weight Gain (g):

Record all Data Every 3 MinutesLeak Rate .00 CFM at 20 "Hg

Trav- erse Point No.	Time		Velocity Pressure (H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential (H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)	
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet	Temp (°F)				
5-3	0	16:00	.86	75	346.850	81	81	1.08	210	82	0.0
2	3		.86	75	348.6	81	81	1.08	215	70	0.0
3	6		.86	75	350.1	81	81	1.08	215	70	0.0
4	9		.91	75	352.2	93	86	1.13	215	69	0.0
5	12		1.1	75	353.8	94	96	1.38	205	69	0.0
6	15		.85	75	356.1	100	86	1.08	205	69	0.0
7	18		.90	75	357.7	101	89	1.14	205	69	0.0
8	21		.86	75	360.0	104	86	1.09	200	70	0.0
9	24		.84	75	361.2	106	93	1.07	200	70	0.0
10	27		1.0	75	363.3	110	96	1.12	200	70	0.0
11	30		.84	75	364.7	110	96	1.07	200	70	0.0
12	33		1.1	75	366.6	110	97	1.4	200	70	0.0
13	36		1.3	75	368.6	110	94	1.65	200	70	1.0
14	39		1.5	75	371.2	114	95	1.91	200	70	1.0
15	42		1.7	75	373.1	114	98	2.16	200	70	1.5
16	45		1.4	75	376.0	120	100	2.44	200	72	2.0
17	48		1.9	75	378.2	122	100	2.44	200	72	2.5
AVERAGE (TOTAL)					( )						

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_  
 Source Designation: OUTLET (SCRUBBER)  
 Date: \_\_\_\_\_ Filter Heater Setting: 60  
 Test Number: P-1 (cont) Probe Heater Setting: 50  
 Field Person: L-M S / TVM Nozzle Number: 3/16, Dia. (in.): 0.1875  
 Filter Number: Pitot Tube No. 38, Corr. Factor: \_\_\_\_\_  
 Barometric Pressure ("Hg): 29.81 Meter Box No. RAKF, Corr. Factor: \_\_\_\_\_  
 Stack Static Pressure ("H<sub>2</sub>O): +.75 Meter Isokinetic Factor: 15.85  
 Stack Dimensions: 4.5' Ø Assumed Moisture (%): 47  
 Plume Appearance: Condensate Volume (ml): \_\_\_\_\_  
 Ambient Temperature (°F): Silica Gel Weight Gain (g): \_\_\_\_\_  
 Record all Data Every 3 Minutes Leak Rate .00 CFM at 7.2 "Hg

Trav- erse Point No.	Time		Velocity Pressure (H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)				
	Inlet	Outlet								
18	51	2.1	75	381.5	125	102	2.7	205	73	4.0
19	54	2.2	75	384.3	125	104	2.8	205	73	4.0
20	57	2.5	75	386.4	130	104	3.2	205	73	4.5
	60			389.2	100					
W.D.	6	17.14	75	389.2	110	108	1.02	200	80	0.0
2	63	1.82	75	391.3	114	108	1.02	200	80	0.0
3	66	1.48	75	393.0	118	110	.57	200	80	0.0
4	69	1.42	75	394.3	118	116	.53	200	75	0.0
5	72	17.25	75	395.7	120	110	.61	200	70	0.0
6	75	1.62	75	397.3	110	110	.755	200	70	0.0
7	78	1.65	75	399.0	110	110	.791	200	70	0.0
8	81	1.70	75	400.3	110	110	.853	205	69	0.0
9	84	1.67	75	402.2	110	110	.82	205	69	0.0
10	87	1.76	75	403.7	110	110	.93	205	69	0.0
11	90	1.2	75	405.0	110	110	1.46	205	68	0.0
12	93	1.6	75	407.3	112	110	2.0	205	68	1.5
13	96	1.5	75	410.0	120	112	1.88	205	68	1.3
AVERAGE (TOTAL)				( )	1					

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_  
 Source Designation: SCRUBBER (OUTLET)  
 Date: \_\_\_\_\_  
 Test Number: P-1 (cont)  
 Field Person: GMS. YTVW  
 Filter Number: \_\_\_\_\_  
 Barometric Pressure ("Hg): 29.81  
 Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_  
 Stack Dimensions: 4, 5' Ø  
 Plume Appearance: \_\_\_\_\_  
 Ambient Temperature (°F): \_\_\_\_\_  
 Record all Data Every 3 Minutes

Filter Heater Setting: 60  
 Probe Heater Setting: 50  
 Nozzle Number: 3/16, Dia. (in.) 0.1875  
 Pitot Tube No. 38, Corr. Factor: \_\_\_\_\_  
 Meter Box No. FAF44, Corr. Factor: \_\_\_\_\_  
 Meter Isokinetic Factor: 1.85  
 Assumed Moisture (%): 42  
 Condensate Volume (ml): 88  
 Silica Gel Weight Gain (g): 21.6  
 Leak Rate 0.0 CFM at 20 °Hg

Traverse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Sampling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)				
	Inlet	Outlet								
14	99		1.8	75	4120	121	112	2.3	205	68 2.0
15	102		1.9	75	415.0	125	114	2.4	205	68 2.0
16	105		2.1	75	417.2	127	115	2.7	205	68 2.5
17	108		2.1	75	420.2	127	115	2.7	205	68 2.5
18	110		2.2	75	422.7	130	115	2.8	205	68 2.5
19	114		2.1	75	425.8	130	115	2.7	205	68 2.5
20	117		2.2	75	428.6	132	115	2.8	205	68 4.0
					431,036					
AVERAGE (TOTAL)				105	( )	-	-	-	-	-

## SAMPLING TRAIN DATA

$$1.24 \left( \frac{T_{mt460}}{T_{ST460}} \right) H$$

Company:

Source Designation: Scrubber (OUTLET)

Date: 10-4-78

Filter Heater Setting: 65

Test Number: P-2

Probe Heater Setting: 50

Field Person: CMS/TUM

Nozzle Number: 3/16, Dia. (in.): 0.1815

Filter Number: 1

Pitot Tube No. 38, Corr. Factor: 0.829

Barometric Pressure ("Hg): 29.85

Meter Box No. RAC#4, Corr. Factor: 1.021

Stack Static Pressure ("H<sub>2</sub>O): 0.75

Meter Isokinetic Factor: 1585

Stack Dimensions: 4.5' Ø

Assumed Moisture (%): 49

Plume Appearance:

Condensate Volume (ml):

Ambient Temperature (°F):

Silica Gel Weight Gain (g): 2.1

Record all Data Every 3 Minutes

Leak Rate 0.01 CFM at 20 "Hg

Traverse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Train Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Sampling (min)	Clock			Volume (ft <sup>3</sup> )	Inlet Temp (°F)				
W-2	0	07:50	1.2	75	431,390	76	76	1.49	180	69 1.0
	2	3	1.2	75	433,7	90	82	1.5	180	69 1.0
	3	6	1.6	75	436,6	97	82	.85	180	69 1.0
	4	9	1.6	75	431.8	100	86	.86	180	69 1.0
	5	12	1.6	75	439.0	104	.86	.81	190	68 0.0
	6	15	1.63	75	440.3	104	.88	.81	190	65 0.0
	7	18	1.65	75	442.0	106	90	.89	190	65 0.0
	8	21	1.69	75	443.4	109	76	.89	190	65 0.0
	9	24	1.73	75	445.5	110	93	.95	190	65 0.0
	10	27	1.72	75	447.0	110	94	.93	190	65 0.0
	11	30	1.2	75	448.7	110	94	1.6	190	65 0.0
	12	33	1.5	75	450.4	114	96	1.4	195	65 1.0
	13	36	1.6	75	452.5	116	98	2.1	195	69 1.0
	14	39	1.8	75	455.6	120	100	2.4	195	69 2.0
	15	42	1.7	75	457.8	120	100	2.2	195	69 2.0
	16	45	1.8	75	460.5	122	100	2.3	195	69 2.0
	17	48	2.0	75	463.2	124	102	2.6	195	69 2.0
AVERAGE (TOTAL)				( )						

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_

Source Designation: SCRUBBING OUTLET

Date: 10-4-78

Filter Heater Setting: 65

Test Number: P-12 (Cont)

Probe Heater Setting: 50

Field Person: GMS / TMM

Nozzle Number: 21, Dia. (in.): 0.812

Filter Number: \_\_\_\_\_

Pitot Tube No. 3K, Corr. Factor: \_\_\_\_\_

Barometric Pressure ("Hg): \_\_\_\_\_

Meter Box No. 12ACM, Corr. Factor: \_\_\_\_\_

Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_

Meter Isokinetic Factor: 1585

Stack Dimensions: 4.5' Ø

Assumed Moisture (%): 47%

Plume Appearance: \_\_\_\_\_

Condensate Volume (ml): \_\_\_\_\_

Ambient Temperature (°F): \_\_\_\_\_

Silica Gel Weight Gain (g): \_\_\_\_\_

Record all Data Every 3 Minutes

Leak Rate 0.01 CFM at 20 "Hg

Trav- erse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Sampling Imp. Train Gas Temp (°F)	Sampling Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F) Inlet      Outlet				
14	51		1.9	75	466.1	124 104	2.5	195	71	4.0
19	54		1.9	75	468.7	126 104	2.5	195	71	4.0
20	57		1.4	75	471.4	126 104	2.5	195	71	4.0
	60	9:50			473.9					
52	- 9:53	.92	75	473.4	110	104	1.7	195	71	0.0
2	63	.92	75	475.4	114	114	1.4	205	71	0.0
3	66	.78	75	477.2	114	114	1.0	210	71	0.0
4	69	.77	75	478.8	120	114	1.0	210	71	0.0
5	72	.80	75	480.4	120	114	1.1	210	71	0.0
6	75	.80	75	482.6	122	114	1.1	210	71	0.0
7	78	.82	75	484.7	122	114	1.1	210	71	0.0
8	81	.80	75	486.4	124	114	1.1	210	71	0.0
9	84	.86	75	488.2	124	114	1.2	210	71	0.0
10	87	.83	75	490.2	124	114	1.1	210	71	0.0
11	90	.80	75	492.0	124	114	1.1	210	71	0.0
12	93	.85	110	493.6	124	114	1.1	210	71	0.0
13	96	1.1	110	495.3	124	114	1.5	210	71	0.0
AVERAGE (TOTAL)				( )						

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_  
 Source Designation: SCRubber (OUTLET)  
 Date: 10-4-78 Filter Heater Setting: 65  
 Test Number: P-2 (Cont) Probe Heater Setting: 50  
 Field Person: GMS TVM Nozzle Number: 316, Dia. (in.): 0.122  
 Filter Number: A-263 - 13 Pitot Tube No. 33, Corr. Factor: \_\_\_\_\_  
 Barometric Pressure ("Hg): \_\_\_\_\_ Meter Box No. RAC#4, Corr. Factor: \_\_\_\_\_  
 Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_ Meter Isokinetic Factor: 1585  
 Stack Dimensions: 4.5' Ø Assumed Moisture (%): 49  
 Plume Appearance: \_\_\_\_\_ Condensate Volume (ml): 90  
 Ambient Temperature (°F): \_\_\_\_\_ Silica Gel Weight Gain (g): 21.6  
 Record all Data Every 3 Minutes Leak Rate 0.01 CFM at 20 "Hg

Trav- erse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differ- ential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Samp- ling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F) Inlet      Outlet				
14	99		1.3	110	498.1	126 114	1.6	210	71	1.0
15	102		1.4	110	500.5	128 114	1.8	210	71	1.5
16	105		1.6	110	502.9	128 114	2.0	210	73	2.0
17	108		1.7	110	505.7	130 114	2.2	210	73	2.0
18	111		2.2	110	508.2	130 114	2.8	210	73	3.0
19	114		2.2	110	510.4	132 114	2.8	210	73	3.0
20	117		2.4	110	513.5	136 111	3.0	210	73	4.0
	120				576.747					
					82.9		3			
AVERAGE (TOTAL)				5	(83.64)	111	104	1.59		

## SAMPLING TRAIN DATA

1.29 ( $\frac{T_m + T_{460}}{T_{ST} + T_{460}}$ )

Company:

Source Designation: SCRUBBER (GROUT)

Date: 10-4-75

Test Number: 0-3

Field Person: G-MIS ITVM

Filter Number: A - 263 - C9

Barometric Pressure ("Hg): 29.85

Stack Static Pressure ("H<sub>2</sub>O): 0.5

Stack Dimensions: 4.5' Ø

Plume Appearance:

Ambient Temperature (°F): 75°

Record all Data Every 3 Minutes

Filter Heater Setting: 65

Probe Heater Setting: 50

Nozzle Number: 31, Dia. (in.): 1.18

Pitot Tube No. 37, Corr. Factor: 1.2

Meter Box No. PACTS, Corr. Factor: 1.05

Meter Isokinetic Factor: 1585

Assumed Moisture (%): 4%

Condensate Volume (ml): 87

Silica Gel Weight Gain (g): 28.6

Leak Rate 0.01 CFM at 16 °Hg

Traverse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Train Gas Temp (°F)	Sampling Static Pressure ("Hg)
	Sampling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)				
	Inlet	Outlet								
1-2	0	14:15	1.3	100	516,799	92 92	1.6	165	71	1.0
2	3		1.3	100	518.5	94 92	1.6	165	71	1.0
3	6		.79	100	520.4	98 92	.97	165	71	0.0
4	9		.81	100	522.2	100 99	1.0	180	70	0.0
5	12		.75	105	524.2	104 94	.92	190	70	0.0
6	15		.75	105	526.0	104 94	.92	190	70	0.0
7	18		.71	105	528.0	105 98	.88	205	74	0.0
8	21		.72	105	530.0	110 98	.89	205	71	0.0
9	24		.72	105	531.3	110 98	.89	205	71	0.0
10	27		.74	105	532.8	112 100	.92	205	71	0.0
11	30		1.3	105	534.4	114 100	1.6	205	71	0.0
12	33		1.6	105	537.0	116 102	2.0	205	71	2.0
13	36		1.5	105	539.0	120 104	1.4	205	71	2.0
14	39		1.6	105	541.4	122 104	2.0	205	71	2.0
15	42		1.6	105	544.6	124 106	2.0	205	71	2.0
16	45	10:15:55	1.7	105	546.9	110 110	2.1	205	71	2.0
17	48		1.7	105	549.3	118 112	2.3	205	71	2.0
AVERAGE (TOTAL)					( )					

## SAMPLING TRAIN DATA

Company: \_\_\_\_\_  
 Source Designation: Sulfur (cont'd)  
 Date: 10-4-78 Filter Heater Setting: 61  
 Test Number: P-3 (contd) Probe Heater Setting: 50  
 Field Person: \_\_\_\_\_ Nozzle Number: 3/16, Dia. (in.): 0.17  
 Filter Number: A-263-13 Pitot Tube No. 38, Corr. Factor: \_\_\_\_\_  
 Barometric Pressure ("Hg): \_\_\_\_\_ Meter Box No. K-107, Corr. Factor: \_\_\_\_\_  
 Stack Static Pressure ("H<sub>2</sub>O): \_\_\_\_\_ Meter Isokinetic Factor: \_\_\_\_\_  
 Stack Dimensions: 4.5" Assumed Moisture (%): 42  
 Plume Appearance: \_\_\_\_\_ Condensate Volume (ml): \_\_\_\_\_  
 Ambient Temperature (°F): 75° Silica Gel Weight Gain (g): \_\_\_\_\_  
 Record all Data Every 3 Minutes Leak Rate 0.01 CFM at 76 "Hg

Traverse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differential ("H <sub>2</sub> O) InletOutlet	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)
	Sampling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)				
13	51		1.1	105	5514	126	112 2.4	215	70	3.0
14	54		1.4	105	5542	130	113 2.4	215	70	3.0
20	57		1.4	105	556.7	130	113 2.4	215	70	3.0
	6.1				554.0					
5-2	-15.54	1.1	105	559.0	126	114	1.4	215	70	0.5
2	63		1.6	105	561.6	124	115 1.3	215	70	0.5
3	66		.89	105	562.4	126	116 1.1	215	70	0.5
4	69		.98	105	565.1	128	116 1.3	215	70	0.0
5	72		.98	105	567.6	120	116 1.2	220	70	0.5
6	75		.93	105	569.1	126	118 1.2	220	70	0.2
7	78		.89	105	571.3	125	118 1.1	220	70	0.2
8	81		.91	105	573.0	12	118 1.2	220	70	0.1
9	84		.83	105	575.0	130	118 1.1	220	70	0.0
10	87		.78	105	577.4	130	120 1.0	220	70	0.0
11	90		.82	105	578.4	130	120 1.0	220	70	0.0
12	93		.91	105	589.4	130	120 1.2	220	70	0.0
13	96		1.1	105	582.6	130	120 1.1	220	70	0.5
<b>AVERAGE (TOTAL)</b>					( )					

## SAMPLING TRAIN DATA

Company:

Source Designation: RUBBER (EX-LET)

Date: 10-4-78

Filter Heater Setting: 65

Test Number: P-2 (cont)

Probe Heater Setting: 50

Field Person: GHS/TM

Nozzle Number:  $\frac{3}{16}$ , Dia. (in.):  $\frac{1}{16}$ 

Filter Number: A-265-13

Pitot Tube No. 3P, Corr. Factor:

Barometric Pressure ("Hg): 29.85

Meter Box No. ~~210~~, Corr. Factor:Stack Static Pressure ("H<sub>2</sub>O):

Meter Isokinetic Factor: 15.85

Stack Dimensions: 4.5' x 6'

Assumed Moisture (%): 4.5

Plume Appearance:

Condensate Volume (ml):

Ambient Temperature (°F): 75°

Silica Gel Weight Gain (g):

Record all Data Every 3 Minutes

Leak Rate 0.01 CFM at  $\frac{1}{16}$ " Hg

Traverse Point No.	Time		Velocity Pressure ("H <sub>2</sub> O)	Stack Temp (°F)	Dry Gas Meter		Orifice Pressure Differential ("H <sub>2</sub> O)	Filter Box Temp (°F)	Last Imp. Gas Temp (°F)	Sampling Train Static Pressure ("Hg)	
	Sampling (min)	Clock			Volume (ft <sup>3</sup> )	Temp (°F)					
	Inlet	Outlet									
14	94		1.3	105	584.2	128	120	1.6	210	80	1.0
15	102		1.5	105	584.8	130	120	1.9	210	80	1.5
16	105		1.5	105	589.6	130	120	1.9	210	80	1.5
17	108		1.7	105	591.2	130	120	2.2	210	80	2.0
18	110		2.0	105	593.7	130	120	2.4	210	80	3.0
19	114		2.1	105	596.3	130	120	2.7	210	80	3.5
20	117		2.1	105	599.1	130	120	2.7	210	80	3.5
	120				661.744						
AVERAGE (TOTAL)				104 (11.25)		130	110	1.53			

APPENDIX B-2

SAMPLING SUMMARY DATA

Table B-2.1. Summary of Stack Conditions and Flowrates

Sample Location	Sample No.	Date (1978)	Temperature		Stack Flowrate		
			°F	°C	DSCFM	ACFM	DSM <sup>3</sup> min.
Inlet	P-1	10-3	182	83	43,000	53,100	1220 1510
	P-2	10-4	188	87	42,300	52,800	1200 1490
	P-3	10-4	188	87	42,300	52,900	1200 1500
	Average		186	86	42,500	52,900	1210 1500
Outlet	P-1	10-3	105 <sup>a</sup>	41	51,100	58,300	1450 1650
	P-2	10-4	110 <sup>a</sup>	43	50,200	57,700	1420 1630
	P-3	10-4	104	40	51,000	58,200	1440 1650
	Average		106	41	50,800	58,100	1440 1640

<sup>a</sup> Due to a malfunctioning pyrometer, these temperatures are estimated based on the preliminary and subsequent temperature traverses.

SAMPLING SUMMARY SHEET

Plant Dow-Badische

Location Freeport, Texas

Sampled Source Ammonium Sulfate - Inlet

Run	Date	N <sub>p</sub>	P <sub>m</sub>	P <sub>b</sub>	V <sub>m</sub>	T <sub>m</sub>	V <sub>m std</sub>	V <sub>w</sub>	V <sub>w gas</sub>	%M	M <sub>d</sub>
P-1	10-3-78	40	2.34	29.81	103.630	99	98.102	76.7	3.61	3.5	0.964
P-2	10-4-78	40	2.65	29.85	108.387	102	102.272	84.3	3.97	3.7	0.963
P-3	10-4-78	40	2.68	29.85	110.737	104	104.126	91.1	4.29	4.0	0.960

Run	MW <sub>d</sub>	MW	P <sub>st</sub>	P <sub>s</sub>	C <sub>p</sub>	$\sqrt{\Delta P_s \times (T_s + 460)}^c$	V <sub>s</sub>	T <sub>s</sub>	T <sub>t</sub>	D <sub>n</sub>	%I
P-1	28.96	28.57	+0.7	30.51	0.828	23.28	3343	182	120	0.249	88.8
P-2	28.96	28.56	+0.7	30.55	0.828	23.13	3320	188	120	0.249	94.1
P-3	28.96	28.51	+0.7	30.55	0.828	23.17	3329	188	120	0.249	95.9

$$V_{w std} = \frac{17.65 \times V_w (P_b + P_m)}{(T_m + 460)}$$

$$\bar{x} H = \frac{100 \times V_{w gas}}{V_{std} + V_{w gas}}$$

H<sub>p</sub>

Total No. of Sampling Points

P<sub>m</sub> Average Driftage Pressure Drop, in. H<sub>2</sub>O

V<sub>w gas</sub> Volume of Water Vapor Collected at STP, SCF

P<sub>st</sub> Static Pressure of Stack Gas, in. Hg

P<sub>b</sub> Barometric Pressure, in. Hg Absolute

$\bar{x} H$  % Moisture by Volume

P<sub>s</sub> Stack Gas Pressure, in. Hg Absolute

V<sub>m</sub> Volume of Dry Gas at Meter Conditions, DCF

H<sub>d</sub> Hole Fraction of Dry Gas

C<sub>p</sub> Pilot Tube Coefficient

T<sub>m</sub> Average Meter Temperature, °F

$\bar{x} CO_2$  Volume % Dry

V<sub>s</sub> Stack Gas Velocity at Stack Conditions, fpm.

MW<sub>d</sub> = (XCO<sub>2</sub> × 44) + (XO<sub>2</sub> × 32) + (XCO + XH<sub>2</sub>) × 28

$\bar{x} O_2$  Volume % Dry

T<sub>s</sub> Average Stack Temperature °F

MW = MW<sub>d</sub> × H<sub>d</sub> + 18 (1 - H<sub>d</sub>)

XCO Volume % Dry

T<sub>t</sub> Net Time of Test, Min.

P<sub>s</sub> = P<sub>b</sub> ± P<sub>st</sub>

H<sub>d</sub> Molecular Weight of Stack Gas, Dry Basis

D<sub>n</sub> Sampling Nozzle Diameter, in.

V<sub>w</sub> Total H<sub>2</sub>O Collected in Ingemeters and Silica Gel, ml

HM Molecular Weight of Stack Gas, Wet Basis

XI Percent Isokinetic

XI =  $\frac{1.032 \times (T_s + 460) \times V_{m std}}{V_s + T_s \times P_s \times H_d \times (D_n)^2}$  1/2

\* Dry standard cubic feet at 68°F, 29.92 in. Hg.

standard conditions at 68°F, 29.92 in. Hg.

\*\*  $\sqrt{\Delta P_s \times (T_s + 460)}$  is determined by averaging the square root of the product of the velocity head ( $\Delta P_s$ ) and the absolute

## SAMPLING SUMMARY SHEET

Plant Dow-Badische

Location Freeport, Texas

Sampled Source Ammonium Sulfate - Outlet

Run	Date	N <sub>p</sub>	P <sub>m</sub>	P <sub>b</sub>	V <sub>m</sub>	T <sub>m</sub>	V <sub>m std</sub>	V <sub>w</sub>	V <sub>w gas</sub>	%M	M <sub>d</sub>
P-1	10-3-78	40	1.62	29.81	85.954	107	80.080	109.6	5.16	6.1	0.939
P-2	10-4-78	40	1.59	29.85	86.639	110	80.394	111.6	5.26	6.1	0.939
P-3	10-4-78	40	1.57	29.85	86.780	115	79.821	115.6	5.44	6.4	0.936

Run	MW <sub>d</sub>	MW	P <sub>st</sub>	P <sub>s</sub>	C <sub>P</sub>	$\sqrt{\Delta P_s X (T_s + 460)^c}$	V <sub>s</sub>	T <sub>s</sub>	T <sub>t</sub>	D <sub>n</sub>	%I
P-1	28.96	28.30	0.055	29.86	0.829	26.09	3810	105	120	0.1875	103.6
P-2	28.96	28.29	0.055	29.90	0.829	25.82	3769	110	120	0.1875	106.3
P-3	28.96	28.26	0.055	29.90	0.829	26.04	3803	104	120	0.1875	103.5

$$\frac{17.85 \times V_m (P_b + P_m)}{(T_s + 460)} = \frac{100 \times V_{w gas}}{V_{std} + V_{w gas}}$$

$$\bar{x} H = \frac{100 \times V_{w gas}}{V_{std} + V_{w gas}}$$

 $H_p$  Total No. of Sampling Points $P_m$  Average Driftless Pressure Drop, in. H<sub>2</sub>O $P_b$  Barometric Pressure, in. lg. Absolute $V_m$  Volume of Dry Gas at Meter Conditions, DCF $T_m$  Average Meter Temperature, °F $V_{std}$  Volume of Dry Gas at STP, DSCF $V_w$  Total H<sub>2</sub>O Collected in Inggers and Silica Gel, ml $V_{w gas}$  Volume of Water Vapor Collected at STP, SCF $\bar{x} H$  % Moisture by Volume $H_d$  Mole Fraction of Dry Gas $\bar{x} CO_2$  Volume % Dry $\bar{x} O_2$  Volume % Dry $\bar{x} CO$  Volume % Dry $\bar{x} H_2$  Volume % Dry $MW_d$  Molecular Weight of Stack Gas, Dry Basis $MW$  Molecular Weight of Stack Gas, Wet Basis $P_{st}$  Static Pressure of Stack Gas, in. lg $P_s$  Stack Gas Pressure, in. Hg Absolute $C_P$  Pitot Tube Coefficient $V_s$  Stack Gas Velocity at Stack Conditions, fpm. $T_s$  Average Stack Temperature °F $T_t$  Net Time of Test, Min. $D_n$  Sampling Nozzle Diameter, in. $\bar{x} I$  Percent Isokinetic<sup>a</sup> Dry standard cubic foot at 68°F, 29.92 in. lg.<sup>b</sup> Standard conditions at 68°F, 29.92 in. lg.<sup>c</sup>  $\sqrt{C_P \times (T_s + 460)}$  is determined by averaging the square root of the product of the velocity head (fpm) and the absolute

$$V_s = 8120.8 \times C_P \times \sqrt{C_P \times (T_s + 460)} \left[ \frac{1}{T_s + MW} \right]^{1/2}$$

$$\bar{x} I = \frac{1.032 \times (T_s + 460) \times V_{w gas}}{V_s \times T_s \times P_s \times H_d \times (D_n)^2}$$

APPENDIX B-3

PARTICLE SIZING DATA SHEET



APPENDIX B-4

VISIBLE EMISSIONS DATA SHEETS

**SUMMARY  
RECORD OF VISIBLE EMISSIONS**

Type of Plant Ammonium Sulfate

Date 10/3/78

Company Name Dow-Badische Agro Task

Hours of Observation \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer A Lazarevic

Type of Discharge STACK OTHER \_\_\_\_\_

Discharge Location Scrubber Outlet

Height of Point of Discharge 55'

Observer's Location:

Distance to Discharge Point 250'

Height of Observation Point ground level

Direction from Discharge Point 105° East

Background Description Gras elevator shaft

Weather: Clear Overcast Partly Cloudy Other \_\_\_\_\_ Color black/grey

Wind Direction SE 125° Wind Velocity 5 mi/hr

Plume Description:

Detached: Yes No

Color: Black White Other \_\_\_\_\_

Plume Dispersion Behavior: Looping Coning Fanning

Lofting Fumigating Other straight up

Estimated Distance Plume Visible \_\_\_\_\_

Summary of Observations:

<u>Opacity</u>	<u>Aggregate Time @ Opacity</u>		<u>Opacity</u>	<u>Aggregate Size @ Opacity</u>
	min.	sec.		
0			55	
5			60	
10			65	
15			70	
20			75	
25			80	
30			85	
35			90	
40			95	
45			100	
50				

## RECORD OF VISIBLE EMISSIONS

Company Name Dow Badische Epox K6 Date 10/3/78  
 Plant Address \_\_\_\_\_ Observer V Loprinse  
 Stack Location \_\_\_\_\_ Observer's Location 105° East  
 Weather Conditions Overcast - Occasional  
haze

HR	MIN	TIME				COMMENTS
		00	15	30	45	
15.16	00	10	10	10	10	- using green elevator shaft to read off of.
	01	10	10	10	10	- very overcast day
	02	10	10	10	10	
	03	10	10	10	10	5 pnts.
15.20	04	10	10	10	10	
	05	10	10	10	10	
	06	10	10	10	10	
	07	10	10	10	10	
	08	10	10	10	10	
	09	10	10	10	10	
	10	10	10	10	10	
	11	10	10	10	10	
	12	10	10	10	10	
	13	10	10	10	10	
15.30	14	10	10	10	10	
	15	10	10	10	10	
	16	10	10	10	10	
	17	10	10	10	10	
	18	10	10	10	10	
	19	10	10	10	10	
	20	10	10	10	10	
	21	10	10	10	10	
	22	10	10	10	10	
	23	10	10	10	10	
	24	10	10	10	10	
	25	10	10	10	10	
	26	10	10	10	10	
	27	10	10	10	10	
	28	10	10	10	10	
15.45	29	10	10	10	10	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS	Pg. 2 10
		00	15	30	45		
15	42	30	10	10	10		
		31	10	10	10		
		32	10	10	10		
		33	10	10	10		
		34	10	10	10		
		35	10	10	10		
		36	10	10	10		
		37	10	10	10		
		38	10	10	10		
15	55	39	10	10	10		
	↓	40	10	10	10		
		41	10	10	10		
		42	10	10	10		
		43	10	10	10		
		44	10	10	10		
		45	10	10	10		
		46	10	10	10	TEST STARTED (16:40)	
16	03	47	10	10	10		
		48	10	10	10		
		49	10	10	10		
		50	10	10	10		
		51	10	10	10		
16	09	52	10	10	10		
		53	10	10	10		
		54	10	10	10		
		55	10	10	10		
		56	10	10	10		
		57	10	10	10		
		58	10	10	10		
		59	10	10	10		

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_ Date \_\_\_\_\_  
 Plant Address \_\_\_\_\_ Observer \_\_\_\_\_  
 Stack Location \_\_\_\_\_ Observer's  
 Weather Conditions \_\_\_\_\_ Location \_\_\_\_\_

pg 3/

HR	MIN	TIME				COMMENTS
		00	15	30	45	
16:16	00	10	10	10	10	- steady smoke
	01	10	10	10	10	-
	02	10	10	10	10	-
	03	10	10	10	10	-
	04	10	10	10	10	-
	05	10	10	10	10	-
	06	10	10	10	10	
	07	10	10	10	10	
	08	10	10	10	10	
16:25	09	10	10	10	10	
	10	10	10	10	10	
	11	10	10	10	10	
	12	10	10	10	10	
	13	10	10	10	10	
16:30	14	10	10	10	10	rain stopped
	15	10	10	10	10	
	16	10	10	10	10	
	17	10	10	10	10	
	18	10	10	10	10	
	19	10	10	10	10	
	20	10	10	10	10	
	21	10	10	10	10	
	22	10	10	10	10	
	23	10	10	10	10	
	24	10	10	10	10	
	25	10	10	10	10	
	26	10	10	10	10	
	27	10	10	10	10	
	28	10	10	10	10	
16:45	29	10	10	10	10	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
	30	10	10	10	10	
1647	31	10	10	10	10	
	32	10	10	10	10	
	33	10	10	10	10	
	34	10	10	10	10	
	35	10	10	10	10	
	36	10	10	10	10	
	37	10	10	10	10	
	38	10	10	10	10	
	39	10	10	10	10	
	40	10	10	10	10	
	41	10	10	10	10	
	42	10	10	10	10	
	43	10	10	10	10	
17:00	44	10	10	10	10	
	45	10	10	10	10	1
	46	10	10	10	10	
17.03	47	10	10	10	10	changing ports (w)
	48	10	10	10	10	
	49	10	10	10	10	
	50	10	10	10	10	
	51	10	10	10	10	
	52	10	10	10	10	
	53	10	10	10	10	
	54	10	10	10	10	
	55	10	10	10	10	
	56	10	10	10	10	
	57	10	10	10	10	
	58	10	10	10	10	
17:15	59	10	10	10	10	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_ Date \_\_\_\_\_  
 Plant Address \_\_\_\_\_ Observer \_\_\_\_\_  
 Stack Location \_\_\_\_\_ Observer's  
 Weather Conditions \_\_\_\_\_ Location \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
17	16	00	10	10	10	
		01	10	10	10	
		02	10	10	10	
		03	10	10	10	
		04	10	10	10	
(7)	21	05	10	10	10	
(7)	22	06	10	10	10	
		07	10	10	10	
		08	10	10	10	
		09	10	10	10	
		10	10	10	10	
(8)	23	11	10	10	10	
		12	10	10	10	
		13	10	10	10	
		14	10	10	10	
(8)	24	15	10	10	10	Stop test - system down
(8)	25	16	10	10	10	wind has died down 0-5 Start up
		17	10	10	10	
		18	10	10	10	
		19	10	10	10	
		20	10	10	10	
(8)	25	21	10	10	10	
		22	10	10	10	
		23	10	10	10	
		24	10	10	10	
		25	10	10	10	
		26	10	10	10	
		27	10	10	10	
		28	10	10	10	
		29	10	10	10	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
8:14	30	10	10	10	10	
	31	10	10	10	10	wind changed direction NW 0-5 mph
	32	10	10	10	10	
8:12	33	10	15	15	15	
	34	15	15	15	15	
	35	15	15	15	15	
	36	15	15	15	15	
	37	15	15	15	15	
	38	15	15	15	15	
8:13	39	15	15	15	15	
	40	15	15	15	15	
	41	15	15	15	15	
	42	15	15	15	15	
	43	15	15	15	15	
	44	10	15	15	15	
	45	15	15	15	15	
	46	15	15	15	15	
	47	15	15	15	15	
	48	15	15	15	15	
	49	15	15	15	15	
	50	15	15	15	15	
	51	15	15	15	15	
	52	15	15	15	15	
	53	15	15	15	15	
8:18	54	15	15	15	15	
	55	15	15	15	15	
	56	15	15	15	15	
	57	15	15	15	15	
	58	15	15	15	15	
8:19	59	15	15	15	15	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_ Date \_\_\_\_\_  
Plant Address \_\_\_\_\_ Observer \_\_\_\_\_  
Stack Location \_\_\_\_\_ Observer's  
Weather Conditions \_\_\_\_\_ Location \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
00	15	15	15	15		
01	15	15	15	15		
02	15	15	15	15		
(4-27)	03	15	15	15	15	
	04	10				
	05					
	06					
	07					
	08					
	09					
	10					
	11					
	12					
	13					
	14					
	15					
	16					
	17					
	18					
	19					
	20					
	21					
	22					
	23					
	24					
	25					
	26					
	27					
	28					
	29					

SUMMARY  
RECORD OF VISIBLE EMISSIONS

10 P 2

Type of Plant Amonium Sulfate

Date 10-4-78

Company Name Dow Chemical

Hours of Observation \_\_\_\_\_

Plant Address Town

Observer Dawn Schick

Type of Discharge STACK OTHER \_\_\_\_\_

Discharge Location Scrubber Exhaust

Height of Point of Discharge .55

Observer's Location:

Distance to Discharge Point 60'

Height of Observation Point .55

Direction from Discharge Point SE

Background Description \_\_\_\_\_

Weather: Clear Overcast Partly Cloudy Other Windy Color 66

Wind Direction N E Wind Velocity 15 mi/hr

Plume Description:

Detached: Yes No

Color: Black White Other \_\_\_\_\_

Plume Dispersion Behavior: Looping Coning Fanning  
Lofting Fumigating Other \_\_\_\_\_

Estimated Distance Plume Visible 10'

Summary of Observations:

Opacity	Aggregate Time @ Opacity	Opacity	Aggregate Time @ Opacity
---------	--------------------------	---------	--------------------------

0	min.	sec.	55
5			60
10			65
15			70
20			75
25			80
30			85
35			90
40			95
45			100

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date 10-4-78

Plant Address \_\_\_\_\_

Observer Donna Schmitz

Stack Location \_\_\_\_\_

Observer's Location 100' SE of StackWeather Conditions Blowing NNE

HR	MIN	TIME				COMMENTS
		00	15	30	45	
30						
31						
32						
33						
34						
35						
36						
37						
38						
39						
40	40	5	5	5	5	P-2
41	41	5	5	5	5	
42	42	5	5	5	5	S-10 int of NE
43	43	5	5	5	5	
44	44	5	5	5	0	
45	45	5	5	5	5	
46	46	5	0	5	5	
47	47	5	5	5	5	
48	48	5	5	5	5	
49	49	5	5	5	5	
50	50	5	5	5	5	
51	51	5	5	5	5	
52	52	5	5	5	5	
53	53	5	5	5	5	
54	54	0	5	0	5	
55	55	3	0	0	5	
56	56	5	5	0	5	
57	57	5	5	5	5	
58	58	0	5	0	0	
59	59	5	0	5	0	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
00	0	0	5	0		
01	5	5	5	5		
02	5	5	5	0		
03	5	0	5	5		
04	0	0	5	0		
05	0	0	0	5		
06	5	0	5	5		
07	5	5	0	5		
08	5	0	0	5		
09	0	0	5	0		
10	5	5	5	5		
11	5	5	5	5		
12	5	5	5	5		
13	5	5	5	0		
14	5	0	0	0		
15	5	5	0	5		
16	5	5	5	5		
17	5	5	0	0		
18	0	5	0	5		
19	0	0	0	0		
20	0	0	0	0		
21	0	0	0	5		
22	5	5	0	5		
23	5	5	0	5		
24	5	5	0	0		
25	5	5	0	0		
26	5	5	5	5		
27	0	0	0	0		
28	5	5	5	5		
29	0	5	5	0		

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
30	5	5	0	5	0	
31	0	5	0	0	0	
32	0	0	0	0	0	
33	0	2	0	0	0	
0134	34	0	0	0	0	
	35	0	0	0	0	
	36	0	0	0	0	
	37	0	0	0	0	
	38	0	5	0	0	
	39	0	0	0	0	
	40	0	0	0	0	
	41	0	0	0	5	
	42	0	0	0	0	
	43	0	0	0	0	
	44	0	0	5	0	
	45	0	0	0	0	
	46	0	0	0	0	
	47	0	0	0	0	
	48	0	0	0	0	
	49	0	0	0	0	
	50	0	0	0	0	Post Change
	51	0	0	0	0	
	52	0	0	5	0	
	53	5	0	0	0	
	54	0	0	0	0	
	55	0	0	0	0	
	56	0	0	0	0	
	57	0	0	0	0	
	58	0	0	0	0	
	59	0	0	5	0	

Company Name \_\_\_\_\_ Date \_\_\_\_\_

Plant Address \_\_\_\_\_ Observer \_\_\_\_\_

Stack Location \_\_\_\_\_ Observer's Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME			COMMENTS
		00	15	30	
10	00	0	0	0	Start at 2nd point
01	00	0	0	0	
02	05	0	0	0	
03	00	0	0	0	
04	00	0	0	0	
05	00	4	0	0	
06	5	0	0	5	
07	00	0	0	0	
08	00	0	0	0	
09	00	0	0	0	
10	00	0	0	0	
11	00	0	0	0	
12	00	0	0	0	
13	00	0	0	0	
14	00	0	0	0	
15	00	0	0	0	
16	0	0	5	0	
17	0	2	0	0	
18	0	0	0	0	
19	0	0	0	0	
20	0	0	0	0	
21	0	0	0	0	
22	0	0	0	0	
23	0	0	0	0	
24	0	0	0	0	
25	0	0	0	0	
26	0	0	0	0	
27	0	0	0	0	
28	0	5	0	0	
29	0	0	0	0	

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's

Weather Conditions \_\_\_\_\_

Location \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
30	0	0	0	0	0	
31	0	0	0	0	0	
32	0	0	0	0	0	
33	0	0	0	0	0	
34	0	0	0	0	0	
35	0	0	0	0	0	
36	0	0	0	0	0	
37	0	0	0	0	0	
38	0	0	0	0	0	
39	0	0	0	0	0	
40	0	0	0	0	0	
41	0	0	0	0	0	
42	0	0	0	0	0	
43	0	0	0	0	0	
44	0	0	0	0	0	
45	0	0	0	0	0	
46	0	0	0	0	0	
47	0	5	0	0	0	
48	0	0	0	0	0	
49	0	0	0	0	0	
50	0	0	0	0	0	
51	0	0	0	0	0	
52	0	0	0	0	0	
53	0	0	0	0	0	
54	0	0	0	0	0	
55	5	0	0	0	0	
56	5	0	0	0	0	
57	0	5	0	0	0	
58	0	0	0	0	0	
59	0	0	0	0	0	

SUMMARY  
RECORD OF VISIBLE EMISSIONS

Type of Plant Ammmonium Sulfate

Date 10/4/78

Company Name Dre Badische

Hours of Observation \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer Al Lazzara

Type of Discharge STACK OTHER \_\_\_\_\_

Discharge Location Schneller Outlet

Height of Point of Discharge: \_\_\_\_\_

Observer's Location:

Distance to Discharge Point 250'

Height of Observation Point ground level

Direction from Discharge Point E 105°

Background Description green elevator shaft

Weather: Clear Overcast Partly Cloudy Other Hazy Color \_\_\_\_\_

Wind Direction NE 45° Wind Velocity 5-10 ± mi/hr

Plume Description:

Detached: Yes No

Color: Black White Other \_\_\_\_\_

Plume Dispersion Behavior: Looping Coning Fanning  
Lofting Fumigating Other straight up

Estimated Distance Plume Visible \_\_\_\_\_

Summary of Observations:

Acidity	Aggregate Time @ Opacity		Opacity	Aggregate Time @ Opacity
	min.	sec.		
0			55	
5			60	
10			65	
15			70	
20			75	
25			80	
30			85	
35			90	
40			95	
45			100	
50				62

## RECORD OF VISIBLE EMISSIONS

Company Name Dow - Badische Date 10/12/78  
 Plant Address \_\_\_\_\_ Observer LP Suzanne  
 Stack Location \_\_\_\_\_ Observer's Location East 105°  
 Weather Conditions Overcast - hazy - very windy

HR	MIN	TIME				COMMENTS
		00	15	30	45	
14	15	00	10	10	5	during P-3
	01	5	10	10	10	
	02	10	10	10	10	
	03	10	10	10	10	
	04	10	10	10	10	
	05	10	10	10	10	
	06	10	5	5	5	
	07	5	5	10	10	
	08	10	10	10	10	
	09	10	10	10	10	
	10	10	10	10	10	
	11	10	10	10	10	
	12	10	10	10	10	
	13	10	10	10	10	
	14	10	10	10	10	
	15	10	10	10	10	
	16	10	10	10	10	
	17	10	10	10	10	
	18	10	10	10	10	
	19	10	10	10	10	
	20	10	10	10	10	
	21	10	10	10	10	
	22	10	10	10	10	
	23	10	10	10	10	
	24	10	10	10	10	
	25	10	10	10	10	
	26	10	10	10	10	
	27	10	10	10	10	
	28	10	10	10	10	
	29	10	10	10	10	

## RECORD OF VISIBLE EMISSIONS

Company Name \_\_\_\_\_ Date \_\_\_\_\_  
 Plant Address \_\_\_\_\_ Observer \_\_\_\_\_  
 Stack Location \_\_\_\_\_ Observer's  
 Weather Conditions \_\_\_\_\_ Location \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
1445	30	10	10	10	10	
	31	5	5	5	5	
	32	5	5	5	10	
	33	10	10	10	10	
	34	10	10	10	10	
1450	35	10	10	10	10	
	36	10	10	10	10	
	37	10	10	10	10	
1453	38	10	10	10	5	process down
1526	39	5	5	5	5	hot v started
	40	5	5	5	5	
	41	5	5	5	5	
	42	5	5	5	5	
1543	43	10	10	10	10	
	44	5	5	5	5	
1531	45	5	5	5	5	
	46	5	5	5	5	
	47	5	5	5	5	
	48	5	5	5	10	
	49	10	10	10	10	
	50	10	10	5	5	
1532	51	5	5	5	5	
	52	5	5	5	5	
	53	5	5	5	5	
	54	5	5	5	5	
	55	5	5	5	5	
	56	5	5	5	5	
1543	57	5	5	5	5	
	58	5	5	5	5	
	59	5	5	5	5	

## RECORD OF VISIBLE EMISSIONS

Company Name Dow BadischeDate 10/14/78

Plant Address \_\_\_\_\_

Observer V.L. Lazzarino

Stack Location \_\_\_\_\_

Observer's

Weather Conditions PARTLY - Hazy

Location \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
15:46	00	5	5	5	5	
	01	5	5	5	5	
	02	5	5	5	5	
15:47	03	5	5	5	5	changing parts
	04	5	5	5	5	
	05	5	5	5	5	
	06	5	5	5	5	
	07	5	5	5	5	
	08	5	5	5	5	
15:51	09	5	5	5	5	
	10	5	5	5	5	
	11	5	5	5	5	
	12	5	5	5	5	
	13	5	5	5	5	
	14	5	5	5	5	
15:53	15	5	5	5	5	
1	16	5	5	5	5	
	17	5	5	5	5	
	18	5	5	5	5	
	19	5	5	5	5	
	20	5	5	5	5	
16:02	21	5	5	5	5	
	22	5	5	5	5	
	23	5	5	5	5	
	24	5	5	5	5	
	25	5	5	5	5	
	26	5	5	5	5	
16:13	27	5	5	5	5	
	28	5	5	5	5	
	29	5	5	5	5	

## RECORD OF VISIBLE EMISSIONS

Company Name Dow BadischeDate 10/4/70

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS
		00	15	30	45	
16:16	30	5	5	5	5	
	31	5	5	5	5	
	32	5	5	5	5	
16:17	33	5	5	5	5	
	34	5	5	5	5	
	35	5	5	5	5	
	36	5	5	5	5	
	37	5	5	5	5	
	38	5	5	5	5	
16:25	39	5	5	5	5	
	40	5	5	5	5	
	41	5	5	5	5	
	42	5	5	5	5	
	43	5	5	5	5	
	44	5	5	5	5	Soutient will devide
16:21	45	5	5	5	5	
	46	5	5	5	5	
	47	5	5	5	5	
	48	5	5	5	5	
	49	5	5	5	5	
	50	5	5	5	5	
16:37	51	5	5	5	5	
	52	5	5	5	5	
	53	5	5	5	5	
	54	5	5	5	5	
	55	5	5	5	5	
	56	5	5	5	5	
	57	5	5	5	5	
	58	5	5	5	5	
	59	5	5	5	5	

Company Name \_\_\_\_\_

Date \_\_\_\_\_

Plant Address \_\_\_\_\_

Observer \_\_\_\_\_

Stack Location \_\_\_\_\_

Observer's  
Location \_\_\_\_\_

Weather Conditions \_\_\_\_\_

HR	MIN	TIME				COMMENTS	Cont
		00	15	30	45		
16:46	00	5	5	5	5		
	01	5	5	5	5		
	02	5	5	5	5		
16:49	03	5	5	5	5		
	04	5	5	5	5		
	05	5	5	5	5		
	06	5	5	5	5		
	07	5	5	5	5		
	08	5	5	5	5		
16:52	09	5	5	5	5		
	10	5	5	5	5		
	11	5	5	5	5		
	12	5	5	5	5		
	13	5	5	5	5		
17:00	14	5	5	5	5		
	15						
	16						
	17						
	18						
	19						
	20						
	21						
	22						
	23						
	24						
	25						
	26						
	27						
	28						
	29						

APPENDIX C

SUMMARY OF PARTICULATE WEIGHT  
BY FRACTION  
AND  
CAPROLACTAM DETERMINATIONS  
BY FRACTION

Table C.1 Summary of Particulate Weight by Fraction, Grams

Sampling Location	Sample No.	110 mm Type A Glass-Fiber Filter (gm)	Front Acetone Wash (gm)	Front Water Wash (gm)	Filterable Particulate (gm)	Back Acetone Wash (gm)	Back Water Wash (gm)	Total Particulate (gm)
Inlet	P-1	0.2223	0.0121	110.81	111.04	0.0083	0.0035	111.06
	P-2	0.2900	0.0129	108.57	108.87	0.0069	0.0121	108.89
	P-3	0.2542	0.0080	118.87	119.13	0.0233	0.0113	119.17
Outlet	P-1	0.0089	0.0099	0.0701	0.0889	0.0015	0.0040	0.0944
	P-2	0.0097	0.0056	0.0281	0.0434	0.0049	0.0017	0.0500
	P-3	0.0096	0.0093	0.1486	0.1675	0.0078	0.0109	0.1862

Table C.2 Summary of Caprolactam Determinations by Fraction, Milligrams

Sampling Location	Sampling No.	Front Water Rinse	Filter	Filterable Portion	Back Half Water	Total
Inlet	P-1	24.9	<0.25	24.9	627	652
	P-2	63.5	<0.25	63.5	756	820
	P-3	<4.60	<0.25	<4.85	877	877
Outlet	P-1	2.15	<0.25	2.15	58.1	60.3
	P-2	<2.50	<0.25	<2.75	73.9	73.9
	P-3	<2.70	<0.25	<2.95	87.6	87.6

APPENDIX D

AMMONIUM SULFATE DETERMINATIONS  
AND PERCENT MOISTURES

Table D.1 Summary of Ammonium Sulfate in Scrubber Water

Sample No.	Date	$(\text{NH}_4)_2 \text{SO}_4$ (g/l)
1	10-3-78	320
2	10-4-78	367
3	10-4-78	380
Average		356

}

Table D.2 Percent Moisture in Ammonium Sulfate

Sample No.	Date	Percent Moisture		Percent Moisture Reduction
		Dryer Inlet	Dryer Outlet	
1	10-3-78	0.96	0.09	90.6
2	10-4-78	1.02	0.09	91.2
3	10-4-78	1.10	0.07	93.6
Average		1.03	0.08	91.8

APPENDIX E

SUMMARY OF VISIBLE EMISSIONS


**SUMMARY OF VISIBLE EMISSIONS**

Sample No. 1

Date: 10-3-78  
Type of Discharge: Particulate  
Height of Point of Discharge: 55'  
Wind Direction: SE & NW  
Color of Plume: white  
Observer No.: Dusanka Lazarevic  
Distance from Observer to Discharge Point: 250'  
Direction of Observer from Discharge Point: East  
Height of Observation Point: Ground level  
Description of Background: green elevator shaft

SUMMARY OF AVERAGE OPACITY									
Set Number	Time		Opacity		Set Number	Time		Opacity	
	Start	End	Sum	Average		Start	End	Sum	Average
1	1516	1521	240	10	21	1716	1721	240	10
2	1522	1527	240	10	22	1722	1727	240	10
3	1528	1533	240	10	23	1728	1731	240	10
4	1534	1539	240	10	24	1800	1805	240	10
5	1540	1545	240	10	25	1806	1811	240	10
6	1546	1551	240	10	26	1812	1817	255	11
7	1552	1557	240	10	27	1818	1823	360	15
8	1558	1603	240	10	28	1824	1829	360	15
9	1604	1609	240	10	29	1830	1835	360	15
10	1610	1615	240	10	30	1836	1841	360	15
11	1616	1621	240	10	31	1842	1847	360	15
12	1622	1627	240	10	32				
13	1628	1633	240	10	33				
14	1634	1639	240	10	34				
15	1640	1645	240	10	35				
16	1646	1651	240	10	36				
17	1652	1657	240	10	37				
18	1658	1703	240	10	38				
19	1704	1709	240	10	39				
20	1710	1715	240	10	40				

Sketch Showing How Opacity Varied With Time:



## SUMMARY OF VISIBLE EMISSIONS


Sample No. 2

Date: 10-4-78  
Type of Discharge: Particulate  
Height of Point of Discharge: 55'  
Wind Direction: NE  
Color of Plume: White  
Observer No.: Donna Schick  
Distance from Observer to Discharge Point: 60'  
Direction of Observer from Discharge Point: SE  
Height of Observation Point: 55'  
Description of Background: Building

Type of Plant: Ammonium Sulfate  
Location of Discharge: Scrubber Exhaust  
Description of Sky: Hazy  
Wind Velocity: 10 mph  
Detached Plume: No  
Duration of Observation: 2 hr.19 min.

S U M M A R Y   O F   A V E R A G E   O P A C I T Y							
Set Number	Time		Set Number	Time		Opacity	
	Start	End		Sum	Average	Start	End
1	0840	0845	21	1040	1045	0	0
2	0846	0851	22	1046	1051	15	0.6
3	0852	0857	23	1052	1057	45	1.9
4	0858	0903	24	1058	1059	0	0
5	0904	0909	25				
6	0910	0915	26				
7	0916	0921	27				
8	0922	0927	28				
9	0928	0933	29				
10	0934	0939	30				
11	0940	0945	31				
12	0946	0951	32				
13	0952	0957	33				
14	0958	1003	34				
15	1004	1009	35				
16	1010	1015	36				
17	1016	1021	37				
18	1022	1027	38				
19	1028	1033	39				
20	1034	1039	40				

Sketch Showing How Opacity Varied With Time:



## SUMMARY OF VISIBLE EMISSIONS


Sample No. 3

Date: 10-4-78  
Type of Discharge: Particulate  
Height of Point of Discharge: 55'  
Wind Direction: NE  
Color of Plume: White  
Observer No.: Dusanka Lazarevic  
Distance from Observer to Discharge Point: 250'  
Direction of Observer from Discharge Point: East  
Height of Observation Point: Ground level  
Description of Background: green elevator shaft

Type of Plant: Ammonium Sulfate  
Location of Discharge: Scrubber Exhaust  
Description of Sky: Partly Cloudy/Hazy  
Wind Velocity: 5-10 mph  
Detached Plume: No  
Duration of Observation: 2 hr. 45 min

SUMMARY OF AVERAGE OPACITY									
Set Number	Time		Opacity		Set Number	Time		Opacity	
	Start	End	Sum	Average		Start	End	Sum	Average
1	1415	1420	230	9.6	21	1644	1649	120	5.0
2	1421	1426	215	9.0	22	1650	1655	120	5.0
3	1427	1432	240	10.0	23	1656	1700	100	5.0
4	1433	1438	240	10.0	24				
5	1439	1444	240	10.0	25				
6	1445	1450	205	8.5	26				
7	1451	1453	115	9.6	27				
8	1526	1531	120	5.0	28				
9	1532	1537	155	6.5	29				
10	1538	1543	120	5.0	30				
11	1544	1549	120	5.0	31				
12	1550	1555	120	5.0	32				
13	1556	1601	120	5.0	33				
14	1602	1607	120	5.0	34				
15	1608	1613	120	5.0	35				
16	1614	1619	120	5.0	36				
17	1620	1625	120	5.0	37				
18	1626	1631	120	5.0	38				
19	1632	1637	120	5.0	39				
20	1638	1643	120	5.0	40				

Sketch Showing How Opacity Varied With Time:



APPENDIX F

GAS CHROMATOGRAPH DATA SUMMARY

ANAL Results for SAS Chromatographic testing  
for Caprolactam Using 5% Carbowax 20-TPA  
In Chromosorb W-AW 6' x 1/4"

Test No.	Date of Test	Sample fraction	Sample volume	Peak area	Concentration (PPM)	Weight (mg)
inlet P-1	10-3-78	H <sub>2</sub> O front half	830 ml	63,552	30	24.9
inlet P-2	10-4-78	H <sub>2</sub> O front half	635 ml	116,564	100	63.5
inlet P-3	10-4-78	H <sub>2</sub> O front half	460 ml	26,077	< 10	< 4.60
inlet P-1	10-3-78	H <sub>2</sub> O back half	570 ml	952,186	1100	627
inlet P-2	10-4-78	H <sub>2</sub> O back half	540 ml	1,240,516	1400	756
inlet P-3	10-4-78	H <sub>2</sub> O back half	702 ml	1,125,674	1250	877
outlet P-1	10-3-78	H <sub>2</sub> O front half	215 ml	35,699	10	2.15
outlet P-2	10-4-78	H <sub>2</sub> O front half	250 ml	Ø	< 10	< 2.50
outlet P-3	10-4-78	H <sub>2</sub> O front half	270 ml	17,036	< 10	< 2.70
outlet P-1	10-3-78	H <sub>2</sub> O back half	505 ml	129,650	115	58.1
outlet P-2	10-4-78	H <sub>2</sub> O back half	308 ml	250,930	240	73.9
outlet P-3	10-4-78	H <sub>2</sub> O back half	1030 ml	100,930	85	87.6
inlet P-1	10-3-78	filter A-263-12	25 ml	8,316	< 10	< 0.25
inlet P-2	10-4-78	filter A-263-15	25 ml	12,437	< 10	< 0.25
inlet P-3	10-4-78	filter A-263-14	25 ml	10,220	< 10	< 0.25
outlet P-1	10-3-78	filter A-263-11	25 ml	5,543	< 10	< 0.25
outlet P-2	10-4-78	filter A-263-13	25 ml	6,728	< 10	< 0.25
outlet P-3	10-4-78	filter A-263-09	25 ml	7,279	< 10	< 0.25
all	10-3,4-78	H <sub>2</sub> O blank	290 ml	Ø	< 10	< 2.90
all	10-3,4-78	filter blank	25 ml	Ø	< 10	< 0.25

Caprolactam Standard Curve Calibrations  
Using 5% Carbowax 20-TPA In Chromosorb WAW 6' x 1/4"

Standard stock solution 0.10118 g per 100ml H<sub>2</sub>O (1012 ppm)


SOLUTION	CONCENTRATION	AREA	
Standard	1012 ppm	872,728	
"	"	904,516	
"	"	881,360	
"	"	848,351	
Standard x 1/10	~ 100 ppm	118,784	
Standard x 1/100	~ 10 ppm	34,861	
Standard x 1/1000	~ 1 ppm	No peak	
Standard x 10	~ 10,000 ppm	9159,168	

KoE LOGARITHMIC 467522,  
3 X 5 CYCLES MADE IN U.S.A.  
KEUFFEL & ESSER CO.

Chlorowak 20A1 TRA 6' 190°

250/250

Agreement of methods by PC



## APPENDIX G

### EXAMPLE CALCULATIONS

### Nomenclature

$A_s$  = Stack area, inches<sup>2</sup>  
 $C_f$  = Front half (probe & filter) particulate concentration, gr/DSCF  
 $C_p$  = Pitot tube correction factor, dimensionless  
 $C_t$  = Total particulate concentration, gr/DSCF  
 $CM_f$  = Front half (probe & filter) particulate concentration, mg/DSm<sup>3</sup>  
 $CM_t$  = Total particulate concentration, mg/DSm<sup>3</sup>  
 $D_n$  = Sampling nozzle diameter, inches  
 $ER_f$  = Emission rate of front half particulate, lb/hr  
 $ER_t$  = Emission rate of total particulate, lb/hr  
 $ERM_f$  = Emission rate of front half particulate, kg/hr  
 $ERM_t$  = Emission rate of total particulate, kg/hr  
 $M_d$  = Mole fraction of dry gas, g/g-mole  
 $MW$  = Molecular weight of wet stack gas  
 $MW_d$  = Molecular weight of dry stack gas  
 $P_b$  = Barometric pressure, inches mercury  
 $P_m$  = Average orifice pressure drop, inches water  
 $P_s$  = Absolute stack gas pressure, inches mercury  
 $P_{st}$  = Static pressure of stack gas, inches mercury  
 $Q_a$  = Actual stack gas flowrate at stack conditions, ACFM  
 $Q_{am}$  = Actual stack gas flowrate at stack conditions, Am<sup>3</sup>/min  
 $Q_m$  = Dry stack gas flowrate at standard conditions, DSM<sup>3</sup>/min  
 $Q_s$  = Dry stack gas flowrate at standard conditions, DSCFM  
 $SW_f$  = Front half sample weight, mg  
 $SW_t$  = Total sample weight, mg  
 $T_m$  = Average meter temperature, °F

$T_s$  = Stack temperature, °F  
 $T_t$  = Net time of test, minutes  
 $V_m$  = Volume of dry gas at meter conditions, ft<sup>3</sup>  
 $V_{m_{std}}$  = Volume of dry gas at standard conditions, DSCF  
 $V_s$  = Stack gas velocity at stack conditions, fpm  
 $V_w$  = Total condensate collected in sampling train, ml  
 $V_{w_{gas}}$  = Volume of water vapor at standard conditions, SCF  
 $\Delta P_s$  = Velocity pressure, inches water  
%I = Percent of isokinetic variation, dimensionless  
%M = Percent moisture, dimensionless  
%R = Percent of removal efficiency, dimensionless

#### Calculation of Particulate Emissions

The dry volume of sampled gas corrected to standard conditions of 20°C and 760 mm Hg (29.92 in. Hg) is calculated as follows:

$$V_{m_{std}} = \frac{17.65 * V_m * P_b + \left( \frac{P_m}{13.6} \right)}{T_m + 460}$$

The dry stack gas flowrate corrected to standard conditions is calculated using the following set of equations sequentially:

$$V_{w_{gas}} = 0.0471 * V_w$$

$$\%M = \frac{100 * V_{w_{gas}}}{V_{m_{std}} + V_{w_{gas}}}$$

$$M_d = \frac{100 - \%M}{100}$$

$$MW_d = (\%CO_2 * 44/100) + (\%O_2 * 32/100) + [(\%CO + \%N_2) * 28/100]$$

$$MW = (MW_d * M_d) + 18(1 - M_d)$$

$$P_s = P_b + P_{st}$$

$$V_s = 5120.8 * C_p * \sqrt{\Delta P_s * (T_s + 460)} \pm \sqrt{\frac{1}{P_s * MW}}$$

$$Q_s = \frac{0.1225 * V_s * A_s * M_d * P_s}{T_s + 460}.$$

Stack gas flowrate may be expressed metrically as dry normal cubic meters per minute ( $\text{DNm}^3/\text{min}$ ) and in terms of actual cubic feet per minute (ACFM) and metrically as actual cubic meters per minute ( $\text{Am}^3/\text{min}$ ) with use of the following equations:

$$Q_m = Q_s * 0.02832$$

$$Q_a = \frac{0.05667 * Q_s * (T_s + 460)}{P_s * M_d}$$

$$Q_{am} = Q_a * 0.02832.$$

The equation employed to determine percent of isokinetic variation is:

$$\%I = \frac{1032 * (T_s + 460) * V_{m\text{std}}}{V_s * T_t * P_s * M_d * (D_n)^2}.$$

To determine the concentration of particulate matter in grains per dry standard cubic foot (gr/DSCF), one of the following equations is used:

$$C_f = 0.01543 * \frac{S_{Wf}}{V_{m\text{std}}} \quad \text{and}$$

$$C_t = 0.01543 * \frac{S_{Wt}}{V_{m\text{std}}}.$$

$$\%R = \frac{ER_t \text{ inlet} - ER_t \text{ outlet}}{ER_t \text{ inlet}}$$

#### Example Calculation

Using the data from particulate Test 3 at the inlet location an example of the calculation of sampled volume in dry standard cubic feet (DSCF) is as follows:

Given:

$$P_b = 29.85 \text{ in. Hg}$$

$$P_m = 2.68 \text{ in. H}_2\text{O}$$

$$T_m = 104^\circ\text{F}$$

$$V_m = 110.737 \text{ ft}^3$$

$$V_w = 91.1 \text{ ml}$$

and using the first two equations on page 2:

$$V_{w\text{gas}} = 4.29 \text{ SCF}$$

$$V_{m\text{std}} = 104 \text{ DSCF}$$

With the following additional information from the data sheet one can determine the flowrate in dry standard cubic feet per minute (DSCFM).

$$\sqrt{P_s * (T_s + 460)} = 23.17$$

$$C_p = 0.828$$

$$T_s = 88^\circ\text{F}$$

$$A_s = 2290 \text{ sq.in.}$$

$$P_{st} = 0.7 \text{ in. Hg}$$

Since no Orsat was run, and using the equations on page 2, we can determine the following information:

When metric units are desired, the concentration is calculated in milligrams per dry standard cubic meter ( $\text{mg}/\text{DSm}^3$ ) as follows:

$$\text{CM}_f = \frac{\text{SW}_f}{(0.02832)(V_{m_{std}})} \quad \text{and}$$

$$\text{CM}_t = \frac{\text{SW}_t}{(0.02832)(V_{m_{std}})} .$$

Front half particulate concentrations are obtained by summing the weight of particulate matter collected on the filter and all portions of the train preceding it. Total particulate concentration includes, in addition, any particulate matter collected in the impingers.

The emission rate of particulate matter can be calculated from the filterable or total particulate concentration using one of the following equations:

$$\text{ER}_f = 0.00857 * \text{C}_f * Q_s \quad \text{and}$$

$$\text{ER}_t = 0.00857 * \text{C}_t * Q_s .$$

For metric units,

$$\text{ERM}_f = (1.70 * 10^{-6}) * \text{CM}_f * Q_s \quad \text{and}$$

$$\text{ERM}_t = (1.70 * 10^{-6}) * \text{CM}_t * Q_s .$$

To avoid rounding errors it is preferable to carry out the calculation of concentration and emission rate in one operation. Removal efficiency is calculated using the pounds per hour emission rate in the following equation:

$$MW_d = 28.96$$

Then using the equations on pages 2 and 3, the flowrate in dry standard cubic feet per minute can be calculated.

$$\%M = 4.0$$

$$M_d = 0.960$$

$$MW = 28.51$$

$$P_s = 30.55 \text{ in. Hg}$$

$$V_s = 3330 \text{ fpm}$$

$$Q_s = 42300 \text{ DSCFM.}$$

Then using the equations on page 3, flowrate can be expressed as follows:

$$Q_m = 1200 \text{ DNm}^3/\text{min}$$

$$Q_a = 52900 \text{ ACFM}$$

$$Q_{am} = 1500 \text{ Am}^3/\text{min.}$$

Having determined sampled volume to be 104 DSCF and the flowrate to be 42300 DSCFM, the percent of isokinetic variation can be determined.

Given:

$$V_{m, std} = 104 \text{ DSCF}$$

$$Q_s = 42300$$

$$T_t = 120 \text{ min.}$$

$$D_n = 0.249 \text{ in.}$$

then using the equation on page 3

$$\%I = 95.9$$

The concentration and emission rate can now be calculated for this particulate test as follows:

Given:

$$SW_f = 119.13 \text{ g}$$

$$SW_t = 119.17 \text{ g}$$

Using equations on page 3 the concentration of filterable particulate and total particulate, both in grains per dry standard cubic foot (gr/DSCF), are as follows:

$$C_f = 17.5 \text{ gr/DSCF}$$

$$C_t = 17.5 \text{ gr/DSCF}$$

Concentrations may be expressed metrically as follows:

$$CM_f = 40,400 \text{ mg/DSm}^3$$

$$CM_t = 40,500 \text{ mg/DSm}^3$$

The emission rates in pounds per hour (lb/hr), and metrically as kilograms per hour (kg/hr) are as follows:

$$ER_f = 6410 \text{ lb/hr}$$

$$ER_t = 6410 \text{ lb/hr}$$

$$ERM_f = 2910 \text{ kg/hr}$$

$$ERM_t = 2910 \text{ kg/hr}$$

Removal efficiency can be determined using the pounds per hour value previously calculated together with the pounds per hour value calculated for the simultaneous test at the outlet location and the equation on page 4.

Given:

$$ER_{t_{\text{outlet}}} = 15.7$$

then:

$$\%R = 99.8\%$$

APPENDIX H

CALIBRATION DATA

$C_{Ptest} = 0.99$


$$\sqrt{\frac{\Delta P_{std}}{\Delta P_{test}}}$$

Pitot Tube Type S Pitot Tube No. 2

Standard Pitot Tube No. -

Calibrator: TVM Date: 8-22-78 Client:

Anticipated $\Delta P_{std}$	$\Delta P_{std}$	A		B	
		$\Delta P_{test}$	$\Delta C_{Ptest}$	$\Delta P_{test}$	$\Delta C_{Ptest}$
0.02	0.	0.	0.	0.	0.
0.04	0.	0.	0.	0.	0.
0.06	0.	0.	0.	0.	0.
0.08	0.	0.	0.	0.	0.
0.10	0. <u>110</u>	0. <u>154</u>	0. <u>837</u>	0. <u>158</u>	0. <u>826</u>
0.12	0. <u>111</u>	0. <u>158</u>	0. <u>830</u>	0. <u>160</u>	0. <u>825</u>
0.16	0. <u>110</u>	0. <u>158</u>	0. <u>826</u>	0. <u>158</u>	0. <u>826</u>
0.20	0.	0.	0.	0.	0.
0.30	0.	0.	0.	0.	0.
0.50	0.	0.	0.	0.	0.
0.70	0.	0.	0.	0.	0.
0.80	0.	0.	0.	0.	0.



$C_{Ptest} = 0.99$

$$\frac{\Delta P_{std}}{\Delta P_{test}}$$

Pitot Tube Type \_\_\_\_\_ Pitot Tube No. Z3

Standard Pitot Tube No. \_\_\_\_\_


S

Calibrator: BFE/TUM

Date: 10 OCT 78 Client: DOW -

CDA TASK

Anticipated $\Delta P_{std}$	$\Delta P_{std}$	A		B	
		$\Delta P_{test}$	$\Delta C_{Ptest}$	$\Delta P_{test}$	$\Delta C_{Ptest}$
0.02	0._____	0._____	0._____	0._____	0._____
0.04	0._____	0._____	0._____	0._____	0._____
0.06	0.0998	0.1434	0.826	0.1380	0.892
0.08	0.0966	0.1390	0.825	0.1388	0.826
0.10	0.0972	0.1380	0.831	0.1408	0.923
0.12	0._____	0._____	0._____	0._____	0._____
0.16	0._____	0._____	0._____	0._____	0._____
0.20	0._____	0._____	0._____	0._____	0._____
0.30	0._____	0._____	0._____	0._____	0._____
0.50	0._____	0._____	0._____	0._____	0._____
0.70	0._____	0._____	0._____	0._____	0._____
0.80	0._____	0._____	0._____	0._____	0._____



$$C_{Ptest} = 0.99 \sqrt{\frac{\Delta P_{std}}{\Delta P_{test}}}$$

Pitot Tube Type S Pitot Tube No. 35


Standard Pitot Tube No. 18

Calibrator: DJC

Date: 3/1/78

Client:

Anticipated $\Delta P_{std}$	$\Delta P_{std}$	A		B	
		$\Delta P_{test}$	$\Delta C_{Ptest}$	$\Delta P_{test}$	$\Delta C_{Ptest}$
0.02	0._____	0._____	0._____	0._____	0._____
0.04	0._____	0._____	0._____	0._____	0._____
0.06	0.056	0.078	0.839	0.079	0.834
0.08	0._____	0._____	0._____	0._____	0._____
0.10	0.105	0.150	0.828	0.150	0.828
0.12	0._____	0._____	0._____	0._____	0._____
0.16	0._____	0._____	0._____	0._____	0._____
0.20	0._____	0._____	0._____	0._____	0._____
0.30	0.371	0.525	0.832	0.521	0.835
0.50	0._____	0._____	0._____	0._____	0._____
0.70	0._____	0._____	0._____	0._____	0._____
0.80	0.1.066	0.1.484	0.839	0.1.482	0.839



$\Delta P_{test}$  ("H<sub>2</sub>O)

$C_{Ptest} = 0.99$

$\sqrt{\frac{\Delta P_{std}}{\Delta P_{test}}}$

Pitot Tube Type S


Pitot Tube No. 38

Standard Pitot Tube No. \_\_\_\_\_

Calibrator: TVM

Date: 11-9-78 Client: U.S. EPA - Dow

Anticipated $\Delta P_{std}$	$\Delta P_{std}$	A		B	
		$\Delta P_{test}$	$\Delta C_{Ptest}$	$\Delta P_{test}$	$\Delta C_{Ptest}$
0.02	0._____	0._____	0._____	0._____	0._____
0.04	0._____	0._____	0._____	0._____	0._____
0.06	0._____	0._____	0._____	0._____	0._____
0.08	0._____	0._____	0._____	0._____	0._____
0.10	0. <u>99</u>	0. <u>1.40</u>	0. <u>.833</u>	0. <u>1.42</u>	0. <u>827</u>
0.12	0. <u>96</u>	0. <u>1.40</u>	0. <u>.820</u>	0. <u>1.39</u>	0. <u>823</u>
0.16	0. <u>97</u>	0. <u>1.39</u>	0. <u>.827</u>	0. <u>1.41</u>	0. <u>821</u>
0.20	0._____	0._____	0._____	0._____	0._____
0.30	0._____	0._____	0._____	0._____	0._____
0.50	0._____	0._____	0._____	0._____	0._____
0.70	0._____	0._____	0._____	0._____	0._____
0.80	0._____	0._____	0._____	0._____	0._____



METER AND ORIFICE CALIBRATION

Date 9-5-78 Client \_\_\_\_\_ Meter Box Number RAC-3  
 Barometric Pressure Pb ("Hg) 29.45 Calibrator BFE Gas Meter Number \_\_\_\_\_

	Orifice Manometer Setting, $\Delta m$ (in. H <sub>2</sub> O)	Gas Volume Wet Test Meter $V_w$ (ft <sup>3</sup> )	Gas Volume Dry Gas Meter $V_d$ (ft <sup>3</sup> )	Temperature				Vacuum Wet Test Meter $P_w$ (in. H <sub>2</sub> O)	Time $\theta$ (min)	$\gamma$	$K_m$				
				Wet Test Meter $t_w$ (°F)	Dry Gas Meter										
					Inlet $t_{di}$ (°F)	Outlet $t_{do}$ (°F)	Average $t_d$ (°F)								
Stop	0.5	5593.00	816.731	75.0	85	79		0.05							
Start		5588.00	811.710	74.5	78	76			12.20						
Average	29.49	(5) 5.0	5.021	74.75			79.5	29.45	12.33	1.003	0.135				
Stop	1.0	5598.00	91.952	75.5	85	82									
Start		5593.00	816.731	75.0	85	79		0.05	8.38						
Average	29.52	(5) 5.0	5.221	75.25			82.75	29.45	8.63	0.969	0.136				
Stop	2.0	56058.00	153.155	74	94	85									
Start		56040.00	134.860	74	85	85		0.05							
Average	29.60	(10) 18	18.295	74			87.75	29.45	22.43	1.004	0.133				
Stop	3.0	56018.05	111.319	76	103	90									
Start		56008.00	101.184	75.5	85	82		0.05	9.11						
Average	29.67	(10) 10.05	10.135	75.75			90.00	29.45	9.18	1.010	0.148				
Stop	4.0	56030.00	123.674	76	104	91									
Start		56018.05	111.319	76	103	90		0.05	10.53						
Average	29.74	(10) 11.95	12.355	76			97.0	29.45	10.88	0.995	0.129				
Stop	5.0	56040.00	134.860	75.5	105	91									
Start		56030.00	123.674	76	104	91		0.05	8.02						
Average	29.82	(10) 10.0	11.186	75.75			97.75	29.45	8.03	0.919	0.131				

$$P_w = P_b - \frac{P_w}{13.6}$$

$$P_d = P_b + \frac{\Delta m}{13.6}$$

$$K_m = \frac{V_w}{\theta} \sqrt{\frac{P_w}{T_w \Delta m}}$$

AVERAGE

0.983 0.135

$$\gamma = \frac{V_w P_w (t_d + 460)}{V_d P_d (t_w + 460)}$$

$$\text{Factor in isokinetic equation} = \frac{27.40}{(\bar{K}_m)^2} = \frac{27.40}{(1496)^2} = 1496$$

## / METER AND ORIFICE CALIBRATION

Date 10-7-78 Client US EPA Dow - Pneumatic Meter Box Number RAC 3  
 Barometric Pressure Pb ("Hg) 29.38 Calibrator TVM Gas Meter Number \_\_\_\_\_

	Orifice Manometer Setting, $\Delta m$ (in. $H_2O$ )	Gas Volume Wet Test Meter $V_w$ ( $ft^3$ )	Gas Volume Dry Gas Meter $V_d$ ( $ft^3$ )	Temperature			Vacuum Wet Test Meter $P_w$ (in. $H_2O$ )	Time $\theta$ (min)	$\gamma$	$K_m$
				Wet Test Meter $t_w$ ( $^{\circ}F$ )	Inlet $t_{di}$ ( $^{\circ}F$ )	Outlet $t_{do}$ ( $^{\circ}F$ )				
Stop	0.5	6531.000	514.920	62	76	64		21:10		
Start		6522.000	505.759	62	74	64	0			
Average	29.42	(5) 9.000	9.161	62	75	66.5	70.8	29.38	21.17	.998 .143
Stop	1.0	6544.000	528.191	62	79	72		22:29		
Start		6531.000	514.920	62	76	69	0			
Average	29.45	(5) 13.000	13.271	62	77.5	70.5	74.0	29.38	22.48	1.000 .137
Stop	2.0	6556.000	540.391	62	83	73		14:53		
Start		6544.000	528.191	62	79	72	0			
Average	29.53	(10) 12.000	12.200	62	81	72.5	76.8	29.38	14.88	1.006 .135
Stop	3.0	6576.000	560.630	62	85	74		20:23		
Start		6556.000	540.391	62	83	73	0			
Average	29.60	(10) 20.000	20.239	62	84	73.5	78.8	29.38	20.38	1.012 .134
Stop	4.0	6604.000	588.889	61.5	87	75		25:06		
Start		6576.000	560.630	62	85	74	0			
Average	29.67	(10) 29.000	28.259	61.8	86	74.5	80.3	29.38	25.10	1.016 .132
Stop	5.0	6637.000	622.160	61	88	75		26:47		
Start		6604.000	588.889	61.5	87	75	0			
Average	29.75	(10) 33.000	33.271	61.3	87.5	75	81.3		26.78	1.017 .131

$$\frac{P_w}{P_b} = \frac{P_w}{13.6} \quad P_d = P_b + \frac{\Delta m}{13.6} \quad K_m = \frac{V_w}{\theta} \sqrt{\frac{P_w}{T_w \Delta m}}$$

AVERAGE 1.008 .135

$$= \frac{V_w P_w (t_d + 460)}{V_d P_d (t_w + 460)}$$

Factor in isokinetic equation =  $\frac{27.40}{(\bar{K}_m)^2} = \frac{27.40}{(\gamma)^2} = 14.94$

## METER AND ORIFICE CALIBRATION

Date 9-29-78 Client 21.61  
Barometric pressure  $P_b$  ("Hg) 29.961

Meter Box Number RAC 4

Calibrator TVM							Gas Meter Number			
	Orifice Manometer Setting, $\Delta m$ (in. H <sub>2</sub> O)	Gas Volume Wet Test Meter $V_w$ (ft <sup>3</sup> )	Dry Gas Meter $V_d$ (ft <sup>3</sup> )	Temperature			Vacuum Test Meter $P_w$ (in. H <sub>2</sub> O)	Time $\theta$ (min)	$\gamma$	$K_m$
				Wet Test Meter $t_w$ (°F)	Inlet $t_{d1}$ (°F)	Outlet $t_{d2}$ (°F)				
Stop 0.5	1.15	6245.000	220.842	64.5	78	66				
Start		1231.000	214.914	66	65	64				
Average		(5) 6.000	5.928	64.85						
Stop 1.0		6256.000	231.834	67	94	74				
Start	1.16	6245.000	220.842	66.5	78	66	0	14.47	1.015	0.1391
Average		(5) 11.000	10.982	66.5			25.61			
Stop 2.0		6281.000	260.184	65	105	85				
Start		6256.000	231.824	67	94	74	0			
Average		(10) 2.000	2.000	67.5			29.61	19.32	1.021	0.1350
Stop 3.0		6298.000	274.462	68	108	87				
Start	2.93	6284.000	260.184	68	105	85	0			
Average		(10) 4.000	4.000	68			29.61	35.60	1.023	0.137
Stop 4.0		6343.000	230.506	68.5	110	90				
Start	2.94	6298.000	274.462	68	105	87	0			
Average		(10) 7.000	7.000	68.5			29.61	41.31	1.024	0.1383
Stop 5.0		6361.000	338.942	69	112	91				
Start	2.943	6343.000	320.506	68.5	110	90	0			
Average		(10) 10.000	10.000	68.5			29.61	15.00	1.023	0.1370
							AVERAGE			1.022 0.1378

$$\zeta_w = P_b - \frac{P_w}{13.6} \quad P_d = P_b + \frac{\Delta m}{13.6}$$

$$K_m = \frac{V_w}{\theta} \sqrt{\frac{P_w}{T_w \Delta m}}$$

$$\text{Factor in isokinetic equation} = \frac{27.40}{(\bar{K}_m)^2} = \frac{27.40}{(1.022)^2} = 11.31$$

$$= \frac{V_w P_w (t_d + 460)}{V_d P_d (t_w + 460)}$$

METER AND ORIFICE CALIBRATION

Date 10-7-78 Client US EPA D. M. Hollingshead Meter Box Number RAC 1  
 Barometric Pressure Pb ("Hg) 29.38 Calibrator TVM Gas Meter Number

	Orifice Manometer Setting, $\Delta m$ (in. H <sub>2</sub> O)	Gas Volume Wet Test Meter $V_w$ (ft <sup>3</sup> )	Gas Volume Dry Gas Meter $V_d$ (ft <sup>3</sup> )	Temperature			Vacuum Wet Test Meter $P_w$ (in. H <sub>2</sub> O)	Time $\theta$ (min)	$\gamma$	$K_m$
				Wet Test Meter $t_w$ (°F)	Inlet $t_{d1}$ (°F)	Outlet $t_{d0}$ (°F)				
top	0.5	6643.000	615.393	61	71	62			14:33	
start		66437.000	609.421	61	61	58	0		14.55	1.010 .138
verage	29.42	(5) 6.000	5.972	61	69	60	64.5	29.38	14.55	
top	1.0	6656.000	628.475	61	86	70			23:09	
start		6643.000	615.393	61	74	62	0		23.15	1.015 .133
verage	29.45	(5) 13.000	13.082	61	81	66	73.5	29.38	23.15	
top	2.0	6670.000	612.690	61	96	76			17:55	
start		6656.000	628.475	61	88	70	0		17.92	1.020 .131
verage	29.53	(10) 14.000	14.215	61	92	73	82.5	29.38		
top	3.0	6689.000	662.088	61	100	80			20:11	
start		6670.000	612.690	61	96	76	0		20.18	1.023 .129
verage	29.160	(10) 19.000	19.398	61	93	78	88	29.38	20.18	
top	4.0	6710.000	683.636	61	104	82			19:34	
start		6689.000	662.088	61	100	80	0		19.57	1.021 .127
verage	29.167	(10) 21.000	21.548	61	102	81	91.5	29.38	19.57	
top	5.0	6729.000	703.170	61	106	85			15:57	
start		6710.000	683.636	61	104	82	0		15.95	1.022 .127
verage	29.15	(10) 19.000	19.534	61	105	83.5	91.3	29.38	15.95	

$$w = P_b - \frac{P_w}{13.6} - 39.39$$

$$P_d = P_b + \frac{\Delta m}{13.6}$$

$$K_m = \frac{V_w}{\theta} \sqrt{\frac{P_w}{T_w \Delta m}}$$

AVERAGE 1.019 .131

$$= \frac{V_w P_w (t_d + 460)}{V_d P_d (t_w + 460)}$$

$$\text{Factor in isokinetic equation} = \frac{27.40}{(K_m)^2} = \frac{27.40}{(\gamma)^2} = \frac{160}{1596}$$

