

### 9.5.3

## Meat Rendering Plants

Total VOC emissions for the Supercooker

TRC Environmental Corporation for IBP, Inc.

August 1998

1998 (post section publication) source  
test data.

Note: This material is related to a section in AP42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the file number, the AP42 chapter and then the section. The file name "rel01\_c01s02.pdf" would mean the file relates to AP42 chapter 1 section 2. The document may be out of date and related to a previous version of the section. The document has been saved for archival and historical purposes. The primary source should always be checked. If current related information is available, it will be posted on the AP42 webpage with the current version of the section.



October 13, 1998

Mr. Dave Meierhenry  
Air Quality Compliance Section  
Nebraska Department of Environmental Quality  
P. O. Box 98922  
Lincoln, NE 68509-8922

**RE:** IBP, inc., Lexington, Nebraska  
Updates to the Lexington VOC Final Report

Dear Mr. Meierhenry:

Please find enclosed a copy of the updates for the final VOC report submitted August 26, 1998. The updates reflect the changes discussed with myself and TRC.

If you have any questions concerning the testing results or procedures used, please contact me a 402-241-3647 or you may contact Mr. Scott Miller, TRC Project Manager, at 630-810-1122.

Sincerely,

A handwritten signature in cursive script that reads 'Rechelle Kruse'.

Rechelle Kruse  
Air Pollution Control Engineer

Enclosure

c: Leo Lang  
Ryan Post  
Dallas Safriet

## SECTION 2

### SUMMARY OF RESULTS

On July 21, 1998, testing was conducted to determine emission rates of the Supercooker exhaust at the IBP plant in Lexington, Nebraska. All testing was completed in accordance with approved test methodologies.

Table 2-1 summarizes the data for the Supercooker on July 21, 1998 at the IBP plant located in Lexington, Nebraska.

Raw field data sheets are located in Appendix A. Process data recorded by IBP is located in Appendix B. Laboratory results are located in Appendix C. Equipment calibration data sheets are located in Appendix D. Calculation formulas can be found in Appendix E. All test procedures were conducted as stated in Section 3 except:

On Run #2&3 the moisture content was above saturation therefore moisture was determined by using stack temperature and the saturation table. On Run #1,2&3 RM 25, lab receipt data was used to calculate VOC emission rates. Lab receipt data was used because line loss was not taken into account when final tank measurements were taken. TRC feels that the lab receipt data is the accurate data to be used and is also considered worst case scenario.

**Table 2-1 VOC Emission Rates for the Supercooker**

WET COOKER EXHAUST EMISSION RATE RESULTS			
	TEST #1	TEST #2	TEST #3
TGNMO as Carbon, ppmc	358.0	273.0	296.0

AVG = 1.008 lbs/hr TGNMO as carbon

Table 4-1. Test Results - Supercooker Exhaust

IBP Lexington Supercooker

Run No.	1	2	3	
Date	7-21-98	7-21-98	7-21-98	
Start Time	11:57	13:25	14:55	
Stop Time	12:57	14:25	15:55	AVERAGES
Barometric Pressure, in. Hg	28.80	28.80	28.80	28.80
Net Sampling Time, minutes	30.0	30.0	30.0	30.0
Volume Metered, cf	26.508	26.291	26.582	26.460
Avg. DGM Temp, F	93.4	99.00	102.80	98.4
AVG Delta H, in of H2O	2.00	2.00	2.00	2.00
AVG Delta H, in of Hg	0.1471	0.1471	0.1471	0.1471
DGM Calibration Factor	0.9951	0.9951	0.9951	0.9951
Volume of Gas Collected, dscf	24.349	23.908	24.009	24.089
Total Water Collected, mL	32.0	78.0	163.0	91.0
Volume of Water Vapor, scf	1.509	3.678	7.685	4.291
Moisture, % @ Saturation	5.8	7.2	8.6	7.2
Dry Mole Fraction, 100-%M	0.9417	0.9279	0.9143	0.9280
CO2 at Stack, % dry	0.0	0.0	0.0	0.0
O2 at Stack, % dry	20.9	20.9	20.9	20.9
CO + N2, % dry	79.1	79.1	79.1	79.1
Dry Molecular Weight, lb/lb mole	28.84	28.84	28.84	28.84
Wet Molecular Weight, lb/lb mole	28.20	28.05	27.91	28.06
Stack Diameter, in	10	10	10	10.00
Stack Area, sq. in. (@ pitot meas. location)	78.5	78.5	78.5	78.5
Static Pressure, in. of H2O	-0.62	-0.65	-0.61	-0.63
Stack Pressure, in. of Hg	28.75	28.75	28.76	28.75
Avg. Stack Temp., F	103.3	103.5	109.7	105.5
Avg. Sqrroot of Delta P	1.0659	1.064	1.0663	1.0654
SDE Average	25.298	25.257	25.451	25.335
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	3828.0	3832.2	3871.5	3843.9
Stack Flowrate, wet acfm	2,088	2,090	2,112	2,097
Stack Flowrate, dry scfm	1,771	1,746	1,720	1,746
Stack Flowrate, dry scf/hr	106,263	104,779	103,179	104,741
Stack Flowrate, wet scf/hr	1.1285E+05	1.1292E+05	1.1285E+05	112,873
TGNMO ppmc	358.00	273.00	296.00	309.00
TGNMO Lb/Hr as Carbon	1.184	0.890	0.950	1.008

Triangle Environmental Services, Inc.

METHOD 25 TABLE OF RESULTS

Client: TRC Environmental Corporation

ID#98156R Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

(Post-test PT data replaced by laboratory receipt data)

Sample Description	Concentrations (ppmC)						Mass Conc. (mgC/cu.m)
	CO	CH4	CO2	Noncon- densibles	Conden- sibles	TGNMO	
1 Super Cooker	2	17	6207	5	353	358	179
2 Super Cooker	4	18	5476	19	254	273	136
3 Super Cooker	< 3	21	3479	7	289	296	148

< # = Concentration Below Practical Quantitation Limit

\* Please refer to the "Comments on the Analyses" page of the report for additional information.

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98156R Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

(Post-test PT data replaced by laboratory receipt data)

Sample # 1 Super Cooker

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	3.5	305.37	0.011	Tank N283A:
Postsampling	556.0	297.15	1.871	Tank Volume = 0.004542 cu.m
Lab Receipt	556.0	297.15	1.871	Volume Sampled = 0.003258 dscm
Tank Final	1218.0	297.15	4.099	$\frac{\text{Lab Receipt P/T}}{\text{Postsampling P/T}} = 1.000$
CV Final	1493.0	298.65	4.999	Trap GGI →
				Collection Vessel 33:
				CV Volume = 0.008361 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	376	358	0
CH4	259.6	2	2,024	2,072	1,977
CO2	256.4	2	723,098	722,715	722,456
Noncondensibles	253.5	5	576	490	589
Condensibles	256.4	4	19,003	19,132	19,107

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.6%  
 CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	ppmC			
*=corrected for Blank	Amount	±	SD	%RSD
CO*	2	±	2	86.7
CH4	17	±	0	2.3
CO2*	6207	±	3	0.0
Noncondensibles	5	±	0	9.8
Condensibles*	353	±	1	0.4
TGNMO	358			

Mass Concentration 179 mgC/cu.m

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98156R Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

(Post-test PT data replaced by laboratory receipt data)

Sample # 2 Super Cooker

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	1.5	308.71	0.005	Tank 6209T:
Postsampling	523.0	297.15	1.760	Tank Volume = 0.006126 cu.m
Lab Receipt	523.0	297.15	1.760	Volume Sampled = 0.004147 dscm
Tank Final	1512.0	297.15	5.088	<u>Lab Receipt P/T</u>
CV Final	1500.0	299.65	5.006	Postsampling P/T = 1.000
				Trap DDZ →
				Collection Vessel 12:
				CV Volume = 0.008343 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	3	347	330	368
CH4	259.6	3	1,635	1,597	1,581
CO2	256.4	3	485,063	485,058	485,253
Noncondensibles	253.5	6	1,703	1,679	1,669
Condensibles	256.4	4	17,479	17,554	17,528

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.5%

CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	ppmC		
*=corrected for Blank	Amount	± SD	%RSD
CO*	4	± 0	5.5
CH4	18	± 0	1.7
CO2*	5476	± 1	0.0
Noncondensibles	19	± 0	1.0
Condensibles*	254	± 1	0.2
TGNMO	273		

Mass Concentration 136 mgC/cu.m

Triangle Environmental Services, Inc.

METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98156R Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

(Post-test PT data replaced by laboratory receipt data)

Sample # 3 Super Cooker

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	4.2	308.71	0.014	Tank 6208T:
Postsampling	555.0	298.15	1.861	Tank Volume = 0.006109 cu.m
Lab Receipt	555.0	298.15	1.861	Volume Sampled = 0.004354 dscm
Tank Final	1395.0	298.15	4.679	<u>Lab Receipt P/T</u> = 1.000
CV Final	1496.0	300.65	4.976	<u>Postsampling P/T</u>
				Trap GGE →
				Collection Vessel 40:
				CV Volume = 0.008388 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	3	0	34	308
CH4	259.6	3	2,194	2,209	2,191
CO2	256.4	3	353,186	352,875	353,081
Noncondensibles	253.5	6	645	699	638
Condensibles	256.4	3	20,779	20,939	20,728

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.4%  
 CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

*=corrected for Blank	ppmC		%RSD
	Amount	± SD	
CO*	< 3		
CH4	21	± 0	0.4
CO2*	3479	± 2	0.0
Noncondensibles	7	± 0	5.1
Condensibles*	289	± 2	0.5
TGNMO	296		

Mass Concentration 148 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit





August 26, 1998

Mr. Dave Meirhenry  
Air Quality Compliance Section  
Nebraska Department of Environmental Quality  
P. O. Box 98922  
Lincoln, NE 68509-8922

RE: IBP, inc., Lexington, Nebraska  
Inedible Cooking System VOC Test Report

Dear Mr. Meirhenry:

Please find enclosed a copy of the VOC Test Report for the IBP, Lexington, Nebraska, facility. The testing was conducted on July 21, 1998, by TRC Environmental Corporation. Volatile organic carbon testing was completed per the Nebraska Compliance Sampling Methods and was approved through protocol submittals. As shown in the detailed testing report on page 3, the average VOC (Total Hydrocarbons as Methane) emission rate from the steam heated Dupps Supercooker is 1.00 lbs/hr as carbon.

If you have any questions concerning the testing results or procedures used, please contact me at 402-241-3647 or you may contact Mr. Scott Miller, TRC Project Manager, at 630-810-1122.

Sincerely,

A handwritten signature in cursive script that reads "Rechelle Kruse".

Rechelle Kruse  
Air Pollution Control Engineer

Enclosures

c: Leo Lang (without test report)  
Ryan Post (with test report)  
Mr. Dallas Seifert, Federal EPA- AP-42 (with Test Report)

RK98-563/LE-Stack Testing

IBP, inc. P.O. BOX 515, DAKOTA CITY, NEBRASKA 68731 TELEPHONE: 402-494-2061

**Project Summary:**

IBP created a project to quantify VOC emissions from their rendering processes including blood dryers, edible dryers, and inedible cookers for both beef and pork. The testing was conducted on all three systems under various heating conditions. The intent was to quantify VOC emissions for natural gas system as well as steam systems and to prove or disprove the difference in VOCs from products developed in fuel fired vs. steam heated processes.

A VOC test was conducted on the exhaust outlet of the Lexington steam Dupps Supercooker after the condenser per method 25 TGNMO.

**Emission Data:**

**Inedible Steam Cooker:**

**Test Data:**

Test #1	1.184 lbs/hr
Test #2	0.890 lbs/hr
Test #3	0.928 lbs/hr
Average	1.00 lbs/hr

**Process Information During Test:**

Head Kill	4,665 hd/day
Inedible Yield	39.6 lbs/hd finished crax
Inedible Operation	20 hrs.

**Total Inedible Crax Processed:**

$[(4,645 \text{ hd/day}) \times (39.6 \text{ lbs/hd})] / 20 \text{ hrs/day} = 9,236.7 \text{ lbs/hr finished crax}$   
 $(9,236.7 \text{ lbs/hr}) \times (1 \text{ ton}/2,000 \text{ lbs}) = 4.62 \text{ tons/hr finished crax}$

**Inedible Crax Emission Factor:**

Crax Processed	4.62 tons/hr
VOC Emissions from Blood Drying	1.00 lbs/hr

$1.00 \text{ lbs/hr} / 4.62 \text{ tons/hr} = 0.23 \text{ lbs/ton finished crax}$

**TRC**

**FINAL REPORT**

**TOTAL VOC EMISSIONS OF  
THE SUPERCOOKER**

Prepared for

**IBP, Inc.  
Lexington, Nebraska**

Prepared By

**TRC ENVIRONMENTAL CORPORATION  
DOWNERS GROVE, ILLINOIS 60515**

August 21, 1998

**TRC**

**FINAL REPORT**

**TOTAL VOC EMISSIONS OF  
THE SUPERCOOKER**

Prepared for

**IBP, Inc.**  
**Lexington, Nebraska**

Prepared by

**TRC ENVIRONMENTAL CORPORATION**  
**1307 Butterfield Road, Suite 412**  
**Downers Grove, IL 60515**  
**(630) 810-1122**

August 21, 1998

TRC Project No. 22214-11

## **DISCLAIMER**

This report is intended for use solely by IBP, Inc. the specific purposes described in the contractual documents between TRC Environmental Corporation (TRC) and IBP. All professional services and reports generated by TRC have been prepared for IBP's purposes as described in the contract. The information, statements, and conclusions contained in the report have been prepared in accordance with the work statement, contract terms, and conditions. The report may be subject to differing interpretations and/or may be misinterpreted by third persons or entities who were not involved in the investigative or consultation process. TRC Environmental Corporation therefore expressly disclaims any liability to persons, other than IBP, who may use or rely upon this report in any way or for any purpose.

## TABLE OF CONTENTS

Section	Page
LIST OF FIGURES . . . . .	iii
LIST OF ACRONYMS AND ABBREVIATIONS . . . . .	iv
PROGRAM SUMMARY . . . . .	v
INTRODUCTION . . . . .	1
1.1 Project Scope . . . . .	1
1.2 Sampling Locations . . . . .	1
SUMMARY OF RESULTS . . . . .	2
FIELD SAMPLING PROCEDURES . . . . .	3
3.1 Field Sampling Summary . . . . .	3
3.1.1 Pre-Sampling Preparation . . . . .	3
3.2 Sampling Methods . . . . .	4
3.2.1 Flow Rate Measurements . . . . .	4
3.2.2 CO <sub>2</sub> and O <sub>2</sub> Measurement . . . . .	4
3.2.3 Moisture Measurement . . . . .	4
3.2.4 Total Hydrocarbons . . . . .	4
3.2.4.1 USEPA Method 25 Train for TGNMO . . . . .	4
DATA REPORTING . . . . .	7
4.1 Data Reporting . . . . .	7

## LIST OF FIGURES

Figure 3-1 Method 25 Sampling Train . . . . .	6
Figure 4-1 Measurement Data Flow Scheme . . . . .	9
Figure 4-2 Analytical Data Report Scheme . . . . .	10

## LIST OF TABLES

Table 2-1 VOC Emission Rates for the Supercooker . . . . .	2
Table 4-1 Test Results-Supercooker Exhaust . . . . .	8

## LIST OF APPENDICES

A	Raw Field Data Sheets
B	Process Data
C	Laboratory Data
D	Equipment Calibration
E	Calculations Formulas

## LIST OF ACRONYMS AND ABBREVIATIONS

acfm	actual cubic feet per minute
afmp	actual feet per minute
CEM	continuous emission monitor
CEMS	continuous emission monitoring system
cf	cubic feet
CO <sub>2</sub>	carbon dioxide
dscf	dry standard cubic feet
EPA	Environmental Protection Agency
°F	degrees Fahrenheit
ft	feet
in H <sub>2</sub> O	inches of water
in Hg	inches of mercury
lb/hr	pounds per hour
O <sub>2</sub>	oxygen
ppm (v)	parts per million volume
QA/QC	Quality Assurance/Quality Control
scfm	standard cubic feet per minute
TGNMO	total gaseous non-methane organics
THC	total hydrocarbons
TRC	TRC Environmental Corporation
VOC	volatile organic compound



## PROGRAM SUMMARY

The IBP, Inc. facility located in Lexington, Nebraska has a Supercooker in their rendering operations. TRC Environmental Corporation (TRC) was contracted by IBP, Inc. to conduct emission testing on the Supercooker. The major objectives of the test program was to collect representative flue gas samples and determine the emission rates of volatile organic compounds (VOC's) at the Supercooker exhaust.

TRC accomplished this objective through the use of acceptable test methods performed by trained and experienced staff. IBP, Inc. personnel were responsible for maintaining the proper operations during the emission test series. The emission test program was conducted on July 21, 1998. The emission tests included sampling for total gaseous non-methane organics (TGNMO), total hydrocarbons (THC), volumetric flow rates, and moisture content of the Supercooker flue gas following USEPA Methods 1 (Sampling Location Selection), 2 (Flow Rate), 3 (CO<sub>2</sub> and O<sub>2</sub> for Molecular Weight), 4 (Moisture), and 25 (TGNMO).

## SECTION I

### INTRODUCTION

#### 1.1 Project Scope

The IBP, Inc. facility operates a Supercooker at its Lexington, Nebraska facility. TRC was contracted by IBP, to conduct TGNMO emission testing for determination of volatile organic compound (VOC) emission rates of the Supercooker exhaust.

The major objective of the test program was to collect representative flue gas samples and determine emission rates of VOC at the Supercooker exhaust. Three 1-hour tests were conducted at the Supercooker exhaust, simultaneously with flow rates, CO<sub>2</sub> and O<sub>2</sub> for molecular weight, and moisture.

#### 1.2 Sampling Locations

Sampling for TGNMO was conducted on the Supercooker exhaust. The inside stack dimension was measured to be 10 inches in diameter; therefore, the stack area equals 78.5 square inches. Stack gas velocity, moisture, and volumetric flow rates were measured simultaneously with the TGNMO sampling. The required number of sample points and the sample point locations for the velocity traverses of each source were calculated according to 40 CFR Part 60, Appendix A, Method 1. A copy of the field data sheet can be found in Appendix A.

## SECTION 2

### SUMMARY OF RESULTS

On July 21, 1998, testing was conducted to determine emission rates of the Supercooker exhaust at the IBP plant in Lexington, Nebraska. All testing was completed in accordance with approved test methodologies.

Table 2-1 summarizes the data for the Supercooker on July 21, 1998 at the IBP plant located in Lexington, Nebraska.

Raw field data sheets are located in Appendix A. Process data recorded by IBP is located in Appendix B. Laboratory results are located in Appendix C. Equipment calibration data sheets are located in Appendix D. Calculation formulas can be found in Appendix E. All test procedures were conducted as stated in Section 3. No anomalous data is reported.

**Table 2-1 VOC Emission Rates for the Supercooker**

WET COOKER EXHAUST EMISSION RATE RESULTS			
	TEST #1	TEST #2	TEST #3
TGNMO as Carbon, ppmc	358.0	273.0	289.0

AVG = 1.000 lbs/hr TGNMO as carbon

## SECTION 3

### FIELD SAMPLING PROCEDURES

#### 3.1 Field Sampling Summary

After consideration of the program requirements, TRC provided a experienced professional to conduct the field effort. Mr. Thomas Lundin of the Chicago Measurements office performed the testing.

##### 3.1.1 Pre-Sampling Preparation

Equipment was inspected for proper operation and durability prior to calibration. All calibrations were performed prior to and at the conclusion of the emissions test program as shown below:

- Pitot tubes (QA Handbook Section 3.12, pp. 1-13 and USEPA Reference Method 2) - measured for appropriate spacing and dimensions or calibrated in a wind tunnel. Rejection criteria given on the calibration sheet. Post-test check to inspect for damage.
- Thermocouples (QA Handbook Section 3.4.2, pp. 15-18) - verified against a mercury-in-glass thermometer at three points including the anticipated measurement range. Acceptance limits - impinger  $\pm 2^{\circ}\text{F}$ ; DGM  $\pm 5.4^{\circ}\text{F}$ ; stack  $\pm 1.5$  percent of stack temperature.
- Field barometer (QA Handbook Section 3.4.2, pp. 18-19) - compared against a mercury-in-glass barometer or use the airport station's barometric pressure and correct for elevation. Acceptance criteria -  $\pm 0.02$  in. Hg; post-test check - same.
- Method 25 rotometers - (QA Handbook Section 3.17.2, pp. 4-8) - calibrated against a standard bubble meter. Acceptance criteria - pretest  $Y_i = 0.05Y$ ; post-test check - average 3 run theoretical volume  $\pm 10\%$  of average 3 run actual volume.

## **3.2 Sampling Methods**

### **3.2.1 Flow Rate Measurements**

Velocity measurements at the sampling locations were made following EPA Reference Methods 1 and 2 simultaneously with the TGNMO and (THC) sampling. A Type-S pitot tube with an attached water manometer was used to measure the exhaust velocities at the sampling ports. An attached Type-K thermocouple with remote digimite was used to determine gas temperature.

### **3.2.2 CO<sub>2</sub> and O<sub>2</sub> Measurement**

Tedlar<sup>R</sup> bag flue gas samples were taken concurrently with the TGNMO sampling. A Fyrite was used to determine percent by volume of CO<sub>2</sub> and O<sub>2</sub>.

### **3.2.3 Moisture Measurement**

Moisture was measured simultaneously using USEPA Method 4 for each test run. The moisture train was operated for 30 minutes acquiring a minimum of 21 dry standard cubic feet of gas during the TGNMO sampling run.

### **3.2.4 Total Hydrocarbons**

TRC conducted (TGNMO) testing at the Supercooker exhaust following USEPA RM25.

#### **3.2.4.1 USEPA Method 25 Train for Total Gaseous Non-Methane Organics**

TGNMO sampling as conducted following the criteria of USEPA Reference Test Method 25. Flue gas was sampled from the Supercooker exhaust at a constant rate through a heated probe and filter and a chilled condensate trap by means of an evacuated sample tank. The heated probe and oven were kept at a temperature of  $\geq 265^{\circ}\text{F}$  and  $250 \pm 5^{\circ}\text{F}$  respectively

during the sampling. After completion of each test run, the trap and tank were sealed, labeled and documented on the chain-of-custody record. All traps were kept under dry ice until the moment of analysis. Three one-hour tests were conducted. A schematic representation of the sampling train is included as Figure 3-1.

Leak checks on the Method 25 train were performed before each sampling run. All leak checks and leakage rates are documented on the relevant field test data sheet. Copies of the field data sheets and summary calculations are included in Appendix A.




Figure 3-1 Method 25 Sampling Train

## SECTION 4 DATA REPORTING

### 4.1 Data Reporting

A flow chart depicting the measurement data reporting scheme is shown in Figure 4-1. Figure 4-2 presents the analytical data validation and reporting scheme routinely used at TRC.

All data was reported in standard units depending on the measurement and the ultimate use of the data. The bulk of the data was computer processed and reported as follows:

- Gas Properties:
  - a. Moisture %
  - b. Flow rate, dscfm and acfm
  - c. Pressure, in. Hg
  - d. Temperature, °F
  
- Total Gaseous non-methane Organics as ppmc & lb/hr

Results of the testing conducted at the IBP plant on the Supercooker exhaust are contained in Table 4-1.



**Table 4-1. Test Results - Supercooker Exhaust**

**IBP Lexington Supercooker**

Run No.	1	2	3	
Date	7-21-98	7-21-98	7-21-98	
Start Time	11:57	13:25	14:55	
Stop Time	12:57	14:25	15:55	<b>AVERAGES</b>
Barometric Pressure, in. Hg	28.80	28.80	28.80	28.80
Net Sampling Time, minutes	30.0	30.0	30.0	30.0
Volume Metered, cf	26.508	26.291	26.582	26.460
Avg. DGM Temp, F	93.4	99.00	102.80	98.4
AVG Delta H, in of H2O	2.00	2.00	2.00	2.00
AVG Delta H, in of Hg	0.1471	0.1471	0.1471	0.1471
DGM Calibration Factor	0.9951	0.9951	0.9951	0.9951
Volume of Gas Collected, dscf	24.349	23.908	24.009	24.089
Total Water Collected, mL	32.0	78.0	163.0	91.0
Volume of Water Vapor, scf	1.509	3.678	7.685	4.291
Moisture, % @ Saturation	5.8	7.2	8.6	7.2
Dry Mole Fraction, 100-%M	0.9417	0.9279	0.9143	0.9280
CO2 at Stack, % dry	0.0	0.0	0.0	0.0
O2 at Stack, % dry	20.9	20.9	20.9	20.9
CO + N2, % dry	79.1	79.1	79.1	79.1
Dry Molecular Weight, lb/lb mole	28.84	28.84	28.84	28.84
Wet Molecular Weight, lb/lb mole	28.20	28.05	27.91	28.06
Stack Diameter, in	10	10	10	10.00
Stack Area, sq. in. (@ pitot meas. location)	78.5	78.5	78.5	78.5
Static Pressure, in. of H2O	-0.62	-0.65	-0.61	-0.63
Stack Pressure, in. of Hg	28.75	28.75	28.76	28.75
Avg. Stack Temp., F	103.3	103.5	109.7	105.5
Avg. Sqrroot of Delta P	1.0659	1.064	1.0663	1.0654
SDE Average	25.298	25.257	25.451	25.335
Pitot Coefficient	0.84	0.84	0.84	0.84
Stack Gas Velocity, afpm	3828.0	3832.2	3871.5	3843.9
Stack Flowrate, wet acfm	2,088	2,090	2,112	2,097
Stack Flowrate, dry scfm	1,771	1,746	1,720	1,746
Stack Flowrate, dry scf/hr	106,263	104,779	103,179	104,741
Stack Flowrate, wet scf/hr	1.1285E+05	1.1292E+05	1.1285E+05	112,873
TGNMO ppmc	358.00	273.00	289.00	306.67
TGNMO Lb/Hr as Carbon	1.184	0.890	0.928	1.000




Figure 4-1. Measurement Data Flow Scheme




Figure 4-2. Analytical Data Report Scheme

**APPENDIX A**

**RAW FIELD DATA SHEETS**



# Method 25 Field Data

Client: IBP  
 Location: INED. Super Center  
 Date: 7-21-98

Project Number: \_\_\_\_\_  
 Sample Location: STACK  
 Run Number: 1  
 Operator: T. LUDWIN

Tank Number: 283 Trap Number: GG1 Sample ID: R/1

	Tank Vacuum		Barometric Pressure mm/cm Hg/in. Hg	Ambient Temperature C/F
	Manometer mm/cm Hg	Gauge mm/cm Hg/in Hg		
Pretest	788	235	29.80	90°
Post Term	156	5.0	" "	96°

Pretest Leak Rate (mm/cm Hg/in Hg/5 min): 0.0 i Sm

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting ml/cm	Temperature		Comments
				Probe C/F	Box C/F	
11:57	0	235	40	130	120	
<del>12</del>	5	27.0	40	131	119	Normal
<del>12</del>	10	25.0	40	129	120	Probe
<del>12</del>	15	23.0	40	129	121	heat set
<del>12</del>	20	21.0	40	130	121	to 135 C
<del>12</del>	25	19.0	40	128	121	
<del>12</del>	30	17.0	40	129	121	Box heat
<del>12</del>	35	15.0	40	129	120	set to
<del>12</del>	40	13.0	40	128	121	120 C
<del>12</del>	45	11.0	40	129	122	
<del>12</del>	50	9.0	40	129	121	
<del>12</del>	55	7.0	40	128	122	
12:57	60	5.0	40	128	121	

**TRC**  
 ENVIRONMENTAL

# Method 25 Field Data

Client: IBP  
 Location: LXINGTON NB  
 Date: 7-21-99

Project Number: \_\_\_\_\_  
 Sample Location: INBD - SUPER CASSETTE  
 Run Number: 2  
 Operator: T. LINDON

Tank Number: 6209 Trap Number: DD2 Sample ID: R/2

	Tank Vacuum		Barometric Pressure mm/cm Hg/in. Hg	Ambient Temperature C/F
	Manometer mm/cm Hg	Gauge mm/cm Hg/in Hg		
Pretest	<del>227</del> 730	23.5	28.7	96
Post Term	154	5.5	" "	96

Pretest Leak Rate (mm/cm Hg/in Hg/5 min): 0.0 @ 5min

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting ml / cm	Temperature		Comments
				Probe C/F	Box C/F	
13 <sup>26</sup>	0	23.5	40	130	121	
	5	23.5	40	129	120	Normal
	10	25.0	50	131	122	Probe
	15	23.0	50	130	122	heat set
	20	21.0	60	129	121	to 135 C
	25	19.0	60	131	120	
	30	17.0	60	130	122	Box heat
	35	15.0	60	130	123	set to
	40	13.0	60	131	121	120 C
	45	11.0	60	131	122	
	50	9.0	60	130	120	
	55	7.0	60	130	121	
14 <sup>25</sup>	60	5.5	60	131	121	

**TRC**  
 ENVIRONMENTAL

# Method 25 Field Data

Client: FBR  
 Location: LEXINGTON, NB  
 Date: 7-21-98

Project Number: \_\_\_\_\_  
 Sample Location: INRD. SUPER CORNER  
 Run Number: 3  
 Operator: T. LUNDIN

Tank Number: 6208 Trap Number: GGE Sample ID: P/3

	Tank Vacuum		Barometric Pressure mm/cm Hg/in. Hg	Ambient Temperature <del>°C</del> °F
	Manometer mm/cm Hg	Gauge mm/cm Hg/in Hg		
Pretest	<u>706</u>	<u>29.0</u>	<u>28.7</u>	<u>96°s</u>
Post Term	<u>115</u>	<u>4.5</u>	" "	<u>96</u>


Pretest Leak Rate (mm/cm Hg/in Hg/5 min): 0.0 e sumt

Clock Time	Sample Time	Gauge Vacuum mm/cm Hg	Flowmeter Setting ml / cm	Temperature		Comments
				Probe °C/°F	Box °C/°F	
<u>1455</u>	<u>0</u>	<u>28.5</u>	<u>60</u>	<u>131</u>	<u>120</u>	
	<u>5</u>	<u>26.5</u>	<u>60</u>	<u>131</u>	<u>122</u>	Normal
	<u>10</u>	<u>24.5</u>	<u>60</u>	<u>130</u>	<u>122</u>	Probe
	<u>15</u>	<u>22.5</u>	<u>60</u>	<u>131</u>	<u>121</u>	heat set
	<u>20</u>	<u>20.5</u>	<u>60</u>	<u>132</u>	<u>122</u>	to 135 C
	<u>25</u>	<u>19.5</u>	<u>60</u>	<u>131</u>	<u>120</u>	
	<u>30</u>	<u>16.5</u>	<u>60</u>	<u>131</u>	<u>120</u>	Box heat
	<u>35</u>	<u>14.5</u>	<u>60</u>	<u>132</u>	<u>121</u>	set to
	<u>40</u>	<u>12.5</u>	<u>60</u>	<u>133</u>	<u>121</u>	120 C
	<u>45</u>	<u>10.5</u>	<u>60</u>	<u>131</u>	<u>121</u>	
	<u>50</u>	<u>8.5</u>	<u>60</u>	<u>130</u>	<u>122</u>	
	<u>55</u>	<u>6.5</u>	<u>60</u>	<u>130</u>	<u>121</u>	
<u>1555</u>	<u>60</u>	<u>4.5</u>	<u>60</u>	<u>132</u>	<u>121</u>	

**TRC**  
**ENVIRONMENTAL**



VELOCITY TRAVERSE

Plant: <u>IBP</u>	Date: <u>7-21-98</u>
Unit Number: <u>7MED, Super Comb</u>	Stack Diameter (in.): <u>10"</u>
Load Condition:	Stack Gauge Pressure ("H <sub>2</sub> O): <u>⊖ .62</u>
Run No.: <u>1</u>	Operators: <u>T. LUNDIN</u>
Project No.:	
Barometric Pressure at Ground Level ("Hg): <u>28.70</u>	
Pitot Tube ID:	
Pitot Tube Coefficient: <u>.64</u>	Port Change Pitot Leak Check
Estimated Stack CO <sub>2</sub> %: <u>0.0</u> % O <sub>2</sub> %: <u>16.9</u> % H <sub>2</sub> O %: <u>    </u>	<u>Pass</u> <u>Fail</u>
Platform Elevation (feet): <u>40'</u>	Port #1 <u>✓</u> <u>    </u>
Schematic of Stack Cross Section:	Port #2 <u>✓</u> <u>    </u>
	Port #3 <u>    </u> <u>    </u>
	Port #4 <u>    </u> <u>    </u>
	$\sqrt{\Delta P} = 1.0659$ $T_s = 103.3$

Traverse Point Number	Velocity Head (In H <sub>2</sub> O)	Stack Temp. (F)
1	1.10	102
2	1.30	102
3	1.12	103
4	1.05	104
5	1.22	103
6	1.06	103
Average:		

Traverse Point Number	Velocity Head (In H <sub>2</sub> O)	Stack Temp. (F)
1	1.12	103
2	1.25	102
3	1.10	104
4	1.08	104
5	1.2	105
6	1.05	104
Average:		

Reference: 40 CFR 60, Appendix A, Method 2



**VELOCITY TRAVERSE**

Plant: <u>IBP</u>	Date: <u>7-21-99</u>															
Unit Number: <u>INED. Sump Cooler</u>	Stack Diameter (in.): <u>10"</u>															
Load Condition:	Stack Gauge Pressure ("H <sub>2</sub> O): <u>⊖ .15</u>															
Run No.: <u>2</u>	Operators: <u>T. L. Wood</u>															
Project No.:																
Barometric Pressure at Ground Level ("Hg): <u>28.8</u>																
Pitot Tube ID:																
Pitot Tube Coefficient: <u>.84</u>	<table style="width:100%; border-collapse: collapse;"> <tr> <td style="text-align: center;">Port Change Pitot Leak Check</td> <td style="text-align: center;"><u>Pass</u></td> <td style="text-align: center;"><u>Fail</u></td> </tr> <tr> <td>Port #1</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Port #2</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Port #3</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> <tr> <td>Port #4</td> <td style="text-align: center;">---</td> <td style="text-align: center;">---</td> </tr> </table>	Port Change Pitot Leak Check	<u>Pass</u>	<u>Fail</u>	Port #1	---	---	Port #2	---	---	Port #3	---	---	Port #4	---	---
Port Change Pitot Leak Check		<u>Pass</u>	<u>Fail</u>													
Port #1		---	---													
Port #2		---	---													
Port #3	---	---														
Port #4	---	---														
Estimated Stack CO <sub>2</sub> %: <u>0.0</u> O <sub>2</sub> %: <u>21.9</u> H <sub>2</sub> O%: <u>    </u>																
Platform Elevation (feet):																
Schematic of Stack Cross Section:																

2.1 cm<sup>2</sup>

$\sqrt{\Delta P} = 1.0640$   
T<sub>s</sub> = 103.5

Traverse Point Number	Velocity Head (In H <sub>2</sub> O)	Stack Temp. (F)
1	1.12	102
2	1.27	102
3	1.10	103
4	1.06	105
5	1.20	104
6	1.0	104
Average:		

Traverse Point Number	Velocity Head (In H <sub>2</sub> O)	Stack Temp. (F)
1	1.15	102
2	1.2	103
3	1.12	103
4	1.10	105
5	1.23	105
6	1.05	104
Average:		

**VELOCITY TRAVERSE**

Plant: IBP / LEANINGTON, NB	Date: 7-21-98															
Unit Number: INED SUPER COURSE	Stack Diameter (in.): 10"															
Load Condition:	Stack Gauge Pressure (in.H <sub>2</sub> O): 2.61															
Run No.: 3	Operators: T. LUDLOW															
Project No.:																
Barometric Pressure at Ground Level (in.Hg): 29.8																
Pitot Tube ID:																
Pitot Tube Coefficient: .81	<table style="width:100%; border-collapse: collapse;"> <tr> <td style="border: none;">Port Change Pitot Leak Check</td> <td style="border: none; text-align: center;"><u>Pass</u></td> <td style="border: none; text-align: center;"><u>Fail</u></td> </tr> <tr> <td style="border: none;">Port #1</td> <td style="border: none; text-align: center;">✓</td> <td style="border: none; text-align: center;">—</td> </tr> <tr> <td style="border: none;">Port #2</td> <td style="border: none; text-align: center;">✓</td> <td style="border: none; text-align: center;">—</td> </tr> <tr> <td style="border: none;">Port #3</td> <td style="border: none; text-align: center;">—</td> <td style="border: none; text-align: center;">—</td> </tr> <tr> <td style="border: none;">Port #4</td> <td style="border: none; text-align: center;">—</td> <td style="border: none; text-align: center;">—</td> </tr> </table>	Port Change Pitot Leak Check	<u>Pass</u>	<u>Fail</u>	Port #1	✓	—	Port #2	✓	—	Port #3	—	—	Port #4	—	—
Port Change Pitot Leak Check		<u>Pass</u>	<u>Fail</u>													
Port #1		✓	—													
Port #2		✓	—													
Port #3	—	—														
Port #4	—	—														
Estimated Stack CO <sub>2</sub> %: 0.0 O <sub>2</sub> %: 20.4 H <sub>2</sub> O %: —																
Platform Elevation (feet): 40'																
Schematic of Stack Cross Section:																
See Run #1	$\sqrt{VAP} = 1.0663$ $TS = 109.7$															

Traverse Point Number	Velocity Head (in H <sub>2</sub> O)	Stack Temp. (F)
1	1.15	109
2	1.25	109
3	1.10	110
4	1.07	111
5	1.2	110
6	1.03	109
Average:		

Traverse Point Number	Velocity Head (in H <sub>2</sub> O)	Stack Temp. (F)
1	1.14	109
2	1.23	110
3	1.14	100
4	1.10	111
5	1.25	110
6	1.0	108
Average:		



# FCI 75-0 MOISTURE DETERMINATION

Plant Name: <u>ESP/LEXINGTON</u> Unit: <u>INED. SUPER COOLDR</u> Ambient Temperature: <u>90'</u>	Barometric Pressure: (BPI): <u>28.80</u> Elevation: <u>@ ground</u>
Date: <u>7-21-98</u>	Probe Length & Type: <u>3' 54"</u>
Sampling Location: <u>INED. 54M2 STACK</u> Elevation: <u>40'</u>	Meter Box Number: <u>3</u> Gamma: (Y): <u>9951</u>
Run Number: <u>1</u>	Leak Check: Pre-test: <u>0.00</u> @ 12' Post-test: <u>0.00 @ 10'</u>
Operator: <u>T. LUDWIN</u> Reviewer: _____	

Traverse Point Number	Elapsed Time	Clock Time	Gas Meter Reading (ft <sup>3</sup> )	DELTA H (in H <sub>2</sub> O)	Impinger Temperature (F)	Gas Meter Temperature		Pump Vacuum (Hg")
						INLET °F	OUTLET °F	
1	0	11:58	317.405	2.0	67	92	91	5.0
	5		401.8		62	92	91	5.0
	10		406.2		60	94	92	5.0
	15		410.7		57	96	92	5.0
	20		415.1		58	97	93	5.0
	25		419.5		61	98	93	5.0
	30	12:28	423.913					
			V <sub>m</sub> = 26.508	ΔH = 2.0	Avg.: 93.4		Avg.: 93.4	

Analytical Data				
	Impinger #1 Weight g	Impinger #2 Weight g	Impinger #3 Weight g	Silica Gel Weight g
Final	118	104	2	208
Initial	105	105		205
Net Gain	18	4	2	8
				V <sub>i</sub> (grams) Total

T<sub>m</sub> = 93.4

Moisture Calculation:

Net volume of gas through dry gas meter at meter conditions = V<sub>m</sub> = 26.508 cu. ft.

Average absolute meter temperature (T<sub>m</sub> + 460) = 553.4 °R

Percent moisture = M = 
$$\frac{4.715 (VL)}{.04715 (VL) + 17.64 (Y)(V_m)(BP)} \times \frac{1}{T_m + 460}$$

**FOI 75-b  
MOISTURE DETERMINATION**

Plant Name: <u>IBM / Lexington</u>	Unit: <u>INCO. Super Center</u>	Ambient Temperature: <u>90</u>
Date: <u>7-21-93</u>	Elevation: <u>40</u>	Barometric Pressure (BP): <u>28.8</u>
Sampling Location: <u>Stack</u>	Probe Length & Type: <u>3' 5"</u>	Elevation: <u>0.9451</u>
Run Number: <u>2</u>	Meter Box Number: <u>3</u>	Gamma: <u>IV</u>
Operator: <u>J. Lusk</u>	Reviewer:	Leak Check: <u>Pre-test: 0.002 @ 14" Post-test: 0.001 @ 14"</u>

Traverse Point Number	Elapsed Time	Clock Time	Gas Meter Reading (F <sup>3</sup> )	DELTA H (in H <sub>2</sub> O)	Impinger Temperature (F)	Gas Meter Temperature		Pump Vacuum (Hg")
						INLET °F	OUTLET °F	
	0	1326	424.157	20	67	95	94	8.0
	5		428.2		63	97	95	8.0
	10		432.9		60	101	96	8.0
	15		437.3		58	103	98	8.0
	20		441.7		59	105	99	8.0
	25		446.1		62	106	99	8.0
	30	1355	450.448					
			V <sub>m</sub> = 26.291	ΔH = 20	Avg.:		Avg.:	

T<sub>m</sub> = 99.0

Analytical Data				
	Impinger #1 Weight g	Impinger #2 Weight g	Impinger #3 Weight g	Silica Gel Weight g
Final	166	102	1	207
Initial	105	105		205
Net Gain	66	2	1	9
				V <sub>L</sub> (grams) Total

78

Moisture Calculation:  
 Net volume of gas through dry gas meter at meter conditions = V<sub>m</sub> = 26.291 cu. ft.  
 Average absolute meter temperature (T<sub>m</sub> + 460) = 5590 °R

Percent moisture = M = 
$$\frac{4.715 (VL)}{.04715(VL) + 17.64 (Y)(V_m)(BP)}$$
 T<sub>m</sub> + 460

# FC. 173-0 MOISTURE DETERMINATION

Plant Name: <u>FBP / LAMINGTON</u>	Ambient Temperature: <u>95°</u>
Date: <u>7-21-98</u>	Barometric Pressure (BP): <u>28.8</u> Elevation:
Sampling Location: <u>Stack</u>	Probe Length & Type: <u>3, 25</u>
Run Number: <u>3</u>	Meter Box Number: <u>3</u> Gamma (Y): <u>.9951</u>
Operator: <u>T. LYNDIN</u>	Leak Check: Pre-test: <u>0.000e-10</u> Post-test: <u>0.001 @ 12"</u>

Traverse Point Number	Elapsed Time	Clock Time	Gas Meter Reading (F <sup>3</sup> )	DELTA H (in H <sub>2</sub> O)	Impinger Temperature (F°)	Gas Meter Temperature		Pump Vacuum (Hg <sup>-1</sup> )
						INLET °F	OUTLET °F	
	0	14:55	457.605	2.0	66	101	100	5
	5		462.0		64	102	101	5
	10		466.4		60	103	101	5
	15		470.9		61	105	102	5
	20		475.3		62	106	102	5
	25		479.7		64	108	102	5
	30	15:25	484.187					
			V <sub>m</sub> = <u>26.582</u>	ΔH =	Avg.:		Avg.:	

T<sub>m</sub> = 102.8

Analytical Data			
	Impinger #1 Weight g	Impinger #2 Weight g	Impinger #3 Weight g
Final	236	104	2
Initial	105		
Net Gain	(136)	6	2
	+	+	+
			V <sub>i</sub> (grams) Total

163

### Moisture Calculation:

Net volume of gas through dry gas meter at meter conditions = V<sub>m</sub> = 26.582 cu. ft.  
 Average absolute meter temperature (T<sub>m</sub> + 460) = 562.8 °R

Percent moisture = M =  $\frac{4.715 (VL)}{.04715(VL) + 17.64 (Y)(V_m)(BP)}$  T<sub>m</sub> + 460



**APPENDIX B**

**PROCESS DATA**

Attn: Rachel  
LEXINGTON PLANT

W/E 07/25/98

DAILY STATISTICS REVISED


SLAUGHTER	MON	TUE	WED	THU	FRI	SAT	TOTAL
<b>A SHIFT KILL</b>							
GROSS HOURS	8	8	8	8	8	4	44
NET HOURS	7.75	7.75	7.75	7.5	7.75	3.75	42.25
ACT SUNSHINE MIN	0	6	0	8	0	0	14
PD SUNSHINE MIN	0	6	0	8	0	0	14
HEAD KILLED	2,365	2,365	2,214	2,365	2,230	1,101	12,640
LIVE WT	3,013,537	2,876,047	2,837,450	2,962,056	2,863,579	1,438,911	15,991,580
DRESS WT	1,923,966	1,846,132	1,815,978	1,877,733	1,816,021	911,511	10,191,341
<b>B SHIFT KILL</b>							
GROSS HOURS	7.5	8	8	7.25	8	7.25	46
NET HOURS	7.25	7.75	7.75	7	7.5	7	44.25
ACT SUNSHINE MIN	0	0	0	0	10	0	10
PD SUNSHINE MIN	0	0	0	0	10	0	10
HEAD KILLED	2,064	2,300	2,285	2,070	2,369	2,127	13,215
LIVE WT	2,557,531	2,844,342	2,872,447	2,557,631	2,908,257	2,622,023	16,362,231
DRESS WT	1,622,899	1,802,018	1,828,516	1,840,912	1,858,149	1,683,083	10,435,577
<b>TOTAL KILL #'S</b>							
GROSS HOURS	15.5	16	16	15.25	16	11.25	90
NET HOURS	15	15.5	15.5	14.5	15.25	10.75	86.5
ACT SUNSHINE MIN	0	6	0	8	10	0	24
PD SUNSHINE MIN	0	6	0	8	10	0	24
HEAD KILLED	4,429	4,665	4,499	4,435	4,599	3,228	25,855
LIVE WT	5,571,068	5,720,389	5,709,897	5,519,687	5,771,836	4,060,934	32,353,811
DRESS WT	3,546,865	3,648,150	3,644,494	3,518,645	3,674,170	2,594,594	20,626,918
CONDEMN	1	1	3	4	4	4	17
SLUNKS	2	21	3	0	0	0	26
PERFECT KILL	4,576	4,730	4,730	4,500	4,734	3,279	26,549
PLANNED KILL	4,831	4,960	4,992	4,707	4,938	3,462	27,889
HD FROM PERFECT	(147)	(65)	(231)	(65)	(135)	(51)	(694)
HD FROM PLANNED	(402)	(295)	(493)	(272)	(339)	(234)	(2,034)
TARGETED HD A	2,365	2,365	2,365	2,365	2,365	1,144	12,969
TARGETED HD B	2,211	2,365	2,365	2,135	2,365	2,135	13,576
TARGET % A	100.00%	100.00%	93.62%	100.00%	94.29%	96.26%	97.47%
TARGET % B	93.34%	97.25%	96.62%	96.96%	100.17%	99.63%	97.34%
<b>PROCESSING</b>							
<b>A SHIFT CUT</b>							
HEAD CUT	2,086.0	2,013.5	2,206.0	2,167.5	2,209.5	1,576.5	12,259.0
GROSS HOURS	8	8	8	8	8	5.5	45.5
NET HOURS	7.75	7.75	7.75	7.75	7.75	5.25	44
<b>B SHIFT CUT</b>							
HEAD CUT	1,981.5	1,942.0	2,008.5	1,956.5	2,099.5	1,574.0	11,560.0
GROSS HOURS	8	8	8	8	8	6	46
NET HOURS	7.75	7.75	7.75	7.75	7.75	5.75	44.5
<b>TOTAL CUT #'S</b>							
HEAD CUT	4,067.5	3,955.5	4,212.5	4,124.0	4,309.0	3,150.5	23,819.0
GROSS HOURS	16	16	16	16	16	11.5	91.5
NET HOURS	15.5	15.5	15.5	15.5	15.5	11	88.5



- 1 COOKOR DISCHARGE TEMP
- 2 COOKOR CENTER TEMP
- 3 DISCHARGE RETARD VALVE % SPD
- 4 STEAM VALVE POSITION
- 5 COOKOR LEVEL
- 6 COOKOR VACUUM PRESSURE
- 7 CONTROL WHEEL % SPD - Not incl.
- 8 FEED VALVE - Not incl.

9	_____	17	_____
10	_____	18	_____
11	_____	19	_____
12	_____	20	_____
13	_____	21	_____
14	_____	22	_____
15	_____	23	_____
16	_____	24	_____

3317 ATTN: Rochelle



CH04 0.1  
 CH05 0.1  
 CH06 0.1  
 CH07 0.1  
 CH08 0.1  
 CH09 0.1  
 CH10 0.1  
 CH11 0.1  
 CH12 0.1  
 CH13 0.1  
 CH14 0.1  
 CH15 0.1  
 CH16 0.1  
 CH17 0.1  
 CH18 0.1  
 CH19 0.1  
 CH20 0.1  
 CH21 0.1  
 CH22 0.1  
 CH23 0.1  
 CH24 0.1  
 CH25 0.1  
 CH26 0.1  
 CH27 0.1  
 CH28 0.1  
 CH29 0.1  
 CH30 0.1  
 CH31 0.1  
 CH32 0.1  
 CH33 0.1  
 CH34 0.1  
 CH35 0.1  
 CH36 0.1  
 CH37 0.1  
 CH38 0.1  
 CH39 0.1  
 CH40 0.1  
 CH41 0.1  
 CH42 0.1  
 CH43 0.1  
 CH44 0.1  
 CH45 0.1  
 CH46 0.1  
 CH47 0.1  
 CH48 0.1  
 CH49 0.1  
 CH50 0.1  
 CH51 0.1  
 CH52 0.1  
 CH53 0.1  
 CH54 0.1  
 CH55 0.1  
 CH56 0.1  
 CH57 0.1  
 CH58 0.1  
 CH59 0.1  
 CH60 0.1  
 CH61 0.1  
 CH62 0.1  
 CH63 0.1  
 CH64 0.1  
 CH65 0.1  
 CH66 0.1  
 CH67 0.1  
 CH68 0.1  
 CH69 0.1  
 CH70 0.1  
 CH71 0.1  
 CH72 0.1  
 CH73 0.1  
 CH74 0.1  
 CH75 0.1  
 CH76 0.1  
 CH77 0.1  
 CH78 0.1  
 CH79 0.1  
 CH80 0.1  
 CH81 0.1  
 CH82 0.1  
 CH83 0.1  
 CH84 0.1  
 CH85 0.1  
 CH86 0.1  
 CH87 0.1  
 CH88 0.1  
 CH89 0.1  
 CH90 0.1  
 CH91 0.1  
 CH92 0.1  
 CH93 0.1  
 CH94 0.1  
 CH95 0.1  
 CH96 0.1  
 CH97 0.1  
 CH98 0.1  
 CH99 0.1  
 CH00 0.1

CH04 47.84  
 CH05 20.69  
 CH06 56.78  
 CH07 21.36  
 CH08 58.29  
 CH09 34.11  
 CH10 58.79  
 CH11 34.36  
 CH12 58.5  
 CH13 34.34  
 CH14 58.5  
 CH15 26.16  
 CH16 51.89  
 CH17 13.61  
 CH18 69.36  
 CH19 18.71  
 CH20 55.4  
 CH21 21.62  
 CH22 56.28  
 CH23 27.51  
 CH24 18.4  
 CH25 24.33  
 CH26 25.6  
 CH27 58.44  
 CH28 58.5  
 CH29 38.82  
 CH30 75.4  
 CH31 39.19  
 CH32 52.8  
 CH33 38.88  
 CH34 27.2  
 CH35 33.97  
 CH36 31.4  
 CH37 26.54  
 CH38 37.8  
 CH39 35.14  
 CH40 71.2  
 CH41 40.66  
 CH42 26.43  
 CH43 59.29  
 CH44 38.3  
 CH45 46.38  
 CH46 16.39  
 CH47 25.21

①  
 ②  
 ③

⑤

⑥

④

③

②

④

⑤

⑥

⑦

⑧

⑨

⑩

⑪

⑫

⑬

⑭

⑮

⑯

⑰

⑱

⑲

⑳

㉑

㉒

㉓

㉔

㉕

㉖

㉗

㉘

㉙

㉚

㉛

㉜

㉝

㉞

㉟

㊱

㊲

㊳

㊴

㊵

㊶

㊷

㊸

㊹

㊺

㊻

㊼

㊽

㊾

㊿

0

**APPENDIX C**

**LABORATORY DATA**

**Method 25  
Analytical Results**

prepared for

**TRC ENVIRONMENTAL CORPORATION**

1307 Butterfield Road, Suite 420

Downers Grove, IL 60515

by


**Triangle Environmental Services, Inc.**

Reviewed by:




Donna Nolen-Weathington  
Laboratory Analyst

Approved by:



Larry W. Taylor  
Laboratory Supervisor

Approved by:



John Y. Morimoto, Ph.D.  
QA Officer

Report  
**98156**

August 6, 1998

# Triangle Environmental Services, Inc.

## METHOD 25 TABLE OF RESULTS

Client: TRC Environmental Corporation ID#98156R Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

(Post-test PT data replaced by laboratory receipt data)

Sample Description	Concentrations (ppmC)						Mass Conc. (mgC/cu.m)
	CO	CH4	CO2	Noncon- densibles	Conden- sibles	TGNMO	
1 Super Cooker	2	17	6207	5	353	358	179
2 Super Cooker	4	18	5476	19	254	273	136
3 Super Cooker	< 3	21	3479	7	289	296	148

< # = Concentration Below Practical Quantitation Limit

\* Please refer to the "Comments on the Analyses" page of the report for additional information.

# Triangle Environmental Services, Inc.

## METHOD 25 PROCEDURES

### CALIBRATION

Initial calibrations and operational checks of the recovery and analytical systems are conducted at a frequency of no greater than one year between sets. The calibrations satisfy the requirements for Methods 25, 25-C, and 10-B.

Triplicate injections of a calibration gas mixture consisting of 200.0 ppm carbon monoxide, 50.0 ppm methane, 10000 ppm carbon dioxide, and 20.00 ppm propane are made immediately before and after each batch of samples. Daily response factors are calculated from the pre-batch integrated responses (average area count / concentration in ppmC) and must agree within 10% of the response factors of the initial calibrations. Further, the post-batch response factors must agree within 2% of the pre-batch response factors. Both criteria must be met before the analyses are considered valid.

### CONDENSATE RECOVERY

To flush the trap of CO<sub>2</sub>, hydrocarbon-free air is flushed through the trap maintained at -78 °C into the sample tank until less than 10 ppm CO<sub>2</sub> is detected in the flow stream (the concentration of CO<sub>2</sub> is monitored with an NDIR CO<sub>2</sub> detector and measured using a CO<sub>2</sub> analyzer). The sample tank is pressurized to about 1200 mm Hg for analysis and is replaced with an intermediate collection vessel (ICV).

To oxidize the organic material in the trap, hydrocarbon-free air is then passed through the trap heated to 250 °C and the recovery oxidation catalyst into the ICV until less than 10 ppm CO<sub>2</sub> is detected in the flow stream. The ICV is pressurized to about 1200 mm Hg for analysis.

### ANALYSIS

All samples, which include the daily calibration gas mixture, sample tanks, and ICVs, are analyzed in triplicate using a computer-interfaced gas chromatograph equipped with an automated gas sampling system and a flame ionization detector (FID). CO, CH<sub>4</sub>, and CO<sub>2</sub> are eluted from the Unibead 1S-Carbosieve G column and pass through the analytical oxidation and reduction catalyst to the FID. The column is then backflushed to elute the nonmethane organic (NMO) fraction, which passes through the analytical oxidation and reduction catalysts to the FID.

### CALCULATIONS

Calculations are done in accord with USEPA Method 25 procedures. A sample calculation for one of the samples is provided in the report. CO and CO<sub>2</sub> blanks are used to compensate for a background concentration of (1) "CO" due to the interference of O<sub>2</sub> resulting from the coelution of O<sub>2</sub> and CO and (2) CO<sub>2</sub> due to CO<sub>2</sub> and organic compounds in the recovery carrier gas. A concentration of noncondensibles or condensibles of less than the PQL is considered to be zero in computing the TGNMO.

### EQUIPMENT

Tanks and ICVs are twice evacuated and filled with ambient air filtered through charcoal and are then evacuated to below 10 mm Hg and monitored for at least an hour to check that the tanks do not leak more than 1 mm Hg/hour. They are then pressurized to greater than ambient pressure with helium, analyzed to ensure < 2 ppmC NMO, and stored for later use.

Traps are flushed at 300 °C for at least 30 minutes with compressed air. Each trap is then flushed at 300 °C for thirty minutes with hydrocarbon-free air. The effluent is then routed through an oxidation catalyst and a reduction catalyst for analysis by FID-GC to confirm less than 10 ppmC total C.

Sampling units are reconditioned by replacing filters and checking that all sections operate properly. The unit is heated (with a PTFE line used in place of a trap) and is flushed with zero air for at least thirty minutes before an aliquot of this flow is injected into the analyzer. If the total carbon concentration is below 10 ppm, the unit is made ready for use and stored for shipment.

**Triangle Environmental Services, Inc.**  
**METHOD 25 SAMPLE CALCULATION**

Client: TRC Environmental Corporation

ID#98156 Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

Sample # 1 Super Cooker

**D A T A**

Note: All pressure values have been converted when necessary to mm Hg and all temperature values to Kelvin.

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	
Presampling	3.5	305.37	Tank N283A:
Postsampling	575.5	305.37	Tank Volume = 0.004542 cu.m
Lab Receipt	556.0	297.15	
Tank Final	1218.0	297.15	Trap GGI →
CV Final	1493.0	298.65	Collection Vessel 33:
			CV Volume = 0.008361 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	376	358	0
CH4	259.6	2	2,024	2,072	1,977
CO2	256.4	2	723,098	722,715	722,456
Noncondensibles	253.5	5	576	490	589
Condensibles	256.4	4	19,003	19,132	19,107

CO Blank = 0 area counts    CO2 Blank = 3 ppm

**C A L C U L A T I O N S**

Measured Concentrations, corrected for blank (ppmC):

$$\begin{aligned}
 Cm(CO) &= [Area(CO) - CO\ Blank] / RF(CO) \\
 &= [376 - 0] / 246.7 = 1.5 \\
 &= [358 - 0] / 246.7 = 1.5 \\
 &= [0 - 0] / 246.7 = 0.0
 \end{aligned}$$

$$\begin{aligned}
 Cm(CH4) &= Area(CH4) / RF(CH4) \\
 &= 2024 / 259.6 = 7.8 \\
 &= 2072 / 259.6 = 8.0 \\
 &= 1977 / 259.6 = 7.6
 \end{aligned}$$

$$\begin{aligned}
 Cm(CO2) &= Area(CO2) / RF(CO2) - CO2\ Blank \\
 &= 723098 / 256.4 - 3 = 2817.2 \\
 &= 722715 / 256.4 - 3 = 2815.7 \\
 &= 722456 / 256.4 - 3 = 2814.7
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{Noncondensibles}) &= \text{Area}(\text{Noncondensibles}) / \text{RF}(\text{Noncondensibles}) \\
 &= 576 / 253.5 = 2.3 \\
 &= 490 / 253.5 = 1.9 \\
 &= 589 / 253.5 = 2.3
 \end{aligned}$$

$$\begin{aligned}
 C_m(\text{Condensibles}) &= \text{Area}(\text{Condensibles}) / \text{RF}(\text{Condensibles}) - \text{CO}_2 \text{ Blank} \\
 &= 19003 / 256.4 - 3 = 71.1 \\
 &= 19132 / 256.4 - 3 = 71.6 \\
 &= 19107 / 256.4 - 3 = 71.5
 \end{aligned}$$

Pressure-Temperature Ratio,  $Q(i) = P(i)/T(i)$  (mm Hg/K):

$$\begin{aligned}
 \text{Tank Presampling: } Q(2) &= 3.5 / 305.37 = 0.011 \\
 \text{Tank Postsampling: } Q(1) &= 575.5 / 305.37 = 1.885 \\
 \text{Tank Lab Receipt: } Q(5) &= 556.0 / 297.15 = 1.871 \\
 \text{Tank Final: } Q(3) &= 1218.0 / 297.15 = 4.099 \\
 \text{CV Final: } Q(4) &= 1493.0 / 298.65 = 4.999
 \end{aligned}$$

$$\begin{aligned}
 \text{Volume sampled (dscm)} &= 0.3857 \times \text{Tank Volume} \times [Q(1) - Q(2)] \\
 &= 0.3857 \times 0.004542 \times [1.885 - 0.011] \\
 &= 0.003281
 \end{aligned}$$

Averages and % Relative Standard Deviations (%RSD) of  $C_m$ 's are calculated.  
(%RSD of  $C = \%RSD$  of  $C_m$ )

Calculated concentrations (ppmC):

$$\begin{aligned}
 C(\text{CO}) &= Q(3) / [Q(1) - Q(2)] \times C_m(\text{CO}) \\
 &= 4.099 / (1.885 - 0.011) \times 1.0 = 2.2
 \end{aligned}$$

$$\begin{aligned}
 C(\text{CH}_4) &= Q(3) / [Q(1) - Q(2)] \times C_m(\text{CH}_4) \\
 &= 4.099 / (1.885 - 0.011) \times 7.8 = 17.1
 \end{aligned}$$

$$\begin{aligned}
 C(\text{CO}_2) &= Q(3) / [Q(1) - Q(2)] \times C_m(\text{CO}_2) \\
 &= 4.099 / (1.885 - 0.011) \times 2815.9 = 6161.9
 \end{aligned}$$

$$\begin{aligned}
 C(\text{Noncondensibles}) &= Q(3) / [Q(1) - Q(2)] \times C_m(\text{Noncondensibles}) \\
 &= 4.099 / (1.885 - 0.011) \times 2.2 = 4.8
 \end{aligned}$$

$$\begin{aligned}
 C(\text{Condensibles}) &= \text{Volume}(\text{CV}) / \text{Volume}(\text{Tank}) \times Q(4) / [Q(1) - Q(2)] \times C_m(\text{Condensibles}) \\
 &= 0.008361 / 0.004542 \times 4.999 / (1.885 - 0.011) \times 71.4 = 350.9
 \end{aligned}$$

$$\begin{aligned}
 \text{Total Gaseous Non-Methane Organics (TGNMO)} &= C(\text{Noncondensibles}) + C(\text{Condensibles}) \\
 &= 4.8 + 350.9 \\
 &= 355.6
 \end{aligned}$$

$$\begin{aligned}
 \text{Mass Concentration (mgC/cu.m)} &= 0.4993 \times \text{TGNMO} \\
 &= 0.4993 \times 355.6 = 177.6
 \end{aligned}$$



# Triangle Environmental Services, Inc.

## METHOD 25 SAMPLE QA/QC DATA

### DAILY RECOVERY SYSTEM CHECKS

#### 4.3.1.1\* Condensate Recovery System Leak Check

Evacuate system to  $\leq 10$  mm Hg absolute pressure, isolate system, and monitor for ten minutes.

Requirement: Pressure Change  $\leq 3$  mm Hg

#### 4.3.1.2\* Condensate Recovery System Background Test

Analyze recovery system effluent for  $\text{CO}_2$  concentrations.

Requirement:  $\text{CO}_2 \leq 10$  ppm

#### 4.3.1.3\* Condensate Oxidation Catalyst Efficiency Check

Analyze 1% methane standard through oxidation catalyst.

Requirement:  $\text{CO}_2 = \text{CH}_4$  concentration  $\pm 2\%$

### DAILY ANALYZER CHECKS

#### 5.3\* Daily Calibration

##### Response Factor Checks

Requirement: Daily RF = Initial RF  $\pm 10\%$

See the individual sample data sheet for the daily response factor

	Initial RF for Analyzer A 4/8/98	Initial RF for Analyzer B 4/21/98
CO	219.06	247.37
CH <sub>4</sub>	227.99	250.07
CO <sub>2</sub>	225.44	250.03
NMO	228.34	250.52

Triplicate injections of a mixture of CO, CH<sub>4</sub>, CO<sub>2</sub>, and C<sub>3</sub>H<sub>8</sub> are made before and after each batch of samples.

**INITIAL CONDENSATE RECOVERY SYSTEM TESTS****5.1.1\* Carrier and Auxiliary Gas Blank**Requirement:  $\text{CO} + \text{CH}_4 + \text{CO}_2 + \text{NMO} \leq 5 \text{ ppm}$ **5.1.3\* System Performance Check**

Volume Injected	Compound	Average % Recovery				% RSD			
50 uL	Hexane	101	102	98.8	104.6	0.058	0.101	1.68	0.229
50 uL	Decane	97	100	93.7	103.3	0.120	0.047	1.7	0.359
10 uL	Hexane	104	107	92	90.0	0.118	0.145	1.206	0.135
10 uL	Decane	98	97	99.6	93.3	0.119	0.232	1.36	0.254
Requirement:		100 ± 10%				≤ 5			

**INITIAL NMO ANALYZER PERFORMANCE CHECKS****5.2.1\* Oxidation Catalyst Efficiency Check** Analyzer A,4/8/98; Analyzer B,4/21/98

FID response with reduction catalyst in bypass mode = 0, 0

Requirement: ≤ 1%

**5.2.2\* Reduction Catalyst Efficiency Check** Analyzer A,4/8/98; Analyzer B,4/21/98Response of  $\text{CH}_4$  with oxidation and reduction catalysts in series mode compared to response with both catalysts in bypass mode.

100.0%, 100.0% Requirement: &gt; 95%

**5.2.3\* Analyzer Linearity Check+NMO Calibration** Analyzer A,4/8/98;Analyzer B,4/21/98 $100 \times (1 - \text{RF} / \text{RF}_{\text{average}})$ max. dev.  $\text{CO}$ : +1.70%, +1.28%max. dev.  $\text{CH}_4$ : -2.00%, -1.77%max. dev.  $\text{CO}_2$ : +1.71%, +2.10%

max. dev. NMO: -1.42%, -1.12%

max. %RSD: 1.50%, 0.54%

 $\frac{\text{RF}(\text{NMO})}{\text{RF}(\text{CO}_2)} = 0.98, 1.00$ 

Requirement:

± 2.5%

± 2.5%

± 2.5%

± 2.5%

≤ 2%

1.0 ± 0.1

5.2.4\* **System Performance Check** Analyzer A, 4/8/98; Analyzer B, 4/21/98, 5/1/98

	Measured Value, Expected Value		Requirement
	Analyzer A	Analyzer B	
Propane in Mix	19.6, 20.0	20.22, 20.0	± 5%
Hexane	50.6, 51.6	51.6, 51.6	± 5%
Toluene	20.3, 20.0	19.34, 20.0	± 5%
Methanol	104.5, 109.1	109.55, 109.0	± 5%

**EQUIPMENT CHECKS**4.1.1\* **Clean Sampling Equipment Check**

Sample Unit	<10 ppmC total C	@ 100%
Trap	<10 ppmC total C	@ 100%
Tank	< 2 ppmC NMO	@ 100%

4.1.2\* **Sample Tank Evacuation and Leak Check**

Tank evacuated to  $\leq 10$  mm Hg absolute pressure, monitored for  $\geq 1$  hour, and passed for use if no pressure change ( $< 1$  mm Hg/hr) is noted.

5.4\* **Sample Tank and ICV Volumes**

Tank weighed empty, filled with deionized distilled water (temperature recorded), and weighed to the nearest 2 g. Volume calculated based on density of water at that temperature and results recorded in permanent file.

# Triangle Environmental Services, Inc.

## METHOD 25 DATA REPORT

Client: TRC Environmental Corporation

ID#98156 Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

Sample # 1 Super Cooker

### Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	3.5	305.37	0.011	Tank N283A:
Postsampling	575.5	305.37	1.885	Tank Volume = 0.004542 cu.m
Lab Receipt	556.0	297.15	1.871	Volume Sampled = 0.003281 dscm
Tank Final	1218.0	297.15	4.099	<u>Lab Receipt P/T</u> = 0.993
CV Final	1493.0	298.65	4.999	Postsampling P/T
				Trap GGI →
				Collection Vessel 33:
				CV Volume = 0.008361 cu.m

### Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	376	358	0
CH4	259.6	2	2,024	2,072	1,977
CO2	256.4	2	723,098	722,715	722,456
Noncondensibles	253.5	5	576	490	589
Condensibles	256.4	4	19,003	19,132	19,107

Recovery Oxidation Catalyst Efficiency check: CO2/CH4 = 100.6%

CO Blank = 0 area counts CO2 Blank = 3 ppm

### Concentrations:

*corrected for Blank	ppmC		%RSD
	Amount	± SD	
CO*	2	± 2	86.7
CH4	17	± 0	2.3
CO2*	6162	± 3	0.0
Noncondensibles	5	± 0	9.8
Condensibles*	351	± 1	0.4
TGNMO	356		

Mass Concentration 178 mgc/cu.m

# Triangle Environmental Services, Inc.

## METHOD 25 DATA REPORT

Client: TRC Environmental Corporation ID#98156 Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

Sample # 2 Super Cooker

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	1.5	308.71	0.005	Tank 6209T:
Postsampling	577.5	308.71	1.871	Tank Volume = 0.006126 cu.m
Lab Receipt	523.0	297.15	1.760	Volume Sampled = 0.004409 dscm
Tank Final	1512.0	297.15	5.088	<u>Lab Receipt P/T</u> = 0.941
CV Final	1500.0	299.65	5.006	Postsampling P/T
				Trap DDZ →
				Collection Vessel 12:
				CV Volume = 0.008343 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	3	347	330	368
CH4	259.6	3	1,635	1,597	1,581
CO2	256.4	3	485,063	485,058	485,253
Noncondensibles	253.5	6	1,703	1,679	1,669
Condensibles	256.4	3	17,479	17,554	17,528

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.5%  
 CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	ppmC			%RSD
	Amount	±	SD	
*=corrected for Blank				
CO*	4	±	0	5.5
CH4	17	±	0	1.7
CO2*	5152	±	1	0.0
Noncondensibles	18	±	0	1.0
Condensibles*	239	±	1	0.2
TGNMO	257			

Mass Concentration 128 mgC/cu.m

# Triangle Environmental Services, Inc.

## METHOD 25 DATA REPORT

Client: TRC Environmental Corporation ID#98156 Analyzed: 8/4/98

Project ID: 22214-0000-00011 (IBP/Lexington, Neb.)

Sample # 3 Super Cooker

Pressure, Temperature, Volume Data:

	Pressure (mm Hg)	Temp. (K)	P/T	
Presampling	4.2	308.71	0.014	Tank 6208T:
Postsampling	615.2	308.71	1.993	Tank Volume = 0.006109 cu.m
Lab Receipt	555.0	298.15	1.861	Volume Sampled = 0.004663 dscm
Tank Final	1395.0	298.15	4.679	$\frac{\text{Lab Receipt P/T}}{\text{Postsampling P/T}} = 0.934$
CV Final	1496.0	300.65	4.976	Trap GGE →
				Collection Vessel 40:
				CV Volume = 0.008388 cu.m

Response Factors (RF), Practical Quantitation Limits (PQL), and Area Counts:

	RF (area/ppmC)	PQL (ppmC)	Area 1	Area 2	Area 3
CO	246.7	2	0	34	308
CH4	259.6	2	2,194	2,209	2,191
CO2	256.4	2	353,186	352,875	353,081
Noncondensibles	253.5	5	645	699	638
Condensibles	256.4	3	20,779	20,939	20,728

Recovery Oxidation Catalyst Efficiency Check: CO2/CH4 = 100.4%  
 CO Blank = 0 area counts CO2 Blank = 3 ppm

Concentrations:

	ppmC		%RSD
	Amount	± SD	
*=corrected for Blank			
CO*	< 2		
CH4	20	± 0	0.4
CO2*	3248	± 1	0.0
Noncondensibles	6	± 0	5.1
Condensibles*	270	± 1	0.5
TGNMO	276		

Mass Concentration 138 mgC/cu.m

< # = Concentration Below Practical Quantitation Limit

**Chain  
of  
Custody**





METHOD 25 SAMPLE DATA  
Triangle Environmental Services, Inc.

Company Name: <u>IBP / LEXINGTON, NB</u>		Date: <u>7-21-98</u>		
Units of Measure:	Pressure: <input checked="" type="checkbox"/> mm Hg <input type="checkbox"/> in.Hg	Temperature: <input checked="" type="checkbox"/> °F <input type="checkbox"/> °C		
Run # <u>1</u>	Tank ID # <u>283</u>	Trap ID # <u>GG1</u>		
Description (20 character limit)	<u>S U P E R C O O K E R</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data	<u>28.8</u>	<u>28.5</u>	<u>728</u>	<u>90°S</u>
Post-Test Data	<u>28.8</u>	<u>5.0</u>	<u>156</u>	<u>96°S</u>
Run # <u>2</u>	Tank ID # <u>6209</u>	Trap ID # <u>DD2</u>		
Description (20 character limit)	<u>S U P E R C O O K E R</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data	<u>28.8</u>	<u>28.5</u>	<u>730</u>	<u>96°S</u>
Post-Test Data	<u>28.8</u>	<u>5.5</u>	<u>154</u>	<u>96°S</u>
Run # <u>3</u>	Tank ID # <u>6208</u>	Trap ID # <u>GGE</u>		
Description (20 character limit)	<u>S U P E R C O O K E R</u>			
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data	<u>28.75</u>	<del>28.8</del> <u>28.5</u>	<u>726</u>	<u>96°S</u>
Post-Test Data	<u>28.75</u>	<del>5.0</del> <u>4.5</u>	<u>115</u>	<u>96°S</u>
Run #	Tank ID #	Trap ID #		
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data				
Post-Test Data				
Run #	Tank ID #	Trap ID #		
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data				
Post-Test Data				
Run #	Tank ID #	Trap ID #		
Description (20 character limit)				
	Barometric Pressure	Tank Vacuum	Absolute Pressure	Temperature
Pre-Test Data				
Post-Test Data				

**APPENDIX D**

**EQUIPMENT CALIBRATION**

**PRETEST DRY GAS METER CALIBRATION DATA FORM (ENGLISH UNITS)**

METER BOX NUMBER: 3  
 DRY GAS METER NUMBER: 1197469  
 DATE: 2/2/98  
 REFERENCE TEST METER NUMBER: 27865

DELTA-H	0.5	1	1.5	2	2.5	3	3.5	4	
Vwr	521.055	527.050	533.777	539.676	546.597	552.364	558.432	564.039	569.999
Vdr	37.435	43.636	50.553	56.606	63.691	69.599	75.930	81.677	87.795
Tw	68	70	70	70	70	70	70	70	70
Tdi	75	81	87	91	95	97	98	100	
Tdo	77	77	79	80	81	83	84	85	
Td(AVE)	75.8	79.0	82.8	85.3	87.8	89.8	91.0	92.3	
THETA	14.0	11.0	8.0	8.1	6.0	6.0	5.0	5.0	
VAC.	1	1	1	1	1	1	1	1	
Yi	0.9797	0.9866	0.9943	1.0000	1.0026	0.9868	1.0055	1.0050	
DELTA-H@i	1.5263	1.4989	1.5358	1.5181	1.4928	1.6121	1.5263	1.5403	
Vw	5.995	6.727	5.899	6.921	5.767	6.068	5.607	5.96	
Vd	6.201	6.917	6.053	7.085	5.908	6.331	5.747	6.118	
Vd/Min.	0.4429	0.6288	0.7566	0.8747	0.9847	1.0552	1.1494	1.2236	
Y(AVE)	0.9951	CALIBRATED BY D.W.							
DELTA-H@(AVE)	1.5313								
Pbar	29.47								

Vwr=REFERENCE TEST METER READING

Vdr=DRY GAS METER READING

Vw=GAS VOLUME PASSING THROUGH THE REFERENCE TEST METER, CUBIC FEET

Vd=GAS VOLUME PASSING THROUGH THE DRY GAS METER, CUBIC FEET

Tw=TEMPERATURE OF THE GAS IN THE REFERENCE TEST METER, DEGREES F

Tdi=TEMPERATURE OF THE INLET GAS OF THE DRY GAS METER, DEGREES F

Tdo=TEMPERATURE OF THE OUTLET GAS OF THE DRY GAS METER, DEGREES F

Td=AVERAGE TEMPERATURE OF THE GAS IN THE DRY GAS METER, DEGREES F

DELTA-H=PRESSURE DIFFERENTIAL ACROSS ORIFICE, in. WATER

Yi=RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER FOR EACH RUN

Y=AVERAGE RATIO OF ACCURACY OF REFERENCE TEST METER TO DRY GAS METER

DELTA-H@i=ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

DELTA-H@=AVERAGE ORIFICE PRESSURE DIFFERENTIAL THAT EQUATES TO 0.75 cfm OF AIR

AT 68 DEGREES F AND 29.92 INCHES OF Hg., INCHES OF WATER

TOLERANCE OF Yi=PLUS OR MINUS 0.020 FROM Y

TOLERANCE OF DELTA-H@i=PLUS OR MINUS 0.20 FROM DELTA-H@

Pbar=BAROMETRIC PRESSURE, in. Hg.

THETA=TIME OF CALIBRATION RUN, Min.

Thermocouple Calibration Form

Meter Box #3

Thermocouple Number	Temperature Reading #1	Reference Temp #1	Temperature Reading #2	Reference Temp #2	Temperature Reading #3	Reference Temp #3
1 Stack	71	72	188	186	288	286
2 Probe	71	72	188	186	288	286
3 Filter	72	72	187	186	287	286
4 Impingers	71	72	187	186	288	286
5 Spare	71	72	187	186	287	286
6 DGM In	39	38	71	72	109	108
7 DGM Out	38	38	71	72	109	108

Calibrated By: SRM  
Date: 4-8-96

Criteria: Impinger temperature must be with 2 °F of reference temperature  
Criteria: DGM temperature must be with ±5.4 °F of reference temperature  
Criteria: Stack temperature must be with 1.5% of reference temperature




SUBJECT \_\_\_\_\_

ACTUAL SAMPLING RATE  
cc/min

ROTORMETER SETTINGS  
cc/min

RM 25 RIG #3






SUBJECT \_\_\_\_\_

*ACTUAL SAMPLING RATE  
cc/min*

*KOFORMETER SETTING  
cc/min*

*RM25 RIG # 2*








SUBJECT \_\_\_\_\_


*ACTUAL ROTOMETER READINGS*

*90 100 110 120 130*  
*65 cc/min @*



*RM 25 Rig #1*

# S-TYPE PITOT TUBE CALIBRATION



\*as per 40: CFR


# Type S Pitot Inspection Form

Pitot Tube No. 324

Tubing Diameter,  $D_t$  3/8 in.  $\left(\frac{3}{16} < D_t < \frac{3}{16}\right)$

Pitot Tube Assembly Level?  Yes  No

Pitot Tube Opening Damaged?  Yes  No







Note:

$1.05 D_t < P < 1.50 D_t$

$P_A = P_B$

$P_A = \frac{7}{16}$  in.

$P_B = \frac{7}{16}$  in.



Level Position to find  $\gamma = 1^\circ$

$Z = A' \sin \gamma = .017$  in. ( $< 1/8$  in.)

Level Position to find  $\theta = .5^\circ$

$W = A' \sin \theta = .009$  in. ( $< 1/32$  in.)

Comments: \_\_\_\_\_

Checked by: SM

Date: 8-29-97

Calibration Required? NO

$D_t$  = External Tube Diameter

$A'$  = Distance Between Tips ( $P_A + P_B$ ) inches

**APPENDIX E**

**CALCULATION FORMULAS**

## CALCULATION FORMULAS

<b>Linearity</b>	Percent Difference = $\frac{\text{Analyzer Response} - \text{Cylinder Value}}{\text{Span}} \times 100$
<b>Bias</b>	System Bias = $\frac{\text{System Response} - \text{Analyzer Respor}}{\text{Span}} \times 100$
<b>Drift</b>	System Drift = $\frac{\text{System Response} - \text{Previous System Response}}{\text{Span}} \times 100$
<b>Moisture</b>	Moisture = $\frac{100 \times \text{Volume water vapor (scf)}}{(\text{Volume Gas (dscf)} + \text{Volume water vapor})}$
<b>Stack Area</b>	Area = $3.14 \times \text{Radius}^2$
<b>AFPM</b>	Actual Feet per Minute = $5130 \times .84 \times \text{SDE Avg} \times (1 / (\text{stack pres. Hg} \times \text{wet MW}))^{.5}$
<b>ACFM</b>	Actual Cubic Feet/Min = $\text{AFPM} \times \text{Stack Area (sqare feet)}$
<b>DSCFM</b>	Dry Std. Cubic Feet/Min = $\text{SCFH} / 60 \text{ min}$
<b>DSCF/HR</b>	Dry Std. Cubic Feet/Hr = $\text{MMBTU/HR} \times \text{F-Factor} \times \frac{20.9}{20.9 - (\text{RUN\# O2\%})}$
<b>MMBTU / HR</b>	Million BTU's per Hour = $\text{Fuel Flow (scfm gas)} \times \text{Heat Content ( BTU/scf)} \times 60 \text{ min/hr}$
<b>Humidity</b>	Humidity (gal H2O/gal. air Taken From Chart (Wet bulb / Dry bulb temps)
<b>EFFLUENT GAS CONC CALCULATION</b>	
	$\text{GAS CONC.} = (\text{Avg Stk Conc} - \text{Avg Zero Cal}) \times (\text{Span Conc} / (\text{Avg Span Cal} - \text{Avg Zero Cal}))$
<b>PPM NOx</b>	$\text{NOx PPM @ 15\% O2} = \text{PPM NOx} \times ((20.9\% \text{ O2} - 15\% \text{ O2}) / (20.9\% \text{ O2} - \text{Actual O2\%}))$
<b>PPM CO</b>	$\text{CO PPM @ 15\% O2} = \text{PPM CO} \times ((20.9\% \text{ O2} - 15\% \text{ O2}) / (20.9\% \text{ O2} - \text{Actual O2\%}))$
<b>ISO NOx</b>	$\text{ISO NOx} = \text{PPM NOx @ 15\% O2} \times \{ (760/\text{Barometric mm Hg})^{.5} \times 2.178^{(19 \times (\text{gH2O/gAir} - .00633))} \} \times (288/\text{Ambient temperature in degrees (K)})^{1.53}$
<b>LBS/HR NOx</b>	Pounds per hour NOx = $\text{PPM ISO NOx} \times 1.554\text{E-}7 \times 46 \text{ (MW)} \times \text{DSCFM}$
<b>LBS/HR VOC's</b>	Pounds per hour VOC's = $\text{PPM (C3H8 - CH4)} \times 1.554\text{E-}7 \times 16.01 \text{ (MW)} \times \text{DSCFM}$
<b>LBS/HR CO</b>	Pounds per hour CO = $\text{PPM CO} \times 1.554\text{E-}7 \times 28 \text{ (MW)} \times \text{DSCFM}$
<b>F-Factor</b>	$\text{F-Factor, dscf / MMBTU} = [1,000,000 \times (3.64\text{x\%H}) + (1.53\text{x\%C}) + (.57\text{x\%S}) + (.14\text{x\%N}) - .46\text{x\%O}] / \text{GCV, (I}$