

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/


The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP42 Section:	11.3
Reference:	16
Title:	Sulfur Dioxide Emission Tests Conducted On The #20 Tunnel Kiln In Mooresville, IN, For General Shale Products Corporation, Guardian Systems, Inc., Leeds, AL, December 2, 1986.

AP-42 Section 11.3
Reference 16

GUARDIAN SYSTEMS INC.

**P.O. Box 300
Leeds, Alabama 35094
205/699-6647**



Test Report

SULFUR DIOXIDE EMISSION TESTS
CONDUCTED ON THE
#20 TUNNEL KILN
IN
MOORESVILLE, INDIANA
FOR
GENERAL SHALE PRODUCTS CORPORATION
ON
DECEMBER 2, 1986

Approved by: 

Tom Lotz


Director

Field Services Division

TABLE OF CONTENTS

	Page
I. Introduction and Process Description	1
II. Summary of Test Results	2
Graphs	
1 Combined SO ₂ Results	3
Tables	
1 Summary of Brick Stack SO ₂ Results	4
2 Summary of Round Stack SO ₂ Results	8
Brick Stack Test One SO ₂ Results	5
Brick Stack Test Two SO ₂ Results	6
Brick Stack Test Three SO ₂ Results	7
Round Stack Test One SO ₂ Results	9
Round Stack Test Two SO ₂ Results	10
Round Stack Test Three SO ₂ Results	11
Brick Stack Computer Input Parameters Velocity	12
Brick Stack Computed Results Velocity	13
Round Stack Computer Input Parameters Velocity	14
Round Stack Computed Results Velocity	15
III. Sampling and Analytical Procedures	16
Figures	
1 Stack Breeching Diagram Brick Stack	19
2 Stack Breeching Diagram Round Stack	20
3 SO ₂ Sampling Train	21
IV. Field Data	
SO ₂	
Nomenclature	22
Equations	23
Data Sheets	24
Analytical Sheets	31
Velocity	
Nomenclature	35
Equations	38
Data Sheets	40
V. Plant Operational Data	46
VI. Calibrations	49

Introduction




I. INTRODUCTION AND PROCESS DESCRIPTION

On December 2, 1986, Guardian Systems, Inc. performed a series of Sulfur Dioxide Emissions tests on the #20 Tunnel Kiln System of General Shale Products Corporation located near Mooresville, Indiana. This unit has two stacks, one is a dryer stack (round stack) and the other is the kiln exhaust stack (brick stack). These two stacks were sampled simultaneously and the results summed to determine the total sulfur dioxide emissions from this source. These tests were conducted in accordance to the rules and regulations expressed in the Code of Federal Regulations, Title 40, Section 60, Reference Methods 1-4 and 6 as amended.

Individual bricks are formed and stacked onto kiln cars. The cars are inserted on a regular basis into a long, continuous-fired tunnel kiln. As one car is discharged another is inserted. This provides a constant moving mass inside the kiln. Cars are pushed through the kiln at a slow, methodical pace. (see **Plant Operational Data** for complete process information). By means of a coal firing process, heat is increased in each chamber until the total firing is complete. As the car continues through the kiln from the main firing zone the temperatures are reduced to provide necessary cooling.

Mr. Dave McNeese, Corporate Representative, and Mr. Alvin Hall, Plant Superintendent represented General Shale Products Corporation. Mr. Vic P. Windle represented the Indiana State Board of Health. Mr. Tom Lotz, Mr. Greg Karstens and Mr. Chuck Turner, of Guardian Systems, Inc. performed these tests.

Test Results




II. SUMMARY OF TEST RESULTS

The individual results from the Brick and Round Kiln stacks can be found in the following pages. Below is a summary of the combined sulfur dioxide emissions from the #20 Tunnel Kiln on December 2, 1986.

<u>Test #1</u>	<u>Brick</u>	<u>Round</u>	<u>Total</u>
Sulfur Dioxide Emissions, lbs/hour	17.54	32.01	49.55
Sulfur Dioxide Emissions, tons/year	76.81	140.22	217.03
 <u>Test #2</u>			
Sulfur Dioxide Emissions, lbs/hour	13.93	38.96	52.89
Sulfur Dioxide Emissions, tons/year	61.00	170.63	231.63
 <u>Test #3</u>			
Sulfur Dioxide Emissions, lbs/hour	14.24	35.47	49.71
Sulfur Dioxide Emissions, tons/year	62.37	155.37	217.75
 Average Sulfur Dioxide Emissions, Tons/year			 222.14

GENERAL SHALE CORPORATION

On December 2, 1986



Graph 1

GUARDIAN * SYSTEMS * INCORPORATED
 P.O. BOX 300
 LEEDS, AL 35094
 205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Brick Stk	Brick Stk	Brick Stk	Brick Stk
Time	1050-1235	1337-1453	1530-1640	1050-1650
Stack Temperature, F	159	157	155	157
Moisture Content, %	7.55	8.66	10.74	8.84
Oxygen Content, %	17.00	17.00	17.00	17.00
Carbon Dioxide Content, %	3.00	3.00	3.00	3.00
Stack Velocity, f/s	9.60	8.69	9.32	9.20
Volumetric Flow, ACFM	5,402	4,886	5,245	5,176
Volumetric Flow, DSCFM	4,250	3,810	4,010	4,028
Concentration SO2 #/CF	6.88E-05	6.09E-05	5.92E-05	6.30E-05
Concentration SO2 #/Hr	17.54	13.93	14.24	15.23
Concentration SO2 Tons/Yr	76.81	61.00	62.37	66.73

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	1-A	1-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Brick	Brick	Brick
Time	1050-1110	1215-1235	1050-1235

Total volume sampled, cf	0.621	0.620
Meter correction MCF	1.0995	1.0995
Sampling Time, minutes	20.0	20.0
Barometric Pressure, in Hg	29.85	29.85
Sample Temperature, F	47	51

		Sample Recovery
	SO2	SO2
Norm of titrant	0.0100	0.0100
Vol of sample, ml	100.0	100.0
Vol titrated, ml	10.0	10.0
Vol of titrant, ml	7.40	6.85
Vol of blank, ml	0.25	0.25

		Worksheet Information
	SO2	SO2
Vm	0.683	0.682
Pbar	29.85	29.85
Tm	507	511
Vsoln	100.0	100.0
Va	10.0	10.0
Vt	7.4	6.9
Vtb	0.3	0.3
N	0.0100	0.0100
Volumetric Flow, DSCFM		4,250

		Calculations	
Vol std, Cf	0.7091	0.7024	
Concentration SO2, #/DSCF	7.12E-05	6.63E-05	6.88E-05
mg/DSCM	1140.5	1062.8	1101.6
ppm	422.0	393.2	407.6
#/hr	18.15	16.92	17.54

GUARDIAN * SYSTEMS * INCORPORATED
 P.O. BOX 300
 LEEDS, AL 35094
 205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	2-A	2-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Brick	Brick	Brick
Time	1337-1357	1433-1453	1337-1453

Total volume sampled, cf	0.633	0.628
Meter correction MCF	1.0995	1.0995
Sampling Time, minutes	20.0	20.0
Barometric Pressure, in Hg	29.85	29.85
Sample Temperature, F	52	54

		Sample Recovery
	SO2	SO2
Norm of titrant	0.0100	0.0100
Vol of sample, ml	100.0	100.0
Vol titrated, ml	10.0	10.0
Vol of titrant, ml	6.38	6.40
Vol of blank, ml	0.25	0.25

			Worksheet Information
	SO2	SO2	
Vm	0.696	0.690	
Pbar	29.85	29.85	
Tm	512	514	
Vsoln	100.0	100.0	
Va	10.0	10.0	
Vt	6.4	6.4	
Vtb	0.3	0.3	
N	0.0100	0.0100	
Volumetric Flow, DSCFM			3,810

				Calculations
Vol std, Cf	0.7158	0.7074		
Concentration SO2, #/DSCF	6.05E-05	6.14E-05	6.09E-05	
mg/DSCM	968.7	983.4	976.1	
ppm	358.4	363.9	361.2	
#/hr	13.82	14.03	13.93	

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	3-A	3-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Brick	Brick	Brick
Time	1530-1550	1620-1640	1530-1640

Total volume sampled, cf	0.909	0.820
Meter correction MCF	1.0995	1.0995
Sampling Time, minutes	20.0	20.0
Barometric Pressure, in Hg	29.85	29.85
Sample Temperature, F	53	51

		Sample Recovery
	SO2	SO2
Norm of titrant	0.0100	0.0100
Vol of sample, ml	100.0	100.0
Vol titrated, ml	10.0	10.0
Vol of titrant, ml	9.00	7.90
Vol of blank, ml	0.25	0.25

		Worksheet Information
	SO2	SO2
Vm	0.999	0.902
Fbar	29.85	29.85
Tm	513	511
Vsoln	100.0	100.0
Va	10.0	10.0
Vt	9.0	7.9
Vtb	0.3	0.3
N	0.0100	0.0100
Volumetric Flow, DSCFM		4,010

		Calculations	
Vol std, Cf	1.0259	0.9290	
Concentration SO2, #/DSCF	6.02E-05	5.81E-05	5.92E-05
mg/DSCM	964.8	931.4	948.1
ppm	357.0	344.6	350.8
#/hr	14.49	13.99	14.24

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Round Stk	Round Stk	Round Stk	Round Stk
Time	1045-1225	1335-1450	1530-1640	1045-1640
Stack Temperature, F	124	126	128	126
Moisture Content, %	10.44	10.52	9.22	9.98
Oxygen Content, %	17.00	17.00	17.00	17.00
Carbon Dioxide Content, %	3.00	3.00	3.00	3.00
Stack Velocity, f/s	71.01	71.33	71.69	71.33
Volumetric Flow, ACFM	30,118	30,252	30,404	30,254
Volumetric Flow, DSCFM	24,256	24,258	24,651	24,404
Concentration SO2 #/CF	2.20E-05	2.68E-05	2.40E-05	2.42E-05
Concentration SO2 #/Hr	32.01	38.96	35.47	35.48
Concentration SO2 Tons/Yr	140.22	170.63	155.37	155.41

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	1-A	1-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Round	Round	Round
Time	1045-1105	1205-1225	1045-1225

Total volume sampled, cf	0.462	0.471	
Meter correction MCF	1.1259	1.1259	
Sampling Time, minutes	20.0	20.0	
Barometric Pressure, in Hg	29.85	29.85	
Sample Temperature, F	47	50	

	SO2	SO2	Sample Recovery
Norm of titrant	0.0100	0.0100	
Vol of sample, ml	100.0	100.0	
Vol titrated, ml	10.0	10.0	
Vol of titrant, ml	1.10	2.80	
Vol of blank, ml	0.25	0.25	

	SO2	SO2	Worksheet Information
Vm	0.520	0.530	
Fbar	29.85	29.85	
Tm	507	510	
Vsoln	100.0	100.0	
Va	10.0	10.0	
Vt	1.1	2.8	
Vtb	0.3	0.3	
N	0.0100	0.0100	
Volumetric Flow, DSCFM			24,256

	SO2	SO2	SO2
Vol std, Cf	0.5402	0.5475	
Concentration SO2, #/DSCF	1.11E-05	3.29E-05	2.20E-05
mg/DSCM	178.0	526.8	352.4
ppm	65.8	194.9	130.4
#/hr	16.17	47.86	32.01

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	2-A	2-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Round	Round	Round
Time	1335-1355	1430-1450	1335-1450

Total volume sampled, cf	0.484	0.447
Meter correction MCF	1.1259	1.1259
Sampling Time, minutes	20.0	20.0
Barometric Pressure, in Hg	29.85	29.85
Sample Temperature, F	51	52

		Sample Recovery
	SO2	SO2
Norm of titrant	0.0100	0.0100
Vol of sample, ml	100.0	100.0
Vol titrated, ml	10.0	10.0
Vol of titrant, ml	2.50	2.10
Vol of blank, ml	0.25	0.25

		Worksheet Information
	SO2	SO2
Vm	0.545	0.503
Pbar	29.85	29.85
Tm	511	512
Vsoln	100.0	100.0
Va	10.0	10.0
Vt	2.5	2.1
Vtb	0.3	0.3
N	0.0100	0.0100
Volumetric Flow, DSCFM		24,258

		Calculations	
Vol std, Cf	0.5615	0.5176	
Concentration SO2, #/DSCF	2.83E-05	2.52E-05	2.68E-05
mg/DSCM	453.2	404.3	428.8
ppm	167.7	149.6	158.6
#/hr	41.18	36.73	38.96

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Outlet SO2 Input Parameters for General Shale Products Corporation

Run Number	3-A	3-B	Average
Date	12-02-86	12-02-86	12-02-86
Location	Round	Round	Round
Time	1530-1550	1620-1640	1530-1640

Total volume sampled, cf	0.873	0.906
Meter correction MCF	1.1259	1.1259
Sampling Time, minutes	20.0	20.0
Barometric Pressure, in Hg	29.85	29.85
Sample Temperature, F	52	53

		Sample Recovery
	SO2	SO2
Norm of titrant	0.0100	0.0100
Vol of sample, ml	100.0	100.0
Vol titrated, ml	10.0	10.0
Vol of titrant, ml	4.80	2.65
Vol of blank, ml	0.25	0.25

		Worksheet Information
	SO2	SO2
Vm	0.983	1.020
Pbar	29.85	29.85
Tm	512	513
Vsoln	100.0	100.0
Va	10.0	10.0
Vt	4.8	2.7
Vtb	0.3	0.3
N	0.0100	0.0100
Volumetric Flow, DSCFM		24,651

		Calculations	
Vol std, Cf	1.0109	1.0470	
Concentration SO2, #/DSCF	3.18E-05	1.62E-05	2.40E-05
mg/DSCM	509.1	259.3	384.2
ppm	188.4	95.9	142.2
#/hr	47.01	23.94	35.47

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Computer Input Parameters for General Shale Corporation

Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Brick Stk	Brick Stk	Brick Stk	Brick Stk
Time	1010-1015	1315-1320	1520-1525	1010-1525
Barometric Pressure, in Hg	29.85	29.85	29.85	29.85
Static Pressure, in H2O	-0.030	-0.030	-0.031	-0.030
Meter Volume, CF	0.882	0.808	0.650	
Meter Correction factor, MCF	1.0995	1.0995	1.0995	
Meter Volume (Corrected)	0.970	0.888	0.715	2.573
Stack Temperature, F	159	157	155	157
Meter Temperature, F	53	53	53	53
Meter Pressure, in H2O	0.00	0.00	0.00	0.00
Sqr Velocity Pressure	0.156	0.141	0.151	0.149
Mg of Water Collected	1727.5	1838.0	1875.1	5440.6
% Oxygen	17.00	17.00	17.00	17.00
% Carbon Dioxide	3.00	3.00	3.00	3.00
% Carbon Monoxide	0.00	0.00	0.00	0.00
Stack Area, Sq ft	9.375	9.375	9.375	9.375
Pitot Correction Factor	0.842	0.842	0.842	0.842

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Computed Velocity Results for General Shale Corporation

Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Brick Stk	Brick Stk	Brick Stk	Brick Stk
Time	1010-1015	1315-1320	1520-1525	1010-1525
1. Stack Pressure				
Inches Hg	29.85	29.85	29.85	29.85
Millimeters Hg	758.13	758.13	758.13	758.13
2. Meter Pressure				
Inches Hg	29.85	29.85	29.85	29.85
Millimeters Hg	758.19	758.19	758.19	758.19
3. Meter Volume				
Dry Std Cubic Feet	0.996	0.912	0.734	2.642
Dry Std Cubic Meters	0.028	0.026	0.021	0.075
4. Water Volume				
Std Cubic Feet	0.081	0.087	0.088	0.256
Std Cubic Meters	0.002	0.002	0.002	0.007
5. Moisture Content, %				
	7.55	8.66	10.74	8.84
6. Molecular Weight Dry				
	29.16	29.16	29.16	29.16
7. Molecular Weight Wet				
	28.32	28.19	27.96	28.17
8. Stack Velocity				
Feet per Second	9.60	8.69	9.32	9.20
Meters per Second	2.93	2.65	2.84	2.80
9. Volumetric Flow				
Actual Cubic Ft per minute	5,402	4,886	5,245	5,176
Actual Cubic M per second	2.55	2.31	2.48	2.44
10. Volumetric Flow				
Dry Std Cubic Ft per minute	4,250	3,810	4,010	4,028
Dry Std Cubic M per minute	2.01	1.80	1.89	1.90
12. Excess Air, %				
	412.62	412.62	412.62	412.62

GUARDIAN * SYSTEMS * INCORPORAT
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Computer Input Parameters for General Shale Corporation


Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Round Stk	Round Stk	Round Stk	Round Stk
Time	955-1000			1010-1525
Barometric Pressure, in. Hg	29.85	29.85	29.85	29.85
Static Pressure, in H2O	-1.250	-1.250	-1.260	-1.253
Meter Volume, CF	0.520	0.596	0.725	
Meter Correction factor, MCF	1.1259	1.1259	1.1259	
Meter Volume (Corrected)	0.585	0.671	0.816	2.073
Stack Temperature, F	124	126	128	126
Meter Temperature, F	47	51	53	50
Meter Pressure, in H2O	0.00	0.00	0.00	0.00
Sqr Velocity Pressure	1.179	1.182	1.189	1.183
Mg of Water Collected	1506.4	1727.9	1807.6	5041.9
% Oxygen	17.00	17.00	17.00	17.00
% Carbon Dioxide	3.00	3.00	3.00	3.00
% Carbon Monoxide	0.00	0.00	0.00	0.00
Stack Area, Sq ft	7.069	7.069	7.069	7.069
Pitot Correction Factor	0.842	0.842	0.842	0.842

GUARDIAN * SYSTEMS * INCORPORATED
P.O. BOX 300
LEEDS, AL 35094
205-699-6647

Computed Velocity Results for General Shale Corporation

Run Number	1	2	3	Average
Date	12-02-86	12-02-86	12-02-86	12-02-86
Location	Round Stk	Round Stk	Round Stk	Round Stk
Time	955-1000			1010-1525
1. Stack Pressure				
Inches Hg	29.76	29.76	29.76	29.76
Millimeters Hg	755.86	755.86	755.84	755.85
2. Meter Pressure				
Inches Hg	29.85	29.85	29.85	29.85
Millimeters Hg	758.19	758.19	758.19	758.19
3. Meter Volume				
Dry Std Cubic Feet	0.608	0.692	0.838	2.140
Dry Std Cubic Meters	0.017	0.020	0.024	0.061
4. Water Volume				
Std Cubic Feet	0.071	0.081	0.085	0.237
Std Cubic Meters	0.002	0.002	0.002	0.007
5. Moisture Content, %				
	10.44	10.52	9.22	9.98
6. Molecular Weight Dry				
	29.16	29.16	29.16	29.16
7. Molecular Weight Wet				
	27.99	27.99	28.13	28.05
8. Stack Velocity				
Feet per Second	71.01	71.33	71.69	71.33
Meters per Second	21.65	21.74	21.85	21.74
9. Volumetric Flow				
Actual Cubic Ft per minute	30,118	30,252	30,404	30,254
Actual Cubic M per second	14.22	14.28	14.35	14.28
10. Volumetric Flow				
Dry Std Cubic Ft per minute	24,256	24,258	24,651	24,404
Dry Std Cubic M per minute	11.45	11.45	11.64	11.52
12. Excess Air, %				
	412.62	412.62	412.62	412.62

Sampling & Analytical Procedures



III. SAMPLING AND ANALYTICAL PROCEDURES

General

All sampling and analytical procedures for the determination of Sulfur Dioxide Emission rates were conducted in strict adherence with the Code of Federal Regulations, Title 40, Section 60, Methods 1-4, and 6, as amended. The equipment used in this test series was calibrated before and after these tests (See Calibrations). All samples were taken as close as possible to the centroid of each duct. The velocity was determined before each series of sulfur dioxide tests. The sulfur dioxide concentration was determined for each test by extracting a gas sample from the stack. The sulfuric acid mist (including sulfur trioxide) and sulfur dioxide were separated, and the sulfur dioxide fraction was measured by barium-thorin titration method.

METHOD 1

This method was used to determine the number of sampling points and the required matrix for velocity determination. The dimensions of the stacks (see Figures 1 & 2) indicated that 16 points would be required for the velocity traverses on both stacks. We measured 20 points (4 x 5 matrix) on the brick stack and 16 points (8 per diameter) on the round stack. Verification of absence of cyclonic flow was not determined because cyclonic flow did not seem to exist from either stack exhaust.

METHOD 2

Velocity measurements were taken using a S type pitot tube and a 10 in. water column inclined-vertical manometer, having 0.01 in. H₂O divisions on the 0 to 1 in. inclined scale, and 0.1 in H₂O divisions on the 1 to 10 in. vertical scale. To measure the low flow on the brick stack a micromanometer, having 0.001 in. H₂O divisions on the 0 to 0.25 inclined scale, was used.

METHOD 3

Gas analysis for CO₂, O₂, and N₂ by difference was performed by using the grab sample technique once during each velocity test and analyzed with a Fyrite Gas Analyzer (0-20% scale with 0.5% divisions).

METHOD 4

Moisture content of the stack gases was determined during the velocity measurement for each test by weighing the increase in weight of the silica gel.

METHOD 6

Sampling Techniques

The SO₂ determinations were made by utilizing the sample train in **Figure 3**. Initial and final leak checks of the sampling system as outlined in Method 6 were performed and recorded on the data sheets (**See Field Data**). The sampling probe was placed at the sampling point and the sample was taken for 20 minutes at approximately 1.0 liter/minute.

The stack gases were drawn through a heated probe to prevent condensation which contained a glass wool plug to remove particulate matter. The gases were then scrubbed through a series of midget impingers placed in an ice bath to maintain a maximum exit temperature of 68⁰F. This temperature was also recorded on the data sheets. The scrubbed gases then entered a silica gel tube to remove moisture. The clean gases then passed through the dry gas meter where the gas flow and temperature were measured.

The first impinger, with glass wool in the top to prevent carry over, contained approximately 15 ml of 80% IPA (for SO₃ removal), the second and third approximately 15 ml of a 3% hydrogen peroxide solution and the fourth blank. For the first three determinations a fifth impinger was added to prove the collection efficiency of the sampling train and contained approximately 15 ml of a 3% hydrogen peroxide solution.

After the sampling was complete, the system was purged by drawing ambient air through the system for fifteen minutes at the average flow rate used for sampling. The cleanup data was recorded on **Method 8 Sample Recovery and Integrity Data** and is located in the Field Data Section of this report. The collection system was transported to the field lab where the contents of the second and third impingers were combined with the rinsing of the connecting glassware and the fourth impinger and placed in a clearly marked 100 ml volumetric flask. The contents of the first impinger was discarded. The contents of the fifth impinger (for the first three tests only) and the rinsing of the connecting glassware was placed in a clearly marked 100 ml volumetric flask for analysis.

Analysis

All titrations were performed on jobsite. The Barium Perchlorate was initially standardized in our laboratory in Birmingham. The titer used for this test was again standardized against 0.0200N Sulfuric Acid and the normality was determined to be 0.0100N. A blank was determined for the hydrogen peroxide.

Each container was brought to 100 ml volume and 10 ml was titrated for SO₂ content using the Barium Perchlorate titrant until duplicate titrations agreed within 0.1 ml. For runs 1A, 1B, and 2A, the back half or fifth impinger was titrated to determine the collection efficiency of the sampling train. No SO₂ was found in any of these, indicating a 100% collection efficiency for the sampling train. This data is recorded on the **Sulfur Dioxide Analytical Data**. Additionally one EPA known standard from Lot # 585, and two(2) unknown EPA standards were prepared and titrated with the following results:

<u>Sample</u> <u>Number</u>	<u>Measured</u> <u>Concentration</u>	<u>Actual</u> <u>Concentration</u>	<u>Relative</u> <u>Error</u>	<u>Type</u>
9405	213.5 mg/DSCM	221.2 mg/DSCM	-3.61%	Known
3430	1632 mg/DSCM	1630 mg/DSCM	-0.12%	Unknown
1363	2456 mg/DSCM	2430 mg/DSCM	-1.07%	Unknown






Figure 1



<u>POINTS</u>	<u>DISTANCE</u>
1	1.2"
2	3.8"
3	7.0"
4	11.6'
5	24.4"
6	29.0"
7	32.2'
8	34.8"

ROUND STACK
GENERAL SHALE

Figure 2





Figure 3

Method 6 Sampling Train

Field Data



NOMENCLATURE FOR SO₂

C_{SO_2}	= Concentration of sulfur dioxide, dry basis corrected to standard conditions, mg/dscm (lb/dscf)
C_{ppm}	= Concentration of sulfur dioxide, dry std. conditions, ppm
N	= Normality of barium perchlorate titrant, milliequivalents/ml
P_{bar}	= Barometric pressure at the exit orifice of the dry gas meter, mm Hg (in. Hg).
P_{std}	= Standard absolute pressure, 760 mm Hg (29.92 in Hg)
T_m	= Average dry gas meter absolute temperature, °K (°R).
T_{std}	= Standard absolute temperature, 293 °K (528 °R)
V_a	= Volume of sample aliquot titrated, ml.
V_m	= Dry gas volume measured by the dry gas meter, dcm (dcf)
$V_{m(std)}$	= Sample volume at standard conditions (dry basis), ml.
V_{soln}	= Total volume in which the sulfur dioxide sample is contained, 100ml.
V_t	= Volume of barium perchlorate titrant used for the sample, ml. (average or replicate titrations)
V_{tb}	= Volume of barium perchlorate titrant used for the blank, ml.
Y	= Dry gas meter calibration factor
32.03	= Equivalent weight of sulfur dioxide

EQUATIONS FOR SO₂

$$\begin{aligned}V_{m(\text{std})} &= V_m \times Y \times (T_{\text{std}}/T_m) \times (P_{\text{bar}}/P_{\text{std}}) \\ &= K_1 \times Y \times (V_m) \times (P_{\text{bar}}/T_m)\end{aligned}$$

$$C_{\text{so2}} = K_2 \times (V_t - V_{\text{tb}}) \times (N) \times (V_{\text{soln}}/V_a) / (V_{m(\text{std})})$$

If C_{so2} is in Metric units then:

$$C_{\text{ppm}} = C_{\text{so2}} \times 0.37$$

Where: $K_1 = 17.64 \frac{\text{°R}}{\text{in Hg}}$ for English units

$K_2 = 7.061 \times 10^{-5} \text{lb/meq.}$ for English units

PLANT NAME General Shale CITY Marietta, Ga
 SAMPLE LOCATION Brick Stack DATE 12/2/86
 OPERATOR Turner SAMPLE NO. Run 1-6
 BAROMETRIC PRESSURE mm Hg (in Hg) 29.85 PROBE LENGTH m (ft) 2'
 PROBE MATERIAL glass PROBE HEATER SETTING 40%
 METER BOX NO. #2 714045 METER CALIBRATION FACTOR (Y) _____
 AMBIENT TEMP. °C 45° SAMPLE POINT LOCATION Port C for Run 1/6
 INITIAL LEAK CHECK < 20 cc/min for Run #1, #2, #3, SAMPLE PURGED (min) 15 min / checked for Run 1-6
 FINAL LEAK CHECK < 20 cc/min for Run #1, #2, #3, REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (liters)	Sample flow rate setting (cfm)	Sample volume metered (ft ³)	Percent Deviation (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
Run #1	20 min 1050	1.8 pm		785.800 - 786.421		46.46, 47.47	46.46, 47.47
Run #2	20 min 1215	1.8 pm		787.684 - 788.304		51.57, 51.57	52.52, 52.52
Run #3	20 min 1337	1.8 pm		788.605 - 789.238		52.52, 52.53	53.53, 53.53
Run #4	20 min 1433	1.8 pm		790.237 - 790.865		54.54, 54.54	54.54, 54.54
Run #5	20 min 1530	1.58 pm		791.012 - 791.721		53.53, 54.53	55.55, 54.53
Run #6	20 min 1630	1.58 pm		792.905 - 793.725		51.51, 51.51	50.50, 50.50
Total				ΔV m avg.	Max. Dev.	Avg.	Max. Temp.

+) Percent deviation (S) = $\frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100$

Run #1 786.104
 Run #2 786.221
 Run #3 786.310
 Run #4 790.390
 Run #5 740.600
 Run #6 790.740

Run #1 787.850
 Run #2 787.945
 Run #3 788.160
 Run #4 791.200
 Run #5 791.570
 Run #6 791.700

Run #1 787.765
 Run #2 788.930
 Run #3 789.100
 Run #4 793.140
 Run #5 793.350
 Run #6 793.520

Field sampling data sheet

#5 moisture 786.795 1.8 pm 26 min
 Finish 787.677
 #2 moisture 789.395 1.8 pm 25 min
 790.203
 #4 moisture 792.215 1.58 pm 15 min
 792.865

PLANT NAME LEAD SARGE CITY MORRISVILLE TND
 SAMPLE LOCATION ROUND STACK DATE 12-2-86
 OPERATOR KARSTENS SAMPLE NO. #1A
 BAROMETRIC PRESSURE mm Hg (in Hg) 29.85 PROBE LENGTH m (ft) 3'
 PROBE MATERIAL GLASS PROBE HEATER SETTING 40%
 METER BOX NO. 4 METER CALIBRATION FACTOR (Y) 1
 AMBIENT TEMP. °C 40° SAMPLE POINT LOCATION "A" SIDE
 INITIAL LEAK CHECK 1 at 10" SAMPLE PURGED (min) 15 MINUTES
 FINAL LEAK CHECK 1 at 10" REMARKS:

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (l/cf)	Sample flow rate setting (lpm)	Sample volume metered (l/cf)	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
20	1045-105	1 LPM	1 LPM	96.004		47 F	47 F
5				96.112		47	46
10				96.216		48	46
15				96.312		47	46
20				96.424		48	46
Total				ΔV _m avg. 1.0543		Avg. 47	Max. Temp.

$$\pm) \text{ Percent deviation } (\%) = \frac{\frac{\Delta V_m}{\Delta V_m \text{ avg.}} - \frac{\Delta V_m}{\Delta V_m \text{ avg.}}}{\Delta V_m \text{ avg.}} \times 100$$

0.462

Cell # 3 @ 1 LPM
 START 96.565
 22 MIN
 FINISH 97.075

Field sampling data sheet

PLANT NAME GEN SHALE CITY ROCKSBILL INDIANA
 SAMPLE LOCATION ROUND STACK DATE 12-2-81
 OPERATOR KARSTENS SAMPLE NO. #1 B
 BAROMETRIC PRESSURE mm Hg (in Hg) 29.85 PROBE LENGTH m (ft) 3
 PROBE MATERIAL GLASS PROBE HEATER SETTING 400h
 METER BOX NO. #4 METER CALIBRATION FACTOR (Y) 1
 AMBIENT TEMP. °C 42° SAMPLE POINT LOCATION Point "A"
 INITIAL LEAK CHECK GOOD AT 10" SAMPLE PURGED (min) 15 MIN
 FINAL LEAK CHECK _____ REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (l (ft ³))	Sample flow rate setting (lpm (cfm))	Sample volume metered (l (ft ³))	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
0	1205-1225		1 LPM	97.173		50	47
5			"	97.285		50	47
10			"	97.394		50	48
15			"	97.502		49	49
20			"	97.601		49	49
				428			
Total		Total		ΔV _m avg.	Max. Dev.	Avg.	Max. Temp.
				471		50	

$$\pm) \text{ Percent deviation (\%)} = \frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100$$

Field sampling data sheet

PLANT NAME GEN SHALE CITY MOOREVILLE, MS
 SAMPLE LOCATION ROUND STRCK DATE 12-2-86
 OPERATOR KARSTEN SAMPLE NO. 2A
 BAROMETRIC PRESSURE mm Hg (in Hg) 29.85 PROBE LENGTH m (ft) 3'
 PROBE MATERIAL GLASS PROBE HEATER SETTING 400°
 METER BOX NO. 4 METER CALIBRATION FACTOR (Y) _____
 AMBIENT TEMP. °C 44° SAMPLE POINT LOCATION PORT "A"
 INITIAL LEAK CHECK GOOD AT 10" SAMPLE PURGED (min) 15 MIN
 FINAL LEAK CHECK _____ REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (lit)	Sample flow rate setting lpm (cfm)	Sample volume metered (lit)	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
0			"	98.045		51	50
5			"	98.160		50	49
10			"	98.278		50	50
15			"	98.395		51	49
20			"	98.485		52	49
Total				440		51	

+) Percent deviation (S) = $\frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100$

.484

CELL # 600TUGS
 3000 TONNIB
 TIME START 98.636
 25 MIN FINISH 99.232

Field sampling data sheet

PLANT NAME GEN SHALE CITY MORRISVILLE IND
 SAMPLE LOCATION ROUND SHALE DATE 12-2-82
 OPERATOR KAUTZS SAMPLE NO. 28
 BAROMETRIC PRESSURE mm Hg 29.85 PROBE LENGTH m (ft) 3'
 PROBE MATERIAL C GAS PROBE HEATER SETTING 40%
 METER BOX NO. 4 METER CALIBRATION FACTOR (V) 1
 AMBIENT TEMP. °C 4.0 SAMPLE POINT LOCATION ROCK "A"
 INITIAL LEAK CHECK GOOD AT 10" H₂O SAMPLE PURGED (min) 15 MIN
 FINAL LEAK CHECK _____ REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (l (cc))	Sample flow rate setting (cfm)	Sample volume metered (l (cc))	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
20	1430-1450		12 PM	99.245		53	51
5			"	99.371		52	TD
10			"	99.462		53	49
15			"	99.572		52	49
20			"	99.692		52	49
Total	Total	Total		ΔV _m avg. <u>447</u>	Max. Dev.	Avg. <u>52</u>	Max. Temp.

$$+) \text{ Percent deviation } (\%) = \frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100 = \frac{.097}{.447} \times 100 = 21.91$$

Field sampling data sheet

PLANT NAME GEN SHALE CITY MOORESVILLE TN
 SAMPLE LOCATION ROUND STICK DATE 12-2-86
 OPERATOR KAYENDS SAMPLE NO. 3A
 BAROMETRIC PRESSURE mm Hg (in Hg) 25.85 PROBE LENGTH m (ft) 31
 PROBE MATERIAL CWAS PROBE HEATER SETTING 4000
 METER BOX NO. ✓ METER CALIBRATION FACTOR (Y) 1.0
 AMBIENT TEMP. °C 46.0 SAMPLE POINT LOCATION POCT "A"
 INITIAL LEAK CHECK 6000 AT 10" SAMPLE PURGED (min) 15 MIN
 FINAL LEAK CHECK _____ REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (l (cc))	Sample flow rate setting (lpm (cfm))	Sample volume metered (l (cc))	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
0	1530-1550	15 UPM	"	99.793		54	54
5		"	"	100.042		52	52
10		"	"	100.221		52	49
15		"	"	100.425		52	49
20		"	"	100.446		52	49
Total		Total		ΔV _m avg. <u>373</u>	Max. Dev.	Avg. <u>52</u>	Max. Temp.

+) Percent deviation (%) = $\frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100$

Field sampling data sheet

PLANT NAME GEN SHALE CITY MORGESVILLE MD
 SAMPLE LOCATION ROWND STAC DATE 12-2-86
 OPERATOR KROSTONIS SAMPLE NO. 38
 BAROMETRIC PRESSURE mm Hg (in Hg) 29.95 PROBE LENGTH (in ft) 3'
 PROBE MATERIAL CUASS PROBE HEATER SETTING 4096
 METER BOX NO. 4 METER CALIBRATION FACTOR (V) _____
 AMBIENT TEMP. °C 48° SAMPLE POINT LOCATION POLY "A"
 INITIAL LEAK CHECK COND AT 10" SAMPLE PURGED (min) 15 MIN
 FINAL LEAK CHECK _____ REMARKS: _____

Sampling Time (min)	Clock Time (24 hr)	Sample Volume (lit)	Sample flow rate setting (cfm)	Sample volume metered (lit)	Percent Deviation % (+)	Dry gas meter temp. °C (°F)	Impinger temperature °C (°F)
0	1630-1640		1.5 LPM	103.050		53	51
5			"	103.479		53	50
10			"	103.479		53	50
15			"	103.702		53	50
20			"	103.956		53	50
Total				Δvm avg.	Max. Dev.	Avg.	Max. Temp.
						53	

+) Percent deviation (%) = $\frac{\Delta V_m - \Delta V_m \text{ avg.}}{\Delta V_m \text{ avg.}} \times 100$

Handwritten notes:
 16 MIN FINISH
 7 MIN
 300'S (20, 86 Z)
 Bel # (10v column)

Field sampling data sheet

METHOD 6

SULFUR DIOXIDE ANALYTICAL DATA

PLANT Cent. Shale DATE 12-2-86
 SAMPLE LOCATION AS notes ANALYST Tom Lutz

NORMALITY OF BARIUM PERCHLORATE
 1 20.2 ml .0088 N
 2 20.1 ml .0100 N .0100 N
 3 20.1 ml .0100 N

Run No.	Sample No.	Total Volume of Sample	Sample Aliquot	Volume of Titrant V_t , ml		
				1st Titration	2nd Titration	Average
NA	SP 9405	100	10	1.6	1.7	1.65
NA	A02884	100	10	5.5	5.4	5.45
NA	A02304	100	10	5.4	5.5	5.45
NA	A03430	100	10	10.9	11.0	10.95
IA	IA Pk. Bk. Front	100	10	7.4	7.4	7.4
IA	IA Pk. Bk.	100	10	.25	.20	.225

Blank Analysis - Volume of titrant 1st titration .20
 2nd titration .30
 Average .25

1st titration = 0.99 to 1.01 or 1st titration - 2nd titration = 0.2 ml
 2nd titration

Signature of Analyst Tom Lutz
 Signature of Reviewer or Supervisor Lutz

METHOD 6

SULFUR DIOXIDE ANALYTICAL DATA

PLANT Genl Shale DATE 12-2-86
 SAMPLE LOCATION As noted ANALYST Tom Coste

NORMALITY OF BARIUM PERCHLORATE
 1 20.2 ml 0.099 N
 2 20.1 ml 0.100 N 0.100 N
 3 20.1 ml 0.100 N

Run No.	Sample No.	Total Volume of Sample	Sample Aliquot	Volume of Titrant V_t , ml		
				1st Titration	2nd Titration	Average
1A	Raw Back	100	10	0.1	0.1	0.1
1A	Raw Front	100	10	1.1	1.1	1.1
UNA	FA A01363	100	10	16.35	16.35	16.35
1A	Raw Front	100	10	2.8	2.8	2.8
1B	Raw Back	100	10	0.1	0.1	0.1
1B	Raw Back	100	10	0.3	0.2	0.25

Blank Analysis - Volume of titrant 1st titration .20
 2nd titration .30
 Average .25

1st titration = 0.99 to 1.01 or 1st titration - 2nd titration = 0.2 ml
 2nd titration

Signature of Analyst Tom Coste
 Signature of Reviewer or Supervisor [Signature]

METHOD 6

SULFUR DIOXIDE ANALYTICAL DATA

PLANT Central Shale DATE 12-2-86
 SAMPLE LOCATION as noted ANALYST Tom Lotz

NORMALITY OF BARIUM PERCHLORATE
 1 20.2 ml 0.099 N
 2 20.1 ml 0.100 N 0.100 N
 3 20.1 ml 0.100 N

Run No.	Sample No.	Total Volume of Sample	Sample Aliquot	Volume of Titrant V _t , ml		
				1st Titration	2nd Titration	Average
1B	BRICK Front	100	10	6.9	6.8	6.85
2A	Road Front	100	10	2.5	2.5	2.5
2A	Road Back	100	10	0.2	0.2	0.2
2A	Back Back	100	10	0.2	0.2	0.2
2A	BRICK Front	100	10	6.4	6.35	6.38
2B	BRICK Road Side	100	10	6.45	6.35	6.4

Blank Analysis - Volume of titrant 1st titration .2
 2nd titration .3
 Average .25

1st titration • 0.99 to 1.01 or 1st titration - 2nd titration = 0.2 ml
 2nd titration

Signature of Analyst Tom Lotz
 Signature of Reviewer or Supervisor [Signature]

METHOD 6

SULFUR DIOXIDE ANALYTICAL DATA

PLANT Coal Street DATE 12-1-86
 SAMPLE LOCATION ASBESTO ANALYST Tom Lett

NORMALITY OF BARIUM PERCHLORATE
 1 20.2 ml 0.099 N
 2 20.1 ml 0.100 N 0.100 N
 3 20.1 ml 0.100 N

Run No.	Sample No.	Total Volume of Sample	Sample Aliquot	Volume of Titrant V _t , ml		
				1st Titration	2nd Titration	Average
2B	Coal Street	100	10	2.1	2.1	2.1
2A	Coal Street	100	10	4.5	4.8	4.8
3A	Coal Street	100	10	9.0	9.0	9.0
3B	Coal Street	100	10	2.6	2.7	2.65
3B	Coal Street	100	10	7.9	7.9	7.9

Blank Analysis - Volume of titrant 1st titration 0.2
 2nd titration 0.3
 Average 0.25

1st titration = 0.99 to 1.01 or 1st titration - 2nd titration = 0.2 ml
 2nd titration

Signature of Analyst [Signature]
 Signature of Reviewer or Supervisor [Signature]

NOMENCLATURE

- ACF - Actual Cubic Feet
- ACFM - Actual Cubic Feet per minute
- ACM - Actual Cubic Meters
- ACMS - Actual Cubic Meters per second
- A_n - Cross sectional area of nozzle, (ft²)
- A_s - Area of Stack, (ft²)
- B_{ws} - Water vapor in the gas stream, proportion by volume
(dimensionless)
- C_a - Acetone blank residue concentration, mg/g
- c_a - Particulate Concentration, ACF
- CFM - Cubic feet per minute
- C_p - Pitot tube coefficient, (dimensionless)
- c_s - Particulate Concentration, grains/DSCF
- C_{SO_2} - Concentration of sulfur dioxide (dry basis) corrected
to standard conditions, lb/DSCF
- C_{12} - Particulate concentration (c_s adjusted to 12% excess air),
grains/DSCF
- C_{50} - Particulate concentration (c_s adjusted to 50% excess air),
grains/DSCF
- DSCF - Dry Standard Cubic Feet
- DSCFM - Dry Standard Cubic Feet per minute
- DSCM - Dry Standard Cubic Meters
- DSCMS - Dry Standard Cubic Meters per second
- EA - Excess Air, %
- I - Isokinetic Sampling, %
- K_m - Orifice Correction Factor, (dimensionless)
- K_p - Pitot tube constant, 85.49 $\left[\frac{(\text{lb/lb-mole})(\text{in. Hg})}{(^{\circ}\text{R})(\text{in. H}_2\text{O})} \right]^{1/2}$

NOMENCLATURE - continued

- La - Maximum acceptable leakage rate for either a pretest leak check or for a leak check following a component change; equal to 0.02 CFM or 4 percent of the average sampling rate, whichever is less.
- Li - Individual leakage rate observed during the leak check conducted prior to the "ith" component change (i = 1,2,3,...n), CFM.
- Lp - Leakage rate observed during the post test leak check, ft³/min. (cfm).
- Ma - Mass of residue of acetone after evaporation, mg.
- Md - Molecular weight of stack gas; dry basis, lb/lb-mole.
- Mn - Total amount of particulate matter collected, mg.
- Ms - Molecular weight of stack gas; wet basis, lb/lb-mole.
- Mw - Molecular weight of water, 18.0 g/g-mole (18.01 lb/lb-mole)
- ΔP - Velocity head of stack gas, in. H₂O
- Pa - Density of acetone, mg/ml
- Pbar - Barometric pressure at the sampling site, in. Hg
- Pg - Stack static pressure, in. H₂O
- Pm - Meter pressure, in. Hg
- PMR - Particulate Mass Rate, lbs per hour
- Ps - Absolute stack pressure, in. Hg
- Pstd - Standard absolute pressure, 29.92 in. Hg
- Pw - Density of water, 0.9982 g/ml (0.002201 lb/ml)
- Qa - Volumetric flow rate, ACFM
- Qs - Volumetric flow rate, DSCFM
- R - Ideal gas constant, 0.06236 mm Hg - m³/^oK-g-mole
(21.85 in. Hg-ft³/^oR-lb-mole)
- SCF - Standard Cubic Foot
- ta - Ambient Temperature, °F
- tm - Average Temperature of meter, °F
- ts - Average Temperature of stack, °F

NOMENCLATURE - continued

tstd - Standard Temperature, 68°F

NOTE: Capital "T" denotes degrees Rankin

Va - Volume of acetone blank, ml

Vaw - Volume of acetone used in wash, ml

Vlc - Total volume of liquid collected in condenser and silica gel, ml

Vm - Volume of gas sample, as measured by the dry gas meter, ACF

Vmc - Volume of gas sample, corrected for leak, ACF

Vm(std) - Volume of gas sample measured by the dry gas meter, corrected to standard conditions, DSCF

Vn - Volume collected at stack conditions through nozzle, ACF

Vs - Average stack gas velocity, ft/sec.

Vw(std) - Volume of water in the gas sample, corrected to standard conditions, SCF

Wa - Weight of residue in acetone wash, mg

Y - Dry gas meter calibration factor, (dimensionless)

ΔH - Average pressure differential across the calibrated orifice, in. H₂O

ΔH_a - Value of ΔH measured for a specific orifice when operated under the following conditions: 0.75 cfm of dry air (M.W. = 29) at 68°F, 29.92 in. Hg.

$\sqrt{\Delta P}$ - Average of the square roots of the velocity pressure, in. H₂O

θ - Total sampling time, min.

θ_1 - Sampling time interval from the beginning of a run until the first component change, min.

θ_i - Sampling time interval between two successive component changes, beginning with the interval between the first and second changes, min.

θ_p - Sampling time interval from the final (nth) component change until the end of the sampling run, min.

%CO₂, %O₂, %N₂, %CO - Number percent (%) by volume (dry basis) of each compound in the stack gas.

EQUATIONS

$$1. \quad P_s = P_{\text{bar}} + \frac{P_g}{13.6}$$

$$2. \quad P_m = P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}$$

$$3. \quad V_{m(\text{std})} = V_m Y \left(\frac{T_{\text{std}}}{T_m} \right) \left[\frac{P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6}}{P_{\text{std}}} \right]$$

$$4. \quad V_w(\text{std}) = 0.04707 V_{1c}$$

$$5. \quad B_{ws} = \frac{V_w(\text{std})}{V_m(\text{std}) + V_w(\text{std})}$$

$$6. \quad M_d = 0.44 (\%CO_2) + 0.32 (\%O_2) + 0.28 (\%N_2 + \%CO)$$

$$7. \quad M_s = M_d (1 - B_{ws}) + 18(B_{ws})$$

$$8. \quad v_s = K_p C_p (\sqrt{\Delta p}) \text{ avg.} \quad \sqrt{\frac{T_s}{M_s P_s}}$$

$$9. \quad Q_a = (v_s) (A_s) (60)$$

$$10. \quad Q_s = Q_a (1 - B_{ws}) \left(\frac{528}{T_s} \right) \left(\frac{P_s}{29.92} \right)$$

$$11. \quad c_s = [0.0154 (Mn/Vm_{\text{std}})]$$

$$12. \quad EA = \left[\frac{\%O_2 - 0.5 \%CO}{0.264 \%N_2 (\%O_2 - 0.5 \%CO)} \right] 100$$

$$13. \quad c_{50} = \frac{c_s}{1 - \left[\frac{(1.5)(\%O_2) - 0.133(\%N_2) - 0.75 (\%CO)}{21} \right]}$$

$$14. \quad c_{12} = c_s \frac{12}{\%CO_2}$$

EQUATIONS - continued

$$15. \quad \text{PMR} = (c_s)(Q_s) \left(\frac{60}{7000} \right)$$

$$16. \quad V_n = \frac{T_s}{P_s} \left[(0.002669)(V_{1c}) + \frac{V_m}{T_m} \left(P_{\text{bar}} + \frac{\overline{\Delta H}}{13.6} \right) \right]$$


$$17. \quad C_a = (0.0154)(M_n) / V_n$$

$$18. \quad I = \frac{100 V_n}{60 \theta v_s A_n}$$

$$19. \quad V_{mc} = V_m - (L_p - L_a) \theta$$

$$20. \quad W_a = C_a V_a w p_a$$

Plant Operation Data



PROCESS INFORMATION

PLANT: 20, Mooresville, IN

DATE: December 2, 1986

Brick Rate:

Car Schedule	=	<u>34</u>	Minutes	=	<u>1.765</u>	Cars/Hour
Car Count	=	<u>3,968</u>	S/S Brick/Car			
Hourly Rate	=	<u>7,002</u>	S/S Brick/Hour			
Brick Weight	=	<u>4.8</u>	Lbs.			
Brick Rate	=	<u>33,611</u>	Lbs./Hour			

Fuel Rate:

Total	=	<u>26.2</u>	Therms/M Brick		
Coal	=	<u>15.61</u>	Tons/Day		
		<u>1,301</u>	Lbs./Hour	=	<u>100</u> % of Btu's
Natural Gas	=	<u>-0-</u>	MCF/Day		
			Cu. Ft./Hour	=	<u> </u> % of Btu's

Total Process Weight:


		<u>33,611</u>	Lbs. Brick/Hour
+		<u>1,301</u>	Lbs. Coal/Hour
		<u>34,912</u>	Total Lbs./Hour
		<u>17.46</u>	Tons/Hour

Coal Analysis:

Avg., Previous 12 Months:

<u>(Report Attached)</u>	Btu/Lb.	<u>14,145</u>
<u> </u>	Sulfur	<u>0.97</u>
<u> </u>	Ash	<u>3.68</u>

Allowable Emissions:



GUARDIAN SYSTEMS, INC.

305 Ashville Road
P.O. Box 300
Leeds, Alabama 35094
205/699-6647

December 10, 1986

Customer: General Shale Products Corp.
P.O. Box 3547 C.R.S.
Johnson City, TN 37601

Control number: 63860

Report to: Mr. David McNeas

Sample date: 12/04/86

Sample Mark: Coal Analysis

Sample Number:

LABORATORY REPORT

<u>Parameter</u>	<u>Units</u>		<u>Results</u>
	<u>As Received</u>	<u>Dry Basis</u>	
Moisture, %	4.17		
Ash, %	3.21	3.35	
Sulfur, %	1.00	1.05	
Btu	12,774	13,330	
MAF, Btu		13,792	

Method Reference: "Standard Methods", 15th Ed., 1981
ASTM ANNUAL STANDARDS

Approved by: 

DAILY BURNING REPORT - PLANT #20

Pre-Dryer Supply Temperature 160°
 Green Cars at 8:00 A.M. 56
 Kiln Schedule 34 Minutes
 Cars Burned 166656
 Brick Burned 42
 Type Brick Burned CHALD.
 Kiln Car Bearing Temperature 345°
 Car Count 3968


FUEL:

Coal 31220 THERMS 4402 GAS .1700 THERMS .17
 Total Therms 4402.17
 Total Therms per M 26.51
 BTU/LBS Product 6.87

C.W.A. LOW 1.2 HIGH 5.2 AVG. 3.2

KWH/M 108
 KWH COST/M. 5.29

Calibrations



VI. CALIBRATIONS

Meters

The meters #703039 & #714045 were initially calibrated at a fixed setting 1.0 liter per minute. Upon return to the laboratory from this test the meters were recalibrated at the same flow rate. The recalibration produced a single point MCF which agreed within 5% of the initial value and the initial factor was multiplied by the meter volume to obtain a corrected meter volume.

Pitot Tubes

The S type tubes were calibrated against a standard pitot tube ($C_p = 0.99$) in a wind tunnel with a capacity to generate a test section velocity of approximately 3000 feet/ minute every 6 months. Additionally the pitot tube was measured as to its specifications and alignment. Upon return, the intercomponent spacings and the face opening alignment of the pitot tube assembly were rechecked. If no changes are noticed, it was assumed that the coefficient of the assembly had not changed.

Temperature measurements

All temperature devices shall be calibrated every 6 months against an ASTM mercury-in-glass reference thermometer or a reference thermocouple and potentiometer calibrated by fixed points, e.g., ice bath and boiling water (corrected to barometric pressure). Upon return the stack temperature device was recalibrated within 10% of the average absolute stack temperature. If the device being tested agrees within 1.5% of the reference device, the temperature data taken in the field shall be considered valid.

Barometric Pressure

An aneroid barometer capable of measuring atmospheric pressure to within 0.1 inches Hg was used. If this device is defective the following alternate method shall be used. The barometric reading may be obtained from a nearby national weather service station, in which case the station value (which is the absolute barometric pressure) shall be requested and an adjustment for elevation differences between the weather station and sampling point shall be applied at a rate of minus 0.1 inches Hg per 100 feet elevation increase or vice versa for elevation decrease.

VI. CALIBRATIONS CONTINUED

Specific Test equipment and measurements

The equipment used during these tests was as follows:

	Brick	Round
Meter:	#714045	#703039
Probe:	Collapse 6'	Collapse 6'
Stack Temperature:	Omega II	Omega III
Average Stack Temp:	157	126
Recalibration Temp:	155	125

Each temperature device was recalibrated. The recalibration temperature for each device agreed exactly with an ASTM mercury-in-glass reference thermometer. The intercomponent spacings and the face opening alignment of the Pitot Tube assembly was rechecked and no changes were noticed.

GUARDIAN SYSTEMS INC
 Meter Calibration #714045 w/ pump #2
 on 11/21/86

Run Number	1	2	3	Average
Barometric Pres, in Hg	30.19	30.19	30.19	30.19
Set Flow rate l/m rotometer	1.00	1.00	1.00	1.00
Flow rate l/m from dry gas	1.13	1.15	1.15	1.14
Pres Wet Test Meter, in H2O	-0.11	-0.08	-0.15	-0.11
Gas Volume Wet Init, CF	0.000	0.000	0.000	0.000
Gas Volume Wet Final, CF	0.589	0.621	0.619	1.829
Gas Volume Dry Init, CF	783.103	783.644	784.214	2350.961
Gas Volume Dry Final, CF	783.644	784.214	784.790	2352.648
Temp Wet Init, C	12.2	12.5	12.6	12.4
Temp Wet Final, C	12.5	12.6	12.8	12.6
Dry Gas Temp Init In, F	62	62	63	62
Dry Gas Temp Final In, F	62	63	63	63
Dry Gas Temp Init Out, F	61	61	62	61
Dry Gas Temp Final Out, F	61	62	62	62
Run Time, sec	900	930	930	2760
Meter Calibration Factor, Y Adjusted to 29.92 and 528	1.1038	1.1049	1.0902	1.0995
Qm	0.0398	0.0406	0.0405	0.0403

SIGNATURE _____

GUARDIAN SYSTEMS INC
 Meter Calibration #714045 w/ pump #2
 on 12/04/86


Run Number	1	2	3	Average
Barometric Pres, in Hg	30.30	30.30	30.30	30.30
Set Flow rate l/m rotometer	1.00	1.00	1.00	1.00
Flow rate l/m from dry gas	1.13	1.14	1.14	1.14
Pres Wet Test Meter, in H2O	-0.12	-0.11	-0.10	-0.11
Gas Volume Wet Init, CF	0.000	0.595	1.195	1.790
Gas Volume Wet Final, CF	0.595	1.195	1.793	3.583
Gas Volume Dry Init, CF	793.937	794.481	795.026	2383.444
Gas Volume Dry Final, CF	794.481	795.026	795.568	2385.075
Temp Wet Init, C	14.7	14.9	14.9	14.8
Temp Wet Final, C	14.9	14.9	15.0	14.9
Dry Gas Temp Init In, F	61	63	64	63
Dry Gas Temp Final In, F	63	64	65	64
Dry Gas Temp Init Out, F	61	63	64	63
Dry Gas Temp Final Out, F	63	64	65	64
Run Time, sec	900	900	900	2700
Meter Calibration Factor, Y				
Adjusted to 29.92 and 528	1.1005	1.1106	1.1149	1.1087
Previous Y				1.0995
			Difference	-0.83%

SIGNATURE _____



GUARDIAN SYSTEMS INC
 Meter Calibration #703039 w/ pump #4
 on 11/26/86

Run Number	1	2	3	Average
Barometric Pres, in Hg	29.95	29.95	29.95	29.95
Set Flow rate 1/m rotometer	1.00	1.00	1.00	1.00
Flow rate 1/m from dry gas	0.92	0.92	0.92	0.92
Pres Wet Test Meter, in H2O	-0.16	-0.16	-0.14	-0.15
Gas Volume Wet Init, CF	0.000	0.000	0.000	0.000
Gas Volume Wet Final, CF	0.488	0.488	0.487	1.463
Gas Volume Dry Init, CF	94.354	94.787	95.220	284.361
Gas Volume Dry Final, CF	94.787	95.220	95.657	285.664
Temp Wet Init, C	18.8	18.8	18.8	18.8
Temp Wet Final, C	18.8	18.8	18.8	18.8
Dry Gas Temp Init In, F	66	68	68	67
Dry Gas Temp Final In, F	68	68	67	68
Dry Gas Temp Init Out, F	66	68	68	67
Dry Gas Temp Final Out, F	68	68	67	68
Run Time, sec	900	900	900	2700
Meter Calibration Factor, Y				
Adjusted to 29.92 and 528	1.1291	1.1312	1.1176	1.1259
Qm	0.0326	0.0327	0.0326	0.0326

SIGNATURE 

GUARDIAN SYSTEMS INC
 Meter Calibration #703039 w/ pump #4
 on 12/04/86

Run Number	1	2	3	Average
Barometric Pres, in Hg	30.30	30.30	30.30	30.30
Set Flow rate l/m rotometer	1.00	1.00	1.00	1.00
Flow rate l/m from dry gas	0.93	0.93	0.94	0.93
Pres Wet Test Meter, in H2O	-0.16	-0.15	-0.16	-0.16
Gas Volume Wet Init, CF	0.000	0.488	0.977	1.465
Gas Volume Wet Final, CF	0.488	0.977	1.469	2.934
Gas Volume Dry Init, CF	104.873	105.298	105.727	315.898
Gas Volume Dry Final, CF	105.298	105.727	106.162	317.187
Temp Wet Init, C	14.0	14.1	14.1	14.1
Temp Wet Final, C	14.1	14.1	14.3	14.2
Dry Gas Temp Init In, F	62	63	64	63
Dry Gas Temp Final In, F	63	64	65	64
Dry Gas Temp Init Out, F	62	63	64	63
Dry Gas Temp Final Out, F	63	64	65	64
Run Time, sec	900	900	900	2700
Meter Calibration Factor, Y				
Adjusted to 29.92 and 528	1.1593	1.1529	1.1458	1.1526
Previous Y				1.1259
			Difference	-2.32%

SIGNATURE _____



PITOT CALIBRATION FORM

Date 10-1-86 Probe # COLLAPSE 6'

Calibrated By G KARSTENS

Nozzle Size NA

SIDE A

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(A)$
1	.28	.38	.849	+ .004
2	.30	.41	.846	+ .001
3	.29	.40	.842	- .003
		$\bar{C}_p(A)$.845	

SIDE B

.84

Run #	ΔP_{std} (in. H ₂ O) Standard	$\Delta P(s)$ (in. H ₂ O) Type "s"	$C_p(s)$	Deviation $C_p(s) - \bar{C}_p(B)$
1	.25	.35	.837	- .001
2	.25	.35	.837	- .001
3	.26	.36	.841	+ .003
		$\bar{C}_p(B)$.838	

CALCULATIONS

.84

$$C_p(s) = C_{p(std)} \sqrt{\frac{\Delta P_{std}}{\Delta P(s)}} \text{ (or } 0.99 \text{)}$$

$$\text{Average Deviation} = \frac{\sum |C_p(s) - \bar{C}_p(A \text{ or } B)|}{3}$$

← Must be ≤ 0.01

$$|\bar{C}_p(A) - \bar{C}_p(B)| \leftarrow \text{Must be } \leq 0.01$$

TEMPERATURE CALIBRATION
FOR OMEGA 2

DATE INITIAL 10-11-86

DATE FINAL

DEVICE READING (DEGREES F)


ACTUAL TEMPERATURE (DEGREES F)



TEMPERATURE CALIBRATION
FOR OMEGA 2

DATE INITIAL 10-11-96

DATE FINAL



DEVICE HEADING (DEGREES)

ACTUAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION
FOR OMEGA 3

DATE INITIAL 110-1-86

DATE FINAL

WETBULB READING (DEGREES F)

300 600 900 1200 1500 1800 2100 2400

ACIDAL TEMPERATURE (DEGREES F)

TEMPERATURE CALIBRATION
FOR OMEGA 3

DATE INITIAL 10-11-86

DATE FINAL

DEVICE READING (DEGREES F)

ACTUAL TEMPERATURE (DEGREES F)

