

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

<b>AP42 Section:</b>	11.7
<b>Background Chapter:</b>	4
<b>Reference:</b>	12
<b>Title:</b>	<i>Volatile Organic Compound Emission Testing, Golden Astro Furnace Exhaust, Coors Electronic Package Company, Chattanooga, TN, August 26, 1993, Analytical Testing Consultants, Inc., Kannapolis, NC and Roswell, GA, September 1993.</i>

AP-42 Section 11.7  
Reference \_\_\_\_\_  
Report Sect. 4  
Reference 12

COPY

**VOLATILE ORGANIC COMPOUND EMISSION TESTING  
GOLDEN ASTRO FURNACE EXHAUST**

**COORS ELECTRONIC PACKAGE COMPANY**

**CHATTANOOGA, TENNESSEE  
AUGUST 26, 1993  
REPORT # 5392**

**Temporary Operating Permit #  
0090-30500899-80T**

**ANALYTICAL TESTING CONSULTANTS, INC.**

**301 Brookdale Street  
Kannapolis, N. C. 28083  
(704) 932-3193**

**P. O. Box 767190  
Roswell, Georgia 30076  
(404) 587-5696**

**Prepared by:  
kp**

**Distribution:  
Mr. Brent Floyd  
(5 copies)**

**Issue Date:  
September 1, 1993**



**COPY** TABLE OF CONTENTS

Introduction

Source Description

Results Summary

Results, Conclusions, and Comments

Sampling and Analytical Procedures

Calculations

Data Sheets

## INTRODUCTION

This report presents the results of volatile organic compound (VOC) emissions testing performed on the Golden Astro Furnace exhaust in operation at Coors Electronic Package Company. Testing was conducted on August 26, 1993. These results are presented in the following RESULTS SUMMARY and RESULTS, CONCLUSIONS, AND COMMENTS.

The purpose of this test was to determine emission rates and compare those to permitted levels as established by the Chattanooga-Hamilton County Air Pollution Control Bureau and contained in the applicable provisions of the Chattanooga Air Pollution Control Ordinance.

The test was conducted by ANALYTICAL TESTING CONSULTANTS, INC. Kannapolis, N. C. and Atlanta, Georgia. Members of the test team were Richard Westbrook, team leader, John Welch, and James Whitlock.

## SOURCE DESCRIPTION

A Golden Astro ceramic processing furnace (Model #CPF-2048-MS, serial #F860806) is utilized for curing of ceramic plates for computer chips. The furnace was originally scheduled to be charged with 48 pounds of product. However, the furnace would not hold that much. A full charge of 36 pounds was agreed upon by Hal Roach, representative of Chattanooga-Hamilton County, and Brent Floyd, representative of Coors Electronic Package Company. A normal charge for the furnace is approximately 12 pounds.

### RESULTS SUMMARY

SYSTEM COORS ELECTRONIC PACKAGE CORPORATION  
CPF EXHAUST

TEST DATE AUGUST 26, 1993

<u>PARAMETER</u>	<u>RUN #1</u>	<u>RUN #2</u>	<u>RUN #3</u>	<u>AVERAGE</u>
Qs, FLOW, ACFM	532.8	507.1	460.7	500.2
Qs dry, FLOW SCFM	502.4	465.6	417.2	461.7
MOISTURE, %M	2.05	2.41	2.83	2.43
Vm std, CUBIC FT.	33.29	32.86	32.68	
VOC, PPM CARBON	3.16	3.02	26.62	10.93
VOC, LBS/HR AS CARBON	0.0031	0.0029	0.0228	0.0096
ALLOWABLE, LBS/HR				1.54

## RESULTS, CONCLUSIONS AND COMMENTS

A summary of some pertinent results appear in the preceding RESULTS SUMMARY. For additional information, please consult the CALCULATIONS and DATA SHEETS sections of this report.

Results showed the VOC emissions to be much less than the allowable of 1.54 lbs/hr. Near the end of the third run, a spike occurred. Although the episode was continuing at the end of testing, emissions had already peaked. It was agreed that testing would remain as planned and was limited to the three one hour runs. The highest emission during the testing was 0.07 lbs/hr, so it is highly doubtful that any extension in testing would have created any excursions above the allowable.

## SAMPLING AND ANALYTICAL PROCEDURES

The following test methods were utilized and approved prior to testing as part of the pre-test protocol and agreement. One variation was the use of EPA method 1 instead of 1a. The reason for stipulating EPA method 1a originally was based upon the assumption that the exhaust diameter was eight inches. Once on site, it was measured and found to be twelve inches. Therefore, EPA method 1 is applicable.

### TEST METHODS

#### I. METHODS AND APPLICABILITY

##### A. Method 1 – Sample and Velocity Traverses for Stationary Sources

###### PRINCIPLE AND APPLICABILITY

a. Principle. To aid in the representative measurement of pollutant emissions and/or total volumetric flow rate from a stationary source, a measurement site where the effluent stream is flowing in a known direction is selected, and the cross-section of the stack is divided into a number of equal areas. A traverse point is then located within each of these equal areas.

b. Applicability. This method is applicable to flowing gas streams in ducts, stacks, and flues. The method cannot be used when: (1) flow is cyclonic or swirling (see Section 2.4), (2) a stack is smaller than about 0.30 meter (12 in.) in diameter, or 0.071 m<sup>2</sup> (113 in.<sup>2</sup>) in cross-sectional area, or (3) the measurement site is less than two stack or duct diameters downstream or less than a half diameter upstream from a flow disturbance.

The requirements of this method must be considered before construction of a new facility from which emissions will be measured; failure to do so may require subsequent alterations to the stack or deviation from the standard procedure. Cases involving variants are subject to approval by the Administrator, U.S. Environmental Protection Agency.



**B. Method 2 – Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)**

**PRINCIPLE AND APPLICABILITY**

a. Principle. The average gas velocity in a stack is determined from the gas density and from measurement of the average velocity head with a Type S (Stausscheibe or reverse type) pitot tube.

b. Applicability. This method is applicable for measurement of the average velocity of a gas stream and for quantifying gas flow.

**C. Method 4 – Determination of Moisture Content in Stack Gases**

**PRINCIPLE AND APPLICABILITY**

a. Principle. A gas sample is extracted at a constant rate from the source; moisture is removed from the sample stream and determined either volumetrically or gravimetrically.

b. Applicability. This method is applicable for determining the moisture content of stack gas.

b.1 Two procedures are given. The first is a reference method, for accurate determinations of moisture content (such as are needed to calculate emission data). The second is an approximation method, which provides estimates of percent moisture to aid in setting isokinetic sampling rates prior to a pollutant emission measurement run.

b.2 The reference method is often conducted simultaneously with a pollutant emission measurement run; when it is, calculation of percent isokinetic, pollutant emission rate, etc., for the run shall be based upon the results of the reference method or its equivalent. The reference method was employed for this source.

**D. METHOD 25A- Determination of Total Gaseous Organic Concentration Using a Flame Ionization Detector.**

**APPLICABILITY AND PRINCIPLE**

a. **Applicability.** This method applies to the measurement of total gaseous organic concentration of vapors consisting primarily of alkanes, alkenes, and/or arenes (aromatic hydrocarbons). The concentration is expressed in terms of propane (or other appropriate organic calibration gas) or in terms of carbon.

b. **Principle.** A gas sample is extracted from the source through a heated sample line, if necessary, and glass fiber filter to a flame ionization analyzer (FIA). Results are reported as volume concentration equivalents of the calibration gas or as carbon equivalents.

Heated sampling line was connected to the stainless steel sampling probe and the analyzer. The analyzer was calibrated prior to testing with EPA protocol 1 gases: 16.5 ppm, 30.6 ppm, 64.1 ppm, and 86.6 ppm, all propane mixtures in air.

**II. APPLICATION OF METHODS TO COORS ELECTRONIC PACKAGE CO.**

The test team from Analytical Testing Consultants consisted of Richard Westbrook, test team leader, John Welch, Sr. Technician, and James Whitlock, technician. After setup and preliminary data collection (upstreams, downstreams, cyclonic flow checks), the heated Ratfish (Model #RSCA 55, serial # 414291) flame ionization detector was calibrated with the above specified gases. Preliminary calibrations were acceptable and monitoring began. The protocol sheets for these gases are included in the calibration data section of this report.

Flows and moisture runs were conducted concurrently with the collection of CEM data. The moisture runs were one hour in length and indicated a stack moisture of approximately 2%. The flow data collected at the beginning of each run was utilized to calculate emissions. Flow variance among the three runs was within 14%.

## REFERENCES

1. CODE OF FEDERAL REGULATIONS, Title 40, Part 60, Appendix A, July 1, 1992.

## CALCULATIONS

Flow Rate Calculation  
Moisture Calculation  
VOC Calculations  
Nomenclature  
Calculation Formulae

FLOW RATE AND MOISTURE CALCULATION

DATA/CALCULATION	RUN #1	RUN #2	RUN #3	AVERAGE
DATE	8/26/93	8/26/93	8/26/93	
AVG DH (IN H2O)	1.00	1.00	1.00	
P ATM (IN HG)	29.74	29.74	29.74	
PM (IN HG)	29.81	29.81	29.81	
PS (GUAGE)	0	0	0	
PS (IN HG)	29.740	29.740	29.740	
tM (DEG F)	87.83	105.17	110.17	
TM (DEG R)	547.8333	565.1667	570.1667	
VM (FT3)	34.66	35.3	35.42	
VM STD (FT3)	33.28632	32.86124	32.68379	
VLQ (ML)	14.8	17.2	20.2	
VV STD (FT3)	0.697341	0.810424	0.951776	
V STD (FT3)	33.98366	33.67166	33.63557	
%M	2.052	2.407	2.830	2.430
MD	0.979	0.976	0.972	
MWD	28.840	28.840	28.840	
M	28.618	28.579	28.533	
tS (DEG F)	86.50	99.17	104.50	96.72
TS (DEG R)	546.5	559.1667	564.5	556.7222
SUM SQRT DP	2.358	2.217	2.003	
N DP	12	12	12	
AVG SQRT DP	0.197	0.185	0.167	
CP	0.84	0.84	0.84	
VS (FT/SEC)	11.307	10.761	9.775	10.614
DS (IN)	12	12	12	
AS (FT2)	0.7854	0.7854	0.7854	
QS, ACFM	532.8113	507.0982	460.6504	500.1867
Q STD (FT3/MIN)	512.9429	477.1298	429.332	473.1349
Q STD DRY, SCFM	502.4174	465.646	417.1833	461.7489
%CO2	0.00	0.00	0.00	0.00
%O2	21.00	21.00	21.00	21.00
%CO	0.00	0.00	0.00	0.00
%N2	79.00	79.00	79.00	79.00

MOISTURE DATA

RUN #1

	1ST IMP.	2ND IMP.	3RD IMP.	4TH IMP.	TOTALS
BEGINNING	100	100	0	300	
ENDING	104	100	0	310.8	
NET	4	0	0	10.8	14.8

RUN #2

	1ST IMP.	2ND IMP.	3RD IMP.	4TH IMP.	TOTALS
BEGINNING	100	100	0	300	
ENDING	100	100	2	315.2	
NET	0	0	2	15.2	17.2

RUN #3

	1ST IMP.	2ND IMP.	3RD IMP.	4TH IMP.	TOTALS
BEGINNING	100	100	0	300	
ENDING	100	102	1	317.2	
NET	0	2	1	17.2	20.2



CALCULATIONS

DATE COORS ELECTRONIC PACKAGE CORPORATION

SOURCE GOLDEN ASTRO FURNACE

RUN # TWO

POINT #	Tm	Ts	DP	SQRT DP	dH	% O2	% CO2
A1	102	91	0.03	0.173205	1	21	0
A2	102	101	0.035	0.187083			
A3	101	101	0.035	0.187083			
A4	102	96	0.035	0.187083			
A5	103	100	0.035	0.187083			
A6	104	101	0.035	0.187083			
A7				0			
A8				0			
A9				0			
A10				0			
A11				0			
A12				0			
B1	106	97	0.03	0.173205	1	21	0
B2	107	98	0.035	0.187083			
B3	107	100	0.035	0.187083			
B4	108	102	0.035	0.187083			
B5	110	102	0.035	0.187083			
B6	110	101	0.035	0.187083			
B7				0			
B8				0			
B9				0			
B10				0			
B11				0			
B12				0			
	105.1667	99.16667		2.217239			
							% N2 (BY DIFFERENCE)
							79





TOTAL VOC EMISSIONS MEASUREMENT  
 INSTRUMENTAL ANALYZER METHOD

COORS ELECTRONIC PACKAGING CORPORATION  
 CHATTANOOGA, TENNESSEE  
 GOLDEN ASTRO FURNACE EXHAUST

DATE 8/26/93  
 K= 1.08

RUN #1

TIME	CHART	PPM AS C3H8	PPM C	MG/M3 AS C	ACFM	LBS/HR AS C
900	0.9	0.972	2.92	1.45	532.8	0.0029
905	0.9	0.972	2.92	1.45	532.8	0.0029
910	0.9	0.972	2.92	1.45	532.8	0.0029
915	1	1.08	3.24	1.61	532.8	0.0032
920	1	1.08	3.24	1.61	532.8	0.0032
925	1	1.08	3.24	1.61	532.8	0.0032
930	1	1.08	3.24	1.61	532.8	0.0032
935	1	1.08	3.24	1.61	532.8	0.0032
940	1	1.08	3.24	1.61	532.8	0.0032
945	1	1.08	3.24	1.61	532.8	0.0032
950	1	1.08	3.24	1.61	532.8	0.0032
955	1	1.08	3.24	1.61	532.8	0.0032
AVERAGES			3.16	1.57		0.0031

RUN #2

TIME	CHART	PPM AS C3H8	PPM C	MG/M3 AS C	ACFM	LBS/HR AS C
1013	0.8	0.864	2.59	1.29	507.1	0.0024
1018	0.8	0.864	2.59	1.29	507.1	0.0024
1023	0.8	0.864	2.59	1.29	507.1	0.0024
1028	0.9	0.972	2.92	1.45	507.1	0.0028
1033	0.9	0.972	2.92	1.45	507.1	0.0028
1038	0.9	0.972	2.92	1.45	507.1	0.0028
1043	0.9	0.972	2.92	1.45	507.1	0.0028
1048	1	1.08	3.24	1.61	507.1	0.0031
1053	1	1.08	3.24	1.61	507.1	0.0031
1058	1	1.08	3.24	1.61	507.1	0.0031
1103	1.1	1.188	3.56	1.77	507.1	0.0034
1108	1.1	1.188	3.56	1.77	507.1	0.0034
AVERAGES			3.02	1.50		0.0029

TOTAL VOC EMISSIONS MEASUREMENT  
 INSTRUMENTAL ANALYZER METHOD

COORS ELECTRONIC PACKAGING CORPORATION  
 CHATTANOOGA, TENNESSEE  
 GOLDEN ASTRO FURNACE EXHAUST

DATE 8/26/93  
 K= 1.08

RUN #3

TIME	CHART	PPM AS C3H8	PPM C	MG/M3 AS C	ACFM	LBS/HR AS C
1125	1	1.08	3.24	1.61	460.7	0.0028
1130	1	1.08	3.24	1.61	460.7	0.0028
1135	1.1	1.188	3.56	1.77	460.7	0.0031
1140	1.3	1.404	4.21	2.09	460.7	0.0036
1145	1.8	1.944	5.83	2.90	460.7	0.0050
1150	2.1	2.268	6.80	3.38	460.7	0.0058
1155	26	28.08	84.24	41.85	460.7	0.0723
1200	22	23.76	71.28	35.41	460.7	0.0612
1205	14.5	15.66	46.98	23.34	460.7	0.0403
1210	10.8	11.664	34.99	17.38	460.7	0.0300
1215	9.2	9.936	29.81	14.81	460.7	0.0256
1220	7.8	8.424	25.27	12.56	460.7	0.0217
AVERAGES			26.62	13.23		0.0228

## NOMENCLATURE

AN	(square inches), Cross sectional area of nozzle
AS	(square feet), Cross sectional area of stack
CP	Pitot tube calibration coefficient
% EA	Percent Excess Air
F	(scfd/10 <sup>6</sup> BTU), F factor
DH	(inches of water) Average orifice meter reading
HI	(million BTU/hr), Heat Input Rate
% I	Percent Isokineticity
M	(lb/lb mole), Molecular Weight of wet gas
% M	Percent Moisture
MD	Mole fraction of dry gas
MWD	(lb/lb mole) molecular weight of dry gas
N DP	Number of sample points
P ATM	(in Hg), Local atmospheric pressure
PM	(in Hg), Absolute pressure in dry gas meter
PS	(in Hg), Absolute stack pressure
PS GAUGE	(inches of water), Measured static stack pressure gauge
P STD	(29.92 in Hg), Standard pressure

PMRA (lb/hr), Pollutant mass rate based on ratio of areas  
PMR AVG. (lb/hr), Average pollutant mass rate  
PMRC (lb/hr), Pollutant mass rate based on concentration  
PMRU (lb/million BTU), Specific emission rate  
DP (inches of water), Velocity pressure  
QS (cubic feet/min.), Actual stack volume flow rate  
Q STD (cubic feet/min.), Stack volume flow rate at standard conditions  
TM (degrees R), Average dry gas meter temperature  
TS (degrees R), Average stack temperature  
T STD (528 degrees R), Standard temperature  
VLQ (ml), Liquid volume  
VM (cubic feet), Sample volume measured by dry gas meter  
VM STD (cubic feet), Sample volume at standard conditions  
VS (ft/sec), stack velocity  
VV STD (cubic feet), Volume of water vapor collected, corrected to standard conditions  
WT (gm), Total weight of particulate collected  
TIME (MIN.)Duration of test

## CALCULATION FORMULAE

1. Absolute pressure in dry gas meter

$$PM = P \text{ ATM} + DH/13.6$$

2. Absolute Stack Pressure

$$PS = P \text{ ATM} + PS \text{ gauge}/13.6$$

3. Sample volume at standard conditions

$$VM \text{ STD} = (VM) (T \text{ STD}/TM) (PM/P \text{ STD})$$

4. Volume of water collected, corrected to standard conditions

$$VV \text{ STD} = (.00267) (VLQ) (T \text{ STD}/P \text{ STD})$$

5. Total sample volume at standard conditions

$$V \text{ STD} = VM \text{ STD} + VV \text{ STD}$$

6. Percent moisture in stack gas

$$\%M = (100) (VV \text{ STD})/V \text{ STD}$$

7. Mole Fraction of dry gas

$$MD = (100 - \%M)/100$$

8. Molecular weight of the wet gas

$$M = (MWD) (MD) + 18(1 - MD)$$

9. Stack velocity

$$VS = (85.48)(CP)((TS)/(PS)(M))^{1/2}((\text{Sum DP})^{1/2} N \text{ DP})$$

10. Stack volume flow rate

$$QS = (60)(VS)(AS)$$

11. Stack volume flow rate, standard conditions including moisture

$$Q \text{ STD} = (T \text{ STD}/P \text{ STD})(PS/TS)(QS)$$

12. Stack volume flow rate standard conditions dry

$$Q \text{ STD DRY} = (Q \text{ STD})(1 - \%M)$$

13. Pollutant mass rate, concentration basis

$$PMRC = (.1323)(WT)(Q \text{ STD})/V \text{ STD}$$

14. Pollutant mass rate ratio of areas basis

$$PMRA = (.1323)(WT)(AS)(144)/(Time)(AN)$$

15. Percent Isokineticity

$$\%I = (100) (PMRA)/PMRC$$

16. Average pollutant mass rate

$$PMR \text{ AVG} = (PMRA + PMRC)/2$$

17. % EXCESS AIR

$$\%EA = (100) (\%oxygen - (.5)(\%carbon \text{ monoxide}) \\ (.264)(\%nitrogen) - \%oxygen + (.5) (\%carbon \text{ monoxide}))$$

18. Heat input rate

$$HI = ((.6) (Q \text{ STD DRY})/F)((20.9 - \%oxygen)/20.9)$$

19. Specific emission rate

$$PMRU = PMR \text{ AVG}/HI$$

## DATA SHEETS

Moisture Run Data Sheets  
Impinger Data Sheet  
Flow Traverse Data Sheets  
Orsat Data  
System Calibration Error Data  
Source Survey  
Equal Area Determinations  
Process Temperature Tracking  
System Sketch  
Calibration Information  
Strip Chart



# ANALYTICAL TESTING CONSULTANTS, INC.

KANNAPOLIS, N.C.

ATLANTA, GEORGIA

## MODULE SAMPLING DATA SHEET

CLIENT COORS ELECTRONIC DATE 8/26/93  
 LOCATION CHATTANOOGA, TN SOURCE FURNACE  
 TEST TEAM JW, RW, JW RUN # 1

Pbar 29.74

LEAK RATES

SETUP

Ps ∅

start .017 @ 15"

g \_\_\_\_\_

Method 4

end .004 @ 5"

Tm \_\_\_\_\_

MODULE A.T.C# 1

PITOT:

% H<sub>2</sub>O \_\_\_\_\_

FILTER —

start

NOZZLE \_\_\_\_\_

NOZZLE —

A — B —

C \_\_\_\_\_

PITOT —

end

T<sub>s</sub> \_\_\_\_\_

A — B —

THEORETICAL PITOT

START TIME 9:00AM

FINISH TIME 10:00AM

COMMENTS:

TIME	PT.	LINE VAC	T <sub>M</sub> F <sup>o</sup>	T <sub>S</sub> F <sup>o</sup>	V <sub>P</sub> H <sub>2</sub> O	P <sub>M</sub> H <sub>2</sub> O	V <sub>M</sub>	FT <sup>3</sup>	REMARKS	
00	-	1.0	80	75	-	1.0	093.51			
05	-	1.0	80	75	-	1.0	096.23			
10	-	1.0	82	78	-	1.0	099.10			
15	-	1.0	84	74	-	1.0	101.98			
20	-	1.0	86	83	-	1.0	104.86			
25	-	1.0	88	92	-	1.0	107.77			
30	-	1.0	91	91	-	1.0	110.66			
35	-	1.0	93	93	-	1.0	113.58			
40	-	1.0	93	93	-	1.0	116.48			
45	-	1.0	91	93	-	1.0	119.32			
50	-	1.0	93	95	-	1.0	122.33			
55	-	1.0	93	96	-	1.0	-			
60	SHOT	DOWN	END RUN				-	128.17		
TOT/ AVG			87.8	86.5	2.3581	1	34.66			

# ANALYTICAL TESTING CONSULTANTS, INC.

KANNAPOLIS, N.C.

ATLANTA, GEORGIA

## MODULE SAMPLING DATA SHEET

CLIENT COORS ELECTRONIC  
 LOCATION CHATTANOOGA, TN  
 TEST TEAM RW, JW, JW

DATE 8/26/93  
 SOURCE FURNACE  
 RUN # 2

Pbar 29.74

**LEAK RATES**

**SETUP**

Ps Ø

start .012 @ 8"

g \_\_\_\_\_

Method 4

end .008 @ 5"

Tm \_\_\_\_\_

MODULE A.T.L.#1

**PITOT:**

% H<sub>2</sub>O \_\_\_\_\_

FILTER -

start

NOZZLE \_\_\_\_\_

NOZZLE -

A - B -

C \_\_\_\_\_

PITOT -

end

T<sub>s</sub> \_\_\_\_\_

A - B -

THEORETICAL PITOT

START TIME 10:12AM

FINISH TIME 11:12AM

COMMENTS:

TIME	PT.	LINE VAC	T <sub>M</sub> F <sup>o</sup>	T <sub>S</sub> F <sup>o</sup>	V <sub>P</sub> H <sub>2</sub> O	P <sub>M</sub> H <sub>2</sub> O	V <sub>M</sub>	FT <sup>3</sup>	REMARKS
00	-	1.0	102	91	-	1.0	128.41		
05	-	1.0	102	101	-	1.0	131.34		
10	-	1.0	101	101	-	1.0	134.28		
15	-	1.0	102	96	-	1.0	137.21		
20	-	1.0	103	100	-	1.0	140.14		
25	-	1.0	104	101	-	1.0	143.09		
30	-	1.0	106	97	-	1.0	146.02		
35	-	1.0	107	98	-	1.0	148.97		
40	-	1.0	107	100	-	1.0	151.90		
45	-	1.0	108	102	-	1.0	154.85		
50	-	1.0	110	102	-	1.0	157.90		
55	-	1.0	110	101	-	1.0	160.75		
60	SHOT	DOWN	END	RUN	-	-	163.71		
TOT/ AVG			105.2	99.2	2.2172	1	35.3		

# ANALYTICAL TESTING CONSULTANTS, INC.

KANNAPOLIS, N.C.

ATLANTA, GEORGIA

## MODULE SAMPLING DATA SHEET

CLIENT COORS ELECTRONIC DATE 8/26/93  
 LOCATION CHATTANOOGA, TENN SOURCE FURNACE  
 TEST TEAM RW, JW, JW RUN # 3

Pbar <u>29.74</u>	LEAK RATES	SETUP
Ps <u>∅</u>	start <u>.010 @ 15"</u>	g _____
Method <u>4</u>	end <u>.004 @ 5"</u>	Tm _____
MODULE <u>A.T.C #1</u>	PITOT:	% H <sub>2</sub> O _____
FILTER <u>-</u>	start	NOZZLE _____
NOZZLE <u>-</u>	A <u>-</u> B <u>-</u>	C _____
PITOT <u>-</u>	end	T <sub>s</sub> _____
	A <u>-</u> B <u>-</u>	THEORETICAL PITOT _____
START TIME <u>11:25am</u>	FINISH TIME <u>12:25pm</u>	
COMMENTS:		

TIME	PT.	LINE VAC	T <sub>M</sub> F <sup>o</sup>	T <sub>B</sub> F <sup>o</sup>	V <sub>P</sub> H <sub>2</sub> O	P <sub>M</sub> H <sub>2</sub> O	V <sub>M</sub> FT <sup>3</sup>	REMARKS
00	-	1.0	108	90	-	1.0	164.06	
05	-	1.0	109	81	-	1.0	167.02	
10	-	1.0	110	79	-	1.0	169.97	
15	-	1.0	110	81	-	1.0	172.93	
20	-	1.0	110	81	-	1.0	175.88	
25	-	1.0	111	83	-	1.0	178.84	
30	-	1.0	111	140	-	1.0	181.79	
35	-	1.0	111	135	-	1.0	184.75	
40	-	1.0	110	124	-	1.0	187.70	
45	-	1.0	110	125	-	1.0	190.64	
50	-	1.0	111	122	-	1.0	193.59	
55	-	1.0	111	113	-	1.0	196.54	
60	SHUT	Down	END	Run	-	-	199.48	
TOT/ AVG			110.2	104.5	2.003	1	35.42	













**ANALYTICAL TESTING CONSULTANTS, INC.**  
**GAS ANALYSIS DATA FOR EPA 3A**

DATE: 8/26/93

ANALYST: JW

CLIENT: COORS ELECTRONIC

SOURCE: FURNACE

**CALIBRATION DATA**

INSTRUMENTS

FYRITE

CAL GAS	OXYGEN %	INST. READING
HI PURITY N <sub>2</sub>	0%	<u>          </u>
AIR	20.95%	<u>20.9%</u>
11.0% O <sub>2</sub>	11.0%	<u>          </u>

**CARBON DIOXIDE BY FYRITE**

**SAMPLE DATA**

RUN 1,2,3 SAMPLE TYPE:  GRAB     INTEGRATED     CONTINUOUS

POINT	CO <sub>2</sub> %	O <sub>2</sub> %	N <sub>2</sub> %	OTHER % PPM	REMARK
1	∅	21.0			
2	∅	21.0			
3	∅	21.0			
4	∅	21.0			
5	∅	21.0			
6	∅	21.0			
7	∅	21.0			
8	∅	21.0			
9	∅	21.0			
10	∅	21.0			
11	∅	21.0			
12	∅	21.0			
AVERAGE					

## SYSTEM CALIBRATION ERROR DATA

CLIENT Cours Eled. Pack. DATE 8/26/93  
 LOCATION Chattanooga, TN CAL GAS Propane in N<sub>2</sub>  
 SPAN VALUE \_\_\_\_\_ START TIME \_\_\_\_\_  
 METHOD 25A ANALYZER Raf. 4.4 RS55CA

### INITIAL CALIBRATION

RANGE	CONCENTRATION	PREDICTED CHART	ACTUAL CHART	% ERROR
ZERO	0	0	0	
LOW	16.5	15.2	14.9	1.97
MID	30.6	28.3	27.9	1.41
HIGH	64.1	59.2	58.4	1.37
SPAN	86.6	80.0	80.0	

$K_2 = \text{ACTUAL CHART OF SPAN} / \text{SPAN CONCENTRATION} = \text{PPM OR \% / UNIT}$

$\% \text{ ERROR} = (\text{PREDICTED} - \text{ACTUAL}) / \text{PREDICTED} \times 100$

\*PREDICTED MINUS ACTUAL SHOULD BE TAKEN AS ABSOLUTE VALUE!

### HOURLY SPAN AND ZERO CHECKS

TIME	ZERO			MID		
	PREDICTED	ACTUAL	% ERROR	PREDICTED	ACTUAL	% ERROR
1:00	0	0.5	0.5	28.3	28.0	0.3
2:00	0	0.5	0.5	28.3	28.0	0.3
3:00	0	0.9	0.9	28.3	28.8	0.5
	<del>0</del>			<del>28.3</del>		
FINAL						

ALLOWABLE INITIAL CALIBRATION ERROR = +5%

ALLOWABLE HOURLY CALIBRATION ERROR AND DRIFT = +3%

# ANALYTICAL TESTING CONSULTANTS

## SOURCE SURVEY AND DESCRIPTION

SYSTEM TYPE:        BOILER   ✓   PROCESS        OTHER

NARRATIVE DESCRIPTION: ASTRO

MODEL# CPF-2048-M5

SERIAL# F8608065

ceramic curing Furnace - Batch loading, ceramic plates for computer chips; furnace is purged w/ H<sub>2</sub>, N<sub>2</sub> gas @ 50 CFH. Exhaust is flared by igniters

PURPOSE OF TESTING:   ✓   COMPLIANCE        EVALUATION

PROCESS RATE OR CAPACITY: 36 ~~hrs~~ per batch (ABNORMAL) DETERMINED BY: PLANT PERSONNEL

CONTROL EQUIPMENT:        SCRUBBER        ESP        BAGHOUSE  
  ✓   OTHER HYDROGEN FLARE

CONTROL EQUIPMENT OPERATING PARAMETERS: PRESSURE DROP        N/A  
OTHER       

### SAMPLING LOCATION DATA:

DISTANCE DOWNSTREAM FROM FLOW DISTURBANCE:       

NATURE OF DISTURBANCE: BEND, FAN, EXPANSION, BYPASS, DUCT,  
OTHER 98" 8 DIAMETERS

DISTANCE UPSTREAM FROM FLOW DISTURBANCE:       


NATURE OF DISTURBANCE: STACK EXHAUST, FAN, EXPANSION, DUCT,  
OTHER 24" 2 DIAMETERS

INDIVIDUAL STACK   ✓   COMMON STACK       

STACK DIAMETER OR DIMENSIONS:        12"

NUMBER OF PORTS:   2   POINTS PER PORT:   6  

SKETCH:



ESTIMATED TEMPERATURE: AMBIENT ESTIMATED MOISTURE: 1-2%  
GAS COMPOSITION BY: FYRITE, OXYGEN METER, INSTRUMENTAL,  
OTHER       

### LABORATORY:

SAMPLE RECOVERY: ATC LABORATORY   ✓   CLEAN FIELD AREA         
ATC VAN        OTHER       

SAMPLE SHIPMENT:   ✓   ATC VAN        OTHER       

SAMPLE ANALYSIS:   ✓   ATC        OTHER       

FILTER MATERIAL:        GELMAN A/E        WHATMAN 934AH        OTHER


ANALYTICAL TESTING CONSULTANTS, INC.

Customer COORS ELECTRONIC Date 8/26/93


Location CHATTANOOGA, TN Data by JW


Checked by JW


Description EQUAL AREA CALCULATIONS  
ROUND DUCT - SIX POINT TRAVERSE/DIAMETER



Stack I.D. = 12 In.		
Point No.	% of Diameter	Distance (Inches)
1	4.4	0.53
2	14.7	1.76
3	29.5	3.54
4	70.6	8.47
5	85.3	10.24
6	95.6	11.47







Typical gas flow diagram for the CPF system.

## ANALYTICAL TESTING CONSULTANTS, INC

BAROMETER #1 CALIBRATION

DATE/TIME	STATION PRES.	BAR. READING	ADJUSTMENT	INIT
7/10/92	29.41	29.41	0	DF
8/25/92	29.80	29.83	0.03	JW
9/10/92	29.98	29.98	0	RNW
10/21/92	30.11	30.11	0	CDM
11/19/92	29.17	29.16	0.01	SM
12/4/92	29.43	29.43	0	WKP
1/12/93	29.39	29.46	0.07	SM
2/9/93	29.47	29.47	0	JW
3/5/93	29.77	29.79	0.02	SM
4/5/93	29.38	29.43	0.05	JW
5/14/93	29.75	29.75	0	KP
6/22/93	29.98	29.98	0	SM
7/10/93	29.46	29.51	0.05	SM



PRIMARY MODULE CALIBRATION CALCULATION

DATE 6/25/93  
 P BAR 29.98  
 MODULE ID ATC 1  
 BY MEADOWS

ORIFICE	Vw	Vd	Tw	Td	TIME	D H@	Y
0.5	4.17	4.18	80	75	10	1.65714	0.98716
1	5.88	5.87	80	76	10	1.663779	0.991851
1.5	7.23	7.25	80	77	10	1.647614	0.988066
2	8.32	8.31	80	78	10	1.655832	0.992626
3	10.14	10.18	80	79	10	1.669059	0.986964
						1.658685	0.989333

POSTTEST MODULE CALIBRATION CALCULATION

DATE 8/30/93  
 P BAR 29.87  
 MODULE ID ATC 1  
 BY WELCH

ORIFICE	Vw	Vd	Tw	Td	TIME	D HQ	Y
1.5	7.29	7.26	84	84	10	1.629518	1.000438
1.5	7.29	7.3	84	86	10	1.623549	0.998614
1.5	7.29	7.31	84	87	10	1.620581	0.999075
						1.624549	0.999376

TYPE "S" PITOT TUBE INSPECTION DATA FORM

PITOT TUBE I.D.                    23                    DATE                    6/7/93  
 PITOT TUBE ASSEMBLY LEVEL?                    XX    YES                    NO  
 PITOT TUBE OPENINGS DAMAGED?                    YES (EXPLAIN BELOW) XX NO

CRITICAL ALIGNMENT MEASUREMENTS

MEASUREMENT	ALPHA <10	BETA <5	GAMMA	THETA	A	Z MUST BE <0.125	W MUST BE <0.0313
#1	0	0	0	0	1	0	0
#2	0	0	0	0	1	0	0

Pa =                    0.55                    Pb=                    0.55

Dt =                    0.375

COMMENTS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

CALIBRATION REQUIRED?                    YES    XX NO

Alpha = left to right levelness of the pitot tube openings  
 Beta = front to back pitch of the pitot tube openings

STACK TEMPERATURE SENSOR CALIBRATION DATA FORM

DATE 6/9/93 THERMOCOUPLE NO. 23  
 AMBIENT TEMP., F 81 BAROMETRIC PRESS., IN. Hg 29.84  
 CALIBRATOR WELCH REFERENCE THERMOMETER MERCURY-IN-GLASS

REFERENCE POINT NO.	SOURCE* (SPECIFY)	REFERENCE TEMP. F	THERMOCOUPLE POTENTIOMETER TEMPERATURE, F	TEMPERATURE DIFFERENCE %**
1	AMBIENT	81	81	0.000
2	REFRIGERATOR	37	37.5	0.101
3	THELCO OVEN	151	151	0.000
4	THELCO OVEN	196	197	0.153
5	THELCO OVEN	224	223	0.146
6	THELCO OVEN	258	257	0.139
7	THELCO OVEN	281	281	0.000
8	THELCO OVEN	314	312	0.259

\* = TYPE OF CALIBRATION SYSTEM USED

\*\* =  $[(\text{REF TEMP., C}+273) - (\text{TEST TEMP., C}+273)] / \text{REF TEMP., C}+273 \times 100 < 1.5\%$

NATIONAL SPECIALTY GASES  
630 UNITED DRIVE  
DURHAM, NC 27713  
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-25899 CYLINDER #:CC77880 CYL. PRESSURE:2000PSIG

EXPIRATION DATE: 8-6-96 LAST ANALYSIS DATE:8-6-93

CUSTOMER:NATIONAL WELDERS P.O.# 67393  
SALISBURY, NC METHOD: EPA PROTOCOL # 13.0.4.G-1

STANDARD:

SRM #:2643A

CYL #:SX20245

CONC.:99.1PPM

INSTRUMENT:

COMPONENT: BECKMAN THC

MODEL #: 400

SERIAL #: 1003052

LAST CAL.: 8-2-93

COMPONENT: PROPANE  
MEAN CONC: 86.6PPM

REPLICATE CONC.  
DATE: 8-6-93 DATE:  
86.6PPM  
86.7PPM  
86.5PPM

COMPONENT:  
MEAN CONC:

REPLICATE CONC.  
DATE: DATE:

COMPONENT:  
MEAN CONC:

REPLICATE CONC.  
DATE: DATE:

BALANCE GAS:AIR

NATIONAL SPECIALTY GASES  
630 UNITED DRIVE  
DURHAM, NC 27713  
(919) 544-3772

CERTIFICATE OF ANALYSIS-EPA PROTOCOL MIXTURES

REFERENCE #: 88-25898 CYLINDER #:CC114291 CYL. PRESSURE:2000PSIG

EXPIRATION DATE: 8-6-96 LAST ANALYSIS DATE:8-6-93

CUSTOMER:NATIONAL WELDERS P.O.# 67393  
SALISBURY, NC METHOD: EPA PROTOCOL # 13.0.4.G-1

STANDARD:

SRM #:2643A

CYL #:SX20245

CONC.:99.1PPM

INSTRUMENT:

COMPONENT: BECKMAN THC

MODEL #: 400

SERIAL #: 1003052

LAST CAL.: 8-2-93

COMPONENT: PROPANE  
MEAN CONC: 64.1PPM

REPLICATE CONC.  
DATE: 8-6-93 DATE:  
64.0PPM  
64.1PPM  
64.2PPM

COMPONENT:  
MEAN CONC:

REPLICATE CONC.  
DATE: DATE:

COMPONENT:  
MEAN CONC:

REPLICATE CONC.  
DATE: DATE:

BALANCE GAS:AIR

4:30 P.M.

100 - 0.000000

80 UNITS

$$K_2 = 11.08$$

Richard  
Wright  
Operator


Cover Electronics Packaging

Chattanooga, TN

8/26/93

Chart Speed 30 cm/Hr.

60 50 40 30 20 10 0



29

1

8

11

11

10

1

11:25

START Run #3 11:25 AM

30.6 PPM SPAN Gas

11:50

11:50

11:45

11:40

11:35

11:30

11:25



Coors  
Electronic  
Package  
Co.  
8/26/83  
RNV

30.6 PM Span Bars

2:00

12:25 PM

END Rant#3

12:25

12:20

12:15

12:10

12:05

12:00

(1.9)

(2.0)

(10.8)

(5.11)

(2.8)

(2.6)

