

**ATP** – Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 46219

(317) 345-1720 FAX (317) 351-0411

---

**REPORT ON  
CO, NO<sub>x</sub>, SO<sub>2</sub> & VOC EMISSIONS TESTING**


Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**PPFF Baghouse**  
*on May 19, 2004*

**RECEIVED**  
JUL 06 2004  
State of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Carlos Brown, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
2.	<b>RESULTS</b>	
	PPFF – CO, NO <sub>x</sub> , SO <sub>2</sub> & VOC EMISSIONS	2-1
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA SUMMARIES	B
	FIELD DATA	C
	CHAIN OF CUSTODY	D
	CALIBRATION DATA	E
	SUBMITTED PROTOCOL	F
	PRODUCTION DATA	G

## 1-1 PROJECT OVERVIEW

---

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling at the PPF Baghouse Inlet Duct that controls emissions from EAF 1 and 2, and the AOD. The sampling was performed in Crawfordsville, Indiana on May 19, 2004. The objective of the testing was to determine compliance with permit requirements for the pollutants listed below. The following personnel were involved with the testing program:

ATP	Andrew Young
ATP	Carlos Brown
ATP	Terry Kauffman
Nucor Steel	Mark Washer
IDEM	Jarrold Fisher

The testing program included flow determination (US EPA Methods 1-2), gas analysis (US EPA Method 3), moisture content (US EPA Method 4), SO<sub>2</sub> emissions (US EPA Method 6C), NO<sub>x</sub> emissions (US EPA Method 7E), CO emissions (US EPA Method 10), and VOC emissions (US EPA Method 25A). Listed below is a summary of the results.

**Test Summary**  
Table 1-1

Pollutant	Emissions (lb/hr)	Permitted Limits (lb/hr)
Carbon Monoxide	✓ 274.29 (lb/hr)	1,004 (lb/hr)
Nitrogen Oxide	72.87 (lb/hr)	175.7 (lb/hr)
Sulfur Dioxide	62.77 (lb/hr)	125.0 (lb/hr)
Volatile Organic Compounds	2.90 (lb/hr)	45.18 (lb/hr)

Pollutant	Emissions (lb/ton)	Permitted Limits (lb/ton)
Carbon Monoxide	✓ 1.029 (lb/ton)	2.0 (lb/ton)
Nitrogen Oxide	✓ 0.280 (lb/ton)	✓ 0.35 (lb/ton)
Sulfur Dioxide	✓ 0.233 (lb/ton)	0.25 (lb/ton)
Volatile Organic Compounds	✓ 0.011 (lb/ton)	0.09 (lb/ton)

**2-1 RESULTS**

**CO, NO<sub>x</sub>, SO<sub>2</sub>, VOC Emissions**  
*PPFF Bughouse Inlet Duct*

Table 2-1

<b>Gas Conditions</b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
T <sub>s</sub>	Stack Temperature	207.9	245.4	230.6	227.9
B <sub>wo</sub>	Moisture (volume %)	1.09	1.11	1.34	1.18
O <sub>2</sub>	Oxygen (dry volume %)	19.0	19.0	19.0	19.0
CO <sub>2</sub>	Carbon Dioxide (dry volume %)	0.0	0.5	1.0	0.5
<b><u>Volumetric Flow Rate</u></b>					
Q <sub>a</sub>	Actual Conditions (acfm)	1,357,580	1,282,895	1,307,762	1,316,079
Q <sub>std</sub>	Standard Conditions (dscfm)	1,067,344	954,822	991,941	1,004,702
<b>CARBON MONOXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	59.50	100.20	29.80	63.17
E <sub>r</sub>	Emission Rate (lbs/hr)	276.88	417.12	128.88	274.29
E	Emission Rate (lbs/ton)	1.1817	1.4473	0.4586	1.0292
<b>NITROGEN OXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	12.37	7.13	10.59	10.03
E <sub>r</sub>	Emission Rate (lbs/hr)	94.58	48.80	75.24	72.87
E	Emission Rate (lbs/ton)	0.4037	0.1693	0.2678	0.2802
<b>SULFUR DIOXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	4.61	7.22	7.12	6.32
E <sub>r</sub>	Emission Rate (lbs/hr)	49.10	68.76	70.45	62.77
E	Emission Rate (lbs/ton)	0.2096	0.2386	0.2507	0.2330
<b>VOLATILE ORGANIC COMPOUNDS</b>					
C <sub>gas</sub>	Emission (PPM)	0.26	0.94	0.38	0.53
E <sub>r</sub>	Emission Rate (lbs/hr)	1.56	5.04	2.11	2.90
E	Emission Rate (lbs/ton)	0.0066	0.0175	0.0075	0.0105

266.0

2.0

269.4

2.76.2

### 3-1 PROCESS DESCRIPTION


---

Nucor steel operates a meltshop, which is comprised of the following process units: Two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD with two (2) continuous casters. Of these, the two EAF units, the AOD, and the two caster units, each is evacuated through the **meltshop baghouse**.

The EAF units melt various grades of scrap metal, scrap substitute, pebbled lime, and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel **from** the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD, and casters are generated from melting, refining, charging, tapping, and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. **All** captured emissions are evacuated through the positive pressure fabric filter (PPFF) **baghouse** for collection.

The testing reported in this document **was performed** at **12** of the 16 EAF (PPFF) **baghouse** compartments.



## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

### Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determining of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Determination of Oxygen and Carbon Dioxide Percentages"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 6C	"Determination of Sulfur Dioxide Emissions from Stationary Sources"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide from Stationary Sources"
Method 25A	"Determination of Volatile Organic Compounds from Stationary Sources"

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

**Sampling Points**  
Table 4-1

<b>Location</b>	<b>Dimensions</b>	<b>Points / Port</b>	<b>Total Points</b>
PPFF Inlet Duct	278" x 176" ID	8	32

---

## **4-2 METHODOLOGY**

---

### **SAMPLE AND VELOCITY TRAVERSE – EPA METHOD 1**

Method 1 was utilized for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction, is selected and divided into a sample grid according to the published percentages of the diameter. A traverse point is then located at each of these percentage points. Sampling or velocity measurement is performed at a site located at least two stack or duct diameters downstream and one-half diameter upstream from a disturbance such as a bend, expansion, contraction, or visible flame.

### **VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT – EPA METHOD 4**

The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **SULFUR DIOXIDE CONCENTRATION – EPA METHOD 6C**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a NDIR or fluorescence analyzer for SO<sub>2</sub> concentration determination. The wet stack gas is "dried" before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **NITROGEN OXIDE CONCENTRATION – EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NO<sub>x</sub> concentration determination. The wet stack gas is "dried" before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **CARBON MONOXIDE CONCENTRATION – EPA METHOD 10**

A continuous gas sample is drawn from the stack and a portion of the sample is conveyed to an NDIR analyzer for carbon monoxide concentration determination. The wet stack gas is "dried" before analysis by a chilled condenser. EPA protocol gases are used to calibrate the instrument as well as run system bias and drift checks.

## **4-2 METHODOLOGY, cont.**

---

### **VOC DETERMINATION – EPA METHOD 25A**

Flue gas is drawn into a flame ionization analyzer (FIA) that determines organic concentrations and generates an output proportional to the gas concentration. The sample line is heated to 250 degrees F to prevent the development of condensation in the sampling apparatus. Gases used for either calibrations, fuel, or combustion air, are contained in compressed gas cylinders and are prepared according to the procedure in EPA Protocol No. 1. Calibration gases consist of Zero Gas with less than 0.1 ppmv, Low-level gas at 25 to 35 percent of span, Mid-level gas at 45 to 55 percent of span and High-level gas at 80 to 90 percent of span. Pre-test instrument calibration checks and post-test drift checks are conducted during the test period to validate sampling accuracy. All calibrations and sample measurements are collected and compiled utilizing an electric data-recording device. The sample average is determined by the integration of the output recorded over the period specified in the applicable regulation.

This method is applicable for the measurement of aromatic hydrocarbons and is expressed in terms of propane or in terms of carbon.

**APPENDIX A**

---

## SAMPLE CALCULATIONS

---

### 1. Volume of water collected (wstd)

$$V_{wstd} = (0.04707)(V_{lc})$$

$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{lc}$	total volume of liquid collected in impingers and silica (ml)
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered at standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{baro} + \frac{\Delta H}{13.6} \right) (\Gamma_d)}{(460 + T_m)}$$

$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
$V_m$	volume of sample gas through dry gas meter at meter conditions (ft <sup>3</sup> )
$P_{baro}$	barometric pressure (in Hg)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
$\Gamma_d$	gas meter correction factor (dimensionless)
$T_m$	average dry gas meter temperature (°F)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	conversion constant, °F to °R

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left( \frac{P_g}{13.6} \right)$$

$P_s$	absolute sample gas pressure (in Hg)
$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

### 4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

5. Moisture content (%)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )

6. Saturated moisture content (%)

$$B_{ws} = \frac{P_v}{P_s}$$

$B_{ws}$	portion of water vapor in gas stream by volume at saturated conditions (%)
$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \left( \frac{CO_2}{100} \right) + M_{O_2} \left( \frac{O_2}{100} \right) + M_{CO+N_2} \left( \frac{CO+N_2}{100} \right)$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$M_{CO_2}$	molecular weight of carbon dioxide (lb/lb-mole)
$M_{O_2}$	molecular weight of oxygen (lb/lb-mole)
$M_{CO+N_2}$	molecular weight of carbon monoxide and nitrogen (lb/lb-mole)
$CO_2$	portion of carbon dioxide in the gas stream by volume (%)
$O_2$	portion of oxygen in the gas stream by volume (%)
$CO+N_2$	portion of carbon monoxide and nitrogen in gas stream by volume (%)
100	conversion factor (%)

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{ws}) + (M_{H_2O})(B_{wo})$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (Wsec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(t_s + 460)}{(M_s)(P_s)}} \right)$$

$V_s$	average sample gas velocity (Wsec)
$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$\Delta P$	average differential pressure in the gas stream (in H <sub>2</sub> O)
$t_s$	average sample gas temperature (°F)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in Hg)
460	conversion constant, °F to °R

10. Total flow of sample gas (acfm)

$$Q_a = (60)(A_s)(V_s)$$

$Q_a$	volumetric flow rate at actual conditions (acfm)
$A_s$	cross-sectional area of sampling location (ft <sup>2</sup> )
$V_s$	average sample gas velocity (ft/sec)
60	conversion factor (seconds/minute)

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a)(P_s)(17.64)(1 - B_{wo})}{(t_s + 460)}$$

$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
$Q_a$	volumetric flow rate at actual conditions (acfm)
$P_s$	absolute sample gas pressure (in Hg)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$t_s$	average sample gas temperature (°F)
17.64	conversion factor (°R/in Hg)
460	conversion constant, °F to °R

12. Gas emission concentration (ppm)

$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

$C_{gas}$	effluent gas concentration (ppm)
$\bar{C}$	average gas concentration indicated by gas analyzer (ppm)
$C_o$	average of initial and final system bias checks for zero gas (ppm)
$C_{ma}$	actual concentration of the upscale gas (ppm)
$C_m$	average of initial and final system bias check for upscale cal gas (ppm)

13. Carbon Monoxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(1.3762 \times 10^7)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at <b>standard</b> conditions (dscfm)
<b>60</b>	conversion factor (seconds/minute)
$1.3762 \times 10^7$	CO conversion factor (ppm to lbs/dscf)

14. Nitrogen Oxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(8.3752 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$8.3752 \times 10^6$	NOx conversion factor (ppm to lbs/dscf)

15. Sulfur Dioxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(6.0151 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$6.0151 \times 10^6$	SO2 conversion factor (ppm to lbs/dscf)

16. VOC emissions, mass emission rate (lbs/hr)

$$VOC_{lb/hr} = \frac{(PPM)(Q_{std})(60)(12)}{(385)(10^6)}$$

$VOC_{lbs/hr}$	mass emission rate (lbs/hr)
PPM	pollutant concentration dry as carbon
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	per minute to per hour conversion
12	molecular weight factor
$385 \times 10^6$	ppm to dry standard cubic feet conversion factor

17. Pollutant emission rate (lbs/ton)

$$E_{lbs/ton} = \frac{(E)}{(P_{tons/hr})}$$

$E_{lbs/ton}$	emission rate (lbs/ton)
E	pollutant emission rate (lbs/hr)
$P_{tons/hr}$	facility production rate (tons/hr)

**APPENDIX B**

---

## GASES - STACK EMISSION SUMMARY

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	PPFF Baghouse
<b>Date:</b>	05/19/2004

<b>Gas Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
CO (ppm)	59.50	100.20	29.80	63.17
<b>CO (lbs/hr)</b>	276.88	417.12	128.88	<b>274.29</b>
<b>CO (lb/ton)</b>	1.1817	1.4473	0.4586	<b>1.0292</b>
NOx (ppm)	12.37	7.13	10.59	10.03
<b>NOx (lbs/hr)</b>	94.58	48.80	75.24	<b>72.87</b>
<b>NOx (lb/ton)</b>	0.4037	0.1693	0.2678	<b>0.2802</b>
SO2 (ppm)	4.61	7.22	7.12	6.32
<b>SO2 (lbs/hr)</b>	49.10	68.76	70.45	<b>62.77</b>
<b>SO2 (lb/ton)</b>	0.2096	0.2386	0.2507	<b>0.2330</b>
VOC (ppm)	0.26	0.94	0.38	0.53
<b>VOC (lbs/hr)</b>	1.56	5.04	2.11	<b>2.90</b>
<b>VOC (lb/ton)</b>	0.0066	0.0175	0.0075	<b>0.0105</b>
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	1,357,580	1,282,895	1,307,762	1,316,079
DSCFM	1,067,344	954,822	991,941	1,004,702
Avg. Stack Temp	207.9	245.4	230.6	227.9
Stack Gas Velocity	66.59	62.93	64.15	64.56
Avg. Velocity Head	1.109	0.941	1.000	1.02
Avg. Sq. Rt of Delta P	1.053	0.970	1.000	1.01
% Moisture of Stack Gas	1.09%	1.11%	1.34%	1.18%
Sample Volume	26.011	22.212	20.855	23.026

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/19/2004
Run Number:	1

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 19  
 Md (g/mol) = 28.76

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 6.1  
 Vw (scf) = 0.28713

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 82.0  
 Vm (ft<sup>3</sup>) = 26.395  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 1.720  
 gamma = 1.002  
 Vm (dscf) = 26.01

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.09%  
 1-Bwo = 98.91%

Molecular Weight of Stack Gas, Ms  
 Ms (g/mol) = 28.64

Area of Stack (enter diameter in inches), As  
 Depth = 176  
 Width = 278  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 339.8  
 As(dia.) (ft<sup>2</sup>) = 339.8

Absolute Pressure, Ps  
 Static (in H2O) = 0.05  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 1.053  
 Ts (F) = 207.9  
 Vs (fps) = 66.59

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 339.78  
 Qs (acfm) = 1,357,580

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscfm) = 1,067,344  
 Qstd (dscfh) = 64,040,632

Pollutant Mass Emission Rate, PMR  
 C (dry corrected) (PPM) = 59.50, 1237, 4.61, 0.26  
 PMR (lb/hr) = 276.88, 94.58, 49.10, 1.56  
 PMR (lb/ton) = 11817, 0.4037, 0.2096, 0.006645  
 CO NOx SO2 YOC

FIELD DATA

Start Time	10:09
Stop Time	11:09

Run 1	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	1.10	1.049		1.720	184	78	78
2	1.40	1.183		1.720	189	81	79
3	1.40	1.183		1.720	186	82	79
4	1.05	1.025		1.720	180	84	80
5	0.74	0.860		1.720	197	86	80
6	0.89	0.943		1.720	194	87	82
7	1.05	1.025		1.720	192	89	83
8	0.94	0.970			181		
9	0.72	0.849			151		
10	0.97	0.985			160		
11	1.15	1.072			156		
12	0.98	0.990			152		
13	0.52	0.721			179		
14	0.83	0.911			187		
15	1.20	1.095			192		
16	1.25	1.118			197		
17	0.82	0.906			192		
18	1.02	1.010			180		
19	1.45	1.204			169		
20	1.40	1.183			165		
21	1.40	1.183			225		
22	1.50	1.225			245		
23	1.60	1.265			250		
24	1.25	1.118			257		
25	1.30	1.140			237		
26	1.65	1.285			262		
27	1.55	1.245			242		
28	1.30	1.140			223		
29	0.78	0.883			268		
30	0.97	0.985	346.325		280		
31	0.97	0.985	319.93		287		
32	0.94	0.970			293		

Avg Δ P	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
1.128	1.053	26.395	1.720	207.9	82.0

Production Rate

Furnace 1	128.8
Furnace 2	56.9
AOD Vessel	48.6
Total tons	234.3
Process Time (min)	60
Tons/hr	234.3



<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	PPFF Baghouse
<b>Date:</b>	05/19/04
<b>Run Number:</b>	3

**FIELD DATA**

Start Time	13:01
Stop Time	13:44

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 1.0  
 %O2 = 19.0  
 Md (g/gmol) = 28.92

Volume of Water Vapor Collected @ STD. COND.. Vw  
 Vlc (mL) = 6  
 Vw (sd) = 0.28242

Volume of Dry Gas Collected @ STD. COND.. Vm  
 Tm (F) = 92.3  
 Vm (ft^3) = 21.562  
 Pb (in Hg) = 30.08  
 delta H (in H2O) = 1.744  
 gamma = 1.002  
 Vm (dscf) = 20.86

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.34%  
 1-Bwo = 98.66%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.77

Area of Stack (enter diameter in inches), As  
 Depth = 176  
 Width = 278  
 diameter (in) = 0  
 No. of Stacks = 1  
 As(L\*W) (ft^2) = 339.8  
 As(dia.) (ft^2) = 339.8

Absolute Pressure, Ps  
 Static (in H2O) = 0.05  
 Ps (in Hg) = 30.08

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 1.000  
 Ts (F) = 230.6  
 Vs (fps) = 64.15

Stack Gas Flowrate, Qs  
 As (ft^2) = 339.8  
 Qs (acfm) = 1,307.762

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscfm) = 991,941  
 Qstd (dscfh) = 59,516,444

Pollutant Mass Emission Rate, PMR  
 C (dry, corrected) (PPM) = 29.80  
 PMR (lb/hr) = 128.8759 75.2381 70.4539 2.11476613  
 PMR (lb/ton) = 0.4586 0.2678 0.2507 8E-03  
 CO NOx SO2 VOC

Run	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	1.15	1.072		1.744	191	91	90
2	1.30	1.140		1.744	197	94	90
3	1.25	1.118		1.744	199	96	91
4	1.10	1.049		1.744	208	93	91
5	0.75	0.866		1.744	185	94	91
6	0.90	0.949		1.744	187	95	91
7	0.95	0.975			190		
8	0.90	0.949			191		
9	0.60	0.775			220		
10	0.69	0.831			224		
11	0.90	0.949			225		
12	0.95	0.975			225		
13	0.55	0.742			181		
14	0.75	0.866			184		
15	1.05	1.025			186		
16	1.15	1.072			197		
17	0.70	0.837			220		
18	0.85	0.922			228		
19	1.05	1.025			232		
20	1.15	1.072			231		
21	1.25	1.118			258		
22	1.35	1.162			264		
23	1.40	1.183			271		
24	1.10	1.049			290		
25	1.35	1.162			242		
26	1.45	1.204			261		
27	1.40	1.183			272		
28	1.30	1.140			288		
29	0.70	0.837			277		
30	0.78	0.883	392.53		279		
31	0.87	0.933	370.968		284		
32	0.89	0.943			291		

Avg Δ P	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
1.017	1.000	21.562	1.744	230.6	92.3

**Production Rate**

<b>Furnace 1</b>	151.4
Furnace 2	65.1
AOD Vessel	64.5
Total tons	281
Process Time (min)	60
Tons/hr	281.0

Industrial Environmental Monitoring Instruments Inc.  
7410 Worthington Galena Rd  
Worthington, Ohio 43085

## Sample Analysis Certificate

**Client:** Air Test Professionals  
**Address:** 1201 N Graham Ave  
Indianapolis, In 46219

**Date:** 5/25/04  
**Project Number:** Nucor Steel PPF  
**Sample Date:** 5/19/04  
**Date Received:** 5/25/04  
**Date Analyzed:** 5/25/04  
**Analyst:** RAR

**Attn:** Andrew Young  
**Your Project:** Nucor Steel PPF Baghouse  
**Sampled By:** Andrew Young

---

**Analysis:** CO  
**Method:** 10

### Results:

<b>Sample ID:</b> ATP-1	59.5 ppm
ATP-2	100.2 ppm
ATP-3	29.8 ppm

### QA/QC:

Instrument calibrated using three EPA Protocol 1 CO standards and UHP nitrogen. Sampling system tested for bias and instrument tested for drift and error. "Certificates of Analysis" are attached for each standard.

Reviewed By: Donald A. Janner  
President



772 MARION ROAD, COLUMBUS. Oh10 43207 (614)444-1177

### SPECIALTY GASES CERTIFICATE OF ANALYSIS TYPICAL AND GUARANTEED

DATE 08/23/02

SEND TO: I. E. MONT

PRODUCT- NITROGEN ULTRA HIGH PURITY

Cyl Serial  
NK01705

Cyl. Serial

Cyl. Serial

Component	Requested	Actual	Actual	Actual
Hydrocarbons	<0.5 PPM	0.09 PPM		
Oxygen	<1.0 PPM	0.41 PPM		
Moisture	<1.0 PPM	0.87 PPM		
Co	<0.1 PPM	0.06 PPM		

Method of Analysis: Gow Mac Hydrocarbon Analyzer  
Illinois Oxygen Analyzer  
Meco Aquamatic Moisture Analyzer

Certified By:

JOSH WEINMANN

ANALYST

It is recommended the above cylinders not be depleted below 50 psig unless otherwise indicated

**APPENDIX C**

---

VELOCITY TRAVERSE POINT DETERMINATION  
(EPA Method 1)

Nucor Steel  
PPFF Baghouse Compartment



Crawfordsville, Indiana


Depth-in : 176 Dia. (inches) 215.54  
Height-in : 278 Ports: 8

Points Per Port:

	2	4	5	8	10	13
1	44.00	<b>22.00</b>	17.60	11.00	8.80	6.77
2	132.00	<b>66.00</b>	52.80	33.00	26.40	20.31
3		<b>110.00</b>	88.00	55.00	44.00	33.85
4		<b>154.00</b>	123.20	77.00	61.60	47.38
5			158.40	99.00	79.20	60.92
6				121.00	96.80	74.46
7				143.00	114.40	88.00
8				165.00	132.00	101.54
9					149.60	115.08
10						128.62
11						142.15
12						155.69
13						169.23

Spacing

0.00	<b>44.00</b>	35.20	22.00	17.60	13.54
------	--------------	-------	-------	-------	-------



# ATP - Air Test Professionals, Inc.

Time: 1029 / 1104  
Start Stop

Analysis Used for Run(s) 1

## Field Data Sheet

Molecular Weight Determination ( 40 CFR 60 Methods 3 - 4 )

Client	Nucor Steel	Meter Box ID	A1
Location	Crawfordsville IN	Meter Box Gamma	1.003
Unit	PFFF Baghouse - Inlet	Meter Box Delta H @	1.744
Operator	Andrew Young	Pre-test Leak Rate	0.000 cfm @ 15 in. Hg
Date	5-19-04	Post-test Leak Rate	0.000 cfm @ 12 in. Hg
Barometric	30.08	Static Pressure	0.05
		Pitot Check	<input checked="" type="checkbox"/>

ELAPSED TIME	DGM VOLUME	ORIFICE Delta H	IMPINGER OUTLET (F)	DGM IN TEMP (F)	DGM OUT TEMP (K)	PUMP VAC (IN HG)
--------------	------------	-----------------	---------------------	-----------------	------------------	------------------

0	319.930	1.74	67	78	78	1
5	324.1	1.74	66	81	79	1
10	327.5	1.74	66	82	79	1
15	331.3	1.74	66	84	80	1
20	335.3	1.74	66	86	80	2
25	339.0	1.74	66	87	82	3
30	342.7	1.74	66	89	83	4
35	346.325					
Final Vol.						

### M4 Analysis

Initial Liquid Impinger Volume (ml)

200

Final Liquid Impinger Volume (ml)

200

Initial Silica Gel Weight (gm)

180

Final Silica Gel Weight (gm)

186.1

Total Impinger Catch (ml)

6.1

NOTE: Flow rate does not exceed 0.75 cfm. Total volume must equal more than 21 scf over the elapsed time of the run. Moisture assembly maintained at approximately 250 F to keep gas steam above dew point until first impinger.

### MZ Analysis

ΔP Stack Temp

#	Delta P	Stack T	Pre	Post	
1	1.10	184	0.82	192	
2	1.40	189	1.02	180	E
3	1.40	186	1.45	169	
4	1.05	180	1.40	165	
5	0.74	197	1.40	225	
6	0.89	194	1.50	245	F
7	1.05	192	1.60	250	
8	0.94	181	1.25	257	
9	0.72	151	1.30	237	
10	0.97	160	1.65	262	G
11	1.15	156	1.55	242	
12	0.98	152	1.30	223	
13	0.52	179	0.78	268	
14	0.83	187	0.97	280	H
15	1.20	192	0.97	287	
16	1.25	197	0.94	293	

# ATP - Air Test Professionals, Inc.

Time: 1213 / 1243  
Start Stop

Analysis Used for Run(s) 2

## Field Data Sheet

Molecular Weight Determination ( 40 CFR 60 Methods 3 - 4 )

Client	Nuovr Steel	Meter Box ID	A-1	O2	19.0
Location	Crawfordsville IN	Meter Box Gamma	1.003	CO2	0.5
Unit	PPFF Baghouse - Inlet	Meter Box Delta H @	1.744	Stack Dia.	
Operator	Andrew Young	Pre-test Leak Rate	0.000 cfm @	15" in. Hg	
Date	5-19-04	Post-test Leak Rate	0.000 cfm @	9" in. Hg	
Barometric	30.08	Static Pressure	+0.05	Pitot Check	✓

ELAPSED TIME	DEW VOLUME	ORIGINE Delta H	IMPINGER OUTLET (C)	DEWEN TEMP (F)	DEWOUT TEMP (F)	PUMPVAC (IN HG.)
0	347.844	1.74	66	85	84	2
5	351.7	1.74	58	88	84	2
10	355.5	1.74	61	90	85	2
15	359.3	1.74	62	92	86	2
20	363.4	1.74	62	93	86	2
25	367.3	1.74	62	94	87	2
30	370.648	1.74	63	95	88	2
35						
Final Vol.						

### M4 Analysis

Initial Liquid Impinger Volume (ml)

Final Liquid Impinger Volume (ml)

Initial Silica Gel Weight (gm)

Final Silica Gel Weight (gm)

Total Impinger Catch (ml)

200
200
180
185.3
5.3

### M2 Analysis

#	Delta P	Stack T	DP Ts		
			Pre	Post	
A 1	1.20	187	0.65	241	
2	1.25	188	0.78	250	F
3	1.30	189	1.01	252	
4	0.98	203	1.00	256	
5	0.78	179	1.15	269	
B 6	0.94	181	1.20	294	F
7	0.93	184	1.35	302	
8	0.82	186	0.96	300	
9	0.54	211	1.30	300	
C 10	0.63	212	1.40	301	G
11	0.88	217	1.25	313	
12	0.81	222	0.94	316	
13	0.50	191	0.75	308	
D 14	0.68	201	0.84	315	H
15	1.07	210	0.88	324	
16	1.00	218	0.81	332	

NOTE: Row rate does not exceed 0.75 cfm. Total volume must equal more than 21 scf over the elapsed time of the run. Moisture assembly maintained at approximately 250 F to keep gas steam above dew point until first impinger.

# ATP - Air Test Professionals, Inc.

Time: 1311 / 1341  
Start Stop

Analysis Used for Run(s) 3

## Field Data Sheet Molecular Weight Determination ( 40 CFR 60 Methods 3 - 4 )

Client	<u>Nicar Stee</u>	Meter Box ID	<u>A-1</u>	O2	<u>19.0</u>
Location	<u>Crawfordsville IN</u>	Meter Box Gamma	<u>1.003</u>	C02	<u>1.1</u>
Unit	<u>PPFE Baghouse - INLET</u>	Meter Box Delta H @	<u>1.744</u>	Stack Dia.	
Operator	<u>Andrew Youre</u>	Pre-test Leak Rate	<u>0.000</u> cfm @ <u>12</u> in. Hg		
Date	<u>5-19-04</u>	Post-test Leak Rate	<u>0.000</u> cfm @ <u>8</u> in. Hg		
Barometric	<u>30.08</u>	Static Pressure	<u>0.05</u>	Pitot Check	<input checked="" type="checkbox"/>

ELAPSED TIME	DGM VOLUME	ORIFICE Delta H	IMPINGER OULET (F)	DGM IN TEMP (F)	DGM OUT TEMP (F)	PUMP VAC (IN HG)
0	370.968	1.74	67	91	90	3
5	374.9	1.74	67	74	90	3
10	378.5	1.74	66	96	91	6
15	382.0	1.74	66	93	91	3
20	385.6	1.74	65	94	91	3
25	389.3	1.74	62	95	91	3
30	392.530					
35						
Final Vol.						

### M4 Analysis

Initial Liquid Impinger Volume (ml)

200

Final Liquid Impinger Volume (ml)

200

Initial Silica Gel Weight (gm)

180

Final Silica Gel Weight (gm)

186.0

Total Impinger Catch (ml)

6.0

NOTE: Flow rate does not exceed 0.75 cfm. Total volume must equal more than 21 scf over the elapsed time of the run. Moisture assembly maintained at approximately 250 F to keep gas steam above dew point until first impinger.

### M2 Analysis

#	Delta P	Stack T	Pre	Post
1	1.15	191	0.70	220
2	1.30	197	0.85	228
3	1.25	199	1.05	232
4	1.10	208	1.15	231
5	0.75	185	1.25	258
6	0.90	187	1.35	244
7	0.95	190	1.40	271
8	0.90	191	1.10	290
9	0.60	220	1.35	242
10	0.69	224	1.45	261
11	0.90	225	1.40	272
12	0.95	225	1.30	288
13	0.55	181	0.70	277
14	0.75	184	0.78	279
15	1.05	186	0.87	284
16	1.15	197	0.89	291

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: PPF Baghouse
Date: 5/19/04

Nucor PPF Baghouse
07:58:51 05/19/04
NOx: 000.19
SO2: 100.60
VOC: 001.02

07:58:51 05/19/04
NOx: 000.19
SO2: 100.60
VOC: 001.02

10:15:48 05/19/04
020.40
001.04
-000.28

08:04:53 05/19/04
NOx: 000.00
SO2: 62.4
VOC: 001.10

08:35:46 05/19/04
NOx: 000.00
SO2: 62.4
VOC: 38.7

10:16:48 05/19/04
022.41
001.04
-000.34

08:08:04 05/19/04
NOx: 049.91
SO2: 0
VOC: 000.97

08:08:04 05/19/04
NOx: 049.91
SO2: 0
VOC: 000.97

10:17:48 05/19/04
020.61
001.04
-000.29

08:12:25 05/19/04
NOx: 023.41
SO2: 23.5
VOC: 000.92

10:09:48 05/19/04
013.30
000.73
000.39

10:18:48 05/19/04
019.60
001.19
-000.30

08:22:13 05/19/04
NOx: 023.31
SO2: 23.5
VOC: 000.49

10:10:48 05/19/04
012.72
000.90
000.00

10:19:48 05/19/04
018.51
001.19
-000.33

08:24:34 05/19/04
NOx: 000.00
SO2: 0
VOC: 109

10:11:48 05/19/04
013.11
000.90
-000.10

10:20:48 05/19/04
019.61
001.19
-000.34

08:24:34 05/19/04
NOx: 000.00
SO2: 0
VOC: 109

10:21:48 05/19/04
019.21
001.19
-000.34

10:22:48 05/19/04
018.90
000.50
-000.29

10:23:48 05/19/04
018.51
000.73
-000.32

10:24:48 05/19/04
017.71
000.90
-000.30

10:25:48 05/19/04
017.01
001.04
-000.32

10:26:48 05/19/04
016.60
001.19
-000.32

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse  
**Date:** 5/19/04

10:27:48 05/19/04	10:39:48 05/19/04	10:51:48 05/19/04
1 016.30	1 016.80	1 008.01
3 001.04	3 003.94	3 012.35
5 -000.27	5 -000.26	5 -000.27
10:28:48 05/19/04	10:40:48 05/19/04	10:52:48 05/19/04
1 015.21	1 016.70	1 010.20
3 001.04	3 003.64	3 009.76
5 -000.30	5 -000.28	5 -000.28
10:29:48 05/19/04	10:41:48 05/19/04	10:53:48 05/19/04
1 009.50	1 016.41	1 010.00
3 001.96	3 003.33	3 011.74
5 -000.30	5 -000.31	5 -000.30
10:30:48 05/19/04	10:42:48 05/19/04	10:54:48 05/19/04
1 009.40	1 013.00	1 009.40
3 003.18	3 003.79	3 008.22
5 -000.32	5 -000.26	5 -000.29
10:31:48 05/19/04	10:43:48 05/19/04	10:55:48 05/19/04
1 009.30	1 016.21	1 007.70
3 002.72	3 007.31	3 006.83
5 -000.29	5 -000.24	5 -000.30
10:32:48 05/19/04	10:44:48 05/19/04	10:56:48 05/19/04
1 009.60	1 013.90	1 007.50
3 003.18	3 010.21	3 005.32
5 -000.26	5 000.25	5 001.73
10:33:48 05/19/04	10:45:48 05/19/04	10:57:48 05/19/04
1 010.50	1 020.91	1 013.21
3 003.49	3 011.12	3 004.25
5 -000.22	5 000.23	5 000.00
10:34:48 05/19/04	10:46:48 05/19/04	10:58:48 05/19/04
1 016.00	1 011.50	1 004.50
3 007.16	3 008.07	3 003.79
5 -000.32	5 -000.13	5 002.09
10:35:48 05/19/04	10:47:48 05/19/04	10:59:48 05/19/04
1 015.30	1 008.70	1 002.60
3 008.83	3 006.08	3 003.79
5 -000.35	5 -000.10	5 002.93
10:36:48 05/19/04	10:48:48 05/19/04	11:00:48 05/19/04
1 017.20	1 008.20	1 002.50
3 007.46	3 006.23	3 003.64
5 -000.32	5 -000.11	5 001.91
10:37:48 05/19/04	10:49:48 05/19/04	11:01:48 05/19/04
1 015.81	1 008.10	1 002.70
3 005.77	3 007.46	3 003.58
5 -000.29	5 -000.17	5 003.67
10:38:48 05/19/04	10:50:48 05/19/04	11:02:48 05/19/04
1 016.30	1 008.10	1 002.40
3 004.72	3 009.14	3 003.33
5 -000.25	5 -000.19	5 002.63

# ANALYZER FIELD DATA

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse  
**Date:** 5/19/04

11:03:43 05/19/04  
 1 001.30  
 3 003.49  
 5 000.56

11:04:48 05/19/04  
 1 004.00  
 3 003.64  
 5 000.16

11:05:48 05/19/04  
 1 002.00  
 3 003.49  
 5 000.08

11:06:48 05/19/04  
 1 002.20  
 3 003.33  
 5 -000.05

11:07:48 05/19/04  
 1 001.60  
 3 003.33  
 5 -000.13

11:08:48 05/19/04  
 1 001.80  
 3 003.33  
 5 000.00

11:09:48 05/19/04  
 1 001.80  
 3 003.49  
 5 -000.01

\*\*\*\*\* STOP \*\*\*\*\*  
 11:09:55 05/19/04  
 Run statistics N=00061  
 Min Ave Max  
 1 001.30 012.19 030.31  
 3 000.58 004.09 012.35  
 5 -000.35 000.08 003.67

11:09:57 05/19/04  
 RUN starts logging  
 STOP stops logging  
 PROG starts programming

\*\*\*\*\* OFF \*\*\*\*\*  
 \*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

11:19:50 05/19/04  
 1 000.00  
 3 067.24  
 5 036.41 *38.7 VOC*

\*\*\*\*\* RUN \*\*\*\*\*

11:29:50 05/19/04  
 1 023.01 *23.5 NOx*  
 3 -000.64 *0 SO2*  
 5 -000.31 *0 VOC*

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN \*\*\*\*\*

11:34:50 05/19/04  
 1 000.00 *0 NOx*  
 3 062.64 *62.4 SO2*  
 5 -000.37

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*  
 \*\*\*\*\* RUN (2) \*\*\*\*\*

11:44:13 05/19/04  
 1 009.00  
 3 014.34  
 5 003.42

11:45:13 05/19/04  
 1 005.60  
 3 011.27  
 5 007.14

11:46:13 05/19/04  
 1 005.10  
 3 008.98  
 5 004.26

11:47:13 05/19/04  
 1 005.00  
 3 007.61  
 5 002.83

11:48:13 05/19/04  
 1 003.80  
 3 004.55  
 5 000.56

11:49:13 05/19/04  
 1 004.50  
 3 002.72  
 5 000.49

11:50:13 05/19/04  
 1 004.60  
 3 001.80  
 5 000.26

11:51:13 05/19/04  
 1 002.20  
 3 001.19  
 5 000.23

11:52:13 05/19/04  
 1 001.50  
 3 001.04  
 5 000.41

11:53:13 05/19/04  
 1 002.40  
 3 001.04  
 5 -000.08

11:54:13 05/19/04  
 1 001.90  
 3 001.04  
 5 000.05

11:55:13 05/19/04  
 1 001.90  
 3 000.88  
 5 -000.11

11:56:13 05/19/04  
 1 002.40  
 3 000.58  
 5 -000.12

11:57:13 05/19/04  
 1 002.50  
 3 000.43  
 5 -000.16

11:58:13 05/19/04  
 1 002.70  
 3 000.28  
 5 -000.12

11:59:13 05/19/04  
 1 002.40  
 3 000.28  
 5 -000.13

12:00:13 05/19/04  
 1 004.00  
 3 000.28  
 5 -000.02

12:01:13 05/19/04  
 1 000.30  
 3 000.43  
 5 -000.07

12:02:13 05/19/04  
 1 004.10  
 3 000.28  
 5 -000.07

**ANALYZER FIELD DATA**

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** PPF Baghouse  
**Date:** 5/19/04

12:03:13 05/19/04	12:15:13 05/19/04	12:27:13 05/19/04
1 004.50	1 002.40	1 017.20
3 000.73	3 004.87	3 006.70
5 -000.06	5 000.45	5 000.39
12:04:13 05/19/04	12:16:13 05/19/04	12:28:13 05/19/04
1 005.00	1 002.60	1 021.21
3 000.88	3 004.87	3 005.47
5 000.42	5 000.50	5 000.45
12:05:13 05/19/04	12:17:13 05/19/04	12:29:13 05/19/04
1 005.70	1 002.90	1 013.41
3 001.04	3 005.02	3 009.14
5 001.66	5 000.55	5 001.25
12:06:13 05/19/04	12:18:13 05/19/04	12:30:13 05/19/04
1 003.80	1 003.30	1 018.30
3 001.34	3 004.25	3 003.94
5 007.58	5 000.45	5 000.50
12:07:13 05/19/04	12:19:13 05/19/04	12:31:13 05/19/04
1 002.60	1 003.80	1 013.20
3 001.80	3 003.63	3 002.56
5 006.72	5 000.44	5 000.42
12:08:13 05/19/04	12:20:13 05/19/04	12:32:13 05/19/04
1 002.10	1 003.00	1 012.40
3 002.10	3 003.48	3 005.17
5 003.61	5 000.52	5 000.35
12:09:13 05/19/04	12:21:13 05/19/04	12:33:13 05/19/04
1 002.10	1 004.50	1 011.90
3 002.41	3 003.49	3 008.98
5 002.81	5 000.52	5 000.25
12:10:13 05/19/04	12:22:13 05/19/04	12:34:13 05/19/04
1 001.30	1 007.50	1 011.01
3 002.87	3 003.49	3 011.74
5 000.34	5 000.35	5 000.34
12:11:13 05/19/04	12:23:13 05/19/04	12:35:13 05/19/04
1 001.70	1 011.00	1 013.10
3 004.25	3 004.25	3 031.92
5 000.06	5 000.34	5 000.16
12:12:13 05/19/04	12:24:13 05/19/04	12:36:13 05/19/04
1 002.10	1 016.10	1 003.90
3 005.62	3 003.94	3 017.09
5 000.40	5 000.36	5 000.11
12:13:13 05/19/04	12:25:13 05/19/04	12:37:13 05/19/04
1 002.40	1 022.20	1 004.20
3 006.23	3 009.29	3 015.87
5 000.42	5 000.42	5 000.16
12:14:13 05/19/04	12:26:13 05/19/04	12:38:13 05/19/04
1 002.50	1 022.80	1 003.90
3 005.32	3 007.16	3 018.62
5 000.46	5 000.35	5 000.37

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: PPF Baghouse
Date: 5/19/04

12:39:13 05/19/04
1 004.60
3 018.16
5 000.50

12:40:13 05/19/04
1 017.30
3 022.13
5 000.59

12:41:13 05/19/04
1 015.70
3 023.81
5 000.35

12:42:13 05/19/04
1 004.80
3 014.80
5 000.43

12:43:13 05/19/04
1 016.30
3 009.76
5 000.50

12:44:13 05/19/04
1 015.70
3 010.51
5 000.64

Run statistics N=00061
Min Avg Max
1 001.30 007.06 022.80
3 009.28 006.35 031.92
5 000.10 000.92 007.50

12:44:21 05/19/04
RUN starts logging
STOP stops logging
PRG starts programming

\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

12:51:24 05/19/04
1 023.50
3 -001.25
5 -001.49
23.5 NOx
0 SO2
0 VOC

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

12:56:06 05/19/04
1 000.00
3 061.50
5 037.01
0 NOx
62.4 SO2
38.7 VOC

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN (3) \*\*\*\*\*

13:01:20 05/19/04
1 002.50
3 002.26
5 000.86

13:02:28 05/19/04
1 008.30
3 002.42
5 000.26

13:03:28 05/19/04
1 009.99
3 002.57
5 000.34

13:04:28 05/19/04
1 013.80
3 003.94
5 000.40

13:05:28 05/19/04
1 013.00
3 004.40
5 000.31

13:06:28 05/19/04
1 012.40
3 003.79
5 000.24

13:07:28 05/19/04
1 012.70
3 003.33
5 000.10

13:08:20 05/19/04
1 012.11
3 003.33
5 000.09

13:09:28 05/19/04
1 012.90
3 002.87
5 000.05

13:10:28 05/19/04
1 012.30
3 002.97
5 000.34

13:11:28 05/19/04
1 013.50
3 005.02
5 001.09

13:12:28 05/19/04
1 012.50
3 004.25
5 000.49

13:13:28 05/19/04
1 012.10
3 002.57
5 001.15

13:14:28 05/19/04
1 012.10
3 001.65
5 003.22

13:15:28 05/19/04
1 003.70
3 001.34
5 002.45

13:16:28 05/19/04
1 002.20
3 003.49
5 000.76

13:17:28 05/19/04
1 002.10
3 005.62
5 000.61

13:18:28 05/19/04
1 001.80
3 006.85
5 000.29

13:19:28 05/19/04
1 003.30
3 007.00
5 000.22

13:20:28 05/19/04
1 008.50
3 009.29
5 000.11

13:21:28 05/19/04
1 006.70
3 008.38
5 000.03

ANALYZER FIELD DATA

Company Nucor Steel  
 Location: Crawfordsville, Indiana  
 source: PPF Baghouse  
 Date: 5/19/04

```

13:22:28 05/19/04
1 007.70
3 008.07
5 000.10

13:23:28 05/19/04
1 012.30
3 007.61
5 000.09

13:24:28 05/19/04
1 011.30
3 006.53
5 000.04

13:25:28 05/19/04
1 012.30
3 005.47
5 000.05

13:26:28 05/19/04
1 013.10
3 005.17
5 000.05

13:27:28 05/19/04
1 012.30
3 005.17
5 -000.01

13:28:28 05/19/04
1 008.00
3 005.32
5 000.06

13:29:28 05/19/04
1 010.70
3 005.93
5 000.17

13:30:28 05/19/04
1 019.60
3 006.85
5 001.25

13:31:28 05/19/04
1 024.70
3 004.10
5 000.40

13:32:28 05/19/04
1 012.40
3 002.87
5 000.22

13:33:28 05/19/04
1 011.20
3 004.55
5 000.14
    
```

```

13:34:28 05/19/04
1 011.70
3 007.00
5 000.14

13:35:28 05/19/04
1 011.50
3 012.51
5 000.07

13:36:28 05/19/04
1 010.60
3 014.34
5 000.04

13:37:28 05/19/04
1 011.00
3 012.20
5 000.03

13:38:28 05/19/04
1 010.70
3 011.89
5 -000.01

13:39:28 05/19/04
1 010.50
3 010.66
5 000.00

13:40:28 05/19/04
1 010.40
3 008.98
5 000.00

13:41:28 05/19/04
1 010.60
3 007.00
5 000.03

13:42:28 05/19/04
1 009.00
3 006.23
5 000.04

13:43:28 05/19/04
1 010.20
3 006.70
5 000.07
    
```

```

13:44:28 05/19/04
1 010.10
3 006.23
5 000.05

*** ON (RUNNING) ***
***** STOP *****
13:44:39 05/19/04
Run statistics N=00044
Min Ave Max
1 001.00 010.52 024.70
3 001.34 005.88 014.34
5 -000.01 000.37 003.22

13:44:41 05/19/04
RUN starts logging
STOP stops logging
PRG starts programming

***** OFF *****

***** RUN *****

13:51:36 05/19/04
1 000.00
3 000.01
5 006.43
    NOx
    62.4 SO2
    38.7 VOC

***** OFF *****

***** ON *****
***** RUN *****

13:54:59 05/19/04
1 023.20
3 -001.24
5 -001.06
    23.5 NOx
    0 SO2
    0 VOC

***** OFF *****
    
```

**APPENDIX D**

---



**APPENDIX E**

---

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PPFF Baghouse
Date:	05/19/2004

Pollutant Gas Type: SO2  
 Instrument Span: 105  
 Upscale Calibration Gas: 62.4

## ANALYZER CALIBRATION DATA

Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
0.00	-0.79	0.79	0.75%	Pass
62.40	61.89	0.51	0.49%	Pass
101.00	100.60	0.40	0.38%	Pass

## SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values		Final Values	
	m Calibration Bias (ppm)	System Calibration Bias (% of span)	System Calibration Response (ppm)	System Calibration Bias (% of span)
<u>Run # 1</u>				
Zero gas	-0.49	0.29%	-0.64	0.14%
Upscale gas	62.19	0.29%	62.64	0.71%
<u>Run # 2</u>				
Zero gas	-0.64	0.14%	-1.25	0.44%
Upscale gas	62.64	0.71%	61.58	0.30%
<u>Run # 3</u>				
Zero gas	-1.25	0.44%	-1.24	0.43%
Upscale gas	61.58	0.30%	60.81	1.03%

## EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (dry, ppm)
Run # 1	4.09	4.61
Run # 2	6.35	7.22
Run # 3	5.88	7.12

## ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company	Nucor Steel
Location:	Crawfordsville, Indiana
Source	PPFF Baghouse
Date:	05/19/2004

Pollutant Gas Type: NOx  
 Instrument Span: 50  
 Upscale Calibration Gas: 23.5

### ANALYZER CALIBRATION DATA

	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	0.10	0.10	0.20%	Pass
Mid-range gas	23.5	23.41	0.09	0.18%	Pass
High-range gas	49.9	49.91	0.01	0.02%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values			Drift (% of span)	Drift Error Check
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check		
<u>Run # 1</u>								
Zero gas	0.00	0.20%	Pass	0.00	0.20%	Pass	0.00%	Pass
Upscale gas	23.31	0.20%	Pass	23.01	0.80%	Pass	0.60%	Pass
<u>Run # 2</u>								
Zero gas	0.00	0.20%	Pass	0.00	0.20%	Pass	0.00%	Pass
Upscale gas	23.01	0.80%	Pass	23.50	0.18%	Pass	0.98%	Pass
<u>Run # 3</u>								
Zero gas	0.00	0.20%	Pass	0.00	0.20%	Pass	0.00%	Pass
Upscale gas	23.50	0.18%	Pass	23.20	0.42%	Pass	0.60%	Pass

### EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (dry, ppm)
Run # 1	12.19	12.37
Run # 2	7.06	7.13
Run # 3	10.52	10.59

# CALIBRATION CHECK

(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Location: Crawfordsville, Indiana  
 Source: PPF Baghouse  
 Date: 05/19/04

	Run 1	Run 2	Run 3	Average
Y qa =	1.000	0.984	1.045	1.010
Average result must be within 5% of Y				
Result (%)	0.78			
<b>PASSED POST CAL</b>				

**Dry Gas Meter Box:**

ID: A-1  
 Y: 1.002  
 Delta H: 1.72

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.72	78	78
2		1.72	81	79
3		1.72	82	79
4		1.72	84	80
5		1.72	86	80
6		1.72	87	82
7		1.72	89	83
8				
9				
10	346.325			
11	319.93			
12				

Volume	Delta H	Meter Temp
26.395	1.720	82.0

Barometric Pressure
30.08

Test Time
35.5

Y qa:	1.000
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.720	85	84
2		1.720	88	84
3		1.720	90	85
4		1.720	92	86
5		1.720	93	86
6		1.720	94	87
7		1.720	95	88
8				
9				
10	370.648			
11	347.844			
12				

Volume	Delta H	Meter Temp
22.804	1.720	88.4

Barometric Pressure
30.08

Test Time

Y qa:	0.984
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.720	91	90
2		1.720	94	90
3		1.720	96	91
4		1.720	93	91
5		1.720	94	91
6		1.720	95	91
7				
8				
9				
10	392.53			
11	370.968			
12				

Volume	Delta H	Meter Temp
21.562	1.720	92.3

Barometric Pressure
30.08

Test Time

Y qa:	1.045
-------	-------

## Meter Box Post-Test Calibration

APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor

Filename: Orifice Calibration

Box ID#: **A-1**

Date: .....> 01/20/04  
 Barometric Pressure: ....> 29.98 in Hg  
 Critical Orifice Vacuum:..> 20 in Hg

**IMPORTANT!!!** For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)\*(min)).

..... DRY GAS METER READINGS .....

CRITICAL ORIFICE READINGS

dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial#	K' Orifice Coefficient (see above)	Vacuum (in Hg)	.. Ambient Temperature ..		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
<b>0.38</b>	14.08	216	221	5.00	95	93	96	94	<b>AT-15</b>	<b>0.265</b>	20	88	88	88
<b>0.38</b>	14.08	221	226	5.00	96	94	97	95	<b>AT-15</b>	<b>0.265</b>	20	88	88	88
<b>0.38</b>	14.08	226	231	5.00	97	95	98	95	<b>AT-15</b>	<b>0.265</b>	20	88	88	88

\*\*\*\*\* RESULTS \*\*\*\*\*

... DRY GAS METER ...

..... ORIFICE .....

-- DRY GAS METER --

..... ORIFICE .....

VOLUME CORRECTED	VOLUME CORRECTED
Vm(std) (cu ft)	Vm(std) (liters)
4.7731297	135.175
4.7645372	134.9317
4.7581131	134.7498

VOLUME CORRECTED	VOLUME CORRECTED
Vcr(std) (cu ft)	Vm(std) (liters)
4.77848116	135.32659
4.77848116	135.32659
4.77848116	135.32659

CALIBRATION FACTOR Y	
Value	Variation
(number)	(number)
1.00112	-0.0017
1.00293	0.00015
1.00428	0.0015

CALIBRATION FACTOR dH@		
Value	Value	Variation
(in H2O)	(mm H2O)	(in H2O)
1.7248317	43.81073	0.00826
1.7155279	43.57441	-0.001
1.7093635	43.41783	-0.0072

Average Y .....>

**1.00278**

**1.717** 43.60099 <..... Average dH@

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

Calibrated by: Carlos Brown

Date: January 20, 2004

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

**Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1**

Probe Length/ID.: 12 ft. (w/2ft ext.) Type-S

External Tubing Diameter: 0.375" inches

Base to Opening Plane Distance (Pa): 0.470" inches

Base to Opening Plane Distance (Pa): 0.470" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ <b>10.0</b>
<b>Angle <math>\alpha</math> 2</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ <b>10.0</b>
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ <b>10.0</b>
<b>z (inches)</b>	<b>0.0"</b>	0.125 inches
<b>w (inches)</b>	0.0"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: 0.84

Calibrated By: Carlos Brown Date Calibrated: February 16, 2004

**ATP – Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 12 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

<b>Temperature Range</b>	<b>Mercury Thermometer</b>	<b>Probe Thermometer</b>
Hot Bath	425 deg	425 deg
Room Temperature	72 deg	72 deg
Ice Bath	30 deg	30 deg

Calibrated By: Carlos Brown Date Calibrated: February 16, 2004

---

**Certificate of Analysis**

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

B16405B

Material:	6232	Blend Tolerance:	5 % Relative
EPA NO/N2 2-49 PPM		Store/Use Temp:	35 to 90 F
Production #:	100061997	Blend Type:	EPA Protocol
Lot #:	02499A3090EI	Cyl. Pressure:	2000 psig
Cylinder #:	CC34494	Balance Gas:	Nitrogen
Expiration Date:	112312005	CGA:	660
Shelf Life:	24 months	Analytical Accuracy:	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	22	23.5 +/- 0.2 ppm	0112312003
7727-37-9	Nitrogen		Balance	01/23/2003

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A 2	NOx	23.5 ppm	01/23/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	ND11377 , LS	100.9 ppm	1112112007
10102-43-9	Nitric Oxide	CC120225 , GMIS	20.35 ppm	11/22/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba CLA-510SS	568093024	Chemiluminescence	01/21/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jim Healy

*Jim R Healy*



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

LINDE COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6232	<b>Blend Tolerance:</b>	5 % Relative
EPA NO/N2 2-49 PPM		<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100079533	<b>Cyl. Pressure:</b>	2000 psig
<b>Lot #:</b>	02499A4140BF		Nitrogen
<b>Cylinder #:</b>	CC174364	<b>Balance Gas:</b>	660
<b>Expiration Date:</b>	1/19/2006	<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	24 months	<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	495	49.9 +/- 0.5 ppm	01/19/2004
7727-37-9	Nitrogen		Balance	01/19/2004

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A	NOx	49.9 ppm	01/19/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	CC137201, GMIS	20.41 ppm	01/09/2006

Instrument	Serial #	Analytical Principle	Calibration Date
Nicolet Magna 550	ACJ9300713	FTIR	10/27/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

B17198B

Analytical report approved by Jim Healy




AGA  
Member of the Linde Gas Group



**IE** (800) 532-7474  
www.iermiinc.com

316194B

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6655 EPA SO2/N2 15-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100056269	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499H2260BK	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC150625	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	9/12/2004	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	24 months	<b>CGA:</b>	660
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	60	62.4 +/- 0.6 ppm	09/12/2002
7727-37-9	Nitrogen		Balance	09/12/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CC130050 , GMIS	101.6 ppm	07/26/2004
7446-09-5	Sulfur Dioxide	CC3837 , GMIS	50.45 ppm	07/26/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568279012	Non-Dispersive Infrared	08/05/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Jim Healy



AGA

Member of the Linde Gas Group

Linde

(800)  
532-7474

www.lindec.com

## Certificate of Analysis

### EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

316149 B

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6681	<b>Blend Tolerance;</b>	5 % Relative
EPA SO <sub>2</sub> /N <sub>2</sub>	1.00-3500 PPM	<b>Store/Use Temp;</b>	35 to 90 F
<b>Production #:</b>	100056267	<b>Blend Type:</b>	EPA Protocol
<b>Batch #:</b>	02499H2260BJ	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC150571	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	9/6/2004	<b>CGA:</b>	660
<b>Shelf Life:</b>	24 months	<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	100	101 +/- 1 ppm	09/06/2002
7727-37-9	Nitrogen		Balance	09/06/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CC130050 , GMIS	101.6 ppm	07/26/2004
7446-09-5	Sulfur Dioxide	CC113475 , GMIS	500.4 ppm	06/20/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568279012	Non-Dispersive Infrared	08/05/2002

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jim Healy



Certificate of Analysis

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure GI

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6647 EPA C3H8/N2 1-99 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100077554	<b>Blend Type:</b>	EPA Protocol
<b>Lot #:</b>	02499M3020ZF	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC3860	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	12/15/2006	<b>CGA:</b>	350
<b>Shelf Life:</b>	36 months	<b>Analytical Accuracy:</b>	1.00 % Relative
		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	39	38.7 +/- 0.4 ppm	12/15/2003
7727-37-9	Nitrogen		Balance	12/15/2003


CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC100454, GMIS	10.52 ppm	06/05/2005
74-98-6	Propane	CC154126, GMIS	101.0 ppm	06/05/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	11/11/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

B17111B

Analytical report approved by Jim Healy



HQ Analysis  
Certificate

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-6001R-971121, Procedure GI

Notice: This Cylinder is **not** to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6647	<b>Blend Tolerance:</b>	5 % Relative
EPA C3H8/N2 1-99 PPM		Blend Type:	EPA Protocol
Production #:	100077553	Cyl. Pressure:	2000 psig
Lot #:	02499M3020ZE	Balance Gas:	Nitrogen
Cylinder #:	CC13911	CGA:	350
Expiration Date:	12/15/2006	<b>Analytical Accuracy:</b>	1.00 % Relative
Shelf Life:	36 months	<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	64	63.7 +/- 0.6 ppm	12/15/2003
7727-37-9	Nitrogen		Balance	12/15/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC100454, GMIS	10.52 ppm	06/05/2005
4-98-6	Propane	CC154126, GMIS	101.0 ppm	06/05/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	11/11/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17112B

Analytical report approved by Jim Healy



**Certificate of Analysis**

EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

**Notice:** This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	4004 EPA PROPANE/N2 100-999 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100077552	<b>Blend Type:</b>	EPA Protocol
<b>Lot #:</b>	02499M3010G1	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC27516	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	12/8/2006	<b>CGA:</b>	350
<b>Shelf Life:</b>	36 months	<b>Analytical Accuracy:</b>	1.00 % Relative
		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
74-98-6	Propane	109	109 +/- 1 ppm	12/08/2003
7727-37-9	Nitrogen		Balance	12/08/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
74-98-6	Propane	CC73695 , GMIS	1004 ppm	09/11/2005
74-98-6	Propane	CC154126 , GMIS	101.0 ppm	06/05/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba FIA-510	56847471	Flame Ionization	11/11/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17057B

Analytical report approved by Jim Healy



**HiQ Analysis Certificate**

**AGA**  
Member of the Linde Gas Group



(800)  
532-7474

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure GI

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

AGA Gas, Inc.  
- Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b> 6154 EPA CO/N2 10-99 PPM	<b>Blend Tolerance:</b> 5 % Relative
<b>Production #:</b> 100076206	<b>Blend Type:</b> EPA Protocol
<b>Lot #:</b> 02499K3310UA	<b>Cyl. Pressure:</b> 2000 psig
<b>Cylinder #:</b> CC167431	<b>Balance Gas:</b> Nitrogen
<b>Expiration Date:</b> 11/12/2006	<b>CGA:</b> 350
<b>Shelf Life:</b> 36 months	<b>Analytical Accuracy:</b> 1.00 % Relative
	<b>Confidence:</b> 95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	30.3	30.1 +/- 0.3 ppm	11/12/2003
7727-37-9	Nitrogen		Balance	11/12/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC3859 . GMIS	25.08 ppm	06/04/2004
630-08-0	Carbon Monoxide	CC13630 . GMIS	99.53 ppm	09/12/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	09/26/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

B17004B

Analytical report approved by Jim Healy



## Certificate of Analysis

### EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

Material:	6154	Blend Tolerance:	5 % Relative
EPA CO/N2 10-99 PPM		Blend Type:	EPA Protocol
Production #:	100076208	Cyl. Pressure:	2000 psig
Lot #:	02499K3280ZE	Balance Gas:	Nitrogen
Cylinder #:	CC175246	CGA:	350
Expiration Date:	11/12/2006	Analytical Accuracy:	1.00 % Relative
Shelf Life:	36 months	Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	89.1	89.1 +/- 0.9 ppm	11/12/2003
7727-37-9	Nitrogen		Balance	11/12/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expiry Date
630-08-0	Carbon Monoxide	CC3859 , GMIS	25.08 ppm	06/04/2004
630-08-0	Carbon Monoxide	CC13630 , GMIS	99.53 ppm	09/12/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	09/26/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17006B

Analytical report approved by Jim Healy






(800)  
532-7474  
www.iomiinc.com

Linde

## CERTIFICATE OF ANALYSIS

### EPA PROTOCOL

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G I

**NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig**

#### MANUFACTURED AND CERTIFIED AT:

AGA Gas inc.  
Specialty Gas Division  
6421 Monclova Road  
Maumee, Ohio 43537  
419-893-7226

#### ANALYTICAL AND CYLINDER DATA:

Certified Component	Concentration and Uncertainty	Date of Certification
Carbon Monoxide	133 ± 1 ppm	1/28/2002

Analyzed for Reference Use Only	Concentration	Date of Analysis
N/A - Not Applicable for this Mixture	N/A	N/A

Production Number: 100046348

Cylinder Number: CC23930 *B158113*  
Expiration Date: 1/28/2005

Cylinder Pressure (psi): 2000

Balance Gas: Nitrogen

CGA: 350

#### REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

Reference Standard Number	Cylinder Number	Concentration and Component	Expiration Date
GMIS	CC73603	507.7 ppm Carbon Monoxide	3/21/2002
GMIS	CC100557	50.56 ppm Carbon Monoxide	3/21/2002

#### INSTRUMENTATION DATA:

Instrument Model	Serial Number	Date of Last Calibration	Analytical Principle
Horiba VIA-510	569466011	1/28/2002	Non-Dispersive Infrared (NDIR)

Analytical Report Approved By *[Signature]*

AGA

Member of the Linde Gas Group

**APPENDIX F**

---

**APPENDIX G**

---

**COMPLIANCE TEST PROTOCOL  
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: April 1, 2004 Proposed Test Date May 19-21, 2004

Plant Address and Location: 4537 S. Nucor Road, Crawfordsville, Indiana 47933

**1. Source Information**

AFS: \_\_\_\_\_ Id Number: \_\_\_\_\_ Permit Number: 107-16823-00038  
 Company: Nucor Steel  
 Mail Address: RR2 Box 311, CR 400 E  
 City: Crawfordsville, Indiana Zip: 47933  
**Co. Contact:** Mark Washer Phone: (765) 364-1323

Check program if applicable:

FESOP: \_\_\_\_\_  
 Title V: X  
 SSOA: \_\_\_\_\_


AGENCY USE ONLY		Date Rec'd: _____
Inspector: _____	Reviewer: _____	Date Appr: _____

**2. Tester Information**

Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete? Yes

**3. Process Information**

Unit to Test: PPFF Baghouse (2-EAF's + I-AOD)  
 Max. Rated Capacity: 502 tons per hour  
 Proposed Operating Speed: Close to Max as possible  
 Pollution Control Equipment: PPFF Baghouse  
 Process Description: Process of melting scrap metal to make carbon steel.  
 \_\_\_\_\_  
 \_\_\_\_\_  
 Fuel Type: N/A



**Note:**

**4. Test Information**

Methods 1-4	Moisture/Flow	# Runs	Time/Run
Method 5		3	<u>30 min @ Inlet</u>
Method 6C	SO2	3	<u>60 min @ Inlet</u>
Method 7E	NOx	3	<u>60 min @ Inlet</u>
Method 10	CO	3	<u>60 min @ Inlet</u>
Other Testing:	<u>M25A</u>	3	<u>60 min @ Inlet</u>

**5. Sampling Strategy**

a. Describe any deviations from the standard test method. None

b. **Describe** method used to determine quantity of raw materials  
Plant personnel will keep record of weight rates. New Baseline Values for Fan Amps and Delta P's.

**6. Sample Site Location**

Does sample port location meet 40 CFR 60, Appx A, Method 1 Section 1.2 requirements: Yes/No: YES If No, Explain \_\_\_\_\_

Number of sample points for M5: 32  
 Diameter at sample site: 209" Stack height: N/A  
 Approx. stack gas flow (ACFM): 1,309,000  
 Approx. gas temp. (**degF**): 250 F Max  
 Approx. gas moisture (%): 3%

Reason for test:

State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: Yes  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 326 \_\_\_\_\_  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (**i.e.** EPA, CD, state, 114) \_\_\_\_\_

326 IAC 3-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to: (FEE NOT APPLICABLE IF FESOP OR TITLE V)

**APPENDIX H**

---

Furnace 1 Production: 5/19/04

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
141211	130	9:25 AM	8:40 AM	45	173.3
141212	130	10:36 AM	9:25 AM	71	109.9
141213	130	11:30 AM	10:36 AM	54	144.4
141214	129	12:22 PM	11:30 AM	52	148.8
141215	130	1:22 PM	12:22 PM	60	130.0
141216	129	2:10 PM	1:22 PM	48	161.5
141217	130	3:01 PM	2:10 PM	51	152.9
141218	130	3:47 PM	3:01 PM	46	169.6
141219	129	4:30 PM	3:47 PM	43	180.0
141220	129	5:12 PM	4:30 PM	42	194.7
141221	128	6:47 PM	5:12 PM	75	139.6
141222	130	7:39 PM	6:47 PM	52	160.0
141223	129	8:37 PM	7:39 PM	58	133.4
141224	129	9:50 PM	8:37 PM	73	106.0

Furnace 2 Production: 5/19/04

Heat No.	Tons	Tap Time	Prev. Tap Time	Tap-to-Tap Minutes	Average tons/hr
246985	106	9:25 AM	8:33 AM	52	122.3
246986	112	11:23 AM	9:25 AM	118	66.9
246987	118	12:40 PM	11:23 AM	77	91.9
246988	115	2:26 PM	12:40 PM	106	65.7
246989	118	3:54 PM	2:26 PM	88	80.5
246990	116	5:26 PM	3:54 PM	72	68.7
246991	116	6:37 PM	5:26 PM	71	67.7
246992	115	8:16 PM	6:37 PM	79	63.1
246993	117	9:54 PM	8:16 PM	78	90.0
246994	115	10:42 PM	9:54 PM	68	101.5

Stack Gases - SOx, NOx, CO, VOC

	Run Time	Furn 1 Tons	Furn 2 Tons	AOD Tons	TOTAL
Run 1	10:09 am - 11:09 am	128.8	56.9	48.6	234.3
Run 2	11:44 am - 12:44 pm	142.0	90.1	56.1	288.2
Run 3	1:00 pm - 1:08 pm	52.2	0.0	0.0	52.2
<b>Total</b>					<b>803.5</b>

AOD Production Data: 5/19/04

Heat No.	Tons	Tap Time	Charge Time	Charge-Tap Minutes	Average tons/hr
246985	119.1	12:17 PM	9:55 AM	142	50.3
246986	117.8	2:04 PM	12:52 PM	62	66.5
246987	123.8	3:37 PM	2:11 PM	86	86.4
246988	117.8	4:27 PM	3:40 PM	47	109.5
246989	116.2	6:44 PM	5:13 PM	91	176.0
246990	116.2	8:06 PM	6:46 PM	79	208.3
246991	117.1	9:20 PM	8:07 PM	73	166.2
246992	118	10:29 PM	9:22 PM	67	105.7

Run 1 - PM & Metals

	Run Time	Furn 1 Tons**	Furn 2 Tons**	AOD Tons**	TOTAL**	Avg. Run Production
Run 1	4:00 pm - 9:34 pm	706.7	489.0	568.0	1724.7	334.9

\*\*Run 1 testing was suspended 25 minutes due to furnace downtime.  
Production totals are based on 309 minutes run time rather than 334 minutes

HEAT NO: 141211  
 HEATS ON BOTTOH: \_\_\_\_\_  
 LADLE NO: 12  
 CAST HEAT TAPPED: 9:40

FULL WEIGHT: \_\_\_\_\_  
 TARE WEIGHT: \_\_\_\_\_  
 WEIGHT TAPPED: 136  
 HEATS ON DELTA: 157

DATE: 5-18 KWH END: \_\_\_\_\_  
 HELTER: DAN KWH START: \_\_\_\_\_  
 AIM GRADE: 1008A2 KWH USED: 52  
 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>05</u>			<u>052</u>		<u>08</u>										<u>15</u>
F-2																	
F-3																	
F-4																	

CHORGE BKT #1 BKT #2

HOT HEEL	<u>40,000</u>	
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	<u>25</u>	<u>60</u>
BURNT LIHE	<u>2000</u>	
DOLO LIRE	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>8</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	<u>8</u> Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3071</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>B#1</u>	

TAP TIME: 9:25

OXYGEN PPM 1018  
 REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 1412/2 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOR: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ RELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: \_\_\_\_\_ WEIGHT TAPPED: 26000 AIM GRADE: 100873 KWH USED: 50  
 LAST HEAT TAPPED: 9125 HEATS ON DELTA: \_\_\_\_\_ PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHERISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		027			1047		071									
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL	<del>30,000</del>	
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRLP TOTAL	75	60
BURNT LIRE	2000	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	8
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd 'bucket	_____	_____	8
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
B#1	

Time	Temp	Tire	Temp
_____	3069	022	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1344

TAP TIRE: 11:36

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 141213  
 HEATS ON BOTTOH: \_\_\_\_\_  
 LADLE NO: .5  
 LAST HEAT TAPPED: 10/36

FULL WEIGHT: \_\_\_\_\_  
 TARE WEIGHT: \_\_\_\_\_  
 WEIGHT TAPPED: 240000  
 HEATS ON DELTA: 159

DATE: 5-19 KUH END: \_\_\_\_\_  
 MELTER: Myers KWH START: \_\_\_\_\_  
 AIH GRADE: 1068A2 KWH USED: 49  
 PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		<u>0.39</u>			<u>0.57</u>		<u>0.72</u>							
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>120</u>
SCRAP TOTAL		<u>13560N</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	<u>6</u> Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>3076</u>	<u>007</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT (LBS)
<u>B#1</u>	

TAP TIME: 11:30

REMARKS (list)

OXYGEN PPM 1132

Add A Phase 5 min

EBT HEAT RECORD

HEAT NO: 141214  
HEATS ON BOTTON: \_\_\_\_\_  
LADLE NO: 10  
LAST HEAT TAPPED: 11:30

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 238000 AIM  
HEATS ON DELTA: 160

DATE: 5-19 KWH END: \_\_\_\_\_  
HELTER: MENS KWH START: \_\_\_\_\_  
GRADE: \_\_\_\_\_ KWH USED: 47  
PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		0.32			0.50		0.80							
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	150	129
SCRAP TOTAL		139.540W
BURNT LIME	2000	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	10 Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	10 Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	3033	1:02:41	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
1	

TAP TIRE: 12:22

REMARKS (list)

OXYGEN PPM 1168

Add # 8 phase - (6 min)

HEAT NO: 141215 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: M. Vens KWH START: \_\_\_\_\_  
 LADLE NO: 17 WE BHT TAPPED: 260000 AIM GRADE: \_\_\_\_\_ KYH USED: 379  
 LAST HEAT TAPPED: 10:22 HEATS ON DELTA: 160 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIRE	C	CHEMISTRY											TOTAL RESID		
			Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>043</u>			<u>058</u>		<u>088</u>									
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>129</u>
SCRAP TOTAL		<u>139.56</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

Tire	Temp	Tire	Temp
_____	<u>2946</u>	<u>1027</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 96

TAP TIME 11:22

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

COOK STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141216 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH EM): \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Wyers KWH START: \_\_\_\_\_  
 LADLE NO: 16 WEIGHT TAPPED: 258000 AIM GRADE: \_\_\_\_\_ KUH USED: 47  
 LAST HEAT TAPPED: 1:02 HEATS ON DELTA: 162 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		035			056		092									
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	150	129
SCRAP TOTAL		139.5 tons
BURNT LIME	2000	
DOLO LIME	4700	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	6 Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	6 Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
1	

Time	Temp	Time	Temp
_____	2788	1:05	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1079

TAP TIME: 2:10

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141218 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 210000 AIM GRADE: \_\_\_\_\_ KWH USED: 46  
 AST HEAT TAPPED: 3:01 HEATS ON DELTA: 164 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N				
F-1		<u>031</u>					<u>0.16</u>		<u>0.19</u>								
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL																	
BUSHELING																	
SKULLS																	
BUNDLES																	
P/S																	
SHREDDED																	
SCRAP TOTAL			<u>150</u>	<u>133</u>													
BURNT LIME			<u>2000</u>														
DOLO LIME			<u>4700</u>														
CRG. CARBON			<u>1500</u>														

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Tire	Temp	Tire	Temp
_____	<u>2873</u>	<u>287</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

TAP TIME: 3:47

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

OXYGEN PPM 9521



20

NULOR STEEL - GRANFORDVILLE  
EBT HEAT RECORD

HEAT NO: 1412  
HEATS ON BOTTOM: \_\_\_\_\_  
LADLE NO: 11  
LAST HEAT TAPPED: 4/30

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 258000  
HEATS ON DELTA: 166

DATE: 5-19 KWH END: \_\_\_\_\_  
MELTER: Myers KYH START: \_\_\_\_\_  
AIM GRADE: \_\_\_\_\_ KWH USED: 23  
PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1																
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		Scrap
	P.B	127
	150	<del>100</del>
SCRAP TOTAL		138.5
BURNT LIME	2000	
DOLO LIME	5500	
CRG. CARBON	1500	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	6 Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcrn lance on	_____	_____	CF 0
Carbon Injector on	_____	_____	Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
1	

Time	Temp	Time	Temp
_____	2970	000	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1247

TAP TIRE: 5152

REMARKS (list) \_\_\_\_\_  
150,000 P. Back Cast on  
Hot Metal Tapped Out  
55 mins

EBT HEAT RECORD

HEAT NO: 141221 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myo19 KWH START: \_\_\_\_\_  
 LADLE NO: 7 WEIGHT TAPPED: 25 AIM GRDE: \_\_\_\_\_ KYH USED: 39  
 LAST HEAT TAPPED: 5:52 HEATS ON DELTR: \_\_\_\_\_ PATCH: ✓ LBS(EST) \_\_\_\_\_

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		<u>033</u>			<u>012</u>		<u>076</u>							
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>154</u>	<u>130</u>
SCRAP TOTAL		<u>142</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CRRBON	<u>150P</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
	_____	_____	CF 0
Vulcan lance on	_____	_____	
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
	_____	_____	CF 0
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2990</u>	<u>020</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

TAP TIME: 6:47

REMARKS (list)

OXYGEN PPM 130

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 191222 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOH: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: Myers KWH START: \_\_\_\_\_  
 LADLE NO: 10 WEIGHT TAPPED: 260000 AIM GRADE: \_\_\_\_\_ KWH USED: 45  
 LAST HEAT T A P P E D : \_\_\_\_\_ HEATS ON DELTA: 168 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Ho	Sn	V	N			
F-1		<u>0.3</u>			<u>0.47</u>		<u>0.86</u>									
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>141</u>
SCRAP TOTAL		<u>1455</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	Tap no.
Oxy-fuel burners	_____	_____	CF
	_____	_____	CF CH
Vulcan lance on	_____	_____	CF O
Carbon Injector on	_____	_____	Lbs. Inj

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

Tire	Terp	Tire	Terp
_____	<u>2941</u>	<u>1026</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 232

TAP TIME: 7:39

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141223  
HEATS ON BOTTOM: \_\_\_\_\_  
LADLE NO: 12  
LAST HEAT TAPPED: +

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 258000  
HEATS ON DELTA: 169

DATE: 5-19 KWH END: \_\_\_\_\_  
MELTER: Myers KYH START: \_\_\_\_\_  
AIM GRADE: \_\_\_\_\_ KWH USED: \_\_\_\_\_  
PATCH: \_\_\_\_\_ LBS (EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N		
F-1		<del>037</del>			<del>051</del>		<del>023</del>								
F-2		037			051		023								
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	150	129
SCRAP TOTAL		139.5
BURNT LINE	2000	
DOLO LINE	4700	
CRG. CARBON	1500	

	START	END		
Drop 1st bucket	_____	_____	6 Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		Tap no.
Oxy-fuel burners	_____	_____	CF	
Vulcan lance on	_____	_____	CF CH	
	_____	_____	CF 0	
Drop 2nd bucket	_____	_____	6 Tap no.	
Power on	_____	_____		Tap no.
	_____	_____		CF
Oxy-fuel burners	_____	_____	CF CH	
Vulcan lance on	_____	_____	CF 0	
Carbon Injector on	_____	_____	Lbs. Inj	

Time	Temp	Tiae	Teap
_____	3029	1002	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT (LBS)
1	

TAP TIME: 8:37

OXYGEN PPM 1056  
REMARKS (list) \_\_\_\_\_  
\_\_\_\_\_ Add C phase grains \_\_\_\_\_  
\_\_\_\_\_

NUCOR STEEL - CRAUFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141224 FULL WEIGHT: \_\_\_\_\_ DATE: 5-1 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 11 eye 5 KWH START: \_\_\_\_\_  
 LADLE NO: 11 WEIGHT TAPPED: 258000 AIM GRADE: \_\_\_\_\_ KWH USED: 38  
 LAST HEAT TAPPED: 8237 HEATS ON DELTA: 170 PATCH: 2500 LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		<u>040</u>					<u>050</u>		<u>083</u>							
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>130</u>
SCRAP TOTAL		<u>140 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	<u>10</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	<u>6</u> Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	
Carbon Injector on	_____	_____	_____ Lbs. Inj

Tire	Temp	Tire	Temp
_____	<u>3000</u>	<u>-086</u>	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
<u>1</u>	

TAP TIME: 9:50 REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
patch - 11 miles  
 \_\_\_\_\_  
 \_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 141225  
HEATS ON BOTTOM: \_\_\_\_\_  
LADLE NO: \_\_\_\_\_  
LAST HEAT TAPPED: 9:50

FULL WEIGHT: \_\_\_\_\_  
TARE WEIGHT: \_\_\_\_\_  
WEIGHT TAPPED: 129  
HEATS ON DELTA: 177

DATE: 5-18 KWH EM: \_\_\_\_\_  
HELTER: Tim KWH START: \_\_\_\_\_  
RIM GRADE: \_\_\_\_\_ KWH USED: 50  
PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	No	Sn	V	N				
F-1		<u>054</u>			<u>054</u>												
F-2																	
F-3																	
F-4																	

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>150</u>	<u>130</u>
SCRAP TOTAL		<u>140 tons</u>
BURNT LIME	<u>2000</u>	
DOLO LIME	<u>4700</u>	
CRG. CARBON	<u>1500</u>	

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	Tap no. _____
	_____	_____	Tap no. _____
	_____	_____	Tap no. _____
Oxy-fuel burners	_____	_____	CF _____
Vulcan lance on	_____	_____	CF CH _____
	_____	_____	CF O _____
Drop 2nd bucket	_____	_____	
Power on	_____	_____	Tap no. _____
	_____	_____	Tap no. _____
Oxy-fuel burners	_____	_____	CF _____
Vulcan lance on	_____	_____	CF CH _____
	_____	_____	CF O _____
Carbon Injector on	_____	_____	Lbs. Inj _____

Time	Temp	Time	Temp
_____	<u>2797</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 1018

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 22:54

REMARKS (list) \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_



EBT HEAT RECORD

HEAT NO: 246986 FULL WEIGHT: \_\_\_\_\_ DATE: 5-18-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOH: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ HELTER: David KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 224000 AIM GRADE: 40953 KWH USED: 52  
 AST HEAT TAPPED: 09:25 HEATS ON DELTA: 82 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID
		C	Mn	P	S	Si	Cu	Ni	Cr	tlo	Sn	V	N		
F-1		.82			.07	.10	.14		8.9					.005	53
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	80	46
SCRAP TOTAL	160000	92
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON	—	

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Tire	Temp
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

TAP TIME: 11:23

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



WORLD STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-6987 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOH: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DM KWH START: \_\_\_\_\_  
 LADLE NO: 6 WEIGHT TAPPED: 236006 R# GRADE: 409 KWH USED: 93  
 LAST HEAT TAPPED: 11:27 HEATS ON DELTA: 83 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY													TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		<u>.8</u>		<u>.05</u>	<u>.05</u>	<u>.14</u>	<u>.18</u>			<u>.8</u>					<u>.006</u>	<u>.38</u>
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
	<u>81</u>	<u>45</u>
SCRAP TOTAL	<u>162000</u>	<u>90000</u>
BURNT LIME	<u>3000</u>	
DOLO LIME	<u>3000</u>	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcrn lance on	_____	_____	_____ Lbs. Inj
Carbon Injector on	_____	_____	

Time	Temp	Time	Temp
_____	_____	_____	<u>2971</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

LADLE ALLOYS	WEIGHT(LBS)

TAP TIME: 12:40

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

IRON STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-698 FULL WEIGHT: \_\_\_\_\_ DATE: 5-17-04 KWH END: \_\_\_\_\_  
 HERTS ON BOTTOH: \_\_\_\_\_ TARE YEIGHT: \_\_\_\_\_ MELTER: 124 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 230006 AIM GRADE: 407 KWH USED: 56  
 LAST HEAT TAPPED: 12:40 HEATS ON DELTA: 84 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	C	CHEMISTRY											TOTAL RESID		
			Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		1.0		.03	.05	.19	.16			4					.007	73
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL																
BUSHELING																
SKULLS																
BUNDLES																
P/S																
SHREDDED																
SCRAP TOTAL		81	162000	90000												
BURNT LIME			3000													
DOLO LIME			5000													
CRG. CARBON																

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

lire	Terp	Time	Temp
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 14:26

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

BOUR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-6989 FULL YEIGHT: \_\_\_\_\_ DATE: 5-19-64 KUJ END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE YEIGHT: \_\_\_\_\_ RELTER: DM  
 LADLE NO: 0 WEIGHT TAPPED: 236006 AIR GRADE: 409 KWH START: 11  
 LAST HEAT TAPPED: 14:26 HEATS ON DELTA: 85 PATCH: \_\_\_\_\_ LBS USED: EE

SAMPLE	TIRE	CHEMISTRY												TOTAL RESID	
		C	Mn	P	S	Si	Cu	Ni	Cr	Ro	Sn	V	N		
F-1		1.2			06	.22	.13		11					.007	52
F-2															
F-3															
F-4															

CHARGE BKT #1 BKT X2

HOT HEEL															
BUSHELING															
SKULLS															
BUNDLES															
P/S															
SHREDDED															
SCRAP TOTAL		80	45												
BURNT LIME		3000													
DOLO LIME		5000													
CRG. CARBON															

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcrn lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcrn lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	3012
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

LADLE ALLOYS	WEIGHT (LBS)
_____	_____
_____	_____

TAP TIRE: 15:54

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 24-1090 FULL YEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOU: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: 8129 KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 232006 AIM GRADE: 409 KWH USED: 56  
 LAST HEAT TAPPED: 15:54 HEATS ON DELTA: 86 PATCH: \_\_\_\_\_ LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESXD
F-1		1.5			.04	.2	.15		71				.006	.4
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SHREDDED		
SCRAP TOTAL	16000	9000
BURNT LIME	3000	
DOLO LIME	4500	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	Tap no. _____
	_____	_____	Tap no. _____
	_____	_____	Tap no. _____
Oxy-fuel burners	_____	_____	CF _____
	_____	_____	CF CH _____
Vulcan lance on	_____	_____	CF 0 _____
Drop 2nd bucket	_____	_____	
Power on	_____	_____	Tap no. _____
	_____	_____	Top no. _____
Oxy-fuel burners	_____	_____	CF _____
	_____	_____	CF CH _____
Vulcan lance on	_____	_____	CF 0 _____
Carbon Injector on	_____	_____	Lbs. Inj _____

Time	Temp	Time	Temp
_____	_____	_____	2986
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 17:36

OXYGEN PPM

REMARKS (list) \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

EBT HEAT RECORD

HEAT NO: 24-6991 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-09 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: ML KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 236000 AIM GRADE: 409 KWH USED: 54  
 LAST HEAT TAPPED: 17:36 HEATS ON DELTA: 87 PATCH: 2200 LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID			
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V		N		
F-1		1.3			.06	.16	.14			10					.006	35
F-2																
F-3																
F-4																

CHARGE BKT #1 BKT #2

HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	16000	9000 <sup>D</sup>
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	3061
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 18:57

REMARKS (list)

OXYGEN PPM

patch 11  
Hot Mill 10

HEAT NO: 27-6992 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: DM KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 232000 AIR GRADE: 407 KWH USED: 52  
 LAST HEAT TAPPED: 18:57 HEATS ON DELTA: 88 PATCH: 4200 LBS(EST)

CHEMISTRY

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N	TOTAL RESID
F-1		1.2			.05	.15	.14		10				.004	34
F-2														
F-3														
F-4														

CHARGE BKT #1 BKT #2

HOT HEEL														
BUSHELING														
SKULLS														
BUNDLES														
P/S														
SHREDDED														
SCRAP TOTAL		160000	90000											
BURNT LIME		3000												
DOLO LIME		5000												
CRG. CARBON														

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ CF O
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
	_____	_____	_____ CF O
Vulcan lance on	_____	_____	_____ CF O
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	_____	_____	2965
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM

LADLE ALLOYS WEIGHT(LBS)


TAP TIME: 20:16

REMARKS (list)  
patch 11  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**NUCOR STEEL - CRAWFORDSVILLE**

EBT HEAT RECORD

HEAT NO: 24-6993

FULL WEIGHT: \_\_\_\_\_

DATE: 5-19-04 KWH END: \_\_\_\_\_

HEATS ON BOTTOM: \_\_\_\_\_

TARE WEIGHT: \_\_\_\_\_

MELTER: 127 KWH START: \_\_\_\_\_

LADLE NO: 0

WEIGHT TAPPED: 234000

AIM GRADE: 409 KWH USED: 52

LAST HEAT TAPPED: 20:16

HEATS ON DELTA: 89

PATCH: 2200 LBS(EST)

SAMPLE	TIME	CHEMISTRY											TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	no	Sn	V		N	
F-1		1.12			0.03	0.16									0.35
F-2															
F-3															
F-4															

CHARGE	BKT #1	BKT 12
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	160000	90000
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	_____ Tap no.
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ CF
Oxy-fuel burners	_____	_____	_____ CF CH
	_____	_____	_____ CF 0
Vulcrn lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Tiae	Temp	Time	Temp
_____	_____	_____	3057
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

LADLE ALLOYS	WEIGHT(LBS)
_____	_____
_____	_____

TAP TIME: 21:34

OXYGEN PPM

REMARKS (list) patch 11

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

NUCOR STEEL - CRAWFORDSVILLE  
EBT HEAT RECORD

HEAT NO: 24-6994 FULL WEIGHT: \_\_\_\_\_ DATE: 5-19-04 KWH END: \_\_\_\_\_  
 HEATS ON BOTTOM: \_\_\_\_\_ TARE WEIGHT: \_\_\_\_\_ MELTER: WES KWH START: \_\_\_\_\_  
 LADLE NO: 0 WEIGHT TAPPED: 230000 AIM GRADE: 408 KWH USED: 46  
 LAST HEAT TAPPED: 21:34 HEATS ON DELTA: 90 PATCH: \_\_\_\_\_ LBS(EST)

SAMPLE	TIME	CHEMISTRY												TOTAL RESID		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	N			
F-1		1.065				042		16								37
F-2																
F-3																
F-4																

CHARGE	BKT #1	BKT #2
HOT HEEL		
BUSHELING		
SKULLS		
BUNDLES		
P/S		
SHREDDED		
SCRAP TOTAL	16000	9000
BURNT LIME	3000	
DOLO LIME	5000	
CRG. CARBON		

	START	END	
Drop 1st bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Drop 2nd bucket	_____	_____	
Power on	_____	_____	_____ Tap no.
	_____	_____	_____ Tap no.
Oxy-fuel burners	_____	_____	_____ CF
	_____	_____	_____ CF CH
Vulcan lance on	_____	_____	_____ CF 0
Carbon Injector on	_____	_____	_____ Lbs. Inj

Time	Temp	Time	Temp
_____	<u>2965</u>	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

OXYGEN PPM 77

TAP TIME: 22:42

REMARKS (list)

\_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Heat # **246985**      Grade **409S2**      Operator **bfay**  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 09:39  
 Lining ID April#2 04      Lining Minutes 605      Heats 160      Min. Weight 200,000  
 Addswiz Oxygen Estimate 75046      TapToCharge 173.0248

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			

Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.582	0.270	0.040	0.065	0.158	5.970	0.140	0.005	0.008
A1	0.026	0.140	0.032	0.065	0.009	7.430	0.150	0.008	0.002
A2	0.009	0.190	0.030	0.048	0.016	9.150	0.140	0.007	0.002
A3	0.009	0.260	0.029	0.018	0.204	10.030	0.140	0.006	0.002
A4	0.010	0.280	0.029	0.018	0.322	10.620	0.140	0.007	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
42.51	6.35	30.04	20.91	0.00	0.00	25,818.52

Time	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
9:40	Chem T1					
9:55	Charge					
9:58	Sample		0.5823			6816
10:03	Temp	2753				
10:04	Decarb					
10:04	Addswiz					
10:05	Sample		0.5908	3623		10476
10:06	Decarb					
10:06	Addswiz					
10:35	Sample		0.0147	89996		80254
10:38	Temp	2980				
10:39	Decarb					
10:53	Chem A1					
10:56	Reduce					
10:58	Addswiz					
11:07	Sample		0.0067	106435		185644
11:15	Temp	2970				
11:18	Chem A2					
11:18	Addswiz					
11:22	Reduce					
11:28	Sample		0.0088	106435		207823
11:32	Temp	2887				
11:46	Addswiz					
11:50	Fuel %Al					
11:55	Sample		0.0094	116279		229997
11:59	Temp	2931				
12:11	Chem A4					
12:13	Fuel %Si					
12:16	Sample		0.0106	119817		238525
12:17	Tap					

Tap Heat	05/19/04 12:17		TOTALS	119817	0	238621
Charge Heat	05/19/04 9:55	Transfer Wt		214.000		
Charge - Tap	143	Tap Wt		238,234		

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	Recipe5	Recipe7	Stainless lime	WizDec0 1	WizDSg 01	WizRe 1
Al	500		250	1,000			200				1,0
Dolo										2,772	
FeCrSi											1,0
FeSi	1,000				250						1,5
HCFeCr									17,602		
LCCr	3,500		3,500			1,000					
Lime		1,000						5,000		1,740	
<b>Total</b>	<b>5,000</b>	<b>1,000</b>	<b>3,750</b>	<b>1,000</b>	<b>250</b>	<b>1,000</b>	<b>200</b>	<b>5,000</b>	<b>17,602</b>	<b>4,512</b>	<b>3,6</b>

Heat # 246986      Grade 409S2      Operator bfay  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created. 05119/04 12:22  
 Lining ID April#2 04      Lining Minutes 748      Heats 161      Min. Weight 200,000  
 Addswiz Oxygen Estimate 64707      TapToCharge 4.9585

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.820	0.340	0.038	0.070	0.106	8.850	0.140	0.005	0.007
A1	0.019	0.210	0.031	0.050	0.010	9.550	0.150	0.005	0.002
A2	0.011	0.300	0.029	0.045	0.122	10.9100	0.140	0.006	0.002
A3	0.010	0.320	0.030	0.031	0.189	11.000	0.140	0.006	0.002
L4	0.009	0.330	0.029	0.016	0.243	11.020	0.140	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
44.28	5.78	34.65	15.04	0.00	0.00	16,135.44,

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
12:22	Charge					
12:23	Chem T1					
12:25	Sample		0.8199			4557
12:27	Temp	2725				
12:28	Decarb					
12:28	Addswiz					
12:57	Sample		0.0148	78345		78653
13:01	Temp	2999.				
13:02	Decarb					
13:06	Chem A1					
13:12	Reduce					
13:13	Addswiz					
13:19	Sample		0.0040	89910		139344
13:22	Temp	3074				
13:26	Chem A2					
13:29	Reduce					
13:33	Sample		0.0124	89910		155807
13:39	Temp	3015				
13:46	Chem A3					
13:48	Reduce					
13:54	Sample		0.0100	89910		176715
14:04	Tap					

Tap Heat	05/19/04 14:04		<b>TOTALS</b>	<b>89910</b>	<b>0</b>	<b>176832</b>
Charge Heat	05/19/04 12:22	Transfer Wt	224,000			
Charge - Tap	102	Tap Wt	234,273			

ADDITIONS	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Tot:
Al	250		300						816	700	2,0
Dolo								2,134			2,1
FeCrSi									1,000		1,0
FeSi	350		150						1,225	1,000	2,7
HCFeCr							10,000				10,0
LCCr	750				500						1,2
Lime		1,000		500		5,000		500			7,0
<b>Total</b>	<b>1,350</b>	<b>1,000</b>	<b>450</b>	<b>500</b>	<b>500</b>	<b>5,000</b>	<b>10,000</b>	<b>2,634</b>	<b>3,041</b>	<b>1,700</b>	<b>26,1</b>

Heat# 246987      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 14:11  
 Lining ID April#2 04      Lining Minutes 850      Heats 162      Min. Weight 200,000

AddsWiz Oxygen Estimate 81095      TapToCharge 6.929333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	0.817	0.330	0.035	0.054	0.138	8.010	0.150	0.005	0.008
A1	0.006	0.210	0.028	0.052	0.009	8.710	0.170	0.005	0.002
A2	0.009	0.310	0.027	0.013	0.056	11.280	0.160	0.006	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.13	8.17	29.19	11.28	0.00	0.00	22,464.85

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
14:11	Charge					
14:12	Chem T1					
14:13	Sample		0.8175			4428
14:15	Temp	2643				
14:16	Decarb					
14:16	Sample		0.8175	45		6722
14:22	Decarb					
14:22	AddsWiz					
14:54	Sample		0.0147	94780		83063
14:56	Temp	3158				
14:57	Decarb					
15:01	Sample		0.0065	96805		101020
15:03	Temp	3065				
15:04	Decarb					
15:09	Chem A1					
15:09	Reduce					
15:09	AddsWiz					
15:21	Sample		0.0071	101121		163460
15:27	Temp	3043				
15:30	Chem A2					
15:31	Reduce					
15:36	Sample		0.0095	101121		179103
15:37	Tap					

Tap Heat	05/19/04 15.37	<b>TOTALS</b>	<b>101121</b>	<b>0</b>	<b>179216</b>
Charge Heat	05/19/04 14:11	Transfer Wt	236.000		
<b>Charge - Tap</b>	<b>86</b>	<b>Tap Wt</b>	<b>247,565</b>		

<b>ADDITIONS</b>	Recipe1	Recipe2	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	<b>Total</b>
Al	100					1,154	600		<b>1,854</b>
Dolo					2,997			1,273	<b>4,270</b>
FeCrSi						1,000			<b>1,000</b>
FeSi	400	250				1,814	800		<b>3,264</b>
HCFeCr				13,000					<b>13,000</b>
Lime			5,000		2,310			2,823	<b>10,133</b>
<b>Total,</b>	<b>500</b>	<b>250</b>	<b>5,000</b>	<b>13,000</b>	<b>5,307</b>	<b>3,968</b>	<b>1,400</b>	<b>4,096</b>	<b>33,521</b>

Heat # **246988** Grade **409S2** Operator jnichols  
 Practice CRSS LCLN Slag ANY SS GRADE Heat Created 05/19/04 15:40  
 Lining ID April#2 04 Lining Minutes 935 Heats 163 Min. Weight 200,000

AddsWiz Oxygen Estimate 73566 TapToCharge 3.925

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.046	0.340	0.034	0.049	0.189	9.070	0.120	0.007	0.014
A1	0.009	0.250	0.028	0.049	0.010	9.980	0.140	0.005	0.002
A2	0.008	0.330	0.028	0.008	0.236	11.350	0.130	0.006	0.003

PctCaO	PctMgO	PctSiO2 <sub>21</sub>	PctAl2O3 <sub>13-14</sub>	PctCr2O3	PctFeO	WtSlag
49.12	7.18	30.54	12.78	0.00	0.00	16,048.11

Time	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnk
15:40	Charge					
15:44	Chem T1					
15:45	Sample		1.0456			8512
15:47	Temp	2669				
15:47	Decarb					
15:48	AddsWiz					
16:17	Sample		0.0148	82585		84681
16:20	Temp	3041				
16:20	Decarb					
16:24	Chem A1					
16:27	Reduce					
16:27	AddsWiz					
16:37	Sample		0.0057	89875		145934
16:44	Temp	3071				
16:47	Tap					

Tap Heat	05/19/04 16:47	<b>TOTALS</b>	<b>89875</b>	<b>0</b>	<b>146049</b>
Charge Heat	05/19/04 15:40	Transfer Wt	230,000		
Charge - Tap	67	Tap Wt	<b>235,622</b>		

'ADDITIONS	Recipe1	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al				1,200	250		1,450
Dolo			2,190			700	2,890
FeCrSi				1,000			1,000
FeSi				1,022	708		1,730
HCFeCr	1,000	6,774					7,774
Lime			450			1,500	1,950
<b>Total</b>	<b>1,000</b>	<b>6,774</b>	<b>2,640</b>	<b>3,222</b>	<b>958</b>	<b>2,200</b>	<b>16,794</b>

Heat# 246989 Grade 409S2 Operator jnichols  
 Practice CRSS LCLN Slag ANY SS GRADE. Heat Created 05/19/04 16:56  
 Lining ID April#2 04 Lining Minutes 1002 Heats 164 Min. Weight 200,000  
 Addswiz Oxygen Estimate 63016 TapToCharge 25.796

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.181	0.310	0.033	0.056	0.224	10.870	0.140	0.007	0.018
A1	0.024	0.270	0.027	0.054	0.010	10.590	0.150	0.005	0.002
A2	0.009	0.320	0.027	0.006	0.150	11.370	0.140	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.48	8.28	26.46	13.26	0.02	0.00	15,319.50

TimeActivity	Activity	Temp	%C	O2 Cnt	N2 Cnts	Ar Cnts
16:56	Chem T1					
17:13	Charge					
17:18	Sample		1.1813			9086
17:19	Temp	2719				
17:20	Decarb					
17:21	Addswiz					
17:48	Sample		0.0148	71185		86518
17:50	Temp	3031				
17:51	Decarb					
17:57	Chem A1					
18:04	Reduce					
18:04	Addswiz					
18:15	Sample		0.0064	81893		174900
18:18	Temp	3057				
18:41	Reduce					
18:42	Sample		0.0064	81893		181362
18:44	Tap					
Tap Heat	05/19/04 18:44		<b>TOTALS</b>	81893	0	181472
Charge Heat	05/19/04 17:13	Transfer Wt	234,000			
Charge - Tap	91	Tap Wt	232,455			

ADDITIONS	Recipe1	Recipe2	Stainless lime	WizDSg 01	WizRed0 1	WizRed0 2	WizRSg 01	Total
Al					1,000	450		1,450
Dolo				1,808			1,077	2,885
FeCrSi					509			509
FeSi		200			541	600		1,341
HCFeCr	750							750
Lime			5,000				1,851	6,851
<b>Total</b>	750	200	5,000	1,808	2,050	1,050	2,928	13,786

Heat# 246990      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 18:46  
 Lining ID April#2 04      Lining Minutes 1093      Heats 165      Min. Weight 200,000

AddsWiz Oxygen Estimate 69766      TapToCharge 2.133333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.526	0.410	0.034	0.049	0.205	10.900	0.190	0.006	0.016
A1	0.059	0.370	0.028	0.041	0.010	11.070	0.190	0.004	0.002
A2	0.006	0.400	0.028	0.003	0.192	11.390	0.190	0.004	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
51.12	7.72	24.39	16.12	0.03	0.00	13,346.82

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
18:46	Charge					
18:46	Chem T1					
18:50	Sample		1.5260			6600
18:52	Temp	2773				
18:53	Decarb					
18:55	AddsWiz					
19:23	Sample		0.0148	77151		87515
19:25	Temp	3023				
19:25	Decarb					
19:29	Chem A1					
19:44	Reduce					
19:44	AddsWiz					
19:51	Sample		0.0035	90528		186898
19:56	Temp	3109				
20:03	Reduce					
20:03	Chem A2					
20:04	Sample		0.0064	90528		193620
20:05	Tap					
Tap Heat	05/19/04 20:05		<b>TOTALS</b>	<b>90528</b>	<b>0</b>	<b>193744</b>
Charge Heat	05/19/04 18:46	Transfer Wt	236.000			
Charge - Tap	<b>79</b>	Tap Wt	<b>232,566</b>			

ADDITIONS	Recipe1	Recipe2	Stainless lime	WizDSg 01	WizRed0 1	WizRed0 2	Total
Al					900	600	1,500
Dolo				2,500			2,500
FeSi		150				1,000	1,150
HCFeCr	500						500
Lime			5,000	1,500			6,500
<b>Total</b>	<b>500</b>	<b>150</b>	<b>5,000</b>	<b>4,000</b>	<b>900</b>	<b>1,600</b>	<b>12,150</b>

Heat# 246991      Grade 40982      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 20:07  
 Lining ID April#2 04      Lining Minutes 1172      Heats 166      Min. Weight 200,000

AddsWiz Oxygen Estimate 60933      TapToCharge 2.158333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.265	0.270	0.032	0.062	0.163	10.240	0.160	0.006	0.015
A1	0.056	0.250	0.027	0.032	0.009	10.420	0.160	0.004	0.002
A2	0.008	0.290	0.026	0.004	0.143	11.130	0.160	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
55.64	9.29	20.82	13.74	0.02	0.00	15,580.41

TimeActivity	Activity	Temp	%C	O 2 Cnts	N2 Cnts	Ar Cnts
20:07	Charge					
20:08	Chem T1					
20:11	Sample		1.2647			6145
20:12	Temp	2884				
20:13	Decarb					
20:14	AddsWiz					
20:42	Sample		0.0148	70455		83622
20:44	Temp	3038				
20:45	Decarb					
20:49	Chem A1					
21:02	Reduce					
21:02	AddsWiz					
21:09	Sample		0.0034	82362		175733
21:13	Temp	3122				
21:17	Reduce					
21:17	Chem A2					
21:19	Sample		0.0078	82362		183385
21:20	Tap					
Tap Heat	05/19/04 21:20		<b>TOTALS</b>	82362	0	183481
Charge Heat	05/19/04 20:07	Transfer Wt	234,000			
Charge - Tap	72	Tap Wt	234,190			

ADDITIONS	Recipe1	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total	
Al					900	600	1,500	
Dolo				3,400			3,400	
FeCrSi					616		616	
FeSi		300				800	1,100	
HCFeCr			2,800				2,800	
Lime		5,000		3,000			8,000	
<b>Total</b>		300	5,000	2,800	6,400	1,516	1,400	17,416



**ADDITIONS**

	Recipe1	Recipe2	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	<b>Total</b>
1006	1,500							<b>1,500</b>
Al						1,000	450	<b>1,450</b>
Dolo					3,500			<b>3,500</b>
FeCrSi						1,000		<b>1,000</b>
FeSi		600					350	<b>950</b>
HCFeCr				4,000				<b>4,000</b>
LCCr		700						<b>700</b>
Lime			5,000		3,000			<b>8,000</b>
<b>Total</b>	<b>1,500</b>	<b>1,300</b>	<b>5,000</b>	<b>4,000</b>	<b>6,500</b>	<b>2,000</b>	<b>800</b>	<b>21,100</b>

Heat # 246993      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 22:30  
 Lining ID April#2 04      Lining Minutes 1311      Heats 168      Min. Weight 200,000

AddsWiz Oxygen Estimate 72507      TapToCharge 1.558333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.123	0.340	0.030	0.047	0.170	9.380	0.140	0.006	0.012
A1	0.031	0.300	0.024	0.039	0.010	10.040	0.150	0.004	0.002
A2	0.011	0.350	0.024	0.003	0.209	11.000	0.140	0.006	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.97	8.24	21.86	14.48	0.00	0.00	15.733 01

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
22:30	Charge					
22:32	Chem T1					
22:34	Sample		1.1233			6708
22:35	Temp	2805				
22:35	AddsWiz					
22:36	Decarb					
23:05	Sample		0.0148	76200		81759
23:06	Temp	3048				
23:08	Decarb					
23:10	Chem A1					
23:20	Reduce					
23:20	AddsWiz					
23:27	Sample		0.0059	82297		156354
23:31	Temp	3043				
23:34	Chem A2					
23:35	Reduce					
23:36	Sample		0.0109	82297		161991
23:37	Tap					

Tap Heat	05/19/04 23:37		<b>TOTALS</b>	<b>82297</b>	<b>0</b>	<b>162100</b>
Charge Heat	05/19/04 22:30	Transfer Wt	233.000			
<b>Charge - Tap</b>	<b>67</b>	<b>Tap Wt</b>	<b>239,806</b>			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
1006	300		1,000				1,500		2,800
Al							1,175	400	1,575
Dolo						3,000			3,000
FeCrSi							1,000		1,000
FeSi		175					450	300	925
HCFeCr					5,625				5,625
LCCr		1,200							1,200
Lime				5,000		3,000			8,000
<b>Total</b>	<b>300</b>	<b>1,375</b>	<b>1,000</b>	<b>5,000</b>	<b>5,625</b>	<b>6,000</b>	<b>4,125</b>	<b>700</b>	<b>24,125</b>

---

Nucor Steel - Crawfordsville AOD Log

Heat # 246994      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/19/04 23:38  
 Lining ID April#2 04      Lining Minutes 1378      Heats 169      Min. Weight 200,000

AddsWiz Oxygen Estimate 66721      TapToCharge 1.45

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.066	0.330	0.024	0.043	0.172	9.160	0.150	0.007	0.014
A1	0.033	0.310	0.021	0.024	0.009	10.140	0.160	0.005	0.002
A2	0.009	0.360	0.021	0.008	0.140	11.340	0.160	0.005	0.004

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
53.01	5.85	23.72	16.90	0.01	0.00	15,326.78

Time	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
23 39	Charge					
23 39	Chem T1					
23 42	Sample		1 0655			5320
23 43	Temp	2789				
23 43	AddsWiz					
23 44	Decarb					
0 12	Sample		0.0148	74717		78605
0 14	Temp	3019				
0 14	Decarb					
0 18	Chem A1					
0 28	Reduce					
0 28	AddsWiz					
0 34	Sample		0 0059	83750		152677
0 38	Temp	3095				
0 42	Chem A2					
0 44	Chem A2					
0 44	Reduce					
0 46	Sample		0.0095	83750		159257
0 47	Tap					
Tap Heat	05/20/04 0 47		<b>TOTALS</b>	<b>83750</b>	<b>0</b>	<b>159362</b>
Charge Heat	05/19/04 23 39	Transfer Wt	229,000			
Charge - Tap	68	Tap Wt	237,513			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Stainless lime	WizDec0 1	WizDSg 01	WizRed0 1	WizRed0 2	Total
1006	300	1,500	1,000				1,500		4,300
Al							1,100	700	1,800
Dolo						2,000			2,000
FeCrSi							1,000		1,000
FeSi		350					150	650	1,350
HCFeCr					6,374				6,374
LCCr		500							500
Lime				5,000		3,000			8,000
<b>Total</b>	<b>300</b>	<b>2,350</b>	<b>1,000</b>	<b>5,000</b>	<b>6,374</b>	<b>5,000</b>	<b>3,750</b>	<b>1,350</b>	<b>25,124</b>

---

Heat # 246995      Grade 409S2      Operator jnichols  
 Practice CRSS LCLN      Slag ANY SS GRADE      Heat Created 05/20/04 00:48  
 Lining ID April#2 04      Lining Minutes 1446      Heats 170      Min. Weight 200,000  
 Addswiz Oxygen Estimate 14025      TapToCharge 1.683333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.004				0.100	11.050			
Max	0.015			0.010	0.200	11.250			
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
T1	1.156	0.330	0.029	0.049	0.228	9.490	0.140	0.006	0.015
A1	0.031	0.280	0.023	0.038	0.009	10.540	0.150	0.004	0.002
A2	0.009	0.330	0.024	0.003	0.171	11.4200	0.150	0.005	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
54.48	6.00	22.95	13.82	2.62	0.00	14,875.93

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
0:48	Charge					
0:49	Chem T1					
0:51	Sample		1.1557			5506
0:53	Temp	2800				
0:53	Addswiz					
0:54	Decarb					
1:21	Sample		0.0148	74799		77818
1:23	Temp	3040				
1:24	Decarb					
1:29	Chem A1					
1:38	Reduce					
1:39	Addswiz					
1:39	Addswiz					
1:39	Addswiz					
1:46	Sample		0.0054	82790		160007
1:50	Temp	3064				
1:55	Chem A2					
1:57	Reduce					
1:57	Chem A2					
1:59	Sample		0.0096	82790		165050
1:59	Tap					

Tap Heat	05120104	1:59		<b>TOTALS</b>	<b>82790</b>	<b>0</b>	<b>165152</b>
Charge Heat	05120104	0:48	Transfer Wt	232,000			
Charge - Tap	71		Tap Wt	236,423			

**ADDITIONS**

	Recipe1	Recipe2	Recipe3	Recipe4	Recipe5	WizDec0 1	WizRed0 1	Total
1006		300			500		1,500	2,300
Al				500			950	1,450
Dolo	2,000		1,500					3,500
FeCrSi							1,000	1,000
FeSi				400	250		147	797
HCFeCr						5,103		5,103
LCCr								
Lime	3,000		3,000					6,000
<b>Total</b>	<b>5,000</b>	<b>300</b>	<b>4,500</b>	<b>900</b>	<b>750</b>	<b>5,103</b>	<b>3,597</b>	<b>20,150</b>

---

Nucor Steel - Crawfordsville AOD Log

Heat # 246996      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/20/04 02:02  
 Lining ID April#2 04      Lining Minutes 1517      Heats 171      Min. Weight 200.000

AddsWiz Oxygen Estimate

TapToCharge 7.166667

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	0.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.107	0.130	0.012	0.065	0.010	0.781	0.050	0.007	0.002
T1	0.051	0.090	0.010	0.064	0.001	0.563	0.052	0.009	0.002
A1	0.013	0.590	0.012		0.415	0.579	0.053	0.004	0.003
A2	0.013	0.590	0.012		0.381	0.587	0.052	0.004	0.003

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
52.80	9.57	11.48	25.69	0.00	0.00	6,805.43

TimeActivity	Activity	Temp	%C	O 2 Cnts	N2 Cnts	Ar Cnts
2:06	Chem T1					
2:07	Charge.					
2:09	Decarb					
2:15	Reduce					
2:22	Sample		0.0401	12346		37405
2:27	Temp	3007				
2:28	Chem A1					
2:29	Fuel %Al					
2:30	Reduce					
2:30	Reduce					
2:33	Sample		0.0141	14142		47833
2:35	Temp	3011				
2:38	Chem A2					
2:38	Fuel %Al					
2:39	Reduce					
2:42	Sample		0.0130	15112		56695
2:42	Tap					

Tap Heat	05/20/04 2:42		<b>TOTALS</b>	<b>15112</b>	<b>0</b>	<b>56889</b>
Charge Heat	05/20/04 2:07	Transfer Wt	232,997			
Charge - Tap	36	Tap Wt	235,465			

ADDITIONS	Recipe1	Recipe2	Recipe4	Recipe5	Recipe6	Total
1006					100	100
Al	500	800				1,300
Dolo			1,500			1,500
FeSi		1,200				1,200
Lime			3,000			3,000
Med C		1,300		100		1,400
<b>Total</b>	<b>500</b>	<b>3,300</b>	<b>4,500</b>	<b>100</b>	<b>100</b>	<b>8,500</b>

Heat# 246997      Grade 1005S1      Operator jnichols  
 Practice Castrip      Slag LCLNCarbon      Heat Created 05/20/04 02:47  
 Lining ID April#2 04      Lining Minutes 1553      Heats 172      Min. Weight 200,000

AddsWiz Oxygen Estimate

TapToCharge 12.73333

Spec	C	Mn	P	S	Si	Cr	Ni	N	Ti
Min	0.010	0.250			0.150				
Max	3.040	0.450			0.200				
Sample	C	Mn	P	S	Si	Cr	Ni	N	Ti
F1	0.051	0.050	0.003	0.037		0.135	0.022	0.008	0.002
L1	0.012	0.570	0.004		0.319	0.165	0.023	0.004	0.002
A1	0.012	0.570	0.004		0.316	0.164	0.022	0.004	0.002

PctCaO	PctMgO	PctSiO2	PctAl2O3	PctCr2O3	PctFeO	WtSlag
57.16	10.24	12.75	19.73	0.00	0.00	6,322.28

TimeActivity	Activity	Temp	%C	O2 Cnts	N2 Cnts	Ar Cnts
2:48	Ch m F1					
2:55	Charge					
2:58	Decarb					
3:03	Reduce					
3:11	Sample		0.0289	12162		38147
3:17	Temp	2989				
3:20	Ch m A1					
3:20	Reduce					
3:22	Sample		0.0136	12162		43471
3:23	Tap					

Tap Heat	05/20/04 3:23		<b>TOTALS</b>	<b>12162</b>	<b>0</b>	<b>43598</b>
Charge Heat	05/20/04 2:55	Transfer Wt	236,000			
<b>Charge - Tap</b>	<b>28</b>	<b>Tap Wt</b>	<b>238,596</b>			

ADDITIONS	Recipe1	Recipe3	Recipe4	Total
Al	500	850		1,350
FeSi		1,200		1,200
Med C		1,400	150	1,550
<b>Total</b>	<b>500</b>	<b>3,450</b>	<b>150</b>	<b>4,100</b>

**Castrip LMS Baghouse testing for Emissions:**

**Test Date: 01/03/2003**

**Production Rate: Approximately 53.8 tph, LMS only.**

**The process and air pollution control equipment were operating normally at the time of testing.**

#63324

4.2

47.1

DAE  
SBC  
HAW  
16.1

**ATP** – Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 46219

(317) 345-1720 FAX (317) 351-0411

---

**REPORT on Compliance Testing  
For CO, NO<sub>x</sub>, SO<sub>2</sub>, Lead and PM/PM<sub>10</sub> TESTING**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**Castrip**  
on October 2<sup>nd</sup>, 3<sup>rd</sup> and 5<sup>th</sup>, 2006

---

---

**REPORT on Compliance Testing  
For CO, NOx, SO2, Lead and PM/PM10 TESTING**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**Castrip**  
on October 2<sup>nd</sup>, 3<sup>rd</sup> and 5<sup>th</sup>, 2006

RECEIVED  
NOV 24 2006  
State of Indiana  
Department of Environment & Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:



Andrew Young, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
2.	<b>RESULTS</b>	
	PM/PM10, CO, NO <sub>x</sub> & SO <sub>2</sub> , Table 2-1	2-1
	LEAD EMISSIONS, Table 2-2	2-2
	VISIBLE EMISSIONS, Table 2-3	2-3
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	PRODUCTION DATA	I

## 1-1 PROJECT OVERVIEW

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling at the LMS baghouse stack that controls emissions from the LMS and Strip Caster. The sampling was performed in Crawfordsville, Indiana on October 2<sup>nd</sup>, 3<sup>rd</sup> and 5<sup>th</sup>, 2006. The objective of the testing was to determine compliance with permit requirements for the pollutants listed below. The following personnel were involved with the testing program:

ATP	Carlos Brown
ATP	Andrew Young
ATP	Nita Greenburg
Nucor	Trevor Beers
Nucor	Eric Ferguson
IDEM	David Harrison

The testing program included flow and gas analysis (US EPA Methods 1-4), particulate (US EPA Method 5), condensible particulate matter (US EPA Method 202), Carbon Monoxide emissions (US EPA Method 10), Nitrogen Oxide emissions (US EPA Method 7E), Sulfur Dioxide emissions (US EPA Method 6C), Lead emissions (US EPA Method 29) and visible emissions (US EPA Method 9.) Listed below is a summary of the results.

**Test Summary**  
Table 1-1

Pollutant	Filterable (PM/PM10)	Filterable & Condensable (PM/PM10)	Permitted Emission Limits
Particulate Matter	*0.0016 (gr/dscf) 0.0146 (lb/ton)	0.0067 (gr/dscf) 0.0630 (lb/ton)	*0.0018 / 0.0052 (gr/dscf)

Pollutant	Total Lead	Permitted Emission Limit
Lead	3.57E-06 (lb/ton)	3.30E-04 (lb/ton)

Pollutant	Average Emissions	Permitted Emission Limits
Carbon Monoxide	0.129 (lb/ton) <sup>13</sup>	0.141 (lb/ton)
Nitrogen Oxide	0.05 (lb/ton)	0.19 (lb/ton)
Sulfur Dioxide	0.189 (lb/ton) <sup>175</sup>	0.210 (lb/ton)

**2-1 RESULTS**

**PM/PM10, CO, NOx and SO2 Emissions**  
*Castrip Baghouse Stack*

Table 2-1

<u>Gas Conditions</u>		1	2	3	Average
Ts	Stack Temperature	122.4	154.2	127.4	134.7
Bwo	Moisture (volume %)	1.75	2.53	1.75	2.01
O2	Oxygen (dry volume %)	20.0	20.0	20.0	20.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b><u>Volumetric Flow Rate</u></b>					
Qa	Actual Conditions (acfm)	132,707	128,339	130,733	130,593
Qstd	Standard Conditions (dscfm)	119,018	108,319	116,279	114,539
<b>PM/PM10</b>					
ETSP	Filterable (gr/dscf)	0.0017	0.0018	0.0012	<b>0.0016</b>
E	Filterable & Condensable (gr/dscf)	0.0034	0.0057	0.0108	<b>0.0067</b>
<b>PM/PM10</b>					
ETSP	Filterable (lb/ton)	0.0164	0.0157	0.0118	<b>0.0146</b>
E	Filterable & Condensable (lb/ton)	0.0330	0.0498	0.1062	<b>0.0630</b>
<b>CARBON MONOXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	17.14	18.21	44.29	26.55
E	Emission (lb/ton)	0.0838	0.0805	0.2213	<b>0.1285</b>
<b>NITROGEN OXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	6.32	3.62	10.51	6.82
E	Emission (lb/ton)	0.0508	0.0263	0.0863	<b>0.0544</b>
<b>SULFUR DIOXIDE</b>					
C <sub>gas</sub>	Emission (PPM)	11.32	21.45	19.63	17.47
E	Emission (lb/ton)	0.1266	0.2169	0.2244	<b>0.1893</b>

**2-2 RESULTS**

**LEAD EMISSIONS**  
*Castrip Baghouse Stack*

Table 2-2

<u>Gas Conditions</u>		1	2	3	Average
Ts	Stack Temperature	118.6	152.0	127.1	132.5
Bwo	Moisture (volume %)	1.76	2.25	2.09	2.03
O2	Oxygen (dry volume %)	20.0	20.0	20.0	20.0
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	132,739	134,292	131,593	132,875
Qstd	Standard Conditions (dscfm)	119,764	113,724	116,697	116,728
<u>Lead Emissions</u>					
E	Emission Rate (lb/ton)	6.26E-06	3.38E-06	1.07E-06	3.57E-06

**2-3 RESULTS**

---

**VISIBLE EMISSIONS - OPACITY**  
*Castrip Baghouse Stack*

Table 2-3

<b>Run No.</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>Average</b>
Date	October 2, 2006	October 3, 2006	October 5, 2006	
Start Time (approx)	09:02	14:32	09:04	
Stop Time (approx)	10:02	15:32	10:04	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	<b>0.0 %</b>

### **3-1 PROCESS DESCRIPTION**

---

Nucor Steel of Crawfordsville, Indiana operates the units listed below:

A Strip Caster Line rated at a maximum steel production rate of 270 tons per hour from the existing electric arc furnace (EAF) and is capable of producing several grades of steel at various widths and thicknesses:

1. One (1) ladle metallurgy station (LMS) identified as LMS-2. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
2. One (1) tundish that feeds the molten metal from the LMS ladle to one (1) continuous strip caster. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
3. One (1) hot rolling stand. The stand rolls the steel strips from the continuous strip caster to a desired gauge.
4. Two (2) coilers. After the strip passes the rolling mill it is then rolled into coils.

The testing reported in this document was performed at the LMS baghouse stack.

## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

### Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determining of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 5	"Determination of Particulate Emissions from Stationary Sources"
Method 6C	"Determination of Sulfur Dioxide Emissions from Stationary Sources"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide Emissions from Stationary Sources"
Method 12	"Determination of Lead Emissions from Stationary Sources"
Method 9	"Visual Determination of the Opacity from Stationary Sources"

### Title 40 CFR Part 51 Appendix M

Method 202	"Determination of Condensable Particulate Emissions from Stationary Sources"
------------	--

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

### Sampling Points

Table 4-1

Location/Pollutant	Dimensions	Points/Port	Total Points
<u>LMS Baghouse Stack</u>			
PM/PM10	96" ID	12	24
Lead	96" ID	6	24

---

## 4-2 METHODOLOGY

---

### **SAMPLE AND VELOCITY TRAVERSE – EPA METHOD 1**

Method 1 is utilized for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction, is selected and divided into a sample grid according to the published percentages of the diameter. A traverse point is then located at each of these percentage points. Sampling or velocity measurement is performed at a site located at least two stack or duct diameters downstream and one-half diameter upstream from a disturbance such as a bend, expansion, contraction, or visible flame.

### **VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT – EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined volumetrically and gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **PARTICULATE/CONDENSIBLE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle and filter. Condensible particulate is captured in the first three impingers; each impinger contains 100 mls of deionized water. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit.

The nozzle and glass filter holder are rinsed with acetone and captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with deionized water and captured in a sealed container. Two rinses of methylene chloride were captured and stored in a sealed container.

### **SULFUR DIOXIDE CONCENTRATION – EPA METHOD 6C**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to an NDIR or fluorescence analyzer for SO<sub>2</sub> concentration determination. The moisture in the wet stack gas is removed before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

## **4-2 METHODOLOGY, cont.**

---

### **NITROGEN OXIDE CONCENTRATION – EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NO<sub>x</sub> concentration determination. The moisture in the wet stack gas is removed before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **CARBON MONOXIDE CONCENTRATION – EPA METHOD 10**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a non-dispersive infrared (NDIR) analyzer for CO concentration determination. The moisture in the wet stack gas is removed before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **LEAD EMISSIONS DETERMINATION – EPA METHOD 12**

Stack gas is withdrawn isokinetically and Lead particulate matter is collected on the nozzle, probe and filter. Lead particulate matter is also captured in the first two impingers; each impinger contains 100 mls of 0.1 N Nitric Acid. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit, while the probe and filter are maintained at temperatures of 248 degrees F(+/- 25 deg F.) The probe, nozzle, impingers and glass filter holder are rinsed with approximately 100 mLs of 0.1 N nitric acid and captured in a sealed glass container.

### **VISIBLE EMISSIONS – EPA METHOD 9**

Stack opacity readings were taken at 15-second intervals, for 60-minutes per each 60-minutes tested by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs. The results are reported as an average emissions percentage for each test period. Copies of the visible emissions certification cards are included in Appendix G.

**APPENDIX A**

---

## SAMPLE CALCULATIONS

---

### 1. Volume of water collected (wstd)

$$V_{wstd} = (0.04707)(V_{lc})$$

$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{lc}$	total volume of liquid collected in impingers and silica (ml)
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered at standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{baro} + \frac{\Delta H}{13.6} \right) (\Gamma_d)}{(460 + T_m)}$$

$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
$V_m$	volume of sample gas through dry gas meter at meter conditions (ft <sup>3</sup> )
$P_{baro}$	barometric pressure (in Hg)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
$\Gamma_d$	gas meter correction factor (dimensionless)
$T_m$	average dry gas meter temperature (°F)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	conversion constant, °F to °R

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left( \frac{P_g}{13.6} \right)$$

$P_s$	absolute sample gas pressure (in Hg)
$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

### 4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

5. Moisture content (%)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )

6. Saturated moisture content (%)

$$B_{ws} = \frac{P_v}{P_s}$$

$B_{ws}$	portion of water vapor in gas stream by volume at saturated conditions (%)
$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \left( \frac{CO_2}{100} \right) + M_{O_2} \left( \frac{O_2}{100} \right) + M_{CO+N_2} \left( \frac{CO + N_2}{100} \right)$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$M_{CO_2}$	molecular weight of carbon dioxide (lb/lb-mole)
$M_{O_2}$	molecular weight of oxygen (lb/lb-mole)
$M_{CO+N_2}$	molecular weight of carbon monoxide and nitrogen (lb/lb-mole)
$CO_2$	portion of carbon dioxide in the gas stream by volume (%)
$O_2$	portion of oxygen in the gas stream by volume (%)
$CO+N_2$	portion of carbon monoxide and nitrogen in gas stream by volume (%)
100	conversion factor (%)

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{ws}) + (M_{H_2O})(B_{wo})$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \left( \sqrt{\frac{(t_s + 460)}{(M_s)(P_s)}} \right)$$

$V_s$	average sample gas velocity (ft/sec)
$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$\Delta P$	average differential pressure in the gas stream (in H <sub>2</sub> O)
$t_s$	average sample gas temperature (°F)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in Hg)
460	conversion constant, °F to °R

10. Total flow of sample gas (acfm)

$$Q_a = (60)(A_s)(V_s)$$

$Q_a$	volumetric flow rate at actual conditions (acfm).
$A_s$	cross-sectional area of sampling location (ft <sup>2</sup> )
$V_s$	average sample gas velocity (ft/sec)
60	conversion factor (seconds/minute)

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a)(P_s)(17.64)(1 - B_{wo})}{(t_s + 460)}$$

$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
$Q_a$	volumetric flow rate at actual conditions (acfm)
$P_s$	absolute sample gas pressure (in Hg)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$t_s$	average sample gas temperature (°F)
17.64	conversion factor (°R/in Hg)
460	conversion constant, °F to °R

12. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{mstd})}{(P_s)(V_s) \left( \frac{(D_n)^2(\pi)}{(144)(4)} \right) (\theta)(1 - B_{wo})}$$

I	percent relative to isokinetic sampling (%)
T <sub>s</sub>	absolute sample gas temperature (°R)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
P <sub>s</sub>	absolute sample gas pressure (in Hg)
V <sub>s</sub>	average sample gas velocity (ft/sec)
D <sub>n</sub>	diameter of nozzle (inches)
B <sub>wo</sub>	portion of water vapor in the gas stream by volume (%)
θ	total sample time (minutes)
0.09450	conversion constant

13. Particulate concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(M_n)}{V_{mstd}}$$

C <sub>gr/dscf</sub>	measured concentration in gas stream (gr/dscf)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor (grains/gram)

14. Particulate emissions, mass emission rate (lbs/hr)

$$E_{lb/hr} = \frac{(M_n)(Q_{std})}{(7.567)(V_{mstd})}$$

E <sub>lbs/hr</sub>	mass emission rate (lbs/hr)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
7.567	conversion factor (grams/pound)

15. Gas emission concentration (ppm)

$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

$C_{gas}$	effluent gas concentration (ppm)
$\bar{C}$	average gas concentration indicated by gas analyzer (ppm)
$C_o$	average of initial and final system bias checks for zero gas (ppm)
$C_{ma}$	actual concentration of the upscale gas (ppm)
$C_m$	average of initial and final system bias check for upscale cal gas (ppm)

16. Carbon Monoxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(1.3762 \times 10^7)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$1.3762 \times 10^7$	CO conversion factor (ppm to lbs/dscf)

17. Nitrogen Oxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(8.3752 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$8.3752 \times 10^6$	NOx conversion factor (ppm to lbs/dscf)

18. Sulfur Dioxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(6.0151 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$6.0151 \times 10^6$	SO2 conversion factor (ppm to lbs/dscf)

19. Pollutant emission rate (lbs/ton)

$$E_{lbs/ton} = \frac{(E)}{(P_{tons/hr})}$$

$E_{lbs/ton}$	emission rate (lbs/ton)
E	pollutant emission rate (lbs/hr)
$P_{tons/hr}$	facility production rate (tons/hr)

**APPENDIX B**

---

**FIELD DATA PRINTOUTS**

Particulate & Gas Emissions

## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	CASTRIP
Date:	10/2-3/06 - 10/05/06

	Run 1	Run 2	Run 3	Average
<b>Particulate Concentration</b>				
Filterable PM/PM10 (gr/dscf)	0.0017	0.0018	0.0012	<b>0.0016</b>
Filterable and Condensable PM/PM10 (gr/dscf)	0.0034	0.0057	0.0108	<b>0.0067</b>
Filterable (lbs/ton)	0.0164	0.0157	0.0118	<b>0.0146</b>
Filterable + Condensable (lbs/ton)	0.0330	0.0498	0.1062	<b>0.0630</b>
<b>Gas Concentration</b>				
Carbon Monoxide (lbs/ton)	0.0838	0.0805	0.2213	<b>0.1285</b>
Nitrogen Oxide (lbs/ton)	0.0508	0.0263	0.0863	<b>0.0544</b>
Sulfur Dioxide (lbs/ton)	0.1266	0.2169	0.2244	<b>0.1893</b>
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	132,707	128,339	130,733	130,593
DSCFM	119,018	108,319	116,279	114,539
<b>Avg. Stack Temp</b>	122.42	154.21	127.38	134.67
<b>Stack Gas Velocity</b>	44.002	42.554	43.347	43.301
<b>Avg. Velocity Head</b>	0.555	0.491	0.535	0.527
<b>Avg. Sq. Rt of Delta P</b>	0.745	0.700	0.731	0.726
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 90-110%	100.23	101.40	99.75	100.46
% Moisture of Stack Gas	1.70%	2.22%	1.75%	1.89%
Sample Volume	46.240	42.576	44.962	44.593

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	CASTRIP
Date:	10/2/06
Run Number:	1

**FIELD DATA**

K' Factor	3.5
-----------	-----

Start Time	9:01
Stop Time	10:09

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vic (mL) = 17  
 Vw (scf) = 0.80019

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 70.7  
 Vm (ft^3) = 46.401  
 Pb (in Hg) = 30.13  
 delta H (in H2O) = 1.948  
 gamma = 0.99  
 Vm (dscf) = 46.24

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.70%  
 1-Bwo = 98.30%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.62

Area of Stack (enter diameter in inches), As  
 Depth = 0  
 Width = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft^2) = 0.000  
 As(dia.) (ft^2) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.11

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.745  
 Ts (F) = 122.4  
 Vs (fps) = 44.00

Stack Gas Flowrate, Qs  
 As (ft^2) = 50.27  
 Qs (acfm) = 132.707

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 119,018  
 Qstd (dscf/hr) = 7,141,102

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft^2) = 0.00032472  
 Time of Run (min) = 60.00  
 Vn (fps) = 44.10

% Isokinetic, %I  
 %I = 100.23  
 % Isokinetic measured from intermediate values  
 %I = 100.23

**PM/PM10**  
 Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0051 0.0052  
 PMR (lb/hr) = 1.7364 1.7704 3.5068  
 PMR (lb/ton) = 0.0164 0.0167 0.0330  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0015

**PM/PM10**  
 Grains per dscf  
 gr/dscf = 0.0017 0.0017 0.0034

Pollutant Mass Emission Rate, PMR  
 C (dry, corrected) (PPM) = 17.14 6.32 11.32  
 PMR (lb/hr) = 8.894 5.389 13.439  
 PMR (lb/ton) = 0.084 0.051 0.127  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.65	0.806		2.28	96	66	64
2	0.65	0.806		2.28	98	66	64
3	0.62	0.787		2.17	98	66	64
4	0.62	0.787		2.17	102	66	65
5	0.62	0.787		2.17	104	67	65
6	0.60	0.775		2.10	107	68	65
7	0.58	0.762		2.03	113	68	65
8	0.58	0.762		2.03	115	69	66
9	0.57	0.755		2.00	118	70	66
10	0.57	0.755		2.00	118	71	67
11	0.50	0.707		1.75	120	71	68
12	0.50	0.707		1.75	126	71	68
13	0.54	0.735		1.89	130	73	68
14	0.52	0.721		1.82	131	73	68
15	0.52	0.721		1.82	134	73	68
16	0.54	0.735		1.89	134	75	70
17	0.50	0.707		1.75	137	77	71
18	0.50	0.707		1.75	138	78	71
19	0.52	0.721		1.82	138	79	72
20	0.52	0.721		1.82	137	80	73
21	0.52	0.721		1.82	137	81	74
22	0.52	0.721		1.82	137	81	74
23	0.48	0.693	906.001	1.68	136	81	74
24	0.62	0.787	859.6	2.17	136	81	74

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.557	0.745	46.401	1.948	122.4	70.7

**Production Rate**

LMS Tons	115
Process Time (min)	65
Tons/hr	106.15

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	CASTRIP
Date:	10/03/06
Run Number:	2

**FIELD DATA**

K' Factor	3.5
-----------	-----

Start Time	14:32
Stop Time	15:36

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 20.5  
 Vw (scf) = 0.96494

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 92.4  
 Vm (ft<sup>3</sup>) = 44.597  
 Pb (in Hg) = 30.06  
 delta H (in H2O) = 1.722  
 gamma = 0.99  
 Vm (dscf) = 42.58

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.22%  
 1-Bwo = 97.78%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.56

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.04

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.700  
 Ts (F) = 154.2  
 Vs (fps) = 42.55

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 128,339

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 108,319  
 Qstd (dscf/hr) = 6,499,122

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft<sup>2</sup>) = 0.00032472  
 Time of Run (min) = 60  
 Vn (fps) = 43.15

% Isokinetic, %I  
 %I = 101.40  
 % Isokinetic measured from intermediate values  
 %I = 101.40

**PM/PM10**

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0050 0.0108  
 PMR (lb/hr) = 1.6826 3.6345 5.3172  
 PMR (lb/ton) = 0.0157 0.0340 0.0498  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0015

**PM/PM10**

Grains per dscf  
 gr/dscf = 0.0018 0.0039 0.0057

Pollutant Mass Emission Rate, PMR

C (dry, corrected) (PPM) = 18.21 3.62 21.45  
 PMR (lb/hr) = 8.600 2.809 23.176  
 PMR (lb/ton) = 0.080 0.026 0.217  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.60	0.775		2.10	149	86	85
2	0.55	0.742		1.93	149	87	86
3	0.55	0.742		1.93	150	87	86
4	0.52	0.721		1.82	151	88	87
5	0.46	0.678		1.61	152	89	87
6	0.46	0.678		1.61	153	89	87
7	0.46	0.678		1.61	155	91	89
8	0.44	0.663		1.54	156	92	89
9	0.42	0.648		1.47	157	92	89
10	0.40	0.632		1.40	157	93	90
11	0.40	0.632		1.40	152	93	90
12	0.40	0.632		1.40	144	94	91
13	0.50	0.707		1.75	159	95	92
14	0.54	0.735		1.89	160	96	92
15	0.54	0.735		1.89	161	96	93
16	0.54	0.735		1.89	156	96	93
17	0.48	0.693		1.68	156	97	93
18	0.48	0.693		1.68	155	98	94
19	0.45	0.671		1.58	155	98	94
20	0.48	0.693		1.68	156	98	94
21	0.52	0.721		1.82	155	99	95
22	0.54	0.735		1.89	155	99	95
23	0.54	0.735	961.297	1.89	154	100	95
24	0.54	0.735	916.7	1.89	154	101	96

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp	
	0.492	0.700	44.597	1.722	154.2	92.4

**Production Rate**

LMS Tons	114
Process Time (min)	64
Tons/hr	106.88

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	CASTRIP
<b>Date:</b>	10/05/06
<b>Run Number:</b>	3

**FIELD DATA**

K' Factor	3.5
-----------	-----

Start Time	8:59
Stop Time	10:07

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 17  
 Vw (scf) = 0.80019

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 59.0  
 Vm (ft<sup>3</sup>) = 44.1  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 1.875  
 gamma = 0.99  
 Vm (dscf) = 44.96

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.75%  
 1-Bwo = 98.25%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.61

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.13

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.731  
 Ts (F) = 127.4  
 Vs (fps) = 43.35

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 130,733

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 116,279  
 Qstd (dscf/hr) = 6,976,729

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft<sup>2</sup>) = 0.00032472  
 Time of Run (min) = 60  
 Vn (fps) = 43.24

% Isokinetic, %I  
 %I = 99.75  
 % Isokinetic measured from intermediate values  
 %I = 99.76

**PM/PM10**

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0035 0.0280  
 PMR (lb/hr) = 1.1973 9.5784 10.7756  
 PMR (lb/ton) = 0.0118 0.0944 0.1062  
 Filterable Condensable Total

Grains per acf  
 gr/acf = 0.0011

**PM/PM10**

Grains per dscf  
 gr/dscf = 0.0012 0.0096 0.0108

**Pollutant Mass Emission Rate, PMR**

C (dry, corrected) (PPM) = 44.29 10.51 19.63  
 PMR (lb/hr) = 22.453 8.755 22.768  
 PMR (lb/ton) = 0.221 0.086 0.224  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.50	0.707		1.75	106	57	56
2	0.50	0.707		1.75	108	57	56
3	0.48	0.693		1.68	109	57	56
4	0.48	0.693		1.68	110	57	56
5	0.46	0.678		1.61	110	57	56
6	0.44	0.663		1.54	115	58	56
7	0.50	0.707		1.75	123	58	56
8	0.51	0.714		1.79	130	59	57
9	0.54	0.735		1.89	137	59	57
10	0.55	0.742		1.93	142	61	57
11	0.57	0.755		2.00	140	61	57
12	0.60	0.775		2.10	138	62	57
13	0.55	0.742		1.93	144	61	57
14	0.55	0.742		1.93	148	61	57
15	0.52	0.721		1.82	146	62	58
16	0.52	0.721		1.82	144	62	58
17	0.51	0.714		1.79	140	63	58
18	0.52	0.721		1.82	139	63	58
19	0.58	0.762		2.03	131	63	58
20	0.60	0.775		2.10	127	63	58
21	0.60	0.775		2.10	124	64	59
22	0.58	0.762		2.03	120	64	59
23	0.60	0.775	1007.6	2.10	116	64	59
24	0.60	0.775	963.5	2.10	110	64	59

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.536	0.731	44.1	1.875	127.4	59.0

**Production Rate**

LMS Tons	115
Process Time (min)	68
Tons/hr	101.47

## ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10-2-06 to 10-5-06

Pollutant Gas Type: CO  
 Instrument Span: 182  
 Upscale Calibration Gas: 94.36

### ANALYZER CALIBRATION DATA

	10/02/06			Run # 1	
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	-0.1	0.1	0.05%	Pass
Mid-range gas	94.36	93.4	1.0	0.53%	Pass
High-range gas	182.0	181.6	0.4	0.22%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.1	0.11%	Pass	0.4	0.27%	Pass	0.16%	Pass
Upscale gas	90.5	1.59%	Pass	90.5	1.59%	Pass	0.00%	Pass

### ANALYZER CALIBRATION DATA

	10/03/06			Run # 2	
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	0.1	0.1	0.05%	Pass
Mid-range gas	94.36	93.1	1.3	0.69%	Pass
High-range gas	182.0	181.4	0.6	0.33%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.3	0.11%	Pass	0.3	0.11%	Pass	0.00%	Pass
Upscale gas	91.2	1.04%	Pass	90.3	1.54%	Pass	0.49%	Pass

### ANALYZER CALIBRATION DATA

	10/05/06			Run # 3	
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	0.2	0.2	0.11%	Pass
Mid-range gas	94.36	94.0	0.4	0.20%	Pass
High-range gas	182.0	182.2	0.2	0.11%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.3	0.05%	Pass	0.4	0.11%	Pass	0.05%	Pass
Upscale gas	93.6	0.22%	Pass	93.5	0.27%	Pass	0.05%	Pass

### EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (dry, ppm)
Run # 1	16.64	17.14
Run # 2	17.76	18.21
Run # 3	44.1	44.29

## ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10-2-06 to 10-5-06

Pollutant Gas Type: NOx  
 Instrument Span: 87.1  
 Upscale Calibration Gas: 49.1

ANALYZER CALIBRATION DATA	10/02/06	Run # 1		
Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	0.0	0.00%	Pass
Mid-range gas	49.1	49.8	0.63%	Pass
High-range gas	87.1	87.8	0.80%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	-0.1	0.11%	Pass	0.0	0.00%	Pass	0.11%	Pass
Upscale gas	48.9	1.03%	Pass	49.2	0.69%	Pass	0.34%	Pass

ANALYZER CALIBRATION DATA	10/03/06	Run # 2		
Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	-0.2	0.23%	Pass
Mid-range gas	49.1	49.7	0.69%	Pass
High-range gas	87.1	88.1	1.15%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.2	0.46%	Pass	0.1	0.34%	Pass	0.11%	Pass
Upscale gas	49.9	0.23%	Pass	49.5	0.23%	Pass	0.46%	Pass

ANALYZER CALIBRATION DATA	10/05/06	Run # 3		
Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	-0.1	0.11%	Pass
Mid-range gas	49.1	49.9	0.92%	Pass
High-range gas	87.1	87.3	0.23%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	-0.2	0.11%	Pass	0.0	0.11%	Pass	0.23%	Pass
Upscale gas	49.6	0.34%	Pass	50.1	0.23%	Pass	0.57%	Pass

### EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (dry, ppm)
Run # 1	6.27	6.32
Run # 2	3.8	3.62
Run # 3	10.59	10.51

### ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10-2-06 to 10-5-06

Pollutant Gas Type: SO2  
 Instrument Span: 150.1  
 Upscale Calibration Gas: 62.09

ANALYZER CALIBRATION DATA		10/02/06	Run # 1		
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	0.0	0.0	0.00%	Pass
Mid-range gas	62.09	60.8	1.3	0.86%	Pass
High-range gas	150.1	150.0	0.1	0.07%	Pass

#### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	-0.1	0.07%	Pass	0.1	0.07%	Pass	0.13%	Pass
Upscale gas	57.8	2.00%	Pass	58.3	1.87%	Pass	0.33%	Pass

ANALYZER CALIBRATION DATA		10/03/06	Run # 2		
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	-0.1	0.1	0.07%	Pass
Mid-range gas	62.09	60.7	1.4	0.93%	Pass
High-range gas	150.1	151.2	1.1	0.73%	Pass

#### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.5	0.40%	Pass	0.7	0.53%	Pass	0.13%	Pass
Upscale gas	58.4	1.53%	Pass	57.8	1.93%	Pass	0.40%	Pass

ANALYZER CALIBRATION DATA		10/05/06	Run # 3		
	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
Zero gas	0.0	-0.2	0.2	0.13%	Pass
Mid-range gas	62.09	60.8	1.3	0.86%	Pass
High-range gas	150.1	152.0	1.9	1.27%	Pass

#### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	0.0	0.13%	Pass	1.3	1.00%	Pass	0.87%	Pass
Upscale gas	60.1	0.47%	Pass	58.1	1.80%	Pass	1.33%	Pass

#### EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (dry, ppm)
Run # 1	10.58	11.32
Run # 2	20.48	21.45
Run # 3	19.13	19.63

**APPENDIX B**

---

**FIELD DATA PRINTOUTS**

Lead Emissions

## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	LEAD - Castrip
Date:	10/2/06 - 10/5/06

Particulate Concentration	Run 1	Run 2	Run 3	Average
Lead (lb/ton)	6.26E-06	3.38E-06	1.07E-06	3.57E-06
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	132,739	134,292	131,593	132,875
DSCFM	119,764	113,724	116,697	116,728
Avg. Stack Temp	118.6	152.0	127.1	132.5
Stack Gas Velocity	44.01	44.53	43.63	44.06
Avg. Velocity Head	0.559	0.539	0.541	0.547
Avg. Sq. Rt of Delta P	0.748	0.734	0.736	0.739

### ISOKINETIC TESTING SUMMARY

Allowable isokinetic 90-110%	94.34	98.21	95.70	96.08
% Moisture of Stack Gas	1.76%	2.25%	2.09%	2.03%
Sample Volume	45.975	45.449	45.446	45.623

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	LEAD - Castrip
<b>Date:</b>	10/03/06
<b>Run Number:</b>	2

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 22.2  
 Vw (scf) = 1.04495

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 91.229  
 Vm (ft<sup>3</sup>) = 47.478  
 Pb (in Hg) = 30.06  
 delta H (in H2O) = 1.946  
 gamma = 0.99  
 Vm (dscf) = 45.45

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.25%  
 1-Bwo = 97.75%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.56

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.04

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.734  
 Ts (F) = 151.96  
 Vs (fps) = 44.53

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 134.292

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 113,724  
 Qstd (dscf/hr) = 6,823,431

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.25 An (ft<sup>2</sup>) = 0.00034  
 Time of Run (min) = 60  
 Vn (fps) = 43.73

% Isokinetic, %I  
 %I = 98.21  
 % Isokinetic measured from intermediate values  
 %I = 98.21

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.00000109  
 PMR (lbs/hr) = 0.0004  
 PMR (lbs/ton) = 3.38E-06  
 Lead Total

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 3.70E-07

**FIELD DATA**

K' Factor 3.6

Start Time 14:32  
 Stop Time 15:38

Run 2	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.60	0.775		2.16	142	86	85
2	0.58	0.762		2.09	142	86	85
3	0.58	0.762		2.09	143	86	85
4	0.58	0.762		2.09	144	87	86
5	0.52	0.721		1.87	146	88	86
6	0.48	0.693		1.73	144	88	86
7	0.58	0.762		2.09	149	89	87
8	0.58	0.762		2.09	150	89	87
9	0.55	0.742		1.98	151	91	88
10	0.60	0.775		2.16	151	92	88
11	0.50	0.707		1.80	151	92	88
12	0.46	0.678		1.66	147	93	89
13	0.58	0.762		2.09	155	94	90
14	0.54	0.735		1.94	155	94	90
15	0.54	0.735		1.94	155	95	90
16	0.54	0.735		1.94	156	95	90
17	0.47	0.686		1.69	156	96	91
18	0.42	0.648		1.51	156	97	92
19	0.58	0.762		2.09	156	97	93
20	0.60	0.775		2.16	158	98	93
21	0.65	0.742		1.98	159	99	93
22	0.56	0.762	183.578	2.09	160	99	94
23	0.54	0.735	136.1	1.94	160	100	95
24	0.42	0.648		1.51	161	101	96

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.540	0.734	47.478	1.946	152.0	91.2

**Production Rate**

LMS Tons	114
Process Time (min)	64
Tons/hr	106.88

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	LEAD - Castrip
<b>Date:</b>	10/2/06
<b>Run Number:</b>	1

**FIELD DATA**

K' Factor	3.5
-----------	-----

Start Time	9:01
Stop Time	10:09

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = .20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 17.5  
 Vw (scf) = 0.82373

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 71.500  
 Vm (ft<sup>3</sup>) = 46.200  
 Pb (in Hg) = 30.13  
 delta H (in H2O) = 1.960  
 gamma = 0.99  
 Vm (dscf) = 45.97

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.76%  
 1-Bwo = 98.24%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.61

Area of Stack (enter diameter in inches), As  
 Depth = 0  
 Width = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.11

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sq(delta p) = 0.748  
 Ts (F) = 118.58  
 Vs (fps) = 44.01

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 132.739

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 119,764  
 Qstd (dscf/hr) = 7,185,818

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.25 An (ft<sup>2</sup>) = 0.0003409  
 Time of Run (min) = 60.00  
 Vn (fps) = 41.52

% Isokinetic, %I  
 %I = 94.34  
 % Isokinetic measured from intermediate values  
 %I = 94.34

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.00000193  
 PMR (lb/hr) = 0.0007  
 PMR (lb/ton) = 6.28E-08  
 Lead Total

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 6.48E-07

Run	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.65	0.806		2.28	95	66	64
2	0.65	0.806		2.28	95	66	64
3	0.62	0.787		2.17	96	66	64
4	0.62	0.787		2.17	103	67	64
5	0.62	0.787		2.17	104	68	65
6	0.60	0.775		2.10	105	69	65
7	0.60	0.775		2.10	110	70	66
8	0.61	0.781		2.14	111	70	66
9	0.59	0.768		2.07	112	71	66
10	0.58	0.762		2.04	115	72	67
11	0.52	0.721		1.82	120	74	68
12	0.52	0.721		1.82	120	74	68
13	0.54	0.735		1.89	126	74	69
14	0.53	0.728		1.86	127	76	70
15	0.52	0.721		1.82	128	76	70
16	0.52	0.721		1.82	129	78	71
17	0.51	0.714		1.79	132	79	72
18	0.51	0.714		1.79	132	80	73
19	0.52	0.721		1.82	132	81	73
20	0.50	0.707		1.75	132	81	73
21	0.52	0.721		1.82	131	81	73
22	0.51	0.714	123.4	1.79	131	81	73
23	0.50	0.707	77.2	1.75	130	81	73
24	0.59	0.768		2.03	130	81	73

Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.560	46.2	1.960	118.6	71.5

**Production Rate**

LMS Tons	115
Process Time (min)	65
Tons/hr	106.15

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	LEAD - Castrip
<b>Date:</b>	10/05/06
<b>Run Number:</b>	3

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20  
 Md (g/gmol) = 28.8

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 20.6  
 Vw (scf) = 0.96964

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 55.4  
 Vm (ft<sup>3</sup>) = 44.25  
 Pb (in Hg) = 30.15  
 delta H (in H2O) = 2.010  
 gamma = 0.99  
 Vm (dscf) = 45.45

Moisture Content of Stack Gas, Bwo  
 Bwo = 2.09%  
 1-Bwo = 97.91%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.57

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 30.13

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.736  
 Ts (F) = 127.1  
 Vs (fps) = 43.63

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 131,593

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 116,697  
 Qstd (dscf/hr) = 7,001,810

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.25 An (ft<sup>2</sup>) = 0.00034  
 Time of Run (min) = 60  
 Vn (fps) = 41.76

% Isokinetic, %I  
 %I = 95.70  
 % Isokinetic measured from intermediate values  
 %I = 95.70

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.00000032  
 PMR (lbs/hr) = 0.0001  
 PMR (lbs/ton) = 1.07E-06  
 Lead\*Total

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 1.09E-07

**FIELD DATA**

K' Factor 3.7

Start Time 8:59  
 Stop Time 10:07

Run 3	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.50	0.707		1.85	106	54	54
2	0.50	0.707		1.85	107	54	54
3	0.48	0.693		1.78	108	54	54
4	0.44	0.663		1.63	112	55	54
5	0.42	0.648		1.55	119	55	54
6	0.42	0.648		1.55	121	55	54
7	0.48	0.693		1.78	123	55	54
8	0.56	0.748		2.07	128	55	54
9	0.56	0.748		2.07	132	56	54
10	0.58	0.762		2.15	130	56	54
11	0.60	0.775		2.22	134	56	55
12	0.62	0.787		2.29	138	56	55
13	0.52	0.721		1.92	140	56	55
14	0.52	0.721		1.92	145	56	55
15	0.54	0.735		2.00	146	56	55
16	0.54	0.735		2.00	142	56	55
17	0.55	0.742		2.04	140	57	56
18	0.56	0.748		2.07	138	57	56
19	0.56	0.748		2.07	125	57	56
20	0.58	0.762		2.15	123	57	56
21	0.60	0.775		2.22	125	57	56
22	0.62	0.787	228.35	2.29	124	57	56
23	0.64	0.800	184.1	2.37	122	57	56
24	0.65	0.806		2.41	122	57	56

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.543	0.736	44.25	2.010	127.1	55.4

**Production Rate**

LMS Tons	115
Process Time (min)	68
Tons/hr	101.47

**APPENDIX C**

---

**FIELD DATA**

Particulate & Gas Emissions

**VELOCITY TRAVERSE POINT DETERMINATION**  
 (EPA Method 1)

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	PM/PM10 - Castrip
Date:	10-2-06 to 10-5-06

Circular Stack  
 Traverse Points on Diameter:  
 Stack Diameter (inches):

		4	6	8	10	12
96						
Point	1	6.43	4.22	3.07	2.50	2.02
	2	24.00	14.02	10.08	7.87	6.43
	3	72.00	28.42	18.62	14.02	11.33
	4	89.57	67.58	31.01	21.70	16.99
	6		81.98	64.99	32.83	24.00
	6		91.78	77.38	63.17	34.18
	7			85.92	74.30	61.82
	8			92.93	81.98	72.00
	9				88.13	79.01
	10				93.50	84.67
	11					89.67
	12					93.98

AIR TEST PROFESSIONALS FIELD DATA SHEET

PM/PM10 TESTIN

EPA METHOD

1-5/202/9


RUN 1

PAGE

CLIENT	NUCOR STEEL	METER BOX ID	A-2	K FACTOR	3.5	DUCT DIMENSIONS (in.)	96	Diagram of Test Location
LOCATION	CRAWFORDSVILLE, IN	METER Y	0.99	METER ΔH	1.81	PORT LENGTH (in.)	5	
UNIT	CAST STRIP	PITOT C <sub>p</sub>	0.84	PROBE LINER	TEFLON	FILTER ID	R1-B	SILICA ID
DATE	10-2-06	PROJECT #		NOZZLE ID	0.244	TEDLAR BAG ID		
METER OPERATOR	CARLOS BROWN	BAROMETRIC	30.13	AMBIENT TEMP (°F)		PITOT CHECK		O <sub>2</sub> 22.0
PROBE OPERATOR	MARCUS ALLEN	STATIC PRESSURE (in. H <sub>2</sub> O)			-0.25	PASS	<input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>
VISIBLE EMISSIONS READER	NITA GREENBURG	LEAK RATE BEFORE (cfm)	0.000	@ (in. Hg)	10"	H <sub>2</sub> O (mL)		4.0
CLIENT CONTACT	TRAVOR BEERS	LEAK RATE AFTER (cfm)	0.000	@ (in. Hg)	9"	SILICA GEL (g)		13.0
AGENCY CONTACT	DAVID HARRISON	START TIME	0901	STOP TIME	1009	TOTAL V <sub>c</sub>		17.0

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume V <sub>m</sub> (ft <sup>3</sup> )	Stack Temp. T <sub>s</sub> (°F)	Probe T <sub>p</sub> (°F)	Filter T <sub>f</sub> (°F)	Cond. Temp. T <sub>c</sub> (°F)	DGM Inlet T <sub>m</sub> (°F)	DGM Outlet T <sub>m</sub> (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.65	2.28	859.60	96	249	249	57	66	69	3.5	
2	5.0	0.65	2.28	863.6	96	249	250	57	66	64	3.5	
3	7.5	0.62	2.17	865.6	98	250	251	57	66	64	3.5	
4	10.0	0.62	2.17	867.7	102	250	251	57	66	65	3.5	
5	12.5	0.62	2.17	869.7	104	250	252	58	67	65	3.5	
6	15.0	0.60	2.10	871.8	107	250	253	58	68	65	3.5	
7	17.5	0.58	2.04	873.6	113	251	252	58	68	65	3.5	
8	20.0	0.58	2.04	875.8	115	251	252	58	69	66	3.5	
9	22.5	0.57	1.99	877.4	118	250	249	60	70	66	3.5	
10	25.0	0.57	1.99	880.6	118	249	250	61	71	67	3.5	
11	27.5	0.50	1.75	881.7	120	250	254	61	71	68	3.5	
12	30.0	0.50	1.75	883.1	126	250	250	64	71	68	3.5	
13	32.5	0.54	1.89	885.0	130	251	254	63	73	68	3.5	
14	35.0	0.52	1.82	887.1	131	251	252	63	73	68	3.5	
15	37.5	0.52	1.82	888.8	134	252	248	63	73	68	3.5	
16	40.0	0.54	1.89	890.7	134	251	247	64	75	70	3.5	
17	42.5	0.50	1.75	892.5	137	251	251	65	77	71	3.5	
18	45.0	0.50	1.75	894.3	138	251	251	65	78	71	3.5	
19	47.5	0.52	1.82	896.4	138	250	248	65	79	72	3.5	
20	50.0	0.52	1.82	898.3	137	250	249	65	80	73	3.5	
21	52.5	0.52	1.82	900.1	137	249	250	65	81	74	3.5	
22	55.0	0.52	1.82	902.1	137	249	250	65	81	74	3.5	
23	57.5	0.48	1.68	904.0	136	249	250	65	81	74	3.5	
24	60.0	0.62	2.17	906.001	136	249	249	65	81	74	3.5	

ph = 5.5



AIR TESTING PROFESSIONALS FIELD DATA SHEET

PM/PA10 TESTING

EPA METHOD 1-4/12/9


RUN 2

PAGE

CLIENT Nuclear Steel DUCT DIMENSIONS (in.) 96"  
 LOCATION CRAWFORDVILLE IN PORT LENGTH (in.) 51"  
 UNIT CAST STRIP PITOT Co. 0.87 PROBE LINER TEFLON FILTER ID R2 SILICA ID #7  
 DATE 10-3-06 PROJECT # 1211 NOZZLE ID 0.244 TEDLAR BAG ID  
 METER OPERATOR CARLOS BROWN BAROMETRIC 30.06 AMBIENT TEMP (°F) -0.25 PITOT CHECK PASS FAIL   
 PROBE OPERATOR ANDY YOUNG STATIC PRESSURE (in. H<sub>2</sub>O) 0.000 @ (in. Hg) 10" H<sub>2</sub>O (ml) 0.0  
 VISIBLE EMISSIONS READER NITA GOSWAMI LEAK RATE BEFORE (cfm) 0.000 @ (in. Hg) 6" SILICA GEL (g) 10.5  
 CLIENT CONTACT TREVOR BEERS LEAK RATE AFTER (cfm) 0.000 @ (in. Hg) 6" TOTAL Vic 20.5  
 AGENCY CONTACT DAVID HARRISON START TIME 1432 STOP TIME 1536

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.60	2.10	916.70	149	251	347	68	86	85	5	
2	5.0	0.55	1.93	920.9	149	248	249	66	87	86	5	
3	7.5	0.55	1.93	922.9	150	249	253	66	87	86	5	
4	10.0	0.52	1.82	924.8	151	248	247	65	88	87	5	
5	12.5	0.46	1.61	926.5	152	249	249	65	89	87	4	
6	15.0	0.46	1.61	928.6	153	249	252	65	89	87	4	
7	17.5	0.46	1.61	930.3	155	250	248	64	91	89	4	
8	20.0	0.44	1.54	932.2	156	250	253	64	92	89	4	
9	22.5	0.42	1.47	933.8	157	249	252	64	92	89	4	
10	25.0	0.46	1.40	935.5	157	251	250	63	93	90	4	
11	27.5	0.40	1.40	937.1	152	250	251	63	93	90	4	
12	30	0.40	1.40	938.7	144	251	254	63	94	91	4	
13	32.5	0.50	1.75	940.5	159	250	250	64	95	92	4	
14	35.0	0.54	1.89	942.5	160	250	252	64	96	92	4	
15	37.0	0.54	1.89	944.3	161	250	252	64	96	93	4	
16	40.0	0.54	1.89	946.4	156	250	248	64	96	93	4	
17	42.5	0.48	1.68	948.3	156	251	255	65	97	93	4	
18	45.0	0.48	1.68	950.0	155	250	250	65	98	94	4	
19	47.5	0.45	1.58	951.6	155	249	252	65	98	94	4	
20	50.0	0.48	1.68	953.3	156	249	247	65	98	94	4	
21	52.5	0.52	1.82	955.5	155	250	250	65	99	95	4	
22	55.0	0.54	1.89	957.3	155	252	254	65	99	95	4	
23	57.5	0.54	1.89	959.6	154	251	249	65	100	95	4	
24	60	0.54	1.89	961.297	154	250	250	65	101	96	4	

ph = 5.5



**AIR TEST, PROFESSIONALS FIELD DATA SHEET**

PAY/PM 10 TESTIN.


EPA METHOD 1-5/202/9

RUN 3

PAGE

CLIENT	Nicola Steel	METER BOX ID	A-2	K FACTOR	3.5	DUCT DIMENSIONS (in.)	96"	Diagram of Test Location	
LOCATION	Crawfordsville, IN	METER	0.99	METER AH@	1.81	PORT LENGTH (in.)	5"		
UNIT	CAST STRIP	PITOT Cp	0.84	PROBE LINER	TEFLON	FILTER ID	R3	SILICA ID	8
DATE	10-5-06	PROJECT #		NOZZLE ID	0.244	TEFLON BAG ID			
METER OPERATOR	CARLOS BROWN	BAROMETRIC	30.15	AMBIENT TEMP (°F)		PITOT CHECK	PASS <input checked="" type="checkbox"/>	FAIL <input type="checkbox"/>	O <sub>2</sub> 20.0 CO <sub>2</sub> 0.0
PROBE OPERATOR	AUDY YOUNG	STATIC PRESSURE (in. H <sub>2</sub> O)	0.000	@ (in. Hg)	12"	H <sub>2</sub> O (mL)			6
VISIBLE EMISSIONS READER	ERIC FERGUSON	LEAK RATE BEFORE (cfm)	0.000	@ (in. Hg)	8"	SILICA GEL (g)			N.O
CLIENT CONTACT	TREVOR KEETZ	LEAK RATE AFTER (cfm)	0.000	STOP TIME	1007	TOTAL Vg			17.0
AGENCY CONTACT	DAVID HARRISON	START TIME	0859						

Traverse Point Number	Mini/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Office Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Slack Temp. Ts (°F)	Probe Tip (°F)	Filter Tf (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.50	1.75	963.5	106	249	248	51	57	56	3	
2	5.0	0.50	1.75	967.4	108	250	250	50	57	56	3	
3	7.5	0.48	1.68	969.2	109	250	251	50	57	56	3	
4	10.0	0.48	1.68	971.1	110	251	250	50	57	56	3	
5	12.5	0.46	1.61	973.0	110	250	253	50	57	56	3	
6	15.0	0.44	1.54	974.8	115	252	250	51	58	56	3	
7	17.5	0.50	1.75	976.6	123	250	251	51	58	56	3	
8	20.0	0.51	1.79	978.5	130	249	253	51	59	57	3	
9	22.5	0.54	1.89	980.2	137	249	252	51	59	57	3	
10	25.0	0.55	1.93	982.0	142	248	254	52	61	57	3	
11	27.5	0.57	2.00	984.0	140	250	255	52	61	57	3	
12	30	0.60	2.10	985.6	138	251	257	52	62	57	3	
13	32.5	0.55	1.93	987.2	144	251	250	52	61	57	3	
14	35.0	0.55	1.93	989.0	148	252	250	52	61	57	3	
15	37.5	0.52	1.82	990.8	146	250	251	52	62	58	3	
16	40.0	0.52	1.82	992.5	144	250	251	53	62	58	3	
17	42.5	0.51	1.79	994.4	140	251	250	53	63	58	3	
18	45.0	0.52	1.82	996.2	139	249	250	53	63	58	3	
19	47.5	0.58	2.03	998.0	131	249	248	53	63	58	3	
20	50.0	0.60	2.10	1000.1	127	247	246	54	63	58	3	
21	52.5	0.60	2.10	1001.9	124	249	248	53	64	59	3	
22	55.0	0.58	2.03	1003.8	120	249	249	53	64	59	3	
23	57.5	0.60	2.10	1005.7	116	251	248	53	64	59	3	
24	60	0.60	2.10	1007.6	110	250	246	53	64	59	3	



**ANALYZER FIELD DATA**

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	Castrip
<b>Date:</b>	10/2/2006
<b>Run Number:</b>	1

Date/Time	CO ppm	SO2 ppm	NOx ppm	INITIAL CALS
10/2/2006 8:06	181.6	0	-0.3	CO gas (182.0)
10/2/2006 8:07	120.4	0	-0.3	
10/2/2006 8:08	0.7	0	0.1	
10/2/2006 8:09	0.3	0	0.2	
10/2/2006 8:10	0.3	0	0.2	
10/2/2006 8:11	0.2	0	0.2	
10/2/2006 8:12	0.3	0	0.2	
10/2/2006 8:13	0.2	72	0.2	
10/2/2006 8:14	0.2	149	0.2	
10/2/2006 8:15	0.3	150	0.3	SO2 gas (150.1)
10/2/2006 8:16	0.3	20.3	0.3	
10/2/2006 8:17	-0.1	0	0	Zero gas (0)
10/2/2006 8:18	-0.1	0.5	0	
10/2/2006 8:19	-0.1	57.4	0	
10/2/2006 8:20	-0.1	60.5	0.2	
10/2/2006 8:21	-0.1	60.9	0.2	
10/2/2006 8:22	-0.1	7.9	0.2	
10/2/2006 8:23	-0.1	0.1	5.2	
10/2/2006 8:24	0	0.1	44.6	
10/2/2006 8:25	0	0.1	11.1	
10/2/2006 8:26	0	-0.1	78.4	
10/2/2006 8:27	0	-0.2	87.8	NOx gas (87.1)
10/2/2006 8:28	0	0.1	15.1	
10/2/2006 8:29	0	0	47.5	
10/2/2006 8:30	0	-0.1	49.8	NOx gas (49.08)
10/2/2006 8:31	0	0.2	36.5	
10/2/2006 8:32	0.2	43.2	4.6	
10/2/2006 8:33	0.2	60.1	0.7	
10/2/2006 8:34	0.2	60.8	0.3	SO2 gas (62.09)
10/2/2006 8:35	0.2	10.5	0.2	
10/2/2006 8:36	79.5	-0.1	-0.1	
10/2/2006 8:37	88.6	-0.1	-0.1	
10/2/2006 8:38	93	-0.1	-0.1	
10/2/2006 8:39	93.4	-0.1	-0.1	CO gas (94.38)
10/2/2006 8:40	45.2	0.2	-0.1	
10/2/2006 8:41	6.1	49.6	0.1	BIAS CHECKS
10/2/2006 8:42	0.2	57.8	0.2	SO2 gas (62.09)
10/2/2006 8:43	0.3	58	0.2	
10/2/2006 8:44	0.2	37.3	0.2	
10/2/2006 8:45	65.1	0.5	-0.1	
10/2/2006 8:46	90.5	-0.1	-0.1	CO gas (94.38)
10/2/2006 8:47	90.5	-0.1	-0.1	
10/2/2006 8:48	25.2	0.9	10.2	
10/2/2006 8:49	0.3	0	45	
10/2/2006 8:50	0.1	-0.1	48.9	NOx gas (48.08)
10/2/2006 8:51	1.5	1.8	32.5	
10/2/2006 8:52	5.2	1.1	4	
10/2/2006 8:53	5.3	0.7	0.4	
10/2/2006 8:54	5.2	0.6	0	
10/2/2006 8:55	5.2	0.6	-0.1	
10/2/2006 8:56	5.3	0.6	-0.1	
10/2/2006 8:57	5.2	0.5	-0.2	
10/2/2006 8:58	5.2	0.5	-0.2	
10/2/2006 8:59	5.3	14.6	0	
10/2/2006 9:00	5.3	14.4	0.9	
10/2/2006 9:01	0.4	10.7	3.5	
10/2/2006 9:02	5.1	9.8	6.3	
10/2/2006 9:03	5.2	14	4.7	
10/2/2006 9:04	5.3	13.7	3.8	
10/2/2006 9:05	5.3	10.5	3.5	
10/2/2006 9:06	5.3	11.5	3.4	
10/2/2006 9:07	9.8	34.1	3.7	
10/2/2006 9:08	10.2	19.1	3.3	
10/2/2006 9:09	10.2	11.6	4.7	
10/2/2006 9:10	10.2	9.1	5.6	
10/2/2006 9:11	10.2	7	5.7	
10/2/2006 9:12	10.3	5.7	5.8	
10/2/2006 9:13	10.3	5.4	6.1	
10/2/2006 9:14	10.3	5.5	6.8	

**ANALYZER FIELD DATA**

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	Castrip
<b>Date:</b>	10/2/2006
<b>Run Number:</b>	1

Date/Time	CO ppm	SO2 ppm	NOx ppm
10/2/2006 9:15	10.3	9.7	7.9
10/2/2006 9:16	10.3	10.4	6
10/2/2006 9:17	10.3	10.3	8.6
10/2/2006 9:18	19.6	10.4	4.7
10/2/2006 9:19	20.3	6.6	1.5
10/2/2006 9:20	20.3	5.1	1.1
10/2/2006 9:21	20.3	3.4	0.9
10/2/2006 9:22	20.3	2.6	0.8
10/2/2006 9:23	16.1	3.2	0.9
10/2/2006 9:24	10.3	11.5	2.2
10/2/2006 9:25	10.3	12.7	3.4
10/2/2006 9:26	10.3	8.7	7.3
10/2/2006 9:27	10.3	8.5	10.2
10/2/2006 9:28	10.3	10.6	8.4
10/2/2006 9:29	10.3	67.5	25.9
10/2/2006 9:30	7.1	88.2	45
10/2/2006 9:31	9.9	38.8	37.4
10/2/2006 9:32	10.3	18.6	23.3
10/2/2006 9:33	19.6	10.8	8.4
10/2/2006 9:34	20.4	8.5	3.5
10/2/2006 9:35	16.1	7.3	4.4
10/2/2006 9:36	14.7	10.9	13.2
10/2/2006 9:37	29.9	9.7	4.8
10/2/2006 9:38	28.5	13.6	1.8
10/2/2006 9:39	32	15.7	1.3
10/2/2006 9:40	17.2	8.2	1.8
10/2/2006 9:41	15.4	7.8	5.3
10/2/2006 9:42	10.5	7.8	13.3
10/2/2006 9:43	23.6	8.7	5.6
10/2/2006 9:44	15.8	7.7	10.4
10/2/2006 9:45	10.7	8.7	18.4
10/2/2006 9:46	15.2	8.6	20.4
10/2/2006 9:47	10.5	8.2	21.6
10/2/2006 9:48	19.7	8.3	10.1
10/2/2006 9:49	25.3	9.7	2.6
10/2/2006 9:50	33.8	6.8	1.7
10/2/2006 9:51	45.2	7.4	1.7
10/2/2006 9:52	30.7	6.2	1.1
10/2/2006 9:53	30.4	4.6	1
10/2/2006 9:54	25.6	4.3	1.1
10/2/2006 9:55	28.8	3.5	1
10/2/2006 9:56	30.4	2.6	0.9
10/2/2006 9:57	30.4	2.2	1
10/2/2006 9:58	25.8	2.3	1.1
10/2/2006 9:59	20.5	4.6	1.9
10/2/2006 10:00	25.3	6.6	2.1
10/2/2006 10:01	25.4	5.7	1.2
10/2/2006 10:02	25.4	5	1.3
10/2/2006 10:03	25.4	4	1.2
10/2/2006 10:04	25.4	2.7	1
10/2/2006 10:05	20.6	2	0.8
10/2/2006 10:06	12	1.6	0.9
10/2/2006 10:07	5.8	1.3	1
10/2/2006 10:08	5.5	1.2	1
10/2/2006 10:09	5.4	1	0.8
10/2/2006 10:10	5.4	0.9	0.8
10/2/2006 10:11	5.4	0.8	0.6
10/2/2006 10:12	5.4	0.7	0
10/2/2006 10:13	1	0.6	27.1
10/2/2006 10:14	0.3	0.5	46.9
10/2/2006 10:15	0.3	0.4	48.8
10/2/2006 10:16	0.3	0.3	49.2
10/2/2006 10:17	0.4	0.2	<b>49.2 NOx gas (49.08)</b>
10/2/2006 10:18	4	0.3	33.6
10/2/2006 10:19	90.5	0.1	4.5
10/2/2006 10:20	<b>90.5</b>	<b>0.1</b>	<b>0 CO gas (94.36)</b>
10/2/2006 10:21	90.5	0.1	0
10/2/2006 10:22	55.5	0.2	0
10/2/2006 10:23	1	47.7	0.1
10/2/2006 10:24	0.4	55.1	0.2
10/2/2006 10:25	0.4	56.9	0.2
10/2/2006 10:26	0.4	57.7	0.3
10/2/2006 10:27	0.4	58.2	0.3
10/2/2006 10:28	<b>0.4</b>	<b>58.3</b>	<b>0.3 SO2 gas (62.09)</b>

Run 1 Averages	
CO	16.64
NOx	6.27
SO2	10.58

### ANALYZER FIELD DATA

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10/3/2006
Run Number:	2

CO SO<sub>2</sub> NO<sub>x</sub>

	CO	SO <sub>2</sub>	NO <sub>x</sub>	INITIAL CALS
10/3/2006 9:50	0.1	151.2	-0.2	SO <sub>2</sub> gas (150.1)
10/3/2006 9:51	0.4	32.1	-0.1	
10/3/2006 9:52	160.5	0.7	-0.2	
10/3/2006 9:53	184.3	0.6	-0.2	
10/3/2006 9:54	<b>181.4</b>	<b>-0.1</b>	<b>-0.2</b>	CO gas (182.0)
10/3/2006 9:55	135.5	14.7	-0.2	
10/3/2006 9:56	1	60.3	0.2	
10/3/2006 9:57	0.3	<b>60.7</b>	0.3	SO <sub>2</sub> gas (62.09)
10/3/2006 9:58	3.8	6	0.2	
10/3/2006 9:59	88.8	0	-0.1	
10/3/2006 10:00	92.5	-0.1	-0.2	
10/3/2006 10:01	<b>93.1</b>	-0.1	-0.2	CO gas (94.36)
10/3/2006 10:02	15.7	0.2	22.5	
10/3/2006 10:03	0.4	-0.1	82.3	
10/3/2006 10:04	0.3	-0.1	89	
10/3/2006 10:05	0.3	-0.1	88.6	
10/3/2006 10:06	0.3	-0.2	<b>88.1</b>	NO <sub>x</sub> gas (87.1)
10/3/2006 10:07	0.4	0.1	77.5	
10/3/2006 10:08	0.3	0.1	11.7	
10/3/2006 10:09	0.3	0.1	1.4	
10/3/2006 10:10	0.3	-0.1	36.9	
10/3/2006 10:11	0.4	-0.1	<b>49.7</b>	NO <sub>x</sub> gas (49.08)
10/3/2006 10:12	0.4	0	42.5	
10/3/2006 10:13	0.4	0	6.1	

	CO	SO <sub>2</sub>	NO <sub>x</sub>	BIAS CHECKS
10/3/2006 13:39	0.3	58.4	0.2	SO <sub>2</sub> gas (62.09)
10/3/2006 13:40	0.3	39	0.2	
10/3/2006 13:41	85.5	7.1	0.2	
10/3/2006 13:42	90.4	3.8	0.1	
10/3/2006 13:43	<b>91.2</b>	2.3	-0.1	CO gas (94.36)
10/3/2006 13:44	12.1	6.9	5.5	
10/3/2006 13:45	0.7	3	43.4	
10/3/2006 13:46	0.3	1	49.1	
10/3/2006 13:47	0.3	0.6	49.8	
10/3/2006 13:48	0.3	<b>0.5</b>	<b>49.9</b>	NO <sub>x</sub> gas (49.08)
10/3/2006 13:49	13.8	18.6	15.1	
10/3/2006 13:50	15.4	40.8	3.2	

10/3/2006 14:32	15.4	1.3	1.1
10/3/2006 14:33	10.5	1.2	1.1
10/3/2006 14:34	11.7	2.3	1.1
10/3/2006 14:35	10.4	56.6	1.4
10/3/2006 14:36	15.3	44.2	2.4
10/3/2006 14:37	15.4	36.7	4.2
10/3/2006 14:38	11.6	30.1	5.4
10/3/2006 14:39	10.3	25.8	5.9
10/3/2006 14:40	10.3	24.3	7
10/3/2006 14:41	10.3	25.4	7
10/3/2006 14:42	10.3	26.2	6.6
10/3/2006 14:43	10.3	25.3	6.5
10/3/2006 14:44	10.3	33.2	6.3
10/3/2006 14:45	10.3	51.1	5.6
10/3/2006 14:46	10.3	33.7	5
10/3/2006 14:47	10.4	23.7	7.3
10/3/2006 14:48	10.4	22	7.9
10/3/2006 14:49	10.3	22.6	7.3
10/3/2006 14:50	10.3	16.9	9.7
10/3/2006 14:51	10.4	17.2	10.3
10/3/2006 14:52	10.3	15.6	11
10/3/2006 14:53	10.3	13.7	13.8
10/3/2006 14:54	14.2	12.6	13.5
10/3/2006 14:55	25.1	13.2	4.2
10/3/2006 14:56	21.5	10.9	2.2
10/3/2006 14:57	15.5	13.6	7.6
10/3/2006 14:58	15.4	12.5	12.2
10/3/2006 14:59	29.1	19.4	3.4
10/3/2006 15:00	25.6	40.9	1.8

# ANALYZER FIELD DATA

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10/3/2006
Run Number:	2

	CO	SO <sub>2</sub>	NO <sub>x</sub>
10/3/2006 15:01	25.4	51.1	1.2
10/3/2006 15:02	25.9	46.8	1.2
10/3/2006 15:03	25.3	36.7	1.4
10/3/2006 15:04	25.3	22.3	1.6
10/3/2006 15:05	25.3	15.4	1.3
10/3/2006 15:06	29.2	10.1	1.2
10/3/2006 15:07	25.9	32	1.2
10/3/2006 15:08	25.4	22.9	1.1
10/3/2006 15:09	15.7	29.4	2.2
10/3/2006 15:10	19.8	14.4	1.8
10/3/2006 15:11	25.3	9	1.3
10/3/2006 15:12	25.3	11.8	1.1
10/3/2006 15:13	25.3	11.4	1.1
10/3/2006 15:14	25.3	10.8	1.1
10/3/2006 15:15	25.3	8.2	1.2
10/3/2006 15:16	16.6	19.6	1.5
10/3/2006 15:17	10.4	30.1	3
10/3/2006 15:18	10.3	29.9	3.8
10/3/2006 15:19	10.3	26.1	4.8
10/3/2006 15:20	24.3	17.8	2.3
10/3/2006 15:21	25.3	13.4	1.7
10/3/2006 15:22	25.3	20.4	2
10/3/2006 15:23	25.4	13.5	1.3
10/3/2006 15:24	25.3	8.8	1.2
10/3/2006 15:25	11.3	25.1	2.3
10/3/2006 15:26	20.1	11.8	1.7
10/3/2006 15:27	25.3	7.4	1.2
10/3/2006 15:28	25.3	8	1.3
10/3/2006 15:29	15.9	18	1.8
10/3/2006 15:30	10.4	22.6	4.1
10/3/2006 15:31	10.3	21.1	6.7
10/3/2006 15:32	20.1	12.9	3
10/3/2006 15:33	20.4	7.4	1.5
10/3/2006 15:34	20.4	4.7	1.2
10/3/2006 15:35	20.4	3.6	1.1
10/3/2006 15:36	20.4	3	1.1
10/3/2006 15:37	20.4	2.5	1.1
10/3/2006 15:38	20.4	2.2	1.1
10/3/2006 15:39	11.3	1.9	0.9
10/3/2006 15:40	5.9	1.8	0.6
10/3/2006 15:41	5.3	1.6	0.4
10/3/2006 15:42	5.3	1.4	0.4
10/3/2006 15:43	5.3	1.3	0.3
10/3/2006 15:44	5.3	1.2	0.3
10/3/2006 15:45	5.3	1.2	0.3
10/3/2006 15:46	5.4	1.1	10
10/3/2006 15:47	0.4	0.9	45
10/3/2006 15:48	0.3	0.7	49.6 NOx gas (49.08)
10/3/2006 15:49	0.3	0.6	50
10/3/2006 15:50	50.4	0.6	17.1
10/3/2006 15:51	90.3	0.6	1.8
10/3/2006 15:52	90.3	0.5	0.1 CO gas (94.36)
10/3/2006 15:53	1.3	44.4	0.4
10/3/2006 15:54	0.4	52.7	0.4
10/3/2006 15:55	0.4	55.6	0.4
10/3/2006 15:56	0.4	57	0.3
10/3/2006 15:57	0.3	57.8	0.3 SO2 gas (82.09)

Run 2 Averages	
CO	17.76
NOx	3.80
SO2	20.46

# ANALYZER FIELD DATA

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10/5/2006
Run Number:	3

	CO	SO <sub>2</sub>	NO <sub>x</sub>	INITIAL CALS
10/5/2006 8:27	0.2	162	-0.1	SO2 gas (150.1)
10/5/2006 8:28	0.2	34.1	-0.1	
10/5/2006 8:29	22.3	3.4	-0.1	
10/5/2006 8:30	178.4	3.2	0.3	
10/5/2006 8:31	182.2	3.5	2.3	CO gas (182.0)
10/5/2006 8:32	0.8	-0.3	66.2	
10/5/2006 8:33	0.4	-0.2	61.9	
10/5/2006 8:34	0.4	-0.2	62.1	
10/5/2006 8:35	0.4	-0.2	56.1	
10/5/2006 8:36	0.4	-0.2	84.8	
10/5/2006 8:37	0.4	-0.2	87.3	NOx gas (87.1)
10/5/2006 8:38	25.3	-0.2	33.8	
10/5/2006 8:39	93.2	-0.2	3.1	
10/5/2006 8:40	94	-0.3	-0.3	CO gas (84.36)
10/5/2006 8:41	10.4	60.4	-0.3	
10/5/2006 8:42	0.5	60.8	-0.2	SO2 gas (62.09)
10/5/2006 8:43	0.4	0.3	9.7	
10/5/2006 8:44	0.4	-0.1	45.5	
10/5/2006 8:45	0.4	-0.1	49.9	NOx gas (49.08)
10/5/2006 8:46	0.4	0.1	21.8	
10/5/2006 8:47	31.2	0.1	14.3	
10/5/2006 8:48	0.8	0	45.8	BIAS CHECKS
10/5/2006 8:49	0.3	0	49.6	NOx gas (49.08)
10/5/2006 8:50	4.6	0.1	39.8	
10/5/2006 8:51	90.5	-0.1	4.9	
10/5/2006 8:52	93.6	-0.1	-0.2	CO gas (94.36)
10/5/2006 8:53	93.7	-0.1	-0.2	
10/5/2006 8:54	5.5	33.6	-0.1	
10/5/2006 8:55	0.5	48.7	0.1	
10/5/2006 8:56	0.4	60.1	0	SO2 gas (62.09)
10/5/2006 8:57	0.4	42.1	-0.1	
10/5/2006 8:58	12.7	58	15.9	
10/5/2006 8:59	20.2	65.8	27.6	
10/5/2006 9:00	23.8	67.3	41.3	
10/5/2006 9:01	20.5	84.8	50.3	
10/5/2006 9:02	11.2	16.3	31.1	
10/5/2006 9:03	7.1	25.9	9.9	
10/5/2006 9:04	30.1	33.6	17.9	
10/5/2006 9:05	32.1	36.4	19.5	
10/5/2006 9:06	35.4	43.3	19.6	
10/5/2006 9:07	35.5	56.6	22.3	
10/5/2006 9:08	26.2	51.3	28.2	
10/5/2006 9:09	27.5	33.6	22.4	
10/5/2006 9:10	38.1	40.1	25.9	
10/5/2006 9:11	25.8	52.2	17.1	
10/5/2006 9:12	32.5	29.1	7.2	
10/5/2006 9:13	35.4	33.4	8.9	
10/5/2006 9:14	33.1	25.6	6.2	
10/5/2006 9:15	37.7	18.9	5.2	
10/5/2006 9:16	36.2	17.6	5.3	
10/5/2006 9:17	37.8	18.6	4.9	
10/5/2006 9:18	59.7	12.2	1.4	
10/5/2006 9:19	52.5	8.8	0.8	
10/5/2006 9:20	48	7.2	0.9	
10/5/2006 9:21	58.1	5.6	0.6	
10/5/2006 9:22	47.5	4.8	0.6	
10/5/2006 9:23	35.6	10.9	4.2	
10/5/2006 9:24	44.7	9.8	9.6	
10/5/2006 9:25	32.3	33.6	35.6	
10/5/2006 9:26	30.4	45.9	65	
10/5/2006 9:27	35.4	51.2	65.7	
10/5/2006 9:28	30.5	44	51.1	
10/5/2006 9:29	43.5	38.4	38.7	
10/5/2006 9:30	69.8	21.6	9.7	

# ANALYZER FIELD DATA

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	10/5/2006
Run Number:	3

	CO	SO <sub>2</sub>	NO <sub>x</sub>
10/5/2006 9:31	60.6	12.3	1.9
10/5/2006 9:32	65.4	12.9	0.9
10/5/2006 9:33	55.7	17.3	0.7
10/5/2006 9:34	58.6	16.4	0.7
10/5/2006 9:35	57.4	12.6	0.6
10/5/2006 9:36	60.2	7.5	0.6
10/5/2006 9:37	59.7	5.6	0.6
10/5/2006 9:38	65.2	4.6	0.5
10/5/2006 9:39	62.3	4.1	0.6
10/5/2006 9:40	60.4	3.7	0.6
10/5/2006 9:41	70	3.6	0.5
10/5/2006 9:42	65.8	4.2	0.5
10/5/2006 9:43	69.6	4.2	0.6
10/5/2006 9:44	67.2	3.7	0.8
10/5/2006 9:45	69.7	3.2	0.5
10/5/2006 9:46	52.1	4	0.7
10/5/2006 9:47	40.6	15.6	3.1
10/5/2006 9:48	40.4	10.7	9.1
10/5/2006 9:49	40	11.7	18.7
10/5/2006 9:50	58.7	7.4	4.2
10/5/2006 9:51	60.4	14.4	2.4
10/5/2006 9:52	60.4	10.3	1.5
10/5/2006 9:53	51	9.7	1.8
10/5/2006 9:54	40.8	9.9	3.4
10/5/2006 9:55	54.7	6.9	1.2
10/5/2006 9:56	41.1	9	2.3
10/5/2006 9:57	44.7	8.9	6.8
10/5/2006 9:58	50.3	6.4	1.7
10/5/2006 9:59	41	7.2	3.3
10/5/2006 10:00	36.1	6.9	4.8
10/5/2006 10:01	45.2	4.6	1
10/5/2006 10:02	41.1	3.7	0.6
10/5/2006 10:03	16.1	3.1	0.4
10/5/2006 10:04	30.1	2.6	-0.1
10/5/2006 10:05	39.7	2.5	-0.3
10/5/2006 10:06	36.1	2.3	-0.3
10/5/2006 10:07	40.4	2.2	-0.3
10/5/2006 10:08	45	2.1	-0.3
10/5/2006 10:09	40.8	2	-0.3
10/5/2006 10:10	40.2	2	-0.4
10/5/2006 10:11	40.4	1.9	-0.3
10/5/2006 10:12	36.1	1.8	-0.4
10/5/2006 10:13	12	35	-0.1
10/5/2006 10:14	0.5	51	0.1
10/5/2006 10:15	0.4	54.4	0
10/5/2006 10:16	0.4	56.1	0
10/5/2006 10:17	0.4	56.9	0
10/5/2006 10:18	0.4	57.5	0
10/5/2006 10:19	0.4	58.1	0 SO2 gas (62.09)
10/5/2006 10:20	9	30.7	0
10/5/2006 10:21	91.1	9.2	-0.1
10/5/2006 10:22	93.5	5.5	-0.1 CO gas (94.36)
10/5/2006 10:23	86.9	4.2	2
10/5/2006 10:24	6.9	3.7	29.3
10/5/2006 10:25	0.4	2.8	48.2
10/5/2006 10:26	0.4	2.3	50
10/5/2006 10:27	0.4	2	50.1
10/5/2006 10:28	0.4	1.3	50.1 NOx gas (49.08)

Run 3 Averages	
CO	44.10
NOx	10.59
SO2	19.13

**APPENDIX C**

---

**FIELD DATA**

Lead Emissions

**VELOCITY TRAVERSE POINT DETERMINATION**  
 (EPA Method 1)

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	LEAD - Castrip
Date:	10-2-06 to 10-5-06

Circular Stack  
 Traverse Points on Diameter:  
 Stack Diameter (inches):

		4	6	8	10	12
96						
Point	1	6.43	4.22	3.07	2.50	2.02
	2	24.00	14.02	10.08	7.87	6.43
	3	72.00	28.42	18.62	14.02	11.33
	4	89.57	67.58	31.01	21.70	16.99
	5		81.98	64.99	32.83	24.00
	6		91.78	77.38	63.17	34.18
	7			85.92	74.30	61.82
	8			92.93	81.98	72.00
	9				88.13	79.01
	10				93.50	84.67
	11					89.57
	12					93.98

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

**LEAD**

TESTING

EPA METHOD

1-4/12/19

RUN 1

PAGE

CLIENT: **Nucor Steel** METER BOX ID: **A-1** K FACTOR: **3.5** DUCT DIMENSIONS (in.): **96"** Diagram of Test Location

LOCATION: **CRAWFORDSVILLE, IN** METERY: **0.84** METER ΔH@: **1.74** PORT LENGTH (in.): **5"**

UNIT: **CAST STRIP** PITOT Cp: **0.87** PROBE LINER: **GLASS** FILTER ID: **R1** SILICA ID: **#1**

DATE: **10-2-06** PROJECT #: **517** NOZZLE ID: **0.25** TEDLAR BAG ID: **01 20.0**

METER OPERATOR: **CARLOS BROWN** BAROMETRIC: **30.13** AMBIENT TEMP (°F): **-0.25** PASS  FAIL  PITOT CHECK


PROBE OPERATOR: **MARCUS ALLEN** STATIC PRESSURE (in. H<sub>2</sub>O): **0.000 @ (in. Hg)** H<sub>2</sub>O (mL): **4.0**

VISIBLE EMISSIONS READER: **NITA GREEN BURG** LEAK RATE BEFORE (cfm): **0.000 @ (in. Hg)** SILICA GEL (g): **13.5**

CLIENT CONTACT: **TRENDA BEERS** LEAK RATE AFTER (cfm): **0.000 @ (in. Hg)** TOTAL Vlc: **17.5**

AGENCY CONTACT: **DAVID HARRISON** START TIME: **0901** STOP TIME: **1009**

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filter TT (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2:5	0.65	2.28	77.20	95	250	249	54	66	64	2	
2	5:0	0.65	2.28	81.1	95	251	252	55	66	64	2	
3	7:5	0.62	2.17	83.0	96	250	250	56	66	64	2	
4	10:0	0.62	2.17	85.0	103	250	248	57	67	64	2	
5	12:5	0.62	2.17	87.0	104	249	248	58	68	65	2	
6	15:0	0.60	2.10	88.8	105	248	249	59	69	65	2	
7	17:5	0.60	2.10	90.8	110	251	253	59	70	66	2	
8	20:0	0.61	2.14	93.0	111	253	250	59	70	66	2	
9	22:5	0.59	2.07	94.9	112	250	250	60	71	66	2	
10	25:0	0.58	2.04	97.0	115	250	250	61	72	67	2	
11	27:5	0.52	1.82	98.8	120	250	251	62	74	68	2	
12	30	0.52	1.82	100.6	120	250	250	62	74	68	2	
13	32:5	0.54	1.89	102.6	126	245	246	62	74	69	2	
14	35:0	0.53	1.86	104.6	127	249	245	62	76	70	2	
15	37:5	0.52	1.82	106.4	128	249	250	62	76	70	2	
16	40:0	0.52	1.82	108.4	129	249	252	63	78	71	2	
17	42:5	0.51	1.79	110.1	132	249	254	64	79	72	2	
18	45:0	0.51	1.79	112.0	132	249	244	64	80	73	2	
19	47:5	0.52	1.82	114.0	132	249	248	64	81	73	2	
20	50:0	0.50	1.75	115.8	132	250	248	64	81	73	2	
21	52:5	0.52	1.82	117.7	131	251	251	65	81	73	2	
22	55:0	0.51	1.79	119.7	131	250	251	65	81	73	2	
23	57:5	0.50	1.75	121.6	130	250	252	66	81	73	2	
24	60	0.59	2.03	123.40	130	250	250	66	81	73	2	



**AIR TEST PROFESSIONALS FIELD DATA SHEET**


TESTING LEAP

EPA METHOD 1-4/12/9 RUN 2

PAGE 2

CLIENT <u>NUCOR STEEL</u>	METER BOX ID <u>A-1</u>	K FACTOR <u>3.60</u>	DUCT DIMENSIONS (in.) <u>96"</u>
LOCATION <u>CANTON OHIO W. VILLE, IN</u>	METER AH@ <u>1.74</u>	METER AH@ <u>1.74</u>	PORT LENGTH (in.) <u>5"</u>
UNIT <u>CAST STRIP</u>	PITOT C <sub>p</sub> <u>0.84</u>	PROBE LINER <u>3-CAS</u>	FILTER ID <u>R2</u> SILICA ID <u>#2</u>
DATE <u>10-3-06</u>	PROJECT # <u>06</u>	NOZZLE ID <u>0.25</u>	TEDLAR BAG ID
METER OPERATOR <u>CARLOS BROWN</u>	BAROMETRIC <u>30.06</u>	AMBIENT TEMP (°F) <u>-0.25</u>	PITOT CHECK <input type="checkbox"/> O <sub>2</sub> <u>20.0</u> <input checked="" type="checkbox"/> FAIL <input type="checkbox"/> CO <sub>2</sub> <u>0.0</u>
PROBE OPERATOR <u>ANDY YOUNG</u>	STATIC PRESSURE (in. H <sub>2</sub> O) <u>0.00</u>	@ (in. Hg) <u>12.1</u>	SILICA GEL (g) <u>12.0</u>
VISIBLE EMISSIONS READER <u>NITA GARDNER</u>	LEAK RATE BEFORE (cfm) <u>0.00</u>	@ (in. Hg) <u>8"</u>	TOTAL V <sub>c</sub> <u>22.2</u>
CLIENT CONTACT <u>TREVOR BEERS</u>	LEAK RATE AFTER (cfm) <u>0.00</u>	STOP TIME <u>1536</u>	
AGENCY CONTACT <u>DAVID HARRISON</u>	START TIME <u>1432</u>		

Traverse Point Number	Min/Point Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filter TT (°F)		Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
							Set Points						
1	2.5	0.60	2.16	136.10	142	250	261	254	66	86	85	4	
2	5.0	0.58	2.09	138.2	142	254	254	251	65	86	85	4	
3	7.5	0.58	2.09	140.3	143	254	251	251	65	86	85	4	
4	10.0	0.58	2.09	142.2	144	252	251	253	65	87	86	4	
5	12.5	0.52	1.87	144.5	146	248	253	250	64	88	86	3.5	
6	15.0	0.48	1.73	146.2	144	247	250	256	64	88	86	3.5	
7	17.5	0.58	2.09	148.1	149	251	256	247	64	89	87	4.0	
8	20.0	0.58	2.09	150.2	150	251	247	245	64	89	87	4.0	
9	22.5	0.55	1.98	152.2	151	249	245	255	64	91	88	4	
10	25.0	0.60	2.16	154.2	151	249	255	255	64	92	88	4	
11	27.5	0.50	1.80	156.3	151	251	250	250	63	92	88	4	
12	30	0.46	1.66	158.2	147	251	252	252	63	93	89	4	
13	32.5	0.58	2.09	160.1	155	249	256	256	64	94	90	4	
14	35.0	0.54	1.94	162.1	155	253	251	251	64	94	90	4	
15	37.5	0.54	1.94	164.1	155	253	251	251	64	95	90	4	
16	40.0	0.54	1.94	166.0	155	253	251	244	64	95	90	4	
17	42.5	0.47	1.69	168.1	156	251	244	252	64	96	91	4	
18	45.0	0.42	1.51	170.0	156	249	252	245	64	97	92	4	
19	47.5	0.58	2.09	171.7	156	248	245	246	65	97	93	4	
20	50.0	0.60	2.16	173.7	158	248	246	253	65	98	93	4	
21	52.5	0.55	1.98	175.7	159	249	253	250	65	99	93	4	
22	55.0	0.58	2.09	177.7	160	250	250	251	66	99	94	4	
23	57.5	0.54	1.94	179.8	160	251	251	255	66	100	95	4	
24	60	0.42	1.51	181.8	160	252	255	250	66	101	96	4	
				183.578	161	252	250						



**AIR TEST PROFESSIONALS FIELD DATA SHEET**

LEAD TEST


EPA METHOD 1-4/12/9

RUN 3

PAGE 1 OF 3

CLIENT: NU CORP METER BOX ID: A-1 K FACTOR: 3.70 DUCT DIMENSIONS (in.): 96"  
 LOCATION: CRAWFORDVILLE, IN METER Y: 0.99 METER ΔH: 1.74 PORT LENGTH (in.): 5"  
 UNIT: CAST STEEL PITOT Cp: 0.84 PROBE LINER: GLASS FILTER ID: R3 SILICA ID: 3  
 DATE: 10-5-06 PROJECT #: PROJECT # NOZZLE ID: 0.25 TEDLAR BAG ID:  
 METER OPERATOR: CARLOS BROWN BAROMETRIC: 30.15 AMBIENT TEMP (°F):  
 PROBE OPERATOR: ANDY YOUNG STATIC PRESSURE (in. H<sub>2</sub>O):  
 VISIBLE EMISSIONS READER: LEAK RATE BEFORE (cfm): 0.00 @ (in. Hg): 1" H<sub>2</sub>O (mL): 7.0  
 CLIENT CONTACT: TREVOR BEERS LEAK RATE AFTER (cfm): 0.00 @ (in. Hg): 8" SILICA GEL (g): 13.6  
 AGENCY CONTACT: PAVID HARRISON START TIME: 0857 STOP TIME: 1007 TOTAL Vols: 20.6

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Office Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.50	1.85	184.700	106	257	250	50	54	54	3	
2	5.0	0.50	1.85	188.0	107	254	250	50	54	54	3	
3	7.5	0.48	1.78	190.0	108	254	248	50	54	54	3	
4	10.0	0.44	1.63	190.0	112	252	248	51	55	54	3	
5	12.5	0.42	1.55	193.2	119	254	250	51	55	54	3	
6	15.0	0.42	1.55	195.0	121	252	250	52	55	54	3	
7	17.5	0.48	1.78	197.0	123	250	250	52	55	54	3	
8	20.0	0.56	2.07	199.0	128	250	252	53	55	54	3	
9	22.5	0.56	2.07	201.0	132	252	250	53	56	54	3	
10	25.0	0.58	2.15	203.0	130	252	252	54	56	55	3	
11	27.5	0.60	2.22	205.0	134	252	254	54	56	55	3	
12	30	0.62	2.29	207.0	138	252	254	54	56	55	3	
13	32.5	0.52	1.92	208.8	140	254	254	54	56	55	3	
14	35.0	0.52	1.92	210.6	145	254	256	54	56	55	3	
15	37.5	0.54	2.00	212.4	146	252	254	55	56	55	3	
16	40.0	0.54	2.00	214.2	142	252	256	55	57	56	3	
17	42.5	0.55	2.04	216.0	140	252	256	55	57	56	3	
18	45.0	0.56	2.07	217.8	138	252	258	55	57	56	3	
19	47.5	0.56	2.07	219.6	125	254	256	55	57	56	3	
20	50.0	0.58	2.15	221.3	123	254	256	56	57	56	3	
21	52.5	0.60	2.22	223.1	125	252	257	56	57	56	3	
22	55.0	0.62	2.29	224.8	124	252	256	56	57	56	3	
23	57.5	0.64	2.37	226.6	122	250	256	56	57	56	3	
24	60	0.65	2.41	228.350	122	250	257	56	57	56	3	



**APPENDIX D**

---

**LABORATORY DATA**

**Particulate Emissions**

**LABORATORY DATA**

**PARTICULATE WEIGHT SHEET**

**Source:** Nucor Steel – Cast Strip Stack

Date:	10/02/06	10/03/06	10/05/06	
<b>Acetone</b>	<b>Blank</b>	<b>1</b>	<b>2</b>	<b>3</b>
Run ID#	A-10	A7	A5	A9
Tare Wt	63.8189	65.7294	64.2841	64.7773
Gross Wt	63.8189	65.7333	64.2874	64.7796
Correction	0.0000	0.0000	0.0000	0.0000
Net Wt	0.0000	0.0039	0.0033	0.0023
<b>Filter</b>	<b>1</b>	<b>2</b>	<b>3</b>	
Run ID#	#460	#458	#465	
Tare Wt	0.4087	0.4016	0.4013	
Gross Wt	0.4099	0.4033	0.4025	
Net Wt	0.0012	0.0017	0.0012	
<b>Total Gain</b>	<b>0.0051</b>	<b>0.0050</b>	<b>0.0035</b>	

# **Air Test Professionals, Inc.**

1201 North Graham Avenue  
Indianapolis, IN 46219

**Nucor Steel– Strip Caster**  
PO# 183

**Analytical Report**  
(1106-17)

***HPLC Analysis***  
Sulfate

***EPA Method 202***  
Condensable particulate



**Enthalpy Analytical, Inc.**

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)
- This analytical report was prepared in Portable Document Format (.PDF) and contains 53 pages.

*Michael Steven Schapira*

QA Review Performed by: Michael Steven Schapira



# Summary of Results



**EPA Method 202 - Condensable Particulate Determination - Data Analysis**

Company	Air Test Professionals, Inc.
Analyst	SLG
Parameters	EPA Method 202
# Samples	3 Runs and 1 Blank

Client #	Nucor Steel-Strip Caster
Job #	1106-17
PO #	183
Report Date	11/10/06

**Analysis of Particulate Recovery**

Sample ID Number	Run-1	Run-2	Run-3
<b>Organic</b>			
Beaker Number	9337	9316	9269
Final Weight, g	1.0111	0.9698	1.0185
Reweigh, Final, g	1.0111	0.9699	1.0185
Beaker Tare Weight, g	1.0099	0.9682	1.0171
Beaker Tare Reweigh, Initial, g	1.0099	0.9682	1.0172
Solvent Blank, g	0.0016	0.0017	0.0015
MeCl2 FV, mL	220	226	212
Net Organic Catch, mg	-0.4	0.0	-0.2
<b>Inorganic</b>			
Beaker Number	9366	9346	9342
Final Weight, g	1.0047	1.0644	1.0437
Reweigh, Final, g	1.0046	1.0645	1.0437
Beaker Tare Weight, g	0.9971	1.0497	1.0134
Beaker Tare Reweigh, Initial, g	0.9972	1.0495	1.0133
Water Blank, g	0.0007	0.0009	0.0009
Sample Final Volume, mL	401	485	475
Charge and Rinse Vol, mL	397	475	469
Sulfate aliquot, mL	5.00	5.00	5.00
Sulfate aliquot CF	1.01	1.01	1.01
Net Inorganic CF	1.09	1.09	1.09
Net Inorganic, mg	7.4	15.7	32.6
Sulfate Catch, ug	6,380	13,619	12,978
Sulfate Correction, mg	2.3	4.9	4.6
Corrected Inorganic, mg	5.2	10.8	28.0
Condensable Particulate, mg	5.2	10.8	28.0

**Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	9282
Final Weight, g	0.9908
Reweigh, Final, g	0.9908
Initial Weight, g	0.9896
Reweigh, Initial, g	0.9896
MeCl2 Residue, g	0.0012
MeCl2 Volume, mL	78.0
Max. MeCl2 Residue, g	0.0010

Sample ID Number	H2O Blank
Beaker Number	9386
Final Weight, g	0.9961
Reweigh, Final, g	0.9961
Initial Weight, g	0.9954
Reweigh, Initial, g	0.9955
Water Residue, g	0.0006
Water Volume, mL	323
Max. Water Residue, g	0.0032

**In-House Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	9329
Final Weight, g	0.9912
Reweigh, Final, g	0.9913
Initial Weight, g	0.9903
Reweigh, Initial, g	0.9903
MeCl2 Residue, g	0.0010
MeCl2 Volume, mL	225
Max. MeCl2 Residue, g	0.0030

Sample ID Number	H2O Blank
Beaker Number	9392
Final Weight, g	0.9953
Reweigh, Final, g	0.9953
Initial Weight, g	0.9948
Reweigh, Initial, g	0.9948
Water Residue, g	0.0005
Water Volume, mL	250
Max. Water Residue, g	0.0025

Company	ATP, Inc.
Analyst	KEH
Parameters	HPLC Analysis
# Samples	3 runs & 1 blank

Client #	Nucor Steel
Job #	1106-17
PO #	183
Report Date	11/10/2006

Compound	Sample ID / Catch Weight (ug)		
	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>
Sulfate	6,380	13,619	12,978
	<b>Blank</b>		
Sulfate	450		

# Results



Company ATP, Inc.  
 Analyst KEH  
 Parameters HPLC Analysis  
 # Samples 3 runs & 1 blank

Client # Nucor Steel  
 Job # 1106-17  
 PO # 183  
 Report Date 11/10/2006

MDL 0.0622 (ug/mL)  
 LOQ 0.372 (ug/mL)

Lower Curve Limit 0.372 (ug/mL)  
 Upper Curve Limit 13.0 (ug/mL)

Compound Sulfate

Sample ID	Lab ID # 1	Lab ID # 2	Analysis Method	Ret Time (min)	Ret Time (min)	% Diff Ret	Conc # 1 (ug/mL)	Conc # 2 (ug/mL)	% Diff Conc	Avg Conc (ug/mL)	DF	Vol (mL)	Catch Weight (ug)	Qual
Run 1	021-1201.D	021-1202.D	1106-17R.	7.38	7.38	0.1	5.31	5.32	0.2	5.32	20	60.0	6,380	
Run 2	022-1301.D	022-1302.D	1106-17R.	7.38	7.40	0.3	2.28	2.25	0.7	2.27	100	60.0	13,619	
Run 3	023-1401.D	023-1402.D	1106-17R.	7.39	7.39	0.0	2.17	2.16	0.1	2.16	100	60.0	12,978	
Blank	024-1501.D	024-1502.D	1106-17R.	7.38	7.38	0.1	7.50	7.50	0.0	7.50	1	60.0	450	
IHB	025-1601.D	025-1602.D	1106-17R.	7.39	7.39	0.0	3.38	3.38	0.0	3.38	1	60.0	203	
DIUF H2O	008-0901.D	008-0902.D	1106-17R.	NA	NA	NA	0.0622	0.0622	0.0	0.0622	1	1.00	0.0622	ND
MS / Run 1	026-1701.D	026-1702.D	1106-17R.	7.38	7.38	0.0	7.41	7.44	0.2	7.43	1	0.525	3.90	
													Spike Amount (ug)	1.25
													Native Amount (ug)	2.66
													Spike Recovery (%)	99.3%

# Narrative Summary



## Enthalpy Analytical Narrative Summary

<b>Company:</b>	ATP, Inc.
<b>Client #:</b>	Nucor Steel
<b>PO #</b>	183

<b>Enthalpy #:</b>	1106-17
<b>Analyst:</b>	SLG
<b>Parameters:</b>	EPA Method 202

### Custody

Erin Ortiz of Enthalpy Analytical, Inc. received the samples at ambient temperature on 11/3/06 after being relinquished by Air Test Professionals, Inc. There were no visible container problems noted upon receipt. Prior to and during analysis they were kept under lock with access only to authorized personnel of Enthalpy Analytical, Inc.

### Methodology

All samples were analyzed in accordance to the requirements and specifications of EPA Method 202.

### Instrumentation

All samples were weighed on Mettler AB265-S (SN-1125163272) certified by Precision Weighing, Inc. through October 2, 2007 (NIST Test Number 1132850A).

### Labeling

OK

### Reporting Notes

The inorganic and organic catch weights are adjusted by a blank correction value. A mathematically determined (theoretical) maximum value is calculated and compared with the actual value measured for each blank. The lower of the two values is used as the blank correction value, which is then factored by the sample volume divided by the blank volume, and subtracted from the sample's catch weight.

Enthalpy considers gravimetric analyses for Method 202  $\pm 0.5$  mg at best. Therefore, negative catch weights between 0 and  $-0.5$  mg are treated as zero when determining the total catch weight and no investigation is undertaken. Negative catch weights  $< -0.5$  mg are investigated. None of the catch results for this data set were  $< -0.5$  mg. The organic fraction of *Run 1* and *Run 3* were both slightly negative, due to the blank correction.

We have reported the sulfate result from the analysis of the post-(resuspended liquid) fraction of the samples, rather than the pre-(initial liquid) fraction. This gives the more scientifically correct number.

## Enthalpy Analytical Narrative Summary

Company:	ATP, Inc.
Client #:	Nucor Steel
PO #:	183

Enthalpy #:	1106-17
Analyst:	KEH
Parameters:	HPLC Analysis

- Custody** Erin Ortiz of Enthalpy Analytical, Inc. received the samples at ambient temperature on 11/3/06 after being relinquished by Air Test Professionals, Inc. Prior to analysis the samples were kept under lock with access only by authorized personnel of Enthalpy Analytical, Inc.
- Analysis** The samples were analyzed for sulfate using a Hewlett-Packard series 1100 High Performance Liquid Chromatograph with a Dionex ED40 conductivity detector and a Dionex ASRS suppressor.
- Separation** Separation was accomplished by a Dionex IonPac AS14 250 x 4.0 mm analytical column using 8.0 mM Na<sub>2</sub>CO<sub>3</sub>/1.0 mM NaHCO<sub>3</sub> as the eluent at 1.2 mL per minute. A copy of the analytical method (1006-38.M) is included.
- Before and after sample analysis, a calibration curve was prepared and analyzed.
- Sulfate eluted at approximately 7.4 minutes, separated well, and was easily identified.
- Matrix Spike** A matrix spike was prepared by spiking a 0.500-mL aliquot of a 20-fold diluted sample *Run 1* with 1.25 µg of sulfate (25.0 µL of a 50.0 µg/mL solution). The spiked samples were analyzed in the same manner as the other samples. The calculated spike recovery was 99.3%.
- Blanks** One blank sample was submitted for analysis. No blank adjustments were made to any of the data.
- Reproducibility** OK
- Quality of Data** OK
- Reporting Notes** None.

## General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. reports, unless specifically noted otherwise.

- The symbol **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot confirm the presence of the analyte of interest reliably.
- The symbol **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The symbol **ND** following a value indicates a non-detect or analytical result below the MDL.
- The symbol **J** following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The symbol **E** following a value indicates an analytical result exceeding 100% of the highest calibration point.
- The symbol **DF** represents a Dilution Factor. This number represents dilutions during the extraction and/or laboratory stages of sample treatment. The analytical result taken from a laboratory instrument is multiplied by the DF to get final results.
- The Sample ID **MS** represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix prohibits analysis for the analyte(s).
- The Sample ID **MSD** represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times. Most methods performed by Enthalpy do not require analysis of an MSD.
- The Sample ID **BS** represents a Blind Spike. A member of the Quality Assurance department has created BS samples for many of the analytes Enthalpy tests for, and only QA and the Enthalpy Analytical ownership have access to the actual values of these samples. The laboratory analyzes them without knowledge of the actual value, and the spreadsheets get completed for these samples solely by the QA group.
- The Sample ID **LCS** represents a Laboratory Control Sample. Whenever spikes are prepared for our clients more spikes are prepared than needed. The extras (randomly chosen) are kept in-house at the appropriate temperature conditions. When the spike samples come back from the client for analysis, the LCSs (usually two are saved) are analyzed to confirm that the analyte could be recovered from the media, separate from the spike samples which were used on the project and which may have had issues caused during collection and/or transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed (specifically values of 1,000 or greater), the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits reported, but no confidence should be placed on more than three significant digits.



# Sample Chromatograms




1106-17

```

=====
Injection Date   : 11/8/2006 9:21:43 PM      Seq. Line   : 12
Sample Name     : Run 1 post*20             Location    : Vial 21
Acq. Operator  : KEH                       Inj         : 1
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```

ADC1 B, Dionex ED 40 (H:\LC2006Q4\GONZO\DATA\NOV\1106-17A\021-1201.D)



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.384	BB	316.40921	1.67775e-2	5.30856		Sulfate

```
Totals :                               5.30856
```

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

1106-17

```

=====
Injection Date   : 11/8/2006 9:33:44 PM      Seq. Line :   12
Sample Name     : Run 1 post*20              Location  : Vial 21
Acq. Operator  : KEH                        Inj       :    2
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier    : 1.0000
Dilution      : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.378	BB	317.36676	1.67779e-2	5.32475		Sulfate

Totals : 5.32475

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*


1106-17

```

=====
Injection Date   : 11/8/2006 9:45:35 PM      Seq. Line :   13
Sample Name     : Run 2 post*100            Location  : Vial 22
.cq. Operator   : KEH                       Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```

ADC1 B, Dionex ED 40 (H:\LC2006Q4\GONZO\DATA\NOV\1106-17A\022-1301.D)



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.376	BB	137.62202	1.66024e-2	2.28485		Sulfate

```
Totals :                               2.28485
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

1106-17

```

=====
Injection Date   : 11/8/2006 9:57:26 PM      Seq. Line :   13
Sample Name     : Run 2 post*100            Location  : Vial 22
Acq. Operator  : KEH                       Inj       :    2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method: H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier    :      1.0000
Dilution      :      1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.397	BB	135.83621	1.65983e-2	2.25465		Sulfate


```
Totals :                               2.25465
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```




1106-17

```

=====
Injection Date   : 11/8/2006 10:09:18 PM      Seq. Line :   14
Sample Name     : Run 3 post*100             Location  : Vial 23
Acq. Operator   : KEH                       Inj       :    1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier          :      1.0000
Dilution            :      1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.393	BB	130.55305	1.65856e-2	2.16530		Sulfate

```
Totals :                               2.16530
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

1106-17

```

=====
Injection Date   : 11/8/2006 10:21:11 PM      Seq. Line : 14
Sample Name     : Run 3 post*100             Location  : Vial 23
Acq. Operator  : KEH                        Inj       : 2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method: H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.390	BB	130.28017	1.65849e-2	2.16069		Sulfate

Totals : 2.16069


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

1106-17 Sample Blank

```

=====
Injection Date : 11/8/2006 10:33:00 PM      Seq. Line : 15
Sample Name    : Blank post                  Location  : Vial 24
Acq. Operator  : KEH                        Inj      : 1
Acq. Instrument : Gonzo                     Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

=====
Sorted By      :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier     :      1.0000
Dilution       :      1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.378	BB	445.85361	1.68167e-2	7.49776		Sulfate

Totals : 7.49776

Results obtained with enhanced integrator!


\*\*\* End of Report \*\*\*

1106-17 Sample Blank

```

=====
Injection Date   : 11/8/2006 10:44:51 PM      Seq. Line : 15
Sample Name     : Blank post                  Location  : Vial 24
Acq. Operator   : KEH                        Inj       : 2
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.383	BB	446.11011	1.68167e-2	7.50210		Sulfate

Totals : 7.50210

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

1106-17 In-House Blank

```

=====
Injection Date   : 11/8/2006 10:56:44 PM      Seq. Line :   16
Sample Name     : IHB post                    Location  : Vial 25
Acq. Operator   : KEH                        Inj       :    1
Acq. Instrument : Gonzo                      Inj Volume: 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.389	BB	202.45164	1.67016e-2	3.38127		Sulfate

```
Totals :                               3.38127
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

1106-17 In-House Blank

```

=====
Injection Date   : 11/8/2006 11:08:37 PM      Seq. Line : 16
Sample Name     : IHB post                    Location  : Vial 25
Acq. Operator  : KEH                          Inj       : 2
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method: H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier    : 1.0000
Dilution      : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.391	BB	202.31219	1.67015e-2	3.37891		Sulfate

Totals : 3.37891

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

Lab Blank DIUF H2O

```

=====
Injection Date : 11/8/2006 8:10:24 PM      Seq. Line : 9
Sample Name    : DIUF H2O                  Location  : Vial 8
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

=====
Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier    : 1.0000
Dilution      : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.356	-	-	-	-	-	Sulfate

Totals : 0.00000

Results obtained with enhanced integrator!

1 Warnings or Errors :


Warning : Calibrated compound(s) not found

Lab Blank DIUF H2O

```

=====
Injection Date   : 11/8/2006 8:22:14 PM      Seq. Line   :    9
Sample Name     : DIUF H2O                  Location    : Vial 8
Acq. Operator  : KEH                       Inj        :    2
Acq. Instrument : Gonzo                    Inj Volume  : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier    :      1.0000
Dilution      :      1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.356	-	-	-	-	-	Sulfate

Totals : 0.00000

Results obtained with enhanced integrator!  
1 Warnings or Errors :


Warning : Calibrated compound(s) not found

## 1106-17 Matrix Spike

```

=====
Injection Date   : 11/8/2006 11:20:27 PM      Seq. Line : 17
Sample Name     : MS/Run 1 post              Location  : Vial 26
Acq. Operator  : KEH                        Inj       : 1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method: H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.382	BB	440.71875	1.68155e-2	7.41092		Sulfate

```
Totals :                               7.41092
```

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====


```

1106-17 Matrix Spike

```

=====
Injection Date : 11/8/2006 11:32:16 PM      Seq. Line : 17
Sample Name    : MS/Run 1 post              Location  : Vial 26
Acq. Operator  : KEH                       Inj       : 2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.381	BB	442.64655	1.68160e-2	7.44353		Sulfate

Totals : 7.44353

Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

# **Curve(s)/QA Point(s) Chromatograms**



=====  
 Calibration Table  
 =====

Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM

Calculate : External Standard  
 Based on : Peak Area

Rel. Reference Window : 15.000 %  
 Abs. Reference Window : 0.000 min  
 Rel. Non-ref. Window : 15.000 %  
 Abs. Non-ref. Window : 0.000 min  
 Use Multiplier & Dilution Factor with ISTDs  
 Uncalibrated Peaks : not reported  
 Partial Calibration : Yes, identified peaks are recalibrated  
 Correct All Ret. Times: No, only for identified peaks

Curve Type : Linear  
 Origin : Connected  
 Weight : Linear (Amnt)

Recalibration Settings:  
 Average Response : Average all calibrations  
 Average Retention Time: Floating Average New 75%

Calibration Report Options :  
 Printout of recalibrations within a sequence:  
     Calibration Table after Recalibration  
     Normal Report after Recalibration  
 If the sequence is done with bracketing:  
     Results of first cycle (ending previous bracket)


Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Lvl Sig	Amount [ug/mL]	Area	Amt/Area	Ref Grp Name
7.356	1 1	3.72000e-1	24.59510	1.51250e-2	Sulfate
	2	2.38000	144.21933	1.65026e-2	
	3	4.55000	268.76852	1.69291e-2	
	4	6.52000	383.97714	1.69802e-2	
	5	9.18000	550.74869	1.66682e-2	
	6	13.00000	771.56766	1.68488e-2	

=====  
 Peak Sum Table  
 =====

\*\*\*No Entries in table\*\*\*  
 =====

=====  
 Calibration Curves  
 =====




Sulfate at exp. RT: 7.356  
 ADC1 B, Dionex ED 40  
 Correlation: 0.99996  
 Residual Std. Dev.: 3.70212  
 Formula:  $y = mx + b$   
     m: 59.12850  
     b: 2.52204  
     x: Amount [ug/mL]  
     y: Area  
 Calibration Level Weights:  
     Level 1 : 1  
     Level 2 : 0.156303  
     Level 3 : 0.081758  
     Level 4 : 0.057055  
     Level 5 : 0.040523  
     Level 6-76- : 0.028615

```

=====
Injection Date : 11/8/2006 5:24:13 PM      Seq. Line : 2
Sample Name    : Standard 1                Location  : Vial 1
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier    : 1.0000
Dilution      : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.367	BP	24.07130	1.51726e-2	3.65225e-1		Sulfate

Totals : 3.65225e-1

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 11/8/2006 5:36:06 PM           Seq. Line :    2
Sample Name     : Standard 1                     Location  : Vial 1
Acq. Operator   : KEH                           Inj       :    2
Acq. Instrument : Gonzo                          Inj Volume: 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier          : 1.0000
Dilution            : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.385	BV	25.11889	1.52143e-2	3.82165e-1		Sulfate

Totals : 3.82165e-1

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 5:47:56 PM      Seq. Line : 3
Sample Name    : Standard 2                Location  : Vial 2
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

=====
Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.363	BB	143.65038	1.66154e-2	2.38681		Sulfate

Totals : 2.38681


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 11/8/2006 5:59:53 PM      Seq. Line :    3
Sample Name     : Standard 2                Location  : Vial 2
Acq. Operator  : KEH                       Inj       :    2
Acq. Instrument : Gonzo                    Inj Volume: 25 µl
.cq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.374	BB	144.78828	1.66177e-2	2.40605		Sulfate

Totals : 2.40605

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 6:11:45 PM      Seq. Line : 4
Sample Name    : Standard 3                Location  : Vial 3
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                    Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.364	BB	269.13486	1.67538e-2	4.50904		Sulfate

Totals : 4.50904


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 11/8/2006 6:23:39 PM           Seq. Line   :    4
Sample Name     : Standard 3                     Location    : Vial 3
Acq. Operator  : KEH                             Inj         :    2
Acq. Instrument : Gonzo                         Inj Volume  : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.360	BB	268.40219	1.67534e-2	4.49665		Sulfate

Totals : 4.49665

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 6:35:28 PM      Seq. Line : 5
Sample Name    : Standard 4                Location  : Vial 4
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.354	BB	383.49753	1.68011e-2	6.44318		Sulfate

Totals : 6.44318


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 11/8/2006 6:47:22 PM      Seq. Line :    5
Sample Name     : Standard 4                 Location  : Vial 4
Acq. Operator  : KEH                        Inj       :    2
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier          :      1.0000
Dilution            :      1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.374	BB	384.45676	1.68014e-2	6.45940		Sulfate

Totals : 6.45940

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 6:59:16 PM      Seq. Line : 6
Sample Name    : Standard 5                Location  : Vial 5
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.370	BB	550.07312	1.68348e-2	9.26036		Sulfate

Totals : 9.26036

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 11/8/2006 7:11:07 PM           Seq. Line   :    6
Sample Name     : Standard 5                     Location    : Vial 5
Acq. Operator  : KEH                             Inj         :    2
Acq. Instrument : Gonzo                          Inj Volume  : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier          : 1.0000
Dilution            : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.367	PB	551.42426	1.68350e-2	9.28321		Sulfate

Totals : 9.28321

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 7:22:54 PM      Seq. Line : 7
Sample Name    : Standard 6                  Location  : Vial 6
Acq. Operator  : KEH                        Inj      : 1
Acq. Instrument : Gonzo                      Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.361	PB	772.01758	1.68571e-2	13.01395		Sulfate

Totals : 13.01395

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 11/8/2006 7:34:44 PM      Seq. Line   :    7
Sample Name     : Standard 6                 Location    : Vial 6
Acq. Operator   : KEH                       Inj         :    2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.355	PB	771.11774	1.68570e-2	12.99874		Sulfate

Totals : 12.99874

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 7:46:38 PM      Seq. Line : 8
Sample Name    : Second Source              Location  : Vial 7
Acq. Operator  : KEH                       Inj       : 1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.366	BB	463.54498	1.68203e-2	7.79697		Sulfate

Totals : 7.79697

Results obtained with enhanced integrator!

```


=====
*** End of Report ***
=====

```

```

=====
Injection Date   : 11/8/2006 7:58:32 PM      Seq. Line   :    8
Sample Name     : Second Source              Location    : Vial 7
Acq. Operator   : KEH                       Inj         :    2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       :      Signal
Calib. Data Modified :      Thursday, November 09, 2006 11:28:59 AM
Multiplier      :      1.0000
Dilution        :      1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.381	PB	464.95905	1.68206e-2	7.82088		Sulfate

Totals : 7.82088

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/8/2006 11:44:10 PM      Seq. Line : 18
Sample Name    : Standard 3                  Location  : Vial 3
Acq. Operator  : KEH                        Inj       : 1
Acq. Instrument : Gonzo                     Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.387	BB	265.43634	1.67516e-2	4.44649		Sulfate

Totals : 4.44649


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 11/8/2006 11:56:04 PM      Seq. Line :   18
Sample Name     : Standard 3                  Location  : Vial 3
Acq. Operator  : KEH                          Inj       :    2
Acq. Instrument : Gonzo                       Inj Volume: 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By           : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier          : 1.0000
Dilution             : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.393	BB	269.65012	1.67541e-2	4.51776		Sulfate

Totals : 4.51776

Results obtained with enhanced integrator!


```

=====
*** End of Report ***
=====

```

```

=====
Injection Date : 11/9/2006 6:15:11 AM      Seq. Line : 32
Sample Name    : Standard 3                Location  : Vial 3
Acq. Operator  : KEH                      Inj      : 1
Acq. Instrument : Gonzo                   Inj Volume : 25 µl
Acq. Method    : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed   : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed   : 11/9/2006 11:29:04 AM by KEH
=====
    
```



External Standard Report

```

Sorted By      : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier     : 1.0000
Dilution       : 1.0000
Use Multiplier & Dilution Factor with ISTDs
    
```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.427	BB	265.79144	1.67518e-2	4.45250		Sulfate

Totals : 4.45250


Results obtained with enhanced integrator!

\*\*\* End of Report \*\*\*

```

=====
Injection Date   : 11/9/2006 6:27:04 AM      Seq. Line   : 32
Sample Name     : Standard 3                 Location    : Vial 3
Acq. Operator   : KEH                       Inj         : 2
Acq. Instrument : Gonzo                     Inj Volume  : 25 µl
Acq. Method     : H:\LC2006Q4\GONZO\METHODS\1006-38.M
Last changed    : 10/9/2006 11:51:11 AM by KAM
Analysis Method : H:\LC2006Q4\GONZO\METHODS\1106-17R.M
Last changed    : 11/9/2006 11:29:04 AM by KEH
=====

```



```

=====
External Standard Report
=====

```

```

Sorted By       : Signal
Calib. Data Modified : Thursday, November 09, 2006 11:28:59 AM
Multiplier      : 1.0000
Dilution        : 1.0000
Use Multiplier & Dilution Factor with ISTDs

```

Signal 1: ADC1 B, Dionex ED 40

RetTime [min]	Type	Area [uS*s]	Amt/Area	Amount [ug/mL]	Grp	Name
7.430	PB	266.56104	1.67523e-2	4.46551		Sulfate

Totals : 4.46551

Results obtained with enhanced integrator!

```

=====
*** End of Report ***
=====

```

Method Information

Dionex IonPac AS-14A 4-mm analytical (4x250mm) column.  
Flow rate 1.2 mL/min  
8mM Na2CO3/1mM NaHCO3 mobile phase  
Suppressed anion conductivity detection

=====

ANALOG DIGITAL CONVERTER

=====

Signal 1

-----

Description:	Dionex ED 40
Source:	Signal
Unit:	uS
Units/Volt:	1000.000
Peakwidth (Data Rate):	0.027 Min (10.00 Hz)
Stop Time:	No Limit
Data Storage:	All

Start Signal Source: External Device Will Start 35900

Timed Event Table:  
<no events>

=====  
1100 Quaternary Pump 1  
=====

Control  
Column Flow : 1.200 ml/min  
Stoptime : 10.00 min  
Posttime : Off

Solvents  
Solvent A : 0.0 % ( )  
Solvent B : Off  
Solvent C : 100.0 % (8.0mM Na2CO3/1.0mM NaHCO3)  
Solvent D : Off

PressureLimits  
Minimum Pressure : 0 bar  
Maximum Pressure : 400 bar

Auxiliary  
Maximal Flow Ramp : 100.00 ml/min^2  
Primary Channel : Auto  
Compressibility : 83\*10^-6/bar  
Minimal Stroke : Auto

Store Parameters  
Store Ratio A : Yes  
Store Ratio B : Yes  
Store Ratio C : Yes  
Store Ratio D : Yes  
Store Flow : Yes  
Store Pressure : Yes

=====  
1100 Quaternary Pump 2  
=====

Control  
Column Flow : 0.000 ml/min  
Stoptime : 18.00 min  
Posttime : Off

Solvents  
Solvent A : 0.0 % ( )  
Solvent B : Off  
Solvent C : Off  
Solvent D : 100.0 % (8mMNa2CO3\1mMNaHCO3)

PressureLimits  
Minimum Pressure : 0 bar  
Maximum Pressure : 400 bar

Auxiliary  
Maximal Flow Ramp : 100.00 ml/min^2  
Primary Channel : Auto  
Compressibility : 100\*10^-6/bar  
Minimal Stroke : Auto

Store Parameters  
Store Ratio A : Yes  
Store Ratio B : Yes  
Store Ratio C : Yes  
Store Ratio D : Yes  
Store Flow : Yes  
Store Pressure : Yes

=====  
Agilent 1100 Autosampler 1  
=====

Injection

Injection Mode : Needle Wash  
Injector volume : 25.00 µl  
Wash Vial : 100  
Optimization : none

Auxiliary

Drawspeed : 100 µl/min  
Ejectspeed : 1000 µl/min  
Draw position : 2.0 mm

Time

Stoptime : As Pump  
Posttime : Off

=====  
Agilent 1100 Column Thermostat 1  
=====

Temperature settings

Left temperature : 30.0°C  
Right temperature : Same as left  
Enable analysis : When Temp. is within setpoint +/- 0.8°C  
Store left temperature : No  
Store right temperature: No

Time

Stoptime : As pump  
Posttime : Off

Column Switching Valve : Column 1

## Sequence Table:

## Method and Injection Info Part:

Line	Location	SampleName	Method	Inj	SampleType	InjVolume	DataFile
1	Vial 1	Standard 1	1006-38	2	Sample		
2	Vial 1	Standard 1	1006-38	2	Sample		
3	Vial 2	Standard 2	1006-38	2	Sample		
4	Vial 3	Standard 3	1006-38	2	Sample		
5	Vial 4	Standard 4	1006-38	2	Sample		
6	Vial 5	Standard 5	1006-38	2	Sample		
7	Vial 6	Standard 6	1006-38	2	Sample		
8	Vial 7	Second Source	1006-38	2	Sample		
9	Vial 8	DIUF H2O	1006-38	2	Sample		
10	Vial 11	M2571*10	1006-38	2	Sample		
11	Vial 12	M2814*100	1006-38	2	Sample		
12	Vial 21	Run 1 post*20	1006-38	2	Sample		
13	Vial 22	Run 2 post*100	1006-38	2	Sample		
14	Vial 23	Run 3 post*100	1006-38	2	Sample		
15	Vial 24	Blank post	1006-38	2	Sample		
16	Vial 25	IHB post	1006-38	2	Sample		
17	Vial 26	MS/Run 1 post	1006-38	2	Sample		
18	Vial 3	Standard 3	1006-38	2	Sample		
19	Vial 4	Standard 4	1006-38	2	Sample		
20	Vial 27	Run 1 pre	1006-38	2	Sample		
21	Vial 28	Run 2 pre	1006-38	2	Sample		
22	Vial 29	Run 3 pre	1006-38	2	Sample		
23	Vial 30	Blank pre	1006-38	2	Sample		
24	Vial 31	IHB pre	1006-38	2	Sample		
25	Vial 32	D19	1006-38	2	Sample		
26	Vial 33	D20	1006-38	2	Sample		
27	Vial 34	C11	1006-38	2	Sample		
28	Vial 35	C12	1006-38	2	Sample		
29	Vial 13	Standard 1	1006-38	7	Sample		
30	Vial 1	Standard 1	1006-38	2	Sample		
31	Vial 2	Standard 2	1006-38	2	Sample		
32	Vial 3	Standard 3	1006-38	2	Sample		
33	Vial 4	Standard 4	1006-38	2	Sample		
34	Vial 5	Standard 5	1006-38	2	Sample		
35	Vial 6	Standard 6	1006-38	2	Sample		

**APPENDIX D**

---

**LABORATORY DATA**

Lead Emissions

# **Air Test Professionals, Inc.**


1201 North Graham Avenue  
Indianapolis, IN 46219

Project Name: Nucor Steel

Lead

EPA Method 12 Analysis


Analytical Report  
8231



Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX: 910-792-6853 e1lab@e1lab.com

The following data for Analytical Report 8231  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Review by:



Melissa Lawrence, QA Officer  
November 7, 2006

Report Reviewed and Finalized By:



Ken Smith, Laboratory Director  
November 7, 2006

**elementOne**

533-ATP-102 Report Packet  
Page 2 of 16

# SUMMARY OF RESULTS

**elementOne**

0361 - 07 V - 0 Report Packet

Page 3 of 18

## Summary of Analysis

### Summary of Method 12 Lead Analysis

<u>Element</u>	Run 1 e8231-1 <u>Total µg</u>	Run 2 e8231-2 <u>Total µg</u>	Run 3 e8231-3 <u>Total µg</u>	Blank e8231-4 <u>Total µg</u>	Run 3 Spike e8231-3 <u>Recovery</u>
Lead, Average	1.93	1.09	0.32	0.50	108%
Triplicate RSD	1.1%	1.3%	1.0%	2.1%	

elementOne

# ANALYTICAL NARRATIVE

**elementOne**

ANALYTICAL NARRATIVE  
A REPORT BY  
elementOne

## Element One Analytical Narrative

Client:	Air Test Professionals, Inc.	Element One #:	8231
Client ID:	Nucor Steel-Strip Caster	Analyst:	DBW
Method:	M12	Date Received:	11/03/06
Analytes:	Lead	Date Analyzed:	11/06/06

### Summary of Analysis

The Method 12 samples were prepared and analyzed according to method protocol. After digestion the samples were brought to a final volume of 100 ml. The digested samples were then analyzed for lead on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limit

The instrument reporting limit was 1.0µg/L for lead.

### Analysis QA/QC

The spike recovery data and triplicate analyses relative standard deviations, RSD, are summarized with the results. All QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank or spike recovery values. The ICP-MS analysis of the Blank sample revealed detectable concentrations of lead. Subsequent analysis produced equivalent results. Nothing unusual was noticed with any of the other samples or analysis.

# ANALYTICAL DATA

**elementOne**

ElementOne Report Packet

Page 1 of 16

One

# AIR TESTING SAMPLE SUBMISSION FORM

Lab ID: 8231

## RUSH-3 Day TAT

Analysis Due Date 11.08.06  
QA/QC/Report Due Date 11.08.06

Client: Air Test Professionals
Project No.:

Date Rec: 11.03.06
Time Rec: 1140

HNO <sub>3</sub> Lot: 1106050	<del>HF Lot:</del>	<del>HCl Lot:</del>	Ref. Method
Volume Marked (Y)/N	Volume Loss Y/(N)?	pH < 2.0 (Y)/N	12

### Sample Identification

1	Run 1		
2	Run 2		
3	Run 3		
4	Blank		

Analyses Requested: Spike All Run 3s	Samples 1-4	Pb
--------------------------------------	-------------	----

Run/FB/RB	BV	FV	Spike	Comments
LRB		100		
LRB+		100		
1	260	100		
2	310	↓		
3-S	295	↓		
4	300	↓		

### Lab Notes / Communications

Page 1 of 1  
 SS by  
 11/3/2006 12:56:39 PM

BV Prep By / Date DBL 11/6/06  
 FV Prep By / Date DBL 11/6/06  
 Verification By / Date SE 11-03-06

# Sample/Batch Report

User Name: daphne.woodman  
Computer Name: ICPMS1  
Sample File: C:\elandata\Sample\Method 12.sam  
Report Date/Time: Monday, November 06, 2006 14:55:06

*Daphne Woodman*  
*11/7/06*

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
12		✓8231-1	ATP						
13		✓8231-2	ATP						
14		✓8231-3	ATP						
15 S		✓8231-3	ATP	Spike - 1					
16		✓8231-4	ATP						
17		8231-4	ATP						

*Q*

# Dataset Report

ser Name: daphne.woodman  
Computer Name: ICPMS1  
Dataset File Path: C:\elandata\Dataset\110606-2\  
Report Date/Time: Monday, November 06, 2006 14:55:03

*Daph Woodman*  
*11/7/06*

Autosampler Position: 3

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted \
13:57:16 Mon 06-Nov-06	Blank		Blank					
13:59:17 Mon 06-Nov-06	Standard 1		Standard #1					
14:01:19 Mon 06-Nov-06	Standard 2		Standard #2					
14:03:21 Mon 06-Nov-06	Standard 3		Standard #3					
14:05:23 Mon 06-Nov-06	Standard 4		Standard #4					
14:07:24 Mon 06-Nov-06	QC Std 1		QC Std #1					
14:09:26 Mon 06-Nov-06	QC Std 2		QC Std #2					
14:11:28 Mon 06-Nov-06	QC Std 3		QC Std #3					
14:13:29 Mon 06-Nov-06	QC Std 4		QC Std #4					
14:15:31 Mon 06-Nov-06	QC Std 9		QC Std #9					
14:17:34 Mon 06-Nov-06	QC Std 10		QC Std #10					
14:19:40 Mon 06-Nov-06	✓8231-1		Sample	ATP				
14:21:46 Mon 06-Nov-06	✓8231-2		Sample	ATP				
14:23:51 Mon 06-Nov-06	✓8231-3		Sample	ATP				
14:25:54 Mon 06-Nov-06	✓8231-3	S	Spike - 1	ATP				
14:27:58 Mon 06-Nov-06	✓8231-4		Sample	ATP				
14:29:58 Mon 06-Nov-06	QC Std 1		QC Std #1					
14:31:59 Mon 06-Nov-06	QC Std 4		QC Std #4					
14:49:48 Mon 06-Nov-06	8231-4		Sample	ATP → Blank Read 5m				
14:51:49 Mon 06-Nov-06	QC Std 1		QC Std #1					
14:53:50 Mon 06-Nov-06	QC Std 4		QC Std #4					

*Q*

013

Analyst: DBW Date: 11-06-06 Solid Samples  / Liquid Samples

*Cap W*  
11/7/06

A/S Loc	Batch # for sample sets	Sample Lab ID	Sample Description	Type Sample QC Spike QC Dup QC Reg Blank	Spike concentration	Prep Volume (ml)	Weight (g)	Aliquot (ml)	Diluted to Volume (ml)
10			LRB	S		100			
11			LRB	SS	Table #1	100			
12			8231-1	S		100			
13			8231-2	S		100			
14			8231-3	S		100			
15			8231-3	SS	Table #1	100			
16			8231-4	S		100			

Dilutions and Rechecks

17			8231-4	S		100			

Spikes are post at 0.02 mL of 25ppm spiking solution lot 021406-A in a final volume of 10ml.

Submitted for QC:	Date: 11/7/06	Time: 7:30	By: DBW	QC Review:	Date: 11-7-06	Time: 13:00	By:
Re-Test required:	No:	Yes:	Comments:				
Resubmitted for QC:	Date:	Time:	By:	QC Review:	Date:	Time:	By:

Analyte	Mass (amu)	Timing		Equation		Calibration		Sampling		Devices		QC...	
		Spike Table 1 (Conc.)	Spike Table 1 Det. Limit (Conc.)	Spike Table 2 (Conc.)	Spike Table 2 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)	Spike Table 4 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)	Spike Table 4 Det. Limit (Conc.)
Rh	102.905												
Pb	207.977	50	0.001	25	1	100	1						
Kr	82.9141												

Report Notes

Frequency QC Std Int Stds Calibration Stds Sample Int Stds Sample Spike Dilution Duplicate Spike Tables QC Action Controls Autosampler

elp:Press F1

Task E: GpibManager

ELAN Instrument Con... Microsoft Word - ICPMS ru...

NUM LOG

2:57 PM

## Analytical Calculations

### Method 12 Lead-

$$\text{Lead Results } (\mu\text{g}) = \text{ICP Results } (\mu\text{g/L}) * \text{Dilution} * \text{Final Volume (L)}$$

### Where-

ICP Results= Raw sample concentration (ppb)--*ICP-Data Sheet*

Dilution=  $\frac{\text{Diluted Volume}}{\text{Aliquot}}$ --*ICP-MS Run Sheet*

Final Volume= FH=Final Volume (FV)--*Sample Submission*

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: Blank

Sample Date/Time: Monday, November 06, 2006 13:57:16

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Rh		103 137652.8		ppb
>	Ho	165	358120.2		ppb
-	Pb	208	849.7		ppb
	Kr	83	87.2		ppb

Replicates

Concentration

Concentration

Concentration

Method 6020 Multi Metals Summary Report

Sample ID: Standard 1

Sample Date/Time: Monday, November 06, 2006 13:59:17

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Rh	103	132809.9		ppb
>	Ho	165	359689.6		ppb
-	Pb	208	17090.1	1.01132	ppb
	Kr	83	76.3		ppb

Replicates

Concentration

1.024507

Concentration

1.012432

Concentration

0.997009

Method 6020 Multi Metals Summary Report

Sample ID: Standard 2

Sample Date/Time: Monday, November 06, 2006 14:01:19

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc.	Meas Report Unit
	Rh	103	129259		ppb
>	Ho	165	362280.6		ppb
-	Pb	208	1671587.9	103.3042	ppb
	Kr	83	68		ppb

Replicates

Concentration

103.848671

Concentration

103.946937

Concentration

102.117012

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: Standard 3  
Sample Date/Time: Monday, November 06, 2006 14:03:21  
Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh	103	126749.8		ppb
>	Ho	165	365520.2		ppb
-	Pb	208	8285653.5	507.7147	ppb
	Kr	83	74.8		ppb

Replicates  
Concentration

499.305598

Concentration

511.403213

Concentration

512.435375

Method 6020 Multi Metals Summary Report

Sample ID: Standard 4  
Sample Date/Time: Monday, November 06, 2006 14:05:23  
Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh	103	129870.3		ppb
>	Ho	165	373276.6		ppb
-	Pb	208	16596826	995.8122	ppb
	Kr	83	98.3		ppb

Replicates  
Concentration

985.212471

Concentration

1000.74935

Concentration

1001.474791

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1  
Sample Date/Time: Monday, November 06, 2006 14:07:24  
Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh	103	114299.2		ppb
>	Ho	165	324311.3		ppb
-	Pb	208	13904.1	0.90802	ppb
	Kr	83	59.8		ppb

Replicates  
Concentration

1.191833

Concentration

0.811755

Concentration

0.72046

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 2  
Sample Date/Time: Monday, November 06, 2006 14:09:26  
Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	109240		ppb
Ho	165	315395.2		ppb
Pb	208	16825.6	1.1418	ppb
Kr	83	61		ppb

Replicates  
Concentration

1.124544

Concentration

1.139862

Concentration

1.160999

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 3  
Sample Date/Time: Monday, November 06, 2006 14:11:28  
Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	104099.1		ppb
Ho	165	310759		ppb
Pb	208	3557102.1	256.3451	ppb
Kr	83	74.3		ppb

Replicates  
Concentration

253.792805

Concentration

254.718299

Concentration

260.524286

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4  
Sample Date/Time: Monday, November 06, 2006 14:13:29  
Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	103896.3		ppb
Ho	165	306370.2		ppb
Pb	208	1458652.6	106.5886	ppb
Kr	83	59.2		ppb

Replicates  
Concentration

106.384703

Concentration

106.921711

Concentration

106.459461

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 9  
Sample Date/Time: Monday, November 06, 2006 14:15:31  
Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	88485.5		ppb
Ho	165	276640.9		ppb
Pb	208	13877.4	1.0747	ppb
Kr	83	54.7		ppb

Replicates  
Concentration

1.428481

Concentration

0.980398

Concentration

0.81521

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 10  
Sample Date/Time: Monday, November 06, 2006 14:17:34  
Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	92779.5		ppb
Ho	165	291384.5		ppb
Pb	208	681281	52.31466	ppb
Kr	83	44.8		ppb

Replicates  
Concentration

51.962292

Concentration

51.922582

Concentration

53.059094

Method 6020 Multi Metals Summary Report

Sample ID: 8231-1  
Sample Date/Time: Monday, November 06, 2006 14:19:40  
Sample Description: ATP

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	89145.4		ppb
Ho	165	291459		ppb
Pb	208	251605.6	19.28124	ppb
Kr	83	66		ppb

Replicates  
Concentration

19.137131

Concentration

19.172056

Concentration

19.534535

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: 8231-2  
Sample Date/Time: Monday, November 06, 2006 14:21:46  
Sample Description: ATP

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	89081		ppb
Ho	165	288253.6		ppb
Pb	208	141348.4	10.93316	ppb
Kr	83	55.7		ppb

Replicates  
Concentration

11.057874

Concentration

10.956309

Concentration

10.785297

Method 6020 Multi Metals Summary Report

Sample ID: 8231-3  
Sample Date/Time: Monday, November 06, 2006 14:23:51  
Sample Description: ATP

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	97700.2		ppb
Ho	165	308087.5		ppb
Pb	208	44397.6	3.17507	ppb
Kr	83	59.3		ppb

Replicates  
Concentration

3.211094

Concentration

3.162813

Concentration

3.151301

Method 6020 Multi Metals Summary Report

Sample ID: 8231-3  
Sample Date/Time: Monday, November 06, 2006 14:25:54  
Sample Description: ATP

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	96989.4		ppb
Ho	165	307893.9		ppb
Pb	208	788911.9	57.33564	ppb
Kr	83	58.3		ppb

Replicates  
Concentration

56.911027

Concentration

57.549436

Concentration

57.546458

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: 8231-4  
 Sample Date/Time: Monday, November 06, 2006 14:27:58  
 Sample Description: ATP

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	83236.4		ppb
Ho	165	278965.4		ppb
Pb	208	62604.2	4.97622	ppb
Kr	83	70.7		ppb

Replicates  
 Concentration

5.090658

Concentration

4.949066

Concentration

4.888945

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1  
 Sample Date/Time: Monday, November 06, 2006 14:29:58  
 Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	97348.9		ppb
Ho	165	292295		ppb
Pb	208	1302.4	0.04678	ppb
Kr	83	46.5		ppb

Replicates  
 Concentration

0.055172

Concentration

0.048334

Concentration

0.036818

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4  
 Sample Date/Time: Monday, November 06, 2006 14:31:59  
 Sample Description:

Concentration Results

Analyte	Mass	Meas. Inten:	Conc. Mea:	Report Unit
Rh	103	94129.6		ppb
Ho	165	295730.7		ppb
Pb	208	1398492.7	105.8687	ppb
Kr	83	52.3		ppb

Replicates  
 Concentration

105.54911

Concentration

105.684569

Concentration

106.372282

PerkinElmer ELAN 6100 ICP-MS

Method 6020 Multi Metals Summary Report

Sample ID: 8231-4  
Sample Date/Time: Monday, November 06, 2006 14:49:48  
Sample Description: ATP

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh		103	76047.7	ppb
>	Ho		165	253864.5	ppb
-	Pb		208	57731.9	5.04294 ppb
	Kr		83	67.3	ppb

Replicates  
Concentration

5.115791

Concentration

5.036078

Concentration

4.976955

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1  
Sample Date/Time: Monday, November 06, 2006 14:51:49  
Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh		103	96050.7	ppb
>	Ho		165	287295.2	ppb
-	Pb		208	1056.4	0.02921 ppb
	Kr		83	48.3	ppb

Replicates  
Concentration

0.028403

Concentration

0.030365

Concentration

0.02887

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4  
Sample Date/Time: Monday, November 06, 2006 14:53:50  
Sample Description:

Concentration Results

	Analyte	Mass	Meas. Inten:	Conc.	Meas Report Unit
	Rh		103	93948.6	ppb
>	Ho		165	294596.3	ppb
-	Pb		208	1386630.3	105.3808 ppb
	Kr		83	53.5	ppb

Replicates  
Concentration

105.398598

Concentration

104.073074

Concentration

106.670783

**APPENDIX E**

---

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

## CHAIN OF CUSTODY RECORD

<b>COMPANY:</b> ATP <b>SEND REPORT TO:</b> Carlos Brown <b>ADDRESS:</b> 1201 N. Graham Ave. Indianapolis, Indiana 46219 <b>PHONE:</b> (317) 345-1723 <b>FAX:</b> (317) 351-0411		<b>PROJECT NAME/NUMBER:</b> NUCOR - Casirp / 183 <b>BILLING INFORMATION</b> <b>BILL TO:</b> <b>ADDRESS:</b> Same <b>PHONE:</b> <b>FAX:</b> PO NO: 183		LAB JOB NO. <span style="border: 1px solid black; display: inline-block; width: 100px; height: 20px; vertical-align: middle;"></span>					
Run 1	Filter	10/02/06		Petri	1	X			
Run 2	Filter	10/03/06		Petri	1	X			
Run 3	Filter	10/05/06		Petri	1	X			
Run 1	Acetone Rinse	10/02/06		AQ	4 oz	X			
Run 2	Acetone Rinse	10/03/06		AQ	4 oz	X			
Run 3	Acetone Rinse	10/05/06		AQ	4 oz	X			
BLANK	Acetone	10/05/06		AQ	4 oz	X			
<b>SAMPLER:</b> Andrew Young <b>SHIPMENT METHOD:</b>		<b>AIRBILL NO.:</b>							
<b>REQUIRED TURNAROUND: *</b>									
<b>RECEIVED:</b> SIGNATURE: <i>Carlos Brown</i> PRINTED NAME/COMPANY: Carlos Brown ATP		DATE: 10/15/06 TIME:	<b>REQUISITIONED BY:</b> SIGNATURE: PRINTED NAME/COMPANY:		DATE: TIME:	<b>RECEIVED:</b> SIGNATURE: PRINTED NAME/COMPANY:		DATE: TIME:	DATE: TIME:
<b>RECEIVED:</b> SIGNATURE: <i>Andrew Young</i> PRINTED NAME/COMPANY: Andrew Young ATP		DATE: 10/15/06 TIME:	<b>REQUISITIONED BY:</b> SIGNATURE: PRINTED NAME/COMPANY:		DATE: TIME:	<b>RECEIVED:</b> SIGNATURE: PRINTED NAME/COMPANY:		DATE: TIME:	DATE: TIME:

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723

Fax (317) 351-0411

Email: atp\_stack@rsbcglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION				PRESERV	CONTAINER	SAMPLE MATRIX	SAMPLE TIME	SAMPLE DATE	No. of Containers	REMARKS / PRECAUTIONS
COMPANY	PROJECT NAME/NUMBER	BILLING INFORMATION		ADDRESS	PHONE							
ATP	Nucor Steel - Strip Caster	Nucor Steel - Strip Caster		1201 N. Graham Ave.	(317) 345-1723	(317) 351-0411	183					
SEND REPORT TO	Carlos Brown	BILLING INFORMATION		Indianapolis, Indiana 46219								
ADDRESS	1201 N. Graham Ave.			Same								
PHONE												
FAX												
SAMPLE NO	SAMPLE DESCRIPTION	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER	PRESERV						
Run 1	DI H2O / Rinse	10/05/06		AQ	500 ml					1	X	
Run 2	DI H2O / Rinse	10/05/06		AQ	500 ml					1	X	
Run 3	DI H2O / Rinse	10/05/06		AQ	500 ml					1	X	
Run 1	MeCl2 Rinse	10/05/06		AQ	4 OZ					1	X	
Run 2	MeCl2 Rinse	10/05/06		AQ	4 OZ					1	X	
Run 3	MeCl2 Rinse	10/05/06		AQ	4 OZ					1	X	
BLANK	DI H2O Blank	10/05/06		AQ	500 ml					1	X	
BLANK	MeCl2 Blank	10/05/06		AQ	4 OZ					1	X	
SAMPLER	Carlos Brown	SHIPMENT METHOD										
REQUIRED TURNAROUND	RUSH	AIRBILL NO										
1. RELINQUISHED BY:		DATE	TIME	2. RELINQUISHED BY:		DATE	TIME	3. RELINQUISHED BY:		DATE	TIME	
SIGNATURE		11/2/06		SIGNATURE				SIGNATURE				
PRINTED NAME/COMPANY				PRINTED NAME/COMPANY				PRINTED NAME/COMPANY				
1. RECEIVED BY:		DATE	TIME	2. RECEIVED BY:		DATE	TIME	3. RECEIVED BY:		DATE	TIME	
SIGNATURE		11/3/06		SIGNATURE				SIGNATURE				
PRINTED NAME/COMPANY				PRINTED NAME/COMPANY				PRINTED NAME/COMPANY				

ETPA Member 2002  
Sulfate Correction

LAB JOB NO.

T=Ambidex

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

8331  
Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION				SHIPMENT METHOD:		AIRBILL NO.	
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucoor Steel - Strip Caster						
SEND REPORT TO:	Carlos Brown	BILLING INFORMATION:							
ADDRESS:	1201 N. Graham Ave.	BILL TO:							
	Indianapolis, Indiana 46219	ADDRESS:	Same						
PHONE:	(317) 345-1723	PHONE:							
FAX:	(317) 351-0411	FAX:							
SAMPLE NO	SAMPLE DESCRIPTION	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER	PRESERV			
							EPA Methods 12		
Run 1	Sample Filter	10/05/06		Filter	Petri		1	X	ANALYZE FOR Pb
Run 2	Sample Filter	10/05/06		Filter	Petri		1	X	
Run 3	Sample Filter	10/05/06		Filter	Petri		1	X	
Run 1	0.1N HNO3 / Rinse	10/05/06		AQ	500 ml		1	X	RUSH (3-DAY)
Run 2	0.1N HNO3 / Rinse	10/05/06		AQ	500 ml		1	X	
Run 3	0.1N HNO3 / Rinse	10/05/06		AQ	500 ml		1	X	
BLANK	BLANK Filter	10/05/06		Filter	Petri		1	X	
BLANK	0.1N HNO3	10/05/06		AQ	500 ml		1	X	
SAMPLER: Carlos Brown									
REQUIRED TURNAROUND: RUSH (3-DAY)									
1. RELINQUISHED BY:	DATE	2. RELINQUISHED BY:	DATE	3. RELINQUISHED BY:	DATE				
SIGNATURE: <i>[Signature]</i>	11/2/06	SIGNATURE:		SIGNATURE:					
PRINTED NAME/COMPANY: <i>[Signature]</i>	TIME	PRINTED NAME/COMPANY:	TIME	PRINTED NAME/COMPANY:	TIME				
1. RECEIVED BY: <i>[Signature]</i>	DATE	2. RECEIVED BY:	DATE	3. RECEIVED BY:	DATE				
SIGNATURE: <i>[Signature]</i>	11/3/06	SIGNATURE:		SIGNATURE:					
PRINTED NAME/COMPANY: <i>[Signature]</i>	TIME	PRINTED NAME/COMPANY:	TIME	PRINTED NAME/COMPANY:	TIME				
123									

LAB JOB NO.

No. of Containers: 12

**APPENDIX F**

---

**CALIBRATION CHECK**

(Post Test) per EMTIC Guideline GD-26

Company:	Nucor Steel
Date:	10/02/06 - 10/05/06
Source:	PM - Castrip
Location:	Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	0.986	0.986	1.007	0.993
Average result must be within 5% of Y				
Result (%)	0.30			
<b>PASSED POST CAL</b>				
<b>Dry Gas Meter Box:</b>				
ID:	A-2			
Y:	0.99			
Delta H:	1.81			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.28	66	64
2		2.28	66	64
3		2.17	66	64
4		2.17	66	65
5		2.17	67	65
6		2.10	68	65
7		2.03	68	65
8		2.03	69	66
9		2.00	70	66
10		2.00	71	67
11		1.75	71	68
12		1.75	71	68
13		1.89	73	68
14		1.82	73	68
15		1.82	73	68
16		1.89	75	70
17		1.75	77	71
18		1.75	78	71
19		1.82	79	72
20		1.82	80	73
21		1.82	81	74
22		1.82	81	74
23	906.001	1.68	81	74
24	859.6	2.17	81	74

Volume	Delta H	Meter Temp
46.401	1.948	70.7

Barometric Pressure	Test Time
30.13	60.0

Y qa:	0.986
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.10	86	85
2		1.93	87	86
3		1.93	87	86
4		1.82	88	87
5		1.61	89	87
6		1.61	89	87
7		1.61	91	89
8		1.54	92	89
9		1.47	92	89
10		1.40	93	90
11		1.40	93	90
12		1.40	94	91
13		1.75	95	92
14		1.89	96	92
15		1.89	96	93
16		1.89	96	93
17		1.68	97	93
18		1.68	98	94
19		1.58	98	94
20		1.68	98	94
21		1.82	99	95
22		1.89	99	95
23	961.297	1.89	100	95
24	916.7	1.89	101	96

Volume	Delta H	Meter Temp
44.597	1.722	92.4

Barometric Pressure	Test Time
30.06	60.0

Y qa:	0.986
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.75	57	56
2		1.75	57	56
3		1.68	57	56
4		1.68	57	56
5		1.61	57	56
6		1.54	58	56
7		1.75	58	56
8		1.79	59	57
9		1.89	59	57
10		1.93	61	57
11		2.00	61	57
12		2.10	62	57
13		1.93	61	57
14		1.93	61	57
15		1.82	62	58
16		1.82	62	58
17		1.79	63	58
18		1.82	63	58
19		2.03	63	58
20		2.10	63	58
21		2.10	64	59
22		2.03	64	59
23	1007.60	2.10	64	59
24	963.5	2.10	64	59

Volume	Delta H	Meter Temp
44.1	1.875	59.0

Barometric Pressure	Test Time
30.15	60.0

Y qa:	1.007
-------	-------

**CALIBRATION CHECK**

(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Date: 10/2/06 - 10/5/06  
 Source: LEAD - Castrip  
 Location: Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	1.014	1.002	1.056	1.024
Average result must be within 5% of Y				
Result (%)	3.41			
<b>PASSED POST CAL</b>				
<b>Dry Gas Meter Box:</b>				
ID:	A-1			
Y:	0.99			
Delta H:	1.74			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.28	66	64
2		2.28	66	64
3		2.17	66	64
4		2.17	67	64
5		2.17	68	65
6		2.10	69	65
7		2.10	70	66
8		2.14	70	66
9		2.07	71	66
10		2.04	72	67
11		1.82	74	68
12		1.82	74	68
13		1.89	74	69
14		1.86	76	70
15		1.82	76	70
16		1.82	78	71
17		1.79	79	72
18		1.79	80	73
19		1.82	81	73
20		1.75	81	73
21		1.82	81	73
22	123.4	1.79	81	73
23	77.2	1.75	81	73
24		2.03	81	73

Volume	Delta H	Meter Temp
46.2	1.960	71.50

Barometric Pressure
30.13

Test Time
60.00

Y qa:	1.014
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.16	86	85
2		2.09	86	85
3		2.09	86	85
4		2.09	87	86
5		1.87	88	86
6		1.73	88	86
7		2.09	89	87
8		2.09	89	87
9		1.98	91	88
10		2.16	92	88
11		1.80	92	88
12		1.66	93	89
13		2.09	94	90
14		1.94	94	90
15		1.94	95	90
16		1.94	95	90
17		1.69	96	91
18		1.51	97	92
19		2.09	97	93
20		2.16	98	93
21		1.98	99	93
22	183.578	2.09	99	94
23	136.1	1.94	100	95
24		1.51	101	96

Volume	Delta H	Meter Temp
47.478	1.946	91.23

Barometric Pressure
30.06

Test Time
60.00

Y qa:	1.002
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.85	54	54
2		1.85	54	54
3		1.78	54	54
4		1.63	55	54
5		1.55	55	54
6		1.55	55	54
7		1.78	55	54
8		2.07	55	54
9		2.07	56	54
10		2.15	56	54
11		2.22	56	55
12		2.29	56	55
13		1.92	56	55
14		1.92	56	55
15		2.00	56	55
16		2.00	56	55
17		2.04	57	56
18		2.07	57	56
19		2.07	57	56
20		2.15	57	56
21		2.22	57	56
22	228.35	2.29	57	56
23	184.1	2.37	57	56
24		2.41	57	56

Volume	Delta H	Meter Temp
44.25	2.010	55.40

Barometric Pressure
30.15

Test Time
60.00

Y qa:	1.056
-------	-------

APEX INSTRUMENTS  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor  
 Filename: Orifice Calibration

Date: 05/26/06  
 Barometric Pressure: 29.66 in Hg  
 Critical Orifice Vacuum: 19 in Hg

Serial #: A1

IMPORTANT!!! For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)<sup>2</sup>(min).

CRITICAL ORIFICE READINGS

dH (in H2O)	Time (min)	Volume		Final Temps.		Orifice K' Orifice Serial# (number)	Vacuum (in Hg)	-- Ambient Temperature --	
		Initial (cu ft)	Final (cu ft)	Inlet (deg F)	Outlet (deg F)			Initial (deg F)	Final (deg F)
0.38	14.20	296.5	300.5	68	68	AT-15	19	68	68
0.38	14.20	300.5	305.5	69	68	AT-15	19	68	68
0.38	14.20	305.5	310.5	70	68	AT-15	19	68	68

DRY GAS METER READINGS

dH (in H2O)	Time (min)	Volume		Final Temps.		Orifice K' Orifice Serial# (number)	Vacuum (in Hg)	-- Ambient Temperature --	
		Initial (cu ft)	Final (cu ft)	Inlet (deg F)	Outlet (deg F)			Initial (deg F)	Final (deg F)
0.38	14.20	296.5	300.5	68	68	AT-15	19	68	68
0.38	14.20	300.5	305.5	69	68	AT-15	19	68	68
0.38	14.20	305.5	310.5	70	68	AT-15	19	68	68

RESULTS

-- DRY GAS METER --		--- ORIFICE ---		-- DRY GAS METER --		--- ORIFICE ---	
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value (number)	Variation (number)	Value (in H2O)	Variation (in H2O)
4.95688862	140.379	4.93054367	139.633	0.9946852	-0.0011	1.748119091	44.402225
4.95220125	140.246	4.93054367	139.633	0.9956267	-0.00016	1.744814518	44.318289
4.9451868	140.048	4.93054367	139.633	0.9970389	0.001255	1.738229151	44.15102
Average Y →				0.996		1.744	44.290511

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is ±0.2.

Calibrated by: Carlos Brown Date: May 26, 2006

**APEX INSTRUMENTS**  
 EPA Method 5  
 522 Series Meter Box Calibration  
 Post-Test Orifice Method  
 English Meter Box Units, English K' Factor

Filename: Orifice Calibration

Serial #: **A2** Date: 05/26/06  
 Barometric Pressure: 29.66 in Hg  
 Critical Orifice Vacuum: 20 in Hg

**IMPORTANT!!!** For valid test results, the Critical Orifice Vacuum must be equal to or higher than the value shown above.  
 The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>((in. Hg)<sup>2</sup>(min)).

----- DRY GAS METER READINGS -----

dH (in H2O)	Time (min)	Volume		Volume Initial Temps.		Final Temps.		Orifice K' Orifice Serial# (number)	Coefficient (see above)	Vacuum (in Hg)	- Ambient Temperature -	
		Initial (cu ft)	Final (cu ft)	Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Final (deg F)				Initial (deg F)	Average (deg F)
0.72	10.38	288	293	68	68	68	68	AT-15	0.37	20	69	69
0.72	10.39	293	298	68	68	69	68	AT-15	0.37	20	69	69
0.72	10.38	298	303	69	68	69	68	AT-15	0.37	20	69	69

----- DRY GAS METER READINGS -----

\*\*\*\*\* RESULTS \*\*\*\*\*

-- DRY GAS METER --		-- ORIFICE --		-- DRY GAS METER --		-- ORIFICE --	
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value (number)	Variation (number)	Value (in H2O)	Variation (in H2O)
Vm(std)	Vm(std)	Vcr(std)	Vm(std)	0.9843583	-0.00094	1.814037606	46.076555
(cu ft)	(liters)	(cu ft)	(liters)	0.9857732	0.000477	1.812320987	46.032953
140.564	138.36517	138.49847	138.36517	0.9857566	0.000461	1.807183702	45.902466
140.497	138.36517	138.49847	138.36517	Average Y ----->		1.811	46.003991
140.364	138.36517	138.49847	138.36517	Average Y ----->		1.811	46.003991

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

Calibrated by: Carlos Brown Date: May 26, 2006

**ATP - AIR TEST PROFESSIONALS, INC.**  
Nozzle Calibration


Nozzle Type: Glass

**NOZZLE DIAMETER MEASUREMENT**

A = 0.250 inches

B = 0.250 inches

C = 0.250 inches



Calibrated by: Andrew Young


Date Calibrated: October 2, 2006

**ATP** - AIR TEST PROFESSIONALS, INC.  
Nozzle Calibration

Nozzle Type: Stainless Steel

**NOZZLE DIAMETER MEASUREMENT**

A = 0.244 inches  
B = 0.244 inches  
C = 0.244 inches



Calibrated by: Andrew Young      Date Calibrated: October 2, 2006

**ATP - Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 5 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

Temperature Range	Mercury Thermometer	Probe Thermometer
Hot Bath	490 deg	491 deg
Room Temperature	67 deg	67 deg
Ice Bath	33 deg	33 deg

Calibrated By: Carlos Brown Date Calibrated: April 2006

**ATP - Air Test Professionals, Inc.**  
**Thermocouple Calibration**

Probe Length/ID: 12 ft. Type-S Dry Gas Meter ID: A-1

Standard Used: Mercury Thermometer Temperature Scale: Degrees F

Temperature Range	Mercury Thermometer	Probe Thermometer
Hot Bath	424 deg	425 deg
Room Temperature	58 deg	58 deg
Ice Bath	34 deg	34 deg

Calibrated By: Carlos Brown Date Calibrated: April 2006

**ATP - Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1

Probe Length/ID.: 5 ft. Type-S (w/probe)

External Tubing Diameter: 0.250" inches

Base to Opening Plane Distance (Pa): 0.370" inches

Base to Opening Plane Distance (Pa): 0.370" inches

	Measured	Allowable
Pa/Dt	1.478"	1.05 - 1.50 inches
Pb/Dt	1.478"	1.05 - 1.50 inches
Angle $\alpha$ 1	1 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
Angle $\alpha$ 2	1 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
Angle $\beta$ 1	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
Angle $\beta$ 2	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
Z (inches)	0.010"	0.125 inches
W (inches)	0.000"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: 0.84

Calibrated By: Carlos Brown Date Calibrated: April 2006

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1

Probe Length/ID.: 12 ft. Type-S

External Tubing Diameter: 0.375" inches

Base to Opening Plane Distance (Pa): 0.470" inches

Base to Opening Plane Distance (Pa): 0.470" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.25"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\alpha</math> 2</b>	0 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>z (inches)</b>	0.0"	0.125 inches
<b>w (inches)</b>	0.0"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: April 2006



**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 54265-71-65000  
Project No.: 05-32658-003

Customer

CLEAN AIR INSTRUMENT RENTAL  
GARY ZAPEL  
500 WEST WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM002866      Certification Date: 14Jul2005      Exp. Date: 13Jul2008  
Cylinder Pressure\*\*\*: 1917 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
CARBON MONOXIDE	94.36 PPM	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 1679	02Apr2007	ALM040697	94.90 PPM	CARBON MONOXIDE

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
FTIR/09286 21	20Jun2005	FTIR

**ANALYZER READINGS**

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**CARBON MONOXIDE**

Date: 06Jul2005		Response Unit: PPM
Z1 = -0.01447	R1 = 95.64342	T1 = 94.64726
R2 = 95.66893	Z2 = 0.00629	T2 = 94.67961
Z3 = 0.06052	T3 = 94.78347	R3 = 95.68381
Avg. Concentration:	93.95	PPM

Date: 14Jul2005		Response Unit: PPM
Z1 = -0.00218	R1 = 94.72713	T1 = 94.54809
R2 = 94.73702	Z2 = 0.00792	T2 = 94.59821
Z3 = 0.03069	T3 = 94.70185	R3 = 94.74591
Avg. Concentration:	94.78	PPM

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99991E-1	
Constants:	A = 0.00000E+0
B = 9.80863E-1	C = 7.32000E-4
D = 1.00000E-6	E = 0.00000E+0

APPROVED BY:

JEFF CROTEAU



**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 55023-71-65000  
Project No.: 05-44820-001

Customer

CLEAN AIR INSTRUMENT RENTAL  
  
500 WEST WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM048771 Certification Date: 14Jul2006 Exp. Date: 13Jul2009  
Cylinder Pressure\*\*\*: 1962 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
CARBON MONOXIDE	182.0 PPM	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 2636	02Oct2008	AAL7022	248.5 PPM	CARBON MONOXIDE

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
FTIR/0928621	26Jun2006	FTIR

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**CARBON MONOXIDE**

Date: 07Jul2006	Response Unit: PPM		
Z1 = -0.00220	R1 = 251.3061	T1 = 184.2558	
R2 = 251.4409	Z2 = 0.05403	T2 = 184.4522	
Z3 = 0.05900	T3 = 184.6303	R3 = 251.4937	
Avg. Concentration:	182.3	PPM	

Date: 14Jul2006	Response Unit: PPM		
Z1 = -0.03688	R1 = 251.4314	T1 = 183.7341	
R2 = 251.6482	Z2 = -0.00870	T2 = 184.2685	
Z3 = 0.11361	T3 = 184.5140	R3 = 252.1969	
Avg. Concentration:	181.8	PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99989E-1	
Constant:	A = 0.00000E+0
B = 6.70122E-1	C = 1.40000E-4
D = 0.00000E+0	E = 0.00000E+0

APPROVED BY:

*[Signature]*  
Scott King

RATA CLASS

Dual-Analyzed Calibration Standard

9810 BAY AREA BLVD, PASADENA, TX 77507

Phone: 281-474-5800

Fax:

31-474-5857

CERTIFICATE\_OF\_ACCURACY: EPA Protocol Gas

Assay Laboratory

Customer

P.O. No.: 53907-71-65000

CLEAN AIR INSTRUMENT RENTALS

SCOTT SPECIALTY GASES Project No.: 04-31834-020

NANCY DAVIS

9810 BAY AREA BLVD

321 CENTURY PLAZA

PASADENA, TX 77507

SUITE 110

HOUSTON TX 77073

ANALYTICAL INFORMATION

This certification was performed according to EPA Traceability Protocol For Assay & Certification

of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM030371 Certification Date: 16Feb2005 Exp. Date: 16Feb2007

Cylinder Pressure\*\*\*: 2015 PSIG

ANALYTICAL

COMPONENT	CERTIFIED CONCENTRATION (Moles)	ACCURACY**	TRACEABILITY
NITRIC OXIDE	87.1 PPM	+/- 1%	Direct NIST and NMI
NITROGEN - OXYGEN FREE			
TOTAL OXIDES OF NITROGEN	87.1 PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

REFERENCE STANDARD

TYPE/SRM_NO.	EXPIRATION_DATE	CYLINDER_NUMBER	CONCENTRATION	COMPONENT
NTRM 1684	04Jul2008	AAL070287	97.00PPM	NITRIC OXIDE

INSTRUMENTATION

INSTRUMENT/MODEL/SERIAL#	DATE_LAST_CALIBRATED	ANALYTICAL_PRINCIPLE
KS Online/2030/0929061	24Jan2005	FTIR

ANALYZER READINGS

(Z=Zero Gas R=Reference Gas T=Test Gas r=Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

NITRIC OXIDE

Date: 08Feb2005 Resp Unit: PPM Date: 16Feb2005 Resp Unit: PPM

Concentration=A+Bx+Cx2+Dx3+Ex4

Z1=0.163371=97.062341=87.08656	Z1=0.114941=96.59197=87.04693	r=9.99991E-1
R2=97.19909=0.22082T2=87.12320	R2=96.60682=0.162182=87.05434	Constants: A=0.00000E+0
Z3=0.251343=87.206763=97.27835	Z3=0.164583=87.10065=96.73040	B=9.98287E-1 C=2.04000E-4
Avg. Conc: 86.95 PPM	Avg. Conc: 87.37 PPM	D=0.00000E+0 E=0.00000E+0

APPROVED BY: (signature on file)

GARY WRIGHT



**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 54685-71-65000  
05-39648-017

Customer

CLEAN AIR INSTRUMENT RENTAL  
GARY ZAPEL  
500 WEST WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM057888 Certification Date: 31Jan2006 Exp. Date: 31Jan2008  
Cylinder Pressure\*\*\*: 1884 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
NITRIC OXIDE	49.08 PPM	+/- 1%	Direct NIST and NMI
NITROGEN - OXYGEN FREE	BALANCE		
TOTAL OXIDES OF NITROGEN	<u>49.10</u> PPM		Reference Value Only

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 1683	15Aug2009	AAL070681	49.82 PPM	NITRIC OXIDE

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
FTIR/0928621	09Jan2006	FTIR

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**NITRIC OXIDE**

Date: 24Jan2006		Response Unit: PPM	
Z1 = -0.17728	R1 = 97.14961	T1 = 49.05994	
R2 = 97.21331	Z2 = 0.26575	T2 = 49.43356	
Z3 = 0.28894	T3 = 49.52723	R3 = 97.50117	
Avg. Concentration: 49.13		PPM	

Date: 31Jan2006		Response Unit: PPM	
Z1 = -0.32533	R1 = 50.07219	T1 = 49.32755	
R2 = 50.36399	Z2 = -0.24991	T2 = 49.37923	
Z3 = -0.14477	T3 = 49.98800	R3 = 50.69381	
Avg. Concentration: 49.02		PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99998E-1	
Constants:	A = 0.00000E+0
B = 9.99660E-1	C = 1.86000E-4
D = 0.00000E+0	E = 0.00000E+0

APPROVED BY: JEFF CROTEAU



**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 53691-71-65000  
Project No.: 05-23984-031

Customer

CLEAN AIR INSTRUMENT RENTAL  
GARY ZAPEL  
500 WEST WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM009211      Certification Date: 22Oct2004      Exp. Date: 15Oct2006  
Cylinder Pressure\*\*\*: 1753 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
SULFUR DIOXIDE *	62.09 PPM	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

Product certified as +/- 1% analytical accuracy is directly traceable to NIST or NMI standards.

\* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected Protocols.

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 1694	01Sep2007	ALM051641	98.10 PPM	SULFUR DIOXIDE

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
MKS Online/2030/0928621	28Sep2004	FTIR

**ANALYZER READINGS**

(Z = Zero Gas    R = Reference Gas    T = Test Gas    r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**SULFUR DIOXIDE \***

Date: 15Oct2004	Response Unit: PPM	
Z1 = -0.00242	R1 = 99.34406	T1 = 62.83456
R2 = 99.39227	Z2 = 0.05579	T2 = 62.88644
Z3 = 0.05988	T3 = 62.92573	R3 = 99.40588
Avg. Concentration:	62.06	PPM

Date: 22Oct2004	Response Unit: PPM	
Z1 = -0.00893	R1 = 98.72887	T1 = 62.51701
R2 = 98.75321	Z2 = 0.03114	T2 = 62.65223
Z3 = 0.03375	T3 = 62.57860	R3 = 98.75853
Avg. Concentration:	62.13	PPM

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99995E-1	
Constants:	A = 0.00000E+0
B = 9.97040E-1	C = 0.00000E+0
D = 0.00000E+0	E = 0.00000E+0

APPROVED BY:

Dave Babcock



**CERTIFICATE OF ACCURACY: EPA Protocol Gas**

Assay Laboratory

SCOTT SPECIALTY GASES  
1290 COMBERMERE STREET  
TROY, MI 48083

P.O. No.: 55166-71-65000  
Project No.: 05-46952-003

Customer

CLEAN AIR INSTRUMENT RENTAL  
500 WEST WOOD STREET  
PALATINE IL 60067

**ANALYTICAL INFORMATION**

This certification was performed according to EPA Traceability Protocol For Assay & Certification of Gaseous Calibration Standards; Procedure G-1; September, 1997.

Cylinder Number: ALM058090 Certification Date: 13Sep2006 Exp. Date: 12Sep2008  
Cylinder Pressure\*\*\*: 1816 PSIG

<u>COMPONENT</u>	<u>CERTIFIED CONCENTRATION (Moles)</u>	<u>ANALYTICAL ACCURACY**</u>	<u>TRACEABILITY</u>
SULFUR DIOXIDE *	150.1 PPM	+/- 1%	Direct NIST and NMI
NITROGEN	BALANCE		

\*\*\* Do not use when cylinder pressure is below 150 psig.

\*\* Analytical accuracy is based on the requirements of EPA Protocol Procedure G1, September 1997.

\* This Protocol has been certified using corrected NIST SO2 standard values, per EPA guidance dated 7/24/96 and will not correlate with uncorrected

**REFERENCE STANDARD**

<u>TYPE/SRM NO.</u>	<u>EXPIRATION DATE</u>	<u>CYLINDER NUMBER</u>	<u>CONCENTRATION</u>	<u>COMPONENT</u>
NTRM 026O	01May2008	ALM019186	254.4 PPM	SULFUR DIOXIDE

**INSTRUMENTATION**

<u>INSTRUMENT/MODEL/SERIAL#</u>	<u>DATE LAST CALIBRATED</u>	<u>ANALYTICAL PRINCIPLE</u>
FTIR//0928621	22Aug2006	FTIR

**ANALYZER READINGS**

(Z = Zero Gas R = Reference Gas T = Test Gas r = Correlation Coefficient)

First Triad Analysis

Second Triad Analysis

Calibration Curve

**SULFUR DIOXIDE \***

Date: 06Sep2006		Response Unit: PPM	
Z1 = -0.00120	R1 = 256.2494	T1 = 151.4877	
R2 = 256.6201	Z2 = 0.00218	T2 = 151.5950	
Z3 = 0.03731	T3 = 151.8651	R3 = 256.6377	
Avg. Concentration: 150.4		PPM	

Date: 13Sep2006		Response Unit: PPM	
Z1 = 0.02749	R1 = 256.4774	T1 = 151.1583	
R2 = 256.6410	Z2 = 0.04677	T2 = 151.1978	
Z3 = 0.06748	T3 = 151.4039	R3 = 256.8676	
Avg. Concentration: 149.9		PPM	

Concentration = A + Bx + Cx <sup>2</sup> + Dx <sup>3</sup> + Ex <sup>4</sup>	
r = 9.99992E-1	
Constants:	A = 0.00000E+0
B = 9.96543E-1	C = 9.00000E-6
D = 0.00000E+0	E = 0.00000E+0

APPROVED BY: \_\_\_\_\_

JEFF CROTEAU

**APPENDIX G**

---

---

**CARL KOONTZ ASSOCIATES**

of Nashville, Tennessee

This is to acknowledge that

Nita Greenburg

successfully participated in Visible Emissions  
training on 9/21/2006

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

Carl Koontz  
Instructor

Visible Emissions Observations Form

RUN NUMBER 1

SOURCE NAME NUCOR Steel

OBSERVATION DATE 10-2-06

START TIME 9:02

STOP TIME 10:02

ADDRESS

sec	0	15	30	45	sec	0	15	30	45
min					min				

CITY

STATE

ZIP

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0

PHONE

SOURCE ID NUMBER

3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0

PROCESS EQUIPMENT  
Castrip

OPERATING MODE

5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0

CONTROL EQUIPMENT

OPERATING MODE

7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0

DESCRIBE EMISSION POINT (Stack Exit Dimensions)

9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0

HEIGHT ABOVE GROUND LEVEL  
START 100' STOP 100'

HEIGHT RELATIVE TO OBSERVER  
START 100' STOP 100'

11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0

DISTANCE FROM OBSERVER  
START 350' STOP 350'

DIRECTION FROM OBSERVER  
START W STOP W

13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0

DESCRIBE EMISSIONS  
START N/A STOP N/A

15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0

EMISSION COLOR  
START N/A STOP

PLUME TYPE: CONTINUOUS  
FUGITIVE INTERMITTENT

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0

WATER DROPLETS PRESENT  
 NO  YES

IF WATER DROPLET PLUME:  
ATTACHED DETACHED

19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START At Stack STOP At stack

21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0

DESCRIBE BACKGROUND  
START Blue sky STOP Cloudy

23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0

BACKGROUND COLOR  
START Blue STOP

SKY CONDITIONS  
START Clear STOP Cloudy

25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0

WIND SPEED (MPH)  
START STOP


WIND DIRECTION  
START NE STOP

27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0

AMBIENT TEMPERATURE (F)  
START 65° STOP

WET BULB TEMP. RH PERCENT

29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD

RANGE OF OPACITY READINGS  
MINIMUM MAXIMUM

OBSERVER'S NAME (PRINT)  
Nita Greenberg

OBSERVER'S SIGNATURE  
Nita Greenberg DATE 10-2-06

ORGANIZATION  
Air Test Professionals, Inc. (ATP)

CERTIFIED BY  
Carl Koontz Associates DATE

Comments:


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

2

SOURCE NAME <b>NUCOR Steel</b>			OBSERVATION DATE <b>10-3-06</b>				START TIME <b>2:32 PM</b>		STOP TIME <b>3:32</b>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY		STATE	ZIP	1	0	0	0	31	0	0	0	0
PHONE		SOURCE ID NUMBER		2	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT <b>Castrip</b>		OPERATING MODE		3	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE		4	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			5	0	0	0	0	35	0	0	0	0
			6	0	0	0	0	36	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>100'</b> STOP <b>100'</b>			HEIGHT RELATIVE TO OBSERVER START <b>100'</b> STOP <b>100'</b>			7	0	0	0	0	0	0
						8	0	0	0	0	0	0
DISTANCE FROM OBSERVER START <b>350'</b> STOP <b>350'</b>		DIRECTION FROM OBSERVER START <b>NW</b> STOP <b>NW</b>		9	0	0	0	0	0	0	0	0
				10	0	0	0	0	0	0	0	0
DESCRIBE EMISSIONS START <b>N/A</b> STOP			11	0	0	0	0	41	0	0	0	0
			12	0	0	0	0	42	0	0	0	0
EMISSION COLOR START <b>N/A</b> STOP		PLUME TYPE: CONTINUOUS		13	0	0	0	0	0	0	0	0
		FUGITIVE INTERMITTENT		14	0	0	0	0	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO <input checked="" type="radio"/> YES		IF WATER DROPLET PLUME: ATTACHED DETACHED		15	0	0	0	0	0	0	0	0
				16	0	0	0	0	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>At Stack</b> STOP <b>At Stack</b>			17	0	0	0	0	47	0	0	0	0
			18	0	0	0	0	48	0	0	0	0
DESCRIBE BACKGROUND START <b>Sky</b> STOP <b>At Stack</b>			19	0	0	0	0	49	0	0	0	0
			20	0	0	0	0	50	0	0	0	0
BACKGROUND COLOR START <b>Blue</b> STOP		SKY CONDITIONS START <b>Clear</b> STOP		21	0	0	0	0	0	0	0	0
				22	0	0	0	0	0	0	0	0
WIND SPEED (MPH) START STOP		WIND DIRECTION START STOP		23	0	0	0	0	0	0	0	0
				24	0	0	0	0	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>74°</b> STOP		WET BULB TEMP. REL. HUMIDITY		25	0	0	0	0	0	0	0	0
				26	0	0	0	0	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
OBSERVER'S NAME (PRINT) <b>Nita Greuburg</b>			
OBSERVER'S SIGNATURE <i>Nita Greuburg</i>		DATE <b>10-3-06</b>	
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>			
CERTIFIED BY <b>Carl Koontz Associates</b>		DATE	
Comments:			


- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER

3

SOURCE NAME <b>NUCOR steel</b>			OBSERVATION DATE <b>10 - 05 - 06</b>				START TIME <b>9:04 a.m.</b>		STOP TIME <b>10:04 a.m.</b>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY		STATE	ZIP	1	0	0	0	31	0	0	0	0
PHONE		SOURCE ID NUMBER		2	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT <b>Castrip</b>		OPERATING MODE		3	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE		4	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			5	0	0	0	0	35	0	0	0	0
			6	0	0	0	0	36	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>100'</b> STOP <b>100'</b>			HEIGHT RELATIVE TO OBSERVER START <b>100'</b> STOP <b>100'</b>			7	0	0	0	0	0	0
						8	0	0	0	0	0	0
DISTANCE FROM OBSERVER START <b>350'</b> STOP <b>350'</b>		DIRECTION FROM OBSERVER START <b>NW</b> STOP <b>NW</b>		9	0	0	0	0	0	0	0	0
				10	0	0	0	0	0	0	0	0
DESCRIBE EMISSIONS START <b>N/A</b> STOP <b>N/A</b>						11	0	0	0	0	0	0
						12	0	0	0	0	0	0
EMISSION COLOR START <b>N/A</b> STOP <b>N/A</b>		PLUME TYPE: CONTINUOUS				13	0	0	0	0	0	0
		FUGITIVE INTERMITTENT				14	0	0	0	0	0	0
WATER DROPLETS PRESENT <input checked="" type="radio"/> NO YES		IF WATER DROPLET PLUME: ATTACHED DETACHED				15	0	0	0	0	0	0
						16	0	0	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START STOP						17	0	0	0	0	0	0
						18	0	0	0	0	0	0
DESCRIBE BACKGROUND START <b>SKY</b> STOP <b>SKY</b>						19	0	0	0	0	0	0
						20	0	0	0	0	0	0
BACKGROUND COLOR START <b>GRAY</b> STOP <b>GRAY</b>		SKY CONDITIONS START <b>cloudy</b> STOP <b>cloudy</b>				21	0	0	0	0	0	0
						22	0	0	0	0	0	0
WIND SPEED (MPH) START <b>17 mph</b> STOP <b>17 mph</b>		WIND DIRECTION START <b>NE</b> STOP <b>NE</b>				23	0	0	0	0	0	0
						24	0	0	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>54°</b> STOP <b>54°</b>						25	0	0	0	0	0	0
						26	0	0	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD		NUMBER OF READINGS ABOVE WERE	
RANGE OF OPACITY READINGS			
MINIMUM		MAXIMUM	
OBSERVER'S NAME (PRINT) <b>ERIC Ferguson</b>			
OBSERVER'S SIGNATURE <i>Eric Ferguson</i>		DATE <b>10 - 05 - 06</b>	
ORGANIZATION <b>Air Test Professionals, Inc. (ATP)</b>			
CERTIFIED BY <b>Whitlow Enterprises</b> <del>Carl Koontz Associates</del>		DATE <b>9-8-06</b>	
Comments:			

- X = Emission Point
- = Observer's Position
- ☀ = Sun
- = Wind
- = Plume



**Whitlow Enterprises, LLC**

[www.smokeschool.net](http://www.smokeschool.net)

**Certifies that**


**Eric Ferguson of Nucor Steel**

**Has met all of the requirements of EPA Reference Method 9 and 22  
And is qualified as a Visible Emissions Observer**

**Date: September 8, 2006**

**This certificate is valid for 6 months after the above date**

**George Artie "Butch" Whitlow**



**APPENDIX H**

---

**COMPLIANCE TEST PROTOCOL  
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: 8/15/2006 Proposed Test Date: \_\_\_\_\_

Plant Address and Location: \_\_\_\_\_

4537 S. Nucor Road, Crawfordsville, Indiana 47933

**1. Source Information**

AFS: \_\_\_\_\_ Id Number: \_\_\_\_\_ Permit Number: F 107-12143-00038  
 Company: Nucor Steel  
 Mail Address: 4537 S. Nucor Road  
Crawfordsville, Indiana Zip: 47933  
 Co. Contact: Mark Washer Phone: (765) 364-1323

Check program if applicable:

FESOP: \_\_\_\_\_  
 Title V:  \_\_\_\_\_  
 SSOA: \_\_\_\_\_

<b>AGENCY USE ONLY</b>	Date Rec'd: _____
Inspector: _____	Reviewer: _____
	Date Appr: _____

**2. Tester Information**


Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete?  Yes

**5. Sampling Strategy**

a. Describe any deviations from the standard test method.  
 \_\_\_\_\_  
 None

**3. Process Information**

Unit to Test: Strip Caster Line  
 Max. Rated Capacity: 135 tons per hour  
 Proposed Operating Speed: As close to max as possible  
 Pollution Control Equipment: LMS Baghouse  
 Process Description: Molds molten grades of carbon steel into rolled steel of various widths and thicknesses.



**6. Sample Site Location**

Does sample port location meet 40 CFR 60, Appx. A, Method 1 Section 1.2 requirements: Yes/No: YES If No, Explain \_\_\_\_\_

Number of sample points for MS: 24  
 Diameter at sample site: 96" Stack height: 100 ft.  
 Approx. stack gas flow (ACFM): 120,000  
 Approx. gas temp. (degF): 100 F  
 Approx. gas moisture (%): 1.5%

**Reason for test:**

State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: YES  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 326 \_\_\_\_\_  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (i.e. EPA, CD, state, 114) \_\_\_\_\_

**4. Test Information**

Methods	Moisture/Flow	# Runs	Time/Run
Method 1-4	Particulate	3	60 min
Method 5	SO2	3	60 min
Method 6C	NOx	3	60 min
Method 7	Opacity	3	60 min
Method 9	CO	3	60 min
Method 10	Lead	3	60 min
Method 12	M202	3	60 min
Other Testing:			

326 IAC 3-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to:  
 (FEE NOT APPLICABLE IF FESOP OR TITLE V)

Questions may be directed to 317-232-8338, FAX: 317-233-6865

Compliance Data Section  
 Office of Air Management  
 Indiana Department of Environmental Management  
 100 North Senate  
 PO BOX 6015  
 Indianapolis, IN 46206-6015

**APPENDIX I**

---

10/2/06

# Castrip

	8:50 AM	9:05	9:20	9:35	9:50	10:05
Amp	94	94	94	92	91	95
Delta	5.21	5.21	5.72	5.72	6.76	7.10

---

10:10 AM

Amp	96
Delta	7.10

NUCOR STEEL - CRAWFORDSVILLE  
LMF HEAT RECORD

Caster # \_\_\_\_\_ Seq# 3108 Aim Grade: 1005S4 Date: 10/2/06 2nd OP: \_\_\_\_\_  
 Heat No.: 162393 Liquidus: \_\_\_\_\_ Melter: TT Utility: \_\_\_\_\_  
 LMF: (E or W): \_\_\_\_\_ Finish Grade: 34 1st OP: 120  
 Ladle No.: 18 Wt. tapped: 115 Tap Time: \_\_\_\_\_ Power on time: \_\_\_\_\_

CHEMISTRY

SAMPLE	TIME	CHEMISTRY																TOTAL		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	Nb	Ti	Sb	B	N	RESID
LMF-1		<u>026?</u>	<u>.58</u>	<u>0113</u>	<u>0032</u>	<u>.22</u>							<u>0050</u>						<u>.46</u>	
LMF-2		<u>035'</u>	<u>.60</u>	<u>0116</u>	<u>0036</u>	<u>.19</u>							<u>0022</u>	<u>0033</u>					<u>.48</u>	
LMF-3																				
LMF-4																				

LADLE ADDITION	TIME	AMOUNTS
Lime		<u>1200 #</u>
L.C.SiMn		<u>1250 #</u>
MED C FeMn		<u>600 # / 75 #</u>
STD FeMn		
CARBON		
75% FeSi		
NITRO VAN		
PHOS		
LC FeCr		
ANTIMONY		
FeNb		
Nickel		
COPPER		
FE VAN		
FeMo		
AL SHOT		
AL WIRE		
FeTi WIRE		
SPONGE TI		
Fe BORON		
C WIRE		<u>125'</u>
FeCa WIRE		
CaSi		<u>350</u>

DESULF

	Flow	No Flow	TIME
Plug			
Lance			
Lance Change #			

HYDROGEN

TIME	TEMP	PPM
<u>7:08</u>	<u>2934</u>	<u>8.1 - 109</u>

DEPARTURE TIME TEMP  
3019 62.3 14m

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**NUCOR STEEL - CRAWFORDSVILLE**  
**LMF HEAT RECORD**

Caster # \_\_\_\_\_ Seq# 3108-2 Aim Grade: 100SS4 Date: 10/2 2nd OP: \_\_\_\_\_  
 Heat No.: 102395 Liquidus: \_\_\_\_\_ Melter: TT Utility: \_\_\_\_\_  
 LMF: (E or W): \_\_\_\_\_ Finish Grade: 100SS4 1st OP: PS  
 Ladle No.: 15 Wt. tapped: 115 Tap Time: \_\_\_\_\_ Power on time: \_\_\_\_\_

**CHEMISTRY**

SAMPLE	TIME	CHEMISTRY																TOTAL		
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	Nb	Ti	Sb	B	N	RESID
LMF-1		0.33	.54	0.117	.0020	.13								0.052					.56	
LMF-2		0.34	.56	0.12	.002	.13								.25					.53	
LMF-3			+			+							+							
LMF-4																				

**DESULF**

	Flow	No Flow	TIME
Plug			
Lance			
Lance Change #			

**HYDROGEN**

TIME	TEMP	PPM
9:18	2871	
9:43	2949	
9:59	3609	73.9
10:04	3003	43.8

DEPARTURE TIME TEMP  
10:05 3003

**REMARKS**

LADLE ADDITION	TIME	AMOUNTS
Lime		1200# / 300
L.C.SiMn		1000# / 225
MED C FeMn		500# / 150#
STD FeMn		
CARBON		
75% FeSi		135#
NITRO VAN		
PHOS		
LC FeCr		
ANTIMONY		
FeNb		
Nickel		
COPPER		
FE VAN		
FeMo		
AL SHOT		
AL WIRE		
FeTi WIRE		
SPONGE TI		
Fe BORON		
C WIRE		
FeCa WIRE		
CaSi		250

NUCOR STEEL - CRAWFORDSVILLE  
LMF HEAT RECORD

Caster # \_\_\_\_\_ Seq# 3110 Aim Grade: S3 Date: 10/3 2nd OP: \_\_\_\_\_  
 Heat No.: 162424 Liquidus: \_\_\_\_\_ Melter: 6H Utility: \_\_\_\_\_  
 LMF: (E or W): \_\_\_\_\_ Finish Grade: \_\_\_\_\_ 1st OP: Dm  
 Ladle No.: 20 Wt. tapped: 117 Tap Time: 11:50 Power on time: 1:07

CHEMISTRY

TOTAL

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	Nb	Ti	Sb	B	N	RESID
LMF-1		024	65	009	0035	30								010					37	
LMF-2		034	64	009	005	28								25					45	
LMF-3													+							
LMF-4																				

DESULF

	Flow	No Flow	TIME
Plug			
Lance			
Lance Change #			

HYDROGEN

TIME	TEMP	PPM
1:37	2910	
1:52	2948	
2:10	2999	61.4 19.
2:16	3012	49.8 0

DEPARTURE TIME TEMP  
2:19 3025 49.8 0.

REMARKS  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

LADLE ADDITION	TIME	AMOUNTS
Lime		1000 / 500
L.C.SiMn		2300
MED C FeMn		100 / 50
STD FeMn		
CARBON		
75% FeSi		125
NITRO VAN		
PHOS		
LC FeCr		
ANTIMONY		
FeNb		
Nickel		
COPPER		
FE VAN		
FeMo		
AL SHOT		1 BAG
AL WIRE		
FeTi WIRE		
SPONGE Ti		
Fe BORON		
C WIRE		125'
FeCa WIRE		
CaSi		300'



NUCOR STEEL - CRAWFORDSVILLE  
LMF HEAT RECORD

60-15  
mN Si

Caster # \_\_\_\_\_ Seq# 3014-2 Aim Grade: S-4 Date: 10/5 2nd OP: \_\_\_\_\_  
Heat No.: 162467 Liquidus: 8 Melter: TM Utility: \_\_\_\_\_  
LMF: (E or W): \_\_\_\_\_ Finish Grade: S-4 1st OP: KO  
Ladle No.: 15 Wt. tapped: 115 Tap Time: \_\_\_\_\_ Power on time: \_\_\_\_\_

CHEMISTRY

TOTAL

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	Nb	Ti	Sb	B	N	RESID
LMF-1		0208	.58	0193	0027	20								0052					.45	
LMF-2		0341	5.8	0069	004	17								23					44	
LMF-3																				
LMF-4																				

LADLE ADDITION	TIME	AMOUNTS
Lime		1200 #
L.C.SiMn		1200 #
MED C FeMn		600 # / 75 # / 40 #
STD FeMn		
CARBON		
75% FeSi		
NITRO VAN		
PHOS		
LC FeCr		
ANTIMONY		
FeNb		
Nickel		
COPPER		
FE VAN		
FeMo		
AL SHOT		
AL WIRE		
FeTi WIRE		
SPONGE Ti		
Fe BORON		
C WIRE		175'
FeCa WIRE		
CaSi		275 / 35 / 10

DESULF

	Flow	No Flow	TIME
Plug			
Lance			
Lance Change #			

HYDROGEN

TIME	TEMP	PPM
9:20	2906	10.7 - 81
9:50	3003	73.9 31
9:55	3011	59.0 13
9:59	3019	56.7 7

DEPARTURE TIME TEMP  
10:01 3020

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**NUCOR STEEL - CRAWFORDSVILLE**  
**LMF HEAT RECORD**

Caster # \_\_\_\_\_ Seq# 3014 Aim Grade: 1005S3 Date: 10/5 2nd OP: \_\_\_\_\_  
 Heat No.: 162465 Liquidus: \_\_\_\_\_ Melter: TM Utility: \_\_\_\_\_  
 LMF: (E or W): \_\_\_\_\_ Finish Grade: 1005S3 1st OP: PO  
 Ladle No.: 16 Wt. tapped: 115 Tap Time: \_\_\_\_\_ Power on time: \_\_\_\_\_

**CHEMISTRY**

SAMPLE	TIME	CHEMISTRY														TOTAL RESID				
		C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	Nb		Ti	Sb	B	N
LMF-1		0.264	.61	0.009	0.038	.28								0.078						.53
LMF-2		0.263	.66	0.005	0.049	.26							0.019	0.007						.54
LMF-3			+			+														
LMF-4																				

LADLE ADDITION	TIME	AMOUNTS
Lime		1200#
L.C.SiMn		2200#
MED C FeMn		175# / 50#
STD FeMn		
CARBON		
75% FeSi		135# / 100#
NITRO VAN		
PHOS		
LC FeCr		
ANTIMONY		
FeNb		
Nickel		
COPPER		
FE VAN		
FeMo		
AL SHOT		1 BAG
AL WIRE		
FeTi WIRE		
SPONGE Ti		
Fe BORON		
C WIRE		150'
FeCa WIRE		
CaSi		300'

**DESULF**

	Flow	No Flow	TIME
Plug			
Lance			
Lance Change #			

**HYDROGEN**

TIME	TEMP	PPM
7:47	2874	

DEPARTURE \_\_\_\_\_ TIME \_\_\_\_\_ TEMP \_\_\_\_\_

REMARKS \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**ATP** – Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 46219

(317) 345-1720 FAX (317) 351-0411

**REPORT on COMPLIANCE TESTING**  
**for SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb and PM/PM<sub>10</sub>**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**Strip Caster**  
on November 20 & 21, 2003

4.3

43.2

16.2

DAE  
~~SEA~~  
MUD-RE

**ATP** – Air Test Professionals, Inc.

1201 North Graham Avenue, Indianapolis, Indiana 46219

(317) 345-1720 FAX (317) 351-0411

**RECEIVED**

JAN 02 2004

State of Indiana  
Department of Environmental Management  
Office of Air Quality

**REPORT on COMPLIANCE TESTING  
for SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb and PM/PM<sub>10</sub>**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**Strip Caster**  
on November 20 & 21, 2003

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:



Andrew Young, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
2.	<b>RESULTS</b>	
	STRIP CASTER – PM/PM10, SO2, NOx, & CO EMISSIONS	2-1
	STRIP CASTER – LEAD EMISSIONS	2-2
	STRIP CASTER – VISIBLE EMISSIONS	2-3
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA SUMMARIES	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	PRODUCTION DATA	I

**1-1 PROJECT OVERVIEW**

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling at the LMS Baghouse that controls emissions from the LMS and Strip Caster. The sampling was performed in Crawfordsville, Indiana on November 20-21, 2003. The objective of the testing was to determine compliance with permit requirements for the pollutants listed below. The following personnel were involved with the testing program:

ATP	Andrew Young
ATP	Carlos Brown
ATP	Ron Stapert
Nucor Steel	Mark Washer
IDEM	Steve Friend

The testing program included flow determination (US EPA Methods 1-2), gas analysis (US EPA Method 3), moisture content (US EPA Method 4), PM/PM10 emissions (US EPA Method 5/202), SO2 emissions (US EPA Method 6C), NOx emissions (US EPA Method 7E), CO emissions (US EPA Method 10), and visible emissions (US EPA Method 9). Listed below is a summary of the results.

**Test Summary**  
Table 1-1

Pollutant	PM/PM10 (filterable)	PM/PM10 (filterable & condensible)	PM (filterable)
Particulate Matter	0.0010 (gr/dscf)	0.0043 (gr/dscf)	0.9232 (lb/hr)

Pollutant	Lead	Total Lead
Lead	0.000000 (gr/dscf)	0.0005 (lb/hr)

Pollutant	Emissions (lb/hr)	Emissions (lb/ton)
Sulfur Dioxide	10.50 (lb/hr)	0.0510 (lb/ton)
Nitrogen Oxide	3.8294 (lb/hr)	0.0181 (lb/ton)
Carbon Monoxide	<u>3.810</u> 11.7834 (lb/hr)	0.0567 (lb/ton)

**2-1 RESULTS**

**PM/PM10, SO2, NOx, CO Emissions**  
*Strip Caster Baghouse Stack*

Table 2-1

<u>Gas Conditions</u>		1	2	3	Avg
Ts	Stack Temperature	99.38	101.33	111.33	104.01
Bwo	Moisture (volume %)	1.39	1.05	1.32	1.25
O2	Oxygen (dry volume %)	20.9	20.9	20.9	20.9
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	124,327	115,915	111,894	117,482
Qstd	Standard Conditions (dscfm)	116,055	107,871	102,032	108,652
<u>PM/PM10</u>					
E <sub>TSP</sub>	Filterable (gr/dscf)	0.0008	0.0008	0.0013	0.0010
E	Filterable & Condensable (gr/dscf)	0.0050	0.0024	0.0053	0.0043
<u>PM</u>					
E <sub>TSP</sub>	Filterable (lbs/hr)	0.8454	0.7723	1.1518	0.9232
<u>SULFUR DIOXIDE</u>					
E	Emission (lb/ton)	0.0299	0.0240	0.0990	0.0510
<u>NITROGEN OXIDE</u>					
E	Emission (lb/ton)	0.0040	0.0226	0.0279	0.0181
<u>CARBON MONOXIDE</u>					
E	Emission (lb/ton)	0.0476	0.0670	0.0554	0.0567

**2-2 RESULTS**

**Lead Emissions**  
*Strip Caster Baghouse Stack*

Table 2-2

<u>Gas Conditions</u>		1	2	3	Avg
Ts	Stack Temperature	101.13	102.33	112.17	105.21
Bwo	Moisture (volume %)	1.39	0.86	0.83	1.03
O2	Oxygen (dry volume %)	20.9	20.9	20.9	20.9
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	125,926	118,177	115,974	120,026
Qstd	Standard Conditions (dscfm)	116,887	109,941	106,072	110,966
<b>LEAD EMISSIONS</b>					
E <sub>TSP</sub>	Emission Rate (gr/dscf)	0.000001	0.000001	0.000000	0.000000
E	Emission Rate (lbs/hr)	0.0005	0.0005	0.0003	<b>0.0005</b>

**2-3 RESULTS**

**VISIBLE EMISSIONS - OPACITY**

*LMS Stack*  
Table 2-3

Run No.	1	2	3	Average
Date	November 20, 2003	November 21, 2003	November 21, 2003	
Start Time (approx)	11:23	08:50	16:38	
Stop Time (approx)	12:23	09:50	17:38	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0 %

*Roof Monitors*

Run No.	1	2	3	Average
Date	November 20, 2003	November 21, 2003	November 21, 2003	
Start Time (approx)	11:23	08:50	16:38	
Stop Time (approx)	12:23	09:50	17:38	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0 %

### **3-1 PROCESS DESCRIPTION**

---

Nucor Steel of Crawfordsville, Indiana operates the units listed below:

A Strip Caster Line rated at a maximum steel production rate of 135 tons per hour from the existing electric arc furnace (EAF) and is capable of producing several grades of steel at various widths and thicknesses:

1. One (1) ladle metallurgy station (LMS) identified as LMS-2. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
2. One (1) tundish that feeds the molten metal from the LMS ladle to one (1) continuous strip caster. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
3. One (1) hot rolling stand. The stand rolls the steel strips from the continuous strip caster to a desired gauge.
4. Two (2) coilers. After the strip passes the rolling mill it is then rolled into coils.

The testing reported in this document was performed at the LMS baghouse stack, with additional visible emissions read at the roof monitor.

## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

### Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determining of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Determination of Oxygen and Carbon Dioxide Percentages"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 5	"Determination of Particulate Emissions from Stationary Sources"
Method 6C	"Determination of Sulfur Dioxide Emissions from Stationary Sources"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide from Stationary Sources"
Method 12	"Determination of Lead Emissions from Stationary Sources"
Method 9	"Visual Determination of the Opacity from Stationary Sources"

### Title 40 CFR Part 51 Appendix M

Method 202	"Determination of Condensable Particulate Emissions from Stationary Sources"
------------	--

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

Sampling Points  
Table 4-1

Location	Dimensions	Points / Port	Total Points
LMS Baghouse Stack	96.0" ID	6	24

---

## **4-2 METHODOLOGY**

---

### **SAMPLE AND VELOCITY TRAVERSE – EPA METHOD 1**

Method 1 was utilized for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction, is selected and divided into a sample grid according to the published percentages of the diameter. A traverse point is then located at each of these percentage points. Sampling or velocity measurement is performed at a site located at least two stack or duct diameters downstream and one-half diameter upstream from a disturbance such as a bend, expansion, contraction, or visible flame.

### **VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT – EPA METHOD 4**

The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **PARTICULATE/CONDENSIBLE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe and filter. Condensible particulate is captured in the first three impingers; each impinger contains 100 mls of deionized water. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The probe and filter temperatures are maintained at temperatures of 248 degrees F (+/- 25 deg F). The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit.

The nozzle, probe liner and glass filter holder are rinsed with acetone and captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with deionized water and captured in a sealed container. Two rinses of methylene chloride were captured and stored in a sealed container.

### **SULFUR DIOXIDE CONCENTRATION – EPA METHOD 6C**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a NDIR or fluorescence analyzer for SO<sub>2</sub> concentration determination. The wet stack gas is "dried" before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **NITROGEN OXIDE CONCENTRATION – EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NO<sub>x</sub> concentration determination. The wet stack gas is "dried" before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

#### **4-2 METHODOLOGY, cont.**

---

##### **CARBON MONOXIDE CONCENTRATION – EPA METHOD 10**

A continuous gas sample is drawn from the stack and a portion of the sample is conveyed to an NDIR analyzer for carbon monoxide concentration determination. The wet stack gas is “dried” before analysis by a chilled condenser. EPA protocol gases are used to calibrate the instrument as well as run system bias and drift checks.

##### **LEAD EMISSIONS DETERMINATION – EPA METHOD 12**

Stack gas is withdrawn isokinetically and lead particulate matter is collected on the nozzle, probe and filter. Lead particulate matter is also captured in the first two impingers; each impinger contains 100 mls of 0.1 N Nitric Acid. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The probe and filter temperatures are maintained at temperatures of 248 degrees F(+/- 25 deg F). The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit. The probe, nozzle, filter holder, impingers, and connecting glassware are rinsed with approximately 100 mls of 0.1 N nitric acid and collected in a sealed container.

##### **VISIBLE EMISSIONS – EPA METHOD 9**

Stack opacity readings were taken for 60-minutes at 15-second intervals by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs at both the LMS baghouse stack and the LMS Roof Monitors. The results are reported as an average emissions percentage for each hour period. A copy of the visible emissions certification card is included in Appendix G.

**APPENDIX A**

---

## SAMPLE CALCULATIONS

### 1. Volume of water collected (wstd)

$$V_{wstd} = (0.04707)(V_{lc})$$

$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{lc}$	total volume of liquid collected in impingers and silica (ml)
0.04707	conversion factor (ft <sup>3</sup> /ml)

### 2. Volume of gas metered at standard conditions (dscf)

$$V_{mstd} = \frac{(17.64)(V_m) \left( P_{baro} + \frac{\Delta H}{13.6} \right) (\Gamma_d)}{(460 + T_m)}$$

$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
$V_m$	volume of sample gas through dry gas meter at meter conditions (ft <sup>3</sup> )
$P_{baro}$	barometric pressure (in Hg)
$\Delta H$	average pressure drop across meter box orifice (in H <sub>2</sub> O)
$\Gamma_d$	gas meter correction factor (dimensionless)
$T_m$	average dry gas meter temperature (°F)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	conversion constant, °F to °R

### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left( \frac{P_g}{13.6} \right)$$

$P_s$	absolute sample gas pressure (in Hg)
$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

### 4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

5. Moisture content (%)

$$B_{wo} = \frac{V_{wstd}}{(V_{mstd} + V_{wstd})}$$

$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
$V_{mstd}$	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )

6. Saturated moisture content (%)

$$B_{ws} = \frac{P_v}{P_s}$$

$B_{ws}$	portion of water vapor in gas stream by volume at saturated conditions (%)
$P_v$	vapor pressure, actual (in Hg)
$P_s$	absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \left( \frac{CO_2}{100} \right) + M_{O_2} \left( \frac{O_2}{100} \right) + M_{CO+N_2} \left( \frac{CO+N_2}{100} \right)$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$M_{CO_2}$	molecular weight of carbon dioxide (lb/lb-mole)
$M_{O_2}$	molecular weight of oxygen (lb/lb-mole)
$M_{CO+N_2}$	molecular weight of carbon monoxide and nitrogen (lb/lb-mole)
$CO_2$	portion of carbon dioxide in the gas stream by volume (%)
$O_2$	portion of oxygen in the gas stream by volume (%)
$CO+N_2$	portion of carbon monoxide and nitrogen in gas stream by volume (%)
100	conversion factor (%)

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{ws}) + (M_{H_2O})(B_{ws})$$

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{ws}$	portion of water vapor in the gas stream by volume (%)
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)\left(\sqrt{\Delta P}\right)\left(\sqrt{\frac{(t_s + 460)}{(M_s)(P_s)}}\right)$$

$V_s$	average sample gas velocity (ft/sec)
$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$\Delta P$	average differential pressure in the gas stream (in H <sub>2</sub> O)
$t_s$	average sample gas temperature (°F)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in Hg)
460	conversion constant, °F to °R

10. Total flow of sample gas (acfm)

$$Q_a = (60)(A_s)(V_s)$$

$Q_a$	volumetric flow rate at actual conditions (acfm)
$A_s$	cross-sectional area of sampling location (ft <sup>2</sup> )
$V_s$	average sample gas velocity (ft/sec)
60	conversion factor (seconds/minute)

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a)(P_s)(17.64)(1 - B_{wo})}{(t_s + 460)}$$

$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
$Q_a$	volumetric flow rate at actual conditions (acfm)
$P_s$	absolute sample gas pressure (in Hg)
$B_{wo}$	portion of water vapor in the gas stream by volume (%)
$t_s$	average sample gas temperature (°F)
17.64	conversion factor (°R/in Hg)
460	conversion constant, °F to °R

12. Percent isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{mstd})}{(P_s)(V_s) \left( \frac{(D_n)^2(\pi)}{(144)(4)} \right) (\theta)(1 - B_{wo})}$$

I	percent relative to isokinetic sampling (%)
T <sub>s</sub>	absolute sample gas temperature (°R)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
P <sub>s</sub>	absolute sample gas pressure (in Hg)
V <sub>s</sub>	average sample gas velocity (ft/sec)
D <sub>n</sub>	diameter of nozzle (inches)
B <sub>wo</sub>	portion of water vapor in the gas stream by volume (%)
θ	total sample time (minutes)
0.09450	conversion constant

13. Particulate concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(M_n)}{V_{mstd}}$$

C <sub>gr/dscf</sub>	measured concentration in gas stream (gr/dscf)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor (grains/gram)

14. Particulate emissions, mass emission rate (lbs/hr)

$$E_{lbs/hr} = \frac{(M_n)(Q_{std})}{(7.567)(V_{mstd})}$$

E <sub>lbs/hr</sub>	mass emission rate (lbs/hr)
M <sub>n</sub>	particulate collected, corrected for reagent blank (grams)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
V <sub>mstd</sub>	volume of sample gas through dry gas meter at standard conditions (ft <sup>3</sup> )
7.567	conversion factor (grams/pound)

15. Gas emission concentration (ppm)

$$C_{gas} = (\bar{C} - C_o) \frac{C_{ma}}{C_m - C_o}$$

$C_{gas}$	effluent gas concentration (ppm)
$\bar{C}$	average gas concentration indicated by gas analyzer (ppm)
$C_o$	average of initial and final system bias checks for zero gas (ppm)
$C_{ma}$	actual concentration of the upscale gas (ppm)
$C_m$	average of initial and final system bias check for upscale cal gas (ppm)

16. Carbon Monoxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(1.3762 \times 10^7)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$1.3762 \times 10^7$	CO conversion factor (ppm to lbs/dscf)

17. Nitrogen Oxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(8.3752 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$8.3752 \times 10^6$	NOx conversion factor (ppm to lbs/dscf)

18. Sulfur Dioxide emission rate (lbs/hr)

$$E = \frac{(C_{gas})(Q_{std})(60)}{(6.0151 \times 10^6)}$$

E	pollutant emission rate (lbs/hr)
$C_{gas}$	effluent gas concentration (ppm)
$Q_{std}$	volumetric flow rate at standard conditions (dscfm)
60	conversion factor (seconds/minute)
$6.0151 \times 10^6$	SO2 conversion factor (ppm to lbs/dscf)

19. Pollutant emission rate (lbs/ton)

$$E_{lbs/ton} = \frac{(E)}{(P_{tons/hr})}$$

$E_{lbs/ton}$	emission rate (lbs/ton)
E	pollutant emission rate (lbs/hr)
$P_{tons/hr}$	facility production rate (tons/hr)

**APPENDIX B**

---

**Particulate Field Data Summaries**

## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/03-11/21/03

	Run 1	Run 2	Run 3	Average
<b>Particulate Concentration</b>				
Filterable PM/PM10 (gr/dscf)	0.0008	0.0008	0.0013	0.0010
Filterable and Condensible PM/PM10 (gr/dscf)	0.0050	0.0024	0.0053	0.0043
Filterable (lbs/hr)	0.8454	0.7723	1.1518	0.9232
Condensible (lbs/hr)	4.1256	1.4775	3.5230	3.0420
Filterable + Condensible (lbs/hr)	4.9710	2.2498	4.6748	3.9652
<b>Gas Concentration</b>				
Sulfur Dioxide (lbs/ton)	0.0299	0.0240	0.0990	0.0510
Nitrogen Oxide (lbs/ton)	0.0040	0.0226	0.0279	0.0181
Carbon Monoxide (lbs/ton)	0.0476	0.0670	0.0554	0.0567
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	124,637	115,915	111,894	117,482
DSCFM	116,055	107,871	102,032	108,652
<b>Avg. Stack Temp</b>	99.38	101.33	111.33	104.01
<b>Stack Gas Velocity</b>	41.326	38.434	37.101	38.954
<b>Avg. Velocity Head</b>	0.508	0.438	0.401	0.449
<b>Avg. Sq. Rt of Delta P</b>	0.713	0.662	0.633	0.669
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 90-110%	100.91	101.62	100.74	101.09
% Moisture of Stack Gas	1.39%	1.05%	1.32%	1.25%
Sample Volume	45.396	42.492	39.842	42.576

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/03
Run Number:	1

**FIELD DATA**

K' Factor	3.6
-----------	-----

Start Time	11:44
Stop Time	12:54

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 13.6  
 Vw (scf) = 0.64015

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 78.3  
 Vm (ft^3) = 45.840  
 Pb (in Hg) = 29.95  
 delta H (in H2O) = 1.860  
 gamma = 1.004  
 Vm (dscf) = 45.40

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.39%  
 1-Bwo = 98.61%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.69

Area of Stack (enter diameter in inches), As  
 Depth = 0  
 Width = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft^2) = 0.000  
 As(dia.) (ft^2) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 29.93

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.713  
 Ts (F) = 99.4  
 Vs (fps) = 41.33

Stack Gas Flowrate, Qs  
 As (ft^2) = 50.27  
 Qs (acfm) = 124,637

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 116,055  
 Qstd (dscf/hr) = 6,963,288

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft^2) = 0.00032472  
 Time of Run (min) = 60.00  
 Vn (fps) = 41.70

% Isokinetic, %I  
 %I = 100.91  
 % Isokinetic measured from intermediate values  
 %I = 100.91

**PM FILTERABLE**

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0025 0.0122  
 PMR (lb/hr) = 0.8454 4.1256 4.9710  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0008

**PM/PM10 FILTERABLE (AND + CONDENSIBLE)**

Grains per dscf  
 gr/dscf = 0.0008 0.0041 0.0050

Pollutant Mass Emission Rate, PMR  
 C (dry, corrected) (PPM) = 18.137 0.919 4.976  
 PMR (lb/hr) = 9.1769 0.7641 5.7604  
 PMR (lb/ton) = 0.0476 0.0040 0.0299  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.43	0.656		1.55	80	71	71
2	0.43	0.656		1.55	91	71	71
3	0.45	0.671		1.62	93	73	71
4	0.42	0.648		1.51	98	73	71
5	0.41	0.640		1.48	99	75	71
6	0.40	0.632		1.44	99	74	71
7	0.46	0.678		1.66	101	75	72
8	0.51	0.714		1.84	101	76	73
9	0.50	0.707		1.80	101	79	73
10	0.50	0.707		1.80	101	79	74
11	0.46	0.678		1.66	101	81	74
12	0.49	0.700		1.76	101	83	75
13	0.46	0.678		1.66	103	82	76
14	0.46	0.678		1.66	103	82	76
15	0.47	0.686		1.69	103	84	77
16	0.47	0.686		1.69	102	84	77
17	0.45	0.671		1.62	101	86	78
18	0.41	0.640		1.48	100	87	78
19	0.44	0.663		1.58	103	86	79
20	0.39	0.624		1.40	102	86	79
21	0.42	0.648		1.51	101	88	80
22	1.05	1.025		3.78	99	88	81
23	1.08	1.039	591.945	3.89	96	91	82
24	0.97	0.985	546.105	3.49	96	92	83

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.522	0.713	45.84	1.880	99.4	78.3

**Production Rate**

LMS tons	106
Caster tons	119
Total tons	225
Process Time (min)	70
Tons/hr	182.86

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/21/03
Run Number:	2

**FIELD DATA**

K' Factor	3.6
-----------	-----

Start Time	8:49
Stop Time	9:54

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 9.6  
 Vw (scf) = 0.45187

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 73.1  
 Vm (ft<sup>3</sup>) = 42.563  
 Pb (in Hg) = 29.92  
 delta H (in H2O) = 1.581  
 gamma = 1.004  
 Vm (dscf) = 42.49

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.05%  
 1-Bwo = 98.95%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.72

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.05  
 Ps (in Hg) = 29.92

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqr(delta p) = 0.662  
 Ts (F) = 101.3  
 Vs (fps) = 38.43

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 115,915

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 107,871  
 Qstd (dscf/hr) = 6,472,232

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft<sup>2</sup>) = 0.00032472  
 Time of Run (min) = 60  
 Vn (fps) = 39.06

% Isokinetic, %I  
 %I = 101.62  
 % Isokinetic measured from intermediate values  
 %I = 101.62

**PM FILTERABLE**

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0023 0.0044  
 PMR (lb/hr) = 0.7723 1.4775 2.2498  
 Filterable Condensible Total

Grains per acf  
 gr/acf = 0.0008

**PM/PM10 FILTERABLE (AND + CONDENSIBLE)**

Grains per dscf  
 gr/dscf = 0.0008 0.0016 0.0024

Pollutant Mass Emission Rate, PMR  
 C (dry, corrected) (PPM) = 31.304 6.417 4.904  
 PMR (lb/hr) = 14.7222 4.9590 5.2767  
 PMR (lb/ton) = 0.0670 0.0226 0.0240  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.45	0.671		1.62	86	68	67
2	0.44	0.663		1.58	87	68	67
3	0.43	0.656		1.55	87	68	67
4	0.41	0.640		1.48	90	69	67
5	0.41	0.640		1.48	93	71	67
6	0.38	0.616		1.37	94	71	67
7	0.47	0.686		1.69	95	71	68
8	0.47	0.686		1.69	98	72	68
9	0.43	0.656		1.55	99	73	69
10	0.40	0.632		1.44	101	73	69
11	0.40	0.632		1.44	103	74	69
12	0.38	0.616		1.37	104	74	69
13	0.45	0.671		1.62	108	76	69
14	0.46	0.678		1.66	108	77	71
15	0.49	0.700		1.76	109	78	71
16	0.47	0.686		1.69	109	79	72
17	0.49	0.700		1.76	108	79	72
18	0.48	0.693		1.73	108	80	73
19	0.47	0.686		1.69	108	80	73
20	0.45	0.671		1.62	108	81	74
21	0.45	0.671		1.62	108	82	75
22	0.45	0.671		1.62	107	83	76
23	0.44	0.663	634.878	1.58	107	84	76
24	0.37	0.608	592.315	1.33	107	84	76

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp	
	0.439	0.662	42.563	1.581	101.3	73.1

**Production Rate**

LMS tons	119
Caster tons	119
Total tons	238
Process Time (min)	65
Tons/hr	219.69

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/21/03
Run Number:	3

**FIELD DATA**

K Factor	3.5
----------	-----

Start Time	16:33
Stop Time	17:38

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 11.3  
 Vw (scf) = 0.53189

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 80.7  
 Vm (ft^3) = 40.498  
 Pb (in Hg) = 29.92  
 delta H (in H2O) = 1.406  
 gamma = 1.004  
 Vm (dscf) = 39.84

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.32%  
 1-Bwo = 98.68%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.69

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft^2) = 0.000  
 As(dia.) (ft^2) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.05  
 Ps (in Hg) = 29.92

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.633  
 Ts (F) = 111.3  
 Vs (fps) = 37.10

Stack Gas Flowrate, Qs  
 As (ft^2) = 50.27  
 Qs (acfm) = 111,894

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 102,032  
 Qstd (dscf/hr) = 6,121,920

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.244 An (ft^2) = 0.00032472  
 Time of Run (min) = 60  
 Vn (fps) = 37.37

% Isokinetic, %I  
 %I = 100.74  
 % Isokinetic measured from intermediate values  
 %I = 100.74

**PM FILTERABLE**

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 0.0034 0.0104  
 PMR (lb/hr) = 1.1518 3.5230 4.6748  
 Filterable Condensable Total

Grains per acf  
 gr/acf = 0.0012

**PM/PM10 FILTERABLE (AND + CONDENSIBLE)**

Grains per dscf  
 gr/dscf = 0.0013 0.0040 0.0053

Pollutant Mass Emission Rate, PMR  
 C (dry, corrected) (PPM) = 25.742 7.887 20.120  
 PMR (lb/hr) = 11.4511 5.7651 20.4773  
 PMR (lb/ton) = 0.0554 0.0279 0.0990  
 CO NOx SO2

	Delta P	Squ Δ P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.45	0.671		1.58	96	73	71
2	0.38	0.616		1.33	98	74	71
3	0.40	0.632		1.40	102	76	72
4	0.37	0.608		1.30	106	77	72
5	0.35	0.592		1.23	107	78	73
6	0.37	0.608		1.30	109	79	74
7	0.41	0.640		1.44	111	79	74
8	0.44	0.663		1.54	112	81	75
9	0.44	0.663		1.54	113	82	75
10	0.43	0.656		1.51	114	84	76
11	0.41	0.640		1.44	115	85	77
12	0.39	0.624		1.37	117	85	77
13	0.45	0.671		1.58	117	85	78
14	0.45	0.671		1.58	119	86	78
15	0.43	0.656		1.51	118	87	80
16	0.40	0.632		1.40	115	88	80
17	0.43	0.656		1.51	115	88	81
18	0.34	0.583		1.19	111	89	81
19	0.40	0.632		1.40	114	88	81
20	0.39	0.624		1.37	114	89	82
21	0.39	0.624		1.37	113	90	83
22	0.38	0.616		1.33	112	90	83
23	0.37	0.608	710.803	1.30	112	90	83
24	0.37	0.608	670.305	1.30	112	90	84

	Squ Δ P	Volume	Delta H	Stack T	Meter Temp
0.402	0.633	40.498	1.406	111.3	80.7

3.042

**Production Rate**

LMS tons	104
Caster tons	120
Total tons	224
Process Time (min)	65
Tons/hr	206.77

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/2003

Pollutant Gas Type: **SO2**  
 Instrument Span: 350  
 Upscale Calibration Gas: 149

## ANALYZER CALIBRATION DATA

Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
0.00	-0.95	0.95	0.27%	Pass
149.00	148.89	0.11	0.03%	Pass
309.00	309.21	0.21	0.06%	Pass

## SYSTEM CALIBRATION BIAS AND DRIFT DATA

Run # 1	Initial Values			Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	Drift (% of span)	Drift Error Check
Zero gas	2.07	0.86%	Pass	0.85	0.51%	Pass	0.35%	Pass
Upscale gas	144.59	1.23%	Pass	145.19	1.06%	Pass	0.17%	Pass

## EMISSION CALCULATION

Average Analyzer Gas Concentration (ppm)	6.250
Effluent Gas Concentration (corrected ppm)	4.976

Run # 1

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/21/2003

Pollutant Gas Type: **SO2**  
 Instrument Span: 350  
 Upscale Calibration Gas: 149

## ANALYZER CALIBRATION DATA

	Cylinder Gas Value (ppm)	Analyzer Calibration		Absolute		Difference (% of span)	Analyzer Calibration Error Check
		Response (ppm)	Difference (ppm)	Difference (ppm)	Difference (ppm)		
Zero gas	0.0	-2.15	2.15	2.15	0.61%	Pass	
Mid-range gas	149.0	147.07	1.93	1.93	0.55%	Pass	
High-range gas	309.0	308.01	0.99	0.99	0.28%	Pass	

## SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values				Final Values				
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Bias Error Check
<u>Run # 2</u>	-2.15	0.00%	Pass	-1.55	0.17%	Pass	142.77	0.17%	Pass
Zero gas	145.21	0.53%	Pass		1.23%	Pass		0.70%	Pass
Upscale gas									
<u>Run # 3</u>	-2.77	0.18%	Pass	-4.61	0.70%	Pass	139.11	0.53%	Pass
Zero gas	143.37	1.06%	Pass		2.27%	Pass		1.22%	Pass
Upscale gas									

## EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (corrected ppm)
Run # 2	2.950	4.904
Run # 3	15.880	20.120

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/2003

Pollutant Gas Type: **NOx**  
 Instrument Span: 80  
 Upscale Calibration Gas: 30.1

### ANALYZER CALIBRATION DATA

	Cylinder Gas Value (ppm)	Analyzer Calibration		Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration Error Check
		Response (ppm)	Difference (% of span)			
Zero gas	0.00	-0.01	0.01%	0.01	0.01%	Pass
Mid-range gas	30.10	30.13	0.04%	0.03	0.04%	Pass
High-range gas	64.20	64.34	0.18%	0.14	0.18%	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values		Final Values	
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Calibration Response (ppm)	System Calibration Bias (% of span)
<u>Run # 1</u>				
Zero gas	0.02	0.04%	0.02	0.04%
Upscale gas	30.51	0.48%	30.44	0.39%

	System Bias Error Check	System Bias Error Check	Drift Error Check	Drift Error Check
Zero gas	Pass	Pass	0.00%	Pass
Upscale gas	Pass	Pass	0.09%	Pass

### EMISSION CALCULATION

Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (corrected ppm)
0.95	0.919

Run # 1

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrlip
Date:	11/21/2003

**Pollutant Gas Type:** NOx  
**Instrument Span:** 80  
**Upscale Calibration Gas:** 30.1

### ANALYZER CALIBRATION DATA

	Cylinder Gas Value (ppm)	Analyzer Calibration		Absolute Difference (ppm)		Difference (% of span)	Analyzer Calibration Error Check
		Response (ppm)	Bias (% of span)	Difference (ppm)	Difference (% of span)		
Zero gas	0.00	0.02	0.00%	0.02	0.03%	Pass	
Mid-range gas	30.10	30.22	0.15%	0.12	0.15%	Pass	
High-range gas	64.20	64.04	0.20%	0.16	0.20%	Pass	

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	Initial Values		Final Values	
	System Calibration Response (ppm)	System Calibration Bias (% of span)	System Calibration Response (ppm)	System Calibration Bias (% of span)
<b>Run # 2</b>				
Zero gas	0.02	0.00%	0.02	0.00%
Upscale gas	30.01	0.26%	30.16	0.07%
<b>Run # 3</b>				
Zero gas	0.06	0.05%	0.00	0.03%
Upscale gas	29.98	0.30%	30.38	0.20%

### EMISSION CALCULATION

	Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (corrected ppm)
Run # 2	6.430	6.417
Run # 3	7.930	7.887

## ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/2003

Pollutant Gas Type: **CO**  
 Instrument Span: 350  
 Upscale Calibration Gas: 133

### ANALYZER CALIBRATION DATA

	Cylinder Gas Value (ppm)	Analyzer Calibration Response (ppm)	Absolute Difference (ppm)	Difference (% of span)	Analyzer Calibration	
					Error Check	Error Check
Zero gas	0.0	-0.71	0.71	0.20%	Pass	Pass
Low-range gas	133.0	131.81	1.19	0.34%	Pass	Pass
Mid-range gas	181.0	179.24	1.76	0.50%	Pass	Pass
High-range gas	316.0	316.00	0.00	0.00%	Pass	Pass

### SYSTEM CALIBRATION BIAS AND DRIFT DATA

	System Calibration Response (ppm)	System Calibration Bias (% of span)	Initial Values		Final Values	
			System Bias Error Check	System Calibration Response (ppm)	System Bias Error Check	System Calibration Bias (% of span)
Run # 1						
Zero gas	0.08	0.23%	Pass	0.39	Pass	0.09%
Upscale gas	131.44	0.11%	Pass	131.78	Pass	0.10%

### EMISSION CALCULATION

Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (corrected ppm)
18.15	18.137

Run # 1

# ANALYZER AND SYSTEM CALIBRATION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/21/2003

Pollutant Gas Type: **CO**  
 Instrument Span: 350  
 Upscale Calibration Gas: 133

## ANALYZER CALIBRATION DATA

Cylinder Gas Value (ppm)	Analyzer Calibration		Absolute		Difference (% of span)	Analyzer Calibration Error Check
	Response (ppm)	Difference (ppm)	Difference (ppm)	Difference (ppm)		
Zero gas	0.0	0.00	0.00	0.00	0.00%	Pass
Low-range gas	133.0	131.61	1.39	1.39	0.40%	Pass
Mid-range gas	181.0	180.20	0.80	0.80	0.23%	Pass
High-range gas	316.0	313.00	3.00	3.00	0.86%	Pass

## SYSTEM CALIBRATION BIAS AND DRIFT DATA

System Calibration Response (ppm)	Initial Values		Final Values		System Bias Error Check	System Calibration Response (ppm)	System Bias Error Check	Drift (% of span)	Drift Error Check
	System Calibration Bias (% of span)	System Calibration Bias (% of span)	System Calibration Bias (% of span)	System Calibration Bias (% of span)					
<u>Run #2</u>									
Zero gas	-0.28	0.08%	Pass	0.48	Pass	0.14%	Pass	0.22%	Pass
Upscale gas	131.09	0.15%	Pass	131.76	Pass	0.04%	Pass	0.19%	Pass
<u>Run #3</u>									
Zero gas	-0.16	0.05%	Pass	1.18	Pass	0.34%	Pass	0.38%	Pass
Upscale gas	131.31	0.09%	Pass	132.90	Pass	0.37%	Pass	0.45%	Pass

## EMISSION CALCULATION

Average Analyzer Gas Concentration (ppm)	Effluent Gas Concentration (corrected ppm)
Run #2	31.304
Run #3	25.742

**APPENDIX B**

---

**Lead Field Data Summaries**

## STACK EMISSION SUMMARY

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/20/03-11/21/03

	Run 1	Run 2	Run 3	Average
<b>Lead Concentration</b>				
Lead (gr/dscf)	0.000001	0.000001	0.000000	0.000000
Total Lead (lbs/hr)	0.0006	0.0005	0.0003	<b>0.0005</b>
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	125,926	118,177	115,974	120,026
DSCFM	116,887	109,941	106,072	110,966
<b>Avg. Stack Temp</b>	101.13	102.33	112.17	105.21
Stack Gas Velocity	41.754	39.184	38.454	39.797
<b>Avg. Velocity Head</b>	0.517	0.455	0.431	0.468
Avg. Sq. Rt of Delta P	0.719	0.675	0.656	0.683
<b>ISOKINETIC TESTING SUMMARY</b>				
Allowable isokinetic 90-110%	100.19	102.31	102.46	101.65
% Moisture of Stack Gas	1.39%	0.86%	0.83%	1.03%
Sample Volume	55.999	53.781	51.968	53.916

<b>Company:</b>	Nucor Steel
<b>Location:</b>	Crawfordsville, Indiana
<b>Source:</b>	Castrip
<b>Date:</b>	11/20/03
<b>Run Number:</b>	1 <span style="float: right;">Lead</span>

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 16.8  
 Vw (scf) = 0.79078

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 63.9  
 Vm (ft<sup>3</sup>) = 54.597  
 Pb (in Hg) = 29.95  
 delta H (in H2O) = 2.678  
 gamma = 1.01  
 Vm (dscf) = 56.00

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.39%  
 1-Bwo = 98.61%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.69

Area of Stack (enter diameter in inches), As  
 Depth = 0  
 Width = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 29.93

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.719  
 Ts (F) = 101.1  
 Vs (fps) = 41.75

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 125,926

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 116,887  
 Qstd (dscf/hr) = 7,013,233

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.271 An (ft<sup>2</sup>) = 0.0004006  
 Time of Run (min) = 60.00  
 Vn (fps) = 41.83

% Isokinetic, %I  
 %I = 100.19  
 % Isokinetic measured from intermediate values  
 %I = 100.19

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 2.10E-06  
 PMR (lb/hr) = 0.00058  
Lead

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 0.000001

**FIELD DATA**

K' Factor 5.1

Start Time 11:44  
 Stop Time 12:51

	Delta P	Squ D P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.42	0.648		2.14	91	60	60
2	0.53	0.728		2.70	92	61	60
3	0.48	0.693		2.45	96	62	60
4	0.48	0.693		2.45	99	62	60
5	0.53	0.728		2.70	99	63	61
6	0.53	0.728		2.70	100	63	61
7	0.50	0.707		2.55	101	62	61
8	0.48	0.693		2.45	102	63	62
9	0.53	0.728		2.70	102	64	62
10	0.53	0.728		2.70	102	65	62
11	0.52	0.721		2.65	102	65	62
12	0.47	0.686		2.40	102	66	63
13	0.47	0.686		2.40	103	66	63
14	0.43	0.656		2.19	104	66	64
15	0.45	0.671		2.30	105	67	64
16	0.45	0.671		2.30	105	67	64
17	0.45	0.671		2.30	105	67	64
18	0.45	0.671		2.30	105	67	64
19	0.48	0.693		2.45	104	67	64
20	0.50	0.707		2.55	104	67	65
21	0.46	0.678		2.35	104	67	65
22	0.46	0.678		2.35	104	67	65
23	1.00	1.000	332.558	5.10	99	68	65
24	1.00	1.000	277.961	5.10	97	68	65

	Squ D P	Volume	Delta H	Stack T	Meter Temp
0.625	0.719	54.597	2.678	101.1	63.9

Company:	Nucor Steel	
Location:	Crawfordsville, Indiana	
Source:	Castrip	
Date:	11/21/03	
Run Number:	2	Lead

**FIELD DATA**

K' Factor	5.1
-----------	-----

Start Time	8:50
Stop Time	9:55

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vc (mL) = 9.9  
 Vw (scf) = 0.46599

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 58.6  
 Vm (ft<sup>3</sup>) = 52  
 Pb (in Hg) = 29.92  
 delta H (in H2O) = 2.325  
 gamma = 1.01  
 Vm (dscf) = 53.78

Molsture Content of Stack Gas, Bwo  
 Bwo = 0.86%  
 1-Bwo = 99.14%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.74

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 29.80

Stack Gas Velocity, Vs  
 Cp = 0.84  
 sqrt(delta p) = 0.675  
 Ts (F) = 102.3  
 Vs (fps) = 39.18

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 118,177

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 109,941  
 Qstd (dscf/hr) = 6,596,436

Velocity at the Nozzle, Vn Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.271 An (ft<sup>2</sup>) = 0.000401  
 Time of Run (min) = 60  
 Vn (fps) = 40.09

% Isokinetic, %I  
 %I = 102.31  
 % Isokinetic measured from intermediate values  
 %I = 102.31

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 2.00E-06  
 PMR (lbs/hr) = 0.00054  
 Lead

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 0.000001

	Delta P	Squ D P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.46	0.678		2.35	87	54	53
2	0.50	0.707		2.55	88	54	53
3	0.53	0.728		2.70	88	56	53
4	0.48	0.693		2.45	90	57	53
5	0.43	0.656		2.19	93	57	54
6	0.41	0.640		2.09	93	58	54
7	0.47	0.686		2.40	98	58	54
8	0.47	0.686		2.40	101	59	55
9	0.43	0.658		2.19	102	59	65
10	0.43	0.658		2.19	104	60	55
11	0.40	0.632		2.04	106	60	55
12	0.40	0.632		2.04	107	60	56
13	0.45	0.671		2.30	108	60	56
14	0.43	0.656		2.19	110	61	57
15	0.48	0.693		2.45	111	61	57
16	0.45	0.671		2.30	110	62	57
17	0.40	0.632		2.04	110	63	58
18	0.40	0.632		2.04	108	63	58
19	0.47	0.686		2.40	104	63	59
20	0.50	0.707		2.55	110	65	60
21	0.51	0.714		2.60	109	65	60
22	0.50	0.707		2.55	108	66	61
23	0.47	0.686	384.91	2.40	107	67	61
24	0.47	0.686	332.91	2.40	106	67	62

0.456	Squ D P	Volume	Delta H	Stack T	Meter Temp
	0.675	52.00	2.325	102.3	58.6

Company:	Nucor Steel
Location:	Crawfordsville, Indiana
Source:	Castrip
Date:	11/21/03
Run Number:	3                      Lead

**FIELD DATA**

K Factor	5
----------	---

Start Time	16:32
Stop Time	17:39

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 20.9  
 Md (g/gmol) = 28.836

Volume of Water Vapor Collected @ STD. COND., Vw  
 Vlc (mL) = 9.2  
 Vw (scf) = 0.43304

Volume of Dry Gas Collected @ STD. COND., Vm  
 Tm (F) = 65.4  
 Vm (ft<sup>3</sup>) = 50.93  
 Pb (in Hg) = 29.92  
 delta H (in H2O) = 2.156  
 gamma = 1.01  
 Vm (dscf) = 51.97

Moisture Content of Stack Gas, Bwo  
 Bwo = 0.83%  
 1-Bwo = 99.17%

Molecular Weight of Stack Gas, Ms  
 Ms (g/gmol) = 28.75

Area of Stack (enter diameter in inches), As  
 L = 0  
 W = 0  
 diameter (in) = 96  
 No. of Stacks = 1  
 As(L\*W) (ft<sup>2</sup>) = 0.000  
 As(dia.) (ft<sup>2</sup>) = 50.3

Absolute Pressure, Ps  
 Static (in H2O) = -0.25  
 Ps (in Hg) = 29.90

Stack Gas Velocity, Vs  
 Cp = 0.64  
 sqr(delta p) = 0.656  
 Ts (F) = 112.2  
 Vs (fps) = 38.45

Stack Gas Flowrate, Qs  
 As (ft<sup>2</sup>) = 50.27  
 Qs (acfm) = 115,974

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd  
 Qstd (dscf/m) = 108,072  
 Qstd (dscf/hr) = 6,364,295

Velocity at the Nozzle, Vn                      Area of Nozzle, An  
 Dia. of Nozzle (in) = 0.271                      An (ft<sup>2</sup>) = 0.000401  
 Time of Run (min) = 60  
 Vn (fps) = 39.40

% Isokinetic, %I  
 %I = 102.46  
 % Isokinetic measured from intermediate values  
 %I = 102.46

Pollutant Mass Emission Rate, PMR  
 Mn (g) = 1.10E-06  
 PMR (lbs/hr) = 0.00030  
                     Lead

Grains per acf  
 gr/acf = 0.0000

Grains per dscf  
 gr/dscf = 0.000000

	Delta P	Squ D P	Volume	Delta H	Stack T	DGM Inlet	DGM Outlet
1	0.48	0.693		2.40	98	65	63
2	0.45	0.671		2.25	98	64	63
3	0.48	0.693		2.40	102	64	63
4	0.45	0.671		2.25	105	65	63
5	0.42	0.648		2.10	107	65	63
6	0.43	0.656		2.15	108	65	63
7	0.42	0.648		2.10	109	65	63
8	0.43	0.656		2.15	114	66	63
9	0.43	0.656		2.15	114	66	63
10	0.40	0.632		2.00	116	67	64
11	0.40	0.632		2.00	117	67	64
12	0.39	0.624		1.95	119	67	64
13	0.48	0.693		2.40	118	67	64
14	0.48	0.693		2.40	120	68	64
15	0.40	0.632		2.00	119	68	64
16	0.40	0.632		2.00	118	68	65
17	0.45	0.671		2.25	116	68	65
18	0.40	0.632		2.00	115	69	65
19	0.40	0.632		2.00	113	67	65
20	0.40	0.632		2.00	115	68	65
21	0.45	0.671		2.25	114	68	65
22	0.43	0.656		2.15	114	68	65
23	0.43	0.656	482.54	2.15	113	69	65
24	0.45	0.671	431.61	2.25	112	69	65

	0.431	0.656	50.93	2.156	112.2		Meter Temp 65.4
--	-------	-------	-------	-------	-------	--	--------------------

**APPENDIX C**

---

**Particulate Field Data**

# VELOCITY TRAVERSE POINT DETERMINATION

(EPA Method 1)

Company:	Nucor Steel
Date:	11/20/03-11/21/03
Source:	Castrip
Location:	Crawfordsville, Indiana

Circular Stack  
Traverse Points on Diameter  
Stack Diameter (inches)

	4	6	8	10	12
<b>96</b>					
<b>Point 1</b>	6.43	4.22	3.07	2.50	<b>2.02</b>
<b>2</b>	24.00	14.02	10.08	7.87	<b>6.43</b>
<b>3</b>	72.00	28.42	18.62	14.02	<b>11.33</b>
<b>4</b>	89.57	67.58	31.01	21.70	<b>16.99</b>
<b>5</b>		81.98	64.99	32.83	<b>24.00</b>
<b>6</b>		91.78	77.38	63.17	<b>34.18</b>
<b>7</b>			85.92	74.30	<b>61.82</b>
<b>8</b>			92.93	81.98	<b>72.00</b>
<b>9</b>				88.13	<b>79.01</b>
<b>10</b>				93.50	<b>84.67</b>
<b>11</b>					<b>89.57</b>
<b>12</b>					<b>93.98</b>

**AIR TESTS - PROFESSIONALS FIELD DATA SHEET**

PM/PM<sub>10</sub> TESTING

EPA METHOD 1-5/202/9

RUN 1


PAGE \_\_\_ OF \_\_\_

CLIENT: Nucor Steel  
 LOCATION: Crawfordsville IN  
 UNIT: Casting  
 DATE: 11-20-03 PROJECT#: Andrew Young  
 METER OPERATOR: Conker Brown  
 PROBE OPERATOR: Conker Brown  
 VISIBLE EMISSIONS READER: Ron Stapert  
 CLIENT CONTACT: Dave Silca/Mark Washler  
 AGENCY CONTACT: Steve Friend

METER BOX ID: A2 K FACTOR: 3.0 DUCT DIMENSIONS (in.): 96"  
 METER AH@: 1.83 PORT LENGTH (in.): 6"  
 PROBE LINEAR: Glass FILTER ID: R SILICA ID: #5  
 NOZZLE ID: 0.244 TEDLAR BAG ID:   
 AMBIENT TEMP (°F): 50 PITOT CHECK: PASS FAIL: □  
 BAROMETRIC: 29.95 @ (in. Hg): 0.000 H<sub>2</sub>O (ml): 0.0  
 STATIC PRESSURE (in. H<sub>2</sub>O): 0.004 @ (in. Hg): 0.004 SILICA GEL (g): 13.6  
 LEAK RATE BEFORE (cfm): 1144 STOP TIME: 1254 TOTAL Vc: 13.6  
 LEAK RATE AFTER (cfm): 0.004 @ (in. Hg): 0.004

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔPs (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.43	1.55	546.105	90	250	250	61	71	71	4	
2	5	0.43	1.55	549.6	91	251	251	58	71	71	4	
3	7.5	0.45	1.62	551.5	93	250	249	58	73	71	4	
4	10	0.42	1.51	553.1	98	249	250	58	73	71	4	
5	12.5	0.41	1.48	554.8	99	250	249	57	75	71	4	
6	15	0.40	1.44	556.55	99	250	248	57	74	71	4	
1	17.5	0.46	1.66	558.4	101	250	252	54	75	72	4	
2	20	0.51	1.84	560.3	101	250	247	54	76	73	4	
3	22.5	0.50	1.80	562.3	101	250	251	56	79	73	4.5	
4	25	0.50	1.80	564.2	101	250	252	57	79	74	4.5	
5	27.5	0.46	1.66	566.0	101	250	254	57	81	74	4	
6	30	0.49	1.76	567.80	101	250	256	59	83	75	4	
1	32.5	0.46	1.66	569.6	103	250	252	58	82	76	4	
2	35	0.46	1.66	571.4	103	250	250	58	82	76	4	
3	37.5	0.47	1.69	573.3	103	250	250	59	84	77	4	
4	40	0.47	1.69	575.2	102	250	250	60	84	77	4	
5	42.5	0.45	1.62	577.1	101	250	253	60	86	78	4	
6	45	0.41	1.48	578.74	100	250	254	61	87	78	4	
1	47.5	0.44	1.58	580.6	103	247	243	61	86	79	4	
2	50	0.39	1.40	582.3	102	248	252	61	86	79	4	
3	52.5	0.42	1.51	584.0	101	249	251	61	88	80	4	
4	55	1.05	3.78	586.4	99	250	252	61	88	81	7	
5	57.5	1.08	3.89	589.0	96	250	254	62	91	82	9	
6	60	0.97	3.49	591.945	96	251	249	64	92	83	7	

pH 6.0



**AIR TESTS - PROFESSIONALS FIELD DATA SHEET**

PM/PM<sub>10</sub> TESTING


EPA METHOD 5/502/9

RUN 2

PAGE 2 OF

CLIENT	Nucor Steel	METER BOX ID	A2	K FACTOR	3.6	DUCT DIMENSIONS (in.)	96"
LOCATION	Clarksburgville IN	METER Y	1.004	METER AH@	1.83	PORT LENGTH (in.)	6"
UNIT	Castrip	PITOT Gp	0.84	PROBE LINER	Glass	FILTER ID	R2
DATE	11-21-03	PROJECT #		NOZZLE ID	0.244"	TEDLAR BAG ID	
METER OPERATOR	Andrew Young	BAROMETRIC	29.92	AMBIENT TEMP (°F)	50	PITOT CHECK	O <sub>2</sub> 20.9
PROBE OPERATOR	Carlos Brown	STATIC PRESSURE (in. H <sub>2</sub> O)			-0.03	FAIL	CO <sub>2</sub> 0.10
VISIBLE EMISSIONS READER	Ron Stappert	LEAK RATE BEFORE (cfm)	0.000	@ (in. Hg)			
CLIENT CONTACT	Dave Sdc / Mark Washer	LEAK RATE AFTER (cfm)	0.001	@ (in. Hg)			
AGENCY CONTACT	Steve Friend	START TIME	0849	STOP TIME	0954	TOTAL Vc	9.6

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Set Points		Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
							Probe Tp (°F)	Filter Tt (°F)						
1	2.5	0.43	1.62	592.3	86	251	250	250	248	50	68	67	4	pH = 5.5
2	5	0.44	1.58	595.9	87	251	250	250	252	47	68	67	4	
3	7.5	0.43	1.55	597.7	87	250	250	250	247	49	68	67	4	
4	10	0.41	1.48	599.6	90	250	250	250	250	49	69	67	4	
5	12.5	0.41	1.48	601.1	93	250	250	250	250	50	71	67	4	
6	15	0.38	1.37	602.75	94	250	250	250	250	51	71	67	4	
1	17.5	0.47	1.69	604.5	95	252	250	255	255	50	71	68	4	
2	20	0.47	1.69	606.4	98	253	253	253	253	50	72	68	4	
3	22.5	0.43	1.55	608.0	99	252	250	251	251	51	73	69	4	
4	25	0.40	1.44	609.9	101	251	250	250	250	52	73	69	4	
5	27.5	0.40	1.44	611.5	103	250	250	249	249	52	74	69	4	
6	30	0.38	1.37	613.21	104	249	249	249	249	53	74	69	4	
1	32.5	0.45	1.62	615.0	108	249	247	247	247	52	76	69	4	
2	35	0.46	1.66	616.8	108	248	250	250	250	53	77	71	4	
3	37.5	0.49	1.76	618.7	109	249	254	254	254	54	78	71	4	
4	40	0.47	1.69	620.5	109	250	250	250	250	55	79	72	4	
5	42.5	0.49	1.76	622.4	108	250	249	249	249	55	79	72	4	
6	45	0.48	1.73	624.22	108	250	250	248	248	56	80	73	4	
1	47.5	0.47	1.69	626.0	108	250	250	249	249	55	80	73	4	
2	50	0.45	1.62	627.9	108	250	250	249	249	55	81	74	4	
3	52.5	0.45	1.62	630.1	108	251	250	250	250	56	82	75	4	
4	55	0.45	1.62	631.5	107	250	250	251	251	57	83	76	4	
5	57.5	0.44	1.58	633.2	107	250	249	249	249	58	84	76	4	
6	60	0.37	1.33	634.878	107	250	252	252	252	58	84	76	4	



**AIR TEST PROFESSIONALS FIELD DATA SHEET**

PM/PM<sub>10</sub> TESTING

EPA METHOD 5/200/9

PAGE 3 OF 3

RUN 3

CLIENT	Nucor Steel	METER BOX ID	A2	K FACTOR	3.5	DUCT DIMENSIONS (in.)	96"
LOCATION	Crawfordsville IN	METER	1.004	METER ΔH@	1.83	PORT LENGTH (in.)	6"
UNIT	Castrip	PITOT Cp	0.84	PROBE LINER	6155	FILTER ID	SILICA ID 7
DATE	11-21-03	PROJECT #		NOZZLE ID	0.244"	PITOT CHECK	
METER OPERATOR	A Young	BAROMETRIC	29.92	AMBIENT TEMP (°F)	60	PASS	<input checked="" type="checkbox"/> FAIL <input type="checkbox"/>
PROBE OPERATOR	C. S. Smith	STATIC PRESSURE (in. H <sub>2</sub> O)			-0.05	H <sub>2</sub> O (mL)	0.0
VISIBLE EMISSIONS READER	R. Stanger	LEAK RATE BEFORE (cmh)	0.00	@ (in. Hg)	0	SILICA GEL (g)	0.0
AGENCY CONTACT	D. S. J. / M. Washer	LEAK RATE AFTER (cmh)	0.00	@ (in. Hg)	0	TOTAL Vc	11.3
	S. Friend	START TIME	1633	STOP TIME	1738		

Traverse Point Number	MiniPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tip (°F)	Filter		Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
							TI (°F)	Set Points					
1	2.5	0.45	1.58	670.305	96	250	250	250	63	73	71	4	
2	5	0.38	1.33	672.2	98	251	250	250	63	74	71	4	
3	7.5	0.40	1.40	673.8	102	251	250	250	62	76	72	4	
4	10	0.37	1.30	675.4	106	251	250	250	61	77	72	4	
5	12.5	0.35	1.23	677.0	107	250	251	250	62	78	73	4	
6	15	0.37	1.30	678.6	109	249	250	250	63	79	74	4	
1	17.5	0.41	1.44	680.22	111	252	254	250	63	79	74	4	
2	20	0.44	1.54	682.0	112	252	251	250	63	81	75	4	
3	22.5	0.44	1.54	683.6	113	251	251	250	63	82	75	4	
4	25	0.43	1.51	685.4	114	251	251	250	64	84	76	4	
5	27.5	0.41	1.44	687.2	115	250	250	250	64	85	77	4	
6	30	0.39	1.37	688.9	117	250	249	250	64	85	77	4	
1	32.5	0.45	1.58	690.52	117	249	251	250	64	85	78	4	
2	35	0.45	1.58	692.2	119	249	250	250	64	86	78	4	
3	37.5	0.43	1.51	694.3	118	250	249	250	65	87	80	4	
4	40	0.40	1.40	696.0	115	251	250	250	65	88	80	4	
5	42.5	0.43	1.51	697.6	115	250	250	250	65	88	81	4	
6	45	0.34	1.19	699.4	111	250	249	250	65	89	81	3.5	
1	47.5	0.40	1.40	700.91	114	250	249	250	65	89	81	4	
2	50	0.39	1.37	702.6	114	250	250	250	65	88	81	4	
3	52.5	0.39	1.37	704.2	114	250	250	250	65	89	82	4	
4	55	0.38	1.33	705.9	113	250	248	250	65	90	83	4	
5	57.5	0.37	1.30	707.6	112	251	249	250	65	90	83	4	
6	60	0.37	1.30	709.0	112	250	250	250	66	90	83	4	
				710.803	112	250	250	250	66	90	84	4	

pH = 5.5



ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: Castrip
Date: 11/20/03 - 11/21/03

CO NOx SO2
07:03:41 11/20/03
-001.41 PPM
000.00
309.21
309.502

\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:05:42 11/20/03
1 Voltage overrange 3/6
3 -000.01 zero NOx
5 -000.95 zero SO2

\*\*\* ON (RUNNING) \*\*\*

07:06:42 11/20/03
1 -000.71 PPM zero CO
3 -000.02
5 -000.33

\*\*\* ON (RUNNING) \*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:07:27 11/20/03
1 -000.68 PPM
3 000.00
5 140.89 149 SO2

\*\*\*\*\* RUN \*\*\*\*\*

07:11:34 11/20/03
1 131.01 PPM 133 CO
3 -000.01
5 -000.95

\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:13:42 11/20/03
1 179.24 PPM 181 CO
3 -000.01
5 -000.95

\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:15:04 11/20/03
1 000.33 PPM
3 064.34 64.2 NOx
5 -000.95

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:17:12 11/20/03
1 -001.15 PPM
3 000.13 30.1 NOx
5 -000.95

\*\*\*\*\* RUN \*\*\*\*\*

11:13:30 11/20/03
1 000.00 PPM zero
3 000.02 zero
5 144.59 149 SO2

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

11:15:20 11/20/03
1 131.44 PPM 133 CO
3 000.00
5 000.79

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

11:18:32 11/20/03
1 000.33 PPM
3 030.51 30.1 NOx
5 002.07 zero SO2

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN (1) \*\*\*\*\*

11:44:22 11/20/03
1 004.77 PPM
3 000.25
5 000.31

11:45:22 11/20/03
1 005.17 PPM
3 000.67
5 002.67

11:46:22 11/20/03
1 007.24 PPM
3 001.22
5 007.57

11:47:22 11/20/03
1 015.20 PPM
3 000.21
5 019.83

11:48:22 11/20/03
1 021.00 PPM
3 008.53
5 034.49

11:49:22 11/20/03
1 015.97 PPM
3 010.36
5 054.07

11:50:22 11/20/03
1 014.69 PPM
3 013.23
5 084.03

11:51:22 11/20/03
1 017.17 PPM
3 001.49
5 036.35

11:52:22 11/20/03
1 017.77 PPM
3 000.44
5 011.23

11:53:22 11/20/03
1 017.77 PPM
3 000.50
5 012.61

11:54:22 11/20/03
1 017.77 PPM
3 000.30
5 005.71

11:55:22 11/20/03
1 017.61 PPM
3 000.35
5 005.13

11:56:22 11/20/03
1 017.40 PPM
3 000.29
5 003.27

11:57:22 11/20/03
1 017.18 PPM
3 000.26
5 002.67

11:58:22 11/20/03
1 017.18 PPM
3 000.29
5 002.07

11:59:22 11/20/03
1 015.32 PPM
3 000.28
5 001.45

12:00:22 11/20/03
1 015.40 PPM
3 000.26
5 001.45

12:01:22 11/20/03
1 015.41 PPM
3 000.22
5 001.47

# ANALYZER FIELD DATA

**Company:** Nucor Steel  
**Location:** Crawfordsville, Indiana  
**Source:** Castrip  
**Date:** 11/20/03 - 11/21/03

12:02:22 11/20/03  
 1 015.42 PPM  
 3 000.20  
 5 001.45

12:03:22 11/20/03  
 1 015.42 PPM  
 3 000.33  
 5 002.05

12:04:22 11/20/03  
 1 015.59 PPM  
 3 000.20  
 5 002.07

12:05:22 11/20/03  
 1 017.33 PPM  
 3 000.25  
 5 001.47

12:06:22 11/20/03  
 1 017.62 PPM  
 3 000.22  
 5 000.85

12:07:22 11/20/03  
 1 017.63 PPM  
 3 000.21  
 5 000.85

12:08:22 11/20/03  
 1 017.00 PPM  
 3 000.22  
 5 000.85

12:09:22 11/20/03  
 1 017.93 PPM  
 3 000.20  
 5 000.85

12:10:22 11/20/03  
 1 018.19 PPM  
 3 000.20  
 5 000.85

12:11:22 11/20/03  
 1 019.77 PPM  
 3 000.19  
 5 000.85

12:12:22 11/20/03  
 1 019.99 PPM  
 3 000.19  
 5 000.85

12:13:22 11/20/03  
 1 020.27 PPM  
 3 000.18  
 5 000.85

12:14:22 11/20/03  
 1 020.40 PPM  
 3 000.19  
 5 000.85

12:15:22 11/20/03  
 1 020.40 PPM  
 3 000.19  
 5 000.85

12:16:22 11/20/03  
 1 020.75 PPM  
 3 000.20  
 5 000.85

12:17:22 11/20/03  
 1 021.20 PPM  
 3 000.18  
 5 000.85

12:18:22 11/20/03  
 1 021.29 PPM  
 3 000.16  
 5 000.85

12:19:22 11/20/03  
 1 021.34 PPM  
 3 000.17  
 5 000.85

12:20:22 11/20/03  
 1 017.94 PPM  
 3 001.40  
 5 019.23

12:21:22 11/20/03  
 1 016.67 PPM  
 3 004.04  
 5 021.65

12:22:22 11/20/03  
 1 015.73 PPM  
 3 008.09  
 5 032.65

12:23:22 11/20/03  
 1 019.74 PPM  
 3 000.40  
 5 010.03

12:24:22 11/20/03  
 1 019.79 PPM  
 3 000.20  
 5 003.89

12:25:22 11/20/03  
 1 019.81 PPM  
 3 000.17  
 5 002.69

12:26:22 11/20/03  
 1 019.81 PPM  
 3 000.16  
 5 002.07

12:27:22 11/20/03  
 1 019.80 PPM  
 3 000.14  
 5 001.47

12:28:22 11/20/03  
 1 022.65 PPM  
 3 000.16  
 5 003.27

12:29:22 11/20/03  
 1 022.54 PPM  
 3 000.17  
 5 001.47

12:30:22 11/20/03  
 1 022.60 PPM  
 3 000.17  
 5 004.51

12:31:22 11/20/03  
 1 022.61 PPM  
 3 000.16  
 5 004.51

12:32:22 11/20/03  
 1 022.13 PPM  
 3 000.19  
 5 002.69

12:33:22 11/20/03  
 1 022.13 PPM  
 3 000.15  
 5 001.45

12:34:22 11/20/03  
 1 022.13 PPM  
 3 000.29  
 5 002.07

12:35:22 11/20/03  
 1 022.26 PPM  
 3 000.24  
 5 002.69

12:36:22 11/20/03  
 1 022.51 PPM  
 3 000.17  
 5 002.07

12:37:22 11/20/03  
 1 024.13 PPM  
 3 000.15  
 5 001.47

12:38:22 11/20/03  
 1 024.56 PPM  
 3 000.14  
 5 001.47

12:39:22 11/20/03  
 1 024.57 PPM  
 3 000.14  
 5 001.47

12:40:22 11/20/03  
 1 024.57 PPM  
 3 000.14  
 5 000.85

12:41:22 11/20/03  
 1 024.45 PPM  
 3 000.13  
 5 000.85

12:42:22 11/20/03  
 1 025.04 PPM  
 3 000.13  
 5 000.85

12:43:22 11/20/03  
 1 022.94 PPM  
 3 000.14  
 5 001.47

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: Castrip
Date: 11/20/03 - 11/21/03

12:44:22 11/20/03
1 022.48 PPM
3 000.14
5 000.85

12:45:22 11/20/03
1 020.56 PPM
3 000.20
5 000.85

12:46:22 11/20/03
1 016.01 PPM
3 000.26
5 000.85

12:47:22 11/20/03
1 013.57 PPM
3 000.25
5 000.85

12:48:22 11/20/03
1 012.64 PPM
3 000.24
5 000.85

12:49:22 11/20/03
1 012.25 PPM
3 000.20
5 000.85

12:50:22 11/20/03
1 012.25 PPM
3 000.20
5 000.85

12:51:22 11/20/03
1 012.25 PPM
3 000.19
5 000.85

12:52:22 11/20/03
1 012.25 PPM
3 000.16
5 000.85

12:53:22 11/20/03
1 012.25 PPM
3 000.19
5 000.85

12:54:22 11/20/03
1 012.25 PPM
3 000.17
5 000.85

\*\*\*\*\* STOP \*\*\*\*\*
Run statistics N=00071
Min Avg Max
1 004.77 010.15 025.04
3 000.13 000.95 013.23
5 000.31 006.25 004.03

12:59:07 11/20/03
1 -001.10 PPM
3 030.44
5 000.85

\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

13:00:23 11/20/03
1 131.70 PPM
3 000.02
5 000.85

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

13:02:56 11/20/03
1 000.39 PPM
3 000.14
5 145.19

\*\*\*\*\* OFF \*\*\*\*\*

11/21/03 Initial calcs

\*\*\*\*\* RUN \*\*\*\*\*

07:14:30 11/21/03
CO 1 -001.97 PPM
NOx 3 000.02
SO2 5 308.01

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:16:00 11/21/03
1 Voltage overrange
3 -000.01
5 -002.15

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:17:27 11/21/03
1 000.00 PPM
3 000.00
5 147.07

07:19:06 11/21/03
1 100.20 PPM
3 -000.01
5 -002.15

07:20:10 11/21/03
1 000.36 PPM
3 064.04
5 -002.15

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:22:00 11/21/03
1 131.61 PPM
3 000.00
5 -002.17

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:22:50 11/21/03
1 000.09 PPM
3 030.22
5 -002.15

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:26:06 11/21/03
1 -000.28 PPM
3 030.01
5 -002.15

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:27:34 11/21/03
1 131.09 PPM
3 000.02
5 -002.15

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

07:32:00 11/21/03
1 -000.56 PPM
3 000.02
5 145.21

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: Castrip
Date: 11/20/03 - 11/21/03

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN (2) \*\*\*\*\*

08:50:55 11/21/03
1 014.66 PPM
3 000.24
5 -005.85

08:51:55 11/21/03
1 014.62 PPM
3 000.32
5 -005.85

08:52:55 11/21/03
1 014.75 PPM
3 000.28
5 -005.85

08:53:55 11/21/03
1 014.80 PPM
3 000.29
5 -005.85

08:54:55 11/21/03
1 014.80 PPM
3 000.62
5 -005.21

08:55:55 11/21/03
1 014.79 PPM
3 003.70
5 -000.95

08:56:55 11/21/03
1 014.32 PPM
3 006.35
5 008.17

08:57:55 11/21/03
1 014.31 PPM
3 006.61
5 008.17

08:58:55 11/21/03
1 014.31 PPM
3 007.24
5 011.25

08:59:55 11/21/03
1 014.30 PPM
3 006.98
5 011.85

09:00:55 11/21/03
1 014.77 PPM
3 006.89
5 008.19

09:01:55 11/21/03
1 015.32 PPM
3 007.20
5 008.79

09:02:55 11/21/03
1 016.09 PPM
3 008.17
5 009.43

09:03:55 11/21/03
1 022.35 PPM
3 000.94
5 002.71

09:04:55 11/21/03
1 022.83 PPM
3 000.62
5 -000.95

09:05:55 11/21/03
1 023.12 PPM
3 002.62
5 001.45

09:06:55 11/21/03
1 021.79 PPM
3 004.89
5 006.95

09:07:55 11/21/03
1 021.49 PPM
3 007.10
5 006.97

09:08:55 11/21/03
1 021.38 PPM
3 013.65
5 017.37

09:09:55 11/21/03
1 022.24 PPM
3 017.10
5 011.23

09:10:55 11/21/03
1 022.58 PPM
3 018.03
5 013.07

09:11:55 11/21/03
1 023.18 PPM
3 019.20
5 013.07

09:12:55 11/21/03
1 023.90 PPM
3 020.29
5 013.07

09:13:55 11/21/03
1 023.90 PPM
3 021.36
5 013.69

09:14:55 11/21/03
1 024.83 PPM
3 021.50
5 014.31

09:15:55 11/21/03
1 025.00 PPM
3 021.62
5 016.77

09:16:55 11/21/03
1 025.51 PPM
3 023.14

09:17:55 11/21/03
1 026.40 PPM
3 022.09
5 011.25

09:18:55 11/21/03
1 028.07 PPM
3 022.39
5 010.63

09:19:55 11/21/03
1 029.74 PPM
3 025.21
5 008.79

09:20:55 11/21/03
1 036.13 PPM
3 009.41
5 006.33

09:21:55 11/21/03
1 039.96 PPM
3 000.82
5 000.29

09:22:55 11/21/03
1 039.29 PPM
3 004.04
5 000.29

09:23:55 11/21/03
1 034.22 PPM
3 017.18
5 002.07

09:24:55 11/21/03
1 032.92 PPM
3 023.75
5 004.51

09:25:55 11/21/03
1 032.69 PPM
3 028.78
5 005.13

09:26:55 11/21/03
1 040.63 PPM
3 004.03
5 003.91

09:27:55 11/21/03
1 043.17 PPM
3 001.00
5 000.31

09:28:55 11/21/03
1 043.30 PPM
3 000.34
5 -002.15

09:29:55 11/21/03
1 043.30 PPM
3 000.23
5 -003.41

09:30:55 11/21/03
1 045.10 PPM
3 000.23
5 -002.77

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: Castrip
Date: 11/20/03 - 11/21/03

09:31:55 11/21/03
1 244.89 PPM
3 000.41
5 -002.77

09:32:55 11/21/03
1 050.79 PPM
3 000.74
5 -002.77

09:33:55 11/21/03
1 043.91 PPM
3 000.26
5 -001.55

09:34:55 11/21/03
1 042.02 PPM
3 000.18
5 -002.15

09:35:55 11/21/03
1 042.92 PPM
3 000.15
5 -001.55

09:36:55 11/21/03
1 042.50 PPM
3 000.13
5 -000.95

09:37:55 11/21/03
1 043.61 PPM
3 000.12
5 -000.95

09:38:55 11/21/03
1 043.62 PPM
3 000.11
5 -001.57

09:39:55 11/21/03
1 043.62 PPM
3 000.11
5 -000.95

09:40:55 11/21/03
1 043.61 PPM
3 000.11
5 -000.95

09:41:55 11/21/03
1 043.61 PPM
3 000.10
5 -000.33

09:42:55 11/21/03
1 043.87 PPM
3 000.10
5 -000.33

09:43:55 11/21/03
1 043.87 PPM
3 000.10
5 -000.33

09:44:55 11/21/03
1 033.98 PPM
3 000.34
5 -001.55

09:45:55 11/21/03
1 032.32 PPM
3 000.93
5 -001.55

09:46:55 11/21/03
1 036.19 PPM
3 000.38
5 -000.95

09:47:55 11/21/03
1 036.92 PPM
3 000.24
5 -000.95

09:48:55 11/21/03
1 038.07 PPM
3 000.14
5 -002.15

09:49:55 11/21/03
1 038.71 PPM
3 000.10
5 -002.77

09:50:55 11/21/03
1 039.31 PPM
3 000.16
5 -002.77

09:51:55 11/21/03
1 039.56 PPM
3 000.08
5 -002.77

09:52:55 11/21/03
1 046.71 PPM
3 000.08
5 -003.39

09:53:55 11/21/03
1 038.98 PPM
3 000.07
5 -003.39

\*\*\* ON (RUNNING) \*\*\*
\*\*\*\*\* STOP \*\*\*\*\*
09:54:48 11/21/03
Run statistics N=00064
Min Avg Max
1 014.30 031.01 050.79
3 000.07 006.43 028.78
5 -005.85 002.95 017.37

09:57:31 11/21/03
1 000.48 PPM zero
3 000.02 zero
5 142.77 149

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

09:58:42 11/21/03
1 131.76 PPM 133
3 000.00
5 006.97

\*\*\*\*\* RUN \*\*\*\*\*

10:01:14 11/21/03
1 000.49 PPM
3 030.16 30.1
5 -001.55 zero

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* RUN \*\*\*\*\*

14:59:07 11/21/03
1 -000.16 PPM
3 029.98 30.1 NOx
5 -002.77

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*

15:01:09 11/21/03
1 131.31 PPM 133 CO
3 000.06 zero NOx
5 -002.77 zero SO2

\*\*\*\*\* RUN \*\*\*\*\*

15:05:02 11/21/03
1 000.18 PPM
3 000.07
5 143.37 149 SO2

\*\*\*\*\* OFF \*\*\*\*\*

\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN (3) \*\*\*\*\*

16:33:46 11/21/03
CO 1 012.28 PPM
NOx 3 000.07
SO2 5 -001.55

16:34:46 11/21/03
1 012.76 PPM
3 000.14
5 -001.55

ANALYZER FIELD DATA

Company: Nucor Steel  
 Location: Crawfordsville, Indiana  
 Source: Castrip  
 Date: 11/20/03 - 11/21/03

Time	1	3	5	Time	1	3	5
16:35:46 11/21/03	010.30 PPM	047.11	035.09	16:48:46 11/21/03	005.91 PPM	022.63	039.39
16:36:46 11/21/03	007.97 PPM	021.43	045.49	16:49:46 11/21/03	006.25 PPM	022.10	058.97
16:37:46 11/21/03	007.81 PPM	007.55	024.71	16:50:46 11/21/03	009.19 PPM	009.90	058.99
16:38:46 11/21/03	007.51 PPM	005.51	049.19	16:51:46 11/21/03	015.15 PPM	002.22	035.09
16:39:46 11/21/03	007.52 PPM	004.27	051.63	16:52:46 11/21/03	017.32 PPM	000.37	008.79
16:40:46 11/21/03	007.01 PPM	007.81	051.01	16:53:46 11/21/03	017.80 PPM	001.99	002.69
16:41:46 11/21/03	005.87 PPM	018.45	039.99	16:54:46 11/21/03	012.66 PPM	007.21	021.03
16:42:46 11/21/03	005.74 PPM	020.99	055.29	16:55:46 11/21/03	011.38 PPM	015.63	020.43
16:43:46 11/21/03	005.74 PPM	021.89	065.69	16:56:46 11/21/03	011.38 PPM	021.70	035.11
16:44:46 11/21/03	005.74 PPM	019.83	068.15	16:57:46 11/21/03	011.37 PPM	021.04	048.57
16:45:46 11/21/03	005.74 PPM	014.98	047.33	16:58:46 11/21/03	019.23 PPM	020.89	047.33
16:46:46 11/21/03	005.75 PPM	015.66	038.19	16:59:46 11/21/03	027.10 PPM	017.74	043.69
16:47:46 11/21/03	005.75 PPM	021.35	033.89	17:00:46 11/21/03	029.45 PPM	020.05	043.05
				17:01:46 11/21/03	031.87 PPM	020.71	038.01
				17:02:46 11/21/03	033.20 PPM	020.71	041.23
				17:03:46 11/21/03	038.65 PPM	012.46	038.81
				17:04:46 11/21/03	046.66 PPM	000.41	007.57
				17:05:46 11/21/03	048.64 PPM	000.29	000.87
				17:06:46 11/21/03	042.43 PPM	003.06	000.85
				17:07:46 11/21/03	038.98 PPM	003.33	003.29
				17:08:46 11/21/03	043.64 PPM	000.42	000.85
				17:09:46 11/21/03	044.63 PPM	000.22	-000.95
				17:10:46 11/21/03	037.77 PPM	000.17	-002.15
				17:11:46 11/21/03	036.24 PPM	000.12	-002.15
				17:12:46 11/21/03	036.26 PPM	000.10	-002.79
				17:13:46 11/21/03	036.26 PPM	000.08	-002.77
				17:14:46 11/21/03	036.26 PPM	000.07	-002.79
				17:15:46 11/21/03	036.24 PPM	000.07	-003.39

ANALYZER FIELD DATA

Company: Nucor Steel
Location: Crawfordsville, Indiana
Source: Castrip
Date: 11/20/03 - 11/21/03

17:16:46 11/21/03
1 044.14 PPM
3 000.05
5 -003.39
17:17:46 11/21/03
1 044.26 PPM
3 000.05
5 -003.41
17:18:46 11/21/03
1 044.38 PPM
3 000.05
5 -003.39
17:19:46 11/21/03
1 038.69 PPM
3 000.05
5 -004.01
17:20:46 11/21/03
1 039.69 PPM
3 000.05
5 -004.01
17:21:46 11/21/03
1 030.72 PPM
3 002.45
5 -004.01
17:22:46 11/21/03
1 021.23 PPM
3 028.40
5 002.71
17:23:46 11/21/03
1 020.81 PPM
3 028.19
5 004.53
17:24:46 11/21/03
1 021.88 PPM
3 017.98
5 012.47
17:25:46 11/21/03
1 031.27 PPM
3 000.32
5 000.31
17:26:46 11/21/03
1 032.31 PPM
3 000.19
5 -002.15
17:27:46 11/21/03
1 032.99 PPM
3 000.14
5 -003.41
17:28:46 11/21/03
1 033.29 PPM
3 003.59
5 -003.41

17:29:46 11/21/03
1 035.43 PPM
3 000.07
5 -003.39
17:30:46 11/21/03
1 035.54 PPM
3 000.07
5 -003.39
17:31:46 11/21/03
1 035.65 PPM
3 000.06
5 -004.01
17:32:46 11/21/03
1 036.73 PPM
3 000.05
5 -004.01
17:33:46 11/21/03
1 036.88 PPM
3 000.05
5 -004.59
17:34:46 11/21/03
1 036.59 PPM
3 000.06
5 -004.59
17:35:46 11/21/03
1 034.24 PPM
3 000.04
5 -004.61
17:36:46 11/21/03
1 034.23 PPM
3 000.05
5 -004.01
17:37:46 11/21/03
1 034.27 PPM
3 000.05
5 -004.01
17:38:46 11/21/03
1 034.27 PPM
3 000.05
5 -004.01
17:39:46 11/21/03
1 034.27 PPM
3 000.06
5 -004.01
17:40:46 11/21/03
1 034.27 PPM
3 000.04
5 -004.01
17:41:46 11/21/03
1 034.27 PPM
3 000.07
5 -004.61

17:42:46 11/21/03
1 034.10 PPM
3 000.04
5 -004.61
\*\*\* ON (RUNNING) \*\*\*
\*\*\*\*\* STOP \*\*\*\*\*
17:43:26 11/21/03
Run statistics N=00070
Min Ave Max
CO1 005.74 025.98 048.64
NOx3 000.04 007.93 047.11
SO2S -004.61 015.88 068.15
17:43:27 11/21/03
RUN starts logging
SOP stops logging
PRG starts programming
18:17:42 11/21/03
1 003.18 PPM zero CO
3 000.02
5 139.11 149 SO2
\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* ON \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*
18:10:40 11/21/03
1 132.90 PPM 133 CO
3 000.00 zero NOx
5 006.97
\*\*\*\*\* OFF \*\*\*\*\*
\*\*\*\*\* UN \*\*\*\*\*
\*\*\*\*\* RUN \*\*\*\*\*
18:20:27 11/21/03
1 000.67 PPM
3 030.38 30.1 NOx
5 -004.61 zero SO2
\*\*\*\*\* OFF \*\*\*\*\*

**APPENDIX C**

---

**Lead Field Data**

**AIR TEST PROFESSIONALS FIELD DATA SHEET**


**Pb (Lead) TESTING**

EPA METHOD 1-4/12/9

RUN 1

PAGE \_\_\_ OF \_\_\_

CLIENT	NUGOL STEEL	METER BOX ID	A-1	K FACTOR	4.7	DUCT DIMENSIONS (in.)	
LOCATION	Chattanooga, TN	METER #	7.01	METER ΔH@	1.744	PORT LENGTH (in.)	4"
UNIT	STRIP CASTER	PITOT Cp	0.84	PROBE LINER	GLASS	FILTER ID	R2
DATE	11/20/03	PROJECT #		NOZZLE ID	0.271	TEDLAR BAG ID	
METER OPERATOR	CARLOS BROWN	BAROMETRIC	29.95	AMBIENT TEMP (°F)		PITOT CHECK	
PROBE OPERATOR	CARLOS BROWN	STATIC PRESSURE (in. H <sub>2</sub> O)		-- 0.25		PASS	<input checked="" type="checkbox"/>
VISIBLE EMISSIONS READER	KON STAPPELT	LEAK RATE BEFORE (cfm)	2.000	@ (in. Hg)	10.5	H <sub>2</sub> O (mL)	0.00
CLIENT CONTACT	MARIE WASHNER	LEAK RATE AFTER (cfm)	0.001	@ (in. Hg)	30.1	SILICA GEL (g)	16.8
AGENCY CONTACT	STEVE FRIEND	START TIME	1144	STOP TIME	1251	TOTAL Vlc	16.8



Traverse Point Number	Elapsed Time	MiniPoint	Velocity Head ΔP's (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5		0.42	2.14	217.961	91	230	236	62	60	60	3.0	
2	5.0		0.53	2.70	282.6	92	237	243	62	61	60	4.0	
3	7.5		0.48	2.45	285.0	96	238	257	62	62	60	4.0	
4	10.0		0.48	2.45	287.2	99	232	251	63	62	60	4.0	
5	12.5		0.53	2.70	289.1	99	237	253	63	63	61	4.0	
6	15.0		0.53	2.70	291.3	100	237	250	63	63	61	4.0	
7	17.5		0.50	2.55	293.8	101	232	255	63	62	61	4.0	
8	20.0		0.48	2.45	295.9	102	261	251	63	63	62	4.0	
9	22.5		0.53	2.70	298.1	102	255	251	64	64	62	4.0	
10	25.0		0.53	2.70	300.5	102	248	250	64	65	62	4.0	
11	27.5		0.52	2.65	302.8	102	248	252	64	65	62	4.0	
12	30.0		0.47	2.40	305.1	103	247	247	64	66	63	4.0	
13	32.5		0.43	2.19	307.4	103	236	252	64	66	63	4.0	
14	35.0		0.45	2.30	309.3	104	236	259	64	66	64	3.5	
15	37.5		0.45	2.30	311.5	105	237	243	63	67	64	3.5	
16	40.0		0.45	2.30	313.6	105	246	259	63	67	64	3.5	
17	42.5		0.45	2.30	315.8	105	243	252	63	67	64	3.5	
18	45.0		0.45	2.30	318.6	105	246	247	64	67	64	4.0	
19	47.5		0.48	2.45	320.4	104	246	245	63	67	64	4.0	
20	50.0		0.50	2.55	322.6	104	246	244	62	67	64	4.0	
21	52.5		0.46	2.35	325.0	104	257	250	62	67	65	4.0	
22	55.0		0.46	2.35	327.1	104	256	250	62	67	65	4.0	
23	57.5		1.0	5.1	329.3	99	249	252	63	68	65	8.0	
24	60.0		1.0	5.1	332.558	97	253	254	63	68	65	8.0	

**AIR TEST PROFESSIONALS FIELD DATA SHEET**

**LEAD** TESTING


EPA METHOD 1-4/12/9

RUN 2

PAGE OF

CLIENT	NUCOR STEEL		METER BOX ID	A-1	K FACTOR	5.1	DUCT DIMENSIONS (in.)	96"
LOCATION	CRAWFORDVILLE, IN		METER Y	1.01	METER ΔH	1.744	PORT LENGTH (in.)	4"
UNIT	STRIP CASTER		PITOT Cp	0.84	PROBE LINER	GLASS	FILTER ID	R2
DATE	11/21/03	PROJECT #	PROBE ID	4.1	NOZZLE ID	3.71	TEDLAR BAG ID	SILICA ID #17
METER OPERATOR	CARLOS BROWN		BAROMETRIC	29.92	AMBIENT TEMP (°F)	50.9	PITOT CHECK	O <sub>2</sub> 20.9 CO <sub>2</sub> 0.0
PROBE OPERATOR	CARLOS BROWN		STATIC PRESSURE (in. H <sub>2</sub> O)	-0.25	PASS	<input checked="" type="checkbox"/>	FAIL	<input type="checkbox"/>
VISIBLE EMISSIONS READER	RON SMART		LEAK RATE BEFORE (dm)	0.000	@ (in. Hg)	9"	H <sub>2</sub> O (mL)	0.0
CLIENT CONTACT	MARIL NISHER		LEAK RATE AFTER (dm)	0.001	@ (in. Hg)	10"	SILICA GEL (g)	9.9
AGENCY CONTACT	STEVE FRIEND		START TIME	0850	STOP TIME	0955	TOTAL VIG	9.9

Traverse Point Number	Mini/Point		Velocity Head ΔPs (in. H <sub>2</sub> O)	Orifice Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp Ts (°F)	Probe Tp (°F)	Filter Tf (°F)		Cond. Temp Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
	Elapsed Time	Set Points												
1	2.5	0.46	2.35	335.1	87	247	249	249	54	54	53	3.5		
2	5.0	0.50	2.55	337.4	88	266	250	250	50	54	53	3.5		
3	7.5	0.53	2.70	339.7	88	258	250	250	50	56	53	3.5		
4	10.0	0.48	2.45	344.8	90	247	250	250	54	57	53	3.5		
5	12.5	0.43	2.19	343.9	93	244	250	250	57	57	54	3.0		
6	15.0	0.41	2.09	346.1	93	248	249	249	58	58	54	3.0		
7	17.5	0.47	2.40	348.3	98	237	245	245	58	58	54	3.0		
8	20.0	0.47	2.40	350.4	101	243	263	263	59	59	55	3.0		
9	22.5	0.43	2.19	352.5	102	247	253	253	60	59	55	3.0		
10	25.0	0.43	2.19	354.6	104	250	250	250	60	60	55	3.0		
11	27.5	0.40	2.04	356.6	106	251	251	251	61	60	55	2.5		
12	30.0	0.40	2.04	358.7	107	252	253	253	61	60	56	2.5		
13	32.5	0.45	2.30	360.8	106	245	255	255	61	60	56	2.5		
14	35.0	0.43	2.19	362.9	116	263	253	253	61	61	57	2.5		
15	37.5	0.48	2.45	364.9	111	267	251	251	62	61	57	3.0		
16	40.0	0.45	2.30	367.2	110	249	252	252	62	62	57	3.0		
17	42.5	0.40	2.04	369.4	110	244	253	253	63	63	58	2.5		
18	45.0	0.40	2.04	371.4	108	249	251	251	64	63	58	2.5		
19	47.5	0.47	2.46	373.6	104	238	248	248	64	63	59	3.0		
20	50.0	0.50	2.55	375.8	110	238	252	252	64	65	60	3.0		
21	52.5	0.51	2.60	378.1	109	244	249	249	65	65	60	3.0		
22	55.0	0.50	2.55	380.5	108	252	251	251	65	66	61	3.0		
23	57.5	0.47	2.40	382.7	107	251	251	251	66	67	61	3.0		
24	60.0	0.47	2.40	384.9	106	251	251	251	66	67	62	3.0		



AIR TEST PROFESSIONALS FIELD DATA SHEET

LEAD (Pb) TESTING


EPA METHOD 1-4/12/9

RUN 3

PAGE \_\_\_ OF \_\_\_

CLIENT	NUCAR STEEL		METER BOX ID	A-1	K FACTOR	5.0	DUCT DIMENSIONS (in.)	96"
LOCATION	LEAD BATTERY IN		METER	1.01	METER ΔH@	1.744	PORT LENGTH (in.)	4"
UNIT	1 STAIR CASTER		PITOT Cp	0.84	PROBE LINER	GLASS	FILTER ID	18"
DATE	11/2/03	PROJECT #	PROBE ID	4-1	NOZZLE ID	0.271	TEFLAR BAG ID	
METER OPERATOR	CARLOS BROWN		BAROMETRIC	29.92	AMBIENT TEMP (°F)		PITOT CHECK	O <sub>2</sub> 20.7
PROBE OPERATOR	CARLOS BROWN		STATIC PRESSURE (in. H <sub>2</sub> O)		-0.25		PASS	CO <sub>2</sub> 0.0
VISIBLE EMISSIONS READER	RON STRAYER		LEAK RATE BEFORE (cm)	0.000	@ (in. Hg)	11"	H <sub>2</sub> O (ml)	0.0
CLIENT CONTACT	MARC WATNER		LEAK RATE AFTER (cm)	0.000	@ (in. Hg)	8"	SILICA GEL (g)	9.2
AGENCY CONTACT	STEVE FRIEND		START TIME	16:32	STOP TIME	17:39	TOTAL Vc	9.2

Traverse Point Number	MinPoint Elapsed Time	Velocity Head ΔP's (in. H <sub>2</sub> O)	Office Setting ΔH (in. H <sub>2</sub> O)	Sample Volume Vm (ft <sup>3</sup> )	Stack Temp. Ts (°F)	Probe Tp (°F)	Filter Tt (°F)	Cond. Temp. Tc (°F)	DGM Inlet Tm (°F)	DGM Outlet Tm (°F)	Pump Vacuum (in. Hg)	Notes
1	2.5	0.48	2.4	431.61	96	237	250	61	65	63	3.0	
2	5.0	0.45	2.25	436.1	98	235	249	56	64	63	3.0	
3	7.5	0.48	2.4	438.0	102	241	249	53	64	63	3.0	
4	10.0	0.45	2.25	440.3	105	243	252	57	65	63	3.0	
5	12.5	0.42	2.10	442.4	107	247	249	59	65	63	3.0	
6	15.0	0.43	2.15	444.5	108	248	250	62	65	63	3.0	
7	17.5	0.42	2.10	446.6	109	242	253	62	65	63	3.0	
8	20.0	0.43	2.15	448.6	114	248	246	62	66	63	3.0	
9	22.5	0.43	2.15	450.7	114	253	251	63	66	63	3.0	
10	25.0	0.40	2.0	452.7	116	253	253	63	67	64	3.0	
11	27.5	0.40	2.0	454.8	117	257	253	63	67	64	3.0	
12	30.0	0.39	1.95	456.8	119	250	251	63	67	64	3.0	
13	32.5	0.48	2.4	459.0	118	244	254	63	67	64	3.0	
14	35.0	0.48	2.4	461.2	120	264	250	63	68	64	3.0	
15	37.5	0.40	2.0	463.3	119	261	250	63	68	64	3.0	
16	40.0	0.40	2.0	465.6	118	252	251	63	68	65	3.0	
17	42.5	0.45	2.25	467.8	116	246	251	63	68	65	3.0	
18	45.0	0.40	2.0	469.8	115	248	247	63	69	65	3.0	
19	47.5	0.40	2.0	472.1	113	248	249	62	67	65	3.0	
20	50.0	0.40	2.0	474.0	115	250	249	62	68	65	3.0	
21	52.5	0.45	2.25	476.1	114	252	251	61	68	65	3.0	
22	55.0	0.43	2.15	478.2	114	251	250	62	68	65	3.0	
23	57.5	0.43	2.15	480.3	113	248	248	62	69	65	3.0	
24	60.0	0.45	2.25	482.54	112	250	251	63	69	65	3.0	



**APPENDIX D**

---

**Particulate (condensable) Laboratory Data**

**PARTICULATE WEIGHT SHEET**

**Source:** Nucor Steel – LMS Baghouse Stack

Date:	11/20/03	11/21/03	11/21/03	
<b>Acetone</b>	<b>Blank</b>	<b>1</b>	<b>2</b>	<b>Avg</b>
Run ID#	A-12	A1	A2	A3
Tare Wt	63.8493	66.3626	64.2683	64.5864
Gross Wt	63.8493	66.3651	64.2705	64.5898
Correction	0.0000	0.0000	0.0000	0.0000
Net Wt	0.0000	0.0025	0.0022	0.0034
<b>Filter</b>		<b>1</b>	<b>2</b>	<b>3</b>
Run ID#		R1	R2	R3
Tare Wt		0.2984	0.2940	0.3460
Gross Wt		0.2984	0.2941	0.3460
Net Wt		0.0000	0.0001	0.0000
<b>Total Gain</b>		<b>0.0025</b>	<b>0.0023</b>	<b>0.0034</b>

# **Air Test Professionals, Inc.**

1201 North Graham Avenue  
Indianapolis, IN 46219

**Nucor Steel / Strip Caster**

PO# 051

**Analytical Report**

(1103-99)

***EPA Method 202***

Condensable particulate



**Enthalpy Analytical, Inc.**

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / [www.enthalpy.com](http://www.enthalpy.com)  
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)
- This analytical report was prepared in Portable Document Format (.PDF) and contains 10 pages.

*Michael Steven Schapira*

QA Review Performed by: Michael Steven Schapira



# Summary of Results



**EPA Method 202 - Condensable Particulate Determination - Data Analysis**

Company	ATP, Inc.
Analyst	SLG
Parameters	Method 202
# Samples	3 Runs and 1 Blank

Client #	Nucor Steel-Strip Caster
Job #	1103-99
PO #	051
Report Date	12/12/2003

**Analysis of Particulate Recovery**

Run Number	1	2	3
Sample ID Number	Run # 1	Run # 2	Run # 3
<b>Organic</b>			
Beaker Number	5011	5003	5002
Final Weight, g	0.9741	0.9708	0.9701
Reweigh, Final, g	0.9741	0.9708	0.9702
Beaker Tare Weight, g	0.9680	0.9678	0.9681
Beaker Tare Reweigh, Initial, g	0.9679	0.9677	0.9681
Solvent Blank, g	0.0013	0.0013	0.0011
MeCl2 FV, mL	202	196	168
Net Organic Catch, mg	4.9	1.8	1.0
<b>Inorganic</b>			
Beaker Number	5017	5018	5014
Final Weight, g	0.9779	0.9721	0.9796
Reweigh, Final, g	0.9778	0.9720	0.9795
Beaker Tare Weight, g	0.9702	0.9691	0.9696
Beaker Tare Reweigh, Initial, g	0.9699	0.9689	0.9695
Water Blank, g	0.0006	0.0006	0.0006
H2O FV, mL	392	358	406
Net Inorganic, mg	7.3	2.5	9.4
Condensible Particulate, mg	12.2	4.4	10.4

2.57 = 0.286

6.40 = 0.714

**Blank Analysis**

Sample ID Number	MeCl Blank
Beaker Number	5013
Final Weight, g	0.9687
Reweigh, Final, g	0.9685
Initial Weight, g	0.9673
Reweigh, Initial, g	0.9671
MeCl2 Residue, g	0.0014
MeCl2 Volume, mL	212
Max. MeCl2 Residue, g	0.0028

Sample ID Number	H2O Blank
Beaker Number	5016
Final Weight, g	0.9696
Reweigh, Final, g	0.9694
Initial Weight, g	0.9691
Reweigh, Initial, g	0.9688
Water Residue, g	0.0006
Water Volume, mL	388
Max. Water Residue, g	0.0039

# Narrative Summary



## Enthalpy Analytical Narrative Summary

<b>Company:</b>	ATP, Inc.
<b>Client #:</b>	Nucor Steel-Strip Caster
<b>PO #</b>	051

<b>Enthalpy #:</b>	1103-99
<b>Analyst:</b>	SLG
<b>Parameters:</b>	EPA Method 202

**Custody** Scott Grosshandler of Enthalpy Analytical, Inc. received the samples at ambient temperature on 11/26/03 after being relinquished by Air Test Professionals, Inc. There were no visible container problems noted upon receipt. Prior to and during analysis they were kept under lock with access only to authorized personnel of Enthalpy Analytical, Inc.

**Methodology** All samples were analyzed in accordance to the requirements and specifications of EPA Method 202.

**Instrumentation** All samples were weighed on a Sartorius Model BP 110 S (SN-40707606), certified by Precision Weighing, Inc. through November 4, 2004 (NIST Test # 846895).

**Labeling** OK

**Additional Reporting Notes** The inorganic and organic catch weights are adjusted by a blank correction value. A mathematically determined (theoretical) maximum value is calculated and compared with the actual value measured for each blank. The lower of the two values is used as the blank correction value, which is then factored by the sample volume divided by the blank volume, and subtracted from the sample's catch weight.

## General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. reports, unless specifically noted otherwise.

- The symbol **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot confirm the presence of the analyte of interest reliably.
- The symbol **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The symbol **ND** following a value indicates a non-detect or analytical result below the MDL.
- The symbol **J** following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The symbol **E** following a value indicates an analytical result exceeding 100% of the highest calibration point.
- The symbol **DF** represents a Dilution Factor. This number represents dilutions during the extraction and/or laboratory stages of sample treatment. The analytical result taken from a laboratory instrument is multiplied by the DF to get final results.
- The Sample ID **MS** represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix prohibits analysis for the analyte(s).
- The Sample ID **MSD** represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times. Most methods performed by Enthalpy do not require analysis of an MSD.
- The Sample ID **BS** represents a Blind Spike. A member of the Quality Assurance department has created BS samples for many of the analytes Enthalpy tests for, and only QA and the Enthalpy Analytical ownership have access to the actual values of these samples. The laboratory analyzes them without knowledge of the actual value, and the spreadsheets get completed for these samples solely by the QA group.
- The Sample ID **LCS** represents a Laboratory Control Sample. Whenever spikes are prepared for our clients more spikes are prepared than needed. The extras (randomly chosen) are kept in-house at the appropriate temperature conditions. When the spike samples come back from the client for analysis, the LCSs (usually two are saved) are analyzed to confirm that the analyte could be recovered from the media, separate from the spike samples which were used on the project and which may have had issues caused during collection and/or transport.
- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed (specifically values of 1,000 or greater), the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits reported, but no confidence should be placed on more than three significant digits.



**APPENDIX D**

---

**Lead Laboratory Data**

# **Air Test Professionals, Inc.**


1201 North Graham Avenue  
Indianapolis, IN 46219

Project ID: Nucor Steel Strip Caster

Lead

EPA Method 12 Analysis


Analytical Report  
2555




Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX:910-792-6853 e1lab@hotmail.com

I have reviewed the following data for completeness,  
accuracy, adherence to method protocol, and compliance  
with quality assurance guidelines.

Quality assurance review by Bruce Hawks



# SUMMARY OF RESULTS




## Summary of Analysis

### Summary of Lead Analysis

<u>Element</u>	<u>Run 1 Total µg</u>	<u>Run 2 Total µg</u>	<u>Run 3 Total µg</u>	<u>Blank Total µg</u>	<u>Run 3 Spike Recovery</u>
Lead Average	2.1	2.0	1.1	2.0	99%
Triplicate RSD	0.2%	0.2%	1.3%	1.8%	

# ANALYTICAL NARRATIVE



## Element One Analytical Narrative

Client	Air Test Professionals, Inc.	Element One #:	2555
Client ID:	Nucor Steel Strip Caster	Analyst:	KMS
Date Received	11/26/03	Method:	M12
Analytes	Pb	Dates Analyzed	12/08/03

### Summary of Analysis

The Method 12 samples were prepared and analyzed according to the method protocol. Digested samples were analyzed for on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The instrument reporting limit was for 2.5 µg/L for lead.


### Analysis QA/QC

The spike recovery data and triplicate analyses relative standard deviations are summarized with the results. All QC was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank or spike recovery values. Nothing unusual was noticed with any of the analyses.

# ANALYTICAL DATA



Client ID/PO: 051 – Nucor Steel Strip Caster		Date Received: 11/26/03	Page: 1	of 1
Customer: Air Test Professionals, Inc.		Results Requested: 12/12/03	Time Rec: 1130	
Address: 1201 N. Graham Av.		Contact: Carlos Brown	Rec by: BGH	
Indianapolis, IN 46219		Email: atp_stack@sbcglobal.net	Via:	
		Phone: 317-345-1723	Fax:	
HNO <sub>3</sub> Lot:	HF Lot:	HCl Lot:		
Volume Marked <b>(Y/N)</b>	Volume Loss Y <b>(N/P)</b>	pH < 2.0 <b>(Y/N)</b>	Ref. Method: 12	

	Sample Identification		Sample Identification
1	Run 1		
2	Run 2		
3	Run 3		
4	Run 3 Spike		
5	Blank		

Elements to Analyze: Pb – **METHOD 12**

SAMPLE	Front Half		Back Half			HNO <sub>3</sub> (A)		KMnO <sub>4</sub> (B)		HCl (C)	
	BV, ml	FV, ml	BV, ml	Used	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml	BV, ml	FV, ml
1	293	100									
2	309	↓									
3/4	317	↓									
5	262	↓									
	-										

Comments:

*L2RB spike = 20ug / F.V. 100ml  
 Rot  
 Δ 9055027*

# Dataset Report

Operator Name: ksmith  
Computer Name: ICPMS1  
Dataset File Path: c:\elandata\dataset\120803-1\  
Report Date/Time: Monday, December 08, 2003 17:41:12

*Ken Smith*  
*12-8-03*

Autosampler Position: 13

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Allquot. Vol.	Diluted v
15:59:26 Mon 08-Dec-03	Blank		Blank					
16:01:26 Mon 08-Dec-03	Standard 1		Standard #1					
16:03:27 Mon 08-Dec-03	Standard 2		Standard #2					
16:05:29 Mon 08-Dec-03	Standard 3		Standard #3					
16:07:31 Mon 08-Dec-03	Standard 4		Standard #4					
16:09:33 Mon 08-Dec-03	Standard 5		Standard #5					
16:11:36 Mon 08-Dec-03	QC Std 1		QC Std #1					
16:13:37 Mon 08-Dec-03	QC Std 2		QC Std #2					
16:15:37 Mon 08-Dec-03	QC Std 3		QC Std #3					
16:17:37 Mon 08-Dec-03	QC Std 4		QC Std #4					
16:19:38 Mon 08-Dec-03	QC Std 5		QC Std #5					
16:54:27 Mon 08-Dec-03	2555-1		Sample	Ait T Prof				
16:56:30 Mon 08-Dec-03	2555-2		Sample	Ait T Prof				
16:58:33 Mon 08-Dec-03	2555-3		Sample	Ait T Prof				
17:00:37 Mon 08-Dec-03	2555-3		Spike - 1	Ait T Prof				
17:02:40 Mon 08-Dec-03	2555-5		Sample	Ait T Prof				
17:04:40 Mon 08-Dec-03	QC Std 3		QC Std #3					
17:06:40 Mon 08-Dec-03	QC Std 4		QC Std #4					
17:32:08 Mon 08-Dec-03	LRB		Sample	Ait T Prof				
17:34:14 Mon 08-Dec-03	LRB		Spike - 1	Ait T Prof				
17:36:15 Mon 08-Dec-03	QC Std 3		QC Std #3					
17:38:15 Mon 08-Dec-03	QC Std 4		QC Std #4					


# Sample/Batch Report

*Ken Smith*  
*12-8-03*

Operator Name: ksmith  
Computer Name: ICPMS1  
Sample File: C:\elandata\Sample\Method 12.sam  
Report Date/Time: Monday, December 08, 2003 17:40:21


A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
12		LRB	Alt T Prof						
13		LRB	Alt T Prof	Spike - 1					
14		2555-1	Alt T Prof						
15		2555-2	Alt T Prof						
16		2555-3	Alt T Prof						
17		2555-3	Alt T Prof	Spike - 1					
18		2555-5	Alt T Prof						





Timing Processing Equation Calibration Sampling Devices QC...

Analyte	Mass (amu)	Spike Table 1 (Conc.)	Spike Table 1 Det. Limit (Conc.)	Spike Table 2 (Conc.)	Spike Table 2 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)	Spike Table 4 Det. Limit (Conc.)
Rh	102.905								
Pb	207.977	50	0.001	200	1	100	1		
Kr	82.9141								



Method 6020 Multi Metals Summary Report

Sample ID:

Blank

Sample Date/Time:

Monday, December 08, 2003 15:59:26

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		643850.7		ppb
-	Ho	165		1176247.9		ppb
	Pb	208		1169.7		ppb
	Kr	83		386.3		ppb

Replicates

Concentration

Concentration

Concentration

Method 6020 Multi Metals Summary Report

Sample ID:

Standard 1

Sample Date/Time:

Monday, December 08, 2003 16:01:26

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		661757.3		ppb
-	Ho	165		1198718.9		ppb
	Pb	208		454796	10.19038	ppb
	Kr	83		374.2		ppb

Replicates

Concentration

10.092839

Concentration

10.251392

Concentration

10.226909

Method 6020 Multi Metals Summary Report

Sample ID: Standard 2  
Sample Date/Time: Monday, December 08, 2003 16:03:27  
Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		653595.9		ppb
>	Ho	165		1204607.5		ppb
>	Pb	208		913023.3	20.38672	ppb
	Kr	83		397.2		ppb

Replicates  
Concentration

20.537286

Concentration

20.519772

Concentration

20.103095

Method 6020 Multi Metals Summary Report

Sample ID: Standard 3  
Sample Date/Time: Monday, December 08, 2003 16:05:29  
Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		649636.9		ppb
>	Ho	165		1191972.6		ppb
>	Pb	208		4422531.4	99.89572	ppb
	Kr	83		363.5		ppb

Replicates  
Concentration

100.401369

Concentration

100.291191

Concentration

98.994602

Method 6020 Multi Metals Summary Report

Sample ID: Standard 4

Sample Date/Time: Monday, December 08, 2003 16:07:31

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	685063.9			ppb
>	Ho	165	1238880.4			ppb
>	Pb	208	22852225.8	496.71054		ppb
>	Kr	83	363.7			ppb

Replicates  
Concentration

492.875851

Concentration

498.074888

Concentration

499.180883

Method 6020 Multi Metals Summary Report

Sample ID: Standard 5

Sample Date/Time: Monday, December 08, 2003 16:09:33

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	670331.4			ppb
>	Ho	165	1218656.9			ppb
>	Pb	208	45327940.9	1001.64552		ppb
>	Kr	83	361			ppb

Replicates  
Concentration

987.29896

Concentration

1005.61773

Concentration

1012.019869

Method 6020 Multi Metals Summary Report

Sample ID:

QC Std 1

Sample Date/Time: Monday, December 08, 2003 16:11:36

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		627766.4		ppb
	Ho	165		1151434.4		ppb
	Pb	208		441374.6	10.29698	ppb
	Kr	83		351.3		ppb

Replicates

Concentration

10.400215

Concentration

10.202207

Concentration

10.288525

Method 6020 Multi Metals Summary Report

Sample ID:

QC Std 2

Sample Date/Time: Monday, December 08, 2003 16:13:37

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		645607.2		ppb
	Ho	165		1183583.8		ppb
	Pb	208		48010.4	1.06561	ppb
	Kr	83		364.3		ppb

Replicates

Concentration

1.065851

Concentration

1.067207

Concentration

1.063767

Method 6020 Multi Metals Summary Report

Sample ID:

QC Std 3

Sample Date/Time:

Monday, December 08, 2003 16:15:37

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	645918.6			ppb
>	Ho	165	1181440.2			ppb
>	Pb	208	2915.4	0.03968		ppb
>	Kr	83	392.7			ppb

Replicates

Concentration

0.046034

Concentration

0.037916

Concentration

0.035098

Method 6020 Multi Metals Summary Report

Sample ID:

QC Std 4

Sample Date/Time:

Monday, December 08, 2003 16:17:37

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	660191.4			ppb
>	Ho	165	1203658.8			ppb
>	Pb	208	2387516.3	53.39288		ppb
>	Kr	83	391.3			ppb

Replicates

Concentration

53.794696

Concentration

53.132741

Concentration

53.251214

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 5  
Sample Date/Time: Monday, December 08, 2003 16:19:38  
Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		667287.2		ppb
	Ho	165		1206702.9		ppb
	Pb	208		23222229.7	518.23285	ppb
	Kr	83		397.3		ppb

Replicates  
Concentration

512.400533

Concentration

518.768175

Concentration

523.529837

Method 6020 Multi Metals Summary Report

Sample ID: 2555-1  
Sample Date/Time: Monday, December 08, 2003 16:54:27  
Sample Description: Ait T Prof  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		625550		ppb
	Ho	165		1215046.3		ppb
	Pb	208		938863.9	20.78227	ppb
	Kr	83		516.4		ppb

Replicates  
Concentration

20.832783

Concentration

20.747675

Concentration

20.76635

Method 6020 Multi Metals Summary Report

Sample ID: 2555-2  
Sample Date/Time: Monday, December 08, 2003 16:56:30  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		634014.6		ppb
>	Ho	165		1219181.3		ppb
>	Pb	208		911057.8	20.09742	ppb
	Kr	83		583.2		ppb

Replicates  
Concentration

20.125641

Concentration

20.046318

Concentration

20.120296

Method 6020 Multi Metals Summary Report

Sample ID: 2555-3  
Sample Date/Time: Monday, December 08, 2003 16:58:33  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		630593.1		ppb
>	Ho	165		1217341.1		ppb
>	Pb	208		478940.8	10.5698	ppb
	Kr	83		713.7		ppb

Replicates  
Concentration

10.73271

Concentration

10.473648

Concentration

10.503042

Method 6020 Multi Metals Summary Report

Sample ID: 2555-3  
Sample Date/Time: Monday, December 08, 2003 17:00:37  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		614963.7		ppb
-	Ho	165		1174413.2		ppb
	Pb	208		2627281	60.22004	ppb
	Kr	83		695		ppb

Replicates  
Concentration

60.389044

Concentration

60.413925

Concentration

59.857149

Method 6020 Multi Metals Summary Report

Sample ID: 2555-5  
Sample Date/Time: Monday, December 08, 2003 17:02:40  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103		668807.3		ppb
-	Ho	165		1205999.4		ppb
	Pb	208		910657.4	20.31049	ppb
	Kr	83		1482.8		ppb

Replicates  
Concentration

19.951594

Concentration

20.287117

Concentration

20.692749

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 3  
Sample Date/Time: Monday, December 08, 2003 17:04:40

Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	676606.8			ppb
-	Ho	165	1197046.9			ppb
	Pb	208	1914.6	0.01628		ppb
	Kr	83	388			ppb

Replicates  
Concentration

0.021078

Concentration

0.014028

Concentration

0.013737

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4  
Sample Date/Time: Monday, December 08, 2003 17:06:40

Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	680608.1			ppb
-	Ho	165	1190861.9			ppb
	Pb	208	2358797.2	53.31615		ppb
	Kr	83	402.8			ppb

Replicates  
Concentration

52.666056

Concentration

53.544031

Concentration

53.738359

Method 6020 Multi Metals Summary Report

Sample ID: LRB  
Sample Date/Time: Monday, December 08, 2003 17:32:08  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	670337.3			ppb
>	Ho	165	1189861.5			ppb
>	Pb	208	45689.3		1.00731	ppb
	Kr	83	348.3			ppb

Replicates  
Concentration

1.009163

Concentration

0.999721

Concentration

1.013055

Method 6020 Multi Metals Summary Report

Sample ID: LRB  
Sample Date/Time: Monday, December 08, 2003 17:34:14  
Sample Description: Ait T Prof

Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	683454.2			ppb
>	Ho	165	1210496.3			ppb
>	Pb	208	9276208.5		206.35104	ppb
	Kr	83	356.2			ppb

Replicates  
Concentration

206.065381

Concentration

207.650821

Concentration

205.33691

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 3  
Sample Date/Time: Monday, December 08, 2003 17:36:15

Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	669881.2			ppb
>	Ho	165	1193001			ppb
>	Pb	208	5122.3	0.08907		ppb
>	Kr	83	373.7			ppb

Replicates  
Concentration

0.118173

Concentration

0.079753

Concentration

0.069283

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4  
Sample Date/Time: Monday, December 08, 2003 17:38:15

Sample Description:  
Concentration Results

	Analyte	Mass	Meas. Intens.	Mean Conc.	Mean	Report Unit
>	Rh	103	663487.5			ppb
>	Ho	165	1187007.3			ppb
>	Pb	208	2360258.6	53.52427		ppb
>	Kr	83	381.7			ppb

Replicates  
Concentration

53.425472

Concentration

54.058424

Concentration

53.088906

**APPENDIX E**

---

# ATP - Air Test Professionals, Inc.


1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION				PRESERV	REMARKS / PRECAUTIONS
COMPANY:	PROJECT NAME/NUMBER:	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER		
ATP	Nucor Steel - Strip Caster	11/20/03			Petri	1 X	EPA Method 5 # OF CONTAINERS
SEND REPORT TO:	BILLING INFORMATION	11/21/03			Petri	1 X	
ADDRESS:	BILL TO:	11/21/03			Petri	1 X	
1201 N. Graham Ave.	ADDRESS:						
Indianapolis, Indiana 46219	PHONE:						
	(317) 345-1723						
	(317) 351-0411						
	PO NO: 051						
Run 1	Sample Filter	11/20/03			Petri	1 X	
Run 2	Sample Filter	11/21/03			Petri	1 X	
Run 3	Sample Filter	11/21/03			Petri	1 X	
Run 1	Acetone Rinse	11/20/03		AQ	4 OZ	1 X	
Run 2	Acetone Rinse	11/21/03		AQ	4 OZ	1 X	
Run 3	Acetone Rinse	11/21/03		AQ	4 OZ	1 X	
BLANK	Acetone Blank			AQ	4 OZ	1 X	
SAMPLER:	Carlos Brown	SHIPMENT METHOD:		AIRBILL NO:			

REQUIRED TURNAROUND:		DATE	
1. RELINQUISHED BY:	SIGNATURE:	DATE	TIME
		11/21/03	
PRINTED NAME/COMPANY:	ATP		
2. RECEIVED BY:	SIGNATURE:	DATE	TIME
PRINTED NAME/COMPANY:			

3. RELINQUISHED BY:		DATE	
SIGNATURE:	PRINTED NAME/COMPANY	DATE	TIME
PRINTED NAME/COMPANY:			

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION			PROJECT INFORMATION			BILLING INFORMATION	
COMPANY:	ATP	PROJECT NAME/NUMBER:	Nucon Steel - Strip Caster	PROJECT NO.:			
SEND REPORT TO:	Carlos Brown	BILL TO:		BILLING INFORMATION			
ADDRESS:	1201 N. Graham Ave.	ADDRESS:	Same	LAB JOB NO.:			
PHONE:	(317) 345-1723	PHONE:		EPA METHOD 12			
FAX:	(317) 351-0411	FAX:	051	REMARKS / PRECAUTIONS			
Run 1	HNO3 Rinse	11/20/03	AQ	500 ml	1	X	
Run 2	HNO3 Rinse	11/21/03	AQ	500 ml	1	X	
Run 3	HNO3 Rinse	11/21/03	AQ	500 ml	1	X	
Run 1	Sample Filter	11/20/03		Petri	1	X	
Run 2	Sample Filter	11/21/03		Petri	1	X	
Run 3	Sample Filter	11/21/03		Petri	1	X	
BLANK	HNO3 BLANK			AQ	1	X	
BLANK	Filter BLANK			Petri	1	X	
SAMPLER: Carlos Brown		SHIPMENT METHOD:		AIRBILL NO.:			
REQUIRED TURNAROUND:							
SIGNATURE:	<i>Carlos Brown</i>	DATE:	11/21/03	SIGNATURE:		DATE:	
PRINTED NAME/COMPANY:	ATP	TIME:		PRINTED NAME/COMPANY:		TIME:	
SIGNATURE:	<i>Bruce Hanks, Element One</i>	DATE:	11/26/03	SIGNATURE:		DATE:	
PRINTED NAME/COMPANY:	Bruce Hanks, Element One	TIME:	1130	PRINTED NAME/COMPANY:		TIME:	

02555

# ATP - Air Test Professionals, Inc.

1201 North Graham Avenue  
Indianapolis, Indiana 46219

Phone (317) 345-1723  
Fax (317) 351-0411  
Email: atp\_stack@sbcglobal.net

## CHAIN OF CUSTODY RECORD

CUSTOMER INFORMATION		PROJECT INFORMATION				BILLING INFORMATION		NO. OF CONTAINERS	REMARKS / PRECAUTIONS
COMPANY:	PROJECT NAME/NUMBER:	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER	PRESERV			
ATP	Nucor Steel - Slip Caster (Strip)								
SEND REPORT TO:	Carlos Brown								
ADDRESS:	1201 N. Graham Ave.								
	Indianapolis, Indiana 46219								
PHONE:	(317) 345-1723								
FAX:	(317) 351-0411								
SAMPLE NO	SAMPLE DESCRIPTION	SAMPLE DATE	SAMPLE TIME	SAMPLE MATRIX	CONTAINER	PRESERV			
Run 1	MeCl2 Rinse	11/20/03		AQ	4 oz		1	X	
Run 2	MeCl2 Rinse	11/21/03		AQ	4 oz		1	X	
Run 3	MeCl2 Rinse	11/21/03		AQ	4 oz		1	X	
Run 1	DI H2O Rinse	11/20/03		AQ	500 ml		1	X	
Run 2	DI H2O Rinse	11/21/03		AQ	500 ml		1	X	
Run 3	DI H2O Rinse	11/21/03		AQ	500 ml		1	X	
BLANK	MeCl2			AQ	4 oz		1	X	
BLANK	DI H2O			AQ	500 ml		1	X	
SAMPLER: Carlos Brown		SHIPMENT METHOD:		A/RBILL NO:					
REQUIRED TURNAROUND: .									
1. RELINQUISHED BY:		DATE	2. RELINQUISHED BY:		DATE	3. RELINQUISHED BY:		DATE	
SIGNATURE:			SIGNATURE:			SIGNATURE:			
PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY:		TIME	
ATP - Carlos Brown		11/21/03	ATP - Carlos Brown			ATP - Carlos Brown			
1. RECEIVED BY:		DATE	2. RECEIVED BY:		DATE	3. RECEIVED BY:		DATE	
SIGNATURE:			SIGNATURE:			SIGNATURE:			
PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY:		TIME	PRINTED NAME/COMPANY:		TIME	
Scott Grosshandl		11/20/03	Scott Grosshandl			Scott Grosshandl			
Enthopy		10:00 AM	Enthopy			Enthopy			

**APPENDIX F**

---

### CALIBRATION CHECK

(Post Test) per EMTIC Guideline GD-26

Company:	Nucor Steel
Date:	11/20/03-11/21/03
Source:	Castrip
Location:	Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	0.997	0.971	0.961	0.976
Average result must be within 5% of Y				
Result (%)	3.36			
<b>PASSED POST CAL</b>				
Dry Gas Meter Box:				
ID:	A-1			
Y:	1.01			
Delta H:	1.744			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.14	60	60
2		2.70	61	60
3		2.45	62	60
4		2.45	62	60
5		2.70	63	61
6		2.70	63	61
7		2.55	62	61
8		2.45	63	62
9		2.70	64	62
10		2.70	65	62
11		2.65	65	62
12		2.40	66	63
13		2.40	66	63
14		2.19	66	64
15		2.30	67	64
16		2.30	67	64
17		2.30	67	64
18		2.30	67	64
19		2.45	67	64
20		2.55	67	65
21		2.35	67	65
22		2.35	67	65
23	332.658	5.10	68	65
24	277.961	5.10	68	65

Volume	Delta H	Meter Temp
54.597	2.678	63.86

Barometric Pressure
29.95

Test Time
60.00

Y qa:	0.997
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.35	54	53
2		2.55	54	53
3		2.70	56	53
4		2.45	57	53
5		2.19	57	54
6		2.09	58	54
7		2.40	58	54
8		2.40	59	55
9		2.19	59	55
10		2.19	60	55
11		2.04	60	55
12		2.04	60	56
13		2.30	60	56
14		2.19	61	57
15		2.45	61	57
16		2.30	62	57
17		2.04	63	58
18		2.04	63	58
19		2.40	63	59
20		2.55	65	60
21		2.60	65	60
22		2.55	66	61
23	384.91	2.40	67	61
24	332.91	2.40	67	62

Volume	Delta H	Meter Temp
52	2.325	58.56

Barometric Pressure
29.92

Test Time
60.00

Y qa:	0.971
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		2.40	65	63
2		2.25	64	63
3		2.40	64	63
4		2.25	65	63
5		2.10	65	63
6		2.15	65	63
7		2.10	65	63
8		2.15	66	63
9		2.15	66	63
10		2.00	67	64
11		2.00	67	64
12		1.95	67	64
13		2.40	67	64
14		2.40	68	64
15		2.00	68	64
16		2.00	68	65
17		2.25	68	65
18		2.00	69	65
19		2.00	67	65
20		2.00	68	65
21		2.25	68	65
22		2.15	68	65
23	482.54	2.15	69	65
24	431.61	2.25	69	65

Volume	Delta H	Meter Temp
50.93	2.156	65.40

Barometric Pressure
29.92

Test Time
60.00

Y qa:	0.961
-------	-------

# CALIBRATION CHECK

(Post Test) per EMTIC Guideline GD-26

Company: Nucor Steel  
 Date: 11/20/03-11/21/03  
 Source: Castrip  
 Location: Crawfordsville, Indiana

	Run 1	Run 2	Run 3	Average
Y qa =	0.985	0.969	0.968	0.974
Average result must be within 5% of Y				
Result (%)	2.99			
<b>PASSED POST CAL</b>				
Dry Gas Meter Box:				
ID:	A-2			
Y:	1.004			
Delta H:	1.83			

Run 1	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.55	71	71
2		1.55	71	71
3		1.62	73	71
4		1.51	73	71
5		1.48	75	71
6		1.44	74	71
7		1.66	75	72
8		1.84	76	73
9		1.80	79	73
10		1.80	79	74
11		1.66	81	74
12		1.76	83	75
13		1.66	82	76
14		1.66	82	76
15		1.69	84	77
16		1.69	84	77
17		1.62	86	78
18		1.48	87	78
19		1.58	86	79
20		1.40	86	79
21		1.51	88	80
22		3.78	88	81
23	591.945	3.89	91	82
24	546.105	3.49	92	83

Volume	Delta H	Meter Temp
45.84	1.880	78.31

Barometric Pressure
29.95

Test Time
60.00

Y qa:	0.985
-------	-------

Run 2	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.62	68	67
2		1.58	68	67
3		1.55	68	67
4		1.48	69	67
5		1.48	71	67
6		1.37	71	67
7		1.69	71	68
8		1.69	72	68
9		1.55	73	69
10		1.44	73	69
11		1.44	74	69
12		1.37	74	69
13		1.62	76	69
14		1.66	77	71
15		1.76	78	71
16		1.69	79	72
17		1.76	79	72
18		1.73	80	73
19		1.69	80	73
20		1.62	81	74
21		1.62	82	75
22		1.62	83	76
23	634.878	1.58	84	76
24	592.315	1.33	84	76

Volume	Delta H	Meter Temp
42.563	1.581	73.06

Barometric Pressure
29.92

Test Time
60.00

Y qa:	0.969
-------	-------

Run 3	Volume	Delta H	DGM Inlet	DGM Outlet
1		1.58	73	71
2		1.33	74	71
3		1.40	78	72
4		1.30	77	72
5		1.23	78	73
6		1.30	79	74
7		1.44	79	74
8		1.54	81	75
9		1.54	82	75
10		1.51	84	76
11		1.44	85	77
12		1.37	85	77
13		1.58	85	78
14		1.58	86	78
15		1.51	87	80
16		1.40	88	80
17		1.51	88	81
18		1.19	89	81
19		1.40	88	81
20		1.37	89	82
21		1.37	90	83
22		1.33	90	83
23	710.80	1.30	90	83
24	670.305	1.30	90	84

Volume	Delta H	Meter Temp
40.498	1.406	80.71

Barometric Pressure
29.92

Test Time
60.00

Y qa:	0.968
-------	-------

# Meter Box Full Test Calibration

DATE: 5/28/03

Operator: Joe Ward

Meter Box Nc 2027		Meter Box H@: 1.7441		Meter Box Yd 1.0096		Barometric Pressure: 29.40											
Q	P	H	Yds	Standard Meter Gas Volume		Meter Box Gas Volume (ft <sup>3</sup> )		Meter Box Temperature (PF)		Time	Yd	H@					
				Initial	Final	Vf	Vf	Inlet	Outlet				Avg.	Avg.			
0.98	-0.70	3.00	1.0000	0.0	10.000	10.000	143.148	153.257	10.109	73.0	73.0	87.0	79.0	83.0	9.96	1.0171	1.7020
0.98	-0.70	3.00	1.0000	0.0	10.000	10.000	153.257	163.383	10.126	73.0	73.0	88.0	80.0	84.0	9.93	1.0173	1.6886
0.69	-0.50	1.50	1.0000	0.0	10.000	10.000	206.632	216.708	10.076	68.0	68.0	79.0	72.0	75.5	14.24	1.0116	1.7295
0.68	-0.50	1.50	1.0000	0.0	10.000	10.000	216.708	226.830	10.122	68.0	68.0	80.0	73.0	76.5	14.34	1.0089	1.7505
0.39	-0.40	0.50	1.0000	0.0	5.000	5.000	237.933	243.028	5.095	68.0	68.0	78.0	77.0	77.5	12.66	1.0013	1.8057
0.39	-0.40	0.50	1.0000	0.0	5.000	5.000	243.028	248.122	5.094	68.0	68.0	78.0	77.0	77.5	12.60	1.0015	1.7886
AVERAGE												1.0096	1.7441				

Millennium Instruments Inc.  
 2402 Springridge Drive unit A  
 Spring Grove IL. 60081  
 PHONE#(815)675-3225  
 FAX#(815)675-6965  
 E-mail millennium@interaccess.com  
 www.millinst.com

## Vacuum Gauge

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0
25.0	23.5

# Meter Box Full Test Calibration

DATE: 9/5/03

Operator: Joe Ward

Meter Box No		2031		Meter Box H@: 1.8306				Meter Box Yd		1.0043		Barometric Pressure: 29.84						
A-2				Standard Meter Gas Volume		Meter Box Gas Volume (ft <sup>3</sup> )		Temperature (°F)		Meter Box Temperature (PF)		Time		Yd		H@		
				Initial	Final	Vf	Initial	Final	Vf	Inlet	Outlet							Avg.
0.96	-0.60	3.00	1.0000	0.0	10.000	10.000	125.809	136.103	10.294	77.0	77.0	77.0	99.0	81.0	90.0	10.22	1.0038	1.7855
0.95	-0.60	3.00	1.0000	0.0	10.000	10.000	136.103	146.394	10.291	77.0	77.0	77.0	98.0	79.0	88.5	10.27	1.0014	1.8097
0.38	-0.40	0.50	1.0000	0.0	5.000	5.000	155.942	161.056	5.114	78.0	78.0	78.0	98.0	86.0	92.0	12.86	1.0054	1.8745
0.38	-0.40	0.50	1.0000	0.0	5.000	5.000	161.056	166.163	5.107	78.0	78.0	78.0	98.0	86.0	92.0	12.79	1.0068	1.8541
0.67	-0.50	1.50	1.0000	0.0	10.000	10.000	204.510	214.751	10.241	78.0	78.0	78.0	99.0	83.0	91.0	14.70	1.0050	1.8471
0.67	-0.50	1.50	1.0000	0.0	10.000	10.000	214.751	224.995	10.244	78.0	78.0	78.0	99.0	82.0	90.5	14.55	1.0038	1.8129
AVERAGE												1.0043		1.8306				

Millennium Instruments Inc.  
 2402 Springridge Drive unit A  
 Spring Grove IL. 60081  
 PHONE#(815)675-3225  
 FAX#(815)675-6965  
 E-mail millennium@interaccess.com  
 www.millinst.com

**Vacuum Gauge**

(in. Hg)	Gauge
5.0	5.0
10.0	10.0
15.0	15.0
20.0	20.0
25.0	25.0

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

**Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1**

Probe Length/ID.: 7 ft. Type-S (w/probe)

External Tubing Diameter: 0.250" inches

Base to Opening Plane Distance (Pa): 0.370" inches

Base to Opening Plane Distance (Pa): 0.370" inches

	<b>Measured</b>	<b>Allowable</b>
<b>Pa/Dt</b>	1.478"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.478"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	1 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\alpha</math> 2</b>	1 deg	$\alpha$ 1 and $\alpha$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta$ 1 and $\beta$ 2 $\leq$ 10.0
<b>z (inches)</b>	0.013"	0.125 inches
<b>w (inches)</b>	0.000"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: May 27, 2003

## Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove  
 Client: Air Testing Professionals  
 Job or Reference No.: 2027

Temperature Scale Used  Fahrenheit

Full Test

Celsius

Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	
100° F	100° F	
150° F	150° F	
200° F	200° F	
250° F	250° F	
300° F	300° F	
350° F	350° F	
400° F	400° F	
450° F	450° F	
500° F	500° F	
550° F	550° F	
600° F	600° F	

**ATP – Air Test Professionals, Inc.**  
**Pitot Tube Calibration**

**Reference: 40 CFR 60, Appendix A, Method 2, Section 2.1**

Probe Length/ID.: 5 ft. Type-S (w/probe)

External Tubing Diameter: 0.250" inches

Base to Opening Plane Distance (Pa): 0.370" inches

Base to Opening Plane Distance (Pa): 0.370" inches

	Measured	Allowable
<b>Pa/Dt</b>	1.478"	1.05 – 1.50 inches
<b>Pb/Dt</b>	1.478"	1.05 – 1.50 inches
<b>Angle <math>\alpha</math> 1</b>	1 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\alpha</math> 2</b>	1 deg	$\alpha 1$ and $\alpha 2 \leq 10.0$
<b>Angle <math>\beta</math> 1</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>Angle <math>\beta</math> 2</b>	0 deg	$\beta 1$ and $\beta 2 \leq 10.0$
<b>Z (inches)</b>	0.010"	0.125 inches
<b>W (inches)</b>	0.000"	0.031 inches
	If all criteria are met, Pitot Coefficient is 0.84	Pitot Coefficient: <b>0.84</b>

Calibrated By: Carlos Brown Date Calibrated: September 30, 2003

# Pyrometer Calibration Sheet

Pyrometer No.:001

Office: Spring Grove

Client: Air Testing Professionals

Job or Reference No.: 2032

Temperature Scale Used  Fahrenheit

Full Test

Celsius

Post Test

Calibration Reference Settings for Fahrenheit Scale	Pyrometer Reading	Calibration Reference Settings for Celsius Scale
50° F	50° F	
100° F	100° F	
150° F	150° F	
200° F	200° F	
250° F	250° F	
300° F	300° F	
350° F	350° F	
400° F	400° F	
450° F	450° F	
500° F	500° F	
550° F	550° F	
600° F	600° F	



(800) 532-7474

www.lintinc.com

Linde

### CERTIFICATE OF ANALYSIS

EPA PROTOCOL

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G1

NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig

**MANUFACTURED AND CERTIFIED AT:**

AGA Gas inc.  
Specialty Gas Division  
6421 Monclova Road  
Maumee, Ohio 43537  
419-893-7226

#### ANALYTICAL AND CYLINDER DATA:

Certified Component	Concentration and Uncertainty	Date of Certification
Carbon Monoxide	133 ± 1 ppm	1/28/2002

Analyzed for Reference Use Only	Concentration	Date of Analysis
N/A - Not Applicable for this Mixture	N/A	N/A

Production Number: 100046348

Cylinder Number: CC23930 *B158113*

Expiration Date: 1/28/2005

Cylinder Pressure (psi): 2000

Balance Gas: Nitrogen

CGA: 350

#### REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

Reference Standard Number	Cylinder Number	Concentration and Component	Expiration Date
GMIS	CC73603	507.7 ppm Carbon Monoxide	3/21/2002
GMIS	CC100557	50.56 ppm Carbon Monoxide	3/21/2002

#### INSTRUMENTATION DATA:

Instrument Model	Serial Number	Date of Last Calibration	Analytical Principle
Horiba VIA-510	569466011	1/28/2002	Non-Dispersive Infrared (NDIR)

Analytical Report Approved By: *[Signature]*

AGA

Member of the Linde Gas Group



(800) 532-7474

www.ieminc.com



### CERTIFICATE OF ANALYSIS

#### EPA PROTOCOL

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G1

**NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig**

**MANUFACTURED AND CERTIFIED AT:**

AGA Gas inc.  
Specialty Gas Division  
6421 Monclova Road  
Maumee, Ohio 43537  
419-893-7226

#### ANALYTICAL AND CYLINDER DATA:

Gasified Component	Concentration and Uncertainty	Date of Certification
Carbon Monoxide	181 ± 2 ppm	1/28/2002

Analyzed for Reference Use Only	Concentration	Date of Analysis
N/A - Not Applicable for this Mixture	N/A	N/A

Production Number: 100046349  
Cylinder Number: CC7389 8158128  
Expiration Date: 1/28/2005

Cylinder Pressure (psi): 2000  
Balance Gas: Nitrogen  
CGA: 350

#### REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

Reference Standard Number	Cylinder Number	Concentration and Component	Expiration Date
GMIS	CC73603	507.7 ppm Carbon Monoxide	3/21/2002
GMIS	CC100557	50.56 ppm Carbon Monoxide	3/21/2002

#### INSTRUMENTATION DATA:

Instrument Model	Serial Number	Date of Last Calibration	Analytical Principle
Horiba VIA-510	569466011	1/28/2002	Non-Dispersive Infrared (NDIR)

Analytical Report Approved By: *[Signature]*

AGA  
Member of the Linde Gas Group



(800) 532-7474

www.ieminc.com



### CERTIFICATE OF ANALYSIS EPA PROTOCOL

PERFORMED ACCORDING TO EPA-600/R-97/121, PROCEDURE G1

**NOTICE: THIS CYLINDER IS NOT TO BE USED WHEN PRESSURE IS UNDER 150 psig**

**MANUFACTURED AND CERTIFIED AT:**

AGA Gas inc.  
Specialty Gas Division  
6421 Monclova Road  
Maumee, Ohio 43537  
419-893-7226

#### ANALYTICAL AND CYLINDER DATA:

Certified Component	Concentration and Uncertainty	Date of Certification
Carbon Monoxide	316 ± 3 ppm	1/28/2002

Analyzed for Reference Use Only	Concentration	Date of Analysis
N/A - Not Applicable for this Mixture	N/A	N/A

Production Number: 100046344  
Cylinder Number: CC64182 *B158153*  
Expiration Date: 1/28/2005

Cylinder Pressure (psi): 2000  
Balance Gas: Nitrogen  
CGA: 350

#### REFERENCE STANDARDS DATA (TRACEABLE TO NIST AND NMI STANDARDS):

Reference Standard Number	Cylinder Number	Concentration and Component	Expiration Date
GMIS	CC73603	507.7 ppm Carbon Monoxide	3/21/2002
GMIS	CC100557	50.56 ppm Carbon Monoxide	3/21/2002

#### INSTRUMENTATION DATA:

Instrument Model	Serial Number	Date of Last Calibration	Analytical Principle
Horiba VIA-510	569466011	1/28/2002	Non-Dispersive Infrared (NDIR)

Analytical Report Approved By: *[Signature]*

AGA  
Member of the Linde Gas Group

### Certificate of Analysis EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

B160823

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6232	<b>Blend Tolerance:</b>	5 % Relative
EPA NO/N2 2-49 PPM		<b>Store/Use Temp:</b>	35 to 90 F
<b>Production #:</b>	100053732	<b>Blend Type:</b>	EPA Protocol
<b>Batch #:</b>	02499G2060YG	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC148344	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	7/23/2004	<b>CGA:</b>	660
<b>Shelf Life:</b>	24 months	<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	30	30.1 +/- 0.3 ppm	07/23/2002
7727-37-9	Nitrogen		Balance	07/23/2002

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A 2	NOx	30.3 ppm	07/23/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	CC34715 , GMIS	48.58 ppm	08/01/2003
10102-43-9	Nitric Oxide	CC120197 , GMIS	18.84 ppm	04/22/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba CLA-510SS	568093024	Chemiluminescence	07/22/2002

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Roy Yoder

**HIQ Analysis Certificate**

### Certificate of Analysis EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

B16407B

<b>Material:</b>	6599 EPA NO/N2 50-499 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100061999	<b>Store/Use Temp:</b>	35 to 90 F
<b>Lot #:</b>	02499A3080EI	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC35117	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	1/20/2005	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	24 months	<b>CGA:</b>	660
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	62	64.2 +/- 0.6 ppm	01/20/2003
7727-37-9	Nitrogen		Balance	01/20/2003

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A 2	NOx	64.2 ppm	01/20/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	ND11377 , LS	100.9 ppm	11/21/2007
10102-43-9	Nitric Oxide	CC120225 , GMIS	20.35 ppm	11/22/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba CLA-510SS	568093024	Chemiluminescence	12/30/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Jim Healy

**HIQ Analysis Certificate**

P16150B

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*  
AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*  
AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6681 EPA SO2/N2 100-3500 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100056268	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499H2260BI	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC150566	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	9/6/2004	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	24 months	<b>CGA:</b>	660
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	150	149 +/- 1 ppm	09/06/2002
7727-37-9	Nitrogen		Balance	09/06/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CC130050 , GMIS	101.6 ppm	07/26/2004
7446-09-5	Sulfur Dioxide	CC113475 , GMIS	500.4 ppm	06/20/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568279012	Non-Dispersive Infrared	08/05/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Jim Healy

**HIQ Analysis Certificate**

C 16152B

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6681 EPA SO2/N2 100-3500 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100056261	<b>Store/Use Temp:</b>	35 to 90 F
<b>Batch #:</b>	02499H2260BH	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC150552	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	9/6/2004	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	24 months	<b>CGA:</b>	660
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	300	309 +/- 3 ppm	09/06/2002
7727-37-9	Nitrogen		Balance	09/06/2002

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CC130050 , GMIS	101.6 ppm	07/26/2004
7446-09-5	Sulfur Dioxide	CC113475 , GMIS	500.4 ppm	06/20/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568279012	Non-Dispersive Infrared	08/05/2002

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

Analytical report approved by Jim Healy

*Jim R Healy*



**APPENDIX G**

---

CARL KOONTZ ASSOCIATES  
of Nashville, Tennessee

This is to acknowledge that

RONALD STAPERT

successfully participated in Visible Emissions  
training on SEP. 18 2003

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.


Carl Koontz  
Instructor

Visible Emissions Observations Form

RUN NUMBER

1

SOURCE NAME <b>NUCOR</b>				OBSERVATION DATE <b>11 20 03</b>				START TIME <i>Am</i> <b>11:23</b>		STOP TIME <i>Pm</i> <b>12:23</b>	
ADDRESS				sec				sec			
				min	0	15	30	min	0	15	
CITY		STATE	ZIP	1	0	0	0	31	0	0	
<b>CRAWFORDSVILLE</b>		<b>IN</b>		2	0	0	0	32	0	0	
PHONE		SOURCE ID NUMBER		3	0	0	0	33	0	0	
				4	0	0	0	34	0	0	
PROCESS EQUIPMENT		OPERATING MODE		5	0	0	0	35	0	0	
<b>CAST RIP</b>		<b>MAX</b>		6	0	0	0	36	0	0	
CONTROL EQUIPMENT		OPERATING MODE		7	0	0	0	37	0	0	
<b>BAG HOUSE</b>		<b>MAX</b>		8	0	0	0	38	0	0	
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>96" DIA</b>				9	0	0	0	39	0	0	
				10	0	0	0	40	0	0	
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER		11	0	0	0	41	0	0	
START <b>120</b> STOP		START <b>120</b> STOP		12	0	0	0	42	0	0	
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER		13	0	0	0	43	0	0	
START <b>360</b> STOP		START <b>45°</b> STOP		14	0	0	0	44	0	0	
DESCRIBE EMISSIONS <b>CLEAR</b>				15	0	0	0	45	0	0	
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>				16	0	0	0	46	0	0	
EMISSION COLOR <b>CLEAR</b>		PLUME TYPE: <u>CONTINUOUS</u>		17	0	0	0	47	0	0	
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		FUGITIVE <u>INTERMITTENT</u>		18	0	0	0	48	0	0	
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME:		19	0	0	0	49	0	0	
<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES		ATTACHED <input type="checkbox"/> DETACHED <input type="checkbox"/>		20	0	0	0	50	0	0	
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED				21	0	0	0	51	0	0	
START <b>10'</b> STOP <b>30'</b>				22	0	0	0	52	0	0	
DESCRIBE BACKGROUND <b>LIGHT BLUE</b>				23	0	0	0	53	0	0	
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>				24	0	0	0	54	0	0	
BACKGROUND COLOR <b>LIGHT BLUE</b>		SKY CONDITIONS <b>LIGHT BLUE</b>		25	0	0	0	55	0	0	
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		26	0	0	0	56	0	0	
WIND SPEED (MPH) <b>5</b>		WIND DIRECTION <b>STN</b>		27	0	0	0	57	0	0	
START <input checked="" type="checkbox"/> STOP <input type="checkbox"/>		START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		28	0	0	0	58	0	0	
AMBIENT TEMPERATURE (F)		WET BULB TEMP	REL PERCENT	29	0	0	0	59	0	0	
START <b>38</b> STOP <b>39</b>				30	0	0	0	60	0	0	



AVERAGE OPACITY FOR HIGHEST PERIOD **0**

NUMBER OF READINGS ABOVE **0** WERE **0**

RANGE OF OPACITY READINGS

MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE **Ronald Stapert** DATE **11-20-03**

ORGANIZATION  
**ATP - Air Test Professionals, Inc.**

CERTIFIED BY **CARL KOONTZ** DATE **9-18-03**

Comments:  
**STAEH RAN CLEAR**


- X = Emission Point
- = Observer's Position
- = Sun
- = Wind
- = Plume

Visible Emissions Observations Form

RUN NUMBER 1

12 19

SOURCE NAME NUCOR			OBSERVATION DATE 11 -20 -03				START TIME AM 11:23		STOP TIME 12:25PM			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0
CRAWFORDSVILLE	IN		2	0	0	0	0	32	0	0	0	0
PHONE	SOURCE ID NUMBER		3	0	0	0	0	33	0	0	0	0
PROCESS EQUIPMENT		OPERATING MODE	4	0	0	0	0	34	0	0	0	0
ROOF MONITOR			5	0	0	0	0	35	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE	6	0	0	0	0	36	0	0	0	0
			7	0	0	0	0	37	0	0	0	0
			8	0	0	0	0	38	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) RBC, ROOF VENTS 10 X 10 E 10 X 20			9	0	0	0	0	39	0	0	0	0
			10	0	0	0	0	40	0	0	0	0
HEIGHT ABOVE GROUND LEVEL		HEIGHT RELATIVE TO OBSERVER	11	0	0	0	0	41	0	0	0	0
START 130 STOP ✓		START 130 STOP ✓	12	0	0	0	0	42	0	0	0	0
DISTANCE FROM OBSERVER		DIRECTION FROM OBSERVER	13	0	0	0	0	43	0	0	0	0
START 350 STOP ✓		START 45° STOP ✓	14	0	0	0	0	44	0	0	0	0
DESCRIBE EMISSIONS CLEAR			15	0	0	0	0	45	0	0	0	0
START ✓ STOP			16	0	0	0	0	46	0	0	0	0
EMISSION COLOR CLEAR		PLUME TYPE: CONTINUOUS	17	0	0	0	0	47	0	0	0	0
START ✓ STOP ✓		FUGITIVE INTERMITTENT	18	0	0	0	0	48	0	0	0	0
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME:	19	0	0	0	0	49	0	0	0	0
NO YES ✓		ATTACHED DETACHED	20	0	0	0	0	50	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			21	0	0	0	0	51	0	0	0	0
START 10 STOP 30			22	0	0	0	0	52	0	0	0	0
DESCRIBE BACKGROUND LIGHT BLUE			23	0	0	0	0	53	0	0	0	0
START ✓ STOP ✓			24	0	0	0	0	54	0	0	0	0
BACKGROUND COLOR LIGHT BLUE		SKY CONDITIONS LIGHT BLUE	25	0	0	0	0	55	0	0	0	0
START ✓ STOP ✓		START ✓ STOP ✓	26	0	0	0	0	56	0	0	0	0
WIND SPEED (MPH) 5		WIND DIRECTION S-N	27	0	0	0	0	57	0	0	0	0
START ✓ STOP ✓		START ✓ STOP ✓	28	0	0	0	0	58	0	0	0	0
AMBIENT TEMPERATURE (F)		WET BULB TEMP	29	0	0	0	0	59	0	0	0	0
START 38 STOP 39		REL. HUMIDITY	30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD 0

NUMBER OF READINGS ABOVE WERE 0

RANGE OF OPACITY READINGS MINIMUM 0 MAXIMUM 0

OBSERVER'S NAME (PRINT) RONALD STAPERT

OBSERVER'S SIGNATURE Ronald Stapert DATE 11 -20 -03

ORGANIZATION ATP - Air Test Professionals, Inc.

CERTIFIED BY CARL KOONTZ DATE 9-18-03

Comments: ROOF VENTS WERE CLEAR

Visible Emissions Observations Form

RUN NUMBER

2

SOURCE NAME  
**NUCOR**

OBSERVATION DATE  
**11 21 - 03**

START TIME **Am**  
**8:50**

STOP TIME **Am**  
**9:50**

ADDRESS

sec										
min	0	15	30	45	min	0	15	30	45	

CITY  
**CRAWFORDSVILLE**

STATE  
**IN**

ZIP

1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0

PHONE

SOURCE ID NUMBER

3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0

PROCESS EQUIPMENT  
**CAST RIP**

OPERATING MODE  
**MAX**

5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0

CONTROL EQUIPMENT  
**BAG HOUSE**

OPERATING MODE  
**MAX**

7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0

DESCRIBE EMISSION POINT (Stack Exit Dimensions) **9' DIA**

9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0

HEIGHT ABOVE GROUND LEVEL  
START **120'** STOP

HEIGHT RELATIVE TO OBSERVER  
START **120'** STOP

11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0

DISTANCE FROM OBSERVER  
START **360'** STOP

DIRECTION FROM OBSERVER  
START **30°** STOP

13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0

DESCRIBE EMISSIONS **CLEAR**  
START STOP

15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0

EMISSION COLOR **CLEAR**  
START STOP

PLUME TYPE: **CONTINUOUS**  
FUGITIVE INTERMITTENT

17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0

WATER DROPLETS PRESENT  
**NO** YES

IF WATER DROPLET PLUME:  
**ATTACHED** DETACHED

19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0

POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED  
START **0** STOP **30**

21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0

DESCRIBE BACKGROUND **LIGHT BLUE**  
START STOP

23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0

BACKGROUND COLOR **LIGHT BLUE**  
START STOP

SKY CONDITIONS **LIGHT BLUE**  
START STOP

25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0

WIND SPEED (MPH) **5**  
START STOP


WIND DIRECTION **SE TO NE**  
START STOP

27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0

AMBIENT TEMPERATURE (F)  
START **48°** STOP **49°**

WET BULB TEMPERATURE PERCENT

29	0	0	0	0	59	0	0	0	0
30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD **0**

NUMBER OF READINGS ABOVE WERE **0**

RANGE OF OPACITY READINGS  
MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE  
**Ronald Stapert**

DATE  
**10 - 21 - 03**

ORGANIZATION  
**ATP - Air Test Professionals, Inc.**


CERTIFIED BY  
**CARL KOONTZ**

DATE  
**9-18-03**

Comments:  
**STACK PAN CLEAR**

- X = Emission Point
- ☐ = Observer's Position
- ☼ = Sun
- = Wind
- - - = Plume

SOURCE NAME <b>NUCOR</b>			OBSERVATION DATE <b>11 21 03</b>				START TIME <b>Am</b> <b>8:50</b>		STOP TIME <b>Am</b> <b>9:50</b>			
ADDRESS			sec				sec					
			min	0	15	30	45	min	0	15	30	45
CITY	STATE	ZIP	1	0	0	0	0	31	0	0	0	0
<b>CRAWFORDSVILLE</b>	<b>IN</b>		2	0	0	0	0	32	0	0	0	0
PHONE	SOURCE ID NUMBER		3	0	0	0	0	33	0	0	0	0
PROCESS EQUIPMENT		OPERATING MODE	4	0	0	0	0	34	0	0	0	0
<b>ROOF MONITOR</b>			5	0	0	0	0	35	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE	6	0	0	0	0	36	0	0	0	0
			7	0	0	0	0	37	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions)			8	0	0	0	0	38	0	0	0	0
<b>ROOF VENTS 10'x60' And 10'x30'</b>			9	0	0	0	0	39	0	0	0	0
HEIGHT ABOVE GROUND LEVEL	HEIGHT RELATIVE TO OBSERVER		10	0	0	0	0	40	0	0	0	0
START <b>130</b> STOP <input checked="" type="checkbox"/>	START <b>130</b> STOP <input checked="" type="checkbox"/>		11	0	0	0	0	41	0	0	0	0
DISTANCE FROM OBSERVER	DIRECTION FROM OBSERVER		12	0	0	0	0	42	0	0	0	0
START <b>350</b> STOP <input checked="" type="checkbox"/>	START <b>60°</b> STOP <input checked="" type="checkbox"/>		13	0	0	0	0	43	0	0	0	0
DESCRIBE EMISSIONS <b>CLEAR</b>			14	0	0	0	0	44	0	0	0	0
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>			15	0	0	0	0	45	0	0	0	0
EMISSION COLOR <b>CLEAR</b>	PLUME TYPE: <b>CONTINUOUS</b>		16	0	0	0	0	46	0	0	0	0
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>	FUGITIVE <input type="checkbox"/> INTERMITTENT <input type="checkbox"/>		17	0	0	0	0	47	0	0	0	0
WATER DROPLETS PRESENT	IF WATER DROPLET PLUME:		18	0	0	0	0	48	0	0	0	0
<input checked="" type="checkbox"/> NO YES <input type="checkbox"/>	ATTACHED <input checked="" type="checkbox"/> DETACHED <input type="checkbox"/>		19	0	0	0	0	49	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			20	0	0	0	0	50	0	0	0	0
START <input type="checkbox"/> STOP <b>30'</b>			21	0	0	0	0	51	0	0	0	0
DESCRIBE BACKGROUND <b>LIGHT BLUE</b>			22	0	0	0	0	52	0	0	0	0
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>			23	0	0	0	0	53	0	0	0	0
BACKGROUND COLOR <b>LIGHT BLUE</b>	SKY CONDITIONS <b>LIGHT BLUE</b>		24	0	0	0	0	54	0	0	0	0
START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>	START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		25	0	0	0	0	55	0	0	0	0
WIND SPEED (MPH)	WIND DIRECTION <b>SE to NE</b>		26	0	0	0	0	56	0	0	0	0
START <b>5</b> STOP <input checked="" type="checkbox"/>	START <input checked="" type="checkbox"/> STOP <input checked="" type="checkbox"/>		27	0	0	0	0	57	0	0	0	0
AMBIENT TEMPERATURE (F)	WET BULB TEMPERATURE	REL. HUMIDITY	28	0	0	0	0	58	0	0	0	0
START <b>48°</b> STOP <b>50°</b>			29	0	0	0	0	59	0	0	0	0
SOURCE LAYOUT SKETCH			30	0	0	0	0	60	0	0	0	0



AVERAGE OPACITY FOR HIGHEST PERIOD <b>0</b>		NUMBER OF READINGS ABOVE WERE <b>0</b>	
RANGE OF OPACITY READINGS			
MINIMUM <b>0</b>		MAXIMUM <b>0</b>	
OBSERVER'S NAME (PRINT) <b>RONALD STAPERT</b>			
OBSERVER'S SIGNATURE <i>Ronald Stapert</i>		DATE <b>11-21-03</b>	
ORGANIZATION <b>ATP - Air Test Professionals, Inc.</b>			
CERTIFIED BY <b>CARL KOONZ</b>		DATE <b>9-18-05</b>	
Comments: <b>VENTS WERE CLEAR</b>			

Visible Emissions Observations Form


RUN NUMBER

3

SOURCE NAME <b>NUCOR</b>			OBSERVATION DATE <b>11-21-03</b>				START TIME <b>PM</b> <b>4:38</b>		STOP TIME <b>PM</b> <b>5:38</b>			
ADDRESS			sec				sec					
CITY <b>CRAWFORDSVILLE</b>			min	0	15	30	45	min	0	15	30	45
STATE <b>IN</b>		ZIP	1	0	0	0	0	31	0	0	0	0
PHONE		SOURCE ID NUMBER	2	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT <b>CAST RIP</b>		OPERATING MODE <b>MAX</b>	3	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT <b>BACHOUSE</b>		OPERATING MODE <b>MAX</b>	4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>9" DIA</b>			5	0	0	0	0	35	0	0	0	0
HEIGHT ABOVE GROUND LEVEL			6	0	0	0	0	36	0	0	0	0
START <b>120</b> STOP			7	0	0	0	0	37	0	0	0	0
HEIGHT RELATIVE TO OBSERVER			8	0	0	0	0	38	0	0	0	0
START <b>120</b> STOP			9	0	0	0	0	39	0	0	0	0
DISTANCE FROM OBSERVER			10	0	0	0	0	40	0	0	0	0
START <b>400</b> STOP			11	0	0	0	0	41	0	0	0	0
DIRECTION FROM OBSERVER			12	0	0	0	0	42	0	0	0	0
START <b>30</b> STOP			13	0	0	0	0	43	0	0	0	0
DESCRIBE EMISSIONS <b>CLEAR</b>			14	0	0	0	0	44	0	0	0	0
START			15	0	0	0	0	45	0	0	0	0
STOP			16	0	0	0	0	46	0	0	0	0
EMISSION COLOR <b>CLEAR</b>		PLUME TYPE: CONTINUOUS	17	0	0	0	0	47	0	0	0	0
START		FUGITIVE INTERMITTENT	18	0	0	0	0	48	0	0	0	0
STOP			19	0	0	0	0	49	0	0	0	0
WATER DROPLETS PRESENT		IF WATER DROPLET PLUME:	20	0	0	0	0	50	0	0	0	0
<input checked="" type="checkbox"/> NO <input type="checkbox"/> YES		<input checked="" type="checkbox"/> ATTACHED <input type="checkbox"/> DETACHED	21	0	0	0	0	51	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED			22	0	0	0	0	52	0	0	0	0
START <b>0</b> STOP <b>30</b>			23	0	0	0	0	53	0	0	0	0
DESCRIBE BACKGROUND <b>LIGHT BLUR</b>			24	0	0	0	0	54	0	0	0	0
START			25	0	0	0	0	55	0	0	0	0
STOP <b>GRAY</b>			26	0	0	0	0	56	0	0	0	0
BACKGROUND COLOR <b>LIGHT BLUR</b>		SKY CONDITIONS <b>LIGHT BLUR</b>	27	0	0	0	0	57	0	0	0	0
START		START	28	0	0	0	0	58	0	0	0	0
STOP <b>GRAY</b>		STOP <b>GRAY</b>	29	0	0	0	0	59	0	0	0	0
WIND SPEED (MPH) <b>5</b>		WIND DIRECTION <b>STON</b>	30	0	0	0	0	60	0	0	0	0
START		START	AMBIENT TEMPERATURE (F)			WET BULB TEMP		REL. HUMIDITY				
STOP		STOP	START <b>60</b> STOP <b>56</b>									

508

STACK



Draw North Arrow

AVERAGE OPACITY FOR HIGHEST PERIOD: 0

NUMBER OF READINGS ABOVE WERE: 0

RANGE OF OPACITY READINGS: MINIMUM 0, MAXIMUM 0

OBSERVER'S NAME (PRINT): **RONALD STAPERT**

OBSERVER'S SIGNATURE: *Ronald Stapert* DATE: **11-21-03**

ORGANIZATION: **ATP - Air Test Professionals, Inc.**


CERTIFIED BY: **CARL KOONTZ** DATE: **9-18-03**

Comments: **STACK RAN CLEAR**

- X = Emission Point
- = Observer's Position
- ☉ = Sun
- ↖ = Wind
- || = Plume

SOURCE NAME <b>NUCOR</b>			OBSERVATION DATE <b>11 21 03</b>				START TIME <b>4:38 PM</b>		STOP TIME <b>5:38 PM</b>			
ADDRESS			sec				sec					
CITY <b>CRAWFORDSVILLE</b>			min	0	15	30	45	min	0	15	30	45
STATE <b>IN</b>		ZIP	1	0	0	0	0	31	0	0	0	0
PHONE <b>CRAWFORDSVILLE</b>		SOURCE ID NUMBER	2	0	0	0	0	32	0	0	0	0
PROCESS EQUIPMENT <b>ROOF MONITOR</b>		OPERATING MODE	3	0	0	0	0	33	0	0	0	0
CONTROL EQUIPMENT		OPERATING MODE	4	0	0	0	0	34	0	0	0	0
DESCRIBE EMISSION POINT (Stack Exit Dimensions) <b>ROOF VENTS 10'x6' AND 10'x20'</b>			5	0	0	0	0	35	0	0	0	0
HEIGHT ABOVE GROUND LEVEL START <b>150</b> STOP <b>150</b>		HEIGHT RELATIVE TO OBSERVER START <b>150</b> STOP <b>150</b>	6	0	0	0	0	36	0	0	0	0
DISTANCE FROM OBSERVER START <b>400</b> STOP <b>400</b>		DIRECTION FROM OBSERVER START <b>30</b> STOP <b>30</b>	7	0	0	0	0	37	0	0	0	0
DESCRIBE EMISSIONS <b>CLEAR</b>			8	0	0	0	0	38	0	0	0	0
START <b>✓</b> STOP <b>✓</b>			9	0	0	0	0	39	0	0	0	0
EMISSION COLOR <b>CLEAR</b>		PLUME TYPE: <b>CONTINUOUS</b>	10	0	0	0	0	40	0	0	0	0
START <b>✓</b> STOP <b>✓</b>		FUGITIVE <b>INTERMITTENT</b>	11	0	0	0	0	41	0	0	0	0
WATER DROPLETS PRESENT <b>NO</b> YES		IF WATER DROPLET PLUME: <b>ATTACHED</b> DETACHED	12	0	0	0	0	42	0	0	0	0
POINT IN THE PLUME AT WHICH OPACITY WAS DETERMINED START <b>0</b> STOP <b>30</b>			13	0	0	0	0	43	0	0	0	0
DESCRIBE BACKGROUND <b>LIGHT BLUE</b>			14	0	0	0	0	44	0	0	0	0
START <b>✓</b> STOP <b>GRAY</b>			15	0	0	0	0	45	0	0	0	0
BACKGROUND COLOR <b>LIGHT BLUE</b>		SKY CONDITIONS <b>LIGHT BLUE</b>	16	0	0	0	0	46	0	0	0	0
START <b>✓</b> STOP <b>GRAY</b>		START <b>✓</b> STOP <b>GRAY</b>	17	0	0	0	0	47	0	0	0	0
WIND SPEED (MPH) <b>5</b>		WIND DIRECTION <b>S-N</b>	18	0	0	0	0	48	0	0	0	0
START <b>✓</b> STOP		START <b>✓</b> STOP	19	0	0	0	0	49	0	0	0	0
AMBIENT TEMPERATURE (F) START <b>60</b> STOP <b>56</b>		WET BULB TEMP REL. HUMIDITY	20	0	0	0	0	50	0	0	0	0
			21	0	0	0	0	51	0	0	0	0

VENTS



AVERAGE OPACITY FOR HIGHEST PERIOD **0**

NUMBER OF READINGS ABOVE **0** WERE **0**

RANGE OF OPACITY READINGS  
MINIMUM **0** MAXIMUM **0**

OBSERVER'S NAME (PRINT)  
**RONALD STAPERT**

OBSERVER'S SIGNATURE  
*Ronald Stapert* DATE **11-21-03**

ORGANIZATION  
**ATP - Air Test Professionals, Inc.**

CERTIFIED BY  
**CARL KOONTZ** DATE **9-18-03**

Comments:  
**VENTS WERE CLEAR**

- X = Emission Point
- = Observer's Position
- = Sun
- = Wind
- = Plume

**APPENDIX H**

---

**COMPLIANCE TEST PROTOCOL  
INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT**

Date Prepared: Oct 6, 2003 Proposed Test Date November 10-12, 2003

Plant Address and Location: 4537 S. Nucor Road, Crawfordsville, Indiana

1. Source Information  
 AFS: Id Number: 107-12143-00038  
 Company: Nucor Steel  
 Mail Address: 4537 S. Nucor Road  
 City: Crawfordsville, Indiana Zip: 47933  
 Co. Contact: Mark Washer Phone: (812) 364-1323

AGENCY USE ONLY Date Rec'd: \_\_\_\_\_  
 Inspector: \_\_\_\_\_ Reviewer: \_\_\_\_\_ Date Appr: \_\_\_\_\_

2. Tester Information  
 Name: Air Test Professionals, Inc.  
 Address: 1201 N. Graham Ave.  
 Contact: Carlos M. Brown Phone: 317-345-1723  
 Pre-Test Inspection Complete? Yes

3. Process Information  
 Unit to Test: Strip Caster Line  
 Max. Rated Capacity: 135 tons per hour  
 Proposed Operating Speed: 95% of max  
 Pollution Control Equipment: LMS Baghouse  
 Process Description: Molds molten grades of carbon steel into rolled steel of various widths and thicknesses.


4. Test Information  
 Fuel Type: Natural Gas

Methods	Moisture/Flow	# Runs	Time/Run
Methods 1-4		3	60 min
Method 5	Particulate	3	60 min
Method 6C	SO2	3	60 min
Method 7E	NOx	3	60 min
Method 9	Opacity	3	60 min
Method 10	CO	3	60 min
Method 12	Lead	3	60 min
Other Testing:	M202	3	60 min

Check program if applicable:  
 FESOP: \_\_\_\_\_  
 Title V: X  
 SSOA: \_\_\_\_\_

5. Sampling Strategy  
 a. Describe any deviations from the standard test method.  
None  
 b. Describe method used to determine quantity of raw materials  
Plant personnel will keep record production

6. Sample Site Location  
 Does sample port location meet 40 CFR 60, Appx A, Method 1  
 Section 1.2 requirements: Yes/No: YES If No, Explain \_\_\_\_\_



Number of sample points for MS: 24  
 Diameter at sample site: \_\_\_\_\_ Stack height: \_\_\_\_\_  
 Approx. stack gas flow (ACFM): \_\_\_\_\_  
 Approx. gas temp. (degF): \_\_\_\_\_  
 Approx. gas moisture (%): approx 2%

Reason for test:  
 State Agreed Order: Yes/No: \_\_\_\_\_ Operating permit: Yes/No: Yes  
 Construction Permit: Yes/No: \_\_\_\_\_ Compliance w 326  
 NSPS 40 CFR 60 Subpart: \_\_\_\_\_ Other \_\_\_\_\_  
 Title V: \_\_\_\_\_  
 Other (i.e. EPA, CD, state, 114) \_\_\_\_\_

326 IAC 3-2.1 requires this completed form and fee to be submitted 35 days prior to proposed test date to:  
 (FEE NOT APPLICABLE IF FESOP OR TITLE V)

Compliance Data Section  
 Office of Air Management  
 Indiana Department of Environmental Management  
 100 North Senate  
 PO BOX 6015  
 Indianapolis, IN 46206-6015

Questions may be directed to 317-232-8338, FAX: 317-233-6865

**APPENDIX I**

---

1<sup>st</sup> Stack Test (1 hour)

Sequence # 1323 Heat # 137005 + 432783

119 + 106

2nd Stack Test (1 hour)

Sequence # 1325 Heat # 232808

119 + 119

3rd attempt later in cast was aborted

3rd Stack Test (1 hour)

Sequence # 1326 Heat # 432812

# LMF HEAT RECORD

137005

HEAT NO: <u>232785</u>	AIM GRADE: <u>100SS1</u>	DATE: <u>1/19</u>	POWER
WE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>GA</u>	KWH INITIAL: _____
LADLE NO: <u>17</u>	FINISH GRADE: _____	1st OP: <u>ARC</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>119</u>	<u>392</u>	2nd OP: _____	KWH USED: _____

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESH
LMF -1		61	46	005	002	26								0051	52	
LMF -2		014	05	006	003	35								0059	0079	
LMF -3		054	61	006	006	29								0013	0057	
LMF -4																

SLAG  
DEPTH  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
COLOR  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
TEXTURE  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>8:05</u>	<u>8:08</u>	<u>3</u>
	<u>8:09</u>	<u>8:19</u>	<u>1</u>
	<u>8:24</u>	<u>8:39</u>	_____
	<u>8:44</u>	<u>8:51</u>	_____
	<u>10:02</u>	<u>10:06</u>	_____
	<u>10:26</u>	<u>10:30</u>	_____
	<u>10:42</u>	<u>10:46</u>	_____
	<u>11:10</u>	<u>11:13</u>	_____

LADLE ADDITION	TIME	AMOUNT
<u>MNS!</u>	<u>8:25</u>	<u>600</u>
<u>Fes!</u>		
AI SHOT		
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		<u>600</u>

ARGON LANCE ON  
\_\_\_\_\_

TIME/TEMP/OXYGEN	PI
<u>8:21</u>	<u>2820</u> °F _____
<u>8:41</u>	<u>2968</u> °F _____
<u>10:10</u>	<u>2916</u> °F <u>13.3</u> P
<u>11:09</u>	<u>3019</u> °F <u>79.9</u> P
<u>11:15</u>	<u>3030</u> °F <u>79.5</u> P
	°F _____
	°F _____
	°F _____
	°F _____

DEPARTURE  
TIME 11:20 TEMPERATURE 3025  
11:20

REMARKS  
Seq 1322 #2 1323 #1 8 pipes 2057 OKY  
H= 2.5 8:43

8:55 set out 3000

DRAINED

# LMF HEAT RECORD

HEAT NO: 432183      AIM GRADE: 100SS1      DATE: 11/20      POWER  
 FCE (E OR W): \_\_\_\_\_      LIQUIDUS: \_\_\_\_\_      MELTER: SG      KWH INITIAL: \_\_\_\_\_  
 LADLE NO: 15      FINISH GRADE: \_\_\_\_\_      1st OP: DC      KWH FINAL: \_\_\_\_\_  
 WEIGHT TAPPED: 106      2nd OP: \_\_\_\_\_      KWH USED: \_\_\_\_\_

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RES
LMF -1		<u>051</u>	<u>63</u>	<u>011</u>	<u>007</u>	<u>27</u>								<u>0015</u>	<u>0086</u>	
LMF -2																
LMF -3																
LMF -4																

SLAG  
 DEPTH  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
 COLOR  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
 TEXTURE  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>9:13</u>	<u>9:16</u>	<u>1</u>
	<u>9:21</u>	<u>9:28</u>	_____
	<u>11:24</u>	<u>11:50</u>	_____
	<u>12:15</u>	<u>12:18</u>	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____

ARGON LANCE ON  
 \_\_\_\_\_  
 \_\_\_\_\_

TIME	TEMP/OXYGEN	PPI
<u>9:20</u>	<u>2968</u> °F	<u>49.9</u>
<u>9:30</u>	<u>3047</u> °F	<u>55.5</u>
<u>11:51</u>	<u>2992</u> °F	<u>38.4</u>
<u>12:33</u>	<u>3013</u> °F	<u>72.5</u>
_____	_____ °F	_____
_____	_____ °F	_____
_____	_____ °F	_____
_____	_____ °F	_____
_____	_____ °F	_____

LADLE ADDITION	TIME	AMOUNT
<u>FESI</u>		<u>100</u>
AI SHOT		
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		

DEPARTURE  
 TIME 12:50      TEMPERATURE 3009

REMARKS

H 3.2 9:19 - Hyd 3:5 @ 12:02      5 pipes 6/3 oxy  
Log 1323 #2  
Out At 9:35 3050  
Tailed out 65 TON LEFT BACK

# NUCOR STEEL - CRAWFORDSVILLE

## LMF HEAT RECORD

1325-1

HEAT NO: <u>232808</u>	AIM GRADE: <u>M0551</u>	DATE: <u>11/20</u>	POWER
FCE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>6A</u>	KWH INITIAL: _____
LADLE NO: <u>16</u>	FINISH GRADE: _____	1st OP: <u>Dave</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>119</u>	<u>398.500</u>	2nd OP: _____	KWH USED: _____

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1		008	48	009	005	25								0055	54	
LMF -2		048	61	009	007	29								0010	52	
LMF -3		<u>+50'</u>														
LMF -4																

SLAG

DEPTH

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

COLOR

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

TEXTURE

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	
FINISH TAP	_____	_____	
LADLE ON CAR	_____	_____	
IND STIR ON	_____	_____	
UNDER ROOF	_____	_____	
POWER ON	<u>549</u>	<u>552</u>	<u>3</u> TAP NO.
	<u>554</u>	<u>604</u>	<u>1</u> TAP NO.
	<u>606</u>	<u>626</u>	TAP NO.
	<u>631</u>	<u>636</u>	TAP NO.
	<u>720</u>	<u>733</u>	TAP NO.
	<u>735</u>	<u>738</u>	TAP NO.
	<u>741</u>	<u>744</u>	TAP NO.
	<u>815</u>	<u>817</u>	TAP NO.

ARGON LANCE ON

LADLE ADDITION	TIME	AMOUNT
MAs:		500
Fes:		
AI SHOT		
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca SI WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		600/50

TIME	TEMP/OXYGEN	PPM
<u>6:05</u>	<u>2809</u> °F	_____ PPM
<u>6:30</u>	<u>2934</u> °F	_____ PPM
<u>6:46</u>	<u>2966</u> °F	_____ PPM
<u>7:15</u>	<u>2991</u> °F	_____ PPM
<u>7:39</u>	<u>3008</u> °F	<u>23.3</u> PPM <sub>2</sub>
<u>7:58</u>	<u>3019</u> °F	<u>22.7</u> PPM <sub>2</sub>
<u>8:14</u>	<u>3010</u> °F	<u>674</u> PPM <sub>2</sub>

DEPARTURE TEMPERATURE 3020

TIME ~~8:52~~  
8:10

REMARKS 1325-1 AOD 35

OXY 2520

*D. Daniel*

**NUCOR STEEL - CRAWFORDSVILLE**  
**LMF HEAT RECORD**

1325-2

HEAT NO: <u>2328</u>	AIM GRADE: <u>100SS1</u>	DATE: <u>11/20</u>	POWER
FCE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>6 H</u>	KWH INITIAL: _____
LADLE NO: <u>15</u>	FINISH GRADE: _____	1st OP: <u>Jue</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>119</u>		2nd OP: _____	KWH USED: _____

408,000

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1		007	45	007	002	25								0067	0044	
LMF -2		045	61	007	003	29								0016	46	
LMF -3		+														
LMF -4		75														

SLAG

DEPTH

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

COLOR

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

TEXTURE

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>848</u>	<u>1051</u>	<u>3</u>
	<u>852</u>	<u>802</u>	<u>1</u>
	<u>904</u>	<u>919</u>	_____
	<u>921</u>	<u>925</u>	_____
	<u>943</u>	<u>945</u>	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____

LADLE ADDITION	TIME	AMOUNT
<u>msi</u>	<u>9:07</u>	<u>600</u>
<u>Fes1</u>		
AI SHOT		
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca Si WIRE (FT)		
Fa Ca WIRE (FT)		
C WIRE	<u>9:26 9:49</u>	<u>650/75</u>

ARGON LANCE ON

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

TIME/TEMP/OXYGEN			
<u>903</u>	<u>2826</u>	°F	<u>6.6</u> PPM
<u>920</u>	<u>2969</u>	°F	PPM
<u>947</u>	<u>3041</u>	°F	<u>82.2</u> PPM 2
_____	_____	°F	PPM
_____	_____	°F	PPM
_____	_____	°F	PPM
_____	_____	°F	PPM
_____	_____	°F	PPM
_____	_____	°F	PPM

DEPARTURE

TIME 952 TEMPERATURE 3030

1325-2      REMARKS      A0036

oxy 2513

*Diamed*

1325-3

# NUCOR STEEL - CRAWFORDSVILLE LMF HEAT RECORD

1325-3

HEAT NO: 232812      AIM GRADE: 1005S1      DATE: 11/20      POWER  
 FCE (E OR W): \_\_\_\_\_      LIQUIDUS: \_\_\_\_\_      MELTER: 6 B      KWH INITIAL: \_\_\_\_\_  
 LADLE NO: 17      FINISH GRADE: \_\_\_\_\_      1st OP: Jrc      KWH FINAL: \_\_\_\_\_  
 WEIGHT TAPPED: 119      2nd OP: \_\_\_\_\_      KWH USED: \_\_\_\_\_

SAMPLE	TIME	C	Mn	P	S	SI	Cu	NI	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1		010	.45	008	004	.19								205	.48	
LMF -2		049	.48	008	004	.28								0040	.50	
LMF -3		057	.61	008	005	.34								0026	.52	
LMF -4																

SLAG  
 DEPTH  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
 COLOR  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
 TEXTURE  
 ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT      TIME START      TIME END  
 FINISH TAP \_\_\_\_\_  
 LADLE ON CAR \_\_\_\_\_  
 INO STIR ON \_\_\_\_\_  
 UNDER ROOF \_\_\_\_\_  
 POWER ON  
10:18      10:25      3      TAP NO.  
10:24      10:28      1      TAP NO.  
10:38      10:37      \_\_\_\_\_      TAP NO.  
10:36      10:48      1      TAP NO.  
10:55      11:00      1      TAP NO.  
11:02      11:00      \_\_\_\_\_      TAP NO.  
 \_\_\_\_\_      \_\_\_\_\_      \_\_\_\_\_      TAP NO.  
 \_\_\_\_\_      \_\_\_\_\_      \_\_\_\_\_      TAP NO.

LADLE ADDITION	TIME	AMOUNT
MnS		250
FeS		200/150
LIME		500
Al SHOT		
STD FeMn		
MED C FeMn		
Al WIRE (FT)		
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		700'

ARGON LANCE ON  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 TIME/TEMP/OXYGEN  
10:34      2832 °F      6.6 PPM  
10:54      2942 °F      10.2 PPM  
11:00      2964 °F      12.8 PPM  
11:08      2990 °F      13.2 PPM  
 \_\_\_\_\_ °F      \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F      \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F      \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F      \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F      \_\_\_\_\_ PPM  
 DEPARTURE  
 TIME 3021      TEMPERATURE 73.2      25mV  
004      2613

REMARKS  
1325-3      A0037  
 \_\_\_\_\_  
104 TONS TO RETREAT  
 \_\_\_\_\_  
 \_\_\_\_\_



1326-2

18

# NUCOR STEEL - CRAWFORDSVILLE LMF HEAT RECORD



HEAT NO: 252819  
FCE (E OR W): \_\_\_\_\_  
LADLE NO: 16

AIM GRADE: 100551  
LIQUIDUS: \_\_\_\_\_  
FINISH GRADE: \_\_\_\_\_  
WEIGHT TAPPED: 120

DATE: 11/20  
MELTER: T.M.  
1st OP: RD.  
2nd OP: \_\_\_\_\_

POWER  
KWH INITIAL: \_\_\_\_\_  
KWH FINAL: \_\_\_\_\_  
KWH USED: \_\_\_\_\_

SAMPLE	TIME	C	Mn	P	S	SI	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF-1		013	.42	010	007	.24								0048	71	
LMF-2	5:20	053	.65	010	008	.55								0048	70	
LMF-3		050	.63	010	008	.50								0048	73	
LMF-4																

SLAG N-41

DEPTH  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

COLOR  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

TEXTURE  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	4:46	4:49	3
	4:50	5:02	8
	5:05	5:15	1
	5:33	5:46	1
	6:00	6:04	1
	_____	_____	_____
	_____	_____	_____

LADLE ADDITION	TIME	AMOUNT
LCFeMnS		750#
Fes		50#
Line		500#
Al SHOT		
STD FeMn		
MED C FeMn		
Al WIRE (FT)		
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		650'

ARGON LANCE ON

TIME	TEMP	OXYGEN	PPM
5:08	2892	°F	9.9
6:20	2752	°F	15.1
_____	_____	°F	_____
_____	_____	°F	_____
_____	_____	°F	_____
_____	_____	°F	_____
_____	_____	°F	_____
_____	_____	°F	_____

DEPARTURE  
TIME \_\_\_\_\_ TEMPERATURE \_\_\_\_\_

3008 72.6 28mV

### REMARKS

Oxy 2663

105 TON TO Retreat

TUNDISH Slidgate Washed Out

1327

# NUCOR STEEL - CRAWFORDSVILLE (RETREAT) LMF HEAT RECORD

HEAT NO: <u>452819</u>	AIM GRADE: <u>1005S1</u>	DATE: <u>11/20</u>	POWER
FCE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>T.M</u>	KWH INITIAL: _____
LADLE NO: <u>16</u>	FINISH GRADE: _____	1st OP: <u>RD.</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>105</u>		2nd OP: _____	KWH USED: _____

SAMPLE	TIME	C	Mn	P	S	SI	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1	<u>7:44</u>	<u>062</u>	<u>.66</u>	<u>010</u>	<u>007</u>	<u>.29</u>								<u>0025</u>	<u>77</u>	
LMF -2		<u>077</u>	<u>63</u>	<u>01</u>	<u>007</u>	<u>28</u>								<u>001</u>	<u>76</u>	
LMF -3																
LMF -4																

SLAG

DEPTH

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

COLOR

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

TEXTURE

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>7:15</u>	<u>7:25</u>	<u>1</u>
	<u>7:39</u>	<u>7:42</u>	<u>1</u>
	<u>8:37</u>	<u>8:40</u>	<u>1</u>
	<u>9:12</u>	<u>9:16</u>	<u>1</u>
	<u>9:44</u>	<u>9:48</u>	<u>1</u>
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____

LADLE ADDITION	TIME	AMOUNT
<u>fesi</u>		<u>100#</u>
AI SHOT		
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca SI WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		

ARGON LANCE ON  
6 @ 60 SCFM

TIME	TEMP/OXYGEN	PPM
<u>7:40</u>	<u>3033</u> °F	<u>25.5</u> PPM
<u>8:42</u>	<u>2986</u> °F	<u>20.9</u> PPM
<u>9:17</u>	<u>2978</u> °F	<u>18.6</u> PPM
<u>9:47</u>	<u>2972</u> °F	<u>17.5</u> PPM
_____	_____ °F	_____ PPM
_____	_____ °F	_____ PPM
_____	_____ °F	_____ PPM
_____	_____ °F	_____ PPM
_____	_____ °F	_____ PPM

DEPARTURE  
TIME 1015 TEMPERATURE 3000 71.  
30 m

REMARKS

(SLIPPED ALL 3 STICKS)

18 tons in pot

1328-1

NUCOR STEEL - CRAWFORDSVILLE  
LMF HEAT RECORD

HEAT NO: 232832 AIM GRADE: 100S1 DATE: 11/21 POWER  
 FCE (E OR W): \_\_\_\_\_ LIQUIDUS: \_\_\_\_\_ MELTER: KW KWH INITIAL: \_\_\_\_\_  
 LADLE NO: 16 FINISH GRADE: \_\_\_\_\_ 1st OP: KA KWH FINAL: \_\_\_\_\_  
 WEIGHT TAPPED: 118 397500 2nd OP: \_\_\_\_\_ KWH USED: \_\_\_\_\_

SAMPLE	TIME	C	Mn	P	S	SI	Cu	NI	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF-1		044	02	006	002	32								013	77	
LMF-2		054	01	006	004	24								001	68	
LMF-3																
LMF-4																

SLAG  
DEPTH  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
COLOR  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
TEXTURE  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT TIME START TIME END  
 FINISH TAP \_\_\_\_\_  
 LADLE ON CAR \_\_\_\_\_  
 INO STIR ON \_\_\_\_\_  
 UNDER ROOF \_\_\_\_\_  
 POWER ON \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_  
 TAP NO. \_\_\_\_\_

ARGON LANCE ON  
3 min @ 60

LADLE ADDITION	TIME	AMOUNT
LC FeMnSi	400	
Lime	500	
Al SHOT		
STD FeMn		
MED C FeMn	275	
Al WIRE (FT)		
Ca SI WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE	500'	

TIME/TEMP/OXYGEN °F PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM  
 \_\_\_\_\_ °F \_\_\_\_\_ PPM

TIME 7:00 DEPARTURE TEMPERATURE 3021  
75.8  
28mV

REMARKS

DRAINED





1327

**NUCOR STEEL - CRAWFORDSVILLE  
CASTRIP HEAT RECORD**

HEAT NUMBER: 432819 # IN SEQUENCE: \_\_\_\_\_ SUPERVISOR: RH  
 GRADE: 1005 S1 LIQUIDUS: \_\_\_\_\_ PULPIT OPER: CP  
 DATE: 11-21-03

C	Mn	S	AL	SI	TEMP.	LOT
0.055	.63	.008	.0014	.30		22:17
LAST LMF CHEM: <u>NE-0073</u>						TO4 22:18

LADLE NUMBER: <u>110</u>	TUNDISH # <u>4-F</u>
TARE WEIGHT: <u>75</u>	TUNDISH CAR # _____
INITIAL WEIGHT: <u>109</u>	CASSETTE # <u>2</u>
FINAL WEIGHT: <u>34</u>	CASSETTE ROLL # <u>18</u>
OPEN TIME: <u>22:22</u>	C/N PLATE # <u>2</u>
CLOSE TIME: <u>23:21</u>	TUNDISH CLOSE TIME: <u>23:21</u>
FREE OPEN: <u>YES/NO</u>	SKULL WEIGHT: _____
SHROUD ON: <u>YES/NO</u>	
# OF PIPES USED: <u>2 Rod</u>	<u>CAST 63 Coiled 60</u>

CAST FEET	CAST SPEED	EVENT LOG TIME / TUND TEMP	SHEAR CUT TEMP / OXY	REMARKS	
				FORCES	OS OP
173	6.1				500 550
			2929 / 50.9 26mV	16.6 Hyd	450 375
		22:46	2924 / 44.7 19mV		
		22:48		5.3 Hyd	300 375
		23:01	2912 / 43.3 20mV		300 425
		23:15	2895 / 40.0 19mV		
					4.658 4.060

REASON FOR TERMINATION OF CAST: Washed out TP some failed out

TOTAL CAST: 56min

**INTERRUPT**

QF-0260, 08/27/02

SEQ  
1326

NUCOR STEEL - CRAWFORDSVILLE  
CASTRIP HEAT RECORD

HEAT NUMBER: 432812 # IN SEQUENCE: 1 SUPERVISOR: TJM  
 GRADE: 100SS1 LIQUIDUS: \_\_\_\_\_ PULPIT OPER: BB  
 DATE: 11-21-03

C	Mn	S	AL	SI	TEMP.
					Lot 16:47
LAST LMF CHEM:					TOG 16:41

LADLE NUMBER: 17 TUNDISH #: 7-A  
 TARE WEIGHT: 89 TUNDISH CAR #: 2  
 INITIAL WEIGHT: 106 CASSETTE #: 2  
 FINAL WEIGHT: \_\_\_\_\_ CASSETTE ROLL #: 18  
 OPEN TIME: 16:45 CN PLATE #: 2  
 CLOSE TIME: 18:03 TUNDISH CLOSE TIME: \_\_\_\_\_  
 FREE OPEN: YES/NO NO SKULL WEIGHT: \_\_\_\_\_  
 SHROUD ON: YES/NO NO  
 # OF PIPES USED: 2 Cast-97 Coiled-97

N.005.  
S.0056

CAST FEET	CAST SPEED	EVENT LOG TIME / TUND TEMP	SHEAR CUT	REMARKS	
				Temp 10x4	Temp DS/OS
Pool	64	16:46	2950-49.2	300/500	60/85
173	75	16:55		375/450	
		(Exhaust fan off)		350/450	
173	75	17:14	2958-47.4	325/475	
173	75	17:33	2953-48.0	320/475	63/85
173	79	17:51	2944-48.9	325/475	63/90
				112.5/575	

Hyd.  
4.1

TOTAL CAST: 74 REASON FOR TERMINATION OF CAST: 50/PP



1325  
#2

NUCOR STEEL - CRAWFORDSVILLE  
CASTRIP HEAT RECORD

HEAT NUMBER: 232811 # IN SEQUENCE: \_\_\_\_\_ SUPERVISOR: T.M.  
 GRADE: 10054V LIQUIDUS: \_\_\_\_\_ PULPIT OPER: RJS  
 DATE: 11-21-03

C	Mn	S	AL	SI	TEMP.
---	----	---	----	----	-------

Cast 9:50

LADLE NUMBER: 10 400 15  
 TARE WEIGHT: \_\_\_\_\_  
 INITIAL WEIGHT: 124  
 FINAL WEIGHT: \_\_\_\_\_  
 OPEN TIME: 10:02  
 CLOSE TIME: 11:26  
 FREE OPEN: (YES/NO)  
 SHROUD ON: (YES/NO)  
 # OF PIPES USED: \_\_\_\_\_

TUNDISH # 3-E  
 TUNDISH CAN # \_\_\_\_\_  
 CASSETTE # 2  
 CASSETTE ROLL # 18  
 CAN PLATE # 2  
 TUNDISH CLOSE TIME: \_\_\_\_\_  
 SKULL WEIGHT: \_\_\_\_\_  
Cast - 220      Cast - 220

N 0046  
S 0041

CAST FEET	CAST SPEED	EVENT LOG TIME / TUND TEMP	SHEAR CUT	REMARKS			
				1/2	3/4	5/8	7/8
<u>173</u>	<u>80</u>	<u>10:05</u>	<u>2949-51.6</u>	<u>325</u>	<u>315</u>	<u>65</u>	<u>90</u>
	<u>75</u>	<u>10:22</u>	<u>2950-52.4</u>	<u>400</u>	<u>425</u>		
		<u>10:49</u>	<u>2939-45.0</u>				
		<u>Argon on @ 10:70 50fpm</u>					
<u>174</u>	<u>79</u>	<u>11:14</u>	<u>2936-47.1</u>				

Hyd.  
3.9

REASON FOR TERMINATION OF CAST: 50 / 1/18

TOTAL CAST: 166

NUCOR STEEL - CRAWFORDSVILLE

CASTRIP HEAT RECORD

HEAT NUMBER: 232805 # IN SEQUENCE: 1 SUPERVISOR: GH  
 GRADE: 10051 LIQUIDUS: \_\_\_\_\_ PULPIT OPER: \_\_\_\_\_  
 DATE: 8/19

C	Mn	S	AL	SI	TECH	LOT	0833
LAST LMF OPER:							TEC 0838

LADLE NUMBER: 10 TUNDISH # 3-2  
 TARE WEIGHT: \_\_\_\_\_ TUNDISH CAR # \_\_\_\_\_  
 FINAL WEIGHT: \_\_\_\_\_ CASSETTE # 2  
 OPEN TIME: 10:49 CASSETTE ROLL # 1  
 CLOSE TIME: 10:50 ON PLATE # 0  
 TUNDISH CLOSE TIME: \_\_\_\_\_  
 FREE OPEN: YES  NO  SKULL WEIGHT: \_\_\_\_\_  
 THROUGH DR: YES  NO   
 # OF PIPES USED: 3 Cast - 105 Core - 105

CAST FEET	CAST SPEED	EVENT LOG		BREAK OUT				REMARKS	
		TIME	TUND TEMP	Temp	Temp	Temp	Temp	Temp	Temp
3	70	3.1	3.1	2930	47.2	450	500	182	90
41	77	3.9	3.7	2922	41.9	410	325	65	90
49	77								
82	74			2894	47.1	325	310		

REASON FOR TERMINATION OF CAST: 50 / 100

TOTAL CAST: 82

145-0294, 10/17/02

Run #	Time	Fan Amps	Position	Overall ΔP
2	8:44	92	92	-5.71
	8:58	95	97	-4.32
	9:09	92	94	-3.71
	9:19	92	96	-5.36
	9:29	97	98	-5.50
	9:39	92	96	-6.52
	9:49	92	95	-5.55
3	10:19	92	92	-5.74
	10:29	90	92	-5.62
	10:39	87	96	-5.82
	10:49	97	98	-6.29
	11:09	91	98	-5.09
	11:19	96	98	-6.14
	11:29	94	510	-13.92
	11:35	94	55	-11.75
3	4:25	91	97	-5.82
	4:47	91	98	-6.12
	4:57	92	98	-5.24
	5:02	90	98	-4.77
	5:12	90	98	-3.62
	5:22	94	98	-5.38
	5:37	70	70	-5.87

cleaning

Cleaned in between

ladle went to center  
cleaning  
9 top

cleaning

cleaning





Hand Delivered

PK-  
SUC  
MDU

RECEIVED

FEB 04 2005

4.4

43.3

16.3

Department of Environmental Management  
Office of Air-Quality

## Indiana Air Permit Compliance Testing

ΔAir Analysis, Inc.

Report on:  
**Particulates/ PM10, Lead, Sulfur Dioxide, Nitrogen Oxides,  
Carbon Monoxide and Visible Emissions Testing**

Performed for  
**Nucor Steel Corporation  
Castrip Operations**

**December 21, 2004**

Air Analysis Inc. Project Number: 272

(IDEM COPY)

ΔAir Analysis, Inc.

3904 Clarks Creek Road \* Plainfield, Indiana \* 46168 877-683-TEST

# Δ Air Analysis, Inc.

3904 Clarks Creek Road • Plainfield, Indiana 46168  
Tel. 317 837-8514 Fax. 317 837-8518

## Certification Page

Air Analysis, Inc. represents that the information provided in this report is true and accurate. We at Air Analysis, Inc. strive to remain true to our mission, that the people involved are people of integrity, the data accurate, and the reporting timely.

Sincerely,



Michael M. Dicen, President  
Air Analysis, Inc.

Date: \_\_\_\_\_

2-3-05

## **TABLE OF CONTENTS**

1. Executive Summary (Page 3)  
Test Summary, Table 1
2. Results (Page 4)  
Table 2
3. Description of Source Processes and Field Notes (Page 5)
4. Methodology (Pages 6 & 7)  
  
Summary of Sampling Procedures  
Description of Sampling Methods

### **APPENDIX**

<b>SAMPLE CALCULATIONS</b>	<b>I</b>
<b>FIELD DATA PRINTOUTS</b>	<b>II</b>
<b>FIELD DATA</b>	<b>III</b>
<b>LABORATORY DATA</b>	<b>IV</b>
<b>CHAIN OF CUSTODY</b>	<b>V</b>
<b>CALIBRATION DATA</b>	<b>VI</b>
<b>VISIBLE EMISSIONS DATA</b>	<b>VII</b>
<b>SUBMITTED PROTOCOL</b>	<b>VIII</b>
<b>PRODUCTION DATA</b>	<b>IX</b>

**Executive Summary**

Air Analysis, Inc. was contracted by Nucor Steel Corporation to perform air emissions sampling of their Castrip Baghouse Stack in Crawfordsville, Indiana, on December 21, 2004. The objective of the test program was to determine compliance to Indiana air permit requirements for particulate matter/(PM/10), lead, sulfur dioxide, nitrogen oxides, carbon monoxide and visible emissions. The following personnel were involved with the testing program:

Air Analysis	Mike Dicen
Air Analysis	Terry Kauffman
Air Analysis	Marcus Allen
Air Analysis	Ron Stapert
Nucor Steel	Mark Washer
IDEM	Doug VanDemark

Three sets of one-hour test runs were performed for PM/PM10, lead, SO2, NOX, CO and Visible Emissions. Air Analysis, Inc. encountered several power outages during Run 3. Pollutant averages for Run 3 are calculated on a time weighted average. Lead analysis filters and aqueous samples were shipped to Severn Trent Laboratories (STL). STL Valparaiso shipped the lead samples to STL Knoxville. Prior to shipment, STL Valparaiso filled a cooler with ice. The ice melted during shipment to Knoxville and thus contaminated the filters. There was no contamination of the aqueous solution. Air Analysis, Inc. is utilizing the filters used from particulate/PM10 test for lead analysis. Lead analyzed from the particulate filters will be used in the lead analysis total. Element One Laboratories are analyzing the filters and aqueous solution for lead. Please find an STL letter explaining the problem in the Appendix (Lab Section).

Per Mr. Dave Cline of IDEM, testing was to be performed while one ladle is cast at the Caster and another being processed at the LMS. Therefore, total tons on both the Caster and LMS were added since both add to emissions to the baghouse. Please review Section 3 for further details.

**Table 1.  
Test Summary**

Pollutant	Date	Runs	Concentration	Mass Emissions Rate	*Emissions Rate* Per Tons of Metal
PM PM/PM10	12/21/04	1-3	0.0015 gr/dscf 0.0044 gr/dscf	1.2 lbs/hr 3.5 lbs/hr	0.0069 lbs/ton 0.02 lbs/ton
Lead	12/21/04	1-3	0.0000094 gr/dscf	0.0078 lbs/hr	0.00004 lbs/ton
NOX	12/21/04	1-3	14.47 ppm	9.66 lbs/hr	0.056 lbs/ton
SO2	12/21/04	1-3	20.9 ppm	19.3 lbs/hr	0.11 lbs/ton
CO	12/21/04	1-3	23.19 ppm	9.46 lbs/hr	0.055 lbs/ton
Visible Emissions	12/21/04	1-3	0 %	NA	NA

\*\*Based on three run average of 171.9 Tons/hr

**Results**

**Table 2**

<b>STACK EMISSION SUMMARY</b>				
<b>Gaseous Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
NOx lbs/hr	8.05	6.1	14.8	9.66
SO2 lbs/hr	16.77	18.65	22.57	19.3
CO lbs/hr	11.19	7.09	10.1	9.46
<b>PM/PM10 Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
Filterable (gr/dscf)	0.0009	0.0014	0.0023	0.0015
Filterable + Condensible (gr/dscf)	0.0058	0.0035	0.0039	0.0044
Filterable (lbs/hr)	0.75	1.04	1.8	1.2
Condensible (lbs/hr)	4.1	1.6	1.3	2.34
Total (lbs/hr)	4.87	2.66	3.13	3.55
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	101,702.3	92,744.79	93,928.6	96,125.23
DSCFM	97,737.42	88,195.62	93,101.3	93,011.45
Avg. Stack Temp.	87.46	96.3	75.1	86.3
Stack Gas Velocity	33.7	30.7	31.1	31.87

<b>Lead Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
Filterable (gr/dscf)	0.000019	0.0000062	0.0000025	0.0000094
Lead(lbs/hr)	0.0168	0.0046	0.0019	0.0078
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	106,156	91,100	90,320	95,858
DSCFM	101,199	86,063	88,854	92,039
Avg. Stack Temp.	89.1	97.2	76.9	87.7
Stack Gas Velocity	35.2	30.2	29.9	31.8

**Description of Source Processes and Field Notes**

Nucor Steel Corporation operates a steel mill facility in Crawfordsville, Indiana. The facility required to determine compliance to permit conditions is the recently built Castrip. At this facility, molten metal is cast into thin metal sheets.

Two sources have an effect on air emissions according to the Indiana Department of Environmental Management; process emissions from LMS and Caster. Production levels were kept for both metal sheets produced and the ladle on standby.

Production rates follows as described above.

200.6 tons	TEST 1	}	Avg	171.9
135.8 tons	TEST 2			
179.4 tons	TEST 3			

Emissions pass through a baghouse prior to exiting a stack.

Actual recorded production material information is in Appendix.

**Methodology**

The sampling procedures used by Air Analysis, Inc. are as follows:

**Title 40 CFR Part 60 Appendix A**

- Method 1 "Sampling of Velocity Traverses for Stationary Sources"
- Method 2 "Determining of Stack Gas Velocity and Volumetric Flow Rate"
- Method 3 "Gas Analysis for the Determination of Molecular Weight"
- Method 4 "Determination of Moisture Content in Stack Gas"
- Method 5 "Determination of Particulate Emissions"
- Method 9 "Visual Determination of the Opacity of Emissions"
- Method 202 "Determination of Condensible Emissions from Stationary Sources"
- Method 6C "Determination of Sulfur Dioxide Emissions"
- Method 7E "Determination of Nitric Oxide Emissions"
- Method 10 "Determination of Carbon Monoxide Emissions"

**SAMPLE POINT DETERMINATION-EPA METHOD 1**

Sampling point locations were determined according to EPA Reference Method 1.

Locations	Dimensions	Sampling Points		
		Ports	Points Per Port	Total Points
Castrip Stack	96" Diameter	4	6	24

\*\* Exact measure points and distances to disturbances are listed in Appendix- Field Data

**VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements made with a Type K thermocouple and digital pyrometer.

**GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

**MOISTURE CONTENT – EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-2 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

#### **PARTICULATE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe and filter. The probe temperature and filter are maintained at temperatures of 248 degrees F (+/- 25 deg. F). The impinger temperature exit gas is maintained at temperatures at or below 68 degrees F.

The nozzle, probe and glass filter containers are rinsed with acetone and the rinse is captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with de-ionized water and captured in a sealed container. Two rinses of methylene chloride are captured and stored in a sealed glass container.

#### **OPACITY – METHOD 9**

Stack opacity readings are taken for 60 minutes at 15 second intervals *for NSPS* and 30 minutes at 15 second intervals *for state permitted, non-federal sources*, by a certified visible emissions reader. The visible emissions readings are conducted during each of the particulate test runs. The results are reported as an average opacity reading for the half an hour period. A copy of the visible reader's current certification is included in the Appendix.

#### **SO2 DETERMINATION – EPA METHOD 6C**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by infrared detection. Sulfur Dioxide molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of SO2. Quality assurance of the analyzer is determined by first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias.

#### **NOX DETERMINATION – EPA METHOD 7E**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by chemiluminescent detection. NOX molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of NOX. Quality assurance of the analyzer is first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias.

#### **CO DETERMINATION – EPA METHOD 10**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by infrared detection. CO molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of CO. Quality assurance of the analyzer is first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias

**APPENDIX I**




Figure 5-1. Metals & Particulate Sampling Train

### SAMPLE CALCULATIONS

The tables presenting the results are generated electronically from raw data. It may not be possible to exactly duplicate these results using a calculator. The reference method data, results and all calculations are carried to sixteen decimal places throughout. The final table is formatted to an appropriate number of significant figures.

#### 1. Volume of water collected (wscf)

$$V_{wstd} = (0.04707)(V_{lc})$$

Where:

$V_{lc}$	total volume of liquid collected in impingers and silica gel (ml)
$V_{wstd}$	volume of water collected at standard conditions (ft <sup>3</sup> )
0.04707	conversion factor (ft <sup>3</sup> /ml)

#### 2. Volume of gas metered, standard conditions (dscf)

$$V_{std} = \frac{(17.64)(V_m)(P_{baro} + \frac{\Delta H}{13.6})(Y_d)}{(460 + T_m)}$$

Where:

$P_{baro}$	barometric pressure (in Hg)
$T_m$	average dry gas meter temperature (°F)
$V_m$	volume of gas sample through dry gas meter at meter conditions (ft <sup>3</sup> )
$V_{std}$	volume of gas sample through dry gas meter at standard conditions (ft <sup>3</sup> )
$Y_d$	gas meter correction factor (dimensionless)
DH	average pressure drop across meter box orifice (in H <sub>2</sub> O)
17.64	conversion factor (°R/in Hg)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)
460	°F to °R conversion constant

#### 3. Sample gas pressure (in Hg)

$$P_s = P_{baro} + \left(\frac{P_g}{13.6}\right)$$

Where:

$P_{baro}$	barometric pressure (in Hg)
$P_g$	sample gas static pressure (in H <sub>2</sub> O)
$P_s$	absolute sample gas pressure (in H <sub>2</sub> O)
13.6	conversion factor (in H <sub>2</sub> O/in Hg)

4. Actual vapor pressure (in Hg)

$$P_v = P_s$$

Where:

$P_v$  vapor pressure, actual (in Hg)  
 $P_s$  absolute sample gas pressure (in Hg)

5. Moisture Content (%)

$$B_{wo} = \frac{V_{wsid}}{V_{msid} + V_{wsid}}$$

Where:

$B_{wo}$  proportion of water vapor in the gas stream by volume  
 $V_{msid}$  volume of gas sample through the dry gas meter at standard conditions (ft<sup>3</sup>)  
 $V_{wsid}$  volume of water collected at standard conditions (ft<sup>3</sup>)

6. Saturated moisture content (%)

$$B_{ws} = \frac{(P_v)}{(P_s)}$$

Where:

$B_{ws}$  proportion of water vapor in gas stream by volume at saturated conditions (%)  
 $P_v$  vapor pressure, actual (in Hg)  
 $P_s$  absolute sample gas pressure (in Hg)

7. Molecular weight of dry gas stream (lb/lb-mole)

$$M_d = M_{CO_2} \frac{(CO_2)}{(100)} + M_{O_2} \frac{(O_2)}{(100)} + M_{CO-N_2} \frac{(CO+N_2)}{(100)}$$

Where:

$M_d$  dry molecular weight of sample gas (lb/lb-mole)  
 $M_{CO_2}$  molecular weight of carbon dioxide (lb/lb-mole)  
 $M_{O_2}$  molecular weight of oxygen (lb/lb-mole)  
 $M_{CO-N_2}$  molecular weight of carbon monoxide and nitrogen (lb/lb-mole)  
 $CO_2$  proportion of carbon dioxide in the gas stream by volume (%)  
 $O_2$  proportion of oxygen in the gas stream by volume (%)  
 $CO + N_2$  proportion of carbon monoxide and nitrogen in gas stream by volume (%)  
 100 conversion factor, %

8. Molecular weight of sample gas (lb/lb-mole)

$$M_s = (M_d)(1 - B_{wv}) + (M_{H_2O})(B_{wv})$$

Where:

$M_d$	dry molecular weight of sample gas (lb/lb-mole)
$B_{wv}$	proportion of water vapor in the gas stream by volume
$M_{H_2O}$	molecular weight of water (lb/lb-mole)
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)

9. Velocity of sample gas (ft/sec)

$$V_s = (K_p)(C_p)(\sqrt{\Delta P}) \sqrt{\frac{t_s + 460}{(M_s)(P_s)}}$$

Where:

$K_p$	velocity pressure coefficient (dimensionless)
$C_p$	pitot tube constant
$M_s$	molecular weight of sample gas, wet basis (lb/lb-mole)
$P_s$	absolute sample gas pressure (in. Hg)
$t_s$	average sample gas temperature ( $^{\circ}F$ )
$V_s$	average sample gas velocity (ft/sec)
460	$^{\circ}F$ to $^{\circ}R$ conversion factor

10. Total flow of sample gas (acfm)

$$Q_s = (60)(A_s)(V_s)$$

Where:

$A_s$	cross section area of sampling location (ft <sup>2</sup> )
$Q_s$	volumetric flow rate at actual conditions (acfm)
$V_s$	sample gas velocity (ft/sec)
60	conversion factor, seconds to minutes

11. Total flow of sample gas (dscfm)

$$Q_{std} = \frac{(Q_a \times P_s \times 17.64 \times (1 - B_{wv}))}{(t_s + 460)}$$

Where:

B <sub>wv</sub>	proportion of water vapor in the gas stream by volume
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
Q <sub>a</sub>	volumetric flow rate at actual conditions (acfm)
Q <sub>std</sub>	volumetric flow rate at standard conditions (dscfm)
t <sub>s</sub>	average sample gas temperature (°F)
17.64	conversion factor, (°R/in.Hg)
460	°F to °R conversion factor

12. Percent Isokinetic (%)

$$I = \frac{(0.09450)(T_s)(V_{std})}{(P_s)(V_s) \times \frac{(D_n)^2(\pi)}{(144)(4)} \times (t_s)(1 - B_{wv})}$$

Where:

D <sub>n</sub>	diameter of nozzle, inches
B <sub>wv</sub>	proportion of water vapor in the gas stream by volume
I	percent of isokinetic sampling (%)
P <sub>s</sub>	absolute sample gas pressure (in. Hg)
T <sub>s</sub>	average sample gas temperature (°R)
V <sub>std</sub>	volume of gas sample through the dry gas meter at standard conditions (ft <sup>3</sup> )
V <sub>s</sub>	average sample gas velocity (ft/sec)
t <sub>s</sub>	total sample time, minutes
0.09450	constant

13. Particulate concentration (gr/dscf)

$$C_{gr/dscf} = \frac{(15.43)(m_n)}{V_{std}}$$

Where:

C <sub>gr/dscf</sub>	measured concentration in gas stream, gr/dscf
M <sub>n</sub>	particulate collected, corrected for reagent blank, grams
V <sub>std</sub>	volume of gas sample through the dry gas meter at standard conditions (ft <sup>3</sup> )
15.43	conversion factor, grams to grains

14. Particulate Emissions, lb/MMBtu

$$E_{lb/MMBtu} = \frac{(C_{gr/dscf} \times F_d) \times 20.9}{(7000)(20.9 - \%O_2)}$$

Where:

$E_{lb/MMBtu}$	emission rate, pounds per million Btu
$C_{gr/dscf}$	concentration in gas stream, gr/dscf
$F_d$	fuel factor, dscf/MMBtu
$Q_{std}$	volumetric flow rate at standard conditions, dry basis (dscfm)
$20.9 - \%O_2$	ambient conditions minus O <sub>2</sub> (%CO <sub>2</sub> )
7000	conversion factor, grains to pound

15. Particulate Emissions, Mass Emissions Rate lbs/hr

$$E_{lb/hr} = \frac{(G_{gm} \times Q_{std})}{(7.567)(V_{std})}$$

Where:

$E_{lb/hr}$	Mass emissions rate, pounds per hour
$G_{gm}$	Grams of particulate emissions
$Q_{std}$	volumetric flow rate at standard conditions, dry basis (dscfm)
$V_{std}$	Volume Standard conditions
7.567	conversion factor, grams to pound

**APPENDIX II**

**STACK EMISSION SUMMARY**

SOURCE TESTED: Castrip  
 COMPANY NAME: Nucor Steel  
 DATE OF TEST: 12/21/04

<b>Lead Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
Filterable (gr/dscf)	0.0000193	0.0000062	0.0000025	0.0000094
Filterable (lbs/hr)	0.0168	0.0046	0.0019	0.0078
Condensable (lbs/hr)	0.0000	0.0000	0.0000	0.0000
Filterable + Condensable (lbs/hr)	0.0168	0.0046	0.0019	0.0078

**Avg. Stack Vol. Flow Rate**

ACFM	106,156	91,100	90,320	95,858
DSCFM	101,199	86,063	88,854	92,039

Avg. Stack Temp.	89.1	97.2	76.9	87.7
Stack Gas Velocity	35.198	30.206	29.948	31.7840

Avg. Velocity Head	0.3770	0.2743	0.2801	0.3105
Avg. Sq. Rt of Delta P	0.6140	0.5237	0.5292	0.5557

**ISOKINETIC TESTING SUMMARY**

<b>%Isokinetics:</b>	103.62	101.16	100.87	101.89
Allowable isokinetic 90-110%				
% Moisture of Stack Gas	1.68%	1.18%	0.79%	1.22%
Sample Volume	42.656	35.416	36.459	38.177

\*\* Particulate Filters were analyzed for lead. Original lead filters were contaminated by STL Element One Lab performed analysis on filter and HNO3 solutions.

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville, IN  
**SOURCE TESTED:** Castrip  
**DATE OF TEST:** 12/21/04  
**RUN NO.:** 1  
 Lead

**FIELD DATA**

**K-Factor = 4.50**

**Start Time:** 12:00  
**Stop Time:** 13:12

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 = 0  
 %O2 = 21  
 Md = 28.84

**Volume of Water Vapor Collected @ STD. COND., Vw**  
 Vc = 15.5  
 Vw(std) = 0.729

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) = 83.398  
 Vm = 45.732  
 Pbd(inches Hg) = 30.080  
 delta H = 1.920  
 gamma = 0.947  
 Vm(std) = 42.858

**Molalure Content of Stack Gas, Bwo**  
 Bwo = 1.66%  
 1-Bwo = 98.32%

**Molecular Weight of Stack Gas, Ms**  
 Ms = 28.68

**Area of Stack (enter diameter in inches), As**  
 Depth-In = 0  
 Width-In = 0  
 diameter = 96  
 No. of Stacks = 1  
 As(L\*W) = 0  
 As(dia.) = 50,265.44

**Static Pressure, Ps**  
 Static = -0.250  
 Ps = 30.06

**Stack Gas Velocity, Vg, fpm**  
 Cp = 0.84  
 sq(delta p) = 0.614  
 Ts = 69.083  
 Vs = 35.198

**Stack Gas Flowrate, Qg, acfm**  
 As = 50,265.44  
 Qg = 106158

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd**  
 Qstd (dscfm) = 101188.83  
 Qstd (dscf/hr) = 6071928.85

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle = 0.25  
 Time of Run = 60  
 Vn = 36.47  
 An(nozzle) = 0.000341

**% Isokinetic, %I**  
 %I = 103.62  
**% Isokinetic measured from intermediate values**  
 %I = 104.02

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn (g) = 0.000053392      0.0000      5.339E-05  
 PMR (lb/hr) = 0.0188      0.0000      0.0188

	Filterable	Condensible	Total
Grains per acf			
g/acf =	0.00001802		
Grains per dscf			
g/dscf =	0.00001831		

Run	Wt	Wt	Wt	Wt	Wt	Wt	Wt
1	0.410	0.640	1.85	81	77	77	
2	0.380	0.818	1.71	83	77	77	
3	0.400	0.632	1.80	87	78	76	
4	0.400	0.632	1.80	92	80	76	
5	0.280	0.528	1.26	92	82	77	
6	0.180	0.424	0.81	91	83	77	
7	0.440	0.663	1.98	98	83	77	
8	0.450	0.671	2.03	98	87	77	
9	0.410	0.640	1.85	99	90	77	
10	0.190	0.438	0.86	96	89	78	
11	0.190	0.438	0.86	96	90	79	
12	0.180	0.424	0.81	94	90	78	
13	0.140	0.374	0.63	93	84	80	
14	0.120	0.346	0.54	93	89	80	
15	0.120	0.346	0.54	91	89	80	
16	0.110	0.332	0.50	90	89	80	
17	0.120	0.346	0.54	89	89	80	
18	0.290	0.539	1.31	90	92	81	
19	0.800	0.848	4.95	84	91	61	
20	0.900	0.948	4.95	82	94	81	
21	0.680	0.836	3.96	81	95	81	
22	0.900	0.948	4.98815	80	96	82	
23	0.900	0.948	4.53083	80	96	82	
24	0.950	0.975	4.28	78	96	83	

Average	Average	Average	Average	Average	Average	Average
0.427	0.614	45.732	1.920	86.083		83.398

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville, IN  
**SOURCE TESTED:** Castrip  
**DATE OF TEST:** 12/21/04  
**RUN NO.:** 2  
**POLLUTANT:** Lead

**FIELD DATA**  
Colonial Brick

K-Factor = 4.30

Start Time: 14:00  
 Stop Time: 15:07

Enter Date  
**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 = 0  
 %O2 = 21  
 Md = 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vc = 9  
 Vw(std) = 0.423

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) = 84.375  
 Vm = 36.103  
 Pb(inches Hg) = 30.080  
 delta H = 1.215  
 gamma = 0.947  
 Vm(std) = 35.416

**Moisture Content of Stack Gas, Bwo**  
 Bwo = 1.18%  
 1-Bwo = 98.82%

**Molecular Weight of Stack Gas, Ms**  
 Ms = 28.71

**Area of Stack (enter diameter in inches), As**  
 Depth-in = 0  
 Width-in = 0  
 diameter = 96  
 No. of Stacks = 1  
 As(L\*W) = 0  
 As(dia.) = 50.26544

**Static Pressure, Ps**  
 Static = -0.020  
 Ps = 30.08

**Stack Gas Velocity, Vs, fps**  
 Cp = 0.84  
 sqrt(delta p) = 0.524  
 Ts = 97.208  
 Vs = 30.206

**Stack Gas Flowrate, Qs, acfm**  
 As = 50.26544  
 Qs = 81100

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd (dscf/m) = 88082.53  
 Qstd (dscf/hr) = 5163751.78

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle = 0.25      An(nozzle) = 0.000341  
 Time of Run = 60  
 Vn = 30.56

**% Isokinetic, %I**  
 %I = 101.16  
**% Isokinetic measured from intermediate values**  
 %I = 101.55

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn (g) = 0.000014342      0.0000      1.43E-05  
 PMR (lb/hr) = 0.0046      0.0000      0.0046

**Grains per acf**  
 gr/acf = 0.0000059

**Grains per dscf**  
 gr/dscf = 0.0000082

Run	CO2	O2	Temp (F)	Pressure (inches Hg)	Humidity (delta H)	Velocity (fps)	Time (min)	Time (hr)
1	0.200	0.447	-0.86	90	80			
2	0.310	0.557	1.33	92	81			
3	0.400	0.632	1.72	91	83			
4	0.380	0.616	1.63	95	85			
5	0.380	0.616	1.63	98	87			
6	0.360	0.600	1.55	99	88			
7	0.250	0.500	1.08	101	86			
8	0.260	0.510	1.12	102	87			
9	0.280	0.529	1.20	104	88			
10	0.280	0.529	1.20	102	89			
11	0.120	0.346	0.62	100	89			
12	0.120	0.346	0.52	99	87			
13	0.140	0.374	0.60	95	85			
14	0.290	0.539	1.26	95	86			
15	0.370	0.608	1.59	96	90			
16	0.360	0.600	1.55	97	92			
17	0.370	0.608	1.59	98	92			
18	0.370	0.608	1.59	98	92			
19	0.290	0.539	1.26	95	90			
20	0.190	0.424	0.77	97	91			
21	0.140	0.374	0.60	97	91			
22	0.240	0.460	0.83	96	92			
23	0.340	0.583	1.46	96	93			
24	0.350	0.592	1.51	98	94			

Avg Delta P	Avg Pressure	Avg Velocity	Avg Temp	Avg Humidity	Avg Time
0.283	0.524	36.103	1.215	97.208	84.375

**COMPANY NAME:** Nucor Steel  
**LOCATION:** Crawfordsville, IN  
**SOURCE TESTED:** Centrip  
**DATE OF TEST:** 1/21/04  
**RUN NO.:** 3  
**POLLUTANT:** Lead

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 Error Data  
 Error Data

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vw (std) 0.292

**Volume of Dry Gas Collected @ STD. COND., Vm(dry)**  
 Tm(F) 73.954  
 Vm 38.484  
 Pm (torr) 30.060  
 Delta H 1.254  
 gamma 0.947  
 Vm(dry) 36.430

**Moisture Content of Stack Gas, B/W**  
 B/w 0.79%  
 1-B/w 99.21%

**Molecular Weight of Stack Gas, Mw**  
 Mw 28.75

**Area of Stack (total diameter in inches), As**  
 Depth 0.0  
 Width 0.0  
 diameter 36.0  
 No. of Stacks 1  
 As(L/V) 0  
 As(dia.) 50.26844

**Static Pressure, Ps**  
 Static -0.250  
 Ps 30.06

**Stack Gas Velocity, Vs, ft/s**  
 Cp 0.84  
 vgr(dia p) 0.620  
 Ts 78.875  
 Vs 29.648

**Stack Gas Flowrate, Qs, scfm**  
 As 50.26844  
 Qs 60320

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qsd**  
 Qsd (scfm) = 60354.44  
 Qsd (scfm) = 5331266.16

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle 0.25  
 Time of Run 60  
 Vn 30.21

**% Leaktight, %l**  
 %l 100.87  
 % Leaktight measured from intermediate values  
 %l 101.28

**Pollutant Mass Emission Rate, PMR, lb./hr.**  
 M(g) = 0.00005892 0.0000 0.00E+00  
 PMR (lb/hr) = 0.0018 0.0000 0.0019

**Grains per acf**  
 grains/acf = 0.0000025  
**Grains per dscf**  
 grains/dscf = 0.0000025

**FIELD DATA**

Colortal Brick

K. Factor = 4.50

Sample No.	Time	Temp (F)	Pressure (in. Hg)	Flow (scfm)	Velocity (ft/s)	Concentration (ppm)	Concentration (ug/m <sup>3</sup> )
1	0.150	0.387	0.68	85	70	71	71
2	0.340	0.583	1.48	70	88	70	70
3	0.400	0.632	1.72	69	89	70	70
4	0.170	0.412	0.73	89	71	70	70
5	0.290	0.528	1.21	89	72	70	70
6	0.330	0.574	1.42	72	74	70	70
7	0.370	0.608	1.60	77	74	70	70
8	0.450	0.671	1.84	77	77	70	70
9	0.500	0.707	2.14	80	79	71	71
10	0.480	0.703	2.11	81	80	71	71
11	0.480	0.683	2.08	83	80	71	71
12	0.450	0.671	1.84	86	81	71	71
13	0.150	0.387	0.68	82	75	71	71
14	0.200	0.447	0.85	82	78	72	72
15	0.220	0.468	0.94	81	77	71	71
16	0.220	0.468	0.94	80	77	71	71
17	0.210	0.458	0.90	78	78	72	72
18	0.220	0.468	0.94	78	78	72	72
19	0.280	0.528	1.25	78	78	72	72
20	0.160	0.400	0.69	78	78	72	72
21	0.188	0.400	0.68	77	80	72	72
22	0.288	0.528	1.25	77	81	72	72
23	0.330	0.574	1.42	78	85	72	72
24	0.160	0.400	0.69	77	83	72	72

Average: 0.292 0.573 38.484 1.254 78.875 71.000 73.954

**STACK EMISSION SUMMARY**

SOURCE TESTED: Castrip  
COMPANY NAME: Nucor Steel Corporation  
DATE OF TEST: 12/21/04

<b>Pollutant Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
PM Filterable (gr/dscf)	0.0009	0.0014	0.0023	0.0015
PM Filterable (lbs/hr)	0.7493	1.0439	1.8238	1.2057
PM10 Condensable (lbs/hr)	4.1213	1.6133	1.3027	2.3458
PM Filterable + Consensable (lbs/hr)	4.8706	2.6572	3.1266	3.5515
PM Filterable /condensable (gr/dscf)	0.0058	0.0035	0.0039	0.0044
NOx ppm	11.5000	9.7000	22.2000	14.4667
NOx lbs/hr	8.0519	6.1286	14.8064	9.6623
SO2 ppm	17.2000	21.2000	24.3000	20.9000
SO2 lbs/hr	16.7686	18.6505	22.5668	19.3287
CO ppm	26.2500	18.4300	24.9000	23.1933
CO lbs/hr	11.1856	7.0867	10.1071	9.4598

**Avg. Stack Vol. Flow Rate**

ACFM	101,702.30	92,744.79	93,928.60	96,125.23
DSCFM	97,737.42	88,195.62	93,101.30	93,011.45

Avg. Stack Temp.	87.458	96.304	75.125	86.296
Stack Gas Velocity	33.722	30.752	31.144	31.873

Avg. Velocity Head	0.3477	0.2852	0.3044	0.3124
Avg. Sq. Rt of Delta P	0.5897	0.5340	0.5517	0.5585

**ISOKINETIC TESTING SUMMARY**

%Isokinetics:	104.15	102.80	99.85	102.26
Allowable isokinetic 90-110%				
% Moisture of Stack Gas	1.18%	0.63%	0.37%	0.73%
Sample Volume	41.408	36.879	37.813	38.700

COMPANY NAME: Nucor Steel Corporation  
 LOCATION: Crawfordsville, IN  
 SOURCE TESTED: Castrip  
 DATE OF TEST: 12/21/04  
 RUN NO.: 1

FIELD DATA

K-Factor = 4.50

Start time: 12:00  
 Stop time:

Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 = 0  
 %O2 = 21  
 Md = 28.84

Volume of Water Vapor Collected @ STD. COND., Vwv  
 Vlc = 10.5  
 Vw(std) = 0.494

Volume of Dry Gas Collected @ STD. COND., Vm(std)  
 Tm(F) = 89.167  
 Vm = 43.920  
 Pbj(inches Hg) = 30.080  
 delta H = 1.652  
 gamma = 0.968  
 Vm(std) = 41.408

Moisture Content of Stack Gas, Bwo  
 Bwo = 1.18%  
 1-Bwo = 98.82%

Molecular Weight of Stack Gas, Ms  
 Ms = 28.71

Area of Stack (enter diameter in inches), As  
 Depth-in = 0  
 Width-in = 0  
 diameter = 96  
 No. of Stacks = 1  
 As(L\*W) = 0  
 As(dia.) = 50.26544

Static Pressure, Ps  
 Static = (0.250)  
 Ps = 30.06

Stack Gas Velocity, Vs, fps  
 Cp = 0.84  
 sq(delta p) = 0.590  
 Ts = 87.458  
 Vs = 33.722

Stack Gas Flowrate, Qs, acfm  
 As = 50.26544  
 Qs = 101702

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.  
 Qstd (dscf/m) = 97737.42  
 Qstd (dscf/hr) = 5804245.40

Velocity at the Nozzle, Vn  
 Dia. of Nozzle = 0.25 An(nozzle): 0.000341  
 Time of Run = 60  
 Vn = 35.12

% Isokinetic, %I  
 %I = 104.15  
 % Isokinetic measured from intermediate values  
 %I = 104.55

Pollutant Mass Emission Rate, PMR, lbs./hr.  
 Mn (g) = 0.0024 0.0132 0.0158  
 PMR (lb/hr) = 0.7493 4.1213 4.6706

	Filterable	Condensible	Total
Grains per acf gr/acf =	0.0009	0.0048	
Grains per dscf gr/dscf =	0.0009	0.0049	0.0058
Grains per mg/dscf mg/dscf =		0.0750	

NOx ppm = 11.5  
 NOx lbs/hr = 8.05191586  
 SO2 ppm = 17.2  
 SO2 lbs/hr = 16.70803575  
 CO ppm = 26.25  
 CO lbs/hr = 11.18561559

Time	Wt	Wt	Wt	Wt	Wt	Wt	Wt
1	0.360	0.600	1.620	79	83	81	
2	0.400	0.632	1.800	81	80	81	
3	0.400	0.632	1.800	86	81	81	
4	0.370	0.608	1.685	89	81	81	
5	0.200	0.447	0.900	90	82	82	
6	0.190	0.436	0.855	89	86	82	
7	0.460	0.678	2.070	95	89	83	
8	0.470	0.686	2.115	97	92	83	
9	0.270	0.520	1.215	96	93	84	
10	0.210	0.458	0.945	95	93	84	
11	0.210	0.458	0.945	94	93	85	
12	0.210	0.458	0.945	93	95	86	
13	0.200	0.447	0.900	90	93	87	
14	0.200	0.447	0.900	91	95	88	
15	0.200	0.447	0.900	90	95	87	
16	0.200	0.447	0.900	89	96	86	
17	0.210	0.458	0.945	89	97	87	
18	0.310	0.557	1.395	89	98	89	
19	0.660	0.812	2.970	83	98	90	
20	0.650	0.806	2.825	81	99	91	
21	0.650	0.742	2.475	80	99	91	
22	0.670	0.819	3.45.320	3.015	78	99	82
23	0.610	0.781	301.400	2.745	78	99	92
24	0.600	0.775	2.700	77	99	92	
Average	0.367	0.590	43.920	1.652	87.458		89.167

COMPANY NAME: Nucor Steel Corporation  
 LOCATION: Crawfordsville, IN  
 SOURCE TESTED: Castrip  
 DATE OF TEST: 12/21/04  
 RUN NO.: 2  
 POLLUTANT:

FIELD DATA

K - Factor = 4.30

Starting: 14:00  
 Stopping: 15:07

Enter Data  
 Molecular Weight of Stack Gas, Dry Basis, Md  
 %CO2 0  
 %O2 21  
 Md 28.84

Volume of Water Vapor Collected @ STD. COND., Vwv  
 Vic 5  
 Vw(std) 0.235

Volume of Dry Gas Collected @ STD. COND., Vm(std)  
 Tm(F) 90.804  
 Vm 39.270  
 Pb(Inches Hg) 30.080  
 delta H 1.265  
 gamma 0.968  
 Vm(std) 36.879

Molature Contont of Stack Gas, Bwo  
 Bwo 0.63%  
 1-Bwo 99.37%

Molecular Weight of Stack Gas, Ms  
 Ms 28.77

Area of Stack (enter diameter in inches), As  
 Depth-in 0  
 Width-in 0  
 diameter 96  
 No. of Stacks 1  
 As(L\*W) 0  
 As(dia.) 50.26544

Static Pressure, Ps  
 Static (0.250)  
 Ps 30.06

Stack Gas Velocity, Vs, fps  
 Cp 0.84  
 sqrt(delta p) 0.534  
 Ts 98.304  
 Vs 30.752

Stack Gas Flowrate, Qs, acfm  
 As 50.26544  
 Qs 92745

Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.  
 Qstd. 88195.62  
 Qstd (dscf/hr) = 5291737.10

Velocity at the Nozzle, Vn  
 Dia. of Nozzle 0.25 An(nozzle) 0.000341  
 Time of Run 60  
 Vn 31.61

% Isokinetic, %I  
 %I 102.80  
 % Isokinetic measured from intermediate values  
 %I 103.19

Pollutant Mass Emission Rate, PMR, lbs./hr.  
 Mn (g) = 0.0033 0.0051 0.0084  
 PMR (lb/hr) = 1.0439 1.6133 2.6572

Grains per acf  
 Filterable 0.0013  
 Condensible 0.0020

Grains per dscf  
 g/dscf = 0.0014 0.0021 0.0035

Grains per mg/dscf  
 mg/dscf = 1.3222

NOx ppm 9.7  
 NOx lbs/hr 6.128571419  
 SO2 ppm 21.2  
 SO2 lbs/hr 18.65053393  
 CO ppm 18.43  
 CO lbs/hr 7.088967261

Run#	W	V	P	T	Q	W	Q	DGM
1	0.130	0.381	0.559	90	85			87
2	0.130	0.381	0.559	90	89			87
3	0.330	0.574	1.419	92	87			87
4	0.290	0.538	1.247	94	89			87
5	0.250	0.500	1.075	96	90			86
6	0.250	0.500	1.075	99	91			87
7	0.430	0.656	1.849	101	90			86
8	0.420	0.648	1.806	101	93			86
9	0.420	0.648	1.806	101	93			86
10	0.430	0.656	1.849	101	95			87
11	0.210	0.458	0.903	98	95			87
12	0.210	0.458	0.903	96	94			87
13	0.140	0.374	0.602	95	93			87
14	0.300	0.548	1.290	95	95			89
15	0.400	0.832	1.720	95	96			89
16	0.390	0.616	1.634	95	96			89
17	0.380	0.616	1.634	96	96			89
18	0.380	0.616	1.634	96	96			89
19	0.300	0.548	1.290	96	96			89
20	0.220	0.469	0.946	96	96			89
21	0.150	0.387	0.645	95	96			89
22	0.270	0.520	1.161	95	96			89
23	0.340	0.583	1.462	95	97			89
24	0.300	0.548	1.290	97	98			90
AVG	0.294	0.534	1.265	96.304				90.804

**COMPANY NAME:** Nucor Steel Corporation  
**LOCATION:** Crawfordsville, IN  
**SOURCE TESTED:** Castrip  
**DATE OF TEST:** 12/21/04  
**RUN NO.:** 3  
**POLLUTANT:**

**FIELD DATA**

K - Factor = 4.30

Start time: 9:28  
 Stop time: 10:38

Enter Data

**Molecular Weight of Stack Gas, Dry Basis, Md**  
 %CO2 0  
 %O2 21  
 Md 28.84

**Volume of Water Vapor Collected @ STD. COND., Vwv**  
 Vic 3  
 Vw(std) 0.141

**Volume of Dry Gas Collected @ STD. COND., Vm(std)**  
 Tm(F) 78.375  
 Vm 39.201  
 Pb(inches Hg) 30.080  
 delta H 1.358  
 gamma 0.968  
 Vm(std) 37.813

**Moisture Content of Stack Gas, Bwo**  
 Bwo 0.37%  
 1-Bwo 99.63%

**Molecular Weight of Stack Gas, Ms**  
 Ms 28.80

**Area of Stack (enter diameter in inches), As**  
 Depth-in 0  
 Width-in 0  
 diameter 96  
 No. of Stacks 1  
 As(L\*W) 0  
 As(dia.) 50.26544

**Static Pressure, Ps**  
 Static (0.250)  
 Ps 30.06

**Stack Gas Velocity, Vs, fps**  
 Cp 0.84  
 sqr(delta p) 0.552  
 Ts 75.125  
 Vs 31.144

**Stack Gas Flowrate, Qs, acfm**  
 As 50.26544  
 Qs 93029

**Stack Gas Flowrate @ STD. COND., Dry Basis, Qstd.**  
 Qstd. 93101.30  
 Qstd (dscf/hr) = 6586077.94

**Velocity at the Nozzle, Vn**  
 Dia. of Nozzle 0.25 An(nozzle) 0.000341  
 Time of Run 60  
 Vn 31.10

**% Isokinetic, %I**  
 %I 99.85  
**% Isokinetic measured from intermediate values**  
 %I 100.23

**Pollutant Mass Emission Rate, PMR, lbs./hr.**  
 Mn (g) = 0.0056 0.004 0.0096  
 PMR (lb/hr) = 1.8238 1.3027 3.12657

**Grains per acf**  
 Filterable Condensib. Total  
 gr/acf = 0.0023

**Grains per dscf**  
 gr/dscf = 0.0023 0.0016 0.00392

**Grains per mg/dscf**  
 mg/dscf = 2.268696971 2.268699

**Run #**  
 NOx ppm 22.2  
 NOx lbs/hr 14.8063913  
 SO2 ppm 24.3  
 SO2 lbs/hr 22.5668225  
 CO ppm 24.9  
 CO lbs/hr 10.10705863

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24
	0.150	0.370	0.370	0.150	0.310	0.400	0.370	0.450	0.480	0.480	0.460	0.460	0.200	0.300	0.310	0.310	0.320	0.320	0.430	0.150	0.150	0.140	0.300	0.200
	0.387	0.608	0.608	0.387	0.557	0.632	0.608	0.671	0.693	0.693	0.878	0.878	0.447	0.548	0.557	0.557	0.566	0.566	0.656	0.387	0.387	0.374	0.548	0.447
	0.645	1.591	1.591	0.645	1.333	1.720	1.591	1.935	2.064	2.064	1.978	1.978	0.860	1.290	1.333	1.333	1.376	1.376	1.849	0.645	0.645	0.602	1.290	0.660
	65	68	68	65	68	71	72	76	78	80	82	83	76	81	80	80	78	78	75	75	75	75	76	75
	-73	-72	-71	-72	-75	-77	-77	-79	-80	-81	-83	-83	-79	-81	-82	-81	-82	-83	-80	-81	-81	-80	-80	-80
	74	74	73	74	72	73	73	74	73	73	74	74	74	74	74	74	74	75	73	75	74	75	75	75

0.316	0.552	39.201	1.358	75.125	76.376
-------	-------	--------	-------	--------	--------

**APPENDIX III**

**VELOCITY TRAVERSE POINT DETERMINATION**  
 (EPA Method 1)

**Nucor Steel Corporation**  
**Circular Stack**  
 Traverse Points on Diameter:  
 Stack Dia. (inches)?

@

**Crawfordsville, IN**

Points:

	4	6	8	10	12
96					
1	6.43	4.22	3.07	2.50	2.02
2	24.00	14.02	10.08	7.87	6.43
3	72.00	28.42	18.62	14.02	11.33
4	89.57	67.58	31.01	21.70	16.99
5		81.98	64.99	32.83	24.00
6		91.78	77.38	63.17	34.18
7			85.92	74.30	61.82
8			92.93	81.98	72.00
9				88.13	79.01
10				93.50	84.67
11					89.57
12					93.98



# AIR ANALYSIS, INC

EPA METHOD 12

Start Time: 2:00 PM

End Time: 3:07 PM

Nozzle size measurement

RUN NUMBER 2 POLLUTANT TESTED Lead

Meter Box # 80

Company: <u>Nusek</u>		Diagram of Test Location		CO2		O2		Notes		
Location: <u>Crawfordsville</u>				1	2	3	Avg. 2.1	Meter Y		
Unit Tested: <u>Coaststrip</u>				0	0	0	#11	Meter DeltaH@		
Meter Operator: <u>TV</u>				0	0	0		Pretest Leak Ch.	0	
Probe Operator: <u>MAJ</u>				0	0	0		Posttest Leak Ch.	0	
Client Contact: <u>MAJ</u>				0	0	0		Meter Outlet	0	
Agency Contact: <u>DV</u>				0	0	0		Vacuum	(Inches)	
V.E. Reader: <u>RS</u>				0	0	0		Temp (F)		
AAJ Project: <u>30.08</u>				0	0	0		Temp (F)		
Barometric Pressure: <u>35</u>				0	0	0		Temp (F)		
Ambient Temperature:				0	0	0		Temp (F)		
Traverse Point	Minutes per point	Δ P	Δ H	Meter Cu. Ft.	Stack Temp. (F)	Static Pressure Probe Temp. (F)	Filter Temp. (F)	Impinger Outlet Temp. (F)	Meter Inlet Temp. (F)	Notes
1	2.5	0.20	0.64	449.97	40	258	250	51	80	
2	5.0	0.20	0.80	501.5	97	258	257	51	80	
3	7.5	0.10	1.12	503.1	91	258	255	53	80	
4	10.0	0.38	1.63	504.6	95	255	255	52	80	
5	12.5	0.38	1.63	506.6	98	254	248	52	80	
6	15.0	0.30	1.55	508.4	99	254	252	52	80	
7	17.5	0.25	1.08	511.9	101	240	251	52	80	
8	20.0	0.16	1.12	512.3	102	240	250	52	80	
9	22.5	0.18	1.20	515.1	104	243	260	54	80	
10	25.0	0.19	1.26	516.7	102	255	260	53	80	
11	27.5	0.12	0.52	517.4	106	263	242	42	80	
12	30.0	0.12	0.52	518.102	99	258	257	45	80	
13	32.5	0.14	0.40	519.8	95	263	244	46	80	
14	35.0	0.19	1.25	521.4	95	258	240	46	80	
15	37.5	0.37	1.54	523.5	94	261	260	41	80	
16	40.0	0.32	1.55	525.8	97	257	261	40	80	
17	42.5	0.37	1.54	527.3	98	240	240	40	80	
18	45.0	0.37	1.54	528.8	98	250	240	40	80	
19	47.5	0.29	1.25	531.0	95	263	262	38	80	
20	50.0	0.18	0.17	532.0	97	263	262	38	80	
21	52.5	0.14	0.60	533.3	97	260	261	38	80	
22	55.0	0.17	1.03	535.2	94	240	258	38	80	
23	57.5	0.34	1.40	536.5	98	240	261	40	80	
24	60.0	0.35	1.51	538.093	98	258	260	41	80	
25										
26										
27										
28										
29										
30										



Filter Number:  
Filter preweight:  
Filter postweight:  
Total:  
Beaker ID:  
Beaker preweight:  
Beaker postweight:  
Total:


Start Time: 9:25pm

**AIR ANALYSIS, INC**  
EPA METHOD 12

RUN NUMBER 3 POLLUTANT TESTED Lead  
Meter Box #80


End Time:

Traverse Point	Minutes per point	Δ P	Δ H	Diagram of Test Location			Static Pressure		Filter Temp. (F)	CO2		O2		Nozzle size measurement		NOTES
				Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)	Impinger Inlet Temp. (F)	Impinger Outlet Temp. (F)		Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (Inches)	Meter Y	Meter Delta H	Pretest Leak Ch.	
2.5 1	1.5	0.15	0.65	538.24	65	265	257	31	70	71	1	0.947				
5.0 2	5.0	0.24	1.46	541.3	70	257	258	31	68	71	2	1.867				
7.5 3	7.5	0.40	1.72	543.0	69	260	258	31	69	70	2.5					
10.0 4	10.0	0.17	0.73	544.4	69	258	254	31	71	70	1					
12.5 5	12.5	0.28	1.20	546.0	68	258	258	30	72	70	2					
15.0 6	15.0	0.33	1.42	547.5	77	263	256	31	74	70	2					
17.5 7	17.5	0.37	1.59	549.4	77	265	263	30	74	70	2.5					
20.0 8	20.0	0.45	1.94	551.7	77	266	241	30	77	70	3					
22.5 9	22.5	0.50	2.15	553.4	80	261	261	30	79	71	3					
25.0 10	25.0	0.44	2.11	555.5	81	259	243	31	80	71	3					
27.5 11	27.5	0.40	2.08	557.5	83	259	263	31	80	71	3					
30.0 12	30.0	0.45	1.94	559.6	80	261	245	31	81	71	3					
32.5 13	32.5	0.15	0.65	560.8	82	260	262	30	75	71	1					
35.0 14	35.0	0.10	0.80	561.9	82	263	261	30	78	72	1					
37.5 15	37.5	0.22	0.95	562.7	81	261	263	30	77	71	1					
40.0 16	40.0	0.22	0.95	565.2	80	265	261	31	77	71	1					
42.5 17	42.5	0.21	0.90	564.8	79	261	259	30	78	72	1					
45.0 18	45.0	0.21	0.95	567.7	78	262	263	30	78	71	1					
47.5 19	47.5	0.28	1.20	569.7	78	259	261	30	76	72	2					
50.0 20	50.0	0.18	0.68	570.8	78	258	265	30	78	72	1					
52.5 21	52.5	0.16	0.69	572.1	77	244	263	30	80	72	1					
55.0 22	55.0	0.18	1.20	573.9	77	261	262	30	81	72	2					
57.5 23	57.5	0.23	1.42	575.4	78	263	265	30	83	72	2					
60.0 24	60.0	0.18	0.68	576.8	77	261	264	30	83	72	1					
25																
26																
27																
28																
29																
30																



Filter Number:  
Filter preweight:  
Filter postweight:  
Total:  
Beaker ID:  
Beaker preweight:  
Beaker postweight:  
Total:

SO<sub>2</sub> NO<sub>x</sub> CO  
**AIR ANALYSIS, INC**  
 EPA METHOD 5/202  
 Start Time: 12:00  
 End Time: 1:23  
 Nozzle size measurement  
 a 0.25  
 b 0.25  
 c 0.25  
 Avg. 0.25



**POLLUTANT TESTED: PM<sub>10</sub>**  
 Diagram of Test Location  
 Meter Cu. ft. 301H  
 Stack Temp. (F) 79  
 Probe Temp. (F) 250  
 Filter Temp. (F) 254  
 Impinger Temp. (F) 42  
 Meter Inlet Temp. (F) 83  
 Meter Outlet Temp. (F) 81  
 Vacuum (inches) 3

Traverse Point	Minutes per point	Δ P	Δ H	Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)	Filter Temp. (F)	Impinger Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (inches)	NOTES
1	2.5	0.36	1.42	303.3	79	250	254	42	83	81	3	Linear
2	7	0.40	1.80	305.1	81	248	257	42	80	81	3	NS, SO <sub>2</sub> Co
3	7.5	0.40	1.8	306.0	80	250	254	41	81	81	3	0 0 0
4	10	0.37	1.67	304.7	84	245	255	42	82	82	1	156 154 134
5	12.5	0.22	0.9	310.5	89	247	254	44	85	82	1	744 94 58.3
6	15	0.17	0.85	311.9	91	249	254	45	84	82	1	32.6
7	17.5	0.46	2.0	313.8	95	247	260	42	84	83	3	Be
8	20	0.47	2.1	316.3	97	247	252	44	84	84	1	0 0 0
9	22.5	0.27	1.2	317.8	96	250	252	44	84	84	1	749 92 59
10	25	0.21	0.95	319.3	95	249	252	44	85	85	1	12-21-04
11	25	0.21	0.95	320.5	94	251	255	44	85	85	1	Blow 0 -0.26
12	25	0.21	0.95	322.3	93	251	252	44	86	86	1	15 0 93
13	25	0.20	0.90	323.7	90	251	250	43	87	87	1	1.0 93 58.5
14	35	0.20	0.90	324.9	91	255	254	44	85	85	1	Blow 0 0
15	35	0.20	0.90	326.5	90	252	255	44	85	85	1	Blow 0 0
16	40	0.20	0.90	327.6	89	249	257	44	86	86	1	Blow 0 0
17	40	0.21	0.95	329.3	89	248	257	44	87	87	1	Blow 0 0
18	42.5	0.31	1.4	330.9	88	254	249	44	87	87	1	Blow 0 0
19	47.5	0.66	2.97	333.2	83	257	248	44	89	89	1	Blow 0 0
20	50	0.65	2.92	335.6	81	245	247	44	89	89	1	Blow 0 0
21	52.5	0.55	2.48	338.1	80	246	244	44	89	89	1	Blow 0 0
22	55	0.67	3.0	340.5	78	246	245	44	89	89	1	Blow 0 0
23	57.5	0.61	2.75	343.1	78	244	250	44	89	89	1	Blow 0 0
24	60	0.60	2.7	345.32	77	243	246	44	89	89	1	Blow 0 0
25												
26												
27												
28												
29												
30												


Company: NWSB  
 Location: CLAYBORNE  
 Unit Tested: CASE STRIP  
 Meter Operator: M. Dixon  
 Probe Operator: M. Allen  
 Client Contact: M. Wabser  
 Agency Contact: M. Wabser  
 V.E. Reader: R. S. [unclear]  
 Date: 12-21-04  
 AAI Project: 20.9.8  
 Barometric Pressure: 30.98  
 Ambient Temperature: 35

Filter Number: P1  
 Filter preweight: 0.3252  
 Filter postweight: 0.3254  
 Total: 0.0002  
 Beaker ID:  
 Beaker preweight: 54.2152  
 Beaker postweight: 54.2119  
 Total:

Blank MeCl<sub>2</sub> 54.7070  
 MeCl<sub>2</sub> 54.7043  
 Blank MeCl<sub>2</sub> 54.0021  
 MeCl<sub>2</sub> 55.9913  
 Dia. Acum 185  
 54.1308  
 54.1297  
 NO<sub>x</sub> Range 185  
 SO<sub>2</sub> Range 236  
 CO Range 136  
 DI Blank 65.7412  
 65.7411  
 Ph = 5

SO<sub>2</sub>, NO<sub>x</sub> Co  
 AIR ANALYSIS, INC  
 EPA METHOD 5  
 RUN NUMBER 2 POLLUTANT TESTED  
 Start Time: 2:50  
 End Time: 3:07

65, 75, 10  
 0.25  
 0.968  
 1.87  
 15  
 9



Traverse Point	Minutes per point	Δ P	Δ H	Static Pressure			Filter Temp. (F)	Impinger Outlet Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Vacuum (inches)	NOTES
				Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)					
1	25	0.12	0.22	345.62	90	220	233	46	85	3	
2	5	0.13	0.56	347.2	90	244	251	47	89	1	S
3	16	0.33	1.4	348.3	92	243	248	47	87	1	C
4	10	0.29	1.25	349.0	94	249	248	47	89	1	N
5	125	0.25	1.07	350.42	96	245	245	49	90	1	2
6	15	0.25	1.07	354.42	97	246	248	50	91	1	6
7	175	0.42	1.85	360.3	101	257	251	51	90	2	13
8	20	0.42	1.8	368.5	101	247	258	52	93	2	91
9	225	0.42	1.8	360.5	101	248	249	53	93	2	125
10	25	0.43	1.85	362.5	101	245	247	54	95	2	11
11	25	0.21	0.90	363.9	97	245	252	55	95	1	24
12	30	0.21	0.90	365.24	94	246	252	54	94	1	PH=5
13	325	0.14	0.60	366.4	95	248	248	53	93	0	
14	35	0.3	1.25	368.1	95	252	249	53	95	1	10
15	375	0.40	1.72	370.1	95	250	237	53	96	2	3
16	40	0.38	1.6	372.5	95	252	258	53	87	2	17
17	425	0.38	1.6	374.2	96	250	247	53	84	2	13
18	45	0.38	1.6	376.16	96	249	260	54	89	1	118
19	475	0.20	1.29	377.4	96	250	247	53	89	1	174
20	50	0.27	0.95	378.3	96	252	247	53	89	1	Filter Number: R2
21	525	0.15	0.65	380.1	95	246	260	54	90	0	Filter preweight: 0.3207
22	55	0.27	1.16	381.7	95	250	257	53	90	1	Filter postweight: 0.3208
23	575	0.34	1.46	383.2	95	250	246	55	89	2	Total: 0.0001
24	60	0.30	1.29	384.869	97	251	246	55	89	2	Beaker ID:
25									90		Beaker preweight: 56.3113
26											Beaker postweight: 57.3178
27											Total:
28											48
29											46
30											28

NO 0.07  
 SD 0.0  
 Ca 0.1  
 59.3426  
 55.7306  
 55.7302  
 74.3  
 94  
 59.3426  
 54.1297  
 54.1302  
 6 Awt  
 65.7912  
 1.57911

SO<sub>2</sub> NO<sub>x</sub> CO  
 AIR ANALYSIS, INC  
 EPA METHOD 7-10  
 Start Time: 9:28 PM  
 End Time: 10:38  
 POLLUTANT TESTED: PH<sub>2</sub>O  
 RUN NUMBER: 3  
 Diagram of Test Location




Company: Nuber  
 Location: C Walk  
 Unit Tested: Cantrip  
 Meter Operator: MD  
 Probe Operator: N/A  
 Client Contact: MW  
 Agency Contact: DV  
 V.E. Reader: Next Day  
 AAI Project: Date: 12-20  
 Barometric Pressure: 30.08  
 Ambient Temperature: 33


Traverse Point	Minutes per point	Δ P	Δ H	Static Pressure			Filter Temp. (F)	Impinger Outlet Temp. (F)	Meter Inlet Temp. (F)	Meter Outlet Temp. (F)	Vacuum (inches)	NOTES
				Meter Cu. ft.	Stack Temp. (F)	Probe Temp. (F)						
1	25	0.15	0.65	385.047	65	260	264	73	74	1	Stop	
2	5	0.37	1.59	386.2	60	257	265	72	73	1		
3	75	0.37	1.59	388.9	68	258	266	71	74	1	S C N	
4	10	0.15	0.65	391.0	68	255	264	75	73	1	52 5 45	
5	12.5	0.31	1.3	392.8	71	257	267	77	73	1	6 8 2	
6	15	0.10	1.7	394.5	72	254	267	77	73	1	8 8 2	
7	17.5	0.27	1.59	396.4	72	257	270	79	74	1	32 6 12.1	
8	20	0.45	1.9	398.3	76	257	265	80	73	1	67 5 53	
9	22.5	0.48	2.06	400.0	80	249	265	81	73	1	100 5 88	
10	25	0.48	2.04	402.0	80	250	266	83	74	1	90 2.4 88	
11	25	0.46	1.98	404.1	82	250	267	83	74	1	81 8.7 81	
12	30	0.46	1.98	406.2	83	252	268	79	74	1	16 1.6 15	
13	35	0.20	0.86	407.5	76	253	259	81	74	1	59 22 65	
14	35	0.30	1.29	409.1	81	254	260	82	74	1	24 42 14	
15	35	0.31	1.33	411.2	80	227	264	82	74	1	23 42 14	
16	40	0.31	1.30	412.8	80	223	260	82	74	1	2 40 39	
17	42.5	0.32	1.38	414.9	79	240	259	83	76	1	4 30 1	
18	45	0.32	1.38	416.7	78	202	257	80	73	1	1 30 1	
19	47.5	0.43	1.85	417.2	75	252	257	80	73	1	Filter Number: RB	
20	50	0.15	0.65	418.9	75	252	256	81	75	1	Filter preweight: 0.3253	
21	52.5	0.15	0.65	419.8	75	251	255	80	75	1	Filter postweight: 0.3252	
22	55	0.14	0.60	421.1	75	251	257	80	75	1	Total: 0.0000	
23	57.5	0.3	1.29	422.8	76	242	251	80	75	1	Beaker ID:	
24	60	0.2	0.86	424.0	75	255	257	80	75	1	Beaker preweight: 54.1171	
25											Beaker postweight: 54.1164	
26											Total:	
27												
28												
29												
30												

DI 54.9525 53.7306  
 54.9506 53.7302  
 Blue Ant 54.1208  
 54.1247  
 Blue Mch 65.7912  
 65.7411  
 No<sub>x</sub> 0.7 78  
 SO<sub>2</sub> 0.1 916  
 CO 0.0 59.6  
 PK-5


### Nucor Steel Castrip Stack Test Run 1



### Nucor Steel Castrip Stack Test Run 1




### Nucor Steel Castrip Stack Test Run 2





Ch 1 = NOX, Ch 2 = SO2, Ch 3 = CO



### Nucor Steel Castrip Stack Test Run 2





Ch 1 = NOX, Ch 2 = SO2, Ch 3 = CO



3



3



*Run*

Nucor Steel Castrip

RUN NUMBER	1	2	3
CO SPAN (%)	136.00	136.00	136.00
CO MEASURED (%)	25.80	18.20	24.86
CO SPAN GAS (%)	59.50	59.50	59.50
CO PRE-ZERO (%)	-0.26	0.00	0.10
CO POST ZERO (%)	0.00	0.10	0.00
CO PRE-SPAN (%)	59.00	58.30	59.00
CO POST SPAN (%)	58.30	59.00	59.60
INITIAL ZERO CAL BIAS (%)	-0.19	0.00	0.07
FINAL ZERO CAL BIAS (%)	0.00	0.07	0.00
ZERO DRIFT (%)	0.19	0.07	-0.07
INITIAL SPAN CAL BIAS (%)	-0.37	-0.88	-0.37
FINAL SPAN CAL BIAS (%)	-0.88	-0.37	0.07
SPAN DRIFT (%)	-0.51	0.51	0.44
CO CORRECTED (%)	26.25	18.43	24.91

Nucor Steel Castrip

RUN NUMBER	1	2	3
NOX SPAN (PPM)	185	185	185
NOX MEASURED (PPM)	11.9	9.6	23.0
NOX SPAN GAS (PPM)	74.5	74.5	74.5
NOX PRE-ZERO (PPM)	1.0	-0.1	0.1
NOX POST ZERO (PPM)	-0.1	0.1	0.7
NOX PRE-SPAN (PPM)	75.0	74.0	74.3
NOX POST SPAN (PPM)	74.0	74.3	78.0
INITIAL ZERO CAL BIAS (%)	0.54	-0.05	0.04
FINAL ZERO CAL BIAS (%)	-0.05	0.04	0.38
ZERO DRIFT (%)	-0.59	0.09	0.34
INITIAL SPAN CAL BIAS (%)	0.27	-0.27	-0.11
FINAL SPAN CAL BIAS (%)	-0.27	-0.11	1.89
SPAN DRIFT (%)	-0.54	0.16	2.00
NOX CORRECTED (PPM)	11.5	9.7	22.2

Nucor Steel Castrip

RUN NUMBER	1	2	3
SO2 SPAN (PPM)	235	235	235
SO2 MEASURED (PPM)	17.1	21.2	24.6
SO2 SPAN GAS (PPM)	94.1	94.1	94.1
SO2 PRE-ZERO (PPM)	0.0	0.0	0.0
SO2 POST ZERO (PPM)	0.0	0.0	0.1
SO2 PRE-SPAN (PPM)	93.0	94.0	94.0
SO2 POST SPAN (PPM)	94.0	94.0	96.0
INITIAL ZERO CAL BIAS (%)	0.00	0.00	0.00
FINAL ZERO CAL BIAS (%)	0.00	0.00	0.04
ZERO DRIFT (%)	0.00	0.00	0.04
INITIAL SPAN CAL BIAS (%)	-0.47	-0.04	-0.04
FINAL SPAN CAL BIAS (%)	-0.04	-0.04	0.81
SPAN DRIFT (%)	0.43	0.00	0.85
SO2 CORRECTED (PPM)	17.2	21.2	24.3

Nucor Steel - ANALYZER CALIBRATION DATA  
 Castrip  
 Crawfordsville, IN  
 December 21, 2004  
 8:00 AM

TAG	ANALYZER RESPONSE	PERCENT DIFFERENCE
<b>CO</b>		
<b>SPAN 0-136 ppm</b>		
ZERO	0.00	0.00%
LOW	30.60	0.37%
MID	69.30	-0.15%
HIGH	134.00	0.00%
SPAN		
<b>NOX</b>		
<b>SPAN 0-185 PPM</b>		
ZERO	0.0	0.00%
MID	74.4	-0.05%
HIGH	156.0	0.00%
SPAN		

136

185

Nucor Steel - ANALYZER CALIBRATION DATA  
 Castrip  
 Crawfordsville, IN  
 December 21, 2004  
 6:00 AM

TAG	ANALYZER RESPONSE	PERCENT DIFFERENCE
<b>SO2</b>		
<b>SPAN 0-235</b>		
ZERO	0.00	0.00%
MID	94.10	-0.07%
HIGH	199.00	0.00%
SPAN		

235

Run 3

Time	Total Min	NOx	SO2	CO
9:28-9:38	10	13.2	14.7	7.4
9:41-10:09	28	41.5	41.6	25.7
10:15-10:34	19	0.8	4.8	32.8

Time weighted avg.

0.175439	2.315789	2.578947	1.298246
0.491228	20.38596	20.43509	12.62456
0.333333	0.266667	1.6	10.93333
	<b>22.96842</b>	<b>24.61404</b>	<b>24.85614</b>

ΔAir Analysis, Inc.

Nucor Steel

Project Number 272

**APPENDIX IV**



# STL

STL Indianapolis Service Center  
4299 W. 96th Street  
Indianapolis, IN 46268

Tel: 317 228 9400 Fax: 317 228 9440  
[www.stl-inc.com](http://www.stl-inc.com)

January 10, 2005

Mike Dicen  
Air Analysis  
3904 Clarks Creek Road  
Plainfield, IN 46168

Re: Nucor Steel, Crawfordsville

Dear Mike:

It is with regret that I am detailing the Nucor Steel, Crawfordsville Lead project that you entrusted to STL. What should have been an opportunity to provide outstanding local service for a premier analytical laboratory has evolved into several unfortunate circumstances. On December 22, 2004, I received your samples on behalf of STL and forwarded them to STL Valparaiso at your request. The samples were received intact at STL Indianapolis and were couriered via STL employees to STL Valparaiso that same day.

Due to the Holidays, the STL Valparaiso team completed their review of this project on January 3, 2005. They concluded that they were no longer setup to complete this project as specified in EPA Method 12. Upon this conclusion, the samples were forwarded to STL Knoxville, which provided you with the quote detailing the analytical cost of this project. The quote highlighted a significant increase in costs and change of how the runs were analyzed. At your request, the quote was revised to reflect analyzing the filters and HNO<sub>3</sub> solutions together. Even with this change, the price was still quite different due to the use of Hydrofluoric Acid in the digestion process by STL Knoxville to break down the filters adequately. STL Knoxville suggested that they forward the samples to Element One for you based on your requests and their capabilities.

Meanwhile, when STL Valparaiso had packaged the samples for shipment to STL Knoxville, they were incorrectly packed on ice. During shipment, some of the melted ice entered the Petri dishes containing the filters, thus compromising the integrity of the filter portion for all of the samples. Upon receipt, STL Knoxville contacted STL Valparaiso and STL Indianapolis to determine possible solutions. STL Knoxville called you on January 5, to inform you of the situation and STL Valparaiso's willingness to cover the cost of resampling, if necessary. You suggested the use of particulate filters in place of the initial filters. Upon further consideration, you requested that STL Knoxville forward the HNO<sub>3</sub> solutions to Element One in Wilmington, NC. The solutions left STL Knoxville January 6, 2005 and were received at Element One on January 7, 2005.

If you need further explanation of these events or have questions about this event, please do not hesitate to contact me. I look forward to discuss STL's capabilities, how they fit your analytical needs and to learn from unfortunate circumstances.

Sincerely,

Sue Barto  
Service Center Manager

**Air Analysis, Inc.**  
3904 Clarks Creek Road  
Plainfield, IN 46168

Project - NUCOR STEEL

Lead

EPA Methods 12 Analysis

Analytical Report  
4417



Element One, Inc.  
5022-C Wrightsville Av., Wilmington, NC 28403  
910-793-0128 FAX:910-792-6853 e1lab@hotmail.com

The following data for Analytical Report 4417  
has been reviewed for completeness, accuracy,  
adherence to method protocol,  
and compliance with quality assurance guidelines.

Quality Assurance Review by:

A handwritten signature in black ink, appearing to read 'Melissa Lawrence', with a horizontal line extending to the right.

Melissa Lawrence, QA Officer  
January 24, 2005

Report Reviewed and Finalized By:

Ken Smith, Laboratory Director  
January 24, 2005

el<sub>1</sub>

# SUMMARY OF RESULTS

el<sub>1</sub>

## SUMMARY OF RESULTS

### Summary of Impinger Analysis

<u>Element</u>	<u>Run 1 Total µg</u>	<u>Run 2 Total µg</u>	<u>Run 3 Total µg</u>	<u>Blank Total µg</u>	<u>Run 3 Spike Recovery</u>
Lead, Average	47.7	9.32	0.590	< 0.3	105%
Triplicate RSD	0.7%	0.3%	0.5%	1.0%	

### Summary of Filter Analysis

<u>Element</u>	<u>Run 1 Total µg</u>	<u>Run 2 Total µg</u>	<u>Run 3 Total µg</u>	<u>Blank Total µg</u>	<u>Run 3 Spike Recovery</u>
Lead, Average	6.82	5.85	6.13	0.528	98%
Triplicate RSD	3.5%	3.0%	2.7%	1.1%	

# ANALYTICAL NARRATIVE

el<sub>1</sub>

## Element One Analytical Narrative

Client	Air Analysis, Inc	Element One #:	4417
Client ID:	Nucor Steel	Analyst:	DBW
Method:	12	Dates Received	1/7 & 13/05
Analytes	Lead	Dates Analyzed	1/24/05

### Summary of Analysis

The Method 12 samples were prepared and analyzed according to the method protocol. After digestion the samples were brought to volume of 100 ml. The digested samples were analyzed for on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The ICP-MS instrument reporting limit was 2.5 µg/L for lead.

### Analysis QA/QC

The spike recovery data and triplicate analyses relative standard deviations are summarized with the results. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Nothing unusual was noticed with any of the samples or analyses.

# SAMPLE CUSTODY

el<sub>1</sub>

4417 5-3809

Report To:

Contact: Mr. Dick  
 Company: Air Analysis  
 Address: 3704 Clark Creek  
Union Station  
 Phone: 3122333333  
 Fax: 3122333333  
 E-Mail: airanalysis@comcast.net

Signature: [Signature]  
 Project Number:  
 Date Required: 11-05-05  
 Hard Copy: 1  
 Fax: 1

Laboratory ID	Client Sample ID	Sampling		Matrix	Comp/Grab	Preserv	Volume	# / Cont.	Refr #	Additional Analyses / Remarks
		Date	Time							
	Run 1	12-21	12P							Moisture 12
	Run 2	12-21	2P							EPA Stack Test
	Run 3	12-21	930P							Moisture
	Blank									40 CFR 60
	Run 1	12-21	12P							App B
	Run 2									No Custody Seals
	Run 3									Rec'd Temp: 3°C
	Received for Element One Inc	1-7	13-05	Ken Smith						1 COOLER / HAS Ground
	Received by: [Signature]									T# 12767442034339754
										ADF 01-05-05

RELINQUISHED BY: [Signature] COMPANY: NAI DATE: 12-22 TIME: 11A  
 RECEIVED BY: [Signature] COMPANY: SE DATE: 12-22 TIME: 1310  
 COMMENTS: ONLY SENDING NITRIC RENOVES FILTERS WILL BE SENT FROM ANOTHER LAB RECEIVED BY: [Signature] 01-05-05

**SEVERN TRENT**

STL Valparaiso  
 2400 Cumberland Drive  
 Valparaiso, IN 46383  
 Phone: 219-464-2389  
 Fax: 219-462-2953

Sampler Name: Air Analysis  
 Project Name: Nucle Steel  
 Project Location: Lawrenceville  
 Lab PM: \_\_\_\_\_

Date Required: 11-05-05  
 Hard Copy: 1  
 Fax: 1

Signature: [Signature]  
 Project Number:  
 Date Required: 11-05-05  
 Hard Copy: 1  
 Fax: 1

Received by: [Signature] COMPANY: NAI DATE: 12-22 TIME: 11A  
 RECEIVED BY: [Signature] COMPANY: SE DATE: 12-22 TIME: 1310

Container Key: 114 Preserved Key  
 1. Plastic  
 2. VOA Vial  
 3. Sterile Plastic  
 4. Amber Glass  
 5. Widenmouth Glass  
 6. Other  
 7. None

Contact: [Signature]  
 Company: **COPY**  
 Address:  
 Phone:  
 Fax:  
 PO#:  
 Quote:

Shaded Areas For Internal Use Only  
 Package Sealed: Yes No  
 Received on Ice: Yes No  
 Temperature °C of Cooler:  
 Within Hold Time: Yes No  
 pH Check OK: Yes No NA  
 Sample Labels and COC Agree: Yes No  
 COC not present:  
 Additional Analyses / Remarks:  
 Moisture 12  
 EPA Stack Test  
 Moisture  
 40 CFR 60  
 App B  
 No Custody Seals  
 Rec'd Temp: 3°C  
 1 COOLER / HAS Ground  
 T# 12767442034339754  
 ADF 01-05-05

RECEIVED BY: [Signature] COMPANY: SE  
 RECEIVED BY: [Signature] COMPANY: SE  
 COMMENTS: ONLY SENDING NITRIC RENOVES FILTERS WILL BE SENT FROM ANOTHER LAB RECEIVED BY: [Signature] 01-05-05

# ANALYTICAL DATA

el<sub>1</sub>

Project ID: Nucor Steel  
 Reference Method M-12

DUE DATE: 1/24/05  
 Page 1 of 1

Client Instructions: Per Mike Dicen via phone: Analyze the impingers and filters SEPARATELY. Report total ug for each fraction

Sample Identification		Sample Identification	
1	Impinger Run 1	5	Filter Run 1
2	Impinger Run 2	6	Filter Run 2
3	Impinger Run 3	7	Filter Run 3
4	Impinger Blank	8	Filter Blank

Analyses Requested: Pb Spike all R-3's

HNO<sub>3</sub> Lot: 11040SD HF Lot: HCl Lot: Reference Method  
 Volume Marked Y/ Volume Loss Y/? pH < 2.0 /N Method 12

SAMPLE	BV	FV	Spike	Comments
LRB	100	100		
LRB+	↓	↓	5ug	Lot 021404-A
1	245	↓		
2	258	↓		
3	211	↓		
4	219	↓		
5				
6				
7				
8				

# Dataset Report

User Name: daphne.woodman  
Computer Name: ICPMS1  
Dataset File Path: c:\elandata\dataset\11905-2\  
Report Date/Time: Monday, January 24, 2005 12:21:02

*Daph Woodman*  
*1-24-05*

Autosampler Position: 3

## The Dataset

Time	Sample ID	Batch ID	Read Type	Description	Init. Quant	Prep. Vol.	Aliquot. Vol.	Diluted V
14:14:09 Wed 19-Jan-05	Blank		Blank					
14:16:10 Wed 19-Jan-05	Standard 1		Standard #1					
14:18:11 Wed 19-Jan-05	Standard 2		Standard #2					
14:20:13 Wed 19-Jan-05	Standard 3		Standard #3					
14:22:14 Wed 19-Jan-05	Standard 4		Standard #4					
14:24:15 Wed 19-Jan-05	QC Std 1		QC Std #1					
14:26:17 Wed 19-Jan-05	QC Std 2		QC Std #2					
14:28:18 Wed 19-Jan-05	QC Std 3		QC Std #3					
14:30:19 Wed 19-Jan-05	QC Std 4		QC Std #4					
14:32:23 Wed 19-Jan-05	LRB		Sample	Air Analysis Inc.				
14:34:28 Wed 19-Jan-05	LRB	s	Spike - 1	Air Analysis Inc.				
14:36:34 Wed 19-Jan-05	4417-1		Sample	Air Analysis Inc.				
14:38:40 Wed 19-Jan-05	4417-2		Sample	Air Analysis Inc.				
14:40:44 Wed 19-Jan-05	4417-3		Sample	Air Analysis Inc.				
14:42:47 Wed 19-Jan-05	4417-3	s	Spike - 1	Air Analysis Inc.				
14:44:50 Wed 19-Jan-05	4417-4		Sample	Air Analysis Inc.				
14:46:54 Wed 19-Jan-05	4417-5		Sample	Air Analysis Inc.				
14:48:57 Wed 19-Jan-05	4417-6		Sample	Air Analysis Inc.				
14:51:00 Wed 19-Jan-05	4417-7		Sample	Air Analysis Inc.				
14:53:04 Wed 19-Jan-05	4417-7	s	Spike - 1	Air Analysis Inc.				
14:55:05 Wed 19-Jan-05	QC Std 1		QC Std #1					
14:57:05 Wed 19-Jan-05	QC Std 4		QC Std #4					
14:59:10 Wed 19-Jan-05	4417-8		Sample	Air Analysis Inc.				
15:01:10 Wed 19-Jan-05	QC Std 1		QC Std #1					
15:03:11 Wed 19-Jan-05	QC Std 4		QC Std #4					
15:11:30 Wed 19-Jan-05	Blank		Blank					
15:13:30 Wed 19-Jan-05	Standard 1		Standard #1					
15:15:31 Wed 19-Jan-05	Standard 2		Standard #2					
15:17:33 Wed 19-Jan-05	Standard 3		Standard #3					
15:19:35 Wed 19-Jan-05	Standard 4		Standard #4					
15:21:36 Wed 19-Jan-05	QC Std 1		QC Std #1					
15:23:37 Wed 19-Jan-05	QC Std 2		QC Std #2					
15:25:38 Wed 19-Jan-05	QC Std 3		QC Std #3					
15:27:39 Wed 19-Jan-05	QC Std 4		QC Std #4					
15:29:44 Wed 19-Jan-05	LRB		Sample	Air Analysis Inc.				
15:31:49 Wed 19-Jan-05	LRB	s	Spike - 1	Air Analysis Inc.				
15:33:54 Wed 19-Jan-05	4417-1		Sample	Air Analysis Inc.				
15:36:00 Wed 19-Jan-05	4417-2		Sample	Air Analysis Inc.				
15:38:04 Wed 19-Jan-05	4417-3		Sample	Air Analysis Inc.				
15:40:08 Wed 19-Jan-05	4417-3	s	Spike - 1	Air Analysis Inc.				
15:42:11 Wed 19-Jan-05	4417-4		Sample	Air Analysis Inc.				
15:44:14 Wed 19-Jan-05	4417-5		Sample	Air Analysis Inc.				
15:46:17 Wed 19-Jan-05	4417-6		Sample	Air Analysis Inc.				

15:48:21 Wed 19-Jan-05	4417-7		Sample	Air Analysis Inc.
15:50:25 Wed 19-Jan-05	4417-7	s	Spike - 1	Air Analysis Inc.
15:52:25 Wed 19-Jan-05	QC Std 1		QC Std #1	
15:54:26 Wed 19-Jan-05	QC Std 4		QC Std #4	
15:56:30 Wed 19-Jan-05	4417-8		Sample	Air Analysis Inc.
15:58:31 Wed 19-Jan-05	QC Std 1		QC Std #1	
16:00:31 Wed 19-Jan-05	QC Std 4		QC Std #4	
11:20:00 Mon 24-Jan-05	Blank		Blank	
11:22:00 Mon 24-Jan-05	Standard 1		Standard #1	
11:24:01 Mon 24-Jan-05	Standard 2		Standard #2	
11:26:03 Mon 24-Jan-05	Standard 3		Standard #3	
11:28:05 Mon 24-Jan-05	Standard 4		Standard #4	
11:30:05 Mon 24-Jan-05	QC Std 1		QC Std #1	
11:32:07 Mon 24-Jan-05	QC Std 2		QC Std #2	
11:34:08 Mon 24-Jan-05	QC Std 3		QC Std #3	
11:36:09 Mon 24-Jan-05	QC Std 4		QC Std #4	
11:38:14 Mon 24-Jan-05	LRB		Sample	Air Analysis
11:40:19 Mon 24-Jan-05	LRB	s	Spike - 1	Air Analysis
11:42:24 Mon 24-Jan-05	4417-1		Sample	Air Analysis
11:44:30 Mon 24-Jan-05	4417-2		Sample	Air Analysis
11:46:34 Mon 24-Jan-05	4417-3		Sample	Air Analysis
11:48:37 Mon 24-Jan-05	4417-3	s	Spike - 1	Air Analysis
11:50:40 Mon 24-Jan-05	4417-4		Sample	Air Analysis
11:52:44 Mon 24-Jan-05	4417-5		Sample	Air Analysis
11:54:47 Mon 24-Jan-05	4417-6		Sample	Air Analysis
11:56:50 Mon 24-Jan-05	4417-7		Sample	Air Analysis
11:58:54 Mon 24-Jan-05	4417-7	s	Spike - 1	Air Analysis
12:00:54 Mon 24-Jan-05	QC Std 1		QC Std #1	
12:02:55 Mon 24-Jan-05	QC Std 4		QC Std #4	
12:05:00 Mon 24-Jan-05	4417-8		Sample	Air Analysis
12:07:00 Mon 24-Jan-05	QC Std 1		QC Std #1	
12:09:01 Mon 24-Jan-05	QC Std 4		QC Std #4	
12:11:19 Mon 24-Jan-05	4417-7	X2	Sample	Air Analysis
12:13:24 Mon 24-Jan-05	4417-7	X2S	Spike - 1	Air Analysis
12:15:24 Mon 24-Jan-05	QC Std 1		QC Std #1	
12:17:25 Mon 24-Jan-05	QC Std 4		QC Std #4	

# Sample/Batch Report

User Name: daphne.woodman

Computer Name: ICPMS1

Sample File: C:\elandata\Sample\Method 12.sam

Report Date/Time: Monday, January 24, 2005 12:21:07

*Daph Woodman*  
*1-24-05*

A/S Loc.	Batch ID	Sample ID	Description	Sample Type	Init. Quant.	Prep. Vol.	Aliquot Vol.	Diluted Vol.	Solids Ratio
10		LRB	Air Analysis						
11	s	LRB	Air Analysis	Spike - 1					
12		4417-1	Air Analysis						
13		4417-2	Air Analysis						
14		4417-3	Air Analysis						
15	s	4417-3	Air Analysis	Spike - 1					
16		4417-4	Air Analysis						
17		4417-5	Air Analysis						
18		4417-6	Air Analysis						
19		4417-7	Air Analysis						
20	s	4417-7	Air Analysis	Spike - 1					
21		4417-8	Air Analysis						
22	X2	4417-7	Air Analysis						
23	X2S	4417-7	Air Analysis	Spike - 1					

Analyst: DBW Date: 1-19-05 Solid Samples  / Liquid Samples

*Graph Work  
1-24-05*

A/S Loc	Batch # for sample sets	Sample Lab ID	Sample Description	Type Sample QC Spike QC Dup QC Reg Blank	Spike concentratio	Prep Volume (ml)	Aliquot (ml)	Diluted to Volume (ml)	Units
10			LRB	S		100			
11			LRB	SS	Table #1	100			
12			4417-1	S		100			
13			4417-2	S		100			
14			4417-3	S		100			
15			4417-3	SS	Table #1	100			
16			4417-4	S		100			
17			4417-5	S		100			
18			4417-6	S		100			
19			4417-7	S		100			
20			4417-7	SS	Table #1	100			
21			4417-8	S		100			
Recheck on 1/24/05									
10			LRB	S		100			
11			LRB	SS	Table #1	100			
12			4417-1	S		100			
13			4417-2	S		100			
14			4417-3	S		100			
15			4417-3	SS	Table #1	100			
16			4417-4	S		100			
17			4417-5	S		100			

Analyst: DBW Date: 1-19-05 Solid Samples  / Liquid Samples

18			4417-6	S		100			
19			4417-7	S		100			
20			4417-7	SS	Table #1	100			
21			4417-8	S		100			
22			4417-7	S		100	5.0	10	
23			4417-7	SS	Table #1	100	5.0	10	

Spikes are post at 0.02mL of 25ppm spiking solutions lot 021404-ABC & F in a final volume of 10ml.

Submitted for QC:	Date: 1-24-05 DCS	Time: 14:40	By: DW	QC Review:	Date:	Time:	By:
Re-Test Required:	No:	Yes:	Comments:				
Resubmitted for QC:	Date:	Time:	By:	QC Review:	Date:	Time:	By:

File Edit Analysis Options Window Help

Timing Processing Equation Calibration Sampling Devices QC...

Analyte	Mass (amu)	Spike Table 1 (Conc.)	Spike Table 1 Det. Limit (Conc.)	Spike Table 2 (Conc.)	Spike Table 2 Det. Limit (Conc.)	Spike Table 3 (Conc.)	Spike Table 3 Det. Limit (Conc.)	Spike Table 4 (Conc.)	Spike Table 4 Det. Limit (Conc.)
1 Rh	102.905								
2 Pb	207.977	50	0.001	25	1	100	1		
3 Kr	82.9141								1

Report Notes

Method 6020 Multi Metals Summary Report

Sample ID: Blank

Sample Date Monday, January 24, 2005 11:20:00

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	391480.9		ppb
>	Ho	165	938511.3		ppb
-	Pb	208	2909		ppb
	Kr	83	107.7		ppb

Replicates

Concentration

Concentration

Concentration

Method 6020 Multi Metals Summary Report

Sample ID: Standard 1

Sample Date Monday, January 24, 2005 11:22:00

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	394611		ppb
>	Ho	165	928838.7		ppb
-	Pb	208	44084.5	0.94342	ppb
	Kr	83	90.2		ppb

Replicates

Concentration

0.936532

Concentration

0.944347

Concentration

0.949393

Method 6020 Multi Metals Summary Report

Sample ID: Standard 2

Sample Date Monday, January 24, 2005 11:24:01

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	393694.6		ppb
>	Ho	165	936654.2		ppb
-	Pb	208	4346126.2	98.61091	ppb
	Kr	83	96.2		ppb

Replicates

Concentration

97.863184

Concentration

98.250378

Concentration

99.719171

Method 6020 Multi Metals Summary Report

Sample ID: Standard 3

Sample Date Monday, January 24, 2005 11:26:03

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh		103 378395		ppb
>	Ho		165 919401		ppb
	Pb		208 22340120	516.67433	ppb
	Kr		83 127.7		ppb

Replicates

Concentration

512.54341

Concentration

516.53282

Concentration

520.94676

Method 6020 Multi Metals Summary Report

Sample ID: Standard 4

Sample Date Monday, January 24, 2005 11:28:05

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh		103 436937.7		ppb
>	Ho		165 1036575.2		ppb
	Pb		208 48342772	991.8018	ppb
	Kr		83 96.3		ppb

Replicates

Concentration

994.36852

Concentration

993.28313

Concentration

987.75376

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1

Sample Date Monday, January 24, 2005 11:30:05

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh		103 395817.2		ppb
>	Ho		165 941154.7		ppb
	Pb		208 21569.5	0.42297	ppb
	Kr		83 85.7		ppb

Replicates

Concentration

0.579235

Concentration

0.36756

Concentration

0.322105

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 2

Sample Date Monday, January 24, 2005 11:32:07

Sample Description:

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	392382.7		ppb
>	Ho		165	936623.8		ppb
-	Pb		208	47244.8	1.00689	ppb
	Kr		83	100		ppb

Replicates

Concentration

1.018207

Concentration

0.993799

Concentration

1.008649

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 3

Sample Date Monday, January 24, 2005 11:34:08

Sample Description:

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	362856.5		ppb
>	Ho		165	883614		ppb
-	Pb		208	8102509.9	194.948	ppb
	Kr		83	97.3		ppb

Replicates

Concentration

195.06686

Concentration

195.08779

Concentration

194.68936

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4

Sample Date Monday, January 24, 2005 11:36:09

Sample Description:

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	392875.1		ppb
>	Ho		165	951467.6		ppb
-	Pb		208	4416293.2	98.65591	ppb
	Kr		83	94.5		ppb

Replicates

Concentration

98.515932

Concentration

99.824741

Concentration

97.62707

Method 6020 Multi Metals Summary Report

Sample ID: LRB

Sample Date Monday, January 24, 2005 11:38:14

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	414524.2		ppb
>	Ho		165	1000601.3		ppb
-	Pb		208	15361.6	0.26076	ppb
	Kr		83	76.7		ppb

Replicates

Concentration

0.304617

Concentration

0.244531

Concentration

0.233144

Method 6020 Multi Metals Summary Report

Sample ID: LRB

Sample Date Monday, January 24, 2005 11:40:19

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	389035.4		ppb
>	Ho		165	942638.3		ppb
-	Pb		208	1940701	43.71831	ppb
	Kr		83	73.5		ppb

Replicates

Concentration

43.503338

Concentration

43.625372

Concentration

44.026227

Method 6020 Multi Metals Summary Report

Sample ID: 4417-1

Sample Date Monday, January 24, 2005 11:42:24

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	399837		ppb
>	Ho		165	978444.5		ppb
-	Pb		208	21935323	476.68851	ppb
	Kr		83	80.7		ppb

Replicates

Concentration

473.3592

Concentration

476.80374

Concentration

479.9026

Method 6020 Multi Metals Summary Report

Sample ID: 4417-2

Sample Date Monday, January 24, 2005 11:44:30

Sample Description Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	309756.3		ppb
>	Ho	165	758882.7		ppb
-	Pb	208	3327597	93.18662	ppb
	Kr	83	88		ppb

Replicates

Concentration

93.037188

Concentration

93.000283

Concentration

93.522375

Method 6020 Multi Metals Summary Report

Sample ID: 4417-3

Sample Date Monday, January 24, 2005 11:46:34

Sample Description Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	402245.2		ppb
>	Ho	165	959768.6		ppb
-	Pb	208	269401.2	5.90363	ppb
	Kr	83	88.8		ppb

Replicates

Concentration

5.886636

Concentration

5.939818

Concentration

5.884443

Method 6020 Multi Metals Summary Report

Sample ID: 4417-3

Sample Date Monday, January 24, 2005 11:48:37

Sample Description Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	368642.6		ppb
>	Ho	165	876025.4		ppb
-	Pb	208	2406986.5	58.37901	ppb
	Kr	83	75.7		ppb

Replicates

Concentration

59.461515

Concentration

57.945462

Concentration

57.730038

Method 6020 Multi Metals Summary Report

Sample ID: 4417-4

Sample Date Monday, January 24, 2005 11:50:40

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	396443.5		ppb
>	Ho	165	951891		ppb
-	Pb	208	68047.5	1.45445	ppb
	Kr	83	81		ppb

Replicates

Concentration

1.465581

Concentration

1.458955

Concentration

1.438817

Method 6020 Multi Metals Summary Report

Sample ID: 4417-5

Sample Date Monday, January 24, 2005 11:52:44

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	309814.4		ppb
>	Ho	165	771514.6		ppb
-	Pb	208	2477924.1	68.24394	ppb
	Kr	83	817.4		ppb

Replicates

Concentration

66.988611

Concentration

71.032855

Concentration

66.710354

Method 6020 Multi Metals Summary Report

Sample ID: 4417-6

Sample Date Monday, January 24, 2005 11:54:47

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	301923.4		ppb
>	Ho	165	744214.8		ppb
-	Pb	208	2050327.8	58.51319	ppb
	Kr	83	653.7		ppb

Replicates

Concentration

57.143871

Concentration

57.917258

Concentration

60.478449

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1

Sample Date Monday, January 24, 2005 12:00:54

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	489937.9		ppb
>	Ho	165	1097390.4		ppb
-	Pb	208	13725.2	0.20162	ppb
	Kr	83	107.7		ppb

Replicates

Concentration

0.116055

Concentration

0.067009

Concentration

0.421791

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4

Sample Date Monday, January 24, 2005 12:02:55

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	464341.5		ppb
>	Ho	165	1066882.6		ppb
-	Pb	208	4855912.2	96.729	ppb
	Kr	83	108.3		ppb

Replicates

Concentration

96.455488

Concentration

96.695171

Concentration

97.036341

Method 6020 Multi Metals Summary Report

Sample ID: 4417-B

Sample Date Monday, January 24, 2005 12:05:00

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	396252.5		ppb
>	Ho	165	1012304		ppb
-	Pb	208	254475.2	5.28122	ppb
	Kr	83	238.3		ppb

Replicates

Concentration

5.328981

Concentration

5.298655

Concentration

5.216032

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1

Sample Date Monday, January 24, 2005 12:07:00

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	481903.9		ppb
>	Ho	165	1096369		ppb
-	Pb	208	4640.2	0.02411	ppb
	Kr	83	93.7		ppb

Replicates

Concentration

0.028399

Concentration

0.022128

Concentration

0.021812

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4

Sample Date Monday, January 24, 2005 12:09:01

Sample Description:

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	456539.2		ppb
>	Ho	165	1055692.2		ppb
-	Pb	208	4909496.2	98.84661	ppb
	Kr	83	108.7		ppb

Replicates

Concentration

98.826993

Concentration

97.449819

Concentration

100.26302

Method 6020 Multi Metals Summary Report

Sample ID: 4417-7

Sample Date Monday, January 24, 2005 12:11:19

Sample Des: Air Analysis

Concentration Results

	Analyte	Mass	Meas. Intens	Conc. Mean	Report Unit
	Rh	103	420935.3		ppb
>	Ho	165	1022470.7		ppb
-	Pb	208	1476955.9	30.65381	ppb
	Kr	83	391		ppb

Replicates

Concentration

29.817641

Concentration

31.498349

Concentration

30.64544

Method 6020 Multi Metals Summary Report

Sample ID: 4417-7

Sample Date Monday, January 24, 2005 12:13:24

Sample Description: Air Analysis

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	433709.7		ppb
>	Ho		165	1061345.1		ppb
-	Pb		208	3987005.1	79.82664	ppb
	Kr		83	443		ppb

Replicates

Concentration

80.931218

Concentration

78.134832

Concentration

80.413876

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 1

Sample Date Monday, January 24, 2005 12:15:24

Sample Description:

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	481253.3		ppb
>	Ho		165	1087546.5		ppb
-	Pb		208	6778.7	0.06666	ppb
	Kr		83	102.3		ppb

Replicates

Concentration

0.080756

Concentration

0.065287

Concentration

0.053925

Method 6020 Multi Metals Summary Report

Sample ID: QC Std 4

Sample Date Monday, January 24, 2005 12:17:25

Sample Description:

Concentration Results

	Analyte	Mass	Meas.	Intens	Conc. Mean	Report Unit
	Rh		103	467852.5		ppb
>	Ho		165	1062876.2		ppb
-	Pb		208	4851374.3	97.00291	ppb
	Kr		83	104.3		ppb

Replicates

Concentration

96.470626

Concentration

97.202264

Concentration

97.335828

## Element One Analytical Narrative

Client	Air Analysis, Inc	Element One #:	4417
Client ID:	Nucor Steel	Analyst:	DBW
Method:	12	Dates Received	1/7 & 13/05
Analytes	Lead	Dates Analyzed	1/24/05

### Summary of Analysis

The Method 12 samples were prepared and analyzed according to the method protocol. After digestion the samples were brought to volume of 100 ml. The digested samples were analyzed for on a PerkinElmer ELAN 6100 ICP-MS.

### Detection Limits

The ICP-MS instrument reporting limit was 2.5 µg/L for lead.

### Analysis QA/QC

The spike recovery data and triplicate analyses relative standard deviations are summarized with the results. All QA/QC data was within the criteria of the method.

### Additional Comments

The reported results have not been corrected for any blank values or spike recovery values. Nothing unusual was noticed with any of the samples or analyses.

## SUMMARY OF RESULTS

### Summary of Impinger Analysis

<u>Element</u>	<u>Run 1 Total µg</u>	<u>Run 2 Total µg</u>	<u>Run 3 Total µg</u>	<u>Blank Total µg</u>	<u>Run 3 Spike Recovery</u>
Lead, Average	47.7	9.32	0.590	< 0.3	105%
Triplicate RSD	0.7%	0.3%	0.5%	1.0%	

### Summary of Filter Analysis

<u>Element</u>	<u>Run 1 Total µg</u>	<u>Run 2 Total µg</u>	<u>Run 3 Total µg</u>	<u>Blank Total µg</u>	<u>Run 3 Spike Recovery</u>
Lead, Average	6.82	5.85	6.13	0.528	98%
Triplicate RSD	3.5%	3.0%	2.7%	1.1%	





**APPENDIX V**



STL Valparaiso  
2400 Cumberland Drive  
Valparaiso, IN 46383  
Phone: 219-464-2389  
Fax: 219-462-2953

Contact: M. Dican  
Company: Air Analysis  
Address: 3904 Clarks Creek  
Plainfield IN 46168  
Phone: 3178378514  
Fax: 317 837 8578  
E-Mail: airindy@ameritech.net

Contact: Same  
Company: \_\_\_\_\_  
Address: \_\_\_\_\_  
Phone: \_\_\_\_\_  
Fax: \_\_\_\_\_  
PO#: \_\_\_\_\_  
Quote: \_\_\_\_\_

Shaded Areas For Internal Use Only of \_\_\_\_\_  
Package Sealed: Yes No  
Received on Ice: Yes No  
Temperature: °C of Cooler

Laboratory ID	MS/MSD	Client Sample ID	Sampling		Matrix	Comp/Grab	Preserv	Volume	# / Cont.	Refrg #	Within Hold Time		Preserv. Indicated		pH Check OK	Res Cl <sub>2</sub> Check OK	Sample Labels and COC Agree	Additional Analyses / Remarks
			Date	Time							Yes	No	Yes	No				
		Run 1	12-21	12P														Method 1 Z
		Run 2	12-21	2P														EPA Stack Test
		Run 3	12-21	930P														Method
		Blck K																40 CFR 60
		Run 1 Filter	12-21	12P														App B
		Run 2 Filter	"	2P														
		Run 3 Filter	"	930P														

RELINQUISHED BY	COMPANY	DATE	TIME	RECEIVED BY	COMPANY	DATE	TIME
<u>KUD</u>	<u>AAE</u>	<u>12-22</u>	<u>11A</u>				

- Matrix Key**  
 WW = Wastewater  
 W = Water  
 S = Soil  
 SL = Sludge  
 MS = Miscellaneous  
 OL = Oil  
 A = Air
- Container Key**  
 1. Plastic  
 2. VOA Vial  
 3. Sterile Plastic  
 4. Amber Glass  
 5. Widemouth Glass  
 6. Other P
- Preservative Key**  
 1. HCl, Cool to 4°  
 2. H<sub>2</sub>SO<sub>4</sub>, Cool to 4°  
 3. HNO<sub>3</sub>, Cool to 4°  
 4. NaOH, Cool to 4°  
 5. NaOH/Zn, Cool to 4°  
 6. Cool to 4°  
 7. None

COMMENTS

Date Received: \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_  
 Courier: \_\_\_\_\_  
 Bill of Lading: \_\_\_\_\_

ΔAir Analysis, Inc.

Nucor Steel  
Project Number 272

**APPENDIX VI**

**CALIBRATION CHECK**  
 (Post Test) per EMTC Guideline GD-26  
 1/22/04

Nucor Steel Corporation  
 Crawfordsville, IN

Y set =	0.991	0.990	0.989	0.992
---------	-------	-------	-------	-------

Average result must be within 0% of Y

Result (R): 1.86%

PASS POST CAL

R1:	19
Y1:	0.989
Delta H1:	1.87

RUN#	Volume	Delta H	DGM(Inlet)	DGM(Outlet)
1		1.820	83	81
2	Nucor Steel Corporation	1.820	80	81
3	1/22/04	1.820	81	81
4	(Post Test) per EMTC Guideline GD-26	1.895	81	81
5		0.900	82	82
6		0.855	84	82
7		2.070	86	83
8		2.115	92	83
9		1.715	85	84
10		0.945	82	84
11		0.945	83	85
12		0.865	85	86
13		0.900	83	87
14		0.900	85	88
15		0.820	85	87
16		0.900	85	89
17		0.845	87	87
18		1.345	85	88
19		2.070	88	90
20		2.025	80	91
21		2.475	80	91
22	845,300	3.015	88	92
23	301,600	2.745	89	92
24		2.700	90	92

Volume	Avg. Dh	Avg. Meter T(F)
845,300	1.85	88.17

Barometric Pressure:	30.08	Meter Y:	0.989
Test Time:	60	Delta H:	1.87

Yes = 0.991

RUN#	Volume	Delta H	DGM(Inlet)	DGM(Outlet)
1	Nucor Steel Corporation	0.55	73	74
2	1/22/04	0.55	72	74
3	(Post Test) per EMTC Guideline GD-26	1.42	71	74
4		1.42	72	74
5		1.09	75	72
6		1.09	77	73
7		1.85	77	73
8		1.81	79	74
9		1.81	80	73
10		1.85	81	73
11		0.90	83	74
12		0.90	82	74
13		0.90	78	74
14		1.29	81	74
15		1.72	82	74
16		1.68	81	74
17		1.63	82	74
18		1.63	83	75
19		1.29	80	73
20		0.95	81	75
21	384,800	0.95	81	74
22	245,820	1.68	80	75
23		1.68	80	75
24		1.29	80	75

Volume	Avg. Dh	Avg. Meter T(F)
384,800	1.29	78.38

Barometric Pressure:	30.08	Meter Y:	0.989
Test Time:	60	Delta H:	1.870

Yes = 0.990

RUN#	Volume	Delta H	DGM(Inlet)	DGM(Outlet)
1		0.65	73	74
2	Nucor Steel Corporation	1.59	72	74
3	1/22/04	1.59	71	73
4	Crawfordsville, IN	0.65	72	74
5		1.33	75	72
6		1.72	77	73
7		1.59	77	73
8		1.84	79	74
9		2.09	80	73
10		2.08	81	73
11		1.89	83	74
12		1.28	83	74
13		0.86	79	74
14		1.28	81	74
15		1.33	82	74
16		1.33	81	74
17		1.38	82	74
18		1.38	83	75
19		1.85	80	73
20		0.95	81	75
21	434,240	0.95	81	74
22	385,047	0.80	80	75
23		1.29	80	75
24		0.88	80	75

Volume	Avg. Dh	Avg. Meter T(F)
385,047	1.35	78.38

Barometric Pressure:	30.08	Meter Y:	0.989
Test Time:	60	Delta H:	1.870

Yes = 0.989

**CALIBRATION CHECK**  
 (Post Test) per EMTC Guideline GD-26  
 1/27/04

Nucor Steel  
 Crawfordsville, IN

Y <sub>gas</sub> =	0.990	0.947	0.944	0.980
--------------------	-------	-------	-------	-------

Average result must be within 5% of Y  
 Result (%) = 1.31%

PASS POST CAL

ID:	80
Y:	0.947
Delta H:	1.87

Run #	Volume	Delta H	DCMInlet	DCMOutlet
1		1.845	77	77
2	Nucor Steel	1.710	77	77
3	1/27/04	1.800	76	78
4	(Post Test) per EMTC Guideline GD-26	1.800	80	79
5		1.280	82	77
6		0.810	83	77
7		1.350	83	77
8		2.025	83	77
9		1.645	80	77
10		0.855	89	79
11		0.855	90	79
12		0.810	90	78
13		0.830	94	80
14		0.540	98	80
15		0.540	95	80
16		0.495	99	80
17		0.540	99	80
18		1.305	92	81
19		4.050	91	81
20		4.050	94	81
21	Dry Gas Meter Box	3.090	95	82
22		409.815	4.050	95
23		459.083	4.050	95
24		4.775	95	83

Volume	45.752	Avg. Dh	1.82	Avg. Meter T(F)	69.49
--------	--------	---------	------	-----------------	-------

Barometric Pressure:	30.00	Meter Y:	0.947
Test Time:	60	Delta H:	1.87

Y<sub>gas</sub> = 0.990

Run #	Volume	Delta H	DCMInlet	DCMOutlet
1	Nucor Steel	0.85	80	80
2	1/27/04	1.33	81	80
3	(Post Test) per EMTC Guideline GD-26	1.72	85	80
4		1.63	85	80
5		1.63	87	80
6		1.55	88	80
7		1.08	89	80
8		1.42	91	80
9		1.30	89	80
10		1.20	89	80
11		0.52	89	80
12		0.52	87	80
13		0.80	85	80
14		1.25	88	80
15		1.59	90	80
16		1.55	92	81
17		1.59	92	81
18		1.59	92	81
19		1.25	90	81
20		0.77	91	81
21		538.093	0.69	91
22		499.990	1.63	92
23			1.46	93
24		1.51	94	82

Volume	39.103	Avg. Dh	1.21	Avg. Meter T(F)	64.38
--------	--------	---------	------	-----------------	-------

Barometric Pressure:	30.08	Meter Y:	0.947
Test Time:	80	Delta H:	1.870

Y<sub>gas</sub> = 0.947

Run #	Volume	Delta H	DCMInlet	DCMOutlet
1		0.85	70	71
2	Nucor Steel	1.48	58	71
3	1/27/04	1.72	89	70
4	Crawfordsville, IN	0.73	71	70
5		1.20	72	70
6		1.42	74	70
7		1.59	74	70
8		1.94	77	70
9		2.15	79	71
10		2.11	80	71
11		2.08	80	71
12		1.94	81	71
13		0.95	75	71
14		0.88	78	72
15		0.95	77	71
16		0.95	77	71
17		0.90	78	72
18		0.95	76	71
19		1.20	76	72
20		0.69	76	72
21		570.888	0.89	76
22		539.724	1.20	81
23			1.42	83
24		0.89	83	72

Volume	38.484	Avg. Dh	1.25	Avg. Meter T(F)	73.85
--------	--------	---------	------	-----------------	-------

Barometric Pressure:	30.08	Meter Y:	0.947
Test Time:	80	Delta H:	1.870

Y<sub>gas</sub> = 0.944

**GRASEBY NUTECH**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**  
**English Meter Box Units, English K' Factor**

Filename: A:\PTCQC\CAL.XLS  
 Revised: 8/1/97 Version: 1.01

Model #: mst  
 Serial #: 90679.00  
 Date: \_\_\_\_\_  
 Barometric Pressure: 30.10 (in. Hg)  
 Theoretical Critical Vacuum: 14.20 (in. Hg)

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>/(deg R)<sup>0.5</sup>/(in.Hg)<sup>0.5</sup>(min).

**-CRITICAL ORIFICE READINGS-**

Delta H (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Final Temps.		Orifice K' Orifice Serial# (number)	Actual - Ambient Temperature --		Average (deg F)
					Inlet (deg F)	Outlet (deg F)		Vacuum (in Hg)	Initial (deg F)	
1.62	5.00	143.000	146.691	3.691	77.0	71.0	3	17.5	71.0	71.0
1.62	5.00	146.691	150.178	3.487	71.0	72.0	3	17.5	71.0	71.0
1.62	5.00	150.178	153.773	3.595	72.0	71.0	3	18.0	71.0	71.0

**- DRY GAS METER READINGS -**

**\*\*\*\*\* RESULTS \*\*\*\*\***

**- DRY GAS METER - - - - - ORIFICE - - - - -**

VOLUME CORRECTED Vm(std) (cu ft)	VOLUME CORRECTED Vm(std) (liters)	VOLUME CORRECTED Vcr(std) (cu ft)	VOLUME CORRECTED Vcr (liters)	VOLUME NOMINAL Vcr (cu ft)	CALIBRATION FACTOR		CALIBRATION FACTOR		
					Y Value (number)	Y Variation (number)	Delta H@ Value (in H2O)	Delta H@ Value (mm H2O)	
3.700	104.8	3.484	98.7	3.484	0.942	-0.026	1.883	47.83	
3.501	99.1	3.484	98.7	3.484	0.995	0.028	1.879	47.74	
3.606	102.1	3.484	98.7	3.484	0.966	-0.001	1.878	47.69	
Average Y →					0.968		1.880	47.75 ←	Average dh@

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dh@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: 

Date: Sept 9, 2004

**GRASEBY NUTECH**  
**EPA Method 5**  
**Meter Box Calibration**  
**Post-Test Orifice Method**  
**English Meter Box Units, English K' Factor**

Filename: A:\PTCQC\CAL.XLS Version: 1.01  
 Revised: 8/1/97

Model #: msl  
 Serial #: 90680.00  
 Date: \_\_\_\_\_  
 Barometric Pressure: \_\_\_\_\_  
 Theoretical Critical Vacuum: \_\_\_\_\_

29.99 (in. Hg)  
 14.15 (in. Hg)

IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.  
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)<sup>3</sup>\*(deg R)<sup>0.5</sup>/((in.Hg)<sup>3</sup>(min)).

**CRITICAL ORIFICE READINGS**

**DRY GAS METER READINGS**

Delta H (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume		Final Temps.		Orifice K' Orifice Serial# (number)	Actual - Ambient Temperature --		Average (deg F)
				Total (cu ft)	Corrected (cu ft)	Inlet (deg F)	Outlet (deg F)		Vacuum Initial (in Hg)	Vacuum Final (in Hg)	
1.62	5.00	10.490	14.072	3.672	77.0	80.0	77.0	3	18.0	72.0	72.0
1.62	5.00	14.072	17.741	3.669	77.0	80.0	77.0	3	18.0	72.0	72.0
1.62	5.00	17.741	21.541	3.800	77.0	80.0	77.0	3	18.0	72.0	72.0

**RESULTS**

**DRY GAS METER -- ORIFICE**

DRY GAS METER			ORIFICE			DRY GAS METER -- ORIFICE		
VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	VOLUME CORRECTED	Value	Variation	Value
Vm(std)	Vm(std)	Vm(std)	Vcr(std)	Vcr(std)	Vcr(std)	(in H2O)	(number)	(in H2O)
3.625	3.468	3.468	98.2	3.487	3.487	1.867	0.957	1.867
3.619	3.468	3.468	98.2	3.487	3.487	1.867	0.958	1.867
3.748	3.468	3.468	98.2	3.487	3.487	1.867	0.925	1.867
Average Y						1.867	0.947	1.867

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: [Signature] Date: Sept. 7, 2004

# ΔAir Analysis, Inc.

3904 Clarks Creek Road  
Plainfield, Indiana 46168  
(317) 837-8514  
(317) 837-8518 fax

## Pitot Tube Calibration

Reference: 40CFR 60, Appendix A, Method 2, Section 2.1

**Probe Length:** 4 feet  
**External Tubing Diameter:** 0.95 centimeters  
**Base to Opening Plane Distance (Pa):** 1.2 centimeters  
**Base to Opening Plane Distance (Pb):** 1.2 centimeters

	Measured	Allowable
Pa/Dt	1.26cm	$1.05Dt \leq P \leq 1.50Dt$ (0.9975cm - 1.42cm)
Pb/Dt	1.26cm	$1.05Dt \leq P \leq 1.50Dt$ (0.9975cm - 1.42cm)
Angle $\alpha$ 1	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0^\circ$
Angle $\alpha$ 2	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0^\circ$
Angle $\beta$ 1	1 deg	$\beta 1$ and $\beta 2 \leq 5.0^\circ$
Angle $\beta$ 2	1 deg	$\beta 1$ and $\beta 2 \leq 5.0^\circ$
z (cm)	0.0	z is less than 0.32cm (1/8 <sup>th</sup> " )
w (cm)	0.0	w is less than 0.08cm (1/32 <sup>nd</sup> " )
If all criteria are met, Pitot Coefficient is 0.84		<b>Pitot Coefficient: 0.84</b>

Calibrated By:



Date Calibrated:

February 4, 2004

## Thermocouple Test

Control factor	Mercury Thermometer F	Probe Response
ICE	33°	34°
AMBIENT	74°	72°
BOILING/ HOT H2O	160°	160°

Test performed by:



Date of test: February 4<sup>st</sup>, 2004

# ΔAir Analysis, Inc.

3904 Clarks Creek Road  
Plainfield, Indiana 46168  
(317) 837-8514  
(317) 837-8518 fax

## Pitot Tube Calibration

Reference: 40CFR 60, Appendix A, Method 2, Section 2.1

**External Tubing Diameter:** 0.95 centimeters  
**Base to Opening Plane Distance (Pa):** 1.15 centimeters  
**Base to Opening Plane Distance (Pb):** 1.15 centimeters

	Measured	Allowable
Pa/Dt	1.21cm	$1.05Dt \leq P \leq 1.50Dt$ (0.9975cm - 1.42cm)
Pb/Dt	1.21cm	$1.05Dt \leq P \leq 1.50Dt$ (0.9975cm - 1.42cm)
Angle $\alpha$ 1	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0^\circ$
Angle $\alpha$ 2	0 deg	$\alpha 1$ and $\alpha 2 \leq 10.0^\circ$
Angle $\beta$ 1	1 deg	$\beta 1$ and $\beta 2 \leq 5.0^\circ$
Angle $\beta$ 2	1 deg	$\beta 1$ and $\beta 2 \leq 5.0^\circ$
z (cm)	0.0	z is less than 0.32cm (1/8 <sup>th</sup> " )
w (cm)	0.0	w is less than 0.08cm (1/32 <sup>nd</sup> " )

If all criteria are met, Pitot Coefficient is 0.84

**Pitot Coefficient: 0.84**

Calibrated By:  Date Calibrated: February 5, 2004

## Thermocouple Test

Control factor	Mercury Thermometer F	Probe Response
ICE	25°	26°
AMBIENT	71°	72°
BOILING/HOT H2O	171°	172°

Test performed by:  Date of test: February 5, 2004



532-7474

Linde Gas



# Certificate of Analysis EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

LINDE COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	2241	<b>A31</b>	<b>Blend Tolerance:</b>	5 % Relative
EPA MISC 2 COMPONENT			<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100088590		<b>Cyl. Pressure:</b>	2000 psig
<b>Lot #:</b>	02499H4300YC		<b>Balance Gas:</b>	Nitrogen
<b>Cylinder #:</b>	CC136537		<b>CGA:</b>	660
<b>Expiration Date:</b>	9/17/2006		<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	24 months		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	95	94.1 ± 0.9 ppm	09/17/2004
7727-37-9	Nitrogen		Balance	09/17/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CC13966 , GMIS	50.40 ppm	01/30/2006
7446-09-5	Sulfur Dioxide	CC7797 , GMIS	500.3 ppm	09/07/2006

Instrument	Serial #	Analytical Principle	Calibration Date
Thermo Nicolet AEM	AET0100218	FTIR	07/13/2004
Horiba VIA-510	4131546004	Non-Dispersive Infrared	07/16/2004

All analyses are performed under controlled environmental conditions. This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

B17782B

Analytical report approved by Roy Yoder

*Roy Yoder*



**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

**Notice:** This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*  
Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*  
LINDE COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6651	<b>Blend Tolerance:</b>	5 % Relative
EPA SO2/AIR 100-4500 PPM	A31	<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100081509	<b>Cyl. Pressure:</b>	1450 psig
<b>Lot #:</b>	02499A2180GK1	<b>Balance Gas:</b>	Air
<b>Cylinder #:</b>	CC35190	<b>CGA:</b>	660
<b>Expiration Date:</b>	3/18/2006	<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	24 months	<b>Confidence:</b>	95 %

\* Recertification

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
7446-09-5	Sulfur Dioxide	199	199 +/- 2 ppm	03/18/2004
132259-10-0	Air		Balance	03/18/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
7446-09-5	Sulfur Dioxide	CAL010533 , SRM 1661A	504.4 ppm	01/13/2009
7782-44-7	Oxygen	CC73601 , NTRM	20.89 %	05/29/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Nicolet Magna 550	ACJ9300713	FTIR	03/15/2004

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B15842B

Analytical report approved by Jim Healy



**Certificate of Analysis**  
EPA Protocol  
Performed according to EPA-600/R-97/121, Procedure G1

**Notice:** This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

Material:	6154 EPA CO/N2 10-99 PPM	Blend Tolerance:	5 % Relative
Production #:	100076205	Blend Type:	EPA Protocol
Lot #:	02499K3280ZD	Cyl. Pressure:	2000 psig
Cylinder #:	CC175394	Balance Gas:	Nitrogen
Expiration Date:	11/12/2006	CGA:	350
Shelf Life:	36 months	Analytical Accuracy:	1.00 % Relative
		Confidence:	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	59.8	59.5 +/- 0.6 ppm	11/12/2003
7727-37-9	Nitrogen		Balance	11/12/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC3839 , GMIS	25.08 ppm	06/04/2004
630-08-0	Carbon Monoxide	CC13630 , GMIS	99.53 ppm	09/12/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	09/26/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B1700SB

Analytical report approved by Jim Healy



**HiQ Analysis**  
**Certificate**

**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6154	<b>Blend Tolerance:</b>	5 % Relative
EPA CO/N2 10-99 PPM		<b>Blend Type:</b>	EPA Protocol
<b>Production #:</b>	100076206	<b>Cyl. Pressure:</b>	2000 psig
<b>Lot #:</b>	02499K3310UA	<b>Balance Gas:</b>	Nitrogen
<b>Cylinder #:</b>	CC167431	<b>CGA:</b>	350
<b>Expiration Date:</b>	11/12/2006	<b>Analytical Accuracy:</b>	1.00 % Relative
<b>Shelf Life:</b>	36 months	<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	30.3	30.1 +/- 0.3 ppm	11/12/2003
7727-37-9	Nitrogen		Balance	11/12/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC3859 , GMIS	25.08 ppm	06/04/2004
630-08-0	Carbon Monoxide	CC13630 , GMIS	99.53 ppm	09/12/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	09/26/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17004B

Analytical report approved by Jim Healy

*Jim R. Healy*





(800)  
532-7474

Linde Gas



### Certificate of Analysis EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

**Manufactured and certified at:**

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

**Produced for customer:**

LINDE COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b> EPA CO/N2 100-999 PPM	6198 A31	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100087549	<b>Blend Type:</b>	EPA Protocol
<b>Lot #:</b>	02499H4030ZH	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC72257	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	8/17/2007	<b>CGA:</b>	350
<b>Shelf Life:</b>	36 months	<b>Analytical Accuracy:</b>	1.00 % Relative
		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
630-08-0	Carbon Monoxide	133	134 +/- 1 ppm	08/17/2004
7727-37-9	Nitrogen		Balance	08/17/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
630-08-0	Carbon Monoxide	CC3813 , GMIS	501.8 ppm	09/05/2005
630-08-0	Carbon Monoxide	CC41779 , GMIS	99.58 ppm	09/12/2005

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba VIA-510	568384012	Non-Dispersive Infrared	07/16/2004

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

B17714B

Analytical report approved by Roy Yoder

*Roy Yoder*



**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

Manufactured and certified at:

AGA Gas, Inc.  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

Produced for customer:

AGA COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

816408B

<b>Material:</b>	6599 EPA NO/N2 50-499 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100062041	<b>Store/Use Temp:</b>	35 to 90 F
<b>Lot #:</b>	02499A3090EE	<b>Blend Type:</b>	EPA Protocol
<b>Cylinder #:</b>	CC150105	<b>Cyl. Pressure:</b>	2000 psig
<b>Expiration Date:</b>	1/23/2005	<b>Balance Gas:</b>	Nitrogen
<b>Shelf Life:</b>	24 months	<b>CGA:</b>	660
		<b>Analytical Accuracy:</b>	1.00 % Relative

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	75	74.5 +/- 0.7 ppm	01/23/2003
7727-37-9	Nitrogen		Balance	01/23/2003

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A 2	NOx	74.6 ppm	01/23/2003

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	ND11377 , LS	100.9 ppm	11/21/2007
10102-43-9	Nitric Oxide	CC120225 , GMIS	20.35 ppm	11/22/2004

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba CLA-510SS	568093024	Chemiluminescence	01/21/2003

This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.

Analytical report approved by Jim Healy

*Jim R. Healy*



**Certificate of Analysis**  
EPA Protocol

Performed according to EPA-600/R-97/121, Procedure G1

Notice: This Cylinder is not to be used when pressure is under 150 psig.

*Manufactured and certified at:*

Linde Gas LLC  
Maumee Specialty Gas Plant  
6421 Monclova Road  
MAUMEE OH 43537  
419-893-7226

*Produced for customer:*

LINDE COLUMBUS INTERBRANCH  
450 GREENLAWN AVE  
COLUMBUS OH 43223  
USA  
614-443-7487

<b>Material:</b>	6599 EPA NO/N2 50-499 PPM	<b>Blend Tolerance:</b>	5 % Relative
<b>Production #:</b>	100079435	<b>Blend Type:</b>	EPA Protocol
<b>Lot #:</b>	02499A4220JA	<b>Cyl. Pressure:</b>	2000 psig
<b>Cylinder #:</b>	CC15Q147	<b>Balance Gas:</b>	Nitrogen
<b>Expiration Date:</b>	2/4/2006	<b>CGA:</b>	660
<b>Shelf Life:</b>	24 months	<b>Analytical Accuracy:</b>	1.00 % Relative
		<b>Confidence:</b>	95 %

CAS #	Certified Component	Requested Concentration	Concentration and Uncertainty	Date of Certification
10102-43-9	Nitric Oxide	150	156 +/- 2 ppm	02/04/2004
7727-37-9	Nitrogen		Balance	02/04/2004

CAS #	Analyzed (For Ref Use Only)	Concentration	Analysis Date
N/A	NOx	156 ppm	02/04/2004

CAS #	Reference Standard	Cylinder/Standard #	Concentration	Expire Date
10102-43-9	Nitric Oxide	CC52960 , GMIS	495.1 ppm	12/22/2005
10102-43-9	Nitric Oxide	CC99263 , GMIS	101.5 ppm	01/14/2006

Instrument	Serial #	Analytical Principle	Calibration Date
Horiba CLA-510SS	568093024	Chemiluminescence	11/19/2003

*This product is manufactured using equipment which has been calibrated with NIST traceable, or equivalent, standards, weights, or equipment.*

B17202B

Analytical report approved by Jim Healy

*Jim R Healy*



**APPENDIX VII**

**CARL KOONTZ ASSOCIATES**  
**SMOKE SCHOOL TRAINING FORM**

NAME RONALD STAPERT RUN # 1 SUNGLASSES YES

COMPANY AIR ANALYSIS, INC COURSE LOCATION INDY, IN

DATE 9-23-04 SKY Clear WIND 5 DISTANCE & DIRECTION TO STACK \_\_\_\_\_

WHITE

ERROR

1	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1	
2	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	2	0	
3	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	3	1	
4	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	4	2	
5	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
6	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
7	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
8	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
9	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
10	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
11	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
12	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
13	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
14	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
15	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
16	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
17	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
18	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
19	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	19	1/2	
20	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	20	0	
21	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	21	0	
22	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	22	0	
23	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	23	0	
24	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	24	0	
25	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	25	0	

**CARL KOONTZ ASSOCIATES**  
of Nashville, Tennessee

This is to acknowledge that  
**RONALD STAPERT**

successfully participated in Visible Emissions training on SEP 23 2004

and is qualified to evaluate Visible Emissions for a period of six (6) months from the date of certification.

*Carl Koontz*  
Instructor

DEVIATION 16 **3.2**

BLACK

26	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	26	1
27	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	27	1
28	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	28	0
29	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	29	0
30	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	30	0
31	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	31	0
32	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	32	0
33	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	33	2
34	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	34	1
35	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	35	0
36	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	36	0
37	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	37	0
38	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	38	0
39	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	39	1
40	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	40	1
41	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	41	0
42	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	42	1
43	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	43	1
44	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	44	3
45	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	45	2
46	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	46	0
47	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	47	1
48	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	48	1
49	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	49	0
50	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	50	0

DEVIATION 17 **3.4**

I hereby certify that the above readings

are my own.

*Ronald Stapert*

**CARL KOONTZ ASSOCIATES**

of Nashville, Tennessee

This is to acknowledge that

DAN DAVIS

successfully participated in Visible Emissions  
training on SEP 23 2004

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

Carl Koontz  
Instructor

**CARL KOONTZ ASSOCIATES  
SMOKE SCHOOL TRAINING FORM**

NAME RONALD STAPERT RUN # 1 SUNGLASSES YES  
 COMPANY AIR ANALYSIS, INC COURSE LOCATION INDY, IN  
 DATE 9-23-04 SKY CLEAR WIND 5 DISTANCE & DIRECTION TO STACK \_\_\_\_\_

WHITE																	ERROR							
1	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1	
2	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	2	0	
3	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	3	1	
4	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	4	2	
5	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
6	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
7	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
8	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
9	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
10	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
11	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
12	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
13	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
14	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
15	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
16	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
17	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
18	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
19	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	19	1/2	
20	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	20	0	
21	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	21	0	
22	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	22	0	
23	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	23	0	
24	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	24	0	
25	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	25	0	

**CARL KOONTZ ASSOCIATES**  
 of Nashville, Tennessee  
 This is to acknowledge that  
RONALD STAPERT  
 successfully participated in Visible Emissions  
 training on SEP 23 2004  
 and is qualified to evaluate Visible Emissions  
 for a period of six (6) months from the date of  
 certification.  
*Carl Koontz*  
 Instructor

DEVIATION 16 3.2

BLACK																							
26	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	26	1
27	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	27	1
28	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	28	0
29	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	29	0
30	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	30	0
31	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	31	0
32	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	32	0
33	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	33	2
34	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	34	1
35	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	35	0
36	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	36	0
37	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	37	0
38	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	38	0
39	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	39	1
40	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	40	1
41	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	41	0
42	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	42	1
43	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	43	1
44	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	44	3
45	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	45	2
46	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	46	0
47	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	47	1
48	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	48	1
49	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	49	0
50	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	50	0

I hereby certify that the above readings  
 are my own. Ronald Stapert  
 DEVIATION 17 3.4

**CARL KOONTZ ASSOCIATES  
SMOKE SCHOOL TRAINING FORM**

NAME RONALD STAPERT RUN # 1 SUNGLASSES YES  
 COMPANY AIR ANALYSIS, INC COURSE LOCATION INDY, IN  
 DATE 9-23-04 SKY Clear WIND 5 DISTANCE & DIRECTION TO STACK \_\_\_\_\_

WHITE

ERROR

1	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1	
2	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	2	0	
3	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	3	1	
4	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	4	2	
5	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
6	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
7	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
8	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
9	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
10	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
11	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
12	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
13	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
14	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
15	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
16	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
17	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
18	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
19	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	19	1/2	
20	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	20	0	
21	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	21	0	
22	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	22	0	
23	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	23	0	
24	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	24	0	
25	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	25	0	

**CARL KOONTZ ASSOCIATES**  
of Nashville, Tennessee

This is to acknowledge that

**RONALD STAPERT**

successfully participated in Visible Emissions training on **SEP 23 2004**

and is qualified to evaluate Visible Emissions for a period of six (6) months from the date of certification.

*Carl Koontz*  
Instructor

DEVIATION 16 **(3.2)**

BLACK

26	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	26	1
27	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	27	1
28	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	28	0
29	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	29	0
30	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	30	0
31	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	31	0
32	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	32	0
33	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	33	2
34	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	34	1
35	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	35	0
36	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	36	0
37	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	37	0
38	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	38	0
39	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	39	1
40	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	40	1
41	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	41	0
42	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	42	1
43	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	43	1
44	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	44	3
45	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	45	2
46	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	46	0
47	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	47	1
48	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	48	1
49	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	49	0
50	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	50	0

I hereby certify that the above readings

are my own.

*Ronald Stapert*

DEVIATION 17 **(3.4)**

**CARL KOONTZ ASSOCIATES  
SMOKE SCHOOL TRAINING FORM**

NAME RONALD STAPERT RUN # 1 SUNGLASSES YES  
 COMPANY AIR ANALYSIS, INC COURSE LOCATION INDY, IN  
 DATE 9-23-04 SKY Clear WIND 5 DISTANCE & DIRECTION TO STACK \_\_\_\_\_

WHITE

ERROR

1	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	1	1	
2	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	2	0	
3	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	3	1	
4	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	4	2	
5	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
6	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
7	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
8	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
9	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
10	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
11	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
12	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
13	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
14	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
15	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
16	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
17	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
18	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70									
19	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	19	1	
20	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	20	1/2	
21	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	21	0	
22	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	22	0	
23	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	23	0	
24	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	24	0	
25	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	25	0	

**CARL KOONTZ ASSOCIATES**  
of Nashville, Tennessee

This is to acknowledge that  
**RONALD STAPERT**  
successfully participated in Visible Emissions  
training on **SEP 23 2004**

and is qualified to evaluate Visible Emissions  
for a period of six (6) months from the date of  
certification.

*Carl Koontz*  
Instructor

DEVIATION 16 **(3.2)**

BLACK

26	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	26	1
27	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	27	1
28	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	28	0
29	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	29	0
30	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	30	0
31	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	31	0
32	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	32	0
33	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	33	2
34	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	34	1
35	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	35	0
36	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	36	0
37	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	37	0
38	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	38	0
39	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	39	1
40	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	40	1
41	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	41	0
42	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	42	1
43	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	43	1
44	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	44	3
45	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	45	2
46	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	46	0
47	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	47	1
48	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	48	1
49	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	49	0
50	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70	75	80	85	90	95	100	50	0

I hereby certify that the above readings

are my own.

*Ronald Stapert*

DEVIATION 17 **(3.4)**

**APPENDIX VIII**


DATE SKC  
TCC  
PAC  
SIC

Compliance Test Protocol  
 Indiana Department of Environmental Management  
 Office of Air Quality/Compliance Data Section  
 100 North Senate Avenue, Post Office Box 6015  
 Indianapolis, IN 46208-6015  
 Phone: 317/232-8338 Fax: 317/233-8865


Date Prepared: 11-12-04 Proposed Test Date: 12/20/04/04 Plant Address: 4537 S. Avior Rd  
 1. SOURCE INFO: ID/Permit No. 102-2203 107-1243-003A  
 Company: Nucor Steel  
 Mail Address: 4537 South Avior Rd  
 City, State, Zip: Crawfordsville IN 47933  
 Contact: Dave Sillc Phone: 765-941-2679  
 2. TEST COMPANY INFORMATION  
 Name: To be determined  
 Address:  
 City, State, Zip:  
 Contact:  
 Phone:  
 3. PROCESS INFORMATION (Submit Separate Form for Each Unit)  
 Unit to Test: Custop LMS Baghouse Stack  
 Max. Rated Capacity: 135 tons/hr  
 Proposed Operating Speed: As close to max as possible  
 3a. Describe Method Used to Determine Operating Level:  
 Production heat sheets  
 Pollution Control Equipment: Fabric Filter Baghouse  
 3b. Process Description:  
 Molten steel from EAF's refined  
 prior to coating  
 Fuel Type: N/A  
 4. TEST INFORMATION

Method	No. Runs	Time
Method 1-4	3	1 hr
Method 5	3	1 hr
Method 6	3	1 hr
Method 7	3	1 hr
Method 9	3	1 hr
Method 201	201A	
Method 202		
Other:	Method 10, Method 12	1 hr
4a.	Describe Any Deviations from Standard Test Method	

5. AGENCY USE ONLY:  
 Title V:  FESOP  SSOA  Other   
 Inspector: RJS  
 Reviewer: SCF  
 Date Received: 11-16-04  
 Approval Date: 12/13/04  
 Comments: 0  
 State of Indiana  
 Department of Environmental Management  
 Office of Air Quality  
 6. SAMPLE SITE LOCATION  
 No. of Method 5 Sample Points: 24  
 Diameter at Sample Site: 96 inches  
 Stack Height: 100 ft  
 Approximate Stack Gas Flow (ACFM): 120,000  
 Approximate Stack Gas Temp (deg. F): 105  
 Approximate Stack Gas Moisture (%): 1.5%  
 Does sample port location meet 40 CFR 60, Appx. A. Method 1, Sec. 1.2 Requirements: Yes  No   
 If No, explain:  
 7. REASON FOR TEST  
 Operating Permit: Yes  No   
 Construction Permit: Yes  No   
 If yes, Unit Start Up Date:  
 State Agreed Order No.:  
 Title V: Yes  No   
 Compliance with 326 IAC NSPS 40 CFR 60 Subpart: Yes  No   
 Other (EPA, CD, State, 114):  
 326 IAC 3-6.2(a) requires that completed form to be submitted 35 days prior to the proposed test date to the above address. 326 IAC 2-1-7(b)(3) requires any applicable test fee to be submitted with the protocol. **SEE NOT APPLICABLE IF PROGRAM IS FESOP TITLE V OR VE TESTING ONLY**



**APPENDIX IX**



**Nucor Steel - Crawfordsville, IN**  
**Castrip LMS & Caster Stack Test Production Data**  
**December 21, 2004**

**Run 1: 12:00 Noon - 1:00 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run
Castrip LMS	242006	11:53 AM	12:54 PM	114.0	61.0	54.0	100.9
Castrip Caster	242004	11:56 AM	1:01 PM	108.0	65.0	60.0	99.7

**TOTAL TONS: 222.0 200.6**

**Run 2: 1:50 pm - 2:50 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run
Castrip LMS	146351	1:44 PM	3:10 PM	126.0	86.0	60.0	87.9
Castrip Caster	242006	1:03 PM	2:24 PM	114.0	81.0	34.0	47.9

**TOTAL TONS: 240.0 135.8**

**Run 3: 9:28 pm - 10:34 pm**

	Heat Number	Start	End	Net Ladle Tons	Total Minutes	Run Minutes	Tons During Run
Castrip LMS	242017	9:24 PM	10:35 PM	105.0	71.0	66.0	97.6
Castrip Caster	146355	9:37 PM	9:53 PM	109.0	76.0	57.0	81.8

**TOTAL TONS: 214.0 179.4**

# Δ AIR ANALYSIS, INC

3904 CLARKS CREEK ROAD • PLAINFIELD, INDIANA 46168

TX: 317-837-8514

FAX: 317-837-8518

## FACSIMILE TRANSMITTAL SHEET

TO:	FROM:
Mark Washer	M. Dicen
COMPANY:	DATE:
Nucor Steel	12/13/04
FAX NUMBER:	TOTAL NO. OF PAGES INCLUDING COVER:
765-364-5311 361-5720	1
PHONE NUMBER:	SENDER'S REFERENCE NUMBER:
765-364-1323	
REGARDING	YOUR REFERENCE NUMBER:
Information	

URGENT    FOR REVIEW    PLEASE COMMENT    PLEASE REPLY    PLEASE RECYCLE

NOTES/COMMENTS:

Mark:

Here's the information you requested:

Castrip Baghouse recorded every 15 minutes

	Fan Amps	Delta P
Run 1	86, 86, 72, 86	8.0, 7.0, 4.1, 6.7
Run 2	85.4, 73.2, 82.2, 71.1	7.7, 4.8, 7.2, 4.2
Run 3	79, 88, 73, 87	4.2, 6.6, 4.2, 7.7

Mike

This facsimile is intended for the organization/person(s) listed above. If you have received this transmittal in error, please notify sender immediately.

KUN 1 - LMF

# NUCOR STEEL - CRAWFORDSVILLE

## LMF HEAT RECORD

HEAT NO: <u>242000</u>	AIM GRADE: <u>100551</u>	DATE: <u>12/21 04</u>	POWER
FCE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>SG</u>	KWH INITIAL: _____
LADLE NO: <u>14</u>	FINISH GRADE: _____	1st OP: <u>DL</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>114</u>		2nd OP: _____	KWH USED: _____

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1		035	54	013	047	32								0527	0055	
LMF -2		044	61	013	002	33								0184	0032	
LMF -3																
LMF -4																

SLAG

DEPTH

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

COLOR

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

TEXTURE

ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>12:06</u>	<u>10:11</u>	<u>3</u>
	<u>10:12</u>	<u>10:17</u>	<u>1</u>
	<u>10:21</u>	<u>10:31</u>	<u>1</u>
	<u>10:40</u>	<u>10:51</u>	<u>VTD</u>
	<u>11:53</u>	<u>12:03</u>	_____
	<u>12:11</u>	<u>12:18</u>	_____
	<u>12:30</u>	<u>12:31</u>	_____
	_____	_____	_____
	_____	_____	_____
	_____	_____	_____

DLE ADDITION	TIME	AMOUNT
LCMNSI		1600/250
FESI		300
AI SHOT		1
STD FeMn		
MED C FeMn		
AI WIRE (FT)		
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		160
LIME		400/2000
SPAR		200

ARGON LANCE ON

10:18	2893	°F	2.4	PPM
10:38	2945	°F		PPM
12:04	2927	°F		PPM
12:41	3069	°F	87.1	PPM
_____	_____	°F		PPM
_____	_____	°F		PPM
_____	_____	°F		PPM
_____	_____	°F		PPM

TIME 12:54 DEPARTURE TEMPERATURE 3060

Seq 1926-2

REMARKS: approx 2200 oxy

VTD

DRAWN



Run 3 - LMF

# NUCOR STEEL - CRAWFORDSVILLE

## LMF HEAT RECORD

HEAT NO: <u>242017</u>	AIM GRADE: <u>100551</u>	DATE: <u>12/21/04</u>	POWER
FCE (E OR W): _____	LIQUIDUS: _____	MELTER: <u>SG</u>	KWH INITIAL: _____
LADLE NO: <u>17</u>	FINISH GRADE: _____	1st OP: <u>JK</u>	KWH FINAL: _____
WEIGHT TAPPED: <u>105</u>		2nd OP: _____	KWH USED: _____

SAMPLE	TIME	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	V	Ca	Al	N	TOTAL RESID
LMF -1		<u>026</u>	<u>48</u>	<u>015</u>	<u>021</u>	<u>31</u>										<u>0272056</u>
LMF -2		<u>049</u>	<u>65</u>	<u>016</u>	<u>009</u>	<u>36</u>								<u>016</u>	<u>0050</u>	
LMF -3																
LMF -4																

SLAG  
DEPTH  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
COLOR  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_  
TEXTURE  
ARRIVE: \_\_\_\_\_ DEPART: \_\_\_\_\_

EVENT	TIME START	TIME END	TAP NO.
FINISH TAP	_____	_____	_____
LADLE ON CAR	_____	_____	_____
IND STIR ON	_____	_____	_____
UNDER ROOF	_____	_____	_____
POWER ON	<u>7:03</u>	<u>7:08</u>	<u>3</u>
	<u>7:09</u>	<u>7:14</u>	<u>1</u>
	<u>7:23</u>	<u>7:28</u>	_____
	<u>7:33</u>	<u>7:43</u>	<u>VTD</u>
	<u>9:24</u>	_____	_____
	<u>9:43</u>	<u>9:51</u>	_____
	<u>10:17</u>	<u>10:19</u>	_____
	<u>10:25</u>	<u>10:27</u>	_____

DLE ADDITION	TIME	AMOUNT
<u>LLMNSI</u>		<u>1600 / 500</u>
<u>FES 1</u>		<u>300</u>
AI SHOT		<u>1</u>
STD FeMn		
MED C FeMn		
AI WIRE (FT)		<u>100</u>
Ca Si WIRE (FT)		
Fe Ca WIRE (FT)		
C WIRE		<u>300</u>
<u>Lime</u>		<u>400</u>
<u>SPAR</u>		<u>200</u>

ARGON LANCE ON

TIME	TEMP/OXYGEN	PPM
<u>7:15</u>	<u>2923</u> °F	<u>4.4</u> PPM
<u>9:42</u>	<u>2914</u> °F	PPM
<u>10:20</u>	<u>3032</u> °F	<u>74.4</u> PPM <u>23</u>
	°F	PPM
	°F	PPM
	°F	PPM

DEPARTURE TEMPERATURE 3025

1927-2 REMARKS

VTD

Run 1 - Caster

# NUCOR STEEL - CRAWFORDSVILLE CASTRIP HEAT RECORD

SEQ #: 1926  
HEAT #: 242004  
GRADE: 100551

# IN SEQUENCE: 1  
LIQUIDUS

SUPERVISOR: SG  
PULPIT OPER: JG  
DATE: 12-21-04

BRUSHES  
PRECAST EOS 16  
POSTCAST EOS  
EDS 16  
DOS 16  
DDS 16

C	Mn	S	Si	AL	N	Temp

LOT 11:43  
TOG 11:53

LADLE #: 17  
TARE WEIGHT: (106 LMF) 108  
INITIAL WEIGHT: 11:56  
FINAL WEIGHT: 11:01  
OPEN TIME: 66s  
CLOSE TIME: 66s  
FREE OPEN: No  
# OF PIPES USED:

TUNDISH #: Z-F  
TUNDISH CAR #: Z  
TUNDISH CLOSE TIME:   
SKULL WEIGHT:   
CASSETTE #: 2  
CASSETTE ROLL #: 25  
C/N PLATE #: 1

S/D WEAR  
HMI 4.9  
ACTUAL  
D/S  
O/S 5.7

TIME	POOL	SPEED	FLUX ENT	DEL	TEMP	OXY	MV	ROLL FORCE		S/D FORCE		HYDRO	TP		BRUSH SPEED	
								D/S	O/S	D/S	O/S		ACTUAL	DEL	ENT	
11	175	69	4.04	4.16	2944	52.4	24	600	600	300	300				1150	1150
27	175	83	4.07	4.17	2931	47.2	20	475	550	95	80				1150	1150
41	175	83	4.08	4.19				450	525	85	60				1150	1150
50	175	83	4.07	4.10	2931	44.4	16	450	525	80	56				1150	1150

Cast Comments: Run 1 - CASTER  
Top Hat Size: 10.6 / 9  
Holes plugged: 0

Reason for Termination of Cast: Drawn  
Total cast: 62.5 Cast tons:  
Coiled tons: 100.36

Run 2 - CASTER

# NUCOR STEEL - CRAWFORDSVILLE CASTRIP HEAT RECORD

BRUSHES  
 PRECAST EOS 16 POSTCAST EOS \_\_\_\_\_  
 EDS 16 EDS \_\_\_\_\_  
 DOS 16 DOS \_\_\_\_\_  
 DDS 16 DDS \_\_\_\_\_

SUPERVISOR: SG  
 PULPIT OPER: JG  
 DATE: 12-21-04

# IN SEQUENCE 2  
 LIQUIDUS

SEQ #: 1926  
 HEAT #: 242006  
 GRADE: 100551

C	Mn	S	Si	AL	N	Temp

LOT 12:56  
 TOG \_\_\_\_\_

CASSETTE #: 2  
 CASSETTE ROLL #: 75  
 C/N PLATE #: 1

TUNDISH #: 2-F  
 TUNDISH CAR #: 2  
 TUNDISH CLOSE TIME: 14:24

LADLE #: 14  
 TARE WEIGHT: \_\_\_\_\_  
 INITIAL WEIGHT: (14 LME) 113  
 FINAL WEIGHT: \_\_\_\_\_  
 OPEN TIME: 13:03  
 CLOSE TIME: 14:14  
 FREE OPEN: 13:03  
 # OF PIPES USED: \_\_\_\_\_

S/D WEAR  
 HMI 8.39 ACTUAL  
 O/S 9.95

TIME	POOL	SPEED	ENT	DEL	TEMP	OXY	MV	ROLL FORCE			SID FORCE			HYDRO	TP		BRUSH SPEED	
								D/S	O/S	D/S	O/S	D/S	O/S		CAL	ACTUAL	DEL	ENT
72	175	82	4.09	4.22	2945	47.2	16	450	525	70	55						1150	1150
87	175	79	3.96	4.09				450	525	70	55						1150	1150
110	175	79	3.90	4.02				450	525	70	56						1150	1150
120	175	80	3.90	4.03	2976	51.1	13	450	515	70	56						1150	1150
130					2970													

Cast Comments: Argon at 14% at 71 min off at 86 min (No charge)  
Dropped Pool to 170 at 86 min (No profile change)  
Upped MCW Temp from 60 to 75 (No profile change)  
 Reason for Termination of Cast: Dr.  
 Top Hat Size: 10.6/9  
 Holes plugged: 0

Total cast: 142.9 Cast tons: 243.38  
 Coiled tons: 223.94





**ΔAir Analysis, Inc.**

Report on:  
**Particulates/ PM10, Lead, Sulfur Dioxide, Nitric Oxides,  
Carbon Monoxide and Visible Emissions  
Indiana Air Permit Compliance Testing**

Performed for  
**Nucor Steel Corporation  
Castrip Operations**

**January 3, 2003**

Air Analysis Inc. Project Number: 129

## **TABLE OF CONTENTS**

1. Executive Summary (Page 3)  
Test Summary, Table 1
2. Results (Page 4)  
Table 2
3. Description of Source Processes and Field Notes (Page 5)
4. Methodology (Pages 6 & 7)

Summary of Sampling Procedures  
Description of Sampling Methods

## **APPENDIX**

SAMPLE CALCULATIONS	I
FIELD DATA PRINTOUTS	II
FIELD DATA	III
LABORATORY DATA	IV
CHAIN OF CUSTODY	V
CALIBRATION DATA	VI
VISIBLE EMISSIONS DATA	VII
SUBMITTED PROTOCOL	VIII
PRODUCTION DATA	IX

**Executive Summary**

Air Analysis, Inc. was contracted by Nucor Steel Corporation to perform air emissions sampling of their Castrip Baghouse Stack in Crawfordsville, Indiana, on January 3, 2003. The objective of the test program was to determine compliance to Indiana air permit requirements for particulate matter /(PM/10), lead, sulfur dioxide, nitric oxides, carbon monoxide and visible emissions. The following personnel were involved with the testing program:

Air Analysis	Mike Dicen
Air Analysis	Chris Sgroi
Air Analysis	Doug Van Demark
Air Analysis	Ron Raynor
Nucor Steel	Dave Sulc
IDEM	Dave Cline

Three sets of one-hour test runs were performed for SO<sub>2</sub>, NO<sub>X</sub>, CO and Visible Emissions. Three runs were attempted for PM/PM<sub>10</sub> and lead however only two runs were completed due to equipment failure. Run 2 of PM/PM<sub>10</sub> was voided due to failed pitot leak check. In addition, a filter hot box short circuited thus sampling was limited to one complete Method 5 train. Since two lead runs were completed and performed within requirements, it was determined to complete one other run of PM/PM<sub>10</sub>.

Per Mr. Dave Cline of IDEM, testing was to be performed while one ladle is cast at the Caster and another being processed at the LMS. Therefore, total tons on both the Caster and LMS were added since both add to emissions to the baghouse. Please review Section 3 for further details.

**Table 1.**

**Test Summary**

Pollutant	Date	Runs	Concentration	Mass Emissions Rate
PM	1/03/03	1, 3	0.0003 gr/dscf	0.28 lbs/hr
PM/PM <sub>10</sub>	1/03/03	1,3	0.0055 gr/dscf	5.0 lbs/hr
Lead	1/03/03	1, 2	0.0000 gr/dscf	0.0142 lbs/hr****
NO <sub>X</sub>	1/03/03	1-3	2.2 ppm	1.69 lbs/hr
SO <sub>2</sub>	1/03/03	1-3	6.59 ppm	7.06 lbs/hr
CO	1/03/03	1-3	20.37 ppm	9.55 lbs/hr
Visible Emissions	1/03/03	1-3	0 %	NA

\*\*\*\* Lead is non detect. Entered was the minimum laboratory detection limit.

**Results**

**Table 2**

<b>STACK EMISSION SUMMARY</b>				
<b>Gaseous Emissions</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
NOx lbs/hr	1.6461	1.9805	1.4466	1.6911
SO2 lbs/hr	5.1299	4.6848	11.3606	7.0585
CO lbs/hr	8.5394	11.4482	8.6640	9.5506
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	111,880.86	109,793.71	111,165.98	110,946.85
DSCFM	109,422.08	106,741.68	106,840.87	107,668.21
Avg. Stack Temp.	74.333	81.652	84.375	80.120
Stack Gas Velocity	37.097	36.405	36.860	36.787
Avg. Velocity Head	0.4290	0.4083	0.4159	0.4177
Avg. Sq. Rt of Delta P	0.6549	0.6390	0.6449	0.6463
<b>Lead Emissions</b>				
Filterable (gr/dscf)	0.0000	0.0000	No run	0.0000
Lead(lbs/hr)	0.0143	0.0141	Equipment Failure	0.0142
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	111,873.76	109,812.39		110,843.07
DSCFM	109,412.05	106,722.42		108,067.24
Avg. Stack Temp.	74.333	81.652		77.993
Stack Gas Velocity	37.094	36.411		36.753
Avg. Velocity Head	0.4290	0.4083		0.4186
Avg. Sq. Rt of Delta P	0.6549	0.6390		0.6469
<b>*** PM/PM10 Emissions</b>				
Filterable (gr/dscf)	0.0005	Void Run	0.0001	0.0003
Filterable + Condensable (gr/dscf)	0.0037	Failed pitot	0.0073	0.0055
Filterable (lbs/hr)	0.4876	Leak check	0.0776	0.2826
Condensable (lbs/hr)	2.8282		6.6191	4.7236
Total (lbs/hr)	3.3158		6.6967	5.0062
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	107,409.59	106,443.44	111,150.86	108,334.63
DSCFM	105,249.18	103,650.22	106,844.26	105,247.89
Avg. Stack Temp.	75.417	82.783	84.375	80.858
Stack Gas Velocity	35.614	35.294	36.855	35.921
Avg. Velocity Head	0.3951	0.3839	0.4159	0.3983
Avg. Sq. Rt of Delta P	0.6286	0.6196	0.6449	0.6310

Entered minimum detection limit of 0.055 mg

**\*\*\* Note – Air purge of the Method 202 train was not performed**

**Description of Source Processes and Field Notes**

Nucor Steel Corporation operates a steel mill facility in Crawfordsville, Indiana. The facility required to determine compliance to permit conditions is the recently built Castrip. At this facility, molten metal is cast into thin metal sheets.

Two sources have an effect on air emissions according to the Indiana Department of Environmental Management; process emissions from LMS and Caster. Production levels were kept for both metal sheets produced and the ladle on standby.

Production rates follows as described above. The permitted capacity is 135 tons /hr of finished product which was not exceeded during the test.

123.3 tons	
114.5 tons-----	237.8 tons TEST 1
125.2 tons-----	239.7 tons TEST 2
112.8 tons-----	238.0 tons TEST 3

Emissions pass through a baghouse prior to exiting a stack.

Actual recorded production material information is in Appendix.

**Methodology**

The sampling procedures used by Air Analysis, Inc. are as follows:

Title 40 CFR Part 60 Appendix A

Method 1 “Sampling of Velocity Traverses for Stationary Sources”

Method 2 “Determining of Stack Gas Velocity and Volumetric Flow Rate”

Method 3 “Gas Analysis for the Determination of Molecular Weight”

Method 4 “Determination of Moisture Content in Stack Gas”

Method 5 “Determination of Particulate Emissions”

Method 9 “Visual Determination of the Opacity of Emissions”

Method 202 “Determination of Condensable Emissions from Stationary Sources”

Method 6C “Determination of Sulfur Dioxide Emissions”

Method 7E “Determination of Nitric Oxide Emissions”

Method 10 “Determination of Carbon Monoxide Emissions”

**SAMPLE POINT DETERMINATION-EPA METHOD 1**

Sampling point locations were determined according to EPA Reference Method 1.

Locations	Dimensions	Sampling Points		Total Points
		Ports	Points Per Port	
Castrip Stack	96” Diameter	4	6	24

\*\* Exact measure points and distances to disturbances are listed in Appendix- Field Data

**VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measures with a Type S pitot tube. Gas temperature measurements made with a Type K thermocouple and digital pyrometer.

**GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

**MOISTURE CONTENT – EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-2 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

**PARTICULATE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe and filter. The probe temperature and filter are maintained at temperatures of 248 degrees F (+/- 25 deg. F). The impinger temperature exit gas is maintained at temperatures at or below 68 degrees F.

The nozzle, probe and glass filter containers are rinsed with acetone and the rinse is captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with de-ionized water and captured in a sealed container. Two rinses of methylene chloride are captured and stored in a sealed glass container.

**OPACITY – METHOD 9**

Stack opacity readings are taken for 60 minutes at 15 second intervals *for NSPS* and 30 minutes at 15 second intervals *for state permitted, non-federal sources*, by a certified visible emissions reader. The visible emissions readings are conducted during each of the particulate test runs. The results are reported as an average opacity reading for the half an hour period. A copy of the visible reader's current certification is included in the Appendix.

**SO2 DETERMINATION – EPA METHOD 6C**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by infrared detection. Sulfur Dioxide molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of SO2. Quality assurance of the analyzer is determined by first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias.

**NOX DETERMINATION – EPA METHOD 7E**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by chemiluminescent detection. NOX molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of NOX. Quality assurance of the analyzer is first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias.

**CO DETERMINATION – EPA METHOD 10**

Stack gas is withdrawn from the stack and conditioned (moisture is removed ) before being analyzed by infrared detection. CO molecules are “ excited “ by specific wavelengths. Molecular excitement is directly proportional to the concentration of CO. Quality assurance of the analyzer is first determined by direct injection of known EPA protocol 1 gas concentrations. A system check of the probe, connection lines and conditioner is also determined prior to and after each sample period to determine drift bias

**Meltshop Baghouse #1 Testing for Emissions:**

**Test Date: 02/22 and 02/24/1995**

**Production Rate: Approximately 242.0 ton/hr, EAF's only**

**The process and air pollution control equipment were operating normally at the time of testing.**

# RAMCON

ENVIRONMENTAL CORPORATION

March 31, 1995

Mr. Dave Sulc  
Nucor Steel  
RR 2, Box 311  
Crawfordsville, Indiana 47933

RE: Source Sampling — Acid Regeneration Unit, Pickle Line and EAF Baghouse

Dear Mr. Sulc:

Enclosed you will find four (4) copies of our report on the particulate, hydrogen chloride and carbon monoxide emissions testing conducted at your facility located in Crawfordsville, Indiana.

You will want to sign the report covers and send two copies to:

Mr. Ed Surla  
Indiana Air Pollution Control  
Department of Environmental Management  
105 South Meridian Street  
P. O. Box 6015  
Indianapolis, Indiana 46206

You will need to keep one copy of the report at the plant.

We certainly have enjoyed working with you. Please let us know if we can be of further assistance.

Sincerely,



William Joseph Sewell, II  
Vice President

WJSii:wpc  
Enclosures

## TABLE OF CONTENTS

	<u>Page</u>
I. INTRODUCTION .....	1
II. TEST RESULTS .....	3
Table A — Acid Regeneration Unit, Particulate and HCl Test Summary .....	4
Table B — Pickle Line, Particulate and HCl Test Summary .....	4
Table C — EAF Baghouse, Particulate Matter Test Summary .....	5
Table D — EAF Baghouse, CO Test Summary .....	5
III. TEST PROCEDURES .....	6
A. Determination of Hydrogen Chloride Emissions From Stationary Sources - US EPA Method 26 .....	6
B. Determination of Particulate Matter Emissions from Positive Pressure Fabric Filters — US EPA Reference Methods 5D .....	8
C. Determination of Carbon Dioxide and Oxygen Emissions From Stationary Sources (Instrumental Analyzer Procedure) - US EPA Method 3A .....	11
D. Determination of Carbon Monoxide Emissions From Stationary Sources (Instrumental Analyzer Procedure) — US EPA Method 10 .....	15
IV. SOURCE DESCRIPTION .....	17
A. Acid Regeneration Unit-HCL .....	17
B. Pickle Line .....	18
V. RAMCON PERSONNEL .....	19

APPENDIX A — Equipment Used

APPENDIX B — Laboratory Analysis and Results

APPENDIX C — Calculations

APPENDIX D — Field Data

1. Acid Regeneration Unit, Particulate and HCl
2. Pickle Line, Particulate and HCl
3. EAF Baghouse, Particulate
4. EAF Baghouse, Inlet Flows
5. Analysis Data - CO, CO<sub>2</sub>, O<sub>2</sub>
6. Visible Emissions

APPENDIX E — Calibration Data

1. CO, CO<sub>2</sub>, O<sub>2</sub> Instrumental Field Analysis
2. Certificates of Analysis

## I. INTRODUCTION

On February 21 through 24, 1995 personnel from RAMCON Environmental Corporation conducted air emissions testing at Nucor Steel located in Crawfordsville, Indiana. The scope of work involved testing the acid regeneration unit and pickle line exhaust for filterable particulate matter and hydrogen chloride. The EAF baghouse was subject to sampling for particulate matter, carbon monoxide, carbon dioxide and oxygen.

The carbon monoxide, oxygen and carbon dioxide were collected and analyzed by test methods that utilize "real-time" continuous emission monitor (CEM) instrumentation. This technology provides data with a high degree of reliability on-site. Reference Methods 3A and 10 were employed for the analysis of oxygen and carbon dioxide, and carbon monoxide, respectively.

These instrumental analyzer testing procedures set forth a sampling strategy to continuously extract sample gas from the source. This sample stream is routed to individual CEMs for analysis of the various targeted pollutants and diluent gases. The test results are based on the average value of one-minute averages generated by the CEM instrument data acquisition during the test periods. Three (3) sampling periods were performed in which the gaseous concentrations were continuously monitored for the listed target compounds.

The particulate matter emissions from the EAF baghouse were sampled according to Reference Method 5D. This procedure sets forth a strategy whereby the velocities at the sampling location are calculated from volumetric flow values determined at the inlet duct to the baghouse process.

The particulate matter and hydrogen chloride emissions from the acid regeneration unit and pickle line exhaust were sampled according to US EPA Reference Method 26A requirements. The stack gas moisture, velocity, and volumetric flow rates were also determined during this isokinetic sampling procedure. This data enabled conversion of flue gas pollutant concentrations to emission data values in pounds per hour (lb/hr).

The purpose of the testing project was to determine if the targeted pollutant emissions are equal to or below the allowable limitation set forth by the State of Indiana EPA in the facility's operating permit. Dave Kline and Steve Friend representing the State of Indiana was present during the testing procedure(s) conducted by RAMCON Environmental Corporation. The test results and supporting calculations are provided in the following sections.

## II. TEST RESULTS

The test results are summarized in Tables A through D.

Table A summarizes the test results for the particulate matter and hydrogen chloride emissions from the acid regeneration unit. The first test run performed on the acid regeneration unit yielded particulate results which were significantly higher than subsequent tests. The majority of the excess particulate matter was obtained from the acetone wash of the sample probe. High levels of particulate matter collected in this portion of the sample train could possibly be collected due to scrapping of the probe against the stack or port wall during the test. Two test runs following the initial run were rejected due to failure of post test leak checks. Therefore test runs 4 and 5 were performed to provide three valid sampling runs. The last two particulate results provide consistent values and should be considered as demonstration of the levels of particulate matter emitted during process operation. Run 1 results are likely biased high due to sampling error.

Table B summarizes the test results for the particulate matter and hydrogen chloride emissions from the pickle line exhaust. Table C tabulates the particulate matter emissions obtained from the EAF baghouse process. These summary tables provide the test results in concentration values of grains per dry standard cubic feet (gr/dscf). The emission values of the targeted pollutants are listed in pounds per hour (lb/hr).

The isokinetics determined for the first test run of the Reference Method 5D was 132% which exceeds the tolerance established by EPA for acceptable test quality assurance. This initial test was followed by two additional runs which were performed near 100% and represent valid emissions results. Because the facility easily passes the allowable emission limitation for particulate matter and the spread of test results are consistent across the three test runs, it is requested that the emissions test be considered demonstration of compliance.

**Table C — EAF Baghouse  
Particulate Matter Test Summary  
February 22 and 24, 1995**

Run	Time	gr/dscf	lb/hr	Isokinetics
1	13:12 - 17:31	0.0020	14.47	132.60
2	19:29 - 23:08	0.0016	10.93	98.73
3	11:03 - 15:31	0.0015	12.18	100.90
Average:		0.0017	12.53	

**Table D — EAF Baghouse  
CO Test Summary  
February 22, 1995**

Run	Time	O <sub>2</sub> , %	CO <sub>2</sub> , %	CO, ppm	CO, lb/hr
1	13:01 - 14:01	19.95	1.41	78.72	289.3
2	15:13 - 16:13	20.03	1.30	57.35	198.9
3	16:48 - 17:48	19.99	1.45	29.71	122.5
Average:		19.99	1.39	55.26	203.6

AVG T/HR 241.97

CO lb/hr = 0.84

### III. TEST PROCEDURES

The following is a description of each of the test method(s) that were conducted during the project. In this description, a discussion of the pertinent segments including preparation, sampling, and analysis is addressed. This section will provide information supporting the validity of the samples.

A. Determination of Hydrogen Chloride Emissions From Stationary Sources - US EPA Method 26.

This test procedure was coupled with the particulate determination for test location described above. This enables two test components involved in the scope of work to be collected simultaneously by one sample train. This practice is employed only when neither of the test components results will be altered or biased.

1. Preparation:

All glassware utilized in each sampling train was thoroughly cleaned and dried prior to each test series.

The impinger system was assembled using 100 ml of 0.1 N sulfuric acid in the first two impingers. The third and fourth impingers contained 100 ml each of 0.1 N sodium hydroxide. The fourth impinger contained a pre-weighed amount of silica gel. In assembling the sample train, a small amount of silicon grease was placed on the ball joints to ensure adequate sealing.

A glass probe liner and nozzle system was utilized for the hydrogen chloride collection train. The probe housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack velocity and temperature respectively.

## 2. Sampling:

The probe and sample box were heated to an approximate temperature of 250°F. These temperatures were monitored throughout the testing to prevent moisture condensation and associated HCl losses.

An ice bath was prepared to submerge the impinger system into. The temperature of the last impinger was monitored throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

A leak check was performed prior to each test run. The entire sample train system was subjected to a vacuum that did not exceed 0.02 cfm leakage rate. The vacuum that was established during the pre-test leak check was not exceeded during the test period.

Three sample runs were conducted to constitute a complete test. The sampling time was a minimum of one hour. The stack gas was extracted via the sampling system proportionally at a rate of approximately 1.0 liter per minute.

When a test run had been completed, a post-test leak check was conducted prior to any dismantling of the sampling train. Once this has been successfully achieved, the sample train was dismantled for sample recovery.

The contents of the impingers were volumetrically measured and transferred to a labeled sample container.

## 3. Hydrogen Chloride Analysis:

The absorbent solutions of 0.1 N sulfuric acid utilized in the collection of the hydrogen chloride were analyzed by ion chromatography. The sulfuric acid solution is used to capture the hydrogen chloride and the sodium hydroxide solution collects the chlorine.

A sample field blank of the absorption solution was collected, contained, labeled and analyzed in conjunction with the samples.

4. Particulate Matter Analysis:

The glass fiber filter was desiccated for 24 hours prior to any weighing. The acetone probe wash was transferred to a tared beaker and evaporated to dryness. The resultant residue was also desiccated prior to gravimetric analysis.

The first weighing was performed after this initial period of drying. The weights were recorded to 0.0001 g. After a minimum of six additional hours of desiccating, a second weighing was conducted. The weights must agree within 0.0005 g or further desiccation must be conducted until the weights stabilize.

Sample field blanks of acetone were collected, contained, labeled and analyzed in conjunction with the samples. The blank weight was deducted from the acetone probe wash residue weight determinations.

B. Determination of Particulate Matter Emissions from Positive Pressure Fabric Filters — US EPA Reference Methods 5D.

This method applies to the determination of particulate matter emissions from positive pressure fabric filters. Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter.

1. Preparation:

All glassware utilized in each sampling train was thoroughly cleaned and dried prior to each test series. A glass fiber filter was used that has been labeled, desiccated for a minimum of 24 hours and pre-weighed.

The impinger system was assembled using the modified Greenburg-Smith type. One hundred ml of deionized water was placed in the first two impingers. The third impinger was initially empty and the fourth impinger contained a pre-weighed amount of silica gel for complete moisture removal. This impinger train configuration is according to Reference Method 5 for particulate. In assembling the sample train, a small amount of silicon grease was placed on the ball joints to ensure adequate sealing.

A stainless steel probe liner and nozzle system is typically utilized for the particulate determinations at the sampling location. The probe system housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack velocity and temperature.

2. Sampling:

The probe and sample box was heated to an approximate temperature of 250°F. These temperatures were monitored throughout the testing. An ice bath was prepared to submerge the impinger system into. The temperature of the last impinger was also monitored throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

A leak check was performed prior to each test run. The entire sample train system was subjected to a vacuum that did not exceed 0.02 cfm leakage rate. The vacuum that is established during the pre-test leak check was not exceeded during the test period.

The variation of Reference Method 5 versus 5D is comprised of taking the velocity readings at an inlet location for the 5D versus at each sampling traverse point via Method 5.

Therefore velocity traverses were taken at the inlet duct(s) to the baghouse process. This data is utilized for the purpose of determining the volumetric flow rate of air through the baghouse. This value is utilized to determine the average velocity at each respective sampling location or compartment. With the average velocity through each compartment known, the test can then be performed according to Method 5 for sample nozzle selection and isokinetic sampling procedures.

Three sample runs were conducted to constitute a complete test of the baghouse process. Each test run consisted of sampling four (4) compartments in the baghouse. The sampling runs were conducted over a period of four hours each and at least 160 scf of stack gas was extracted via the sampling system.

When a test run has been completed, a post-test leak check was conducted prior to any dismantling of the sampling train. Once this has been successfully achieved, the sample train was dismantled for sample recovery.

The probe and connecting glassware was washed with acetone. The contents of the impingers was volumetrically measured for moisture gain and transferred to a labeled sample container. The glass fiber filter was carefully transferred to its sample container.

### 3. Analysis:

The glass fiber filter was desiccated for 24 hours prior to any weighing. The acetone probe wash was transferred to a tared beaker and evaporated to dryness. The resultant residue was also desiccated prior to gravimetric analysis.

The first weighing was performed after this initial period of drying. The weights were recorded to 0.0001 g. After a minimum of six additional hours of desiccating, a second weighing was conducted. The weights must agree within 0.0005 g or further desiccation must be conducted until the weights stabilize.

Sample field blanks of acetone were collected, contained, labeled and analyzed in conjunction with the samples. The blank weight was deducted from the acetone probe wash residue weight determinations.

C. Determination of Carbon Dioxide and Oxygen Emissions From Stationary Sources (Instrumental Analyzer Procedure) - US EPA Method 3A.

This method is applicable to the determination of oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) concentrations in emissions from stationary sources. A sample is continuously extracted from the effluent stream. A portion of the sample stream is conveyed to an instrumental analyzer(s) for determination of O<sub>2</sub> and CO<sub>2</sub> concentrations. These concentrations are provided in terms of percentage (%), dry basis.

The collection and analysis of diluent gases, carbon dioxide and oxygen, at the test location was performed by US EPA Reference Method 3A. This procedure utilizes continuous emissions monitors that provide the data results from the source on a "real-time" or instantaneous basis.

All of the CEM instrumental procedures that were conducted at the testing location(s) were extracted and analyzed with similar testing strategies. Because of this similarity, a detailed description of the calibration and operation procedures of the CEM testing is provided in the discussion of Method 3A and is referred to in the other sections concerning the additional CEM procedures.

1. Pre-Test Calibration:

The calibration of the instruments is performed using certified gas standards composed of a known concentration of carbon dioxide and oxygen in zero-grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed providing a certification tolerance not greater than two percent (2%) of the target concentration. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The oxygen instrument utilizes a paramagnetic detector and the carbon dioxide instrument utilizes a nondispersive infrared detector. The minimum detection limit for both gas analyzers is one-tenth of one percent (0.1%). The fullscale limitations of the oxygen and carbon dioxide analyzers is twenty-five percent (25%) and twenty percent (20%) respectively.

Immediately prior to each compliance test series, a complete multi-point calibration of the instrument is performed. Each instrument is introduced to a zero-grade nitrogen. The zero potentiometer on each analyzer is adjusted, if necessary, until the proper output from the analyzer is achieved.

Then a high-range pollutant gas mixture, that has been prepared in the specified range percentage of the span or fullscale, is injected. After the system stabilizes, the span or fullscale potentiometer is adjusted until the output from analyzer corresponds to the certification of analysis for the respective calibration gas.

When this procedure is complete and the system has responded properly to a zero and fullscale reading, a mid- and/or low-range certified calibration gas is introduced to the sampling system. No adjustments are made to the system except to achieve proper flow rate through the analyzer. The analyzer, after reaching a stable value, must correspond to the certified value of the calibration gas within the specified tolerance set forth in the test procedure.

This mid-range calibration gas serves two (2) purposes of quality control and quality assurance. The first is to demonstrate the instruments ability to analyze and output data on

a linear scale. The second purpose is to validate that the zero and fullscale values of the instrument are properly set.

Prior to sampling, a system bias check is conducted. This quality control check is performed by introducing a single calibration standard into the sample probe inlet. This calibration gas is usually a mixture of oxygen and carbon dioxide in a balance of zero nitrogen. The system is not adjusted except to achieve proper flow through the analyzers. The calibration standard is allowed to traverse the sampling system under conditions identical to actual flue gas sampling. The response of the analyzer during this bias check must agree with the initial analyzer response of this standard within the specified tolerances set forth in the test method. This system bias check serves to demonstrate that the sample train is leak free and causes no interference to the integrity of the sample.

## 2. Sampling:

After the initial multi-point calibration, the system is purged with zero-grade nitrogen to remove any contaminants that were injected during calibration. Once the system indicates that the pollutant gases have been removed, the calibration valve assembly is positioned to allow stack gas to flow through the instrument.

The sample gas is filtered at the stack position to prevent all particulate matter from entering the sampling train. This provides the instruments with a filtered gas sample from the source.

All samples injected to the instruments are removed from the stack and delivered to the instruments via a heated probe and sample line. This prevents any condensation of water vapor and/or pollutant in the gas stream. Once the sample gas exits the sample line, the stream is separated in a sample gas manifold. The split stream enables analysis of the CEM instrumentation on both wet and dry basis as necessary.

The portion of the sample gas dedicated to the dry basis analyzers is directed into a gas conditioning system where the moisture content of the stream is removed. The sample gas that exits the gas conditioning system is then routed to the instruments for analysis on a dry basis.

3. Post-Test Calibration:

To demonstrate that the instrument did not exhibit any deviation from the calibrated values set at the beginning of a test period, a calibration standard is injected into the sampling system at the conclusion of each test run. The sample system must respond within specified tolerance limits according to the initial system bias check.

This post-test calibration serves two purposes: (1) it demonstrates that excessive calibration drift of the instrument(s) did not occur during the test period and, (2) that the system was not contaminated with any foreign material from the source to alter any results during the test period.

4. Data Acquisition:

The CEM monitors utilized in the testing project output a voltage signal corresponding to the pollutant concentration determined by the detector. This signal is relayed to a computerized datalogger system. This system retrieves the output signal from each monitor every ten (10) seconds. This data is then averaged on a per-minute basis and stored on the hard drive of the computer. Additionally, a back-up data acquisition device is employed. A strip chart recorder is utilized to record the digital value data points. This device records the instrument output on a one minute, instantaneous basis.

D. Determination of Carbon Monoxide Emissions From Stationary Sources (Instrumental Analyzer Procedure) — US EPA Method 10.

1. Calibration:

The calibration of the instrument(s) is performed using certified gas standards composed of a known concentration of carbon monoxide in zero-grade nitrogen. These gas standards are prepared using partial pressure/volumetric and gravimetric methods.

The prepared gas mixture is analyzed and the certification tolerance is not greater than 2% of the pollutant component. A copy of the analysis certificate for each of the certified gas mixtures used during the testing is included in the test report.

The instrument(s) use(s) a Luft-type nondispersive infrared detector. Immediately prior to each compliance test series, a complete calibration of the instrument(s) is performed. Each instrument has zero-grade nitrogen injected into it and the zero potentiometer is adjusted, if necessary, until the proper voltage output from the analyzer is achieved.

Then a high-range pollutant gas mixture that has been prepared in the specified range percentage of the span or fullscale is injected. After the system stabilizes, the span or fullscale potentiometer is adjusted until the voltage output from the analyzer corresponds to the certification of analysis for the respective calibration gas.

When this procedure is complete and the system has responded properly to a zero and fullscale reading, a mid- and low-range certified calibration gas is injected into the system. No adjustments are made to the system except to achieve proper flow rate through the analyzer. The analyzer, after reaching a stable value, must correspond to the certified value of the calibration gas within a specified percentage of the fullscale. This mid- and low-range calibration gas serves two purposes: quality control and quality assurance. The first is to show that the instrument analyzes and outputs data on a linear scale, the second is to validate that the zero and fullscale values of the instrument(s) are properly set.

## 2. Sampling.

After calibration of the instrument(s) has been completed, a sample bias check is performed. This involves injecting calibration gas into the sample probe inlet and allowing the calibration gas to traverse through the sample train to the analyzer(s) where it is analyzed. This analysis will correspond to the pre-test calibration analysis value of the standard within the tolerances set forth in the reference method.

Once the system indicates that the calibration gases have been removed, the calibration valve assembly is positioned to allow stack gas to flow through each instrument. The sample gas is filtered at the stack position to remove any particulate matter. This prevents instruments from being contaminated and ensures reliable data acquisition.

All samples injected to the instruments are removed from the stack and delivered to the instrument(s) via a heated probe and sample line. This prevents any condensation of water vapor and/or pollutant in the gas stream.

Three (3) test runs were conducted to determine the emission value of CO. Each test run was conducted over a minimum period of one hour.

To demonstrate that the instrument(s) did not exhibit any deviation from the calibrated values set at the beginning of a test period, a sample of certified calibration gas is injected into the sampling system at the conclusion of each test run. The sample system must respond within specified tolerance limits according to the initial system bias check.

This post-test calibration serves two purposes: first it demonstrates that excessive calibration drift of the instrument(s) did not occur during the test period, and second, it demonstrates that the system was not contaminated with any foreign material from the source to alter any results during the test period.

# RAMCON

ENVIRONMENTAL CORPORATION

---

April 10, 1995

Mr. Dave Sulc  
NUCOR STEEL  
RR #2, Box 311  
Crawfordsville, Indiana 47933


RE: Metals Analysis of EAF Baghouse Particulate Samples

Dear Mr. Sulc:

I have attached the multi-metals summary of results obtained from the particulate filters collected at your EAF Baghouse in February, 1995. The metals results are provided for each test run in terms of milligrams per cubic meter ( $\text{mg}/\text{m}^3$ ) and pounds per hour ( $\text{lb}/\text{hr}$ ).


If I can be of further assistance please do not hesitate to contact me.

Sincerely,



William Joseph Sewell, II  
Vice President

WJSii:wpc  
Attachment



**R E P O R T**

Ramcon Environmental Corporation  
6707 Fletcher Creek Cove  
Memphis, TN 38134

March 28, 1995  
Control No. 12742  
Page 1 of 2

ATTN: Mr. Joe Sewell

Project Description: Three (3) thimble filters received on March 27, 1995  
Nucor Indiana  
Baghouse

Sample Identification: Run #1 TS00291 2.6100  
AIC No. 12742-1

Parameter	Method	Result	Batch	Time Analyzed By
Antimony	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133 07/61
Arsenic	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1132 07/61
Barium	EPA 3051, 6010A	0.64 mg	S3293	27MAR95 1132 07/61
Beryllium	EPA 3051, 6010A	0.000054 mg	S3293	27MAR95 1132 07/61
Cadmium	EPA 3051, 6010A	0.00042 mg	S3293	27MAR95 1132 07/61
Chromium	EPA 3051, 6010A	0.0089 mg	S3293	27MAR95 1132 07/61
Copper	EPA 3051, 6010A	0.0060 mg	S3293	27MAR95 1132 07/61
Lead	EPA 3051, 6010A	0.013 mg	S3293	27MAR95 1133 07/61
Manganese	EPA 3051, 6010A	0.032 mg	S3293	27MAR95 1132 07/61
Nickel	EPA 3051, 6010A	0.011 mg	S3293	27MAR95 1132 07/61
Phosphorus	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133 07/61
Selenium	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133 07/61
Silver	EPA 3051, 6010A	<0.0004 mg	S3293	27MAR95 1132 07/61
Thallium	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133 07/61
Zinc	EPA 3051, 6010A	0.52 mg	S3293	27MAR95 1133 07/61

Sample Identification: Run #2 TS00296 2.2578  
AIC No. 12742-2

Parameter	Method	Result	Batch	Time Analyzed By
Antimony	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133 07/61
Arsenic	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133 07/61
Barium	EPA 3051, 6010A	0.61 mg	S3293	27MAR95 1133 07/61
Beryllium	EPA 3051, 6010A	0.000042 mg	S3293	27MAR95 1133 07/61
Cadmium	EPA 3051, 6010A	<0.0003 mg	S3293	27MAR95 1133 07/61
Chromium	EPA 3051, 6010A	0.0074 mg	S3293	27MAR95 1133 07/61
Copper	EPA 3051, 6010A	0.0043 mg	S3293	27MAR95 1133 07/61
Lead	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133 07/61
Manganese	EPA 3051, 6010A	0.014 mg	S3293	27MAR95 1133 07/61
Nickel	EPA 3051, 6010A	0.0030 mg	S3293	27MAR95 1133 07/61
Phosphorus	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133 07/61
Selenium	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133 07/61
Silver	EPA 3051, 6010A	<0.0004 mg	S3293	27MAR95 1133 07/61
Thallium	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133 07/61
Zinc	EPA 3051, 6010A	0.20 mg	S3293	27MAR95 1133 07/61

**R E P O R T**

Ramcon Environmental Corporation  
6707 Fletcher Creek Cove  
Memphis, TN 38134

March 28, 1995  
Control No. 12742  
Page 2 of 2

Project Description: Three (3) thimble filters received on March 27, 1995  
Nucor Indiana  
Baghouse

Sample Identification: Run #3 TS00288 2.3513  
AIC No. 12742-3

Parameter	Method	Result	Batch	Time Analyzed	By
Antimony	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133	07/61
Arsenic	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133	07/61
Barium	EPA 3051, 6010A	0.48 mg	S3293	27MAR95 1133	07/61
Beryllium	EPA 3051, 6010A	0.000056 mg	S3293	27MAR95 1133	07/61
Cadmium	EPA 3051, 6010A	<0.0003 mg	S3293	27MAR95 1133	07/61
Chromium	EPA 3051, 6010A	0.0098 mg	S3293	27MAR95 1133	07/61
Copper	EPA 3051, 6010A	0.0085 mg	S3293	27MAR95 1133	07/61
Lead	EPA 3051, 6010A	0.010 mg	S3293	27MAR95 1133	07/61
Manganese	EPA 3051, 6010A	0.030 mg	S3293	27MAR95 1133	07/61
Nickel	EPA 3051, 6010A	0.038 mg	S3293	27MAR95 1133	07/61
Phosphorus	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133	07/61
Selenium	EPA 3051, 6010A	<0.01 mg	S3293	27MAR95 1133	07/61
Silver	EPA 3051, 6010A	<0.0004 mg	S3293	27MAR95 1133	07/61
Thallium	EPA 3051, 6010A	<0.005 mg	S3293	27MAR95 1133	07/61
Zinc	EPA 3051, 6010A	0.48 mg	S3293	27MAR95 1133	07/61

**AMERICAN INTERPLEX CORPORATION**

By Steven Lovell  
Steven Lovell  
Technical Director

SL/lms

Enclosure: Analysis Protocol

**Nucor Steel — EAF Baghouse**  
**Metal Analysis of Method 5D Filters**  
**February 22 and 24, 1995**

Metal	Concentration, mg/m <sup>3</sup>			Emission, lb/hr		
	Run 1	Run 2	Run 3	Run 1	Run 2	Run 3
Antimony	<0.0016	<0.0022	<0.0021	<0.0050	<0.0065	<0.0075
Arsenic	<0.0016	<0.0022	<0.0021	<0.0050	<0.0065	<0.0075
Barium	0.1017	0.1334	0.1022	0.3209	0.3974	0.3619
Beryllium	8.6x10 <sup>-6</sup>	9.2x10 <sup>-6</sup>	1.2x10 <sup>-5</sup>	2.7x10 <sup>-5</sup>	2.7x10 <sup>-5</sup>	4.2x10 <sup>-5</sup>
Cadmium	6.7x10 <sup>-5</sup>	<6.6x10 <sup>-5</sup>	<6.4x10 <sup>-5</sup>	0.0002	<1.95x10 <sup>-4</sup>	<2.3x10 <sup>-4</sup>
Chromium	0.0014	0.0016	0.0021	0.0045	0.0048	0.0074
Copper	0.0010	0.0009	0.0018	0.0030	0.0028	0.0064
Lead	0.0021	<0.0011	0.0021	0.0065	<0.0033	0.0075
Manganese	0.0051	0.0031	0.0064	0.0160	0.0091	0.0226
Nickel	0.0017	6.6x10 <sup>-4</sup>	0.0081	0.0055	0.0020	0.0286
Phosphorus	<0.0008	<0.0011	<0.0011	<0.0025	<0.0033	<0.0038
Selenium	<0.0016	<0.0022	<0.0021	<0.0050	<0.0065	<0.0075
Silver	<6.4x10 <sup>-5</sup>	<8.7x10 <sup>-5</sup>	<8.5x10 <sup>-5</sup>	<0.0002	<2.6x10 <sup>-4</sup>	<3.0x10 <sup>-4</sup>
Thallium	<0.0008	<0.0011	<0.0011	<0.0025	<0.0033	<0.0038
Zinc	0.0826	0.0437	0.1022	0.2607	0.1303	0.3619

Meltshop LMF testing for Lead:

Test Date: 08/14/2000

Production Rate: Approximately 241.1 ton/hr

The process and air pollution control equipment were operating normally at the time of testing.

*Supreme  
Environmental Service Company*

*ESCo Group*

1426 West 29<sup>th</sup> Street \*Indianapolis, Indiana 46208

(317)347-9590, FAX (317)347-9591


---

**REPORT on IN-HOUSE  
LEAD (Pb) TESTING**  
Performed for:  
**NUCOR Steel**  
*Crawfordsville, Indiana*  
**LMF**  
on 08/14/00

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Michael Dicen, Vice-President

## **TABLE OF CONTENTS**

---

1.	PROJECT OVERVIEW	
	SUMMARY OF TEST, Table 1-1	1-1
2.	RESULTS	
	LEAD EMISSIONS, Table 2-1	2-1
4.	METHODOLOGY	
	SUMMARY OF SAMPLING PROCEDURES	3-1
	SAMPLING POINT DETERMINATION, Table 3-1	3-1
	DESCRIPTION OF REFERENCE METHODS	3-2
5.	APPENDIX	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	LABORATORY DATA	C

NUCOR Steel  
Crawfordsville, Indiana

SESCO Project No. 4098

## 1-1 PROJECT OVERVIEW

SESCO Group was contracted by Nucor Steel, to perform in-house air sampling of the LMF Line stack at Crawfordsville, Indiana on August 14, 2000. The objective of the testing was to determine Lead (Pb) emissions. The following personnel were involved with the testing program:

SESCO	Michael Dicen
SESCO	Andrew Young
NUCOR	David Sulc

The testing program included flow determination and lead emissions (Method 12). Below is a summary of the results:

*Table 1-1:  
Summary of Test Results*

Pollutant	Runs	Date	Time	Filter (lbs/hr)	Acid Rinse (lbs/hr)
LEAD (Pb)	1	08/14/00	11:40-12:46	0.0019	0.0019
	2	08/14/00	13:05-14:12	0.0019	0.0019
	3	08/14/00	14:30-15:37	0.0019	0.0019

<b>3-Run Avg</b> (filterable & acid rinse)	<b>0.0038</b> (lbs/hr)
--	------------------------

**SESCO Group**

NUCOR Steel  
Crawfordsville, Indiana

SESCO Project No. 4098

**2-1 RESULTS**

*Table 2-1:  
LMF Emissions*

<u>Gas Conditions</u>		1	2	3	Avg
Ts	Stack Temperature (°F)	157.70	157.29	155.87	156.95
Bwo	Moisture (volume %)	1.01	1.56	1.54	1.37
O2	Oxygen (dry volume %)	20.9	20.9	20.9	20.9
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	155248	152530	152531	153436
Qstd	Standard Conditions (dscfm)	132050	129113	129430	130198
<u>Lead (Pb)</u>					
Er	Emission Rate - filterable (lbs/hr)	0.0019	0.0019	0.0019	0.0019
Er	Emission Rate - acid rinse (lbs/hr)	0.0019	0.0019	0.0019	0.0019
Er	Emission Rate - total (lbs/hr)	0.0038	0.0038	0.0038	0.0038

**SESCO Group**

NUCOR Steel  
Crawfordsville, Indiana

SESCO Project No. 4098

### **3-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 12. The following table summarizes the methods:

#### **Summary of Sampling Procedures**

---

##### Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 12	"Determination of Lead Emissions"

---

#### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

*Table 3-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Ports</b>	<b>Points per Port</b>	<b>Total Points</b>
LMF Line	102" ID	2	12	24

---

***SESCO Group***

### **3-2 METHODOLOGY**

---

#### **SAMPLE AND VELOCITY TRAVERSE - EPA METHOD 1**

Method 1 was used for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction is selected and divided into a equal number of areas. A traverse point is then located within each of these equal areas. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters up stream from any flow disturbance such as a bend, expansion, contraction, or visible flame. If necessary, an alternative location may be selected at a position at least two stack or duct diameters downstream and one half diameter upstream from any flow disturbance.

#### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at both the inlet and outlet locations. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

#### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

#### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

#### **LEAD DETERMINATION - EPA METHOD 12**

Outlet stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe, and filter. Lead particulate is also captured in the first two impingers; these impingers contain nitric acid. A fourth and final impinger contains about 200 grams of silica gel. The probe and filter temperature are maintained at 248 degrees F(+/- 25 deg. F). The impinger gas temperature is maintained at temperatures at or below 68 deg. F.




Figure 4-2. Particulate Sampling Train

Meltshop Baghouse #1 testing for Front-half Metals Emissions:

Test Date: 10/31/2001

Production Rate: Approximately 294 tph, EAF's only.

The process and air pollution control equipment were operating normally at the time of testing.

**Supreme  
Environmental Service Company**

*SESCo Group*

1426 West 29<sup>th</sup> Street \*Indianapolis, Indiana 46208

(317)347-9590, FAX (317)347-9591


---

**REPORT on  
METALS EMISSIONS**  
Performed for:  
***Nucor Steel***  
*Crawfordsville, Indiana*  
***Positive Pressure Baghouse***  
on October 31, 2001

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by

  
Michael Dicen, Vice-President *for*

## **TABLE OF CONTENTS**

---

1.	<b>PROJECT OVERVIEW</b>	
	SUMMARY OF TEST, Table 1-1	1-1
2.	<b>RESULTS</b>	
	METALS EMISSIONS, Table 2-1	2-1
3.	<b>PROCESS DESCRIPTION</b>	3-1
	DESCRIPTION OF INSTALLATION	
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	SAMPLING POINT DETERMINATION, Table 4-1	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	LABORATORY DATA	C
	CHAIN OF CUSTODY	D

**1-1 PROJECT OVERVIEW**

---

SESCO Group was contracted by Nucor Steel to perform emissions sampling of the EAF Positive Pressure (PPFF) Baghouse on October 31, 2001. The objective of the testing was to determine Metals Emissions. The following personnel were involved with the testing program:

SESCO	Michael Dicen
SESCO	Carlos Brown
SESCO	Andrew Young
SESCO	Milo Hatfield
Nucor Steel	David Sulc

The testing program included flow and moisture determination (Methods 1-4) and metals emissions (Method 29). Below is a summary of the results:

**Table 1-1:  
Summary of Test Results**

PM	Date	Mass Emission Rate * (lbs/hr)	Concentration * (gr/dscf)
Antimony	10/31/01	0.00e+00	0.00e+00
Arsenic		0.00e+00	0.00e+00
Barium		4.62e-04	5.07e-08
Beryllium		0.00e+00	0.00e+00
Cadmium		0.00e+00	0.00e+00
Chromium		1.11e-03	1.20e-07
Cobalt		0.00e+00	0.00e+00
Copper		1.52e-03	1.65e-07
Lead		1.11e-03	1.21e-07
Manganese		1.12e-01	1.22e-05
Mercury		3.03e-04	3.31e-08
Nickel		4.92e-04	5.40e-08
Phosphorus		3.93e-04	4.21e-08
Selenium		2.99e-05	3.29e-09
Silver		8.55e-05	9.39e-09
Thallium		1.73e-03	1.87e-07
Zinc		4.56e-02	4.98e-06

\* NOTE: Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

**2-1 RESULTS**

**METALS EMISSIONS**  
EAF (PPFF) Baghouse

Table 2-1:

<u>Gas Conditions</u>		1	2	3	Avg.
Ts	Stack Temperature (°F)	204.50	198.75	172.83	192.03
Bwo	Moisture (volume %)	0.83	0.96	1.08	0.96
O2	Oxygen (dry volume %)	19.5	19.5	20.0	19.67
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1,330,773	1,352,353	1,366,714	1,349,947
Qstd	Standard Conditions (dscfm)	1,063,403	1,088,649	1,135,898	1,095,983
<b>METALS EMISSIONS</b>		1	2		Avg.
Er	Antimony (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Arsenic (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Barium (lbs/hr)	9.15e-04	8.53e-06		4.62e-04
Er	Beryllium (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Cadmium (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Chromium (lbs/hr)	1.30e-03	9.13e-04		1.11e-03
Er	Cobalt (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Copper (lbs/hr)	1.93e-03	1.10e-03		1.52e-03
Er	Lead (lbs/hr)	1.98e-03	2.33e-04		1.11e-03

**2-1 RESULTS, cont.**

---

**METALS EMISSIONS**  
EAF (PPFF) Baghouse

Table 2-1:

METALS EMISSIONS		1	2	3	* Avg.
Er	Manganese (lbs/hr)	1.21e-01	1.04e-01		1.12e-01
Er	Mercury (lbs/hr)	4.45e-04	1.62e-04		3.03e-04
Er	Nickel (lbs/hr)	9.83e-04	0.00e+00		4.92e-04
Er	Phosphorus (lbs/hr)	0.00e+00	7.85e-04		3.93e-04
Er	Selenium (lbs/hr)	5.99e-05	0.00e+00		2.99e-05
Er	Silver (lbs/hr)	1.71e-04	0.00e+00		8.55e-05
Er	Thallium (lbs/hr)	1.73e-03	1.72e-03		1.73e-03
Er	Zinc (lbs/hr)	6.41e-02	2.71e-02		4.56e-02

\* **NOTE:** Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

### **3-1 PROCESS DESCRIPTION**

---

Nucor Steel operates a meltshop which is comprised of the following process units: two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD and two (2) continuous casters. Of these, the two EAF units, the AOD and the two caster units are evacuated through the melt shop baghouse. The EAF units melt various grades of scrap metal, scrap substitutes, pebbled lime and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD and casters are generated from melting, refining, charging, tapping and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. All captured emissions are evacuated through the positive pressure (PPFF) baghouse for collection.

The testing reported in this document was performed at the EAF (PPFF) baghouse.

***SESCO Group***

## 4-1 METHODOLOGY

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 29. The following table summarizes the methods:

### Summary of Sampling Procedures

---

Title 40 CFR Part 60 Appendix A

Method 1 "Sampling of Velocity Traverses for Stationary Sources"

Method 2 "Determination of Stack Gas Velocity and Volumetric Flow Rate"

Method 3 "Gas Analysis for the Determination of Molecular Weight"

Method 4 "Determination of Moisture Content in Stack Gas"

Method 29 "Determination of Metals Emissions"

---

### SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

*Table 4-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Points / Compartment</b>
Baghouse	366" x 4160" ID	12

---

## **4-2 METHODOLOGY**

---

### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the outlet locations. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas samples were collected during each sample run and analyzed using an Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-1 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **DETERMINATION OF METALS EMISSIONS - EPA METHOD 29**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe liner and heated filter. Gaseous emissions are collected in an absorbing solution of HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub> (*0.1 N Nitric Acid & Hydrogen Peroxide*) in the 2<sup>nd</sup> and 3<sup>rd</sup> impingers and then in an aqueous acidic solution of KMnO<sub>4</sub> (*Potassium Permanganate*) in the 5<sup>th</sup> and 6<sup>th</sup> impingers (*analyzed only for Hg*). The 1<sup>st</sup> and 4<sup>th</sup> impingers are empty and a 7<sup>th</sup> impinger contains approximately 200 grams of silica gel. High temperature borosilicate probe liner is used and the filter is maintained at temperatures at or above 248 degrees (+/- 25 F). Impinger temperature exit gas is maintained at or below 68 degrees F.

The nozzle, probe liner and front half of glass filter holder are rinsed with 100 ml of 0.1 N HNO<sub>3</sub> and cleaned with a teflon brush and collected in a jar. Impingers 1, 2 and 3 are measured for moisture pick-up and then collected in a jar before rinsing the impingers with 100 ml of 0.1 N HNO<sub>3</sub>, along with the back half of the glass filter holder. Absorbing solutions are combined along with rinse solution. Impinger 4 is measured for moisture pick-up (individually), collected and then rinsed with 100 ml of 0.1 N HNO<sub>3</sub> which is combined with moisture pick-up. Impingers 5 and 6 are measured for moisture pick-up, collected in an amber jar with teflon lid liner and rinsed with 100 ml KMnO<sub>4</sub> followed by 100 ml of HPLC water which is combined with the absorbing solution. Impingers 5 and 6 are then rinsed with 25 ml 8 N HCl and collected in a jar. Silica gel is weighed for moisture.




Figure 4-1. Particulate Sampling Train

Meltshop Baghouse #1 testing for Particulate:

Test Date: 10/31/2001

Production Rate: Approximately 294 tph, EAF's only.

The process and air pollution control equipment were operating normally at the time of testing.

**Supreme  
Environmental Service Company**

*SESCO Group*

1426 West 29<sup>th</sup> Street \*Indianapolis, Indiana 46208

(317)347-9590, FAX (317)347-9591

---


**REPORT on PARTICULATE COMPLIANCE TESTING**

Performed for:  
***Nucor Steel***  
***Crawfordsville, Indiana***  
***Positive Pressure Baghouse***  
by: SESCO  
on October 31, 2001  
**SESCO Project No.: 4214**

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Michael Dicen, Division Manager

## **TABLE OF CONTENTS**

---

1.	<b>PROJECT OVERVIEW</b>	
	SUMMARY OF TEST	1-1
	PROJECT OVERVIEW	1-2
2.	<b>RESULTS</b>	
	PARTICULATE MATTER EMISSIONS	2-1
	INLET - VOLUMETRIC FLOW RATE	2-2
	VISIBLE EMISSIONS - BAGHOUSE	2-3
	VISIBLE EMISSIONS - MELT SHOP	2-4
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	SAMPLING POINT DETERMINATION	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	<b>ATTACHMENT A</b>	
	PRODUCTION DATA	I

**1-1 PROJECT OVERVIEW**

---

SESCO Group, was contracted by Nucor Steel to perform air sampling at the EAF Positive Pressure Fabric Filter Baghouse and Melt Shop, in Crawfordsville, Indiana on October 31, 2001. The testing was performed in accordance with Paragraph 48 of the Consent Decree to establish operating baselines as required by NSPS at the Electric Arc Furnace. The following personnel were involved with the testing program:

SESCO	Carlos Brown
SESCO	Andy Young
SESCO	Michael Dicen
SESCO	Milo Hatfield
SESCO	Quentin Flory
Nucor	David Sulc
Nucor	Eric Ferguson
IDEM	Jarrold Fisher

The testing program included flow and gas analysis (Methods 1-4), particulate (Methods 5D) and visual emissions (Method 9). Below is a summary of the results:

**Table 1-1  
Summary of Test Results**

Date	Runs	Time	Emissions	Emissions
10/31/01	1	12:36-18:17	<b>0.00030</b> (gr/dscf)	0.6840 lbs/hr
10/31/01	2	20:18-01:31	<b>0.00061</b> (gr/dscf)	1.4295 lbs/hr
11/01/01	3	08:41-13:47	<b>0.00074</b> (gr/dscf)	1.8109 lbs/hr

<b>3-Run Averages</b>	<b>0.00055</b> (gr/dscf)	1.3081 lbs/hr
<b>Permitted Emission Rate</b>	<b>0.0018</b> (gr/dscf)	

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

## 1-2 PROJECT OVERVIEW

### Test Program

Table 1-2

<b>Parameter</b>	<b>Methods</b>	<b>Location</b>	<b>Unit</b>
Gas Velocity / Vol. Flow Rate	EPA RM 1-2	Inlet	EAF Baghouse
Particulate	EPA RM 3-5D	Compartment	EAF Baghouse
Opacity	EPA RM 9	Roof Monitor	EAF Baghouse
Opacity	EPA RM 9	Roof Monitor	Melt Shop

The schedule of activities is summarized below:

### Schedule of Activities

<b><i>Date</i></b>	<b><i>Run No.</i></b>	<b><i>Time</i></b>
Particulate Test (EAF Baghouse)		
10/31/01	1	12:36-18:17
10/31/01	2	20:18-01:31
11/01/01	3	08:41-13:47



***SESCO Group***

**1-2 PROJECT OVERVIEW, cont.**

**EAF (PPFF) Baghouse Diagram**

- 1.) Nucor Steel PPFF baghouse consists of 16 compartment housings with an area of 366"d x 260"w per compartment.
- 2.) Compliance testing was conducted at 12 of the 16 compartment housings (see Table: 1-3).
- 3.) Three (3) sample runs were conducted at four compartments (per sample run) resulting in a test area of 366"d x 1040"w.
- 4.) Compartment volumetric flow rates reflect approximately 25% of the total measured inlet flow rate (see 2-1 / 2-2 RESULTS for compartment and Inlet flow rates).

Table: 1-3



**2-1 RESULTS**

**PARTICULATE MATTER/ EMISSIONS**  
Compartment Housings

Table 2-1

		1	2	3	Avg.
<u>Gas Conditions</u>					
Ts	Stack Temperature (°F)	204.50	198.75	172.83	192.03
Bwo	Moisture (volume %)	0.83	0.96	1.08	0.96
O2	Oxygen (dry volume %)	19.5	19.5	20.0	19.67
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	332,693	338,088	341,678	337,487
Qstd	Standard Conditions (dscfm)	265,851	272,162	283,975	273,996
<u>Particulate Results</u>					
C <sub>f</sub>	Concentration, filterable (gr/dscf)	0.00030	0.00061	0.00074	<b>0.00055</b>
E <sub>TSP</sub>	Particulate Matter, filterable (lbs/hr)	0.6840 2.736	1.4295 5.718	1.8109 7.244	1.3081 5.23
<u>Fan Amps / Damper Positions</u>					
	Average Fan Amps	149	141	139	<b>143</b>
	Average Damper Position	93%	100%	100%	<b>98%</b>

**NOTE:** Velocity head settings for Method 5D compartment test runs were derived from Inlet volumetric flow rates. Flow rate calculations were corrected for compartment conditions; temperature, moisture and gas analysis. A minimum of 160 dscf was sampled during each test period.

**2-2 RESULTS**

---

**INLET - VOLUMETRIC FLOW RATE**

Inlet Duct

Table 2-2

---

		1	2	3	Avg.
<u>Gas Conditions</u>					
Ts	Stack Temperature (°F)	194.56	203.06	222.44	206.69
Bwo	Moisture (volume %)	0.83	0.96	1.08	0.96
O2	Oxygen (dry volume %)	19.5	19.5	20.0	19.67
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1,331,074	1,352,652	1,367,028	1,350,251
Qstd	Standard Conditions (dscfm)	1,077,927	1,081,359	1,054,449	1,071,245

---

**NOTE:** Inlet flow rates (*initial*) were measured and calculated over the duct area of 278" x 176".

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

## 2-3 RESULTS

---

### VISIBLE EMISSIONS Positive Pressure Baghouse

Table 2-3

Run No.	1	2	3	4	Average
Date	10/31/01	10/31/01	10/31/01	11/01/01	
Start Time (approx.)	15:13	16:14	17:15	11:00	
Stop Time (approx.)	16:13	17:14	18:15	12:00	
<b>Visible Emissions</b>					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	0.0 %

*SESCO Group*

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

**2-4 RESULTS**

---

**VISIBLE EMISSIONS**

Melt Shop

Table 2-4

<b>Run No.</b>	1	2	3	4	<b>Average</b>
<b>Date</b>	10/31/01	10/31/01	10/31/01	11/01/01	
<b>Start Time (approx.)</b>	15:13	16:14	17:15	10:00	
<b>Stop Time (approx.)</b>	16:13	17:14	18:15	11:00	
<b>Visible Emissions</b>					
Opacity (EPA RM 9)	0.0	0.0	0.0	0.0	<b>0.0 %</b>


***SESCO Group***

### 3-1 DESCRIPTION OF INSTALLATION

Nucor Steel operates a meltshop which is comprised of the following process units: two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD and two (2) continuous casters. Of these, the two EAF units, the AOD and the two caster units are evacuated through the melt shop baghouse. The EAF units melt various grades of scrap metal, scrap substitutes, pebbled lime and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD and casters are generated from melting, refining, charging, tapping and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. All captured emissions are evacuated through the positive pressure (PPFF) baghouse for collection.

The testing reported in this document was performed at 12 of the 16 EAF (PPFF) baghouse compartments.



## **4-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-5D, 9. The following table summarizes the methods.

### **Summary of Sampling Procedures**

---

#### **Title 40 CFR Part 60 Appendix A**

Method 1 "Sampling of Velocity Traverses for Stationary Sources"

Method 2 "Determination of Stack Gas Velocity and Volumetric Flow Rate"

Method 3 "Gas Analysis for the Determination of Molecular Weight"

Method 4 "Determination of Moisture Content in Stack Gas"

Method 5D "Determination of Particulate Emissions from PPF"

Method 9 "Visual Determination of the Opacity of Emissions from Stationary Sources"

---

### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

**Table 4-1:  
Sampling Points**

---

Location	Dimensions	Ports	Points/Port	Total Points
Inlet	14.67' x 23.13' ID	8	4	32
Compartment (ea)	21.67' x 30.50' ID	3	4	12

---

\*\*Exact measure points and distances to disturbances are listed in the Appendix C - Field Data

## **4-2 METHODOLOGY**

---

### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the inlet location. Figure 4-2 includes the components of the EPA Method 2 sampling apparatus. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas samples were collected for each sample run and analyzed using a Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-2 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used in calculation to determine stack gas velocity.

### **PARTICULATE DETERMINATION - EPA METHOD 5D**

Velocity readings were taken at the inlet to the baghouse in accordance with EPA RM-1. The data was then utilized for the determination of the volumetric flow rate through the baghouse compartments. This value was then used to determine the average velocity at the respective compartments. After the compartment velocity was determined, the test was performed according to EPA RM-5. Stack gas was withdrawn isokinetically and particulate matter was collected on the in-stack nozzle and filter. Moisture was captured in an impingers set; the first two impingers contain 100 mls of water. The third impinger was empty and a fourth and final impinger contains about 200 grams of silica gel. The filter temperatures were maintained at in-stack flue gas temperatures. The impinger temperature exit gas was maintained at temperatures at or below 68 deg. F.

The nozzle and glass filter containers were rinsed with acetone and the rinse was captured in a sealed glass container. The filter was placed in a sealed container.

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

#### **4-2 METHODOLOGY, cont.**

---

##### **VISIBLE EMISSIONS - METHOD 9**

Baghouse Roof Monitor and Melt Shop Roof Monitor opacity readings were taken for 60 min. at 15 second intervals by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs. The results are reported as an average opacity reading for the hour period. A copy of the visible emissions reader's current certification is included in the Appendix.

***SESCO Group***




Figure 4-2. Particulate Sampling Train

Meltshop Baghouse #1 testing for Back-half Metals Emissions:

Test Date: 10/31/2001

Production Rate: Approximately 294 tph, EAF's only.

The process and air pollution control equipment were operating normally at the time of testing.

**Supreme  
Environmental Service Company**

*SESCO Group*

1426 West 29<sup>th</sup> Street \*Indianapolis, Indiana 46208

(317)347-9590, FAX (317)347-9591


---

**REPORT on  
METALS EMISSIONS**  
Performed for:  
***Nucor Steel***  
*Crawfordsville, Indiana*  
***Positive Pressure Baghouse***  
on October 31, 2001

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Michael Dicen, Vice-President

**TABLE OF CONTENTS**

---

1.	<b>PROJECT OVERVIEW</b>	
	SUMMARY OF TEST, Table 1-1	1-1
2.	<b>RESULTS</b>	
	METALS EMISSIONS, Table 2-1	2-1
3.	<b>PROCESS DESCRIPTION</b>	3-1
	DESCRIPTION OF INSTALLATION	
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	SAMPLING POINT DETERMINATION, Table 4-1	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA PRINTOUTS	B
	LABORATORY DATA	C
	CHAIN OF CUSTODY	D

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

**1-1 PROJECT OVERVIEW**

SESCO Group was contracted by Nucor Steel to perform emissions sampling of the EAF Positive Pressure (PPFF) Baghouse on October 31, 2001. The objective of the testing was to determine Metals Emissions. The following personnel were involved with the testing program:

SESCO	Michael Dicen
SESCO	Carlos Brown
SESCO	Andrew Young
SESCO	Milo Hatfield
Nucor Steel	David Sulc

The testing program included flow and moisture determination (Methods 1-4) and metals emissions (Method 29). Below is a summary of the results:

**Table 1-1:  
Summary of Test Results**

PM	Date	Mass Emission Rate * (lbs/hr)	Concentration * (gr/dscf)
Antimony	10/31/01	9.10e-03	9.87e-07
Arsenic		0.00e+00	0.00e+00
Barium		3.88e-01	4.21e-05
Beryllium		8.53e-06	9.15e-10
Cadmium		4.27e-04	4.61e-08
Chromium		2.35e-02	2.53e-06
Cobalt		3.42e-04	3.71e-08
Copper		5.75e-03	6.23e-07
Lead		1.18e-02	1.28e-06
Manganese		1.60e-01	1.74e-05
Mercury		3.03e-04	3.31e-08
Nickel		2.80e-03	3.03e-07
Phosphorus		6.88e-03	7.45e-07
Selenium		1.74e-03	1.88e-07
Silver		2.14e-04	2.35e-08
Thallium		1.73e-03	1.87e-07
Zinc		1.65e+00	1.79e-04

\* NOTE: Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

**SESCO Group**

**2-1 RESULTS**

**METALS EMISSIONS**  
EAF (PPFF) Baghouse

Table 2-1:

<u>Gas Conditions</u>		1	2	3	Avg.
Ts	Stack Temperature (°F)	204.50	198.75	172.83	192.03
Bwo	Moisture (volume %)	0.83	0.96	1.08	0.96
O2	Oxygen (dry volume %)	19.5	19.5	20.0	19.67
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1,330,773	1,352,353	1,366,714	1,349,947
Qstd	Standard Conditions (dscfm)	1,063,403	1,088,649	1,135,898	1,095,983
<b>METALS EMISSIONS</b>		1	2		Avg.
Er	Antimony (lbs/hr)	8.55e-03	9.64e-03		9.10e-03
Er	Arsenic (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Barium (lbs/hr)	3.65e-01	4.11e-01		3.88e-01
Er	Beryllium (lbs/hr)	0.00e+00	1.71e-05		8.53e-06
Er	Cadmium (lbs/hr)	2.57e-04	5.97e-04		4.27e-04
Er	Chromium (lbs/hr)	1.23e-02	3.46e-02		2.35e-02
Er	Cobalt (lbs/hr)	3.42e-04	3.41e-04		3.42e-04
Er	Copper (lbs/hr)	4.41e-03	7.09e-03		5.75e-03
Er	Lead (lbs/hr)	7.54e-03	1.61e-02		1.18e-02

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

**2-1 RESULTS, cont.**

**METALS EMISSIONS  
EAF (PPFF) Baghouse**

Table 2-1:

METALS EMISSIONS		1	2	3	* Avg.
Er	Manganese (lbs/hr)	1.44e-01	1.76e-01		1.60e-01
Er	Mercury (lbs/hr)	4.45e-04	1.62e-04		3.03e-04
Er	Nickel (lbs/hr)	2.61e-03	2.99e-03		2.80e-03
Er	Phosphorus (lbs/hr)	5.99e-03	7.77e-03		6.88e-03
Er	Selenium (lbs/hr)	1.26e-03	2.22e-03		1.74e-03
Er	Silver (lbs/hr)	4.28e-04	0.00e+00		2.14e-04
Er	Thallium (lbs/hr)	1.73e-03	1.72e-03		1.73e-03
Er	Zinc (lbs/hr)	1.22e+00	2.08e+00		1.65e+00

\* NOTE: Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

**SESCO Group**

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

### **3-1 PROCESS DESCRIPTION**

---

Nucor Steel operates a meltshop which is comprised of the following process units: two (2) EAF units, one (1) ladle metallurgy station, one (1) AOD and two (2) continuous casters. Of these, the two EAF units, the AOD and the two caster units are evacuated through the melt shop baghouse. The EAF units melt various grades of scrap metal, scrap substitutes, pebbled lime and coke into molten steel. The molten steel is refined into various grades of carbon steel at the ladle metallurgy station or refined into stainless steel at the AOD. The molten steel from the ladle metallurgy station or AOD is cast into continuous strips at the two continuous casters.

The emissions from the EAF units, AOD and casters are generated from melting, refining, charging, tapping and casting operations and are captured in a direct shell evacuation (DEC) system and overhead canopy hoods. All captured emissions are evacuated through the positive pressure (PPFF) baghouse for collection.

The testing reported in this document was performed at the EAF (PPFF) baghouse.

***SESCO Group***

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

## **4-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 29. The following table summarizes the methods:

### **Summary of Sampling Procedures**

---

#### **Title 40 CFR Part 60 Appendix A**

Method 1 "Sampling of Velocity Traverses for Stationary Sources"

Method 2 "Determination of Stack Gas Velocity and Volumetric Flow Rate"

Method 3 "Gas Analysis for the Determination of Molecular Weight"

Method 4 "Determination of Moisture Content in Stack Gas"

Method 29 "Determination of Metals Emissions"

---

### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

*Table 4-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Points / Compartment</b>
Baghouse	366" x 4160" ID	12

---

***SESCO Group***

## **4-2 METHODOLOGY**

---

### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the outlet locations. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas samples were collected during each sample run and analyzed using an Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. Figure 4-2 includes the Method 4 sampling components. The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **DETERMINATION OF METALS EMISSIONS - EPA METHOD 29**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe liner and heated filter. Gaseous emissions are collected in an absorbing solution of HNO<sub>3</sub>/H<sub>2</sub>O<sub>2</sub> (*0.1 N Nitric Acid & Hydrogen Peroxide*) in the 2<sup>nd</sup> and 3<sup>rd</sup> impingers and then in an aqueous acidic solution of KMnO<sub>4</sub> (*Potassium Permanganate*) in the 5<sup>th</sup> and 6<sup>th</sup> impingers (*analyzed only for Hg*). The 1<sup>st</sup> and 4<sup>th</sup> impingers are empty and a 7<sup>th</sup> impinger contains approximately 200 grams of silica gel. High temperature borosilicate probe liner is used and the filter is maintained at temperatures at or above 248 degrees (+/- 25 F). Impinger temperature exit gas is maintained at or below 68 degrees F.

The nozzle, probe liner and front half of glass filter holder are rinsed with 100 ml of 0.1 N HNO<sub>3</sub> and cleaned with a teflon brush and collected in a jar. Impingers 1, 2 and 3 are measured for moisture pick-up and then collected in a jar before rinsing the impingers with 100 ml of 0.1 N HNO<sub>3</sub>, along with the back half of the glass filter holder. Absorbing solutions are combined along with rinse solution. Impinger 4 is measured for moisture pick-up (individually), collected and then rinsed with 100 ml of 0.1 N HNO<sub>3</sub> which is combined with moisture pick-up. Impingers 5 and 6 are measured for moisture pick-up, collected in an amber jar with teflon lid liner and rinsed with 100 ml KMnO<sub>4</sub> followed by 100 ml of HPLC water which is combined with the absorbing solution. Impingers 5 and 6 are then rinsed with 25 ml 8 N HCl and collected in a jar. Silica gel is weighed for moisture.




Figure 4-1. Particulate Sampling Train

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

### **1-1 PROJECT OVERVIEW**

SESCO Group was contracted by Nucor Steel to perform emissions sampling of the EAF Positive Pressure (PPFF) Baghouse on October 31, 2001. The objective of the testing was to determine Metals Emissions. The following personnel were involved with the testing program:

SESCO	Michael Dicen
SESCO	Carlos Brown
SESCO	Andrew Young
SESCO	Milo Hatfield
Nucor Steel	David Sulc

The testing program included flow and moisture determination (Methods 1-4) and metals emissions (Method 29). Below is a summary of the results:

***Table 1-1:  
Summary of Test Results***

<b>PM</b>	<b>Date</b>	<b>Mass Emission Rate * (lbs/hr)</b>	<b>Concentration * (gr/dscf)</b>
Antimony	10/31/01	9.10e-03	9.87e-07
Arsenic		0.00e+00	0.00e+00
Barium		3.88e-01	4.21e-05
Beryllium		8.53e-06	9.15e-10
Cadmium		4.27e-04	4.61e-08
Chromium		2.35e-02	2.53e-06
Cobalt		3.42e-04	3.71e-08
Copper		5.75e-03	6.23e-07
Lead		1.18e-02	1.28e-06
Manganese		1.60e-01	1.74e-05
Mercury		3.03e-04	3.31e-08
Nickel		2.80e-03	3.03e-07
Phosphorus		6.88e-03	7.45e-07
Selenium		1.74e-03	1.88e-07
Silver		2.14e-04	2.35e-08
Thallium		1.73e-03	1.87e-07
Zinc		1.65e+00	1.79e-04

\* NOTE: Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

***SESCO Group***

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

## 2-1 RESULTS

### METALS EMISSIONS EAF (PPFF) Baghouse

Table 2-1:

<u>Gas Conditions</u>		1	2	3	Avg.
Ts	Stack Temperature (°F)	204.50	198.75	172.83	192.03
Bwo	Moisture (volume %)	0.83	0.96	1.08	0.96
O2	Oxygen (dry volume %)	19.5	19.5	20.0	19.67
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1,330,773	1,352,353	1,366,714	1,349,947
Qstd	Standard Conditions (dscfm)	1,063,403	1,088,649	1,135,898	1,095,983
<b>METALS EMISSIONS</b>		1	2		Avg.
Er	Antimony (lbs/hr)	8.55e-03	9.64e-03		9.10e-03
Er	Arsenic (lbs/hr)	0.00e+00	0.00e+00		0.00e+00
Er	Barium (lbs/hr)	3.65e-01	4.11e-01		3.88e-01
Er	Beryllium (lbs/hr)	0.00e+00	1.71e-05		8.53e-06
Er	Cadmium (lbs/hr)	2.57e-04	5.97e-04		4.27e-04
Er	Chromium (lbs/hr)	1.23e-02	3.46e-02		2.35e-02
Er	Cobalt (lbs/hr)	3.42e-04	3.41e-04		3.42e-04
Er	Copper (lbs/hr)	4.41e-03	7.09e-03		5.75e-03
Er	Lead (lbs/hr)	7.54e-03	1.61e-02		1.18e-02

**SESCO Group**

Nucor Steel  
Crawfordsville, Indiana

SESCO Project No. 4214

**2-1 RESULTS, cont.**

**METALS EMISSIONS**  
EAF (PPFF) Baghouse

Table 2-1:

METALS EMISSIONS		1	2	3	* Avg.
E <sub>r</sub>	Manganese (lbs/hr)	1.44e-01	1.76e-01		1.60e-01
E <sub>r</sub>	Mercury (lbs/hr)	4.45e-04	1.62e-04		3.03e-04
E <sub>r</sub>	Nickel (lbs/hr)	2.61e-03	2.99e-03		2.80e-03
E <sub>r</sub>	Phosphorus (lbs/hr)	5.99e-03	7.77e-03		6.88e-03
E <sub>r</sub>	Selenium (lbs/hr)	1.26e-03	2.22e-03		1.74e-03
E <sub>r</sub>	Silver (lbs/hr)	4.28e-04	0.00e+00		2.14e-04
E <sub>r</sub>	Thallium (lbs/hr)	1.73e-03	1.72e-03		1.73e-03
E <sub>r</sub>	Zinc (lbs/hr)	1.22e+00	2.08e+00		1.65e+00

\* NOTE: Test averages include only Sample Runs 1 & 2 due to a cross contamination of chemicals (KmnO4 mixed with HNO3/H2O2) during the 3<sup>rd</sup> Sample Run.

**SESCO Group**

*TOTAL  
F. Items  
&  
Comensibles*

**STACK EMISSION SUMMARY**

<b>SOURCE TESTED:</b>	<b>Positive Pressure Baghouse</b>
<b>COMPANY NAME:</b>	Nucor Steel
<b>DATE OF TEST:</b>	10/31/01 - 11/01/01

<b>Metals / - blanks (lbs/hr)</b>	<b>Run 1</b>	<b>Run 2</b>	<b>Run 3</b>	<b>Average</b>
Antimony	8.55E-003	9.64E-003		9.10E-003
Arsenic	0.00E+000	0.00E+000		0.00E+000
Barium	3.65E-001	4.11E-001		3.88E-001
Beryllium	0.00E+000	1.71E-005		8.53E-006
Cadmium	2.57E-004	5.97E-004		4.27E-004
Chromium	1.23E-002	3.46E-002		2.35E-002
Cobalt	3.42E-004	3.41E-004		3.42E-004
Copper	4.41E-003	7.09E-003		5.75E-003
Lead	7.54E-003	1.61E-002		1.18E-002
Manganese	1.44E-001	1.76E-001		1.60E-001
Mercury	4.45E-004	1.62E-004		3.03E-004
Nickel	2.61E-003	2.99E-003		2.80E-003
Phosphorus	5.99E-003	7.77E-003		6.88E-003
Selenium	1.26E-003	2.22E-003		1.74E-003
Silver	4.28E-004	0.00E+000		2.14E-004
Thallium	1.73E-003	1.72E-003		1.73E-003
Zinc	1.22E+000	2.08E+000		1.65E+000
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	1,330,773	1,352,353	1,366,714	1,349,947
DSCFM	1,063,403	1,088,649	1,135,898	1,095,983
<b>Avg. Stack Temp.</b>				
	204.50	198.75	172.83	192.03
<b>Stack Gas Velocity</b>				
	2.098	2.132	2.154	2.128
<b>Avg. Velocity Head</b>				
	0.0011	0.0012	0.0012	0.0012
<b>Avg. Sq. Rt of Delta P</b>				
	0.0334	0.0341	0.0350	0.0341
<b>ISOKINETIC TESTING SUMMARY</b>				
<b>%Isokinetics:</b>	104.07	104.27	101.96	103.43
Allowable isokinetic 90-110%				
% Moisture of Stack Gas	0.83%	0.96%	1.08%	0.96%
Sample Volume	164.364	168.581	172.009	168.318

Castrip LMS Baghouse testing for Emissions:

Test Date: 11/20 and 11/21/2003

Production Rate: Approximately 104.1tph, LMS only.

The process and air pollution control equipment were operating normally at the time of testing.

---

**REPORT on COMPLIANCE TESTING  
for SO<sub>2</sub>, NO<sub>x</sub>, CO, Pb and PM/PM<sub>10</sub>**

Performed for:  
**Nucor Steel**  
*Crawfordsville, Indiana*  
**Strip Caster**  
on November 20 & 21, 2003

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:



Andrew Young, Project Manager

## TABLE OF CONTENTS

---

1.	<b>PROJECT OVERVIEW</b>	
	TEST SUMMARY, Table 1-1	1-1
2.	<b>RESULTS</b>	
	STRIP CASTER – PM/PM10, SO <sub>2</sub> , NO <sub>x</sub> , & CO EMISSIONS	2-1
	STRIP CASTER – LEAD EMISSIONS	2-2
	STRIP CASTER – VISIBLE EMISSIONS	2-3
3.	<b>DESCRIPTION OF INSTALLATION</b>	
	DESCRIPTION OF PROCESS	3-1
4.	<b>METHODOLOGY</b>	
	SUMMARY OF SAMPLING PROCEDURES	4-1
	DESCRIPTION OF REFERENCE METHODS	4-2
5.	<b>APPENDIX</b>	
	SAMPLE CALCULATIONS	A
	FIELD DATA SUMMARIES	B
	FIELD DATA	C
	LABORATORY DATA	D
	CHAIN OF CUSTODY	E
	CALIBRATION DATA	F
	VISIBLE EMISSIONS DATA	G
	SUBMITTED PROTOCOL	H
	PRODUCTION DATA	I

## 1-1 PROJECT OVERVIEW

Air Test Professionals, Inc. was contracted by Nucor Steel to perform air emissions sampling at the LMS Baghouse that controls emissions from the LMS and Strip Caster. The sampling was performed in Crawfordsville, Indiana on November 20-21, 2003. The objective of the testing was to determine compliance with permit requirements for the pollutants listed below. The following personnel were involved with the testing program:

ATP	Andrew Young
ATP	Carlos Brown
ATP	Ron Stapert
Nucor Steel	Mark Washer
IDEM	Steve Friend

The testing program included flow determination (US EPA Methods 1-2), gas analysis (US EPA Method 3), moisture content (US EPA Method 4), PM/PM10 emissions (US EPA Method 5/202), SO2 emissions (US EPA Method 6C), NOx emissions (US EPA Method 7E), CO emissions (US EPA Method 10), and visible emissions (US EPA Method 9). Listed below is a summary of the results.

### Test Summary

Table 1-1

Pollutant	PM/PM10 (filterable)	PM/PM10 (filterable & condensable)	PM (filterable)
Particulate Matter	0.0010 (gr/dscf)	0.0043 (gr/dscf)	0.9232 (lb/hr)

Pollutant	Lead	Total Lead
Lead	0.000000 (gr/dscf)	0.0005 (lb/hr)

Pollutant	Emissions (lb/hr)	Emissions (lb/ton)
Sulfur Dioxide	10.50 (lb/hr)	0.0510 (lb/ton)
Nitrogen Oxide	3.8294 (lb/hr)	0.0181 (lb/ton)
Carbon Monoxide	11.7834 (lb/hr)	0.0567 (lb/ton)

**2-1 RESULTS**

**PM/PM10, SO2, NOx, CO Emissions**  
*Strip Caster Baghouse Stack*

Table 2-1

<b>Gas Conditions</b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	99.38	101.33	111.33	104.01
Bwo	Moisture (volume %)	1.39	1.05	1.32	1.25
O2	Oxygen (dry volume %)	20.9	20.9	20.9	20.9
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b><u>Volumetric Flow Rate</u></b>					
Qa	Actual Conditions (acfm)	124,327	115,915	111,894	117,482
Qstd	Standard Conditions (dscfm)	116,055	107,871	102,032	108,652
<b>PM/PM10</b>					
ETSP	Filterable (gr/dscf)	0.0008	0.0008	0.0013	0.0010
E	Filterable & Condensable (gr/dscf)	0.0050	0.0024	0.0053	0.0043
<b>PM/PM10</b>					
ETSP	Filterable (lbs/hr)	0.8454	0.7723	1.1518	0.9232
<b>PM/PM10</b>					
E	Emission (lb/ton)	0.0299	0.0240	0.0990	0.0510
<b>PM/PM10</b>					
E	Emission (lb/ton)	0.0040	0.0226	0.0279	0.0181
<b>PM/PM10</b>					
E	Emission (lb/ton)	0.0476	0.0670	0.0554	0.0567

**2-2 RESULTS**

**Lead Emissions**  
*Strip Caster Baghouse Stack*

Table 2-2

<b>Gas Conditions</b>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature	101.13	102.33	112.17	105.21
Bwo	Moisture (volume %)	1.39	0.86	0.83	1.03
O2	Oxygen (dry volume %)	20.9	20.9	20.9	20.9
CO2	Carbon Dioxide (dry volume %)	0.0	0.0	0.0	0.0
<b>Volumetric Flow Rate</b>					
Qa	Actual Conditions (acfm)	125,926	118,177	115,974	120,026
Qstd	Standard Conditions (dscfm)	116,887	109,941	106,072	110,966
<b>LEAD EMISSIONS</b>					
E <sub>TSP</sub>	Emission Rate (gr/dscf)	0.000001	0.000001	0.000000	0.000000
E	Emission Rate (lbs/hr)	0.0005	0.0005	0.0003	<b>0.0005</b>

**2-3 RESULTS**

---

**VISIBLE EMISSIONS - OPACITY**

*LMS Stack*  
Table 2-3

<b>Run No.</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>Average</b>
<b>Date</b>	November 20, 2003	November 21, 2003	November 21, 2003	
<b>Start Time (approx)</b>	11:23	08:50	16:38	
<b>Stop Time (approx)</b>	12:23	09:50	17:38	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	<b>0.0 %</b>

*Roof Monitors*

<b>Run No.</b>	<b>1</b>	<b>2</b>	<b>3</b>	<b>Average</b>
<b>Date</b>	November 20, 2003	November 21, 2003	November 21, 2003	
<b>Start Time (approx)</b>	11:23	08:50	16:38	
<b>Stop Time (approx)</b>	12:23	09:50	17:38	
<b>Visible Emissions</b>				
Opacity (EPA RM 9)	0.0	0.0	0.0	<b>0.0 %</b>

### **3-1 PROCESS DESCRIPTION**

---

Nucor Steel of Crawfordsville, Indiana operates the units listed below:

A Strip Caster Line rated at a maximum steel production rate of 135 tons per hour from the existing electric arc furnace (EAF) and is capable of producing several grades of steel at various widths and thicknesses:

1. One (1) ladle metallurgy station (LMS) identified as LMS-2. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
2. One (1) tundish that feeds the molten metal from the LMS ladle to one (1) continuous strip caster. Particulate emissions are controlled by the LMS baghouse with the remaining emissions exhausted through the roof monitor. The LMS stack and roof monitor are identified as S-20 and S-21, respectively.
3. One (1) hot rolling stand. The stand rolls the steel strips from the continuous strip caster to a desired gauge.
4. Two (2) coilers. After the strip passes the rolling mill it is then rolled into coils.

The testing reported in this document was performed at the LMS baghouse stack, with additional visible emissions read at the roof monitor.

## 4-1 METHODOLOGY

---

The sampling procedures utilized by Air Test Professionals, Inc. were as follows:

### Title 40 CFR Part 60 Appendix A

Method 1	“Sampling of Velocity Traverses for Stationary Sources”
Method 2	“Determining of Stack Gas Velocity and Volumetric Flow Rate”
Method 3	“Determination of Oxygen and Carbon Dioxide Percentages”
Method 4	“Determination of Moisture Content in Stack Gas”
Method 5	“Determination of Particulate Emissions from Stationary Sources”
Method 6C	“Determination of Sulfur Dioxide Emissions from Stationary Sources”
Method 7E	“Determination of Nitrogen Oxide Emissions from Stationary Sources”
Method 10	“Determination of Carbon Monoxide from Stationary Sources”
Method 12	“Determination of Lead Emissions from Stationary Sources”
Method 9	“Visual Determination of the Opacity from Stationary Sources”

### Title 40 CFR Part 51 Appendix M

Method 202	“Determination of Condensable Particulate Emissions from Stationary Sources”
------------	--

---

## SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

**Sampling Points**  
Table 4-1

<b>Location</b>	<b>Dimensions</b>	<b>Points / Port</b>	<b>Total Points</b>
LMS Baghouse Stack	96.0” ID	6	24

---

## **4-2 METHODOLOGY**

---

### **SAMPLE AND VELOCITY TRAVERSE – EPA METHOD 1**

Method 1 was utilized for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction, is selected and divided into a sample grid according to the published percentages of the diameter. A traverse point is then located at each of these percentage points. Sampling or velocity measurement is performed at a site located at least two stack or duct diameters downstream and one-half diameter upstream from a disturbance such as a bend, expansion, contraction, or visible flame.

### **VELOCITY AND VOLUMETRIC FLOW RATE – EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at the stack. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

### **GAS COMPOSITION AND MOLECULAR WEIGHT – EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using a Fyrite analyzer. The results were used to determine gas molecular weight.

### **MOISTURE CONTENT – EPA METHOD 4**

The gas moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorption. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

### **PARTICULATE/CONDENSIBLE DETERMINATION – EPA METHOD 5/202**

Stack gas is withdrawn isokinetically and particulate matter is collected on the nozzle, probe and filter. Condensible particulate is captured in the first three impingers; each impinger contains 100 mls of deionized water. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The probe and filter temperatures are maintained at temperatures of 248 degrees F (+/- 25 deg F). The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit.

The nozzle, probe liner and glass filter holder are rinsed with acetone and captured in a sealed glass container. The impingers and connecting glassware are rinsed twice with deionized water and captured in a sealed container. Two rinses of methylene chloride were captured and stored in a sealed container.

### **SULFUR DIOXIDE CONCENTRATION – EPA METHOD 6C**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a NDIR or fluorescence analyzer for SO<sub>2</sub> concentration determination. The wet stack gas is “dried” before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

### **NITROGEN OXIDE CONCENTRATION – EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NO<sub>x</sub> concentration determination. The wet stack gas is “dried” before analysis by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument as well as run system bias and drift checks.

## **4-2 METHODOLOGY, cont.**

---

### **CARBON MONOXIDE CONCENTRATION – EPA METHOD 10**

A continuous gas sample is drawn from the stack and a portion of the sample is conveyed to an NDIR analyzer for carbon monoxide concentration determination. The wet stack gas is “dried” before analysis by a chilled condenser. EPA protocol gases are used to calibrate the instrument as well as run system bias and drift checks.

### **LEAD EMISSIONS DETERMINATION – EPA METHOD 12**

Stack gas is withdrawn isokinetically and lead particulate matter is collected on the nozzle, probe and filter. Lead particulate matter is also captured in the first two impingers; each impinger contains 100 mls of 0.1 N Nitric Acid. A fourth and final impinger contains an amount of approximately 200 grams of silica gel. The probe and filter temperatures are maintained at temperatures of 248 degrees F(+/- 25 deg F). The impinger temperature exit gas is maintained at or below 68 degrees Fahrenheit. The probe, nozzle, filter holder, impingers, and connecting glassware are rinsed with approximately 100 mls of 0.1 N nitric acid and collected in a sealed container.

### **VISIBLE EMISSIONS – EPA METHOD 9**

Stack opacity readings were taken for 60-minutes at 15-second intervals by a certified visible emissions reader. The visible emissions readings were conducted during each of the particulate test runs at both the LMS baghouse stack and the LMS Roof Monitors. The results are reported as an average emissions percentage for each hour period. A copy of the visible emissions certification card is included in Appendix G.

Meltshop Baghouse #1 testing for Emissions:

Test Date: 11/28/1995

Production Rate: Accurate data not readily available.

The process and air pollution control equipment were operating normally at the time of testing.

# RAMCON

ENVIRONMENTAL CORPORATION

January 3, 1996

Mr. Dave Sulc  
Nucor Steel  
RR 2, Box 311  
Crawfordsville, Indiana 47933

RE: Source Sampling — Acid Regeneration Unit and EAF Baghouse

Dear Mr. Sulc:

Enclosed you will find four (4) copies of our report on the particulate and hydrogen chloride emissions testing conducted at your facility located in Crawfordsville, Indiana.

You will want to sign the report covers and send two copies to:

Mr. Ed Surla  
Indiana Air Pollution Control  
Department of Environmental Management  
105 South Meridian Street  
P. O. Box 6015  
Indianapolis, Indiana 46206

You will need to keep one copy of the report at the plant.

We certainly have enjoyed working with you. Please let us know if we can be of further assistance.

Sincerely;

  
Raymond R. Jenkins  
Director Source Sampling

RRJ:wpc  
Enclosures

RAMCON BUILDING  
6707 FLETCHER CREEK COVE  
MEMPHIS, TENNESSEE 38133  
TELEPHONE: 800/458-4567  
IN TENNESSEE: 901/387-0500  
FAX: 901-387-0400

GULF COAST DIVISION  
1920 TREBLE DRIVE A-1  
HUMBLE, TEXAS 77347  
TELEPHONE: 713/319-4183  
FAX: 713/319-4185

## TABLE OF CONTENTS

	<u>Page</u>
I. INTRODUCTION .....	1
II. TEST RESULTS .....	2
Table A — Acid Regeneration Unit, Particulate and HCl Test Summary .....	2
Table B — EAF Baghouse, Particulate Matter Test Summary .....	2
III. TEST PROCEDURES .....	3
A. Determination of Hydrogen Chloride Emissions From Stationary Sources - US EPA Method 26A .....	3
B. Determination of Particulate Matter Emissions from Positive Pressure Fabric Filters — US EPA Reference Methods 5D .....	5
IV. SOURCE DESCRIPTION .....	8
A. Acid Regeneration Unit .....	8
B. EAF Baghouse .....	9
V. RAMCON PERSONNEL .....	10

APPENDIX A — Equipment Used

APPENDIX B — Laboratory Analysis and Results

APPENDIX C — Calculations

1. Acid Regeneration Unit, Particulate and HCl
2. EAF Baghouse, Particulate and Flow Determination

APPENDIX D — Field Data

1. Acid Regeneration Unit
2. EAF Baghouse
3. Visible Emissions
  - (a) Acid Regeneration Unit
  - (b) E.A.F. Baghouse
4. Plant Operation

APPENDIX E — Calibration Data

## I. INTRODUCTION

On November 28-29, 1995 personnel from RAMCON Environmental Corporation conducted air emissions testing at Nucor Steel located in Crawfordsville, Indiana. The scope of work involved testing the acid regeneration unit for particulate matter and hydrogen chloride. The EAF baghouse was subject to sampling for particulate matter.

The particulate matter emissions from the EAF baghouse were sampled according to Reference Method 5D. This procedure sets forth a strategy whereby the velocities at the sampling location are calculated from volumetric flow values determined at the inlet duct to the baghouse process.

The particulate matter and hydrogen chloride emissions from the acid regeneration unit were sampled according to US EPA Reference Method 26A requirements. The stack gas moisture, velocity, and volumetric flow rates were also determined during this isokinetic sampling procedure. This data enabled conversion of flue gas pollutant concentrations to emission data values in pounds per hour (lb/hr).

The purpose of the testing project was to determine if the targeted pollutant emissions are equal to or below the allowable limitation set forth by the State of Indiana EPA in the facility's operating permit. Steve Friend, representing the State of Indiana, was present during the testing procedure(s) conducted by RAMCON Environmental Corporation. The test results and supporting calculations are provided in the following sections.

## II. TEST RESULTS

The test results are summarized in Tables A and B. Each summary table lists the test results in concentration and emission levels for each target pollutant. The concentrations are reported in terms of grains per dry standard cubic foot (gr/dscf). The emission levels are reported in terms of pounds per hour (lb/hr).

**Table A — Acid Regeneration Unit  
Particulate and HCl Test Summary  
November 29, 1995**

Run	Time	Particulate			Hydrogen Chloride	
		gr/dscf	lb/hr	Isokinetics	gr/dscf	lb/hr
1	18:05 - 19:07	0.0498	1.16	102.0	0.0290	0.67
2	19:36 - 20:40	0.0878	2.04	99.7	0.0351	0.81
3	21:05 - 22:08	0.0267	0.61	103.3	0.0537	1.22
Average:		0.0548	1.27		0.0393	0.90
Allowable:			2.00	Source is in compliance.		

**Table B — EAF Baghouse  
Particulate Matter Test Summary  
November 28, 1995**

Run	Time	gr/dscf	lb/hr	Isokinetics
1	12:39 - 17:02	0.0019	16.92	89.4
2	13:06 - 17:09	0.0016	14.20	88.8
3	17:51 - 21:56	0.0015	13.34	89.0
Average:		0.0017	14.82	
Allowable:		0.0018	Source is in compliance‡.	

‡The isokinetics on this source were determined to be fractionally below the  $\pm 10\%$  established by EPA. Since low isokinetics bias the test results high and the facility is below the 0.0018 gr/dscf allowable, RAMCON Environmental recommends the test to be accepted.

### III. TEST PROCEDURES

The following is a description of each of the test method(s) that were conducted during the project. In this description, a discussion of the pertinent segments including preparation, sampling, and analysis is addressed. This section will provide information supporting the validity of the samples.

A. Determination of Hydrogen Halide and Halogen Emissions From Stationary Sources — US EPA Method 26A.

This procedure is applicable for the collection of hydrogen halides and halogens in stack gas emission samples. This method collects the sample isokinetically and is, therefore, particularly suited for sampling at sources emitting acidic particulate matter.

This test procedure may also be coupled with the particulate matter determination at the sampling location. Two test components involved in the scope of work may be collected simultaneously by one sample train only when neither component sample results will be altered or biased.

1. Preparation:

All glassware components utilized in the sampling train were thoroughly cleaned and dried prior to each test series. The impinger system was assembled using 100 ml of 0.1 N sulfuric acid in the first two impingers. The third impinger contained 100 ml of 0.1 N sodium hydroxide. The fourth impinger contained silica gel. In assembling the sample train, a small amount of silicon grease was placed on the ball joints to ensure adequate sealing.

A glass probe liner and nozzle were utilized for the hydrogen chloride collection train. The probe housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack velocity and temperature, respectively.

A quartz filter was utilized for the collection of particulate matter in the front-half of the sampling train. A teflon frit was utilized to support the quartz filter in the filter holder assembly. This configuration meets the specific requirements of the test procedure.

A leak check was performed prior to each test run. The entire sample train system was subjected to a vacuum which did not exceed 0.02 cfm leakage rate. The vacuum established during the pre-test leak check was not exceeded during the test period.

## 2. Sampling:

The probe and sample box were heated to an approximate temperature of 250°F. These temperatures were recorded for the duration of the testing to prevent moisture condensation and associated HCl/Cl<sub>2</sub> losses. An ice bath was utilized to condense the water vapor from the sample gas stream. The temperature of the last impinger was recorded throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

Three sample runs were conducted to constitute a complete test. The sampling time was conducted over a period of two (2) hours. When a test run had been completed, a post-test leak check was conducted. Once this had been successfully achieved, the sample train was dismantled for sample recovery. The contents of the impingers were volumetrically measured for moisture gain and transferred to a labeled sample container.

## 3. Sample Recovery:

Sample recovery consisted of rinsing the probe and connecting glassware with acetone. This rinse solution was placed in a labeled sample container. The glass fiber filter was carefully removed and transferred to its original petri dish.

The 0.1 N H<sub>2</sub>SO<sub>4</sub> absorbent solution contained in impingers 1 and 2 were placed into a labeled sample container(s). These impingers were then rinsed with D.I. water. The impinger solution and impinger rinse were combined into the same container(s).

The 0.1 N NaOH solution from impingers 3 and 4 was placed into a separately labeled sample container. The impingers were also rinsed with D.I. water. The rinsings again were placed into the sample container with the respective impinger catch.

4. Analysis:

The absorbent solutions utilized in the collection of the pollutant(s) will be analyzed by ion chromatography. The sulfuric acid solution is used to capture the hydrogen chloride and the sodium hydroxide solution collects the chlorine.

A sample field blank of the absorption solutions were collected, contained, labeled and analyzed in conjunction with the samples.

B. Determination of Particulate Matter Emissions from Positive Pressure Fabric Filters — US EPA Reference Methods 5D.

This method applies to the determination of particulate matter emissions from positive pressure fabric filters. Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter.

1. Preparation:

All glassware utilized in each sampling train was thoroughly cleaned and dried prior to each test series. A glass fiber filter was used that has been labeled, desiccated for a minimum of 24 hours and pre-weighed.

The impinger system was assembled using the modified Greenburg-Smith type. One hundred ml of deionized water was placed in the first two impingers. The third impinger was initially empty and the fourth impinger contained a pre-weighed amount of silica gel for complete moisture removal. This impinger train configuration is according to Reference Method 5 for particulate. In assembling the sample train, a small amount of silicon grease was placed on the ball joints to ensure adequate sealing.

A stainless steel probe liner and nozzle system is typically utilized for the particulate determinations at the sampling location. The probe system housed a set of calibrated S-type pitot tubes and a calibrated thermocouple for monitoring stack velocity and temperature.

## 2. Sampling:

The probe and sample box was heated to an approximate temperature of 250°F. These temperatures were monitored throughout the testing. An ice bath was prepared to submerge the impinger system into. The temperature of the last impinger was also monitored throughout the testing to ensure adequate condensation of the water vapor in the flue gases.

A leak check was performed prior to each test run. The entire sample train system was subjected to a vacuum that did not exceed 0.02 cfm leakage rate. The vacuum that is established during the pre-test leak check was not exceeded during the test period.

The variation of Reference Method 5 versus 5D is comprised of taking the velocity readings at an inlet location for the 5D versus at each sampling traverse point via Method 5. Therefore velocity traverses were taken at the inlet duct(s) to the baghouse process. This data is utilized for the purpose of determining the volumetric flow rate of air through the baghouse. This value is utilized to determine the average velocity at each respective sampling location or compartment. With the average velocity through each compartment known, the test can then be performed according to Method 5 for sample nozzle selection and isokinetic sampling procedures.

Three sample runs were conducted to constitute a complete test of the baghouse process. Each test run consisted of sampling four (4) compartments in the baghouse. The sampling runs were conducted over a period of four hours each and at least 160 scf of stack gas was extracted via the sampling system.

When a test run has been completed, a post-test leak check was conducted prior to any dismantling of the sampling train. Once this has been successfully achieved, the sample train was dismantled for sample recovery.

The probe and connecting glassware was washed with acetone. The contents of the impingers was volumetrically measured for moisture gain and transferred to a labeled sample container. The glass fiber filter was carefully transferred to its sample container.

### 3. Analysis:

The glass fiber filter was desiccated for 24 hours prior to any weighing. The acetone probe wash was transferred to a tared beaker and evaporated to dryness. The resultant residue was also desiccated prior to gravimetric analysis.

The first weighing was performed after this initial period of drying. The weights were recorded to 0.0001 g. After a minimum of six additional hours of desiccating, a second weighing was conducted. The weights must agree within 0.0005 g or further desiccation must be conducted until the weights stabilize.

Sample field blanks of acetone were collected, contained, labeled and analyzed in conjunction with the samples. The blank weight was deducted from the acetone probe wash residue weight determinations.

# RAMCON

ENVIRONMENTAL CORPORATION

January 26, 1996

Mr. Dave Sulc  
NUCOR STEEL  
RR 2, Box 311  
Crawfordsville, Indiana 47933


RE: EAF Baghouse — Metals Analysis

Dear Mr. Sulc:

Attached are the results and supporting data for the multi-metals sampling recently conducted on the above-referenced source at your facility.

If I can be of further assistance, please do not hesitate to contact me.

Sincerely,



Raymond R. Jenkins  
Director Source Sampling

RRJ:wpc  
Attachments

TEST DATE  
11-28-95

Nucor Steel - Crawfordsville, Indiana  
Metals Analysis

	Run 1 Results mg	Run 2 Results mg	Run 3 Results mg
Antimony	<0.02	<0.02	<0.02
Arsenic	<0.02	<0.02	<0.02
Barium	0.29	0.30	0.12
Beryllium	<0.00006	<0.00006	<0.00006
Cadmium	<0.0004	<0.0004	<0.0004
Chromium	0.004	0.010	0.007
Cobalt	<0.002	<0.002	<0.002
Copper	0.0017	0.0019	<0.001
Lead	<0.01	<0.01	<0.01
Manganese	0.0095	0.0170	0.0110
Nickel	<0.003	0.0056	<0.003
Phosphorus	<0.01	<0.01	<0.01
Selenium	<0.02	<0.02	<0.02
Silver	<0.0007	<0.0007	<0.0007
Thallium	<0.03	<0.03	<0.03
Zinc	0.13	0.21	0.14

	Results gr/dscf	Results gr/dscf	Results gr/dscf
	BDL	BDL	BDL
	BDL	BDL	BDL
	2.597E-05	2.755E-05	1.069E-05
	BDL	BDL	BDL
	BDL	BDL	BDL
	3.223E-07	9.183E-07	6.238E-07
	BDL	BDL	BDL
	1.522E-07	1.745E-07	BDL
	BDL	BDL	BDL
	8.506E-07	1.561E-06	9.803E-07
	BDL	5.143E-07	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	1.164E-05	1.929E-05	1.248E-05

	Results lb/hr	Results lb/hr	Results lb/hr
	BDL	BDL	BDL
	BDL	BDL	BDL
	2.31E-01	2.45E-01	9.52E-02
	BDL	BDL	BDL
	BDL	BDL	BDL
	2.87E-03	8.18E-03	5.55E-03
	BDL	BDL	BDL
	1.36E-03	1.55E-03	BDL
	BDL	BDL	BDL
	7.57E-03	1.39E-02	8.72E-03
	BDL	4.58E-03	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	BDL	BDL	BDL
	1.04E-01	1.72E-01	1.11E-01

< = detection limit, results will be Below Detection Limit

## **Laboratory Analysis**


REPORT

Ramcon Environmental Corporation  
6707 Fletcher Creek Cove  
Memphis, TN 38134

January 16, 1996  
Control No. 17199  
Page 1 of 2

ATTN: Mr. Sumner Buck

Project Description: Three (3) thimble received on January 11, 1996  
NUCOR-Crawfordsville  
BAGHOUSE  
P.O. No. 081882



Sample Identification: LM01018 1.8318 RUN 1  
AIC No. 17199-1

Parameter	Method	Result	Batch	Time Analyzed By
Antimony	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Arsenic	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Barium	NIOSH 7300	0.29 mg	S4645	15JAN96 0913 65/155
Beryllium	NIOSH 7300	<0.00006 mg	S4645	15JAN96 0913 65/155
Cadmium	NIOSH 7300	<0.0004 mg	S4645	15JAN96 0913 65/155
Chromium	NIOSH 7300	0.0036 mg	S4645	15JAN96 0913 65/155
Cobalt	NIOSH 7300	<0.002 mg	S4645	15JAN96 0913 65/155
Copper	NIOSH 7300	0.0017 mg	S4645	15JAN96 0913 65/155
Lead	NIOSH 7300	<0.01 mg	S4645	15JAN96 0913 65/155
Manganese	NIOSH 7300	0.0095 mg	S4645	15JAN96 0913 65/155
Nickel	NIOSH 7300	<0.003 mg	S4645	15JAN96 0913 65/155
Phosphorus	ICP-AES	<0.01 mg	S4645	15JAN96 0913 65/155
Selenium	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Silver	NIOSH 7300	<0.0007 mg	S4645	15JAN96 0913 65/155
Thallium	NIOSH 7300	<0.03 mg	S4645	15JAN96 0913 65/155
Zinc	NIOSH 7300	0.13 mg	S4645	15JAN96 0913 65/155

Sample Identification: LM01039 2.2986 RUN 2  
AIC No. 17199-2

Parameter	Method	Result	Batch	Time Analyzed By
Antimony	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Arsenic	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Barium	NIOSH 7300	0.30 mg	S4645	15JAN96 0913 65/155
Beryllium	NIOSH 7300	<0.00006 mg	S4645	15JAN96 0913 65/155
Cadmium	NIOSH 7300	<0.0004 mg	S4645	15JAN96 0913 65/155
Chromium	NIOSH 7300	0.010 mg	S4645	15JAN96 0913 65/155
Cobalt	NIOSH 7300	<0.002 mg	S4645	15JAN96 0913 65/155
Copper	NIOSH 7300	0.0019 mg	S4645	15JAN96 0913 65/155
Lead	NIOSH 7300	<0.01 mg	S4645	15JAN96 0913 65/155
Manganese	NIOSH 7300	0.017 mg	S4645	15JAN96 0913 65/155
Nickel	NIOSH 7300	0.0056 mg	S4645	15JAN96 0913 65/155
Phosphorus	ICP-AES	<0.01 mg	S4645	15JAN96 0913 65/155
Selenium	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913 65/155
Silver	NIOSH 7300	<0.0007 mg	S4645	15JAN96 0913 65/155
Thallium	NIOSH 7300	<0.03 mg	S4645	15JAN96 0913 65/155
Zinc	NIOSH 7300	0.21 mg	S4645	15JAN96 0913 65/155

R E P O R T

Ramcon Environmental Corporation  
6707 Fletcher Creek Cove  
Memphis, TN 38134

January 16, 1996  
Control No. 17199  
Page 2 of 2

Project Description: Three (3) thimble received on January 11, 1996  
NUCOR-Crawfordsville  
BAGHOUSE  
P.O. No. 081882

Sample Identification: LM01029 1.8154 RUN 3  
AIC No. 17199-3

Parameter	Method	Result	Batch	Time Analyzed	By
Antimony	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913	65/155
Arsenic	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913	65/155
Barium	NIOSH 7300	0.12 mg	S4645	15JAN96 0913	65/155
Beryllium	NIOSH 7300	<0.00006 mg	S4645	15JAN96 0913	65/155
Cadmium	NIOSH 7300	<0.0004 mg	S4645	15JAN96 0913	65/155
Chromium	NIOSH 7300	0.0070 mg	S4645	15JAN96 0913	65/155
Cobalt	NIOSH 7300	<0.002 mg	S4645	15JAN96 0913	65/155
Copper	NIOSH 7300	<0.001 mg	S4645	15JAN96 0913	65/155
Lead	NIOSH 7300	<0.01 mg	S4645	15JAN96 0913	65/155
Manganese	NIOSH 7300	0.011 mg	S4645	15JAN96 0913	65/155
Nickel	NIOSH 7300	<0.003 mg	S4645	15JAN96 0913	65/155
Phosphorus	ICP-AES	<0.01 mg	S4645	15JAN96 0913	65/155
Selenium	NIOSH 7300	<0.02 mg	S4645	15JAN96 0913	65/155
Silver	NIOSH 7300	<0.0007 mg	S4645	15JAN96 0913	65/155
Thallium	NIOSH 7300	<0.03 mg	S4645	15JAN96 0913	65/155
Zinc	NIOSH 7300	0.14 mg	S4645	15JAN96 0913	65/155

AMERICAN INTERPLEX CORPORATION

By Steven Lovell

Steven Lovell  
Technical Director

KW/lms

Enclosure: Analysis Protocol

17199

RAMCON ENVIRONMENTAL CORPORATION  
ANALYSIS PROTOCOL

P.O.# 081882 Per Quotation 2605

I. Sample Labeling Information

Plant: NUCOR - CRAWFORDVILLE Source(s): BALDHOUSE

Date of Testing 11-28-95

II. Sample Quantity / Types(s):

Filter(s):	Quantity: <u>3</u>	Description <u>THIMBLE (GLASS FIBER)</u>
Probe Wash(s):	Quantity: <u>      </u>	Description <u>      </u>
Back Half(s):	Quantity: <u>      </u>	Description <u>      </u>
<u>      </u> :	Quantity: <u>      </u>	Description <u>      </u>

III. Analysis Description:

<u>Sample Type</u>	<u>Analysis Description</u>	<u>Method Used</u>
<u>FILTER</u>	<u>MULTI METALS</u>	<u>29</u>

IV. Special Instructions:

FAX RESULTS ASAP.

14.11  
14.12  
14.13

**Supreme  
Environmental Service Company**

*SESCo Group*

1426 West 29<sup>th</sup> Street Indianapolis, Indiana 46208

(317)347-9590 FAX (317)347-9591

---

**REPORT on  
NO<sub>x</sub> and CO EMISSIONS**  
Performed for:  
***Nucor Steel***  
*Crawfordsville, IN*  
***Annealing Furnace #9***  
on ***08/24/01***

**RECEIVED**  
OCT 05 2001  
State Of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Report fully Submitted by:



Michael Dicen, Division Manager

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4190

## **1-1 PROJECT OVERVIEW**

---

SESCO Group was contracted by Nucor Steel located in Crawfordsville, Indiana to perform compliance test air sampling of Annealing furnace #9 on August 24, 2001. The objective of the testing was to determine NOx and CO emissions. The following personnel were involved with the testing program:

SESCO	Andrew Young
SESCO	Milo Hatfield
SESCO	Michael Dicen
SESCO	Carlos Brown
Nucor Steel	David Sulc
IDEM	Jed Wolkins

The testing program included flow determination, nitrogen oxide (Method 7E), and carbon monoxide (Method 10). Below is a summary of the results:

*Table 1-1:  
Summary of Test Results*

<b>Pollutant</b>	<b>Time 08/24/01</b>	<b>Emission (PPM)</b>	<b>Emission (lbs/hr)</b>	<b>Emission (lbs/MMbtu)</b>
<b>NOx</b>	09:02-10:06	46.43	0.2369	0.0801
<b>NOx</b>	10:16-11:16	52.23	0.2068	0.1081
<b>NOx</b>	11:25-12:25	47.75	0.1730	0.0912
	<b>Averages</b>	<b>48.80</b>	<b>0.2055</b>	<b>0.0931</b>

<b>CO</b>	09:02-10:06	2.60	0.0081	0.0027
<b>CO</b>	10:16-11:16	1.20	0.0029	0.0015
<b>CO</b>	11:25-12:25	2.60	0.0057	0.0030
	<b>Averages</b>	<b>2.13</b>	<b>0.0056</b>	<b>0.0024</b>

*SESCO Group*

**2-1 RESULTS**

*Table 2-1:  
Annealing Furnace #9 Emissions*

<u>Gas Conditions</u>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Average</b>
Ts	Stack Temperature ("F)	720.62	670.63	637.38	676.21
lBwo	Moisture (volume %)	17.20	16.14	17.59	16.98
β2	Oxygen (dry volume %)	10.2	11.1	9.8	10.4
C02	Carbon Dioxide (dry volume %)	7.2	6.0	6.5	6.6
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1912.53	1403.41	1268.42	1528.12
Qstd	Standard Conditions (dscfm)	712.09	552.60	505.72	590.14
<b>NITROGEN OXIDES</b>					
Er	Emission Rate (PPM)	46.43	52.23	47.75	48.80
Er	Emission Rate (lbs/hr)	0.2369	0.2068	0.1730	0.2055
Er	Emission (lbs/MMbtu)	0.0801	0.1081	0.0912	0.0931
<b>CARBON MONOXIDE</b>					
Er	Emission Rate (PPM)	2.60	1.20	2.60	2.13
Er	Emission Rate (lbs/hr)	0.0081	0.0029	0.0057	0.0056
Er	Emission (lbs/MMbtu)	0.0027	0.0015	0.0030	0.0024

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4190

### **3-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 7E, 10. The following table summarizes the methods:

#### **Summary of Sampling Procedures**

---

Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide Emissions from Stationary Sources"

---

#### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

*Table 3-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Ports</b>	<b>Points per Port</b>	<b>Total Points</b>
Annealing Furnace	13" ID	2	8	16

---

***SESCO Group***

**Supreme  
Environmental Service Company**

**SESCo Group**

1426 West 29" Street Indianapolis, Indiana 46208

(317)347-9590 FAX (317)347-9591

---

**REPORT on  
NO<sub>x</sub> and CO EMISSIONS**  
Performed for:  
**Nucor Steel**  
**Crawfordsville, IN**  
**Annealing Furnace #13**  
on 08/24/01

**RECEIVED**  
OCT 05 2001  
State Of Indiana  
Department of Environmental Management  
Office of Air-Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

  
Michael Dicerl, Division Manager

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4191

## **1-1 PROJECT OVERVIEW**

---

SESCO Group was contracted by Nucor Steel in Crawfordsville, Indiana to perform compliance test air sampling of Annealing furnace #13 on August 24, 2001. The objective of the testing was to determine NO<sub>x</sub> and CO emissions. The following personnel were involved with the testing program:

SESCO	Andrew Young
SESCO	Milo Hatfield
SESCO	Michael Dicen
SESCO	Carlos Brown
Nucor Steel	David Sulc
IDEM	Jed Wolkins

The testing program included flow determination, nitrogen oxide (Method 7E), and carbon monoxide (Method 10). Below is a summary of the results:

*Table 1-1:  
Summary of Test Results*

<b>Pollutant</b>	<b>Time 08/24/01</b>	<b>Emission (PPM)</b>	<b>Emission (lbs/hr)</b>	<b>Emission (lbs/MMbtu)</b>
<b>NO<sub>x</sub></b>	09:41-10:41	34.06	0.1164	0.0605
<b>NO<sub>x</sub></b>	10:53-11:53	47.07	0.1954	0.0573
<b>NO<sub>x</sub></b>	14:02-15:02	44.61	0.1903	0.0707
	<b>Averages</b>	<b>41.91</b>	<b>0.1674</b>	<b>0.0628</b>

<b>CO</b>	09:41-10:41	0.9	0.0019	0.0010
<b>CO</b>	10:53-11:53	0.2	0.0005	0.0001
<b>CO</b>	14:02-15:02	0.8	0.0021	0.0008
	<b>Averages</b>	<b>0.63</b>	<b>0.0015</b>	<b>0.0006</b>

*SESCO Group*

**2-1 RESULTS**

*Table 2-1:  
Annealing Furnace Emissions*

<u>Gas Conditions</u>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature ("F)	673.94	730.56	723.31	709.27
Bwo	Moisture (volume %)	15.10	17.73	14.83	15.89
O2	Oxygen (dry volume %)	8.6	5.6	6.9	7.0
C02	Carbon Dioxide (dry volume %)	7.0	10.2	7.84	8.34
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	1201.03	1579.75	1558.44	1446.41
Qstd	Standard Conditions (dscfm)	477.23	579.42	595.37	550.67
<b>NITROGEN OXIDES</b>					
Er	Emission Rate (PPM)	34.06	47.07	44.61	<b>41.91</b>
Er	Emission Rate (lbs/hr)	0.1164	0.1954	0.1903	<b>0.1674</b>
Er	Emission (lbs/MMbtu)	0.0605	0.0573	0.0707	<b>0.0628</b>
<b>CARBON MONOXIDE</b>					
Er	Emission Rate (PPM)	0.90	0.20	0.80	<b>0.63</b>
Er	Emission Rate (lbsh)	0.0019	0.0005	0.0021	<b>0.0015</b>
Er	Emission (lbs/MMbtu)	0.0010	0.0001	0.0008	<b>0.0006</b>

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4191

### **3-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 7E, 10. The following table summarizes the methods:

#### **Summary of Sampling Procedures**

---

Title 40 CFR Part 60 Appendix A

Method 1 "Sampling of Velocity Traverses for Stationary Sources"  
Method 2 "Determination of Stack Gas Velocity and Volumetric Flow Rate"  
Method 3 "Gas Analysis for the Determination of Molecular Weight"  
Method 4 "Determination of Moisture Content in Stack Gas"  
Method 7E "Determination of Nitrogen Oxide Emissions from Stationary Sources"  
Method 10 "Determination of Carbon Monoxide Emissions from Stationary Sources"

---

#### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

*Table 3-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Ports</b>	<b>Points per Port</b>	<b>Total Points</b>
Annealing Furnace	13" ID	2	8	16

---

***SESCO Group***

**Supreme  
Environmental Service Company**

SESCo Group

1426 West 29<sup>th</sup> Street Indianapolis, Indiana 46208

(317)347-9590 FAX (317)347-9591

---

**REPORT on  
NO<sub>x</sub> and CO EMISSIONS**  
Performed for:  
**Nucor Steel**  
**Crawfordsville, IN**  
**Annealing Furnace #15**  
on 08/23/01

**RECEIVED**  
OCT 05 2001  
State Of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:



Michael Dicen, Division Manager

## **1-1 PROJECT OVERVIEW**

---

SESCO Group was contracted by Nucor Steel in Crawfordsville, Indiana to perform compliance test air sampling of Annealing furnace #15 on August 23, 2001. The objective of the testing was to determine NOx and CO emissions. The following personnel were involved with the testing program:

SESCO	Andrew Young
SESCO	Milo Hatfield
Nucor Steel	David Sulc
IDEM	Jed Wolkins

The testing program included flow determination, nitrogen oxide (Method 7E), and carbon monoxide (Method 10). Below is a summary of the results:

*Table 1-1:  
Summary of Test Results*

<b>Pollutant</b>	<b>Time 08/23/01</b>	<b>Emission (PPM)</b>	<b>Emission (lbs/hr)</b>	<b>Emission (lbs/MMbtu)</b>
<b>NOx</b>	09:41-10:41	52.76	0.3202	0.0936
<b>NOx</b>	10:53-11:53	55.33	0.2310	0.0982
<b>NOx</b>	14:02-15:02	47.58	0.1174	0.0788
	<b>Averages</b>	<b>51.89</b>	<b>0.2229</b>	<b>0.0902</b>

<b>CO</b>	09:41-10:41	0.60	0.0022	0.0006
<b>CO</b>	10:53-11:53	0.50	0.0013	0.0005
<b>CO</b>	14:02-15:02	1.00	0.0015	0.0010
	<b>Averages</b>	<b>0.70</b>	<b>0.0017</b>	<b>0.0007</b>

**2-1 RESULTS**

*Table 2-1:  
Annealing Furnace Emissions*

<u>Gas Conditions</u>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature (°F)	718.50	707.81	560.63	662.31
Bwo	Moisture (volume %)	14.30	15.07	14.60	14.66
O2	Oxygen (dry volume %)	8.5	8.5	8.5	8.5
CO2	Carbon Dioxide (dry volume %)	7.0	7.0	7.5	7.2
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	2191.55	1507.71	774.59	1491.28
Qstd	Standard Conditions (dscfin)	847.07	582.88	344.54	591.50
<b>NITROGEN OXIDES</b>					
Er	Emission Rate (PPM)	52.76	55.33	47.58	<b>51.89</b>
Er	Emission Rate (lbs/hr)	0.3202	0.2310	0.1174	<b>0.2229</b>
Er	Emission (lbs/MMbtu)	0.0936	0.0982	0.0788	<b>0.0902</b>
<b>CARBON MONOXIDE</b>					
Er	Emission Rate (PPM)	0.60	0.50	1.00	<b>0.70</b>
Er	Emission Rate (lbs/hr)	0.0022	0.0013	0.0015	<b>0.0017</b>
Er	Emission (lbs/MMbtu)	0.0006	0.0005	0.0010	<b>0.0007</b>

### 3-1 METHODOLOGY

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 7E, 10. The following table summarizes the methods:

#### Summary of Sampling Procedures

---

Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide Emissions from Stationary Sources"

---

#### SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1

*Table 3-1:  
Sampling Points*

Location	Dimensions	Ports	Points per Port	Total Points
Annealing Furnace	13" ID	2	8	16

---

14.14

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
Indianapolis

OFFICE MEMORANDUM

To: Jay Patterson Date: December 17, 2001  
From: Jarrod Fisher JCF Thru: Ed Surla *ES*  
Marie Luce *AML*  
Subject: Nucor Steel  
Crawfordsville, Indiana  
Source ID No. 107-00038  
Permit ID No. SSM 107-12143-00038

The subject company has submitted a report concerning the stack emissions testing at the subject source. The tests were conducted by SESCO Group, Inc. The purpose of the testing was to determine compliance status of the batch annealing furnaces with regards to the emission limitations stated below. The protocols were approved by Quentin Flory and Marie Luce and the field tests were observed by Marie Luce and Jed Wolkins. I have reviewed this report and found the sampling procedures used and results to be acceptable to this Office. A copy of the test report is filed in the Compliance Data Section. The following is a summary of the test results:

Annealing Furnace #1

Date of test: June 6, 2001  
Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #1  
Pollution Control Equipment: Natural Gas fired burners use low-NOx technology  
Operating Parameters: N/A  
Pollutants: NOx, CO  
Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr  
CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu  
CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0731	0.0035	3.77
Run 2	0.0837	0.0035	3.61
Run 3	0.0895	0.0029	3.21
Average	0.0821	0.0033	3.53

Annealing Furnace #9

Date of test: August 24, 2001  
Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #9  
Pollution Control Equipment: Natural Gas fired burners use low-NOx technology  
Operating Parameters: N/A  
Pollutants: NOx, CO  
Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr  
CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu  
CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.064 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0800	0.0027	3.85
Run 2	0.1083	0.0015	2.94
Run 3	0.0915	0.0030	2.02
Average	0.0932	0.0024	2.94

Annealing Furnace #13

Date of test: August 24, 2001

Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #13

Pollution Control Equipment: Natural Gas fired burners use low-NOx technology

Operating Parameters: N/A

Pollutants: NOx, CO

Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr

CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu

CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0670	0.0008	4.00
Run 2	0.0636	0.0001	3.67
Run 3	0.0756	0.0008	2.98
Average	0.0687	0.0006	3.55

Annealing Furnace #15

Date of test: August 23, 2001

Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #15

Pollution Control Equipment: Natural Gas fired burners use low-NOx technology

Operating Parameters: N/A

Pollutants: NOx, CO

Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr

CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu

CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0820	0.0006	3.64
Run 2	0.0925	0.0005	3.31
Run 3	0.0793	0.0010	1.79
Average	0.0846	0.0007	2.92

STATUS: In Compliance

Note: There are 18 identical natural gas-fired batch annealing furnaces at Nucor Steel in Crawfordsville. Permit Condition D.6.4 (a) requires Nucor to perform NOx and CO testing on "at least four (4) batch annealing furnaces within 60 days after achieving maximum capacity, but no later than 180 days after initial start-up".

cc: J. Fisher, IDEM  
M. Luce, IDEM  
D. Sekula, IDEM  
M. Stuckey- IDEM office of Enforcement  
WPS/General Files, Montgomery Co.

**Supreme  
Environmental Service Company**

*SESCo Group*

1426 West 29<sup>th</sup> Street Indianapolis, Indiana 46208

(317)347-9590 FAX (317)347-9591

---

**REPORT on  
NO<sub>x</sub> and CO EMISSIONS**

Performed for:

***Nucor Steel  
Crawfordsville, IN  
Annealing Furnace  
on 06/06/01***

**RECEIVED**  
JUL 17 2001  
State Of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

Michael Dicen, Division Manager

### STACK EMISSION SUMMARY

SOURCE TESTED:	Annealing Furnace
COMPANY NAME:	Nucor Steel
DATE OF TEST:	0610612001

	Run 1	Run 2	Run 3	Average
<b>NOx Emissions</b>				
PPM	47.11	53.95	57.69	52.91
lbs/hr	0.3749	0.3500	0.3520	0.3590
lbs/MMbtu	0.0731	0.0837	0.0895	0.0821
<b>CO Emissions</b>				
PPM	3.70	3.70	3.10	3.50
lbs/hr	0.0179	0.0146	0.0115	0.0147
lbs/MMbtu	0.0035	0.0035	0.0029	0.0033
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	2977.13	2457.27	2284.21	2572.87
DSCFM	1111.03	905.65	851.70	956.13
<b>Avg. Stack Temp.</b>	757.50	781.31	754.69	764.50
<b>Stack Gas Velocity</b>	53.83	44.43	41.30	46.52
<b>Avg. Velocity Head</b>	0.3865	0.2589	0.2279	0.2911
<b>Avg. Sq. Rt of Delta P</b>	0.6217	0.5088	0.4774	0.5360
<b>% Moisture of Stack Gas</b>	14.58%	13.99%	14.85%	14.48%
<b>Sample Volume</b>	21.110	21.466	21.555	21.377

**2-1 RESULTS**

**Table 2-1:  
Annealing Furnace Emissions**

<u>Gas Conditions</u>		<b>1</b>	<b>2</b>	<b>3</b>	<b>Avg</b>
Ts	Stack Temperature ("F)	757.50	781.31	754.69	764.50
Bwo	Moisture (volume %)	14.58	13.99	14.85	14.48
O2	Oxygen (dry volume %)	7.0	7.0	7.5	7.2
CO2	Carbon Dioxide (dry volume %)	8.0	8.0	8.0	8.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (a ch)	2977.13	2457.27	2284.21	2572.87
Qstd	Standard Conditions (d sch)	1111.03	905.65	851.70	956.13
<b>NITROGEN OXIDES</b>					
ET	Emission Rate (PPM)	47.11	53.95	57.69	52.91
ET	Emission Rate (lbs/hr)	0.3749	0.3500	0.3520	0.3590
<b>CARBON MONOXIDE</b>					
ET	Emission Rate (PPM)	3.70	3.70	3.10	3.50
ET	Emission Rate (lbs/hr)	0.0179	0.0146	0.0115	0.0147

### **3-1 METHODOLOGY**

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 7E, 10. The following table summarizes the methods:

#### **Summary of Sampling Procedures**

---

Title 40 CFR Part 60 Appendix A

Method 1	"Sampling of Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate"
Method 3	"Gas Analysis for the Determination of Molecular Weight"
Method 4	"Determination of Moisture Content in Stack Gas"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources"
Method 10	"Determination of Carbon Monoxide Emissions from Stationary Sources"

---

#### **SAMPLE POINT DETERMINATION**

Sampling point locations were determined according to EPA Reference Method 1.

*Table 3-1:  
Sampling Points*

---

<b>Location</b>	<b>Dimensions</b>	<b>Ports</b>	<b>Points per Port</b>	<b>Total Points</b>
Annealing Furnace	13" ID	2	8	16

---

### **3-2 METHODOLOGY**

---

#### **SAMPLE AND VELOCITY TRAVERSE - EPA METHOD 1**

Method 1 was used for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction is selected and divided into a equal number of areas. A traverse point is then located within each of these equal areas. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters up stream from any flow disturbance such as a bend, expansion, contraction, or visible flame. If necessary, an alternative location may be selected at a position at least two stack or duct diameters downstream and one half diameter upstream from any flow disturbance.

#### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at both the inlet and outlet locations. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

#### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using an Orsat analyzer. The results were used to determine gas molecular weight.

#### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorbtion. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

#### **NITROGEN OXIDE CONCENTRATION - EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NOx concentration determination. The wet stack gas is "dried," before analysis, by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument, as well as run system checks.

#### **CARBON MONOXIDE CONCENTRATION - EPA METHOD 10**

A continuous gas sample is drawn from the stack and a portion is conveyed to a tedlar bag for carbon monoxide concentration determination at a laboratory. The wet stack gas is "dried," before analysis, by a chilled condenser. EPA protocol 1 gases are used to calibrate the laboratory instrument.

## SECTION D.6 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(15)]

- (f) Eighteen (18) natural gas-fired batch annealing furnaces, utilizing propane as a backup fuel. Each batch annealing furnace shall be equipped with low-NOx burners and shall not exceed a maximum heat input rate of 4.8 MMBtu per hour. These units can handle the product from both the existing continuous caster line and the continuous strip caster line to be installed as described above.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards

#### D.6.1 Nitrogen Oxides (NO<sub>x</sub>) and CO Emission Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements), the eighteen (18) batch annealing furnaces shall comply with the following requirements:

- (a) Each batch annealing furnace shall be equipped with low-NOx burners;
- (b) Each batch annealing furnace shall utilize natural gas as the primary fuel and may utilize propane as a backup fuel;
- (c) The NO<sub>x</sub> emissions from each batch annealing furnace shall not exceed 0.10 pounds per MMBtu; and
- (d) The CO emissions from each batch annealing furnace shall not exceed 0.084 pound per MMBtu.

#### D.6.2 Sulfur Dioxide (SO<sub>2</sub>) Emission Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements), the above-mentioned additional batch annealing furnaces shall utilize natural gas as the primary fuel and may utilize propane as a backup fuel.

### Compliance Determination and Monitoring

#### D.6.4 Performance Testing

- (a) Pursuant to 326 IAC 2-1.1-11 and 326 IAC 2-2, the Permittee shall perform NO<sub>x</sub> and CO compliance stack tests on at least four (4) batch annealing furnaces within 60 days after achieving maximum capacity, but no later than 180 days after initial start-up.
- (b) All compliance stack tests shall be repeated at least annually until such time that the Part 70 permit for this source is in effect.
- (c) IDEM, OAQ retains the authority under 326 IAC 2-1-4(f) to require the Permittee to perform additional and future compliance testing as necessary.

#### D.6.5 Vendor Certification

The Permittee shall submit with the affidavit of construction (Condition B.5(a)) the vendor guarantees for the above-mentioned batch annealing furnaces to demonstrate compliance with