

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

<b>AP32 Section:</b>	<b>12.5.1</b>
<b>Background Chapter</b>	<b>3</b>
<b>Reference:</b>	<b>25</b>
<b>Title:</b>	<b>Report on NOx and CO Emissions. Annealing Furnace. Performed for: Nucor Steel, Crawfordsville, IN. June 6, 2001.</b>

INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT  
Indianapolis

OFFICE MEMORANDUM

To: Jay Patterson Date: December 17, 2001  
 From: Jarrod Fisher JCF Thru: Ed Surla *ES*  
 Marie Luce *ML*  
 Subject: Nucor Steel  
 Crawfordsville, Indiana  
 Source ID No. 107-00038  
 Permit ID No. SSM 107-12143-00038

The subject company has submitted a report concerning the stack emissions testing at the subject source. The tests were conducted by SESCO Group, Inc. The purpose of the testing was to determine compliance status of the batch annealing furnaces with regards to the emission limitations stated below. The protocols were approved by Quentin Flory and Marie Luce and the field tests were observed by Marie Luce and Jed Wolkins. I have reviewed this report and found the sampling procedures used and results to be acceptable to this Office. A copy of the test report is filed in the Compliance Data Section. The following is a summary of the test results:

Annealing Furnace #1

Date of test: June 6, 2001  
 Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #1  
 Pollution Control Equipment: Natural Gas fired burners use low-NOx technology  
 Operating Parameters: N/A  
 Pollutants: NOx, CO  
 Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr  
 CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu  
 CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0731	0.0035	3.77
Run 2	0.0837	0.0035	3.61
Run 3	0.0895	0.0029	3.21
Average	0.0821	0.0033	3.53

Annealing Furnace #9

Date of test: August 24, 2001  
 Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #9  
 Pollution Control Equipment: Natural Gas fired burners use low-NOx technology  
 Operating Parameters: N/A  
 Pollutants: NOx, CO  
 Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr  
 CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu  
 CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0800	0.0027	3.85
Run 2	0.1083	0.0015	2.94
Run 3	0.0915	0.0030	2.02
Average	0.0933	0.0024	2.94

Annealing Furnace #13

Date of test: August 24, 2001

Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #13

Pollution Control Equipment: Natural Gas fired burners use low-NOx technology

Operating Parameters: N/A

Pollutants: NOx, CO

Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr

CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu

CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0670	0.0008	4.00
Run 2	0.0636	0.0001	3.67
Run 3	0.0756	0.0008	2.98
Average	0.0687	0.0006	3.55

Annealing Furnace #15

Date of test: August 23, 2001

Identification and Unit No. of Facilities Tested: Batch Annealing Furnace #15

Pollution Control Equipment: Natural Gas fired burners use low-NOx technology

Operating Parameters: N/A

Pollutants: NOx, CO

Test methods: 1-4, 7E, 10

Maximum Rated Capacity: 4.8 MMBtu/hr

CP #107-12143 Condition No. D.6.7 (c) NOx Limit (326 IAC 2-2): 0.10 lbs/MMBtu

CP #107-12143 Condition No. D.6.7 (d) CO Limit (326 IAC 2-2): 0.084 lbs/MMBtu

	NOx Emissions (lb/MMBtu)	CO Emissions (lb/MMBtu)	Heat Input Rate (MMBtu/hr)
Run 1	0.0820	0.0006	3.64
Run 2	0.0925	0.0005	3.31
Run 3	0.0793	0.0010	1.79
Average	0.0846	0.0007	2.92

STATUS: In Compliance

Note: There are 18 identical natural gas-fired batch annealing furnaces at Nucor Steel in Crawfordsville. Permit Condition D.6.4 (a) requires Nucor to perform NOx and CO testing on "at least four (4) batch annealing furnaces within 60 days after achieving maximum capacity, but no later than 180 days after initial start-up".

cc: J. Fisher, IDEM  
M. Luce, IDEM  
D. Sekula, IDEM  
M. Stuckey- IDEM Office of Enforcement  
WPS/General Files, Montgomery Co.

**Supreme  
Environmental Service Company**

*SESCo Group*

1426 West 29<sup>th</sup> Street Indianapolis, Indiana 46208

(317)347-9590 FAX (317)347-9591

---

**REPORT on  
NO<sub>x</sub> and CO EMISSIONS**

Performed for:

***Nucor Steel***

***Crawfordsville, IN***

***Annealing Furnace***

on 06/06/01

**RECEIVED**

JUL 17 2001

State Of Indiana  
Department of Environmental Management  
Office of Air Quality

---

To the best of our knowledge, the data presented in this report is accurate and complete.

Respectfully Submitted by:

Michael Dicen, Division Manager

### STACK EMISSION SUMMARY

SOURCE TESTED:	Annealing Furnace
COMPANY NAME:	Nucor Steel
DATE OF TEST:	06/06/2001

NOx Emissions	Run 1	Run 2	Run 3	Average
PPM	47.11	53.95	57.69	52.91
lbs/hr	0.3749	0.3500	0.3520	0.3590
lbs/MMbtu	0.0731	0.0837	0.0895	0.0821
<b>CO Emissions</b>				
PPM	3.70	3.70	3.10	3.50
lbs/hr	0.0179	0.0146	0.0115	0.0147
lbs/MMbtu	0.0035	0.0035	0.0029	0.0033
<b>Avg. Stack Vol. Flow Rate</b>				
ACFM	2977.13	2457.27	2284.21	2572.87
DSCFM	1111.03	905.65	851.70	956.13
Avg. Stack Temp.	757.50	781.31	754.69	764.50
Stack Gas Velocity	53.83	44.43	41.30	46.52
Avg. Velocity Head	0.3865	0.2589	0.2279	0.2911
Avg. Sq. Rt of Delta P	0.6217	0.5088	0.4774	0.5360
% Moisture of Stack Gas	14.58%	13.99%	14.85%	14.48%
Sample Volume	21.110	21.466	21.555	21.377

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4183

**2-1 RESULTS**

*Table 2-1:  
Annealing Furnace Emissions*

<u>Gas Conditions</u>		1	2	3	Avg
Ts	Stack Temperature (°F)	757.50	781.31	754.69	764.50
Bwo	Moisture (volume %)	14.58	13.99	14.85	14.48
O2	Oxygen (dry volume %)	7.0	7.0	7.5	7.2
CO2	Carbon Dioxide (dry volume %)	8.0	8.0	8.0	8.0
<u>Volumetric Flow Rate</u>					
Qa	Actual Conditions (acfm)	2977.13	2457.27	2284.21	2572.87
Qstd	Standard Conditions (dscfm)	1111.03	905.65	851.70	956.13
<b>NITROGEN OXIDES</b>					
Er	Emission Rate (PPM)	47.11	53.95	57.69	52.91
Er	Emission Rate (lbs/hr)	0.3749	0.3500	0.3520	0.3590
<b>CARBON MONOXIDE</b>					
Er	Emission Rate (PPM)	3.70	3.70	3.10	3.50
Er	Emission Rate (lbs/hr)	0.0179	0.0146	0.0115	0.0147

**SESCO Group**

Nucor Steel  
Crawfordsville, IN

SESCO Project No. 4183

### 3-1 METHODOLOGY

---

The sampling followed procedures as detailed in U.S. Environmental Protection Agency (EPA) Methods 1-4, 7E, 10. The following table summarizes the methods:

#### Summary of Sampling Procedures

---

Title 40 CFR Part 60 Appendix A

Method 1 "Sampling of Velocity Traverses for Stationary Sources"  
Method 2 "Determination of Stack Gas Velocity and Volumetric Flow Rate"  
Method 3 "Gas Analysis for the Determination of Molecular Weight"  
Method 4 "Determination of Moisture Content in Stack Gas"  
Method 7E "Determination of Nitrogen Oxide Emissions from Stationary Sources"  
Method 10 "Determination of Carbon Monoxide Emissions from Stationary Sources"

---

#### SAMPLE POINT DETERMINATION

Sampling point locations were determined according to EPA Reference Method 1.

*Table 3-1:  
Sampling Points*

---

Location	Dimensions	Ports	Points per Port	Total Points
Annealing Furnace	13" ID	2	8	16

---

**SESCO Group**

### **3-2 METHODOLOGY**

---

#### **SAMPLE AND VELOCITY TRAVERSE - EPA METHOD 1**

Method 1 was used for the representative measurement of pollutant emissions and/or total volumetric flow rate. A measurement site where the effluent gas stream, flowing in a known direction is selected and divided into a equal number of areas. A traverse point is then located within each of these equal areas. Sampling or velocity measurement is performed at a site located at least eight stack or duct diameters downstream and two diameters up stream from any flow disturbance such as a bend, expansion, contraction, or visible flame. If necessary, an alternative location may be selected at a position at least two stack or duct diameters downstream and one half diameter upstream from any flow disturbance.

#### **VELOCITY AND VOLUMETRIC FLOW RATE - EPA METHOD 2**

EPA Method 2 was used to determine the gas velocity and flow rate at both the inlet and outlet locations. Each set of velocity determinations included the measurement of gas velocity pressure and gas temperature at each of the Method 1 determined traverse points. The velocity pressures were measured with a Type S pitot tube. Gas temperature measurements were made with a Type K thermocouple and digital pyrometer.

#### **GAS COMPOSITION AND MOLECULAR WEIGHT - EPA METHOD 3**

In order to determine the oxygen and carbon dioxide concentrations, a sample of gas was obtained and analyzed in accordance with EPA Method 3. The gas sample was collected using an Orsat analyzer. The results were used to determine gas molecular weight.

#### **MOISTURE CONTENT - EPA METHOD 4**

The flue gas moisture content at the testing locations was determined in accordance with EPA Method 4. The moisture was determined by quantitatively condensing moisture in the chilled impingers and silica absorbtion. The amount of moisture condensed was determined gravimetrically. A dry gas meter was used to measure the volume of gas sampled. Moisture content is used to determine stack gas velocity.

#### **NITROGEN OXIDE CONCENTRATION - EPA METHOD 7E**

A gas sample is continuously drawn from the stack and a portion of the sample is conveyed to a chemiluminescent analyzer for NOx concentration determination. The wet stack gas is "dried," before analysis, by a chilled condenser. EPA protocol 1 gases are used to calibrate the instrument, as well as run system checks.

#### **CARBON MONOXIDE CONCENTRATION - EPA METHOD 10**

A continuous gas sample is drawn from the stack and a portion is conveyed to a tedlar bag for carbon monoxide concentration determination at a laboratory. The wet stack gas is "dried," before analysis, by a chilled condenser. EPA protocol 1 gases are used to calibrate the laboratory instrument.

## SECTION D.6 FACILITY OPERATION CONDITIONS

### Facility Description [326 IAC 2-7-5(15)]

- (f) Eighteen (18) natural gas-fired batch annealing furnaces, utilizing propane as a backup fuel. Each batch annealing furnace shall be equipped with low-NOx burners and shall not exceed a maximum heat input rate of 4.8 MMBtu per hour. These units can handle the product from both the existing continuous caster line and the continuous strip caster line to be installed as described above.

(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

### Emission Limitations and Standards

#### D.6.1 Nitrogen Oxides (NO<sub>x</sub>) and CO Emission Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements), the eighteen (18) batch annealing furnaces shall comply with the following requirements:

- (a) Each batch annealing furnace shall be equipped with low-NOx burners;
- (b) Each batch annealing furnace shall utilize natural gas as the primary fuel and may utilize propane as a backup fuel;
- (c) The NO<sub>x</sub> emissions from each batch annealing furnace shall not exceed 0.10 pounds per MMBtu; and
- (d) The CO emissions from each batch annealing furnace shall not exceed 0.084 pound per MMBtu.

#### D.6.2 Sulfur Dioxide (SO<sub>2</sub>) Emission Limitations

Pursuant to 326 IAC 2-2 (PSD Requirements), the above-mentioned additional batch annealing furnaces shall utilize natural gas as the primary fuel and may utilize propane as a backup fuel.

### Compliance Determination and Monitoring

#### D.6.4 Performance Testing

- (a) Pursuant to 326 IAC 2-1.1-11 and 326 IAC 2-2, the Permittee shall perform NO<sub>x</sub> and CO compliance stack tests on at least four (4) batch annealing furnaces within 60 days after achieving maximum capacity, but no later than 180 days after initial start-up.
- (b) All compliance stack tests shall be repeated at least annually until such time that the Part 70 permit for this source is in effect.
- (c) IDEM, OAQ retains the authority under 326 IAC 2-1-4(f) to require the Permittee to perform additional and future compliance testing as necessary.

#### D.6.5 Vendor Certification

The Permittee shall submit with the affidavit of construction (Condition B.5(a)) the vendor guarantees for the above-mentioned batch annealing furnaces to demonstrate compliance with