

Note: This is a reference cited in AP 42, *Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at www.epa.gov/ttn/chief/ap42/

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

AP32 Section:	12.5.1
Background Chapter	3
Reference:	38
Title:	Source Evaluation Report, Oregon Steel Mills, Portland, OR, Electric Arc Furnace Baghouse. November 7, 2001. Prepared for Oregon Steel Mills, Portland, OR by Michele R. Kinney & David R. Rossman, P.E. Project No. 1685.



13585 N.E. Whitaker Way • Portland, OR 97230
Phone (503)255-5050 • Fax (503)255-0505
www.horizonengineering.com

Project No. 1685

SOURCE EVALUATION REPORT

**Oregon Steel Mills
Portland, Oregon**


**Electric Arc Furnace Baghouse
Particulate, CO, NO_x, SO₂, VOC, Lead and Opacity**

November 7, 2001

Prepared for
Oregon Steel Mills
14400 N. Rivergate Blvd.
Portland, Oregon 97203

by Michele R. Kinney &
David R. Rossman, P.E.

RECEIVED
FEB 8 2002
AIR QUALITY DIVISION
1100 NE Oregon Street
Portland, Oregon 97232



Expires 12/31/02

TABLE OF CONTENTS

	<u>Page Number</u>
1. Certification	4
2. Introduction	5
3. Summary of Results	6
4. Source Description and Operation	10
5. Sampling and Analytical Procedures	12
6. Discussion	17

APPENDIX

	<u>Page Number</u>
Nomenclature & Drift Correction Documentation	18
Particulate and Lead Calculation Sheets	20
Emission Calculation Worksheets and Field Data Sheets	
Blank Correction and Filter Rinse Allocation	
Laboratory Results, Worksheets, Chain of Custody & Filter Tare Weights	
Baghouse Sampling Diagram	
Volume Flow Rate Determination	50
Flow Rate Determinations and Field Data	
Traverse Point Location – Inlet & Outlet	
Visible Emissions	61
Field Data and Certification	
Gaseous Emissions	65
Gaseous Emissions and Molecular Weight Determinations	
Analyzer Calibration Data, Manual Data and Bias Checks	
Data Logger Gas Charts	
Strip Charts	
Production/Process Data	77
Furnace Heat Logs	
MSDS Sheet	
Baghouse Pressure Drop Field Data	
Calibration Information	107
High-Volume Sampler Calibrations	
Pitots	
Thermocouples and Indicators	
Shortridge Micro manometer	
Magnehelic	
Barometer	
NOx Converter Efficiency Test	
Calibration Gas Certificates	
Audit Sample Results, reporting forms and instructions	
QA/QC Documentation	141
Correspondence	144
Source Test Plan and Correspondence	

1. CERTIFICATIONS

1.1 Test Team Leader

I hereby certify that the test detailed in this report, to the best of my knowledge, was accomplished in conformance with applicable rules and good practices. The results submitted herein are accurate and true to the best of my knowledge.


Name: Michael J. Eisele, E.I.T.

Signature  Date 12/17/01

1.2 Report Reviewer

I hereby certify that I have reviewed this report and find it to be true and accurate, and in conformance with applicable rules and good practices, to the best of my knowledge.

Name: David R. Rossman, P.E.

Signature  Date 12/20/01

2. INTRODUCTION

2.1 Client: Oregon Steel Mills

2.2 Physical Location: 14400 N. Rivergate Blvd., Portland, OR 97203

2.3 Mailing Location: P. O. Box 2760, Portland, OR 97208

2.4 Test Log

Test Date	Source Name	Pollutants
November 7, 2001	Electric Arc Furnace Baghouse	Particulate, CO, NO _x , SO ₂ , VOC, Lead and Opacity

2.5 Test Purpose: Required by Title V Permit No. 26-1865, conditions 37, 38 and 39, issued by the Oregon Department of Environmental Quality (ODEQ).

2.6 Background Information: The expired ACDP Permit required testing for particulate, lead, CO, and opacity on a quarterly basis. The new Title V Permit requires the list above annually.

2.7 Participants:

Horizon Personnel:

Michael J. Eisele, E.I.T., Team Leader
Ryan S. Smith, Field Technician
Tim J. Hertel, Field Technician
Dharma Cole, E.I.T., Field Technician
Brian Galvin, Field Technician
Jay Griffith, Field Technician
Michael E. Wallace, Calculations and QA/QC
David R. Rossman, P.E., Report Review
Michele R. Kinney, Technical Writer

Test Arranged by: Debbie Deetz Silva, Oregon Steel Mills

Source Operator: Mike Anderson

Test Plan Sent to: Jack Herbert, ODEQ

3. SUMMARY OF RESULTS

3.1 Table(s) of Results

Particulate and Lead Test Results

Test Date: November 7, 2001

	Units	Run 1	Run 2	Run 3	Average
Start Time		10:31	12:09	13:50	
End Time		12:05	13:33	15:17	
Sampling Time	min	70	65	60	65
Sampling Results					
Particulate Conc.(Actual)	gr/scfd	0.00069	0.00083	0.00106	0.00086
Particulate Rate	lb/hr	3.1	3.7	4.7	3.9
Based on Cold Charge	lb/ton	0.0227	0.0268	0.0344	0.0280
Sample Volume	dscf	2,214	1,978	1,870	2,021
Sample Weight, Total	mg	98.6	106.6	128.3	111.2
Percent Isokinetic	%	98	100	100	98
Lead Rate	lb/hr	0.036	0.043	0.054	0.044
Based on Cold Charge	lb/ton	0.00026	0.00031	0.00039	0.00032
% of Total Particulate	%	1.14	1.16	1.15	1.15
Opacity	%	0	0	0	0
Source Parameters					
Inlet Flow Rate	dscf/min				389,000
Outlet Flow Rate	dscf/min	530,000	525,000	522,000	526,000
Temperature, Outlet	°F	143	158	155	152
Process Data					
Cold Charge Production	tons/hr	137.36	139.40	137.82	138.20
Baghouse Press. Drop, Avg.	in H ₂ O	4.5	5.5	6.0	5.3

Table 2
Gaseous Emissions Test Results

Test Date: November 7, 2001

	Units	Run 1	Run 2	Run 3	Average
Start Time		10:31	12:09	13:50	
End Time		12:05	13:33	15:17	
Sampling Time	min	70	65	60	65
Sampling Results					
O ₂	%	20.5	20.5	20.5	20.5
CO ₂	%	0.6	0.5	0.6	0.6
CO Concentration	ppmv	202	135	124	154
Rate	lb/hr	341.6	229.6	210.8	260.7
Based on Cold Charge	lb/ton	2.49	1.65	1.53	1.89
NO _x Concentration	ppmv	11	12	11	11
Rate	lb/hr	30.5	32.9	29.5	31.0
Based on Cold Charge	lb/ton	0.22	0.24	0.21	0.22
SO ₂ Concentration ¹	ppmv	5	5	4	4
Rate	lb/hr	19.1	21.2	14.9	18.4
Based on Cold Charge	lb/ton	0.14	0.15	0.11	0.13
TGOC Concentration	ppmvC	29	21	21	24
Rate	lbC/hr	21.1	15.2	15.1	17.1
Based on Cold Charge	lbC/ton	0.15	0.11	0.11	0.12
TGNMOC ² Concentration	ppmvC	9	9	12	10
Rate	lbC/hr	6.7	6.4	9.1	7.4
Based on Cold Charge	lbC/ton	0.049	0.046	0.066	0.053

¹ SO2 results may be slightly high due to excessive drift during the testing. The results are drift corrected.

² VOC emissions as total gaseous non-methane organic compounds

3.2 Description of Collected Samples:

See Blank Correction and Rinse Allocation in Appendix.

3.3 Discussion of Errors and Quality Assurance Procedures

This table is taken from a paper entitled "Significance of Errors in Stack Sampling Measurements", by R.T. Shigahara, W.F. Todd and W.S. Smith. It summarizes the maximum error expressed in percent, which may be introduced into the particulate test procedures by equipment or instrument limitations.

Measurement	% Max Error
Stack Temperature T_s	1.4
Meter Temperature T_m	1.0
Stack Gauge Pressure P_s	0.42
Meter Gauge Pressure P_m	0.42
Atmospheric Pressure P_{atm}	0.21
Dry Molecular Weight M_d	0.42
Moisture Content B_{ws} (Absolute)	1.1
Differential Pressure Head ΔP	10.0
Orifice Pressure Differential ΔH	5.0
Pitot Tube Coefficient C_p	2.4
Orifice Meter Coefficient K_m	1.5
Diameter of Probe Nozzle D_n	0.80

QA procedures outlined in the test methods were followed, including equipment specifications and operation, calibrations, sample recovery and handling, calculations and performance tolerances.

Analyzer system checks performed are noted on the Calibration Field Record sheet, with procedures documented in the QA/QC section in the Appendix. All calibration standards used in the testing were EPA Protocol 1 or traceable to NIST standards. Certificates for the gases are in the Appendix. Tables 3a and 3b summarize the quantifiable QA checks for the continuous emissions monitors.

Table 3a
QA/QC Checks – Continuous Analyzers, Daily Checks

	Cal. Error <2% span or <5% span ³	System Bias <5%	Cylinder value, % of span ⁴	Instrument Span
O₂:				25%
high	0%	--	84%	
mid	0%	0%	46%	
zero	0%	0%	0%	
CO₂:				25%
high	0%	--	87%	
mid	1%	1%	50%	
zero	0%	0%	0%	
CO:				2000 ppmv
high	0%	--	44%	
mid	0%	1%	25%	
mid	0%	0%	4%	
zero	0%	0%	0%	
NO_x:				200 ppmv
high	1%	1%	92%	
mid	1%	0%	45%	
mid	0%	0%	13%	
zero	0%	0%	0%	
SO₂ :				30 ppmv
high	0%	--	88%	
mid	1%	3%	51%	
zero	0%	1%	0%	
VOC #1:				100 ppmv
high	NA ⁵	0%	89%	
mid	NA	0%	52%	
mid	NA	0%	30%	
mid	NA	0%	9%	
zero	NA	0%	0%	
VOC #2:				100 ppmv
high	NA ⁶	0%	89%	
mid	NA	0%	52%	
mid	NA	0%	29%	
mid	NA	0%	9%	
zero	NA	0%	0%	

Response Time: 45 seconds

³ Calibration Error specifications: 2% for Methods 3A, 6C, and 7E; 5% for Method 25A.

⁴ Acceptable values for all calibration gases except VOC: High-level=80-100% of span, mid-level=40-60% of span; for VOC calibration gases: high-level=80-90%, mid-level=45-55%, low-level=25-35%.

⁵ Method 25A requires system bias checks as in Method 6C, but calls them calibration error checks.

⁶ Method 25A requires system bias checks as in Method 6C, but calls them calibration error checks.

Table 3b

QA/QC Checks – Continuous Analyzers		Individual Run Checks				
	O ₂	CO ₂	CO	NO _x	SO ₂	VOC 1 & 2
Zero Drift (<3% span)						
Run 1-3	0%	0%	0%	0%	19% ⁷	2% 2%
Calibration Drift <3% span						
Mid-Range						
Run 1-3	1%	0%	0%	0%	15% ⁷	3% 3%
Mid-Range						
Run 1-3	--	--	1%	1%	--	6% ⁷ 3%
Mid-Range						
Run 1-3	--	--	--	--	--	11% ⁷ 2%
High-range						
Run 1-3	--	--	1%	1%	0%	--% --%

Four audit samples (two liquid samples and two filter samples), prepared by EPA in accordance with Method 12 and provided to Jack Herbert of ODEQ, were submitted to Environmental Services Laboratory November 21, 2001 along with the particulate samples to be analyzed for lead.

On December 11, 2001, Horizon Engineering notified Jack Herbert via fax of the audit sample lab results, and he assured us that the lab results were acceptable. The audit sample lab results are in the Calibration Information section of the Appendix. We have no knowledge of the actual EPA numbers.

4. SOURCE DESCRIPTION AND OPERATION

4.1 Process and Control Device Description and Operation:

The EAF baghouse at Oregon Steel Mills cleans particulate from two significant sources in the melt shop. The main furnace, No. 3, normally produces between 100 and 115 tons of steel per heat from two charges of scrap metal, plus some molten

⁷ More drift than normally allowable was anticipated because of the long duration of the sampling and was addressed in the Test Plan prior to sampling. Analyzer results have been drift corrected.

"pour back" material left over from casting. Records for each heat during the testing times are in the Production-Process Data Section of the Appendix.

The main furnace dust control system is a "fourth hole" duct connection to the top of the furnace, and a series of three openings in the roof above the main furnace that can open into the duct to the baghouse. Each of these pick-up points has a damper that is controlled automatically by certain furnace operations. Generally, the roof vents are open for several minutes following charging of the furnace.

The ladle metallurgy furnace is between the main furnace and the casting area and is used to fine-tune the content and temperature of the molten steel before being cast. Charging is only of molten steel and alloying material and is the minor contributor to the baghouse system. The exhaust from this furnace enters the duct system downstream from the main furnace and roof vents.

All of the pick-up points are evacuated into an 11 foot-diameter duct by two 1250-Hp fans. The fans have automatically controlled dampers on the inlets.

Particulate control is by a 16-compartment, (21 ft. by 14 ft. each) Industrial Clean Air, reverse-air type, baghouse with seamless tube polyester bags. Magnehelic gauges on each of the compartments showed pressure drops averaging 5.3 inches of water.

4.2 Test Ports: Ports and traverse points are described and diagrammed on the Field Data sheets.

4.3 Test Duct Characteristics:

Cyclonic Flow: No Cyclonic flow expected. The inlet (flow traverse) location has been checked for cyclonic flow in the past and it was not cyclonic.
Meets EPA M-1 Criteria: No.

4.4 Process & Control Equipment Flow Diagram: See Process/Sampling Equipment Flow Diagram in Appendix.

4.5 Operating Parameters: See Production/Process Data section of Appendix.

4.6 Process Startups/Shutdowns or Other Operational Changes During Tests:

Process was not continuous during testing. The process was stopped for approximately 10 minutes between Runs 2 and 3 for patching of the furnace walls.

5. SAMPLING AND ANALYTICAL PROCEDURES

5.1 Sampling Procedures

5.1.1 Sampling and Analytical Methods

Testing was conducted in accordance with EPA Methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, July 1, 2000; and Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, January 1992.

Inlet tests:

Flow Rate: EPA Methods 1 and 2 (at BH inlet, twice on test day)
Moisture: ODEQ Method 4 (wet bulb and dry bulb temperatures)
CO₂ and O₂: EPA Method 3A
SO₂: EPA Method 6C
NO_x: EPA Method 7E
CO: EPA Method 10
VOC: EPA Method 25A, (heated sample line and two analyzers,
one with simultaneous VOC "cutter" for back-out of CH₄ content)

Outlet tests:

Flow Rate: EPA Methods 1 and 2 (at each compartment, as done in past)
Particulate: ODEQ Method 8 (High Volume sampler)
Lead: Analysis of M-8 catch, with audit sample analysis
Opacity: EPA Method 9 (six minutes per test)

5.1.2 Sampling Notes:

Flow Rates There are openings at the tube-sheet level of the baghouse where ambient air enters for temperature control around the bags. This means that the

baghouse outlet flow rate is higher than the inlet duct flow rate. Because CO is measured in the duct before dilution takes place, the inlet flow is applied to that parameter. Particulate is measured in the diluted outlet compartments, so separate flow measurements were made at those locations. According to plant personnel, closing off the ambient air openings is not feasible.

Inlet Flow Measurement

The baghouse inlet duct volume flow rate was determined from pitot traverses before and after the baghouse testing according to EPA Methods 1 and 2. Velocity pressure was taken using an S-type pitot with a Shortridge "Airdata" 870 digital micromanometer, and temperature measurements with an attached k-type thermocouple and a Fluke Model 52 digital thermocouple indicator. The traverses included 48 points (24 on each diameter) through ports located off the platform on the melt shop roof. Leak checks were made on the pitot system after each of the traverses.

A check for cyclonic flow at the measurement points was done in December 1991 and was found to be well within the criteria specified in EPA Method 1, Section 2.4, which calls for an average of less than 20°.

Outlet Flow Measurement

The velocity was also measured at the outlet of each compartment using an S-type pitot and the micromanometer with attached thermocouple. The micromanometer has a resolution of 0.0001 inches of water. The flow was determined from 5-point pitot traverses through one port per compartment. Flow was measured in the same ports as particulate.

Because one of the compartments is always shut off for cleaning, outlet flow rates used for calculating emissions are based on one less compartment than the total available.

Particulate and Lead Three test runs were made each lasting through two complete furnace heat cycles. The sampler running times ranged from 60 to 70 minutes in length; each test was started and stopped while the main furnace was being tapped. Although there is some emission to the furnace room during this

operation, the concentration going to the baghouse system is relatively low compared to that when the furnace is in melting mode.

Sampling was done in the area above the bags where the flow is angled diagonally up to the cupola centered on the top of the baghouse. A diagram of the top of the baghouse, showing where the sampler was positioned, is in the Appendix. The location of the particulate sampling nozzle during testing was at velocity traverse point two. The sampling was done isokinetically, using the velocity found from the outlet velocity traverse done just before the particulate sampling run.

Each compartment was sampled for five minutes. Near the end of each sampling interval, the orifice temperature was recorded as well as the temperature of the outlet gas stream. A new sampler flow rate was calculated based on the pre-survey data of the next compartment. At the end of the interval, the sampler was shut off, moved to the next compartment and restarted.

Sample volume calculations were based on the orifice pressure drops combined with the orifice temperatures and the calibration curve for the sampler. Emission rates were calculated using the flow rates measured at the baghouse outlet.

Gases Gas sample for the analyzers was taken from a fixed sampling point in the baghouse inlet duct below the baghouse, approximately below compartment No. 14.

5.1.3 Sample Analysis

Analyte	Laboratory
Particulate	Antech
Lead and Audit Samples	Environmental Services Laboratory

5.2 Sampling Train Diagrams

Figure 1
EPA Methods 3A, 6C, 7E & 10 Analyzer Sample System Diagram





Figure 2
EPA Method 25A VOC Analyzer Sample System Diagram



5.3 Horizon Test Equipment

5.3.1 Manual Methods

<u>Equipment Name</u>	<u>Equipment Identification</u>
Hi Volume Orifice	Horizon No. 1192
Pitots and Thermocouples	11-S, 14-S
Magnehelic Gauge	0-1F (orifice ΔH)
Micro manometer	Shortridge No. 2
Barometer	Test Van II

5.3.2 Continuous Emissions Monitors and Methods

Gas	Brand	Model	Range	Measurement Method	Method
O ₂	Servomex	1400	0-25%	Paramagnetic	3A
CO ₂	Servomex	1400	0-25%	Chopperless NDIR	3A
CO	Thermo Env	48	0-2000 ppm	Gas Filter Correlation	10
TGOC	J.U.M.	VE-7	0-100 ppm	Flame Ionization	25A
NO _x	Thermo Env	42H	0-200 ppm	Chemiluminescent	7E
SO ₂	West. Resch	721M	0-30 ppm	Non Disp. Ultra-violet	6C

5.3.3 Continuous Emissions Monitors Sampling Setup

Sampling: Above listed gases except TGOC.
Probe: Stainless Steel with sintered stainless and polyester filters.
Sample Line(s): Teflon (heated)
Conditioning: Refrigerated M & C Cooler
Data Logger: ESC Model 8816

Sampling: TGOC.
Probe: Stainless
Conditioning: none
Sample Line(s): Teflon (heated)
Pump: heated, internal to analyzer
Data Logger: ESC Model 8816

6. DISCUSSION

The results of the testing should be valid in all respects. All quality assurance checks including leak checks, instrument checks, and calibrations, were within method-allowable tolerances.

As previously noted, drift on the SO₂ and VOC analyzer systems was higher than in normal specifications. The possibility of this issue was discussed in the Test Plan in Paragraph 18. The numbers in the results table have been corrected for that drift.

APPENDIX

Nomenclature & Drift Correction Documentation

Nomenclature

Constants	Value	Units	Definition	Ref
Pstd(1)	29.92126	inHg	Standard Pressure	CRC
Pstd(2)	2116.22	lbf / ft ²		CRC
Tstd	527.67	°R	Standard Temperature	CRC
R	1545.33	ft lbf / lbmol °R	Ideal Gas Constant	CRC
MWatm	28.965	lbm / lbmole	Atmospheric (20.946 %O ₂ , 0.033% CO ₂ , Balance N ₂ +Ar)	
MWc	12.011	lbm / lbmole	Carbon	CRC
MWco	28.010	lbm / lbmole	Carbon Monoxide	CRC
MWco2	44.010	lbm / lbmole	Carbon Dioxide	CRC
MWh2o	18.015	lbm / lbmole	Water	CRC
MWno2	46.006	lbm / lbmole	Nitrogen Dioxide	CRC
MWo2	31.999	lbm / lbmole	Oxygen	CRC
MWso2	64.063	lbm / lbmole	Sulfur Dioxide	CRC
MWn2+ar	28.154	lbm / lbmole (Balance with 98.82% N ₂ & 1.18% Ar)	Emission balance	
C1	385.3211	ft ³ / lbmol	Ideal Gas Constant @ Standard Conditions	
C2	816.5455	inHg in ³ / °R ft ³	Isokenics units correction constant	
Kp	5129.4	ft / min [(inHg lbm/mole) / (°R inH ₂ O)] ^{1/2}	Pitot tube constant	Ref 2.5.1
Symbol	Units	Definition	Calculating Equation or Source of Data	EPA
As	in ²	Area, Stack		
An	in ²	Area, Nozzle		
Bws	%	Moisture, % Stack gas	[100 Vw(std) / [Vw(std)+Vm(std)]]	Eq. 5-3
C	ppmv-C	Carbon (General Reporting Basis for Organics)		
C1	ft ³ /lbmol	Gas Constant @ Standard Conditions	[R Tstd / Pstd(2)]	
C2	inHg in ³ / °R ft ³		[14,400 Pstd / Tstd]	
Cd	lbm-GAS / MMdscf	Mass of gas per unit volume	[Cgas MWgas / C1]	
cg	gr/dscf	Grain Loading, Actual	[15.432 mn / Vm(std) 1,000]	Eq. 5-6
cg @ X%CO ₂	gr/dscf	Grain Loading Corrected to X% Carbon Dioxide	[X% / CO ₂ %]	
cg @ X%O ₂	gr/dscf	Grain Loading Corrected to X% Oxygen	[(20.946-X) / (20.946-O ₂)]	
Cgas	ppmv, %	Gas Concentration, (Corrected)		
Cgas @ X%CO ₂	ppmv	Gas Concentration Correction to X% Carbon Dioxide	[X% / CO ₂ %]	
Cgas @ X%O ₂	ppmv	Gas Concentration Correction to X% Oxygen	[(20.946-X%) / (20.946-O ₂ %)]	
CO	ppmv	Carbon Monoxide		
Co	ft	Outer Circumference of Circular Stack		
Ci	ft	Inner Circumference of Circular Stack		
CO ₂	%	Carbon Dioxide		
Cp		Pitot tube coefficient		
Ct	lb/hr	Particulate Mass Emissions	[60 cg Qsd / 7,000]	
dH	in H ₂ O	Pressure differential across orifice		
Dn	in	Diameter, Nozzle		
dp ^{1/2}		Average square root of velocity pressure		
Ds	in	Diameter, Stack		
E	lb / MMBtu	Pollutant Emission Rate	Cgas Fd MWgas (20.946 / (20.946-O ₂)) / (1,000,000 C1)	
Fd	dscf / MMBtu	F Factor for Various Fuels		Table 19-1
I	%	Percent Isokinetic	[C2 Ts(abs) Vm(std) / (vs Ps mfg An Ø)]	Eq. 5-8*
Md	lbm / lbmole	Molecular weight, Dry Stack Gas	[(1-%O ₂ -%CO ₂)(MWn2+ar)+(%O ₂ MWo2)+(%CO ₂ MWco2)]	Eq. 3-1*
mfg		Mole fraction of dry stack gas	[1-Bws/100]	
Mgas	lbm/hr	Gaseous Mass Emissions	[60 Cgas(ppmv) MW Pstd(2) Qsd / 1,000,000 R Tstd]	
mn	mg	Particulate lab sample weight		
Ms	lbm / lbmole	Molecular weight, Wet Stack	[Md mfg +MWh2o (1-mfg)]	Eq. 2-5
MW	lbm / lbmole	Molecular Weight		
NO ₂	ppmv-NO ₂	Nitrogen Dioxide (General Reporting Basis for NO _x)		
NO _x	ppmv-NO ₂	Nitrogen Oxides (Reported as NO ₂)		
O ₂	%	Oxygen		
OPC	%	Opacity		
Pbar	in Hg	Pressure, Barometric		
Pg	in H ₂ O	Pressure, Static Stack		
Po	in Hg	Pressure, Absolute across Orifice	[Pbar + dH / 13.5951]	
Ps	in Hg	Pressure, Absolute Stack	[Pbar + Pg / 13.5951]	Eq. 2-6*
Qa	acft/min	Volumetric Flowrate, Actual	[As vs / 144]	
Qsd	dscf/min	Volumetric Flowrate, Dry Standard	[Qa Tstd mfg Ps] / [Pstd(1) Ts(abs)]	Eq. 2-10*
Rf	MMBtu/hr		1,000,000 Mgas (20.946-O ₂) / [Cd Fd 20.946]	
SO ₂	ppmv-SO ₂	Sulfur Dioxide		
t	in	Wall thickness of a stack or duct		
TGOC	ppmv-C	Total Gaseous Organic Concentration (Reported as C)		
Tm	°F	Temperature, Dry gas meter		
Tm(abs)	°R	Temperature, Absolute Dry Meter	[Tm + 459.67]	
Ts	°F	Temperature, Stack gas		
Ts(abs)	°R	Temperature, Absolute Stack gas	[Ts + 459.67]	
Vlc	ml	Volume of condensed water		
Vm	dscf	Volume, Gas sample		
Vm(std)	dscf	Volume, Dry standard gas sample	[Y Vm Tstd Po] / [Pstd(1) Tm(abs)]	Eq. 5-1
vs	ft/min	Velocity, Stack gas	Kp Cp dp ^{1/2} [Ts(abs) / (Ps Ms)] ^{1/2}	Eq. 2-9*
Vw(std)	scf	Volume, Water Vapor	0.04707 Vlc	Eq. 5-2
Y		Dry gas meter calibration factor		Fig. 5.6
t	min	Time, Total sample		

* Based on equation



13585 N.E. Whitaker Way • Portland, OR 97230
 Phone (503)255-5050 • Fax (503)255-0505
 horizons@teleport.com

DRIFT CORRECTION DOCUMENTATION

EPA Drift Equations:

- Method 3A: Oxygen and Carbon Dioxide

$$C_{gas} = \frac{(C_{ma} - C_{oa})(C - C_m) + C_{ma}}{(C_m - C_o)} \quad (\text{Eq. 3A-1})$$

- Method 6C: Sulfur Dioxide

$$C_{gas} = \frac{C_{ma}(C - C_o)}{(C_m - C_o)} \quad \text{where } C_{oa} = 0 \quad (\text{Eq. 6C-1})$$

- Method 7E: Nitrogen Oxides, Section 8 of Method 7E states: "Follow Section 8 of Method 6C (Eq. 6C-1)"
- Method 10: Carbon Monoxide, the EPA does not currently address Gas Filter Correlation instruments, therefore there are no current standards.
- Method 25A: Total Gaseous Organic Concentration (TGOC), this method does not mention correcting for drift although there are established limits.

Horizon Engineering Drift Correction Equations:

$$C_{gas} = \frac{(C_{id} - Z_x)(C_{ma} - C_{oa})}{(S_x - Z_x)} \quad S_x = \frac{C_{mf} - C_{mi}}{(T_{cf} - T_{ci})} + C_{mi}$$

$$Z_x = \frac{(C_{of} - C_{oi})(T_x - T_{ci})}{(T_{cf} - T_{ci})} + C_{oi} \quad T_x = \frac{(T_{te} - T_{ts})}{2} + T_{ts}$$

EPA	Definition	Horizon
C_{gas}	Effluent gas concentration, dry basis	C_{gas}
C_{ma}	Actual upscale calibration gas concentration	C_{ma}
C_{oa}	Actual zero/low calibration gas concentration	C_{oa}
C_m	Average of initial and final system upscale calibration bias responses	
	Initial system upscale calibration bias response	C_{mi}
	Final system upscale calibration bias response	C_{mf}
C_o	Average of initial and final system zero/low calibration bias responses	
	Initial system zero/low calibration bias response	C_{oi}
	Final system zero/low calibration bias response	C_{of}
C	Average gas concentration indicated by gas analyzer, dry basis	C_{id}
	Starting test time	T_{ts}
	Ending test time	T_{te}
	Initial system bias calibration response time	T_{ci}
	Final system bias calibration response time	T_{cf}
	Mid-point of test time or gas sampling interval to be analyzed	T_x
	Approximate upscale response at mid-point test time	S_x
	Approximate zero/low response at mid-point test time	Z_x

Notes or exceptions:

TGOC is first recorded on a wet basis, then corrected to a dry basis

The TGOC instruments used by Horizon have some historic data on instrument response to different hydrocarbons. For propane the response is 1 to 1 molecule while methane is 1.037 to 1 molecule. We correct for the instrument's "over response" to methane.

Particulate and Lead Calculation Sheets
Emission Calculation Worksheets and
Blank Correction and Filter Rinse Allocation
Laboratory Results, Worksheets, & Chain of Custody
Filter Tare Weights
Baghouse Sampling Diagram

Particulate and Lead Emissions

Plant Source	Oregon Steel Mills ICA Baghouse-EAF						File	1685	
Date	07-Nov-2001						Tester	MJE/TJH/CDB	
Run#	1						Analysis/QA	MEW	
Points	Wt(mg)	98.579	Stack Area	As=	969.6 sqft	Mol Wt. Dry	Md=	29.01 molwt	
	Lead (mg)	1.126	Stack Temp.	Tdb=	143 °F	Mol Wt. Wet	Ms=	28.80 molwt	
Hivol ID	SN#	1192	Stack Temp.	Twb=	85 °F	Barometric	Pb=	30.50 in H2O	
Orifice	A=	47.8947	Moisture	bws=	1.91 %	Static Pres.	Pstat=	0.04 in H2O	
Constants	B=	0.4763	Nozzle Dia.	Dn=	3.109 in	Stack Pres.	Ps=	29.60 in Hg	
			Nozzle Area	An=	7.59 sqin	Pitot	Cp=	0.8029	

TIME	Compartment #	POINT #	Velocity Pressure dP inH2O	Velocity vs fpm	Orifice in H2O dHo Calc	Pressure in H2O dHo Act	Temp (F) Orifice Tor	Temp (F) Stack Tso	Time min t	Rate cfm Standard Q@68°F	Volume cuft Standard @68°F	Volume cuft Orifice @Tor
10:31												
10:37	1	3	0.0392	685.6	0.4524	0.4600	110.0	143.0	5.0	31.90	159.5	172.2
10:44	2	3	0.0248	539.0	0.2968	0.2800	130.0	129.0	5.0	24.77	123.9	138.4
10:51	3	3	0.0361	647.5	0.4441	0.4200	130.0	124.0	5.0	30.05	150.3	167.9
10:58	4	3	0.0615	851.6	0.7775	0.7300	140.0	133.0	5.0	38.79	194.0	220.4
11:04	5	3	0.0456	731.5	0.5748	0.5400	144.0	130.0	5.0	33.50	167.5	191.6
11:11	6	3	0.0358	654.1	0.4286	0.4200	132.0	141.0	5.0	30.00	150.0	168.2
11:18	7	3	0.0336	636.3	0.4002	0.4000	136.0	146.0	5.0	29.22	146.1	164.9
11:25	8	3	0.0310	606.7	0.3749	0.3700	138.0	137.0	5.0	28.11	140.5	159.2
11:31	9	3	0.0353	646.3	0.4297	0.4200	136.0	135.0	5.0	29.91	149.5	168.8
11:38	10	3	0.0450	737.6	0.5456	0.5300	140.0	148.0	5.0	33.30	166.5	189.2
11:45	11	3	0.0509	784.5	0.6313	0.6000	150.0	148.0	5.0	35.05	175.3	202.5
11:52	12	3	0.0342	652.5	0.4020	0.3900	148.0	166.0	5.0	28.60	143.0	164.7
11:58	13	3	0.0484	777.5	0.5807	0.5600	152.0	168.0	5.0	33.87	169.3	196.3
12:05	14	3	0.0528	799.0	0.6475	0.6200	142.0	148.0	5.0	35.83	179.2	204.3

Time weighting used in averaging =>	696.4	0.4990	0.4814	137.7	142.6	70.00	31.64	2,214.5	2,508.6
-------------------------------------	-------	--------	--------	-------	-------	-------	-------	---------	---------

	Run#	1	2	3	Average		
Sample Volume	V@68 (Pb/29.92)(1-bws/100)	dscf	Vd	2,214.2	1,978.4	1,870.0	2,020.9
Total Flowrate	Outlet Flow	dscf/min	Qsd	530,486	524,781	522,453	525,906
Particulate							
Grain loading	0.01543 Wt/Vd	.gr/dscf	Cg	0.00069	0.00083	0.00106	0.00086
		ug/m3		1572	1902	2423	1966
Emissions	0.00857 Cg Qs	lbm/hr	Ct	3.1237	3.7387	4.7426	3.8683
		lbm/ton		0.0227	0.0268	0.0344	0.0280
LEAD							
Grain loading	0.01543 Lead/Vd	gr/dscf	Cg	0.0000078	0.0000096	0.0000121	0.0000099
		ug/m3		18.0	22.0	27.8	22.6
Emissions	0.00857 Cg Qs	lbm/hr	Ct	0.0357	0.0433	0.0543	0.0444
		lbm/ton		0.00026	0.00031	0.00039	0.00032
Avg Sample Rate	V@Tor / t	acf/min	Qan	35.84	36.16	36.19	36.06
Avg Velocity @ Sample Point	vs=Qa/As	fpm	vs	696.42	697.33	686.91	693.55
Avg Orifice temp		°R	Tor	597.38	610.05	613.25	606.90
Avg Stack temp		°R	Ts	602.24	617.36	614.59	611.40
Avg Nozzle Velocity	Qan*Ts / An*Tor	fpm	vn	685.31	694.19	687.99	689.16
% ISOKINETIC	100 vn/vs	%	%I	98.4	99.6	100.2	99.4
Percent Lead of Total Particulate		%	%	1.14	1.16	1.15	1.15

* The baghouse has 16 compartments. One is always cycling.

* Each Compartment is 52"x179"

Particulate and Lead Emissions

Plant	Oregon Steel Mills							File	1685		
Source	ICA Baghouse-EAF							Tester	MJE/TJH/CDB		
Date	07-Nov-2001										
Run#	2	Wt(mg)	106.572	Stack Area	As=	969.6 sqft	Mol Wt. Dry	Md=	29.02 molwt		
Points	10	Lead(mg)	1.234	Stack Temp.	Tdb=	137 °F	Mol Wt. Wet	Ms=	28.52 molwt		
				Stack Temp.	Twb=	98 °F	Barometric	Pb=	30.50 in H2O		
Hivol ID	SN#	1192		Moisture	bws=	4.53 %	Static Pres.	Pstat=	0.03 in H2O		
Orifice	A=	47.8947		Nozzle Dia.	Dn=	3.109 in	Stack Pres.	Ps=	30.50 in Hg		
Constants	B=	0.4763		Nozzle Area	An=	7.59 sqin	Pitot	Cp=	0.8029		

TIME	Compartment POINT	pt	Velocity		Orifice in H2O dHo Calc	Pressure in H2O dHo Act	Temp (F) Orifice Tor	Temp (F) Stack Ts	Time min t	Rate cfm Standard Q@68°F	Volume cuft Standard @68°F	Volume cuft Orifice @Tor
			Pressure dP inH2O	Correct fpm Vs								
12:09												
12:15	15	3	0.0286	576.83	0.3338	0.3400	132.0	137.0	5.0	27.13	135.6	152.1
12:22	1	3	0.0432	726.54	0.5037	0.5000	150.0	167.0	5.0	32.14	160.7	185.7
12:28	2	3	0.0412	706.11	0.4841	0.4800	150.0	161.0	5.0	31.52	157.6	182.1
12:35	3	3	0.0508	784.08	0.6042	0.6000	151.0	161.0	5.0	35.03	175.1	202.7
12:41	4	3	0.0535	807.88	0.6440	0.6300	162.0	166.0	5.0	35.55	177.7	209.4
12:48	5	3	0.0326	629.12	0.3805	0.3700	155.0	163.0	5.0	27.74	138.7	161.5
12:54	6	3	0.0324	629.70	0.3736	0.3700	153.0	168.0	5.0	27.78	138.9	161.3
13:01	7	3	0.0384	686.62	0.4451	0.4400	153.0	170.0	5.0	30.17	150.8	175.1
13:07	8	3	0.0454	732.82	0.5436	0.5500	144.0	147.0	5.0	33.79	168.9	193.3
13:14	9	3	0.0500	768.42	0.6007	0.6100	142.0	146.0	5.0	35.55	177.8	202.7
13:20	10	3	0.0365	656.54	0.4374	0.4300	150.0	146.0	5.0	29.91	149.6	172.8
13:27	11	3	0.0326	627.10	0.3830	0.3700	155.0	159.0	5.0	27.74	138.7	161.5
13:33	12	3	0.0446	733.49	0.5349	0.5200	158.0	159.0	5.0	32.54	162.7	190.5

Time weighting used in averaging. => 697.33 0.4822 0.4777 150.38 157.69 65.00 31.28 2,032.9 2,350.7

							Run#	2			
Sample Volume			V@68 (Pb/29.92)(1-bws/100)			dscf	Vd	1,978.4			
Total Flowrate			Outlet Flow			dscf/min	Qs	524,781			
Particulate											
Grain loading			0.01543 Wt/Vd			gr/dscf	Cg	0.00083			
Emissions			0.00857 Cg Qs			lb/hr	Ct	3.739			
LEAD											
Grain loading			0.01543 Lead/Vd			gr/dscf	Cg	9.62E-06			
Emissions			0.00857 Cg Qs			lb/hr	Ct	0.04327852995			
Avg Sample Rate			V@Tor / t			acf/min	Qan	36.16			
Avg Velocity @ Sample Point			vs=Qa/As			fpm	vs	697.33			
Avg Orifice temp						°R	Tor	610.05			
Avg Stack temp						°R	Ts	617.36			
Avg Nozzle Velocity			Qan*Ts / An*Tor			fpm	vn	694.19			
% ISOKINETIC			100 vn/vs				%I	99.55			

Particulate and Lead Emissions

Plant	Oregon Steel Mills							File	1685			
Source	ICA Baghouse-EAF							Tester	MJE/TJH/CDB			
Date	07-Nov-2001											
Run#	3	Wt(mg)	128 349	Stack Area	As=	969.6 sqft	Mol Wt. Dry	Md=	29.02 molwt			
Points	11	Lead(mg)	1.471	Stack Temp.	Tdb=	141 °F	Mol Wt. Wet	M _s =	28.82 molwt			
Hivol ID	SN#	1192		Stack Temp.	Twb=	84 °F	Barometric	Pb=	30.50 in H ₂ O			
Orifice	A=	47.8947		Moisture	bws=	1.83 %	Static Pres.	Pstat=	0.01 in H ₂ O			
Constants	B=	0.4763		Nozzle Dia.	Dn=	3.109 in	Stack Pres.	Ps=	30.50 in Hg			
				Nozzle Area	An=	7.59 sqin	Pitot	Cp=	0.8029			
TIME	Compartment POINT		Velocity	Correct	Orifice	Pressure	Temperature		Time	Rate	Volume	
	#	pt	Pressure dP inH ₂ O		in H ₂ O dHo Calc	in H ₂ O dHo Act	Orifice Tor	Stack Ts		min t	Standard Q@68°F	Standard @68°F
13:50												
13:57	13	3	0.0426	717.19	0.4935	0.4900	152.0	166.0	5.0	31.78	158.9	184.2
14:04	14	3	0.0423	698.49	0.5123	0.5200	150.0	138.0	5.0	32.74	163.7	189.2
14:11	15	3	0.0352	637.18	0.4210	0.4300	148.0	138.0	5.0	29.96	149.8	172.5
14:19	1	3	0.0396	674.70	0.4781	0.4800	148.0	136.0	5.0	31.57	157.8	181.8
14:26	2	3	0.0460	741.68	0.5439	0.5400	156.0	160.0	5.0	33.18	165.9	193.6
14:33	3	3	0.0483	760.00	0.5631	0.5700	146.0	160.0	5.0	34.32	171.6	196.9
14:41	4	3	0.0480	759.47	0.5658	0.5600	156.0	163.0	5.0	33.76	168.8	197.0
14:48	5	3	0.0313	612.79	0.3642	0.3600	160.0	162.0	5.0	27.27	136.4	160.1
14:55	6	3	0.0430	718.25	0.5115	0.5100	164.0	162.0	5.0	32.09	160.5	189.7
15:03	7	3	0.0371	667.15	0.4339	0.4300	158.0	162.0	5.0	29.73	148.6	174.0
15:10	8	3	0.0337	630.20	0.3977	0.4000	155.0	151.0	5.0	28.79	143.9	167.7
15:17	9	3	0.0327	625.84	0.3758	0.3900	150.0	161.0	5.0	28.55	142.8	164.9
Time weighting used in averaging. =>			686.91	0.4717	0.4733	153.58	154.92	60.00	31.14	1,868.7	2,171.5	
										Run#	3	
Sample Volume	V@68 (Pb/29.92)(1-bws/100)				dscf	Vd			1,870.0			
Total Flowrate	Outlet Flow				dscf/min	Qs			522.453			
Particulate					gr/dscf	Cg			0.00106			
Grain loading	0.01543 Wt/Vd				lb/hr	Ct			4.743			
Emissions	0.00857 Cg Qs											
LEAD					gr/dscf	Cg			1.21E-05			
Grain loading	0.01543 Lead/Vd				lb/hr	Ct			0.05434628801			
Emissions	0.00857 Cg Qs											
Avg Sample Rate	V@Tor / t				acf/min	Qan			36.19			
Avg Velocity @ Sample Point	vs=Qa/As				fpm	vs			686.91			
Avg Orifice temp					°R	Tor			613.25			
Avg Stack temp					°R	Ts			614.59			
Avg Nozzle Velocity	Qan*Ts / An*Tor				fpm	vn			687.99			
% ISOKINETIC	100 vn/vs				%I							

Blank Correction and Filter Rinse Allocation

Oregon Steel Mills Plant							1685	0.00%
ICA Baghouse-EAF Source							Tester	0.00%
07-Nov-2001 Date								
PARTICULATE		Filter	Wt less	Fraction	Rinse Residue	Filter Residue	TOTAL	
RUN I.D.	FILTER #	Sample Wt mg	Filter Blank mg	of total	Contribution mg	Contribution mg	mg	
1	6776164	85.6	85.1	29.56%	13.479	0.000	98.579	
2	6776159	92.5	92.0	31.96%	14.572	0.000	106.572	
3	6776161	111.3	110.8	38.49%	17.549	0.000	128.349	
TOTALS		289.40	287.90	100.00%	45.600	0.000	333.500	
Runs 1, 2, & 3								
Sampler rinse residue		715 ml		45.60 mg				
Blank Acetone		275 ml		-0.10 mg				
Blank correct residue				45.60 mg				
Sampler filter residue		999		0.0000 mg		System Blank		
Blank correct residue				0.0000 mg				
Blank Filter		6776163/60		0.50 mg		Lab Blank		
*LEAD		Filter	Wt less	Fraction	Rinse Residue	Filter Residue	TOTAL	
RUN I.D.	FILTER #	Sample Wt mg	Filter Blank mg (Corrected)	of total	Contribution mg	Contribution mg	mg	
1	6776164	1.0500	1.0445	29.39%	0.0814	0.0000	1.1259	
2	6776159	1.1500	1.1445	32.21%	0.0892	0.0000	1.2337	
3	6776161	1.3700	1.3645	38.40%	0.1063	0.0000	1.4708	
TOTALS		3.5700	3.5535	100.00%	0.2768	0.0000	3.8303	
Runs 1, 2, & 3								
Sampler rinse residue		715 ml		0.2790 mg				
Blank Acetone		275 ml		0.0008 mg				
Blank correct residue				0.2768 mg				
Sampler filter residue		999		0.0000 mg		System Blank		
Blank correct residue				0.0000 mg				
Blank Filter		6776163/60		0.0055 mg		Lab Blank		

ANTECH

Analysis/Technology

Mr. David Rossman
HORIZON ENGINEERING
13585 NE Whitaker
Portland OR 97220

97-28-07

November 26, 2001
Job# 0131400-06

Identification: OSM (Horizon # 1685)
Received: 11/10/01

<u>Sample #</u>	31400	31404
<u>Identification</u>	OSM Baghouse Rinse (Runs 1-3)	OSM blanks
<u>Front acetone rinse:</u>		
<u>Volume (mls)</u>	715	275
<u>Residue (g)</u>	0.0456	-0.0001

<u>Sample #</u>	31401	31402	31403	31405	31406
	Baghouse	Baghouse	Baghouse	#1	#2
<u>Identification</u>	Run 1	Run 2	Run 3	blank	blank
<u>Filters:</u>					
<u>numbers</u>	6776164	6776159	6776161	6776163	6776160
<u>Residue (g)</u>	0.0856	0.0925	0.1113	0.0009	0.0001

Respectfully submitted:
ANTECH


Diana Tracy
president

ANTECH

SAMPLE DATA: EPA 315 RESIDUES

Analyst: ML reviewer: _____
Job# 3140D-DC Identification: 2501 1638

HOUSE BLANKS:

ACETONE:		IMPINGER:		DCM:	
Sample #	<u>3</u>	_____	_____	_____	_____
Sample ID	_____	_____	_____	_____	_____
vol mark	_____	_____	_____	_____	_____
Date/time	_____	_____	_____	_____	_____
Into dessicator	_____	_____	_____	_____	_____
Vol(mls)	_____	date/time weighed	_____	date/time weighed	_____
GWt1(g)	_____	_____	_____	_____	_____
GWt2(g)	_____	_____	_____	_____	_____
GWt3(g)	_____	_____	_____	_____	_____
GWt4(g)	_____	_____	_____	_____	_____
GWt5(g)	_____	_____	_____	_____	_____
GWt6(g)	_____	_____	_____	_____	_____
Average	_____	_____	_____	_____	_____
Tare (g)	_____	_____	_____	_____	_____
Net (g)	_____	_____	_____	_____	_____

FILTER:		FILTER:		EMPTY:	
Sample #	_____	<u>lab blank</u>	_____	_____	_____
Sample ID	_____	<u>2776162</u>	_____	_____	_____
vol mark	_____	_____	_____	_____	_____
Date/time	_____	_____	_____	_____	_____
Into dessicator	_____	_____	_____	_____	_____
Vol(mls)	_____	date/time weighed	_____	date/time weighed	_____
GWt1(g)	_____	<u>4.2243</u>	<u>11-15 9A</u>	_____	_____
GWt2(g)	_____	<u>4.2233</u>	<u>11-16 9A</u>	_____	_____
GWt3(g)	_____	<u>4.2239</u>	<u>11-19 11A</u>	_____	_____
GWt4(g)	_____	<u>4.2237</u>	<u>11-20 9A</u>	_____	_____
GWt5(g)	_____	_____	_____	_____	_____
GWt6(g)	_____	_____	_____	_____	_____
Average	_____	<u>4.2238</u>	_____	_____	_____
Tare (g)	_____	<u>4.2241</u>	_____	_____	_____
Net (g)	_____	<u>-0.0003</u>	_____	_____	_____

ANTECH

SAMPLE DATA: EPA RESIDUES

Analyst: M.D. reviewer: _____
Job# 31400-06 Identification: OSM # 1638

FRONT ACETONE:

Sample # 31400 _____
Sample ID Bashon R1-3 _____
vol mark ✓✓ _____
Date/time 11/14 9:50P _____
Into dessicator _____
Vol(mls) 7.15 date/time weighed _____ date/time weighed _____ date/time weighed _____
GWt1(g) 141.5151 11-15 9A _____ _____ _____
GWt2(g) 141.5156 11-16 9A _____ _____ _____
GWt3(g) _____ _____ _____ _____
GWt4(g) _____ _____ _____ _____
GWt5(g) _____ _____ _____ _____
GWt6(g) _____ _____ _____ _____
Average 141.5159 _____ _____ _____ _____

Tare (g) 141.4703 11/13 3:50P _____ _____ _____
Net (g) .0456 _____ _____ _____ _____

BACK ACETONE:

Sample # _____
Sample ID _____
vol mark _____
Date/time _____
Into dessicator _____
Vol(mls) _____ date/time weighed _____ date/time weighed _____ date/time weighed _____
GWt1(g) _____ _____ _____ _____
GWt2(g) _____ _____ _____ _____
GWt3(g) _____ _____ _____ _____
GWt4(g) _____ _____ _____ _____
GWt5(g) _____ _____ _____ _____
GWt6(g) _____ _____ _____ _____
Average _____ _____ _____ _____

Tare (g) _____
Net (g) _____

ANTECH

SAMPLE DATA: EPA 315 RESIDUES

Analyst: MJS reviewer: _____
Job# 31400-06 Identification: DCM 1638

BLANKS:

ACETONE:

Sample # 31404
Sample ID OSM-All blanks
vol mark ✓
Date/time 11/14 9:50P
Into dessicator

IMPINGER WATER:

DCM:

Vol(mls)	date/time weighed	date/time weighed	date/time weighed
<u>275</u>			
GWt1(g)	<u>116.1804</u> 11-15 9A		
GWt2(g)	<u>116.1803</u> 11-16 9A		
GWt3(g)			
GWt4(g)			
GWt5(g)			
GWt6(g)			
Average	<u>116.1804</u>		
Tare (g)	<u>116.1805</u> 11/13 3:50P		
Net (g)	<u>-0.0001</u>		

FILTER:

Sample # 31405
Sample ID Blank #1
filter # 6776163
Date/time 11/11 9:00A
Into dessicator

FILTER:

31406
Blank #2
6776160
11/11 9:00A

31407
EMPTY
11/14 9:50P

Vol(mls)	date/time weighed	date/time weighed	date/time weighed
GWt1(g)	<u>4.2089</u> 11-15 9A	<u>4.2022</u> 4-15 9A	<u>107.8571</u> 11-15 9A
GWt2(g)	<u>4.2081</u> 11-16 9A	<u>4.2023</u> 4-16 9A	<u>107.8569</u> 11-16 9A
GWt3(g)	<u>4.2082</u> 11-19 11A	<u>4.2024</u> 4-19 11A	
GWt4(g)	<u>4.2089</u> 11-20 9A		
GWt5(g)			
GWt6(g)			
Average	<u>4.2089</u>	<u>4.2024</u>	<u>107.8570</u>
Tare (g)	<u>4.2080</u> 10-24-01	<u>4.2023</u> 6-1-01	<u>107.8575</u> 11/13 3:50P
Net (g)	<u>-0.0009</u>	<u>-0.0001</u>	<u>-0.0005</u>

ANTECH
 SAMPLE DATA: EPA RESIDUES (page 3)

FILTERS:

	31401		31402		31403	
Sample #	31401		31402		31403	
Sample ID	BHR1 6776164		BHR2 6776159		BHR3 6776161	
Date/time	11/11/01 9:00A		11/11/01 9:00A		11/11/01 9:00A	
In dessicator						
		Date/time		Date/time		Date/time
GWt1(g)	4.2953	11-15 9A	4.3149	11-15 9A	4.3277	11-15 9A
GWt2(g)	4.2945	11-16 9A	4.3139	11-16 9A	4.3265	11-16 9A
GWt3(g)	4.2941	11-18 11A	4.3140	11-19 11A	4.3267	11-19 11A
GWt4(g)						
Average	4.2944		4.3140		4.3266	
Tare (g)	4.2088	10-24-01	4.2215	6-3-01	4.2153	6-1-01
Net (g)	.0856		.0925		.1113	

FILTERS:

Sample #					
Sample ID					
Date/time					
In dessicator					
		Date/time		Date/time	
GWt1(g)					
GWt2(g)					
GWt3(g)					
GWt4(g)					
Average					
Tare (g)					
Net (g)					

QC DATA:

Date/time	11-13	11-15	11-16	11-18	11-19	11-20
Balance calibrated	✓	✓	✓	✓	✓	✓
(NTIS cert wts)	✓	✓	✓	✓	✓	✓
Date/time		9A	11A	1P	10A	8A
Temp/temp		69/63	72/63	68/61	68/61	67/59
Relative humidity (%)		70	61	67	67	62

ANALYTICAL BALANCE CALIBRATION FORM

Balance name Sauter Number _____

Classification of standard weights

Date	0.1000 g	1.0000 g	10.0000 g	50.0000 g	100.0000 g	Analyst
9-17-01	0.1000g	1.0000g			100.0000g	AW
9-18-01	0.0999g	1.0001g			100.0000g	AW
9-19-01	0.1000g	1.0000g			100.0001g	AW
9-20-01	0.0999g	1.0001g			100.0000g	AW
9-23-01	0.1000g	1.0001g			100.0000g	AW
9-24-01	0.1000g	1.0000g			100.0000g	AW
9-25-01	0.1000g	1.0000g			100.0001g	AW
9-26-01	0.1001g	1.0000g			100.0000g	AW
9-27-01	0.1000g	1.0001g			100.0000g	AW
9-28-01	0.0999g	1.0000g			100.0001g	AW
10-18-01	0.0999g	1.0000g			100.0000g	AW
10-21-01	0.0999g	.9999g			100.0000g	AW
10-25-01	0.0999g	1.0000g			100.0000g	AW
11-15-01	0.0999g	1.0000g			100.0000g	AW
11-16-01	0.1000g	1.0000g			100.0000g	AW
11-19-01	0.0999g	0.9999g			100.0000g	AW
11-20-01	0.1000g	1.0000g			100.0000g	AW

ANALYTICAL BALANCE CALIBRATION FORM

Balance name Autorain Number _____

Classification of standard weights _____

Date	0.500 g	1.0000 g	10.0000 g	50.0000 g	100.0000 g	Analyst
9-26-01	0.0999g	1.0000g			100.0000g	ms
	0.1000g	1.0000g			100.0000g	ms
9-28-01	0.1000g	1.0000g			100.0000g	ms
	0.1000g	1.0000g			100.0000g	ms
	0.0999g	1.0000g			100.0000g	ms
10-1-01	0.0999g	1.0000g			100.0000g	ms
	0.0999g	1.0000g			100.0000g	ms
10-1-01	0.1000g	1.0000g			100.0000g	ms
10-3-01	0.1000g	1.0000g			100.0000g	ms
10-7-01	0.1000g	1.0000g			100.0000g	ms
10-1-01	0.1000g	1.0000g			100.0000g	ms
10-2-01	0.1000g	1.0000g			100.0000g	ms
10-3-01	0.1000g	1.0000g			100.0000g	ms
10-16-01	0.0999g	1.0000g			100.0000g	ms
10-17-01	0.0999g	1.0000g			100.0000g	ms
10-21-01	0.1000g	1.0000g			100.0000g	ms
10-21-01	0.0999g	1.0000g			100.0000g	ms
10-23-01	0.1000g	1.0000g			100.0000g	ms
10-23-01	0.1000g	1.0000g			100.0000g	ms
10-23-01	0.1000g	1.0000g			100.0000g	ms
10-23-01	0.0999g	1.0000g			100.0000g	ms
10-24-01	0.0999g	1.0000g			100.0000g	ms
10-23-01	0.1000g	1.0000g			100.0000g	ms
10-29-01	0.1000g	1.0000g			100.0000g	ms
10-30-01	0.1000g	1.0000g			100.0000g	DLT
10-31-01	0.1000g	1.0000g			100.0000g	DLT
11-1-01	0.1000g	1.0000g			100.0000g	DLT
11-2-01	0.1000g	1.0000g			100.0000g	DLT
11-2-01	0.1000g	1.0000g			100.0000g	DLT
11-2-01	0.1000g	1.0000g			100.0000g	DLT
11-2-01	0.1000g	1.0000g			100.0000g	DLT
11-2-01	0.1000g	1.0000g			100.0000g	DLT
11-13-01	0.1000g	1.0000g			100.0000g	DLT
11-15-01	0.0999g	1.0000g			100.0000g	ms
11-16-01	0.1000g	1.0000g			100.0000g	ms
11-18-01	0.1000g	1.0000g			100.0000g	ms

nd

Horizon Tapes

These filters are stored in the desiccator

	5-31-01	6-1-01	6-3-01	6-4-01
6776137	4.2798	4.2805	4.2801	
138	4.2596	4.2602	4.2595	4.2597
139	4.2361	4.2375	4.2362	4.2363
140	4.2577	4.2585	4.2577	4.2576
141	4.2556	4.2571	4.2557	4.2558
6776142	4.2596	4.2603	4.2595	4.2578
143	4.2384	4.2391	4.2382	4.2384
144	4.2341	4.2349	4.2348	
145	4.2205	4.2233	4.2227	4.2222
146	4.2308	4.2314	4.2310	
6776147	4.2549	4.2555	4.2552	
148	4.2321	4.2335	4.2330	
149	4.2372	4.2399	4.2397	
150	4.2392	4.2398	4.2398	
151	4.2329	4.2334		
6776152	4.2251	4.2259	4.2257	
153	4.2224	4.2232	4.2228	
154	4.2045	4.2051	4.2051	
155	4.2268	4.2279	4.2278	
156	4.2307	4.2314	4.2314	
6776157	4.2271	4.2278	4.2278	
158	4.2387	4.2389	4.2386	
✓159	4.2210	4.2215	4.2215	
✓160	4.2026	4.2028		
✓161	4.2179	4.2153		

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS



Horizon News

These filters are kept in the Association

	10-18-01	10-24-01	10-25-01
6776163	4.2081	4.2082	
164	4.2090	4.2088	
165	4.2409	4.2404	
166	4.2224	4.2223	
167	4.2286	4.2270	
6776168	4.2261	4.2259	
169	4.1966	4.1966	
170	4.1837	4.1835	
171	4.2647	4.2645	
172	4.2580	4.2581	
6776173	4.2680	4.2679	
174	4.2340	4.2337	
175	4.2230	4.2229	
176	4.2462	4.2458	
177	4.2396	4.2400	
6776178	4.2336	4.2338	
179	4.2233	4.2234	
180	4.2248	4.2248	
181	4.2192	4.2192	
182	4.2388	4.2383	
6776183	4.2263	4.2266	
184	4.2059	4.2056	
6856201	4.2988	4.2980	4.2983
202	4.3266	4.3268	
203	4.3183	4.3181	
6856204	4.3160	4.3160	
205	4.3176	4.3176	
206	4.3775	4.3775	
207	4.3876	4.3874	
208	4.3307	4.3308	
6856209	4.2982	4.2982	
210	4.3124	4.3122	
211	4.3089	4.3088	
212	4.2979	4.2976	
213	4.3405	4.3403	
6856214	4.3669	4.3672	
215	4.3529	4.3530	
216	4.3478	4.3478	
217	4.3120	4.3108	
218	4.3454	4.3452	

22-141 50 SHEETS
22-142 100 SHEETS
22-144 200 SHEETS





Environmental Services Laboratory, Inc.

E S L

17400 SW Upper Boones Ferry Road, Suite 270 • Portland, OR 97224 • (503) 670-8520

December 07, 2001

Nichole Karl
Horizon Engineering
13585 NE Whitaker Way
Portland, OR 97230
TEL: (503) 255-5050
FAX (503) 255-0505

RE: 1685 Audit/ OSM Audit Samples

Order No.: 0111195

Dear Nichole Karl,

Environmental Services Laboratory received 8 samples on 11/26/01 for the analyses presented in the following report.

The Samples were analyzed for the following tests:

ICP Metals (EPA 6010B)

There were no analytical problems encountered, and all data met laboratory QC criteria, unless noted in a Case Narrative. Results apply only to the samples analyzed. Reproduction of this report is permitted only in its entirety, without the written approval of the Laboratory.

The following checked data sections are included in this report, and numbered to indicate total pages within each report section.

Base Sample Report Method Blank Report Sample Duplicate Report
 Matrix Spike/Matrix Spike Duplicate Report Laboratory Control Spike/Spike Duplicate Report
 Continuing Calibration Verification Report Initial Calibration Verification Report

If you have any questions regarding these test results, please feel free to call.

Sincerely,


Leslie Rush
Project Manager


Keith Hunter
Technical Review

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-01A

Client Sample ID: Filter Run 1(6776164)
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 8010B				Analyst: lmr
Lead	1.050	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
 Lab Order: 0111195
 Project: 1685 Audit/ OSM Audit Samples
 Lab ID: 0111195-02A

Client Sample ID: Filter Run 2(6776159)
 Tag Number:
 Collection Date: 11/21/01
 Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 8010B				Analyst: lmr
Lead	1.150	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 * - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-03A

Client Sample ID: Filter Run 3(6776161)
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	1,370	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
I - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-04A

Client Sample ID: Filter blank 1(6776163)
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	3.30	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-05A

Client Sample ID: Filter blank 2(6776160)
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 8010B				Analyst: lmr
Lead	7.70	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-06A

Client Sample ID: 31400 Acetone rinse
Tag Number:
Collection Date: 11/21/01
Matrix: SOLID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	279	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-07A

Client Sample ID: 31404 Acetone blank
Tag Number:
Collection Date: 11/21/01
Matrix: SOLID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	0.840	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
I - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

7 of 8

13

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111195
Project: 1685 Audit/ OSM Audit Samples
Lab ID: 0111195-08A

Client Sample ID: 314 Lab blank
Tag Number:
Collection Date: 11/21/01
Matrix: SOLID

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	ND	0.500		ug	1	12/3/01

Qualifiers:
ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

8 of 8

44

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Work Order: 0111195
Project: 1685 Audit/ OSM Audit Samples

QC SUMMARY REPORT

Method Blank

Sample ID	Batch ID	Test Code	EPA 6010B	Units: mg/Kg	Analysis Date	12/3/01	Prep Date	11/30/01			
Client ID	0111195	Run ID	ICP_011203A		SeqNo:	98967					
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND										

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Environmental Services Laboratory

CLIENT: Horizon Engineering
Work Order: 0111195
Project: 1685 Audit/OSM Audit Samples
Sample ID: LCS-3578 **Batch ID:** 3578 **Test Code:** EPA 6010B **Units:** mg/Kg
Client ID: 0111195 **Run ID:** ICP_011203A **Analysis Date:** 12/3/01 **Prep Date:** 11/30/01
Analyte: **Result:** **POL:** **SPK value:** **SPK Ref Val:** **%REC:** **LowLimit:** **HighLimit:** **RPD Ref Val:** **%RPD:** **RPDLimit:** **Qual:**
Lead: 49.4 1 50 0 98.8% 80 120 0 0

QC SUMMARY REPORT

Laboratory Control Spike - generic

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
 Work Order: 0111195
 Project: 1685 Audit/ OSM Audit Samples

QC SUMMARY REPORT

Minerals ICV for ICP

Sample ID: ICVHI	Batch ID: 3578	Test Code: EPA 6010B	Units: mg/L	Analysis Date: 12/3/01	Prep Date: 11/30/01						
Client ID	0111195	Run ID: ICP_011203A		SeqNo: 98965							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	9.98	0.005	10	0	99.8%	90	110	0			
Sample ID: ICVLOW	Batch ID: 3578	Test Code: EPA 6010B	Units: mg/L	Analysis Date: 12/3/01	Prep Date: 11/30/01						
Client ID	0111195	Run ID: ICP_011203A		SeqNo: 98965							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	.513	0.005	0.5	0	102.6%	90	110	0			

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank



13585 N.E. Whitaker Way
 Portland, OR 97230
 Ph. (503)255-5060
 Fax (503)255-0505
 horizons@teleport.com

TO: ESL

CHAIN OF CUSTODY REPORT

REPORT TO: Horizon Engineering
 ATTENTION: Mike Wallace
 ADDRESS: 13585 NE Whitaker Way
 Portland, OR 97230
 PHONE: 503-255-5050 FAX: 503-255-0505
 PROJECT NAME: OSM
 PROJECT NUMBER: 1685

INVOICE TO: Horizon Engineering
 ATTENTION: Penny Rossman
 ADDRESS: Same
 P.O. NUMBER:
 Analysis Request:

Work Order # [REDACTED]

TURNAROUND REQUEST in Business Days *

7
 5
 4
 3
 2
 1
 0

5
 4
 3
 2
 1
 0

5
 4
 3
 2
 1
 0

5
 4
 3
 2
 1
 0

CLIENT SAMPLE IDENTIFICATION	SAMPLING DATE/TIME	QUOTE #	MATRIX	W.S.A.O.	# OF CONTAINERS	COMMENTS
Filter Run 1 (6776164)						
Filter Run 2 (6776159)						
Filter Run 3 (6776161)						
Filter blanks 1 (6776163)						
Filter blank 2 (6776160)						
31400 Acetone rinse						
31404 Acetone blank						
314 lab blanks						

OTHER: [REDACTED]

* Incinerated Reports list their standard times under their Charge.


RECEIVED BY: Nichole Karl
 DATE: 11/20/01
 FIRM: horizon
 TIME: horizon

RECEIVED BY: S. MacLeod
 DATE: 11/21/01
 FIRM: ESL
 TIME: 1300

RECEIVED BY: [REDACTED]
 DATE: [REDACTED]
 FIRM: [REDACTED]
 TIME: [REDACTED]

ADDITIONAL REMARKS: Analysis by EPA 6010 (ICP). Digest complete. Filters reporting units should be (ug). Please analyze audit samples at the same time. Similar to previous ESL job # 0101063 please call if you have any questions.

Baghouse Sampling Diagram



.....Horizon Engineering.....

Volume Flow Rate Determination
Flow Rate Determinations and Field Data
Traverse Point Location – Inlet & Outlet

Outlet Flow Rate Determination

Client Source Location	Compart Point	HI-VOL RUN #3															
		1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16
Oregon Steel Mills IC-A Baghouse-EAF Portland, OR 07-Nov-2001 MJE/TJH/CDB 1085 File Analysis QA Equipment Short Ridge, TN Run #3	K L *M N O K L *M N O	0.0312 0.0302 0.0373 0.0472 0.0519	0.0371 0.0352 0.0434 0.0555 0.0596	0.0371 0.0452 0.0421 0.0534 0.0636	0.0328 0.0312 0.0420 0.0553 0.0787	0.0344 0.0337 0.0303 0.0367 0.0323	0.0277 0.0303 0.0370 0.0474 0.0422	0.0351 0.0352 0.0378 0.0422 0.0529	0.0137 0.0283 0.0291 0.0445 0.0529	A B *C D E	0.0113 0.0339 0.0373 0.0418 0.0393	0.0176 0.0265 0.0285 0.0324 0.0354	0.0193 0.0277 0.0299 0.0326 0.0422	0.0349 0.0293 0.0406 0.0629 0.0550	0.0452 0.0326 0.0332 0.0491 0.0528	0.0191 0.0438 0.0363 0.0339 0.0430	0.0175 0.0363 0.0377 0.0430 0.0448
All Points Standard Deviation	0.1944 0.0994	0.1977 0.1060	0.2132 0.1078	0.2187 0.1104	0.2157 0.1112	0.1766 0.0885	0.2052 0.1047	0.1925 0.0964	0.1794 0.0938	0.1772 0.0922	0.1615 0.0832	0.1761 0.0923	0.2091 0.1066	0.2053 0.1037	0.2023 0.1044	0.1855 0.0949	0.1944 0.0994
Symbol	Method/Notes	Time															
As Cp Ts Tdb Twb Pbar Ps dpr % mg Oxygen Carbon Dioxide Ms vs Qa Qad (3 pt)	in: -F *R -F -F in Hg in H2O in Hg Moisture, % Stack Mole fraction dry gas Outlet-Estimated Outlet-Estimated Molecular weight Dry Molecular weight Wet Velocity stack Flowrate actual Flowrate @Std Average Flow During Hi-vol testing	9.308 0.8029 136.0 595.7 141.0 34.0 30.50 0.01 30.50 0.1977 1.83 98.2%	9.308 0.8029 160.0 619.7 141.0 34.0 30.50 0.01 30.50 0.2132 1.83 98.2%	9.308 0.8029 160.0 619.7 141.0 34.0 30.50 0.01 30.50 0.2187 1.83 98.2%	9.308 0.8029 163.0 622.7 141.0 34.0 30.50 0.01 30.50 0.2157 1.83 98.2%	9.308 0.8029 162.0 621.7 141.0 34.0 30.50 0.01 30.50 0.1766 1.83 98.2%	9.308 0.8029 162.0 621.7 141.0 34.0 30.50 0.01 30.50 0.2052 1.83 98.2%	9.308 0.8029 162.0 621.7 141.0 34.0 30.50 0.01 30.50 0.1925 1.83 98.2%	9.308 0.8029 151.0 610.7 141.0 34.0 30.50 0.01 30.50 0.1794 1.83 98.2%	9.308 0.8029 161.0 620.7 141.0 34.0 30.50 0.01 30.50 0.1772 1.83 98.2%	9.308 0.8029 164.0 623.7 141.0 34.0 30.50 0.01 30.50 0.1615 1.83 98.2%	9.308 0.8029 159.0 618.7 141.0 34.0 30.50 0.01 30.50 0.1761 1.83 98.2%	9.308 0.8029 159.0 618.7 141.0 34.0 30.50 0.01 30.50 0.2091 1.83 98.2%	9.308 0.8029 166.0 625.7 141.0 34.0 30.50 0.01 30.50 0.2053 1.83 98.2%	9.308 0.8029 138.0 597.7 141.0 34.0 30.50 0.01 30.50 0.2023 1.83 98.2%	9.308 0.8029 138.0 597.7 141.0 34.0 30.50 0.01 30.50 0.1855 1.83 98.2%	
Avg/Total	15	14 Oct 25 Cumpart															
		156.1															
		670.1 43,316 37,152															

* High volume sampler tested these points (in bold)

Inlet Flow Rate Determination

Client Oregon Steel Mills			Pre-test				Post-Test			
Source	EAF Baghouse INLET	Compartment Point	dP (inH2O)	Ts (°F)	dP (inH2O)	Ts (°F)	dP (inH2O)	Ts (°F)	dP (inH2O)	Ts (°F)
Location	Portland, OR		1.9310	na	2.5280	na	1.4460	na	2.3840	na
Date	07-Nov-2001	1	1.8160	na	2.3310	na	1.5850	na	1.5680	na
Testers	MJE/TJH/CDB	2	1.8070	na	2.0890	na	1.5460	na	1.4240	na
File	1685	3	2.0110	na	2.5850	na	1.3370	na	1.8360	na
Analysis/QA	MEW	4	1.9830	na	2.5450	na	1.6230	na	2.3140	na
Equipment	ShortRidge #2.pitot 14	5	1.9680	na	2.4990	na	1.9090	na	2.0890	na
Total Runs	2	6	1.9240	na	2.4750	na	1.5210	na	2.2170	na
Pts per Run	48	7	1.2860	na	2.5220	na	1.4840	na	1.6570	na
		8	1.7780	na	2.6850	na	1.2260	na	2.1340	na
		9	1.4420	na	2.3380	na	1.2560	na	1.8200	na
		10	1.4500	na	1.8420	na	1.3480	na	2.0460	na
		11	1.2990	na	2.0850	na	2.0160	na	1.8150	na
		12	2.3330	na	2.1250	na	2.1670	na	1.5960	na
		13	2.3450	na	2.0510	na	2.3300	na	1.3260	na
		14	2.4040	na	1.9520	na	2.4080	na	1.7700	na
		15	2.6280	na	1.6260	na	2.2150	na	1.2500	na
		16	2.2770	na	1.9780	na	2.6950	na	1.5900	na
		17	2.9890	na	2.3570	na	2.1530	na	1.4700	na
		18	2.6280	na	2.0780	na	2.6940	na	1.5400	na
		19	2.6130	na	2.5070	na	2.4360	na	1.7870	na
		20	2.6580	na	2.4340	na	2.4760	na	1.7750	na
		21	3.0220	na	2.4080	na	2.2940	na	1.8880	na
		22	2.6840	na	2.4890	na	2.6330	na	1.9970	na
		23	2.2980	na	2.3180	na	2.7820	na	1.9140	na
		24								
All Points	SQRT(dP)		1.4824	sqrt(dP)	0.0	(°F)	1.3666	sqrt(dP)	0.0	(°F)

Symbol	Definitions, Units	Method/Notes	Pre-test	Post-Test	Average
	Time		09:50	15:20	
As	Cross Section	in ²	13,685	13,685	
Cp	Pitot Coef.		0.8237	0.8237	
Ts	Duct temperature	°F	162.0	212.0	187.0
Twb	Duct temperature	°F	88.0	109.0	
Ts	Duct temperature	°R	621.7	671.7	
Pbar	Barometric Pressure	in Hg	30.25	30.25	
Pg	Static Pressure	in H2O	-16.00	-7.00	
Ps	Duct Pressure	in Hg	29.07	29.74	
dp ^{1/2}			1.4824	1.3666	
Bws	Moisture, % Stack	(inlet)	1.95	4.85	3.40
Bws	Moisture, % Stack	(outlet)	1.91	1.83	1.87
mfg	Mole fraction dry gas		98.1%	95.1%	
Md (inlet)	Molecular weight Dry		29.03	29.03	
Ms (inlet)	Molecular weight Wet		28.82	28.50	
vs	Velocity stack	fpm	5.395	5.141	5.268
Qa	Flowrate actual	acf/min	512,722	488,535	500,628
Qsd (Inlet)	Flowrate @std	dscf/min	414,631	362,910	388,771
Qsd (Outlet)	Flowrate @std	dscf/min			525,906
	Difference	(Out-In)/In			35.3%



13585 N.E. Whitaker Way
 Portland, OR 97230
 Phone (503)255-5050
 Fax (503)255-0505

VOLUME FLOWRATE MEASUREMENT

Plant OSM
 Sampling Location Baghouse Outlet
 Test Conditions Normal
 Date 11/7/01 Time _____
 Duct Dimensions _____
 Duct Area _____ in²
 Gauge I.D. 5/8" in H₂O By ATA
 Post Test Leak Check O₂ @ 20

Cyclonic Flow ? Yes ___ No Avg Null Angle _____
 P₀ = Barometric Pressure 30.5 in Hg
 C_p = Pitot Coefficient 0.96294
 Pilot I.D. 11-5

Run #	2									
Time	1159									
Pt 1	.0143		31	.0420		71	.0207		111	.0195
2	.0371		2	.0440		2	.0363		2	.0277
3	.0352		3	.0262		3	.0339		3	.0226
4	.0493		4	.0537		4	.0411		4	.0292
5	.0528	.0377	5	.0882	.0508	5	.0602	.0384	5	.0642
Vs 1	.0178		41	.0304		81	.0239		21	.0349
2	.0207		2	.0511		2	.0302		2	.0295
3	.0195		3	.0416		3	.0375		3	.0406
4	.0357		4	.0812		4	.0428		4	.0629
5	.0492	.0286	5	.0633	.0535	5	.0928	.0454	5	.0556
1-1	.0376		51	.0130		71	.0332			
2	.0390		2	.0262		2	.0457			
3	.0537		3	.0362		3	.0342			
4	.0422		4	.0409		4	.0513			
5	.0635	.0432	5	.0467	.0326	5	.0858	.0500		
2-1	.0297		61	.0280		81	.0192			
2	.0356		2	.0283		2	.0268			
3	.0348		3	.0324		3	.0275			
4	.0338		4	.0336		4	.0342			
5	.0720	.0412	5	.0396	.0324	5	.0748	.0365		
Avg ΔP										

Symbol	Definition, Units	Method/Equation	Run 1	Run 2	Run 3	Average
T _{db}	Dry bulb temp., °F		137			
T _{wb}	Wet bulb temp., °F		98			
P _{stat}	Static press., in H ₂ O		0.0348			
T _s	Duct temp., °R	T _{db} + 460				
P _s	Duct press., in Hg	P ₀ ± P _{stat} /13.6				
S		Avg ΔP × √T _s				
mv	% H ₂ O in gas stream	Psychrometry				
md	Mole fraction dry gas	1.00 - mv/100				
Md	Molecular weight of dry gas	Gas analysis				
Ms	Molecular wt of aq. gas	Ms = mdMd + 18 (1-md)				
Vs	Velocity, fpm	Vs = 5125s (1/PsMs) ^{1/2} (Cp)				
qa	Actual flowrate, acfm	qa = VsAs/144				
qs	Flowrate @ std cond, scfm	qs = 0.123 VsAs md Ps / Ts				



13585 N.E. Whilaker Way
 Portland, OR 97230
 Phone (503)255-5050
 Fax (503)255-0505

VOLUME FLOWRATE MEASUREMENT

Plant OSM
 Sampling Location Baghouse Outlet
 Test Conditions Normal
 Date 11/7/01 Time _____
 Duct Dimensions _____
 Duct Area _____ in²
 Gauge I.D. SR 2 in H₂O By TJH
 Post Test Leak Check 0 in H₂O

Cyclonic Flow ? Yes ___ No Avg Null Angle _____
 P₀ = Barometric Pressure 30.5 in Hg
 C_p = Pitot Coefficient 0.80294
 Pitot I.D. 11.5

Run #	Time								
1	0452		21	.0371		61	.0277		0116
2	.0326		2	.0352		2	.0303		0265
3	.0332		3	.0420		3	.0474		0285
4	.0491		4	.0555		4	.0542		0324
5	.0528	.0426	5	.0596	.0460	5	.0552	.0430	0354
14	1	0191	2	.0371		7	.0351		
2	0438		2	.0452		2	.0352		
3	.0377		3	.0421		3	.0378		
4	.0490		4	.0534		4	.0422		
5	0618	.0423	5	.0630	.0483	5	.0352	.0371	
15	1	0175	9	.0329		8	.0137		
2	0363		2	.0312		2	.0283		
3	.0331		3	.0420		3	.0291		
4	.0436		4	.0553		4	.0445		
5	.0418	.0352	5	.0787	.0480	5	.0529	.0337	
1	6	0312	5	.0344		9	.0113		
2	0302		2	.0337		2	.0339		
3	.0373		3	.0267		3	.0375		
4	.0472		4	.0323		4	.0418		
5	0519	.0396	5	.0292	.0313	5	.0393	.0327	
Avg ΔP									

Symbol	Definition, Units	Method/Equation	Run 1	Run 2	Run 3	Average
T _{db}	Dry bulb temp., °F					
T _{wb}	Wet bulb temp., °F					
P _{stat}	Static press., in H ₂ O		0.0132			
T _s	Duct temp., °R	T _{db} + 460				
P _s	Duct press., in Hg	P ₀ ± P _{stat} /13.6				
S		Avg ΔP × √ T _s				
mv	% H ₂ O in gas stream	Psychrometry				
md	Mole fraction dry gas	1.00 - mv/100				
Md	Molecular weight of dry gas	Gas analysis				
Ms	Molecular wt of act. gas	Ms = mdMd + 18 (1-md)				
Vs	Velocity, fpm	Vs = 5125s (1/PsMs) ^{1/2} (Cp)				
qa	Actual flowrate, acfm	qa = VsAs/144				
qs	Flowrate @ std cond, scfm	qs = 0.123 VsAs md Ps / Ts				



13585 N.E. Whitaker Way
 Portland, OR 97230
 Phone (503)255-5050
 Fax (503)255-0505

VOLUME FLOWRATE MEASUREMENT

Plant OSTA
 Sampling Location Bag house Inlet start of
 Test Conditions Normal
 Date 11/7/01 Time _____
 Duct Dimensions _____
 Duct Area _____ in²
 Gauge I.D. 5/2#2 in H₂O By ESS/BPG
 Post Test Leak Check 0.6 H₂O/min

Cyclonic Flow ? Yes ___ No X Avg Null Angle _____
 P₀ = Barometric Pressure 30.25 in Hg
 C_p = Pitot Coefficient 0.82367
 Pitot I.D. 1/8

Run #	11 start of runs								
Time	9:50								
P1	1,931	22	3,622	19	2,078				
2	1,816	23	2,684	20	2,507				
3	1,807	24	2,298	21	2,434				
4	2,011	8	2,528	22	2,408				
5	1,983	2	2,331	23	2,489				
6	1,968	3	2,089	24	2,318				
7	1,924	4	2,585						
8	1,286	5	2,545						
9	1,778	6	2,499						
10	1,442	7	2,475						
11	1,460	8	2,522						
12	1,299	9	2,685						
13	2,339	10	2,938						
14	2,345	11	1,842						
15	2,404	12	2,085						
16	2,628	13	2,125						
17	2,277	14	2,051						
18	2,989	15	1,952						
19	2,628	16	1,626						
20	2,613	17	1,978						
21	2,658	18	2,357						
Avg ΔP									

Symbol	Definition, Units	Method/Equation	Run 1	Run 2	Run 3	Average
T _{db}	Dry bulb temp., °F		162			
T _{wb}	Wet bulb temp., °F		98			
P _{stat}	Static press., in H ₂ O		-16			
T _s	Duct temp., °R	T _{db} + 460				
P _s	Duct press., in Hg	P ₀ ± P _{stat} /13.6				
S		Avg ΔP × √ T _s				
mv	% H ₂ O in gas stream	Psychrometry				
md	Mole fraction dry gas	1.00 - mv/100				
Md	Molecular weight of dry gas	Gas analysis				
Ms	Molecular wt of act. gas	Ms = mdMd + 18 (1-md)				
Vs	Velocity, fpm	Vs = 5125s (1/PsMs) ^{1/2} (Cp)				
qa	Actual flowrate, acfm	qa = VsAs/144				
qs	Flowrate @ std cond, scfm	qs = 0.123 VsAs md Ps / T _s				



13585 N.E. Whitaker Way
 Portland, OR 97230
 Phone (503)255-5050
 Fax (503)255-0505

VOLUME FLOWRATE MEASUREMENT

Plant OSM
 Sampling Location Baghouse Inlet End of Run
 Test Conditions Normal
 Date 11.7.01 Time _____
 Duct Dimensions _____
 Duct Area _____ in²
 Gauge I.D. SR2 in H₂O By BAQ
 Post Test Leak Check 0.0 H₂O

Cyclonic Flow ? Yes ___ No Avg Null Angle _____
 P₀ = Barometric Pressure 30.5 in Hg
 C_p = Pitot Coefficient 0.82367
 Pitot I.D. 1/4 S

Run #	<u>End of Runs</u>					
Time	<u>1520</u>					
Pt /						
1	<u>1.446</u>	<u>21</u>	<u>2.476</u>	<u>41</u>	<u>1.590</u>	
2	<u>1.585</u>	<u>22</u>	<u>2.294</u>	<u>42</u>	<u>1.470</u>	
3	<u>1.546</u>	<u>23</u>	<u>2.633</u>	<u>43</u>	<u>1.540</u>	
4	<u>1.337</u>	<u>24</u>	<u>2.782</u>	<u>44</u>	<u>1.787</u>	
5	<u>1.623</u>	<u>25</u>	<u>2.384</u>	<u>45</u>	<u>1.775</u>	
6	<u>1.909</u>	<u>26</u>	<u>1.668</u>	<u>46</u>	<u>1.888</u>	
7	<u>1.521</u>	<u>27</u>	<u>1.424</u>	<u>47</u>	<u>1.997</u>	
8	<u>1.484</u>	<u>28</u>	<u>1.836</u>	<u>48</u>	<u>1.914</u>	
9	<u>1.226</u>	<u>29</u>	<u>2.314</u>			
10	<u>1.256</u>	<u>30</u>	<u>2.089</u>			
11	<u>1.349</u>	<u>31</u>	<u>2.217</u>			
12	<u>2.016</u>	<u>32</u>	<u>1.657</u>			
13	<u>2.167</u>	<u>33</u>	<u>2.134</u>			
14	<u>2.330</u>	<u>34</u>	<u>1.820</u>			
15	<u>2.408</u>	<u>35</u>	<u>2.046</u>			
16	<u>2.215</u>	<u>36</u>	<u>1.915</u>			
17	<u>2.695</u>	<u>37</u>	<u>1.596</u>			
18	<u>2.153</u>	<u>38</u>	<u>1.326</u>			
19	<u>2.694</u>	<u>39</u>	<u>1.770</u>			
20	<u>2.436</u>	<u>40</u>	<u>1.250</u>			

Avg ΔP _____


Symbol	Definition, Units	Method/Equation	Run 1	Run 2	Run 3	Average
T _{db}	Dry bulb temp., °F			<u>212</u>		
T _{wb}	Wet bulb temp., °F			<u>109</u>		
P _{stat}	Static press., in H ₂ O					
T _s	Duct temp., °R	T _{db} + 460				
P _s	Duct press., in Hg	P ₀ ± P _{stat} /13.6				
S		Avg √ΔP × √T _s				
mv	% H ₂ O in gas stream	Psychrometry				
md	Mole fraction dry gas	1.00 - mv/100				
Md	Molecular weight of dry gas	Gas analysis				
Ms	Molecular wt of act. gas	Ms = mdMd + 18 (1-md)				
Vs	Velocity, fpm	Vs = 5125s (1/PsMs) ^{1/2} (Cp)				
qa	Actual flowrate, acfm	qa = VsAs/144				
qs	Flowrate @ std cond, scfm	qs = 0.123 VsAs md Ps / Ts				

58

Traverse Point Location

Client	Oregon Steel Mills	Portland, OR	Date
Location	Portland, OR	MJE/TJH/CDB	By
EPA Method #1	Baghouse Inlet	1685	File

Outer Circumference	(ft) [Co]	134.00 "
Wall thickness	(in) [t]	2.00 "
Inner Circumference	(ft) [Ci]	128.0 "
INSIDE of FAR WALL to OUTSIDE of Nipple	(in) [F]	516.0 "
INSIDE of NEAR WALL to OUTSIDE of Nipple	(in) [N]	132.00 "
DOWNStream Disturb	(in) [A]	128.0 "
UPStream Disturb	(in) [B]	516.0 "
Inner Diameter	(in) [Ds]	132.00 "
Area	(sqin) [As]	13,685
DOWNStream Ratio	[A/Ds]	1.0
UPStream Ratio	[B/Ds]	3.91
Traverse (Particulate)		24
Recommended #Pts/Diameter		12
Traverse (NON-Particulate)		16
Recommended #Pts/Diameter		8
Actual Points per Diameter		24



Trav Pt #No	Fract Stk ID (f)	Stack ID (Ds)	Actual Points (Dsxf)	Nearest 8ths (TP)	Adjusted Points (TP)*	Traverse Points (TP + N)	Traverse Points (TP + N)
1	1.05%	132.0	1.4	1.375	1.375	3.375	3 3 / 8
2	3.23%	132.0	4.3	4.250	4.250	6.250	6 1 / 4
3	5.51%	132.0	7.3	7.250	7.250	9.250	9 1 / 4
4	7.92%	132.0	10.5	10.500	10.500	12.500	12 1 / 2
5	10.47%	132.0	13.8	13.875	13.875	15.875	15 7 / 8
6	13.20%	132.0	17.4	17.375	17.375	19.375	19 3 / 8
7	16.15%	132.0	21.3	21.375	21.375	23.375	23 3 / 8
8	19.38%	132.0	25.6	25.625	25.625	27.625	27 5 / 8
9	23.00%	132.0	30.4	30.375	30.375	32.375	32 3 / 8
10	27.18%	132.0	35.9	35.875	35.875	37.875	37 7 / 8
11	32.32%	132.0	42.7	42.625	42.625	44.625	44 5 / 8
12	39.79%	132.0	52.5	52.500	52.500	54.500	54 1 / 2
13	60.21%	132.0	79.5	79.500	79.500	81.500	81 1 / 2
14	67.68%	132.0	89.3	89.375	89.375	91.375	91 3 / 8
15	72.82%	132.0	96.1	96.125	96.125	98.125	98 1 / 8
16	77.00%	132.0	101.6	101.625	101.625	103.625	103 5 / 8
17	80.62%	132.0	106.4	106.375	106.375	108.375	108 3 / 8
18	83.85%	132.0	110.7	110.625	110.625	112.625	112 5 / 8
19	86.80%	132.0	114.6	114.625	114.625	116.625	116 5 / 8
20	89.53%	132.0	118.2	118.125	118.125	120.125	120 1 / 8
21	92.08%	132.0	121.5	121.500	121.500	123.500	123 1 / 2
22	94.49%	132.0	124.7	124.750	124.750	126.750	126 3 / 4
23	96.77%	132.0	127.7	127.750	127.750	129.750	129 3 / 4
24	98.95%	132.0	130.6	130.625	130.625	132.625	132 5 / 8

Traverse Point Location

Client	Oregon Steel Mills			Portland, OR	Date
Location	Portland, OR			MJE/TJH/CDB	By
EPA Method #1	Outlet			1685	File
Number of PORTS	P	#	5		
INSIDE of FAR WALL to OUTSIDE of Nipple	F	in	52.0		
INSIDE of NEAR WALL to OUTSIDE of Nipple	N		0.00		
Stack/Duct WIDTH	Dw	in	179.0		
DOWNstream Disturb	A	in			
UPstream Disturb	B	in			
Stack/Duct DEPTH	Dh	in	52.0		
Equivalent Diameter	De	in	80.6		
Area	As	sqin	9308.0		
DOWNstream Ratio	A/De		0.00		
UPstream Ratio	B/De		0.00		
Traverse (Particulate)			25		
Recommended #Pts/Port		5	5		
Traverse (NON-Particulate)			16		
Recommended #Pts/Port		3	4		
Actual Points used per Port			5		
Actual Number of Points			25		

Trav Pt #No	Fract Depth (f)	Stack Depth (Dp)	Actual Points (Dpxf)	Nearest 8ths (TP)	Adjusted Points (TP)	Traverse Points (TP+N)	Traverse Points (TP+N)
1	10.00%	52.0	5.2	5.250	5.250	5.250	5 1 / 4
2	30.00%	52.0	15.6	15.625	15.625	15.625	15 5 / 8
3	50.00%	52.0	26.0	26.000	26.000	26.000	26
4	70.00%	52.0	36.4	36.375	36.375	36.375	36 3 / 8
5	90.00%	52.0	46.8	46.750	46.750	46.750	46 3 / 4

Visible Emission Data
Field Data
Certifications



13885 NE Whitaker Way • Portland, OR 97230
 Phone (503) 255-9060 • Fax (503) 255-0505
 www.horizonengineering.com

RUN 1

SOURCE INFORMATION

Company Name OSM

Address Portland OR

Phone #

VISIBLE EMISSION OBSERVATION FORM

OBSERVATION RECORD

DATE 11/7/01 TIME: Start 11:12 End 11:18

Source Description <u>EMF</u>	ID #
Operating Mode/Output Rate <u>Normal</u> <u>MAX</u>	
Control Equipment <u>Bushouse</u>	Operating Mode <u>Normal</u>
PLUME INFORMATION	@ Start @ End
Emission Point Description	<u>Metal</u> -
Height Above Ground	<u>75'</u> -
Height Relative to Observer	<u>70'</u> -
Distance from Observer	<u>300'</u> -
Direction from Observer	<u>North west</u> -
Plume Type: Continuous	<u>Yes</u> -
Intermittent	-
Fugitive	-
Plume Color	-
Water Droplets Present?	<u>NO</u> -
Attached Plume?	-
Detached Plume?	-
Point in the Plume at Which Opacity was Observed	<u>Top of BH</u> -
Description of Background	<u>sky</u> -
Color of Background	<u>Blue</u> -
Condition of Sky	<u>clear</u> -
Wind Speed (mph)	<u>0-3</u> -
Wind Direction (from)	<u>South</u> -
Ambient Temperature (°F)	<u>55</u> -
Relative Humidity (Pb)	<u>> 50%</u> -

MIN	Seconds				MIN	Seconds			
	0	15	30	45		0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0				37				
8					38				
9					39				
10					40				
11					41				
12					42				
13					43				
14					44				
15					45				
16					46				
17					47				
18					48				
19					49				
20					50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30					60				

Source Layout Sketch

Draw North Arrow

Emission Point

Observers Position

Sun Location Line

Comments

Range of Opacity Readings Max _____ %
 Min _____ %

Number of Readings Above _____ %

Average Opacity for _____ Readings = _____ %

Observer's Name (print) Mike Eiseler Certification No. 1224

Organization: Horizon Engineering, Portland, Oregon

Certified By: _____ Date: _____

ODEQ _____

Observer's Signature: Mike Eiseler Date: 11/7/01



13585 NE Whiskey Way - Portland, OR 97230
 Phone (503) 255-5050 - Fax (503) 255-0505
 www.horizonengineering.com

Run 2

SOURCE INFORMATION	
Company Name	OSM
Address	Portland OR
Phone #	

Source Description	ID #	
EA F		
Operating Mode/Output Rate	Normal Max	
Control Equipment	Operating Mode	
Baars 056	Normal	
PLUME INFORMATION	@ Start	@ End
Emission Point Description	Meta	-
Height Above Ground	75'	-
Height Relative to Observer	70'	-
Distance from Observer	300'	-
Direction from Observer	NW	-
Plume Type: Continuous	yes	-
Intermittent	-	-
Fugitive	-	-
Plume Color	-	-
Water Droplets Present?	NO	-
Attached Plume?	-	-
Detached Plume?	-	-
Point in the Plume at Which Opacity was Observed	TOP BH of	-
Description of Background	sky	-
Color of Background	Blue	-
Condition of Sky	Clear	-
Wind Speed (mph)	calm	-
Wind Direction (from)	-	-
Ambient Temperature (°F)	55	-
Relative Humidity (Pb)	750%	-

VISIBLE EMISSION OBSERVATION FORM

OBSERVATION RECORD		
DATE	TIME	
11/7/01	Start 12:19	End 12:25

MIN	Seconds				MIN	Seconds			
	0	15	30	45		0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0				37				
8					38				
9					39				
10					40				
11					41				
12					42				
13					43				
14					44				
15					45				
16					46				
17					47				
18					48				
19					49				
20					50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30					60				

Source Layout Sketch	Draw North Arrow
Comments	

Range of Opacity Readings	Max	%
	Min	%
Number of Readings Above	%	
Average Opacity for	Readings =	%

Observer's Name (print)	Certification No.
Mike E. Seale	1224
Organization:	
Horizon Engineering, Portland, Oregon	

Certified By:	Date:
ODEQ	
Observer's Signature:	Date:
	11/7/01



1355 NE Whiskey Way • Portland, OR 97230
 Phone (503) 255-0060 • Fax (503) 255-0505
 www.horizonengineering.com

Run 3

SOURCE INFORMATION

Company Name OSM
 Address Portland OR
 Phone # _____

Source Description EAP ID # _____

Operating Mode/Output Rate
NCR Max Max

Control Equipment Baghouse Operating Mode NCR Max

PLUME INFORMATION	@ Start	@ End
Emission Point Description	<u>Metal</u>	-
Height Above Ground	<u>75'</u>	-
Height Relative to Observer	<u>70'</u>	-
Distance from Observer	<u>300</u>	-
Direction from Observer	<u>NW</u>	-
Plume Type: Continuous	<u>Yes</u>	-
Intermittent	-	-
Fugitive	-	-
Plume Color	-	-
Water Droplets Present?	<u>NO</u>	-
Attached Plume?	-	-
Detached Plume?	-	-
Point in the Plume at Which Opacity was Observed	<u>Top of Baghouse</u>	-
Description of Background	<u>sky</u>	-
Color of Background	<u>Blue</u>	-
Condition of Sky	<u>clear</u>	-
Wind Speed ()	<u>calm</u>	-
Wind Direction (from)	-	-
Ambient Temperature (°F)	<u>60</u>	-
Relative Humidity (Pb)	<u>~50%</u>	-

VISIBLE EMISSION OBSERVATION FORM

OBSERVATION RECORD
 DATE 11/7/01 TIME: Start 1409 End 1419

Seconds					Seconds				
MIN	0	15	30	45	MIN	0	15	30	45
1	0	0	0	0	31				
2	0	0	0	0	32				
3	0	0	0	0	33				
4	0	0	0	0	34				
5	0	0	0	0	35				
6	0	0	0	0	36				
7	0				37				
8					38				
9					39				
10					40				
11					41				
12					42				
13					43				
14					44				
15					45				
16					46				
17					47				
18					48				
19					49				
20					50				
21					51				
22					52				
23					53				
24					54				
25					55				
26					56				
27					57				
28					58				
29					59				
30					60				

Source Layout Sketch

Draw North Arrow

Emission Point

Observers Position

Sun Location Line

Comments

Range of Opacity Readings	Max	_____ %
	Min	_____ %
Number of Readings Above _____ %		_____ %
Average Opacity for _____ Readings =		_____ %

Observer's Name (print) Mike Eisele Certification No. 1224
 Organization: Horizon Engineering, Portland, Oregon

Certified By: _____ Date: _____
 ODEQ
 Observer's Signature: Mike Eisele Date: 11/7/01




13585 N.E. Whitaker Way • Portland, OR 97230
Phone (503)255-5050 • Fax (503)255-0505
www.horizonengineering.com

OREGON DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY CONTROL DIVISION

CERTIFICATION OF COMPLETION
PLUME EVALUATION TRAINING

Michael Eisgle



CERTIFICATION NO. 1224

EXPIRATION DATE 3/29/2002

Mary M. Abrams
ADMINISTRATOR

Gaseous Emissions

Gaseous Emissions Determinations

Molecular Weight Determinations

Analyzer Calibration Data, Manual Data

Bias Checks

Data Logger Gas Charts

Strip Charts

Gaseous Emissions

Client	Oregon Steel Mills		MJE/TJH/CDB		Testers		
Source	ICA Baghouse-EAF Inlet		1685		File		
Location	Portland, OR		MEW		Analysis/QA		
Date	07-Nov-2001						
Number of Completed Runs			Combined	Run 1	Run 2	Run 3	Average
Date Tested							
System Calibration Time - Initial	Tci		08:35	08:35	08:35	08:35	
Test Time-Starting	Tts		10:31	10:31	12:09	13:50	
Test Time-Ending	Tte		15:14	12:05	13:33	15:17	
System Calibration Time - Final	Tcf		15:20	15:20	15:20	15:20	
Test Mid-point Time	Tx		12:52	11:18	12:51	14:33	
Volumetric Flowrate, Dry Standard	dscf/min	Qsd	388,771	388,771	388,771	388,771	
Production	Tons/hr		138.2	137.4	139.4	137.8	138.2
Oxygen	% O2		20.51	20.51	20.45	20.49	
Carbon Dioxide	% CO2		0.55	0.55	0.53	0.62	
Carbon Monoxide	CO	Span	1.000	1,000	1,000	1,000	
Indicated average - Dry	ppmv	Cid	143.1	198.0	133.7	123.6	151.8
Cylinder Value - High Range calibration gas	ppmv	Cma	880.0	880.0	880.0	880.0	
Cylinder Value - Low Range (Zero) calibration gas	ppmv	Coa	0.0	0.0	0.0	0.0	
System Calibration Response - High Range gas - Initial	ppmv	Cmi	857.4	857.4	857.4	857.4	
System Calibration Response - Low Range gas - Initial	ppmv	Coi	-0.8	-0.8	-0.8	-0.8	
System Calibration Response - Low Range gas - Final	ppmv	Cof	-0.9	-0.9	-0.9	-0.9	
System Calibration Response - High Range gas - Final	ppmv	Cmf	883.3	883.3	883.3	883.3	
Actual average - Dry (Corrected for Drift)	ppmv-CO	Cgas	144.8	201.5	135.4	124.3	153.7
Mass Emissions	lbm / hr	Mgas	245.6	341.6	229.6	210.8	260.7
Mass Emissions on Production Basis	lbm/Ton		1.777	2.487	1.647	1.530	1.888
Nitrogen Oxides	NOx	Span	250	250	250	250	
Indicated average-Dry	ppmv	Cid	10.22	10.88	11.53	10.15	10.85
Cylinder Value - High Range calibration gas	ppmv	Cma	89.80	89.80	89.80	89.80	
Cylinder Value - Low Range (Zero) calibration gas	ppmv	Coa	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initial	ppmv	Cmi	88.29	88.29	88.29	88.29	
System Calibration Response - Low Range gas - Initial	ppmv	Coi	0.48	0.48	0.48	0.48	
System Calibration Response - Low Range gas - Final	ppmv	Cof	-0.17	-0.17	-0.17	-0.17	
System Calibration Response - High Range gas - Final	ppmv	Cmf	86.46	86.46	86.46	86.46	
Actual average - Dry (Corrected for Drift)	ppmv-NO2	Cgas	10.47	10.96	11.82	10.60	11.13
Mass Emissions	lbm-NO2 / hr	Mgas	29.17	30.53	32.92	29.53	30.99
Mass Emissions on Production Basis	lbm/Ton		0.211	0.222	0.236	0.214	0.224
Sulfur Dioxide	SO2	Span	30	30	30	30	
Indicated average-Dry	ppmv	Cid	8.11	7.11	8.80	8.71	8.21
Cylinder Value - High Range calibration gas	ppmv	Sc	15.27	15.27	15.27	15.27	
Cylinder Value - Low Range (Zero) calibration gas	ppmv	Coa	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initial	ppmv	Sbs	14.73	14.73	14.73	14.73	
System Calibration Response - Low Range gas - Initial	ppmv	Zbs	0.35	0.35	0.35	0.35	
System Calibration Response - Low Range gas - Final	ppmv	Zbe	5.99	5.99	5.99	5.99	
System Calibration Response - High Range gas - Final	ppmv	Sbe	19.22	19.22	19.22	19.22	
Actual average - Dry (Corrected for Drift)	ppmv-SO2	Cgas	4.67	4.93	5.46	3.85	4.75
Mass Emissions	lbm-SO2 / hr	Mgas	18.11	19.11	21.19	14.92	18.41
Mass Emissions on Production Basis	lbm/Ton		0.131	0.139	0.152	0.108	0.133

TGOC Emissions

Client	Oregon Steel Mills	MJE/TJH/CDB	Testers			
Source	ICA Baghouse-EAF Inlet	1685	File			
Location	Portland, OR	MEW	Analysis/QA			
Date	07-Nov-2001					
Number of Completed Runs		Combined	Run 1	Run 2	Run 3	Average
Date Tested						
System Calibration Time - Initial	Tci	08:35	08:35	08:35	08:35	
Test Time-Starting	Tts	10:31	10:31	12:09	13:50	
Test Time-Ending	Tte	15:14	12:05	13:33	15:17	
System Calibration Time - Final	Tcf	15:20	15:20	15:20	15:20	
Test Mid-point Time	Tx	12:52	11:18	12:51	14:33	
Volumetric Flowrate, Dry Standard	dscf/min Qsd	388.771	388,771	388,771	388,771	
Production	Tons/hr	138.2	137.4	139.4	137.8	138.2
Oxygen	% O2	20.51	20.51	20.45	20.49	
Carbon Dioxide	% CO2	0.55	0.53	0.62	0.61	
Moisture, Mole Fraction dry Gas	mfg	96.60%	96.60%	96.60%	96.60%	
Total Gaseous Organic Concentration (TGOC-1)	Span	100	100	100	100	
Span Gas- Instrument Response Factor	JUM Factor C3H8	1.00	1.00	1.00	1.00	
Span Gas- Carbon Count Equivalent	K	3				
Cylinder Value - High Range calibration gas	ppmv-C3	27.79	27.79	27.79	27.79	
Cylinder Value - Low Range (Zero) calibration gas	ppmv-C3 Coa	0.00	0.00	0.00	0.00	
Indicated average- Wet	ppmv-C3 Ciw	9.84	11.32	9.11	9.73	10.05
Span Gas Concentration- Equivalent	ppmv-C3 Sc	28.69	28.69	28.69	28.69	
Zero Gas Concentration- Equivalent	ppmv-C3 Zc	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initial	ppmv-C3 Ss	28.82	28.82	28.82	28.82	
System Calibration Response - Low Range gas - Initial	ppmv-C3 Zs	0.59	0.59	0.59	0.59	
System Calibration Response - Low Range gas - Final	ppmv-C3 Ze	2.27	2.27	2.27	2.27	
System Calibration Response - High Range gas - Final	ppmv-C3 Se	34.57	34.57	34.57	34.57	
Actual average - Wet (Corrected for Drift & Response)	ppmv-C3	7.62	9.66	6.95	6.90	7.83
Actual average - Dry (Corrected for Drift & Response)	ppmv-C3	7.88	10.00	7.19	7.14	8.11
Actual average - Dry	ppmv-C Cgas	22.91	29.05	20.90	20.75	23.56
Mass Emissions	lbm-C / hr	16.66	21.12	15.19	15.09	17.13
Mass Emissions on Production Basis	lbm-C/Ton	0.121	0.154	0.109	0.109	0.124
TGNMOC (TGOC less Methane) (TGOC-2)	Span	100	100	100	100	
Span Gas- Instrument Response Factor	JUM Factor C3H8	1.00	1.00	1.00	1.00	
Span Gas- Carbon Count Equivalent	K	3				
Cylinder Value - High Range calibration gas	ppmv-C3	27.79	27.79	27.79	27.79	
Cylinder Value - Low Range (Zero) calibration gas	ppmv-C3 Coa	0.00	0.00	0.00	0.00	
Indicated average- Wet	ppmv-C3 Ciw	5.02	4.26	4.65	6.47	5.13
Span Gas Concentration- Equivalent	ppmv-C3 Sc	28.69	28.69	28.69	28.69	
Zero Gas Concentration- Equivalent	ppmv-C3 Zc	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initial	ppmv-C3 Ss	27.32	27.32	27.32	27.32	
System Calibration Response - Low Range gas - Initial	ppmv-C3 Zs	0.42	0.42	0.42	0.42	
System Calibration Response - Low Range gas - Final	ppmv-C3 Ze	2.68	2.68	2.68	2.68	
System Calibration Response - High Range gas - Final	ppmv-C3 Se	30.81	30.81	30.81	30.81	
Actual average - Wet (Corrected for Drift & Response)	ppmv-C3	3.28	3.07	2.90	4.15	3.37
Actual average - Dry (Corrected for Drift & Response)	ppmv-C3	3.39	3.18	3.01	4.30	3.49
Actual average - Dry	ppmv-C Cgas	9.86	9.23	8.74	12.49	10.15
Mass Emissions	lbm-C / hr	7.17	6.71	6.35	9.08	7.38
Mass Emissions on Production Basis	lbm-C/Ton	0.052	0.049	0.046	0.066	0.053
METHANE						
Actual average - Wet (Corrected for Drift & Response)	ppmv-C3	4.34	6.59	4.04	2.75	4.46
Actual average - Dry (Corrected for Drift & Response)	ppmv-C3	4.49	6.82	4.18	2.84	4.62
Actual average - Dry	ppmv-C	13.05	19.82	12.16	8.26	13.41
Mass Emissions	lbm-C / hr	9.49	14.41	8.84	6.01	9.75
Mass Emissions on Production Basis	lbm-C/Ton	0.069	0.105	0.063	0.044	0.071

Molecular Emissions

Client	Oregon Steel Mills		MJE/TJH/CDB				Testers
Source	ICA Baghouse-EAF Inle		1685				File
Location	Portland, OR		MEW				Analysis/QA
Date	07-Nov-2001						
			Combined	Run 1	Run 2	Run 3	Avg
System Calibration Time - Initial		Tci	08:35	08:35	08:35	08:35	
Test Time-Starting (Hivol Interval)		Tts	10:31	10:31	12:09	13:50	
Test Time-Ending (Hivol Interval)		Tte	15:14	12:05	13:33	15:17	
System Calibration Time - Final		Tcf	15:20	15:20	15:20	15:20	
Test Mid-point Time		Tx	12:52	11:18	12:51	14:33	
Volumetric Flowrate, Dry Standard - Inlet Average	dscf/min	Qsd	388,771	388,771	388,771	388,771	
Production Rate	Ton/hr		138.20	137.36	139.40	137.82	
Molecular weight, Dry Stack	lbm/lb-mole	Md	29.03	29.03	29.04	29.04	
Oxygen-Inlet	O2	Span	25	25	25	25	
Indicated average - Dry	%	Cid	20.17	20.26	20.11	20.04	20.14
Cylinder Value - High Range calibration gas	%	Cma	11.60	11.60	11.60	11.60	
Cylinder Value - Low Range (Zero) calibration gas	%	Coa	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initia	%	Cmi	11.57	11.57	11.57	11.57	
System Calibration Response - Low Range gas - Initia	%	Coi	0.03	0.03	0.03	0.03	
System Calibration Response - Low Range gas - Final	%	Cof	0.05	0.05	0.05	0.05	
System Calibration Response - High Range gas - Final	%	Cmf	11.34	11.34	11.34	11.34	
Actual average - Dry (Corrected for Drift)	%	Cgas	20.51	20.51	20.45	20.49	20.48
Carbon Dioxide-Inlet	CO2	Span	25	25	25	25	
Indicated average - Dry	%	Cid	0.57	0.58	0.64	0.60	0.61
Cylinder Value - High Range calibration gas	%	Cma	12.41	12.41	12.41	12.41	
Cylinder Value - Low Range (Zero) calibration gas	%	Coa	0.00	0.00	0.00	0.00	
System Calibration Response - High Range gas - Initia	%	Cmi	12.37	12.37	12.37	12.37	
System Calibration Response - Low Range gas - Initia	%	Coi	0.10	0.10	0.10	0.10	
System Calibration Response - Low Range gas - Final	%	Cof	-0.02	-0.02	-0.02	-0.02	
System Calibration Response - High Range gas - Final	%	Cmf	12.35	12.35	12.35	12.35	
Actual average - Dry (Corrected for Drift)	%	Cgas	0.550	0.533	0.620	0.609	0.587

Calibration Field Record

Client
 Date 11/7/07
 Source

Tester
 Observer
 Date Logger ID

Leak Checks Pre-OK Post-OK Response Time	Valve Position	Cylinder #	Span Gas	Cylinder Value (CV)	Analyzer Calibration Response (ACR)	Start Run System Calibration Response (SRC1)	End Run System Calibration Response (SRC2)	End Run System Calibration Response (SRC3)	End Run System Calibration Response (SRC4)
Response Time: 45300									
CO2 % ch		27	CO2	2.33	2.33	21.74	2.33		
Range		27	CO2	12.41	12.35	12.37	12.35		
Analyzer Model		0-9	N2	2.00	2.00	0.10	0.02		
Analyzer SN:									
CO ppm ch		27	CO	380	371.5	457.4	383.3		
Range		27/R12	CO	400/35	490/35.2	478.1/4.3	476.1/37.2		
Analyzer Model		0-9	N2	0.00	0.00	0.75	-0.93		
Analyzer SN:									
O2% ch		27	O2	Amb	20.93	20.84			
Range		0-9	O2	11.60	11.62	11.57	11.34		
Analyzer Model		27	N2	0.00	0.00	0.03	0.05		
Analyzer SN:									
NOx ppm ch		27	NOx	183.2	184.3	181.7	179.2		
Range		27/N7	NOx	20.4/5.25	33.7/5.25	78.2/4.2	36.4/2.32		
Analyzer Model		0-9	N2	2.00	0.00	0.48	-0.17		
Analyzer SN:									
TGOC ppm ch		P22	CO	39.0	38.25	37.5			
Range		P19	CO	31.5	32.32	31.5	32.18		
Analyzer Model		P15/7	CO	25.69/16	23.39/16	29.52/402	37.37/20		
Analyzer SN:		2007-1	Air	0.00	0.36	2.59	2.27		
TSP ch		P22	CO	39.0	37.0	37.5			
Range		P17	CO	3.5	5.00	4.00	3.00		
Analyzer Model		P15/7	CO	25.69/16	23.39/16	27.32/16	23.00/16		
Analyzer SN:		2007-1	CO	0.00	0.00	0.42	0.00		

Check	Performance Specs		
Analyzer Calibration Error	ACR-CV / SPAN	2 (25A @ 5%)	Hot Line Temp <u>250 °F</u>
Sampling System Bias	(SRCs-ACR) / SPAN	5	Hot Line Temp <u>250 °F</u>
Zero and Cal Drift	(SRC2-SRC1) / SPAN	3	<u>250 °F</u>

Test Times	Run 1	Run 2	Run 3
Start Time	1:00		
End Time	1:15		

Calibration Field Record

Client
 Date
 Source

Tester
 Observer
 Date Logger ID

Lean Checks Pre-OK Post-OK Response Time	Valve Position	Cylinder #	Span Gas	Cylinder Value (CV)	Analyzer Calibration Response (ACR)	Start Run	End Run	End Run	End Run																
						System Calibration Response (SRC1)	Start Run	Start Run	Start Run	System Calibration Response (SRC1)	System Calibration Response (SRC1)	System Calibration Response (SRC1)													
Response Time <u>45 sec</u>																									
<u>Times</u>																									
CO2 % ch <u> </u>			CO2																						
Range			CO2																						
Analyzer Model			N2																						
Analyzer SN:																									
CO ppm ch <u> </u>			CO																						
Range			CO																						
Analyzer Model			N2																						
Analyzer SN:																									
O2% ch <u> </u>			O2																						
Range			O2																						
Analyzer Model			N2																						
Analyzer SN:																									
NOx ppm ch <u> </u>			NOx																						
Range			NOx																						
Analyzer Model			N2																						
Analyzer SN:																									
TGOC ppm ch <u> </u>																									
Range																									
Analyzer Model																									
Analyzer SN:			Air																						
<u>50</u> ch <u> </u>																									
Range <u>0-50 ppm</u>		<u>20</u>		<u>2.147</u>	<u>2.43</u>																				
Analyzer Model <u>Keval</u>		<u>37</u>		<u>15.27</u>	<u>15.51</u>	<u>10.00</u>	<u>10.22</u>																		
Analyzer SN:		<u>20</u>		<u>2.00</u>	<u>0.03</u>	<u>5.00</u>	<u>5.00</u>																		
<table border="0" style="width: 100%;"> <tr> <td style="width: 20%;">Check</td> <td style="width: 40%; text-align: center;">Performance Specs</td> <td style="width: 20%;"></td> <td style="width: 20%;"></td> </tr> <tr> <td>Analyzer Calibration Error</td> <td>(ACR-CV) / SPAN</td> <td>2 (25A @ 5%)</td> <td>Hot Line Temp <u>250 F</u></td> </tr> <tr> <td>Sampling System Bias</td> <td>(SRC1-ACR) / SPAN</td> <td>5</td> <td>Hot Line Temp <u> </u></td> </tr> <tr> <td>Zero and Cal Drift</td> <td>(SRC2-SRC1) / SPAN</td> <td>3</td> <td><u> </u></td> </tr> </table>										Check	Performance Specs			Analyzer Calibration Error	(ACR-CV) / SPAN	2 (25A @ 5%)	Hot Line Temp <u>250 F</u>	Sampling System Bias	(SRC1-ACR) / SPAN	5	Hot Line Temp <u> </u>	Zero and Cal Drift	(SRC2-SRC1) / SPAN	3	<u> </u>
Check	Performance Specs																								
Analyzer Calibration Error	(ACR-CV) / SPAN	2 (25A @ 5%)	Hot Line Temp <u>250 F</u>																						
Sampling System Bias	(SRC1-ACR) / SPAN	5	Hot Line Temp <u> </u>																						
Zero and Cal Drift	(SRC2-SRC1) / SPAN	3	<u> </u>																						

Test Times	Run 1	Run 2	Run 3
Start Time	<u> </u>	<u> </u>	<u> </u>
End Time	<u> </u>	<u> </u>	<u> </u>



13886 NE Wheeler Way • Portland, OR 97230
 Phone (503) 266-0800 • Fax (503) 266-0806
 www.horizonengineering.com

OSM Manual gas values

DATE 11/7/01

	1359:00	1359:15	1359:30	1359:45
O ₂ %	20.18	20.05	20.03	20.11
CO ₂ %	0.54	0.56	0.67	0.59
CO, PPM	18.1	18.9	18.7	18.8
NO _x PPM	8.8	7.1	16.72	15.5
SO ₂ PPM	7.08	7.1	7.17	7.4
C ₂ H ₂ VOC ₁ PPM	6.98	6.6	6.1	6.99
C ₂ H ₂ VOC ₂ PPM	8.72	8.4	6.47	8.7


Bias Check

Oregon Steel Mills EAF Baghouse 7-November-2001		Span	Cylinder Value CV	Analyzer Calibration Response ACR	Initial System Calibration Response SCRi	Final System Calibration Response SCRf	Cylinder Value Percent of Span	Difference < 2%	Initial System Calibration Bias < 5%	Final System Calibration Bias < 5%	Drift < 3%
OXYGEN											
Run 1-3	High Range	25	20.95	20.95	20.88		84%	0%			
	Mid-Range	25	11.60	11.62	11.57	11.34	46%	0%	0%	1%	1%
	Zero	25	0.00	0.00	0.03	0.05	0%	0%	0%	0%	0%
CARBON DIOXIDE											
Run 1-3	High Range	25	21.83	21.85	21.78	21.46	87%	0%			
	Mid-Range	25	12.41	12.55	12.37	12.35	50%	1%	1%	1%	0%
	Zero	25	0.00	0.00	0.10	-0.02	0%	0%	0%	0%	0%
CARBON MONOXIDE											
Run 1-3	High Range	2000	880.00	871.50	857.40	883.30	44%	0%	1%	1%	1%
	Mid-Range	2000	499.00	496.00	478.10	498.00	25%	0%	1%	0%	1%
	Mid-Range	2000	85.90	85.22	84.70	87.20	4%	0%	0%	0%	0%
	Zero	2000	0.00	-0.45	-0.75	-0.93	0%	0%	0%	0%	0%
NITROGEN OXIDES											
Run 1	High Range	200	183.20	184.50	181.70	179.20	92%	1%	1%	3%	1%
	Mid-Range	200	89.80	88.72	88.29	86.46	45%	1%	0%	1%	1%
	Mid-Range	200	25.25	24.37	24.21	23.52	13%	0%	0%	0%	0%
	Zero	200	0.00	0.00	0.48	-0.17	0%	0%	0%	0%	0%
SULFUR DIOXIDE											
Run 1	High Range	30	26.47	26.43			88%	0%			0%
	Mid-Range	30	15.27	15.51	14.73	19.22	51%	1%	3%	12%	15%
	Zero	30	0.00	0.08	0.35	5.99	0%	0%	1%	20%	19%
TOTAL GASEOUS ORGANIC CONCENTRATION #1											
Run 1	High Range	C3H8	100	88.85	87.55		89%				
	Mid-#1	CH4	100	52.32	51.53	62.18	52%				11%
	Mid-#2	CH4	100	29.89	28.82	34.57	30%				6%
	Mid-#3	CH4	100	9.49	9.02	12.51	9%				3%
	Zero	N2	100	0.36	0.59	2.27	0%				2%
TOTAL GASEOUS ORGANIC CONCENTRATION #2											
Run 1	High Range	C3H8	100	89.01	87.51		89%				
	Mid-#1	CH4	100	51.90	49.65	51.96	52%				2%
	Mid-#2	CH4	100	28.82	27.32	30.81	29%				3%
	Mid-#3	CH4	100	8.71	8.32	11.26	9%				3%
	Zero	N2	100	-0.07	0.42	2.68	-0%				2%

Part 60, Appendix A, Method 6C, Figures 6C-3 to 6C-5

Oregon Steel Mills


EAF Baghouse Outlet





- Oxygen
- Carbon Dioxide
- Sulfur Dioxide
- TGOC-Total
- Methane Cutter

Oregon Steel Mills



EAF Baghouse Outlet





— Carbon Monoxide — Nitrogen Oxide




Oregon Steel Mills Flow Rate



Oregon Steel Mills Carbon Monoxide Emissions





Production/Process Data
Furnace Heat Logs
MSDS Sheet
Baghouse Pressure Drop Field Data

Production Data

OSM #3 Furnace Heat Log Data Reduction
07-Nov-2001

Heat	Last Tap	Start Charge	Finish Tap	C-T mins	T-T mins	First Charge lbms	Second Charge lbms	Total Charge lbms	Run Total lbms	Total Time mins	Down Time mins	Run Time mins	Tons/hr
114,406													
114,407	08:21	09:51	10:36	45.0	135.0	137,900	25,300	163,200					
114,408	10:36	10:41	11:21	40.0	45.0	139,400	61,000	200,400	384,600	84		84	137.36
114,409	11:21	11:26	12:05	39.0	44.0	139,200	45,000	184,200					
114,410	12:05	12:10	12:49	39.0	44.0	139,500	60,400	199,900	399,600	86		86	139.40
114,411	12:49	12:54	13:36	42.0	47.0	138,800	60,900	199,700					
114,412	13:36	13:50	14:32	42.0	56.0	139,800	60,000	199,800	390,500	85		85	137.82
114,413	14:32	14:36	15:15	39.0	43.0	140,800	49,900	190,700					
Average				40.2	46.5	139,583	56,200	195,783					
Total									1,174,700	255		255	138.20

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114407 BOH 11/07 at 08:21 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 187 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
08:25	3.95	0.00	3.95	0	0.00			0.00	0.00	Lime_#_ 5
09:50	89.27	0.00	85.32	0	0.00			0.00	0.00	
09:51	89.47	0.00	0.20	0	0.00			0.00	0.00	CHG_1_ 140.0
09:52	90.86	1.38	0.00	2	56.37	0.774	1 S M	1.30	72.12	Bore_In
09:54	92.76	1.90	0.00	4	56.26	0.827	1 L M	3.08	64.10	Bore_In
09:57	95.95	3.20	0.00	7	55.71	0.820	1 L M	6.05	63.98	Melt
10:02	100.97	5.01	0.00	11	59.02	0.837	1 L M	10.98	63.23	Refine
10:05	103.64	2.67	0.00	14	59.75	0.851	1 L M	13.64	61.60	
10:07	105.60	0.00	1.97	13	0.00			13.64	0.00	CHG_2_ 30.0
10:07	105.85	0.00	0.25	13	0.00			13.64	0.00	
10:08	107.34	1.48	0.00	15	61.83	0.798	1 S M	15.17	73.51	
10:13	112.35	5.02	0.00	18	59.74	0.845	1 L M	20.16	62.01	
10:16	115.40	3.05	0.00	21	61.50	0.863	1 L M	23.29	60.57	
10:19	118.18	2.78	0.00	22	64.83	0.816	1 S M	26.29	71.29	
10:19	118.27	0.08	0.00	22	38.45	0.846	1 L M	26.35	48.72	
10:22	121.07	0.00	2.80	22	0.00			26.35	0.00	P'back_ 21.0
10:27	126.03	4.97	0.00	25	64.83	0.815	1 S M	31.71	71.59	P'back_ 24.0
10:29	128.45	2.42	0.00	26	64.85	0.807	1 S M	34.33	71.64	
10:29	128.47	0.02	0.00	26	6.48	0.707	1 L M	34.33	11.88	
10:36	135.15	0.00	6.68	25	0.00			34.33	0.00	Tap_T

total lime weight 4.7 cold charge weight 170.0
 total coke weight 0.0 hot charge weight 45.0
 total oxygen 0 total charge weight 215.0
 total gas 127

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114407 Time: 10:36

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Min. Ctr.	Min. Pit	Max. Floor
UNDEF	1 S	11.6	34.3	21.59	64.45	46.42	79.43	0.811	11.3	11.6	11.6	72.5
UNDEF	1 L	8.2	24.0	22.35	60.07	36.94	70.52	0.852	8.2	8.2	8.2	62.0
BOREIN	1 S	1.4	4.1	21.75	56.37	46.09	72.82	0.774	1.3	1.4	1.4	71.5
BOREIN	1 L	1.9	5.6	22.33	56.26	38.29	68.05	0.827	1.9	1.9	1.9	65.1
MELT	1 L	3.2	9.4	22.28	55.71	38.83	67.91	0.820	3.2	3.2	3.2	64.0
REFINE	1 L	7.7	22.6	22.27	59.27	38.03	70.43	0.842	7.7	7.7	7.7	63.3
		34.0		22.04	60.62	41.06	73.22	0.828	33.6	34.0	34.0	66.4

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.:	114407	Date:	11-07-01	Shift:	2
Melter:	1	First Helper:	1	Product Code:	7168
Tap Time:	10:36	Prev Heat Tapped:	08:21	Time Tap to Tap:	2 hr. 15 m

```

*****
*
* CHARGE  TIME  WEIGHT  *
* -----  -----  -----  *
*   1     09:51   140.0  * TAP TEMP:          0  *
*   2     10:07    30.0  * LADLE TEMP:       0  *
*   3      none    none   * MWH USED:   34.33  *
*   4      none    none   * KWH/TON:   319.3  *
* *****          *****  *
* TOTAL(klbs)      215.0  *
* TOTAL(tons)      107.5  *
*
*****

```

Chemistry File Heat Number 114407 has incorrect number of characters

OSM #3 FURNACE HEAT LOG

HEAT SUMMARY

Heat Number: 114408	Grade: X-60-1	Grade No: 7158
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 1041
		Tap Time: 1121
Heats on Delta: 403		Last Heat Tapped: 1036

Total Charge Wt : 280.0	Furnace Lime Lbs : 5
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 122
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 29.2
Charge to Tap Time : 40	Avg. MW : 60.6
Tap to Tap Time : 45	KWH/Ton : 208.6
Total Delay Time : 16.1	Avg. Pwr. Factor : 0.83

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 139,400
2nd = 61,000

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114408 BOH 11/07 at 10:36 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 188 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
10:41	5.12	0.00	5.12	0	0.00			0.00	0.00	Inspect_Fce
10:41	5.15	0.00	0.03	0	0.00			0.00	0.00	CHG_1__140.0
10:41	5.30	0.00	0.15	0	0.00			0.00	0.00	
10:43	7.28	1.98	0.00	27	61.28	0.790	1 S M	2.03	73.87	Bore_In
10:44	8.28	1.00	0.00	36	55.83	0.833	1 L M	2.95	62.71	Bore_In
10:45	8.97	0.00	0.68	33	0.00			2.95	0.00	Slip_A
10:45	9.03	0.00	0.07	33	0.00			2.95	0.00	Slip_B
10:47	10.80	0.00	1.77	28	0.00			2.95	0.00	Slip_C
10:47	10.95	0.15	0.00	29	32.92	0.723	1 L M	3.04	54.39	Bore_In
10:50	14.05	3.10	0.00	44	57.87	0.831	1 L M	6.03	64.00	Melt
10:54	17.98	3.93	0.00	57	58.50	0.840	1 L M	9.86	61.87	Lime_#_ 5
10:57	21.71	3.73	0.00	64	58.28	0.848	1 L M	13.49	60.49	
10:59	23.58	0.00	1.87	59	0.00			13.49	0.00	CHG_2__140.0
11:00	24:45	0.87	0.00	60	61.73	0.797	1 S M	14.38	72.22	
11:04	28.69	4.25	0.00	66	59.19	0.843	1 L M	18.57	60.88	
11:07	30.91	0.00	2.22	62	0.00			18.57	0.00	
11:12	35.88	4.97	0.00	67	64.20	0.814	1 S M	23.88	70.53	
11:17	40.81	4.93	0.00	71	64.92	0.810	1 S M	29.22	70.88	
11:17	40.84	0.03	0.00	71	39.96	0.849	1 L M	29.24	45.37	
11:21	45.03	0.00	4.18	64	0.00			29.24	0.00	Tap_T

total lime weight 4.7
 total coke weight 0.0
 total oxygen 0
 total gas 122

cold charge weight 280.0
 hot charge weight 0.0
 total charge weight 280.0

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114408 Time: 11:21

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Ctr.	Min. Pit	----- Floor
UNDEF	1 S	10.8	37.2	21.65	64.33	46.42	79.33	0.811	10.7	10.8	10.8	70.8
UNDEF	1 L	4.3	14.8	22.32	59.04	37.68	70.04	0.843	4.3	4.3	4.3	61.9
BOREIN	1 S	2.0	6.8	21.78	61.28	47.50	77.53	0.790	1.9	2.0	2.0	74.3
BOREIN	1 L	1.1	4.0	22.46	52.84	36.30	64.11	0.824	1.1	1.1	1.1	60.6
MELT	1 L	3.1	10.7	22.36	57.87	38.81	69.68	0.831	3.1	3.1	3.1	63.8
REFINE	1 L	7.7	26.5	22.18	58.40	37.08	69.18	0.844	7.7	7.7	7.7	62.7
		28.9		22.01	60.62	41.51	73.47	0.825	28.3	28.9	28.9	66.4

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.: 114408 Date: 11-07-01 Shift: 2
Melter: 1 First Helper: 1 Product Code: 7168
Tap Time: 11:21 Prev Heat Tapped: 10:36 Time Tap to Tap: 0 hr. 45 mi

```
*****  
* CHARGE TIME WEIGHT * TAP TEMP: 0 *  
* 1 10:41 140.0 * LADLE TEMP: 0 *  
* 2 10:59 140.0 * MWH USED: 29.24 *  
* 3 none none * KWH/TON: 208.9 *  
* 4 none none *  
* ***** *  
* TOTAL(klbs) 280.0 *  
* TOTAL(tons) 140.0 *  
* ***** *  
*****
```

```
*****  
* HEATS ON LINE *****  
* DELTA LIFE: *****  
* CHG WT(klbs): *****  
*****
```

Chemistry File Heat Number 114408 has incorrect number of characters

HEAT SUMMARY

Heat Number: 114409	Grade: X-60-1	Grade No: 7168
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 1125
		Tap Time: 1205
Heats on Delta: 404		Last Heat Tapped: 1121

Total Charge Wt : 199.2	Furnace Lime Lbs : 0
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 133
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 33.8
Charge to Tap Time : 39	Avg. MW : 60.1
Tap to Tap Time : 44	KWH/Ton : 339.4
Total Delay Time : 10.6	Avg. Pwr. Factor : 0.83

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 139,200
2nd = 45,000

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114409 BOH 11/07 at 11:21 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 189 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
11:25	4.75	0.00	4.75	0	0.00			0.00	0.00	Inspect_Fce
11:26	4.83	0.00	0.08	0	0.00			0.00	0.00	CHG_1_139.5
11:27	5.98	1.15	0.00	19	60.76	0.786	1 S M	1.16	72.99	Bore_In
11:27	6.08	0.10	0.00	21	60.84	0.786	1 L M	1.27	72.56	
11:29	7.98	1.90	0.00	39	55.52	0.830	1 L M	3.02	61.96	Bore_In
11:32	11.08	3.10	0.00	56	58.60	0.842	1 L M	6.05	62.06	Melt
11:37	16.10	5.02	0.00	70	57.20	0.841	1 L M	10.83	60.32	Refine
11:41	20.61	4.52	0.00	77	58.11	0.862	1 L M	15.21	58.05	
11:43	22.78	0.00	2.17	69	0.00			15.21	0.00	CHG_2_60.0
11:43	22.85	0.07	0.00	69	17.28	0.696	1 S M	15.23	41.72	
11:45	24.28	1.43	0.00	71	63.02	0.801	1 S M	16.73	73.67	
11:50	29.30	5.01	0.00	76	57.60	0.833	1 L M	21.55	62.69	
11:52	31.56	2.27	0.00	78	59.17	0.857	1 L M	23.78	59.62	
11:57	36:58	5.02	0.00	81	66.14	0.819	1 S M	29.31	71.06	
12:01	40.74	4.17	0.00	83	65.27	0.812	1 S M	33.84	70.91	
12:01	40.81	0.07	0.00	83	45.36	0.823	1 L M	33.89	55.35	
12:05	44.43	0.00	3.62	76	0.00			33.89	0.00	Tap_T

total lime weight 0.0
 total coke weight 0.0
 total oxygen 0
 total gas 133

cold charge weight 199.2
 hot charge weight 0.0
 total charge weight 199.2

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114409 Time: 12:05

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Ctr.	Min. Pit	----- Floor
UNDEF	1 S	10.7	31.6	21.69	65.07	46.55	80.01	0.813	10.7	10.7	10.7	71.6
UNDEF	1 L	7.3	21.7	22.40	57.98	37.31	68.94	0.841	7.3	7.3	7.3	63.4
BOREIN	1 S	1.1	3.4	21.62	60.76	47.86	77.35	0.786	1.1	1.1	1.1	72.7
BOREIN	1 L	2.0	5.9	22.51	55.78	37.88	67.43	0.827	2.0	2.0	2.0	62.6
MELT	1 L	3.1	9.2	22.45	58.60	37.62	69.64	0.842	3.1	3.1	3.1	62.1
REFINE	1 L	9.5	28.2	22.30	57.63	35.56	67.72	0.851	9.5	9.5	9.5	58.2
		33.8		22.13	60.14	40.16	72.32	0.832	33.8	33.8	33.8	64.9

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.: 114409 Date: 11-07-01 Shift: 2
Melter: 1 First Helper: 1 Product Code: 7168
Tap Time: 12:05 Prev Heat Tapped: 11:21 Time Tap to Tap: 0 hr. 44 min

```
*****
*
* CHARGE  TIME  WEIGHT *
* -----  -----  *
* 1      11:26  139.2 * TAP TEMP:      0 *
* 2      11:43   60.0 * LADLE TEMP:   0 *
* 3      none   none * MWH USED:    33.89 *
* 4      none   none * KWH/TON:    340.3 *
* *****  ***** *
* TOTAL(klbs)  199.2 *
* TOTAL(tons)   99.6 *
*
*****
```

*
* HEATS ON LINE

*
* DELTA LIFE:

*
* CHG WT(klbs :

*
*

Chemistry File Heat Number 114409 has incorrect number of characters

HEAT SUMMARY

Heat Number: 114410	Grade: X-60-1	Grade No: 7168
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 0
		Tap Time: 1249
Heats on Delta: 405		Last Heat Tapped: 1243

Total Charge Wt : 0.0	Furnace Lime Lbs : 0
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 132
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 3.2
Charge to Tap Time : 769	Avg. MW : 64.3
Tap to Tap Time : 6	KWH/Ton : ++.0
Total Delay Time : 3.0	Avg. Pwr. Factor : 0.80

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 139,500
2nd = 60,400

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114410 BOH 11/07 at 12:43 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 190 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	--- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
12:43	0.00	0.00	0.00	0	0.00			0.00	0.00	Inspect_Fce
12:43	0.12	0.12	0.00	100	63.66	0.816	1 S M	0.12	69.27	Holding
12:46	2.92	2.80	0.00	100	64.57	0.804	1 S M	3.14	71.11	Bore_In
12:46	3.03	0.12	0.00	100	61.93	0.815	1 S M	3.26	68.05	Melt
12:46	3.05	0.02	0.00	100	43.20	0.876	1 L M	3.27	43.92	Melt
12:49	6.02	0.00	2.97	51	0.00			3.27	0.00	Tap_T

total lime weight 0.0 cold charge weight 0.0
 total coke weight 0.0 hot charge weight 0.0
 total oxygen 0 total charge weight 0.0
 total gas 132

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114410 Time: 12:49

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Ctr.	Min. Pit	----- Floor
BOREIN	1 S	2.9	95.6	21.57	64.53	47.71	80.25	0.804	2.9	2.9	2.9	71.1
MELT	1 S	0.1	3.8	21.93	61.93	44.06	76.01	0.815	0.1	0.1	0.1	67.1
MELT	1 L	0.0	0.5	23.38	43.20	23.76	49.30	0.876	0.0	0.0	0.0	43.2
		3.0		21.59	64.32	47.44	79.92	0.805	3.1	3.1	3.1	71.1

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.: 114410 Date: 11-07-01 Shift: 2
Melter: 1 First Helper: 1 Product Code: 7168
Tap Time: 12:49 Prev Heat Tapped: 12:43 Time Tap to Tap: 0 hr. 6 mi

```
*****
*
* CHARGE  TIME  WEIGHT  *
* -----  -----  *
* 1      none   none   * TAP TEMP:      0  *
* 2      none   none   * LADLE TEMP:    0  *
* 3      none   none   * MWH USED:      3.27 *
* 4      none   none   * KWH/TON:       0.0 *
* *****  ***** *
* TOTAL(klbs)      0.0 *
* TOTAL(tons)      0.0 *
*
*****
```

*
* HEATS ON LINE

*
* DELTA LIFE:

*
* CHG WT(klbs):

*
*

Chemistry File Heat Number 114410 has incorrect number of characters

HEAT SUMMARY

Heat Number: 114411	Grade: X-60-1	Grade No: 7168
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 1254
		Tap Time: 1336
Heats on Delta: 406		Last Heat Tapped: 1249

Total Charge Wt : 200.0	Furnace Lime Lbs : 0
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 142
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 35.7
Charge to Tap Time : 42	Avg. MW : 59.7
Tap to Tap Time : 47	KWH/Ton : 357.0
Total Delay Time : 11.4	Avg. Pwr. Factor : 0.83

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 138800
2nd = 60,900

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114411 BOH 11/07 at 12:49 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 191 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
12:54	5.03	0.00	5.03	0	0.00			0.00	0.00	Inspect_Fce
12:54	5.12	0.00	0.08	0	0.00			0.00	0.00	CHG_1__140.0
12:56	7.08	1.97	0.00	28	62.05	0.797	1 S M	2.03	72.77	Bore_In
12:57	8.18	1.10	0.00	37	55.98	0.833	1 L M	3.06	62.60	Bore_In
13:00	11.28	3.10	0.00	55	57.15	0.842	1 L M	6.01	61.76	Melt
13:05	16.22	4.93	0.00	68	57.22	0.845	1 L M	10.72	60.95	Refine
13:10	21.14	4.92	0.00	76	59.38	0.858	1 L M	15.59	60.34	
13:10	21.15	0.02	0.00	76	30.24	0.894	1 L M	15.59	29.30	
13:12	22.74	0.00	1.58	71	0.00			15.59	0.00	CHG_2__60.0
13:13	23.82	1.08	0.00	72	57.85	0.782	1 S M	16.64	71.17	
13:18	28.74	4.92	0.00	77	53.94	0.823	1 L M	21.06	61.86	
13:21	32.29	3.55	0.00	79	58.46	0.847	1 L M	24.52	60.93	
13:26	37.20	4.92	0.00	82	65.97	0.816	1 S M	29.92	71.26	
13:31	42:12	4.92	0.00	84	65.88	0.814	1 S M	35.32	71.23	
13:32	42.49	0.37	0.00	84	60.09	0.807	1 S M	35.69	68.12	
13:32	42.55	0.07	0.00	84	35.64	0.838	1 L M	35.73	47.11	
13:36	47.20	0.00	4.65	76	0.00			35.73	0.00	Tap_T

total lime weight 0.0
 total coke weight 0.0
 total oxygen 0
 total gas 142

cold charge weight 200.0
 hot charge weight 0.0
 total charge weight 200.0

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114411 Time: 13:36

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Ctr.	Min. Pit	--- Floor
UNDEF	1 S	11.3	31.5	21.66	64.96	46.67	79.99	0.812	11.2	11.3	11.3	71.4
UNDEF	1 L	8.5	23.8	22.42	55.67	36.94	66.81	0.833	8.4	8.5	8.5	62.0
BOREIN	1 S	2.0	5.5	21.70	62.05	47.03	77.86	0.797	1.9	2.0	2.0	73.6
BOREIN	1 L	1.1	3.1	22.52	55.98	37.20	67.21	0.833	1.1	1.1	1.1	62.7
MELT	1 L	3.1	8.6	22.44	57.15	36.68	67.91	0.842	3.1	3.1	3.1	61.6
REFINE	1 L	9.9	27.5	22.34	58.25	35.85	68.40	0.852	9.9	9.9	9.9	61.7
		35.9		22.13	59.79	40.24	72.07	0.830	35.7	35.9	35.9	65.5

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.: 114411 Date: 11-07-01 Shift: 2
Melter: 1 First Helper: 1 Product Code: 7168
Tap Time: 13:36 Prev Heat Tapped: 12:49 Time Tap to Tap: 0 hr. 47 mi

```
*****
*                                     *
* CHARGE  TIME  WEIGHT  * TAP TEMP:      0 *
* -----  - - - - -  - - - - -  * LADLE TEMP:    0 *
* 1      12:54   140.0 * MWH USED:     35.73 *
* 2      13:12    60.0 * KWH/TON:     357.3 *
* 3      none    none *
* 4      none    none *
* *****          ***** *
* TOTAL(klbs)      200.0 *
* TOTAL(tons)      100.0 *
*                                     *
*****
```

```
*****
*
* HEATS ON LINE
*****
*
* DELTA LIFE:
*****
*
* CHG WT(klbs):
*****
*
*
*****
```

Chemistry File Heat Number 114411 has incorrect number of characters

HEAT SUMMARY

Heat Number: 114412	Grade: X-60-1	Grade No: 7168
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 1350
		Tap Time: 1432
Heats on Delta: 407		Last Heat Tapped: 1336

Total Charge Wt : 280.0	Furnace Lime Lbs : 0
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 143
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 36.7
Charge to Tap Time : 42	Avg. MW : 59.8
Tap to Tap Time : 56	KWH/Ton : 262.1
Total Delay Time : 19.7	Avg. Pwr. Factor : 0.83

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 139,800
2nd = 40,000

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114412 BOH 11/07 at 13:36 Product Code 7168
 Melter 1 1st Helper 1 Ladle Temp 0 192 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
13:50	14.12	0.00	14.12	0	0.00			0.00	0.00	Inspect_Fce
13:50	14.18	0.00	0.07	0	0.00			0.00	0.00	CHG_1__140.0
13:50	14.25	0.07	0.00	0	15.66	0.649	1 S M	0.02	41.29	Bore_In
13:51	15.15	0.90	0.00	6	60.67	0.779	1 S M	0.93	73.64	Bore_In
13:54	17.45	2.30	0.00	19	56.03	0.832	1 L M	3.08	62.07	Bore_In
13:57	20.55	3.10	0.00	31	57.93	0.839	1 L M	6.07	61.91	Melt
14:02	25.47	4.92	0.00	44	56.87	0.844	1 L M	10.73	60.67	Refine
14:06	30.19	4.72	0.00	53	57.41	0.850	1 L M	15.24	60.49	
14:08	32.00	0.00	1.82	50	0.00			15.24	0.00	CHG_2__140.0
14:09	32.45	0.45	0.00	51	53.42	0.804	1 S M	15.64	67.56	
14:13	36.80	4.35	0.00	57	56.73	0.830	1 L M	19.76	64.29	
14:17	41.40	4.60	0.00	61	58.52	0.845	1 L M	24.24	61.17	
14:22	46.34	4.93	0.00	65	66.09	0.813	1 S M	29.68	71.66	
14:27	51.25	4.92	0.00	69	66.74	0.821	1 S M	35.15	71.68	
14:28	52.42	1.17	0.00	69	64.02	0.815	1 S M	36.39	70.10	
14:28	52.49	0.07	0.00	70	40.40	0.812	1 L M	36.44	53.50	
14:30	53.75	0.00	1.27	68	0.00			36.44	0.00	
14:30	53.84	0.08	0.00	68	35.86	0.879	1 L M	36.49	38.03	
14:30	53.95	0.12	0.00	68	58.32	0.840	1 S M	36.60	62.11	
14:30	54.07	0.12	0.00	68	50.61	0.845	1 L M	36.70	55.51	
14:32	56.45	0.00	2.38	65	0.00			36.70	0.00	Tap_T

total lime weight 0.0
 total coke weight 0.0
 total oxygen 0
 total gas 143

cold charge weight 280.0
 hot charge weight 0.0
 total charge weight 280.0

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114412 Time: 14:32

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	AVG. P.F.	--Arc Floor	Time Ctr.	Min. Pit	----- Floor
UNDEF	1 S	11.6	31.5	21.70	65.59	46.42	80.35	0.816	11.5	11.6	11.6	71.4
UNDEF	1 L	9.2	25.0	22.46	57.24	37.25	68.30	0.838	9.2	9.2	9.2	64.1
BOREIN	1 S	1.0	2.6	21.87	57.57	46.69	74.12	0.777	0.9	1.0	1.0	73.2
BOREIN	1 L	2.3	6.2	22.59	56.03	37.33	67.33	0.832	2.3	2.3	2.3	62.4
MELT	1 L	3.1	8.4	22.51	57.93	37.57	69.05	0.839	3.1	3.1	3.1	61.9
REFINE	1 L	9.6	26.2	22.27	57.13	35.85	67.45	0.847	9.6	9.6	9.6	61.3
		36.8		22.17	59.83	40.05	72.00	0.831	36.7	36.8	36.8	55.5

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.: 114412 Date: 11-07-01 Shift: 2
Melter: 1 First Helper: 1 Product Code: 7168
Tap Time: 14:32 Prev Heat Tapped: 13:36 Time Tap to Tap: 0 hr. 56 mi

*****				*****			
CHARGE	TIME	WEIGHT	*	TAP TEMP:	0	*	HEATS ON LINE
1	13:50	140.0	*	LADLE TEMP:	0	*	*****
2	14:08	140.0	*	MWH USED:	36.70	*	DELTA LIFE:
3	none	none	*	KWH/TON:	262.1	*	*****
4	none	none	*	*****			CHG WT(klbs):
TOTAL(klbs)		280.0	*	*****			*****
TOTAL(tons)		140.0	*	*****			*****
*****				*****			

Chemistry File Heat Number 114412 has incorrect number of characters

HEAT SUMMARY

Heat Number: 114413	Grade: OR 500-2	Grade No: 9108
Crew No : 1	Heat Tap Date: 11/07/2001	Charge Time: 1436
		Tap Time: 1515
Heats on Delta: 408		Last Heat Tapped: 1432

Total Charge Wt : 190.0	Furnace Lime Lbs : 5
Hot Metal Wt : 0.0	Oxygen Batch : 0
Pour Back : 0.0	Nat. Gas Batch : 136
	Tap Temp : 0
Melt Efficiency Rating : 0.00	Total MWH : 35.6
Charge to Tap Time : 39	Avg. MW : 61.3
Tap to Tap Time : 43	KWH/Ton : 374.7
Total Delay Time : 8.6	Avg. Pwr. Factor : 0.84

CHEMISTRY SUMMARY

LADLE ADDITIONS:

1st = 140,800
2nd = 49,900

Oregon Steel Mills, Portland Oregon
 * * * * * H E A T L O G * * * * *

Heat No. 114413 BOH 11/07 at 14:32 Product Code 9108
 Melter 1 1st Helper 1 Ladle Temp 0 193 heats on lance 8

CLOCK TIME	---TIME TOTAL	(MINUTES) ON	-- OFF	TU %	AVG. MW	AVG. P.F.	TAP/ ARC	ACC. MWHR	AVG. KA	EVENT/DELAY DESCRIPTION
14:36	3.70	0.00	3.70	0	0.00			0.00	0.00	Inspect_Fca
14:36	3.92	0.00	0.22	0	0.00			0.00	0.00	CHG_1_140.0
14:36	4.00	0.00	0.08	0	0.00			0.00	0.00	
14:37	4.87	0.87	0.00	18	62.13	0.786	1 S M	0.90	74.06	Bore_In
14:39	7.17	2.30	0.00	44	56.56	0.836	1 L M	3.07	61.87	Bore_In
14:39	7.28	0.12	0.00	45	58.32	0.826	1 L M	3.18	65.07	Lime_#
14:42	10.28	3.00	0.00	61	58.20	0.847	1 L M	6.09	61.30	Melt
14:47	15.20	4.92	0.00	74	59.61	0.864	1 L M	10.97	59.99	Refine
14:51	18.40	3.20	0.00	78	60.16	0.868	1 L M	14.18	59.41	
14:52	19.90	0.00	1.50	72	0.00			14.18	0.00	CHG_2_50.0
14:54	21.77	1.87	0.00	75	58.86	0.803	1 S M	16.01	71.70	
14:59	26.68	4.92	0.00	79	57.53	0.850	1 L M	20.73	60.67	
15:00	27.98	1.30	0.00	80	60.12	0.864	1 L M	22.03	59.15	
15:05	32:90	4.92	0.00	83	66.58	0.822	1 S M	27.49	71.22	
15:10	37.82	4.92	0.00	85	68.37	0.834	1 S M	33.09	71.78	
15:11	39.09	1.27	0.00	86	66.44	0.811	1 S M	34.49	71.71	
15:11	39.30	0.22	0.00	86	55.78	0.837	1 L M	34.69	59.90	
15:11	39.55	0.00	0.25	85	0.00			34.69	0.00	
15:13	40.64	1.08	0.00	86	52.31	0.714	2 L M	35.64	71.82	
15:15	43.52	0.00	2.88	80	0.00			35.64	0.00	Tap_T

total lime weight 4.7	cold charge weight 190.0
total coke weight 0.0	hot charge weight 0.0
total oxygen 0	total charge weight 190.0
total gas 136	

** HEAT ELECTRICAL SUMMARY **

Heat No.: 114413 Time: 15:15

Mode	Tap/ Arc	--Power Min.	On- Pct.	Avg. KV	Avg. MW	Avg. MVAR	Avg. MVA	Avg. P.F.	--Arc Floor	Time Ctr.	Min. Pit	--- Floor
UNDEF	1 S	13.0	37.2	21.72	66.13	45.67	80.37	0.823	12.8	13.0	13.0	72.0
UNDEF	1 L	6.4	18.4	22.37	57.99	35.58	68.04	0.852	6.4	6.4	6.4	60.7
UNDEF	2 L	1.1	3.1	21.42	52.31	51.24	73.22	0.714	1.1	1.1	1.1	72.2
BOREIN	1 S	0.9	2.5	21.75	62.13	48.84	79.03	0.786	0.9	0.9	0.9	73.9
BOREIN	1 L	2.3	6.6	22.58	56.56	37.10	67.64	0.836	2.3	2.3	2.3	63.0
MELT	1 L	3.1	8.9	22.49	58.20	36.72	68.82	0.846	3.1	3.1	3.1	62.4
REFINE	1 L	8.1	23.3	22.33	59.83	34.58	69.10	0.866	8.1	8.1	8.1	60.9
		34.9		22.10	61.30	40.12	73.26	0.837	34.7	34.9	34.9	66.0

Oregon Steel Mills, Portland Oregon

** CHEMISTRY REPORT **

Heat No.:	114413	Date:	11-07-01	Shift:	3
Melter:	1	First Helper:	1	Product Code:	9108
Tap Time:	15:15	Prev Heat Tapped:	14:32	Time Tap to Tap:	0 hr. 44 mi

```

*****
*                                     *
* CHARGE  TIME  WEIGHT  * TAP TEMP:      0 *
* 1       14:36  140.0 * LADLE TEMP:    0 *
* 2       14:52   50.0 * MWH USED:     35.64 *
* 3        none   none * KWH/TON:     375.2 *
* 4        none   none *
* *****                *
* TOTAL(klbs)  190.0 *
* TOTAL(tons)   95.0 *
*
*****

```

Chemistry File Heat Number 114413 has incorrect number of characters

MATERIAL SAFETY DATA SHEET

MSDS ISSUE DATE: AUGUST 17, 1995

SECTION I CHEMICAL PRODUCT AND COMPANY IDENTIFICATION

PRODUCT: ELECTRIC ARC FURNACE DUST (K061)

ORGANIZATION MSDS: #: SAFETY DATA FILE K061 95. SAFETY FILE INDEX #2.14.4.1

MANUFACTURER'S NAME: OREGON STEEL MILLS, INC.

EMERGENCY PHONE NUMBER: 503-286-9651

ADDRESS: PO BOX 2750 PORTLAND, OREGON 97208

HMS CODES
HEALTH: 2
FIRE: 0
REACTIVITY: 0
CHRONIC EFFECTS: 4

MANUFACTURER'S CODE: NE

CHEMICAL NAME/CLASSIFICATION: DUST CONTAINING METALS & INORGANICS

SECTION 2 COMPOSITION, INFORMATION ON INGREDIENTS

METALS LISTED BELOW ARC PRESENT MOSTLY AS OXIDES. IN ADDITION, FREE METALS MAY ALSO BE PRESENT BUT IN SMALL AND VARYING AMOUNTS.

INGREDIENT	CAS#	PERCENT (AS OXIDE)	OSHA PEL (MG/M3)	ACGIH TLV (MG/M3)
IRON OXIDE-Fe _x O _y		35-55	1C	5
FERRIC OXIDE	1309-37-1			
FERROUS OXIDE	1345-25-1			
ZINC OXIDE-ZnO	1314-13-2	14-25	15 TOTAL DUST 5 RESPIRABLE FRACTION	10 DUST, 5 FUME
CALCIUM OXIDE-CaO	1305-78-8	5-16	5	2
MANGANESE OXIDE-Mn _x O _y		3-5	5	0.2 (PROPOSED)

MANGANESE OXIDE	1317-35-7				
MANGANESE DIOXIDE	1313-13-9				
SILICA OXIDE-SiO ₂		1-5	30mg/m ³ / %SiO ₂ +2	0.1	RESPIRABLE
SILICON DIOXIDE	7631-86-9				
MAGNESIUM OXIDE-MgO					
	1309-48-4	2-4	15	10	FUME
LEAD OXIDE-PbO	1309-60-0	1.8-3.3	0.05	0.05	
LEAD DIOXIDE					
SODIUM OXIDE Na ₂ O	1313-59-3	1-6	15(1)	10(2)	
SULFUR - S	7704-34-9*	1-3	15(1)	10(2)	
ALUMINUM OXIDE-Al ₂ O ₃					
	1344-28-1	1-2	15 DUST RESPIRABLE	10 DUST	
POTASSIUM OXIDE-K ₂ O		0.5-2	15(1)	10(2)	
CHROME OXIDE-Cr ₂ O ₃		0.3-0.5			
CHROMIC OXIDE	1308-38-9		0.5	0.5	
CHROMIUM METAL	-		1	0.5	
Cr(VI) COMPOUNDS	-		0.1	0.01	
COPPER OXIDE-Cu ₂ O		0.2-0.4	1 DUST, 0.1 FUME	1 DUST, 0.2 FUME	
CUPRIC OXIDE	1317-38-0				
CALCIUM OXIDE-CaO	1306-19-0	0.05-0.15	0.005	0.01 DUST, 0.002 RESPIRABLE	

*INDICATES CAS# FOR THE METAL. CALC. STANDS FOR CALCULATION. C = CEILING LEVEL STEL = SHORT TERM EXPOSURE LIMIT.

(1) NUISANCE DUST LIMIT APPLIED TO PARTICULATE NOT OTHERWISE REGULATED.

(2) PARTICULATES NOT OTHERWISE CLASSIFIED.

SECTION 3 HAZARDS IDENTIFICATION

POTENTIAL HEALTH EFFECTS:

EYE: WILL CAUSE IRRITATION TO THE EYES.

SKIN: PROLONGED OR EXTENDED CONTACT WITH THE DUST IRRITATE THE SKIN. ARSENIC IS CAPABLE OF PRODUCING KERTOSSES, ESPECIALLY OF THE PALMS AND

SOLES. ECZEMATOUS DERMATITIS HAS BEEN REPORTED FOR TRIVALENT CHROMIUM (III) COMPOUNDS. CHROME (VI) MAY CAUSE IRRITANT AND ALLERGIC CONTACT DERMATITIS.

INGESTION: CADMIUM IS HIGHLY IRRITATING TO THE STOMACH LINING. SWALLOWING THE DUST MAY CAUSE SORE THROAT, NAUSEA, VOMITING, ABDOMINAL PAIN, DIARRHEA, AND PAIN IN THE EXTREMITIES AND JOINTS. ACUTE ENCEPHALOPATHY IS ALSO ASSOCIATED WITH EXTREMELY HIGH LEAD DOSES. HIGH DOSES OF ARSENIC CAN BE FATAL.

INHALATION: ACUTE EFFECTS ARE THE SAME AS THOSE OF INGESTION. ADDITIONALLY, MAY CAUSE DRY THROAT, COUGH, HEADACHE, SHORTNESS OF BREATH, CHEST PAINS AND CHILLS. INHALATION OF ZINC, MAGNESIUM AND MANGANESE MAY RESULT IN METAL FUME FEVER. EXTREME OVEREXPOSURE TO CADMIUM MAY RESULT IN SEVERE LUNG IRRITATION AND PULMONARY EDEMA THAT CAN BE FATAL. THIS IS PRECEDED BY A SENSATION OF THROAT CONSTRICTION, METALLIC TASTE, AND COUGH. SYMPTOMS MAY PROGRESS TO SHORTNESS OF BREATH, CHEST PAIN, FLU-LIKE SYMPTOMS, WITH WEAKNESS, FEVER, HEADACHE, AND CHILLS.

CHRONIC (AND CANCER) INFORMATION: PROLONGED EXPOSURE TO LEAD MAY CAUSE FATIGUE, GASTROINTESTINAL PAIN, ANEMIA, POSSIBLE CENTRAL NERVOUS SYSTEM AND KIDNEY DAMAGE. LEAD AND LEAD COMPOUNDS ARE LISTED BY INTERNATIONAL AGENCY FOR RESEARCH ON CANCER (IARC) AS POSSIBLE CARCINOGENS. REPEATED OR LONG-TERM EXPOSURE TO CADMIUM MAY RESULT IN KIDNEY DAMAGE AND INCREASED RISK OF PROSTATE, RESPIRATORY AND GENITOURINARY CANCERS. LONG-TERM EXPOSURE TO ARSENIC IS ASSOCIATED WITH LUNG CANCER. BOTH CADMIUM AND ARSENIC ARE DESIGNATED AS CARCINOGENS BY OSHA. THE IARC AND THE NATIONAL TOXICOLOGY PROGRAM (NTP) CONSIDER CHROME (VI) AS CARCINOGENIC TO HUMANS AND CRYSTALLIZED SILICON DIOXIDE AS PROBABLY CARCINOGENIC TO HUMANS. CRYSTALLINE SILICON DIOXIDE MAY CAUSE SILICOSIS. MANGANESE MAY RESULT IN DAMAGE TO THE LUNGS, KIDNEYS, BLOOD, AND CENTRAL NERVOUS SYSTEM.

TERATOGENIC/MUTAGENIC INFORMATION: MUTAGENIC EFFECTS DATA HAS BEEN CITED FOR LEAD IN RTECS.

REPRODUCTION INFORMATION: REPRODUCTIVE EFFECTS DATA HAS BEEN CITED FOR LEAD IN RTECS.

MEDICAL CONDITIONS GENERALLY AGGRAVATED BY EXPOSURE: PERSONS WITH PRE-EXISTING HEART CONDITIONS OR IMPAIRED RESPIRATORY FUNCTION.

EYE CONTACT: IMMEDIATELY FLUSH WITH WATER FOR AT LEAST 15 MINUTES, CAREFULLY LIFTING EYELID TO EXPOSE THE EYE TO CONTACT WITH THE WATER. REMOVE CONTACT LENS, IF PRESENT, AND REPEAT WITH AN ADDITIONAL 15 MINUTE FLUSH. IF IRRITATION DEVELOPS OR SYMPTOMS PERSIST, GET MEDICAL ASSISTANCE.

SKIN CONTACT: WASH THOROUGHLY WITH SOAP AND WATER AFTER SKIN CONTACT.

INHALATION: IF AFFECTED, REMOVE TO FRESH AIR. GIVE CPR/ARTIFICIAL RESPIRATION IF NOT BREATHING. PROVIDE OXYGEN IF BREATHING IS DIFFICULT. IF IRRITATION DEVELOPS OR SYMPTOMS PERSIST, GET MEDICAL ASSISTANCE.

IF SWALLOWED: DO NOT INDUCE VOMITING. IF PERSON IS ALERT AND NOT CONVULSING, ADMINISTER 6 TO 8 GLASS OF WATER TO DILUTE THE MATERIAL. THEN CALL CLOSEST POISON CONTROL CENTER. IF SPONTANEOUS VOMITING OCCURS, HAVE PERSON LEAN FORWARD TO AVOID BREATHING IN OF EMESIS. RINSE MOUTH AND ADMINISTER MORE WATER.

NOTES TO PHYSICIAN: NONE GIVEN.

USERS SHOULD COMPLY WITH APPLICABLE OSHA AND RCRA AND OTHER STATE AND FEDERAL REGULATIONS INCLUDING (BUT NOT LIMITED TO) 29 CFR 1910.1000 (AIR CONTAMINANTS), 29 CFR 1910.1025 (LEAD), 29CFR 1910.1027 (CADMIUM), 29 CFR 1910.1200 (HAZARD COMMUNICATION) AND 40 CFR 262 ET AL. (HAZARDOUS WASTE).

SECTION 5 FIRE FIGHTING MEASURES

EXTINGUISHING MEDIA: THIS MATERIAL IS COMPLETELY NON-COMBUSTIBLE. FOR FIRE IN CLOSE PROXIMITY, USE CO2, FOAM, DRY CHEMICAL OR WATER SPRAY.

SPECIAL FIREFIGHTING METHODS: FIREFIGHTERS SHOULD USE SELF-CONTAINED BREATHING APPARATUS.

UNUSUAL FIRE & EXPLOSION HAZARDS: NONE KNOWN

SECTION 6 ACCIDENTAL RELEASE MEASURES

SPILL/CLEANUP PROCEDURE: PROMPTLY CLEAN UP MATERIAL SPILLS, USE WATER TO WET DOWN TO MINIMIZE DUST DURING CLEANUP. SEE SECTION 8 FOR EXPOSURE CONTROL AND PERSONAL PROTECTION INFORMATION. THIS MATERIAL IS A CERCLA AND SARA TITLE III HAZARDOUS SUBSTANCE. SPILLS OF THIS MATERIAL IN EXCESS OF THE REPORTABLE QUANTITY OF 10 LBS (40 CFR 302 AND 40 CFR 355) MAY REQUIRE NOTIFICATION OF FEDERAL, STATE, AND/OR LOCAL AGENCIES.

USERS SHOULD COMPLY WITH APPLICABLE OSHA AND RCRA AND OTHER STATE AND FEDERAL REGULATIONS INCLUDING (BUT NOT LIMITED TO) 29 CFR 1910.1000 (AIR CONTAMINANTS), 29 CFR 1910.1025 (LEAD), 29 CFR 1910.1027 (CADMIUM) AND 29 CFR 1910.1200 (HAZARD COMMUNICATION), 40 CFR 262 ET AL. (HAZARDOUS WASTE).

SECTION 7 HANDLING AND STORAGE

DO NOT BREATHE DUST.

IF USED OR HANDLED IN A MANNER WHICH GENERATES DUST, SEE SECTION 8 FOR

SPECIFIC PERSONAL PROTECTION INFORMATION.

PREVENT SKIN CONTACT, INGESTION AND INHALATION WHEN HANDLING MATERIAL.

STORE ONLY IN ACCORDANCE WITH THE PROVISIONS OF RCRA (INCLUDING BUT NOT LIMITED TO 40 CFR 260-268) AND APPLICABLE STATE REGULATIONS.

PROMPTLY CLEAN UP MATERIAL SPILLS, USE WATER TO WET DOWN TO MINIMIZE DUST DURING CLEANUP. SEE SECTION 6 FOR ACCIDENTAL RELEASE MEASURES.

REFER TO SECTION 11 FOR DISPOSAL INFORMATION.

USERS SHOULD COMPLY WITH APPLICABLE OSHA AND RCRA AND OTHER STATE AND FEDERAL REGULATIONS INCLUDING (BUT NOT LIMITED TO) 29 CFR 1910.1000 (AIR CONTAMINANTS), 29 CFR 1910.1025 (LEAD), 29 CFR 1910.1027 (CADMIUM) AND 29 CFR 1910.1200 (HAZARD COMMUNICATION), 40 CFR 262 ET AL. (HAZARDOUS WASTE).

SECTION 8 EXPOSURE CONTROLS, PERSONAL PROTECTION

RESPIRATORY PROTECTION: DO NOT BREATHE DUST.

IF CONCENTRATIONS IS GREATER THAN THE PEL, BUT LESS THAN 10 TIMES PEL, USE A NIOSH APPROVED HALF-MASK RESPIRATOR WITH HEPA CARTRIDGE.

FOR CONCENTRATIONS ABOVE 10 TIMES PEL, BUT LESS THAN 50 TIMES PEL USE A NIOSH APPROVED FULL FACE RESPIRATOR WITH HEPA CARTRIDGE.

WHERE AIRBORNE CONCENTRATION MAY EXCEED 50 TIMES PEL, USE A SUPPLIED-AIR RESPIRATOR.

VENTILATION: USE LOCAL OR GENERAL VENTILATION TO MAINTAIN AIRBORNE CONCENTRATIONS BELOW THE PEL. IF VENTILATION FAILS TO MAINTAIN CONCENTRATIONS BELOW THE PEL, RESPIRATORY PROTECTION IS REQUIRED BY FEDERAL AND/OR STATE REGULATIONS; SEE RESPIRATORY PROTECTION INFORMATION ABOVE.

RECOMMENDED GLOVES: RUBBER GLOVES ARE RECOMMENDED

EYE PROTECTION: CHEMICAL SAFETY GOGGLES ARE REQUIRED IF FULL FACE RESPIRATORY PROTECTION IS NOT WORN.

OTHER PROTECTION: EYE WASH AND SAFETY SHOWER SHOULD BE NEARBY AND READY FOR USE.

WEAR COVERALLS AND GLOVES AS NECESSARY TO PROVIDE PROTECTION; CLOTHING AND PERSONAL PROTECTIVE EQUIPMENT WHICH HAS COME IN CONTACT WITH THIS MATERIAL MAY REQUIRE SPECIAL HANDLING AS SPECIFIED IN THE REGULATIONS REFERENCED BELOW.

USERS SHOULD COMPLY WITH APPLICABLE OSHA AND RCRA AND OTHER STATE AND FEDERAL REGULATIONS INCLUDING (BUT NOT LIMITED TO) 29 CFR 1910.1000 (AIR CONTAMINANTS), 29 CFR 1910.1023 (LEAD), 29 CFR 1910.1027 (CADMIUM) AND 29 CFR 1910.1200 (HAZARD COMMUNICATION), 40 CFR 262 ET AL. (HAZARDOUS WASTE).

SECTION 9 PHYSICAL AND CHEMICAL PROPERTIES

APPEARANCE: FINE, GRAY DUST

ODOR: NONE

BOILING POINT: NA DEG F.

VAPOR PRESSURE (mm HG): NA mm AT DEG F.

VAPOR DENSITY (AIR = 1): NA

SPECIFIC GRAVITY: 1.3 (WATER = 1)

PERCENT VOLATILE: NA %

EVAPORATION RATE: NA REFERENCE: NA

WATER SOLUBILITY: N (C = COMPLETE, P = PARTIAL, N = NEGLIGIBLE, D = DISPERSION)

FLASH POINT: NA DEG F. METHOD.

AUTO IGNITION TEMPERATURE: NG DEG F.

EXPLOSION LIMITS:

LEL: NA UEL: NA

SECTION 10 STABILITY AND REACTIVITY

STABILITY: STABLE

INCOMPATIBILITY: NONE KNOWN

CONDITIONS TO AVOID: NONE KNOWN.

HAZARDOUS DECOMPOSITION PRODUCTS: NONE

HAZARDOUS POLYMERIZATION: NO

SECTION 11 DISPOSAL CONSIDERATIONS

EPA WASTE CODES: K061

DOT NUMBER: OTHER REGULATED MATERIAL (ORM)

DOT HAZARD CLASS/HAZARD LABEL: LABEL IN ACCORDANCE WITH 49 CFR 173.

USERS SHOULD COMPLY WITH APPLICABLE OSHA AND RCRA AND OTHER STATE AND FEDERAL REGULATIONS INCLUDING (BUT NOT LIMITED TO) 29 CFR 1910.1000 (AIR CONTAMINANTS), 29 CFR 1910.1023 (LEAD), 29 CFR 1910.1027 (CADMIUM) AND 29 CFR 1910.1200 (HAZARD COMMUNICATION), 40 CFR 262 ET AL. (HAZARDOUS WASTE).

OREGON STEEL MILLS HAS PREPARED THIS INFORMATION BASED ON ITS REASONABLE REVIEW OF AVAILABLE INFORMATION RELATING TO THE CHEMICALS THAT MAKE UP THE PRODUCT WHICH UNDERLYING INFORMATION WAS NOT CREATED OR PREPARED BY OREGON STEEL MILLS. ALTHOUGH OREGON STEEL MILLS PROVIDES THIS INFORMATION AS A PUBLIC SERVICE, IT DOES NOT REPRESENT OR WARRANT THE ACCURACY, COMPLETENESS OR APPLICABILITY OF THE INFORMATION CONTAINED HEREIN. OREGON STEEL MILLS DOES NOT WARRANT THE FITNESS OF THE PRODUCT FOR ANY PARTICULAR USE AND HAS NOT EVALUATED THE HAZARDS ASSOCIATED WITH ANY PARTICULAR USES OF THE PRODUCT. ALL EMPLOYERS USING THE PRODUCT SHOULD PERFORM ALL REVIEW AND TESTING AND TAKE ALL PRECAUTIONS REQUIRED TO PROTECT THEIR EMPLOYEES FROM ANY HAZARDS ASSOCIATED WITH THEIR USE OF THE PRODUCT.

N = NO

Y = YES

UN = UNKNOWN

NA = NOT APPLICABLE

NRG = NOT REGULATED

NE = NOT ESTABLISHED

NG = NOT GIVEN

NR = NOT REQUIRED

PDXI. 196499.1 1956S 0007



13585 NE Whitaker Way • Portland, OR 97230
Phone (503) 255-6060 • Fax (503) 255-0506
www.horizonengineering.com

OSM Background ΔP in inches of H_2O

11/17/01

Time	11:03	12:30	
Row #	R1	R2	R3
1	5.1	4.9	5.9
2	4.3	-	4.9
3	5.1	6.1	5.5
4	4.6	5.5	4.8
5	4.9	5.9	-
6	4.5	5.5	5.4
7	3.9	5.2	5.3
8	4.5	5.7	6.3
9	4.0	5.4	6.9
10	3.9	5.0	6.0
11	4.0	5.5	6.6
12	-	5.5	7.1
13	4.5	5.1	6.0
14	5.0	5.6	5.5
15	5.0	5.6	6.0
16	4.0	5.4	6.1

Calibration Information

High-Volume Sampler Calibrations

Pitots

Thermocouples and Indicators

Shortridge Micro manometer

Magnehelic Gauges

Barometer

NO_x Converter Efficiency Data

Calibration Gas Certificates

Audit Sample Results, reporting forms & instructions

High Volume Orifice Calibration Data

File	#1192	A= 47.895	#1032	A= 45.260					
Date	10-08-01	B= 0.476	10-08-01	B= 0.481					
Tester	DBC	Last A= 47.008	Last	A= 45.507					
Analysis	DBC	B= 0.452		B= 0.456					
	CHANGE	A= 1.9%	CHANGE	A= -0.5%					
		B= 5.4%		B= 5.5%					
General Form Of Solution: $Q(68F) = A \cdot (d/Ho)^B$; $A = Q(68) @ T68F, d/Ho = 1.00$ $Q = A \cdot (d/Ho)^B$									
1] $\ln(Q) = \ln(A) + B \cdot \ln(d/Ho)$ 2] $Z = \ln(Q)$ N W C1 Z $W = \ln(d/Ho)$ W W ² C2 WZ $C1 = \ln(A)$ $C2 = B$ 3] $Z = C1 + C2(W)$									
Point	dHo (in H2O)	Q (cfm) @To=68F	Q (cfm) Calculated	Difference %	Point	dHo (in H2O)	Q (cfm) @To=68F	Q (cfm) Calculated	Difference %
1	0.100	15.82	15.99	1.1%	1	0.100	14.93	14.96	0.2%
2	0.100	15.86	15.99	0.9%	2	0.100	14.97	14.96	-0.1%
3	0.100	16.50	15.99	-3.0%	3	0.100	15.71	14.96	-4.8%
4	0.200	22.23	22.25	0.1%	4	0.200	19.81	20.87	5.4%
5	0.200	22.07	22.25	0.8%	5	0.200	20.39	20.87	1.4%
6	0.200	21.65	22.25	2.8%	6	0.200	20.43	20.87	2.2%
7	0.400	31.33	30.96	-1.2%	7	0.400	29.41	29.13	-0.9%
8	0.410	31.65	31.32	-1.0%	8	0.400	29.39	29.13	-0.9%
9	0.410	31.80	31.32	-1.5%	9	0.400	29.30	29.13	-0.6%
10	0.600	37.48	37.55	0.2%	10	0.600	35.45	35.40	-0.1%
11	0.600	37.47	37.55	0.2%	11	0.600	35.67	35.40	-0.7%
12	0.610	37.69	37.85	0.4%	12	0.600	35.88	35.40	-1.3%
13	0.800	43.34	43.07	-0.6%	13	0.800	40.50	40.65	0.4%
14	0.800	43.03	43.07	0.1%	14	0.800	40.22	40.65	1.1%
15	0.790	43.05	42.81	-0.6%	15	0.800	40.39	40.65	0.6%
16	1.000	47.39	47.89	1.1%	16	1.000	46.22	45.26	-2.1%
17	1.000	47.44	47.89	1.0%	17	1.000	44.86	45.26	0.9%
18	1.000	48.12	47.89	-0.5%	18	1.000	45.32	45.26	-0.1%
Average					Average				
No#	W	W ²	Z	WZ	No#	W	W ²	Z	WZ
1	-2.30	5.3019	2.7613	-6.3582	1	-2.30	5.3019	2.7034	-6.2248
2	-2.30	5.3019	2.7637	-6.3637	2	-2.30	5.3019	2.7063	-6.2314
3	-2.30	5.3019	2.8031	-6.4543	3	-2.30	5.3019	2.7544	-6.3423
4	-1.61	2.5903	3.1016	-4.9918	4	-1.61	2.5903	2.9861	-4.8059
5	-1.61	2.5903	3.0943	-4.9801	5	-1.61	2.5903	3.0247	-4.8681
6	-1.61	2.5903	3.0751	-4.9492	6	-1.61	2.5903	3.0172	-4.8560
7	-0.92	0.8396	3.4446	-3.1562	7	-0.92	0.8396	3.3813	-3.0983
8	-0.89	0.7949	3.4547	-3.0802	8	-0.92	0.8396	3.3807	-3.0977
9	-0.89	0.7949	3.4595	-3.0845	9	-0.92	0.8396	3.3776	-3.0948
10	-0.51	0.2609	3.6239	-1.8512	10	-0.51	0.2609	3.5683	-1.8228
11	-0.51	0.2609	3.6235	-1.8510	11	-0.51	0.2609	3.5742	-1.8258
12	-0.49	0.2443	3.6294	-1.7940	12	-0.51	0.2609	3.5800	-1.8288
13	-0.22	0.0498	3.7691	-0.8411	13	-0.22	0.0498	3.7012	-0.8259
14	-0.22	0.0498	3.7618	-0.8394	14	-0.22	0.0498	3.6943	-0.8244
15	-0.24	0.0556	3.7623	-0.8869	15	-0.22	0.0498	3.6987	-0.8253
16	0.00	0.0000	3.8584	0.0000	16	0.00	0.0000	3.8335	0.0000
17	0.00	0.0000	3.8594	0.0000	17	0.00	0.0000	3.8034	0.0000
18	0.00	0.0000	3.8736	0.0000	18	0.00	0.0000	3.8138	0.0000
No#	W	W ²	Z	WZ	No#	W	W ²	Z	WZ
18	-16.63	27.0274	61.7193	-51.4816	18	-16.69	27.13	60.60	-50.5722
18	-16.63	C1	61.72		18	-16.69	C1	60.60	
-16.63	27.03	C2	-51.48		-16.69	27.13	C2	-50.57	
1	-0.92	C1	3.43	C1= 3.86901	1	-0.93	C1	3.37	C1= 3.81242
0	11.66	C2	5.55	C2= 0.47632	0	11.66	C2	5.61	C2= 0.48088
1	-0.92	C1	3.43	A= 47.89474	1	-0.93	C1	3.37	A= 45.25972
0	1	C2	0.48	B= 0.47632	0	1	C2	0.48	B= 0.48088
1	0	C1	3.87	@1.00 47.89	1	0	C1	3.81	@1.00 45.26
0	1	C2	0.48	@0.10 15.99	0	1	C2	0.48	@0.10 14.96

Pitot Calibration Calculations

Date 8-Oct-01		Pb= 30.25 in Hg		File 12-Dec-01		Ta= 520.0 R							
Method 3 section 4. Horizon Shop													
Pitot	Tested Last	[Cp] New	[S]			Pitot	Tested Last	[Cp] New	[S]				
ss7-4	8-Oct-01	0.81562	0.00456			9s-1							
ss7-5	9-Oct-01	0.81041	0.00771			6s-1	9-Oct-01	0.83139	0.00557				
ss7-6	9-Oct-01	0.78745	0.00880			6s-2							
ss7-7	9-Oct-01	0.83171	0.00588			HT-4	10-Dec-01	0.83782	0.00469				
ss9-1	9-Oct-01	0.78734	0.00768			SR-18	8-Oct-01	0.82637	0.00708				
ss10-1	10-Dec-01	0.83477	0.00193			SR-36	8-Oct-01	0.82937	0.00769				
ss10-2	9-Oct-01	0.79742	0.00299			SR-48	8-Oct-01	0.81569	0.00000				
ss10-3	9-Oct-01	0.80118	0.00534			10-s	10-Dec-01	0.82809	0.00625				
3s-1	11-Dec-01	0.82465	0.00653			11-s	10-Oct-01	0.80294	0.00539				
3s-2						14-s1	10-Oct-01	0.82367	0.00494				
5s-1	9-Oct-01	0.84199	0.00913			14-S2	9-Oct-01	0.81017	0.00764				
5s-2						WC 3-5	8-Oct-01	0.81561	0.00470				
dPp	dPs	Cp	dS	Avg Cp	S	dPp	dPs	Cp	dS	Avg Cp	S		
ss7-4	0.375	0.555	0.81377	0.00184	0.81562	0.00456	6s-1	0.371	0.530	0.82829	0.00310	0.83139	0.00557
Pass	0.845	1.230	0.82056	0.00494			Pass	0.830	1.200	0.82335	0.00804		
10/8/01	1.200	1.750	0.81980	0.00418			10/08/01	1.180	1.650	0.83721	0.00582		
JKG	1.300	1.950	0.80833	0.00728			JKG	1.350	1.890	0.83670	0.00531		
ss7-5	0.385	0.575	0.81009	0.00033	0.81041	0.00771							
Pass	0.835	1.200	0.82583	0.01541									
10/9/01	1.200	1.800	0.80833	0.00208									
JKG	1.330	2.050	0.79741	0.01300									
ss7-6	0.390	0.640	0.77282	0.01464	0.78745	0.00880	HT-4	0.330	0.470	0.82955	0.00827	0.83782	0.00469
Pass	0.795	1.250	0.78952	0.00207			Pass	0.750	1.050	0.83670	0.00111		
10/9/01	1.250	1.900	0.80300	0.01554			12/10/01	1.150	1.600	0.83931	0.00150		
JKG	1.350	2.150	0.78448	0.00297			JKG	1.350	1.850	0.84570	0.00788		
ss7-7	0.390	0.550	0.83366	0.00195	0.83171	0.00588	SR-18	0.380	0.545	0.82666	0.00029	0.82637	0.00708
Pass	0.830	1.200	0.82335	0.00836			Pass	0.850	1.180	0.84024	0.01387		
10/9/01	1.250	1.730	0.84153	0.00982			10/08/01	1.100	1.610	0.81831	0.00806		
JKG	1.330	1.900	0.82829	0.00341			JKG	1.270	1.850	0.82026	0.00611		
ss9-1	0.390	0.640	0.77282	0.01452	0.78734	0.00768	SR-36	0.371	0.540	0.82059	0.00878	0.82937	0.00583
Pass	0.770	1.220	0.78650	0.00084			Pass	0.820	1.150	0.83598	0.00661		
10/9/01	1.250	1.950	0.79263	0.00529			10/08/01	1.150	1.650	0.82650	0.00287		
JKG	1.330	2.050	0.79741	0.01007			JKG	1.300	1.830	0.83441	0.00504		
ss10-1	0.350	0.495	0.83247	0.00230	0.83477	0.00193	SR-48	0.365	0.545	0.81018	0.00550	0.81569	0.00769
Pass	0.850	1.200	0.83321	0.00156			Pass	0.795	1.200	0.80580	0.00988		
12/10/01	1.000	1.400	0.83670	0.00193			10/08/01	1.150	1.650	0.82650	0.01081		
JKG	1.250	1.750	0.83670	0.00193			JKG	1.270	1.850	0.82026	0.00457		
ss10-2	0.370	0.575	0.79415	0.00327	0.79742	0.00299	10-s	0.310	0.430	0.84059	0.01249	0.82809	0.00625
Pass	0.825	1.280	0.79480	0.00262			Pass	0.870	1.250	0.82592	0.00217		
10/9/01	1.200	1.850	0.79733	0.00008			12/10/01	1.100	1.600	0.82087	0.00723		
JKG	1.350	2.050	0.80339	0.00597			JKG	1.250	1.800	0.82500	0.00309		
ss10-3	0.380	0.585	0.79790	0.00328	0.80118	0.00534	11-s ✓	0.405	0.625	0.79694	0.00601	0.80294	0.00539
Pass	0.795	1.200	0.80580	0.00462			Pass	0.900	1.350	0.80833	0.00539		
10/9/01	1.230	1.850	0.80724	0.00606			10/10/01	1.300	2.000	0.79816	0.00478		
JKG	1.350	2.100	0.79377	0.00741			JKG	1.400	2.100	0.80833	0.00539		
3s-1	0.350	0.495	0.83247	0.00782	0.82465	0.00653	14-s1 ✓	0.390	0.560	0.82618	0.00251	0.82367	0.00494
Pass	0.715	1.050	0.81695	0.00770			Pass	0.775	1.100	0.83098	0.00731		
12/11/01	1.130	1.650	0.81928	0.00537			10/10/01	1.250	1.850	0.81378	0.00989		
JKG	1.300	1.850	0.82989	0.00525			JKG	1.350	1.950	0.82373	0.00006		
3s-2	na	na	#VALUE!	#VALUE!	#VALUE!	#VALUE!	14-S2	0.385	0.565	0.81722	0.00706	0.81017	0.00764
#VALUE!	na	na	#VALUE!	#VALUE!	#VALUE!	#VALUE!	Pass	0.820	1.200	0.81837	0.00821		
na	na	na	#VALUE!	#VALUE!	#VALUE!	#VALUE!	10/09/01	1.200	1.330	0.80168	0.00849		
na	na	na	#VALUE!	#VALUE!	#VALUE!	#VALUE!	JKG	1.350	2.050	0.80339	0.00678		
5s-1	0.385	0.525	0.84779	0.00579	0.84199	0.00913	WC 3-5	0.380	0.555	0.81918	0.00357	0.81561	0.00470
Pass	0.765	1.050	0.84503	0.00304			Pass	0.810	1.200	0.81337	0.00224		
10/9/01	1.250	1.690	0.85143	0.00943			10/08/01	1.210	1.750	0.82321	0.00760		
JKG	1.350	1.950	0.82373	0.01826			JKG	1.300	1.900	0.81890	0.00329		

Thermocouple Calibration

Date: 02-Oct-01		Deviation		@60 F	7.8 Allowable Diff.	Pb=	29.60 in Hg	BPG			
Next Calibration: 03-Oct-01		Limit		@212 F	10.1 Allowable Diff.	Ta=	60.0 oF	980324tc			
24-Oct-01				@325 F	11.8 Allowable Diff.						
Probe/ID	Ambient			Boiling, Water			Boiling, Oil			Average Difference %	
	Standard, F	Measured, F	Difference %	Standard, F	Measured, F	Difference %	Standard, F	Measured, F	Difference %		
Probe 3-1	70.4	70.6	0.0%	212.2	212.2	0.0%	530.2	523.6	0.7%	0.2%	
Probe 3-2	70.6	70.4	0.0%	212.2	212.2	0.0%	534.2	531.2	0.3%	0.1%	
Probe 3-3											
Probe wc3-4											
Probe 3-5	70.4	70.4	0.0%	211.6	212.2	-0.1%	527.4	522.8	0.5%	0.1%	
Probe 3-6	70.2	70.0	0.0%	212.2	213.2	-0.1%	536.4	538.4	-0.2%	-0.1%	
Probe 3-7	70.2	71.2	-0.2%	212.2	212.0	0.0%	532.0	529.0	0.3%	0.0%	
Probe 3-8	57.8	56.8	0.2%	212.2	212.0	0.0%	584.0	578.0	0.6%	0.3%	
Probe 4-1	70.8	70.8	0.0%	211.6	211.8	0.0%	546.0	548.0	-0.2%	-0.1%	
Probe 4-2	70.6	70.8	0.0%	211.4	212.0	-0.1%	548.0	550.0	-0.2%	-0.1%	
Probe 4-3	58.6	56.8	0.3%	211.4	212.2	-0.1%	574.0	574.0	0.0%	0.1%	
Probe 4-4	58.4	56.2	0.4%	211.4	213.0	-0.2%	575.0	571.0	0.4%	0.2%	
Probe 4-5	70.6	70.6	0.0%	211.4	211.6	0.0%	548.0	547.0	0.1%	0.0%	
Probe 4-6	70.4	70.6	0.0%	211.4	212.0	-0.1%	545.0	540.0	0.5%	0.1%	
Probe 4-7	70.6	71.4	-0.2%	211.6	212.0	-0.1%	543.0	537.0	0.6%	0.1%	
Probe 5-2	58.8	56.2	0.5%	211.0	212.2	-0.2%	569.0	567.0	0.2%	0.2%	
Probe 5-3	70.8	71.2	-0.1%	212.2	213.8	-0.2%	546.0	543.0	0.3%	0.0%	
Probe 5-4	71.0	72.2	-0.2%	211.8	211.4	0.1%	543.0	539.0	0.4%	0.1%	
Probe 5-5	70.8	71.2	-0.1%	212.4	211.8	0.1%	545.0	545.0	0.0%	0.0%	
Probe 5-6	70.8	71.2	-0.1%	211.6	211.6	0.0%	546.0	548.0	-0.2%	-0.1%	
Probe 5-7	70.8	71.4	-0.1%	211.8	211.6	0.0%	545.0	544.0	0.1%	0.0%	
Probe 5-8	70.8	72.0	-0.2%	211.6	211.6	0.0%	542.0	543.0	-0.1%	-0.1%	
Probe 5-9	70.4	71.4	-0.2%	211.8	212.4	-0.1%	542.0	543.0	-0.1%	-0.1%	
Probe 7-1	71.4	71.8	-0.1%	212.0	211.6	0.1%	533.0	530.0	0.3%	0.1%	
Probe 7-2	71.4	73.4	-0.4%	211.8	211.8	0.0%	543.0	540.0	0.3%	-0.0%	
Probe 7-3	71.2	72.8	-0.3%	211.4	213.0	-0.2%	538.0	538.0	0.0%	-0.2%	
Probe 7-4	71.4	71.8	-0.1%	212.0	212.0	0.0%	543.0	544.0	-0.1%	-0.1%	
Probe 7-5	71.4	75.0	-0.7%	212.2	212.2	0.0%	543.0	540.0	0.3%	-0.1%	
Probe 7-6	71.6	72.4	-0.2%	211.2	213.0	-0.3%	544.0	544.0	0.0%	-0.2%	
Probe 9-1	70.6	71.8	-0.2%	211.2	212.2	-0.1%	533.0	534.0	-0.1%	-0.1%	
Probe 10-1	71.6	71.6	0.0%	212.0	212.6	-0.1%	532.0	533.0	-0.1%	-0.1%	
Probe 10-2	71.6	72.2	-0.1%	211.2	212.6	-0.2%	545.0	542.0	0.3%	0.0%	
Probe 10-3	71.4	71.4	0.0%	211.2	212.8	-0.2%	549.0	546.0	0.3%	0.0%	
FS Pitot 10-S			0.0%			0.0%			0.0%	0.0%	
FS Pitot 11-S	75.0	75.4	-0.1%	211.0	211.2	0.0%	542.0	541.0	0.1%	0.0%	
FS Pitot 14-S	75.4	75.2	0.0%	211.0	213.6	-0.4%	510.0	511.0	-0.1%	-0.2%	
14-2	75.8	75.8	0.0%	211.2	211.4	0.0%	525.0	523.0	0.2%	0.1%	
A1											
A2			0.0%			0.0%			0.0%	0.0%	
A3	62.8	62.4	0.1%	211.6	214.0	-0.4%	337.8	349.0	-1.4%	-0.6%	
A4	63.0	63.4	-0.1%	211.4	211.0	0.1%	353.0	354.0	-0.1%	-0.0%	
A5			0.0%			0.0%			0.0%	0.0%	
A6	63.0	63.8	-0.2%	211.8	210.2	0.2%	353.0	349.0	0.5%	0.2%	
F3	72.4	70.8	0.3%	212.2	209.4	0.4%	563.2	560.6	0.3%	0.3%	
F4	73.2	71.4	0.3%	211.6	211.2	0.1%	538.2	539.2	-0.1%	0.1%	
F5			0.0%			0.0%			0.0%	0.0%	
F6	70.8	71.4	-0.1%	211.8	210.8	0.1%	525.0	525.8	-0.1%	-0.0%	
F9	63.0	63.2	0.0%	211.6	214.0	-0.4%	345.6	342.0	0.4%	0.0%	
F11	62.6	65.2	-0.5%	212.2	214.2	-0.3%	355.2	357.2	-0.2%	-0.3%	
F14	73.0	71.8	0.2%	211.8	211.8	0.0%	551.2	549.6	0.2%	0.1%	
F12	71.0	71.6	-0.1%	212.0	213.0	-0.1%	547.6	546.2	0.1%	-0.0%	
F13	72.8	72.0	0.2%	211.8	213.4	-0.2%	584.2	583.4	0.1%	0.0%	
F73	70.8	70.4	0.1%	211.6	212.4	-0.1%	550.4	550.2	0.0%	0.0%	
F23	62.8	63.2	-0.1%	211.8	212.8	-0.1%	360.0	355.0	0.6%	0.1%	
F51											
F84	62.8	63.2	-0.1%	211.4	214.0	-0.4%	353.0	345.8	0.9%	0.1%	
F81	72.0	71.4	0.1%	211.8	212.8	-0.1%	553.4	552.8	0.1%	0.0%	
F85	72.6	71.2	0.3%	212.0	213.2	-0.2%	386.0	392.0	-0.7%	-0.2%	
6S-2											
Probe w/c 4			0.0%			0.0%			0.0%	0.0%	
B1											
B3			0.0%			0.0%			0.0%	0.0%	
B4	63.0	63.0	0.0%	211.6	216.0	-0.7%	357.2	356.0	0.1%	-0.2%	
B7	70.4	71.6	-0.2%	211.0	211.0	0.0%	473.4	475.0	-0.2%	-0.1%	
B10			0.0%			0.0%			0.0%	0.0%	
B11	71.0	71.4	-0.1%	212.2	210.6	0.2%	473.0	480.0	-0.8%	-0.2%	
B15	73.2	71.2	0.4%	212.0	211.8	0.0%	389.0	383.0	0.7%	0.4%	
B16	73.0	71.6	0.3%	212.0	211.6	0.1%	576.0	564.8	1.1%	0.5%	
B17	70.8	71.4	-0.1%	212.0	211.8	0.0%	552.0	550.0	0.2%	0.0%	
AVERAGE	69.2	69.4	0.0%	211.7	212.3	-0.1%	510.2	509.3	0.1%	-0.0%	

Thermocouple Indicator Calibration

Date: 02/20/01		Deviation			PB=			30.05 in Hg			TJH / MJE/DLR	
Next Calibration: 06-01		Limit			Ta=			55.0 of			TCINDM00.WB1	
		@32 F			7.4							
		@212 F			10.1							
		@400 F			12.9							
Thermocouple Indicator	Channel	Measured, F	Standard, F	Deviation % absolute	Measured, F	Standard, F	Deviation % absolute	Measured, F	Standard, F	Deviation % absolute	Average Deviation, %	
Dial multi-indicator	1	139.0	139.6	-0.1	602.0	604.0	-0.2	1255.0	1253.6	0.1	-0.07	
	2	158.0	154.0	0.7	591.0	587.4	0.3	1280.0	1295.6	-0.9	0.04	
	3	107.0	104.0	0.5	523.0	517.0	0.6	1307.0	1307.2	-0.0	0.38	
	4	113.0	100.0	2.3	525.0	524.4	0.1	1353.0	1354.8	-0.1	0.76	
	5	126.0	116.2	1.7	524.0	521.2	0.3	1271.0	1270.4	0.0	0.67	
	6	116.0	117.0	-0.2	523.0	527.4	-0.4	1279.0	1271.6	0.4	-0.06	
	7	144.0	153.2	-1.5	743.0	752.0	-0.7	1388.0	1369.2	1.0	-0.41	
	8	132.0	135.0	-0.5	532.0	533.6	-0.2	1281.0	1296.8	-0.9	-0.52	
	9	113.0	108.8	0.7	560.0	560.2	-0.0	1264.0	1277.0	-0.7	-0.01	
	10	114.0	111.4	0.5	513.0	527.0	-1.4	1328.0	1316.4	0.7	-0.10	
Omega trendicator	1	94.0	90.6	0.6	510.0	509.2	0.1	1215.0	1214.4	0.0	0.25	
	2	102.0	101.4	0.1	520.0	519.0	0.1	1215.0	1214.8	0.0	0.07	
	3	103.0	102.0	0.2	546.0	547.0	-0.1	1213.0	1215.0	-0.1	-0.01	
	4	101.0	100.4	0.1	498.0	500.0	-0.2	1213.0	1215.0	-0.1	-0.07	
	5	101.0	99.8	0.2	537.0	538.0	-0.1	1213.0	1213.8	-0.0	0.02	
Fluke 6393007		60.8	61.6	-0.2	428.6	428.0	0.1	1208.8	1209.4	-0.0	-0.04	
Fluke 7029062		22.6	21.0	0.3	453.8	452.0	0.2	1211.0	1209.2	0.1	0.21	
Fluke 72760077	1			0.0			0.0			0.0	0.00	
	2			0.0			0.0			0.0	0.00	
Meter Box 4	1	84.0	84.6	-0.1	508	509.2	-0.1	1175	1176.6	-0.1	-0.11	
	2	93.0	95.2	-0.4	512	512.8	-0.1	1183	1184.6	-0.1	-0.19	
	3	93.0	94.0	-0.2	514.0	515.4	-0.1	1196.0	1197.0	-0.1	-0.13	
	4	82.0	82.8	-0.1	517.0	518.4	-0.1	1189.0	1190.0	-0.1	-0.12	
	5	82.0	82.2	-0.0	510.0	511.4	-0.1	1178.0	1179.8	-0.1	-0.10	
Meter Box 5	1	109.0	108.4	0.1	538.0	540.2	-0.2	1241.0	1240.8	0.0	-0.03	
	2	104.0	113.0	-1.6	494.0	498.0	-0.4	1405.0	1406.6	-0.1	-0.69	
	3	138.0	142.2	-0.7	530.0	532.4	-0.2	1077.0	1081.0	-0.3	-0.40	
	4	104.0	107.4	-0.6	516.0	516.6	-0.1	1125.0	1124.4	0.0	-0.21	
	5			0.0			0.0			0.0	0.00	
Meter Box 6	1	105.0	104.6	0.1	506.0	506.0	0.0	1212.0	1212.6	-0.0	0.01	
	2	107.0	105.8	0.2	507.0	505.4	0.2	1212.0	1211.0	0.1	0.15	
	3	105.0	103.0	0.4	503.0	501.6	0.1	1212.0	1211.8	0.0	0.17	
	4	105.0	102.8	0.4	502.0	501.0	0.1	1212.0	1211.4	0.0	0.18	
	5	105.0	104.0	0.2	503.0	501.0	0.2	1212.0	1211.2	0.0	0.14	
Meter Box 7	1	102.0	101.6	0.1	506.0	504.6	0.1	1215.0	1215.2	-0.0	0.07	
	2	112.0	111.2	0.1	503.0	502.2	0.1	1214.0	1212.8	0.1	0.10	
	3	103.0	101.0	0.4	510.0	509.4	0.1	1217.0	1216.2	0.0	0.16	
	4	103.0	101.4	0.3	510.0	508.8	0.1	1218.0	1217.6	0.0	0.14	
	5	104.0	102.4	0.3	510.0	508.4	0.2	1218.0	1217.2	0.0	0.17	
Meter Box 8	1	103.0	102.0	0.2	523.0	521.8	0.1	1222.0	1220.2	0.1	0.14	
	2	104.0	101.8	0.4	526.0	524.6	0.1	1219.0	1217.8	0.1	0.20	
	3	102.0	102.4	-0.1	506.0	505.0	0.1	1220.0	1218.0	0.1	0.05	
	4	112.0	110.8	0.2	513.0	511.0	0.2	1220.0	1218.4	0.1	0.17	
	5	112.0	110.6	0.2	518.0	516.6	0.1	1220.0	1218.6	0.1	0.16	
Meter Box 9	1	100.0	101.6	-0.3	507.0	503.0	0.4	1259.0	1260.0	-0.1	0.02	
	2	100.0	97.2	0.5	498.0	497.2	0.1	1270.0	1267.6	0.1	0.24	
	3	101.0	96.8	0.8	511.0	509.0	0.2	1300.0	1300.0	0.0	0.32	
	4	150.0	156.4	-1.0	515.0	517.0	-0.2	1321.0	1321.4	-0.0	-0.42	
	5	123.0	126.6	-0.6	506.0	501.6	0.5	1281.0	1281.6	-0.0	-0.06	
temp. control box 1	1	80.6	81.0	-0.1	226.8	227.8	-0.1	1216.0	1216.2	-0.0	-0.08	
	2	98.0	99.0	-0.2	532.3	533.0	-0.1	1233.0	1233.2	-0.0	-0.09	
	3	59.7	60.0	-0.1	495.4	494.8	0.1	1252.0	1251.6	0.0	0.01	
	4	91.1	92.0	-0.2	521.2	521.4	-0.0	1216.0	1216.0	0.0	-0.06	
	5	78.2	78.8	-0.1	504.2	504.6	-0.0	1216.0	1215.8	-0.0	-0.05	
	6	76.9	77.8	-0.2	593.1	593.2	-0.0	1215.0	1215.2	0.1	-0.02	
temp. control box 2	1	102.0	100.6	0.2	445.0	445.8	-0.1	1212.0	1209.8	0.1	0.10	
	2	106.0	104.8	0.2	554.0	556.4	-0.2	1214.0	1214.2	-0.0	-0.01	
	3	73.0	72.8	0.0	417.0	418.4	-0.2	1213.0	1212.4	0.0	-0.03	
	4	72.0	70.8	0.2	522.0	524.4	-0.2	1210.0	1211.6	-0.1	-0.04	
	5	84.0	84.2	-0.0	497.0	498.8	-0.2	1212.0	1212.0	0.0	-0.07	
	6	83.0	83.6	-0.1	504.0	507.4	-0.4	1208.0	1209.6	-0.1	-0.19	
Van II Heater Controls	1	108.0	119.6	-2.0	507.0	515.8	-0.9	1217.0	1212.8	0.3	-0.88	
	2	122.0	124.6	-0.4	525.0	534.0	-0.9	1220.0	1209.6	0.6	-0.24	
degrees C	3	130.0	131.2	-0.2	282.0	286.5	-0.6	659.0	556.3	0.2	-0.19	
degrees C	4	77.0	78.6	-0.3	304.0	307.0	-0.4	708.0	704.7	0.3	-0.13	
Van III Heater Control	1	101.0	108.4	-1.3	500.0	510.2	-1.1	1213.0	1208.0	0.3	-0.68	
	2	98.0	102.8	-0.9	506.0	522.0	-1.6	1223.0	1218.6	0.3	-0.74	
	3	107.0	109.4	-0.4	508.0	518.6	-1.1	1218.0	1219.2	-0.1	-0.53	
	4	108.0	112.6	-0.8	515.0	524.2	-0.9	1223.0	1221.8	0.1	-0.56	
AVERAGE		100.73	100.93	-0.03	498.66	500.02	-0.14	1197.55	1197.23	0.02	-0.05	

Standard Deviation: 100.93, 100.93, -0.03, 498.66, 500.02, -0.14, 1197.55, 1197.23, 0.02, -0.05

Magnehelic Calibrations

Date	07-feb-01						mgo20220 File	
Testers	cdb						65.0 Temp.(F)	
Location	Whitaker Shop						30.50 Pb(in H2O)	
							Dwyer/bx#1 Manometer	
Magnehelic ID	15 sec. High	leak check Low	Scale Inches	Guage in H2O	Manometer in H2O	Difference in H2O	Difference %	Difference Average
SR#1	OK	OK	electronic	0.000	0.000	0.000	0.0%	0.1%
				1.000	1.000	0.000	0.0%	
				10.100	10.130	0.030	0.3%	
				28.200	28.150	-0.050	-0.2%	
				33.500	33.700	0.200	0.6%	
SR#2	OK	OK	electronic	0.000	0.000	-0.000	0.00%	1.3%
				1.000	1.039	0.039	3.75%	
				4.200	4.287	0.087	2.0%	
				22.500	22.640	0.140	0.62%	
				35.500	35.550	0.050	0.14%	
Dwyer #1	OK	OK	electronic	0.000	0.000	-0.000	0.00%	0.3%
				7.600	7.700	0.100	1.30%	
				15.000	15.020	0.020	0.1%	
				22.200	22.180	-0.020	-0.09%	
				35.500	35.640	0.140	0.39%	

Magnehelic Calibrations

Date	10-Oct-01	05-Feb-01	File					
Testers	PTH	85.0	Temp.(F)					
Location	Whitaker Shop	30.50	Pb(in H2O)					
		0-3Inch/MB-1	Manometer					
Magnehelic ID	15 sec. High	leak check Low	Scale Inches	Magnehelic in H2O	Manometer in H2O	Difference in H2O	Difference %	Difference Average
1-A	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.180	0.160	-0.020	-12.5%	
				0.320	0.320	0.000	0.0%	
				1.000	1.020	0.020	2.0%	
								-2.6%
1-C 21-sept-99	n/a	n/a	1	0.500	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR
1-E	ok	ok	1	0.000	0.000	0.000	0.0%	
				0.080	0.080	0.000	0.0%	
				0.600	0.620	0.020	3.2%	
				0.900	0.800	-0.100	-11.1%	
								0.8%
1-F	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.100	0.100	0.000	0.0%	
				0.400	0.400	0.000	0.0%	
				0.790	0.800	0.010	1.3%	
								0.3%
1-G	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.200	0.200	0.000	0.0%	
				0.420	0.440	0.020	4.5%	
				0.840	0.880	0.040	4.5%	
								2.3%
1-H 02-Feb-00	n/a	n/a	1	0.000	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR
1-I 21-sept-99	n/a	n/a	1	0.000	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR
1-J	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.250	0.240	-0.010	-4.2%	
				0.750	0.740	-0.010	-1.4%	
				1.000	1.040	0.040	3.8%	
								-0.4%
1-K	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.360	0.360	0.000	0.0%	
				0.540	0.540	0.000	0.0%	
				0.940	0.930	-0.010	-1.1%	
								-0.3%
1-L	OK	OK	1	0.000	0.000	0.000	0.0%	
				0.200	0.200	0.000	0.0%	
				0.600	0.620	0.020	3.2%	
				0.980	1.020	0.040	3.9%	
								1.8%
2-A 02-Feb-00	n/a	n/a	2	0.000	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR
2-B 02-Feb-00	OK	OK	2	0.000	0.000	0.000	0.0%	
				0.250	0.240	-0.010	-4.2%	
				0.950	0.940	-0.010	-1.1%	
				1.900	1.900	0.000	0.0%	
								-1.3%
2-C 02-Feb-00	OK	OK	2	0.000	0.000	0.000	0.0%	
				0.550	0.600	-0.050	-8.3%	
				1.500	1.500	0.000	0.0%	
				2.000	2.400	0.400	16.7%	
								2.1%
2-D 10-Feb-99	OK	OK	2	0.000	0.000	0.000	0.0%	
				0.450	0.470	0.020	4.3%	
				1.350	1.000	-0.350	-25.9%	
				1.700	1.660	-0.040	-2.4%	
								-0.8%
2-E 02-Feb-00	n/a	n/a	2	0.000	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR
3-A	OK	OK	3	0.000	0.000	0.000	0.0%	
				1.000	0.980	-0.020	-2.0%	
				1.500	1.520	0.020	1.3%	
				2.900	2.920	0.020	0.7%	
								-0.0%
3-H 10-Feb-99	n/a	n/a	3	0.000	0.000	0.000	0.0%	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
				0.000	0.000	0.000	ERR	
								ERR



13585 NE Whitaker Way • Portland, OR 97230
Phone (503) 255-5050 • Fax (503) 255-0505
www.horizonengineering.com

February 8, 2001
Horizon Engineering shop
Barometer Calibration

The Barometric pressure reported at Portland Troutdale airport was 30.06" Hg as corrected to the altitude of the Horizon Engineering shop. The barometer reading in TVIII was 30.25"Hg. The barometer reading in TVII was 29.95" Hg. The barometer reading in TVI was 30.15" Hg. The FSL independent barometer was 30.29" Hg. All pressures are absolute, read at the Horizon Engineering shop.

DLR


NOx Converter Efficiency Data

NOx Converter Efficiency Test
Thermo Environmental Model 42H #2

02/12/2001

Readings	Time
30.2	12:16
30.19	12:17
30.23	12:18
30.25	12:19
30.30	12:20
30.30	12:21
30.32	12:22
30.30	12:23
30.35	12:24
30.33	12:25
30.41	12:26
30.40	12:27
30.40	12:28
30.41	12:29
30.39	12:30
30.40	12:31
30.41	12:32
30.41	12:33
30.41	12:34
30.41	12:35
30.41	12:36
30.41	12:37
30.41	12:38
30.40	12:39
30.41	12:40
30.41	12:41
30.39	12:42
30.41	12:43
30.40	12:44
30.38	12:45
30.32	12:46
30.31	12:47
30.3	12:48
30.3	12:49
30.3	12:50
30.25	12:51
30.3	12:52
30.24	12:53
30.2	12:54

	Pretest	Post test
Zero	0.00	0.00
Span	100.00	100.00
Mid	n/a	n/a
Time	12:16	12:51



Percent Loss= 0.723

PASS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

E 3/2
P 303
9/25/00

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

HENG01
TO: DAVID ROSSMAN
HORIZON ENG'G/INFRARED NW
13585 NE WHITAKER WAY
PORTLAND OR 97230

DATE: September 21 2000

CUSTOMER ORDER NUMBER: 003070

COMPONENT	CONCENTRATION(v/v) ± EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO: CC53845						
Carbon Dioxide	✓ 21.83 ± 0.05 %	GMS	VARIAN MODEL 1860 TCD	09/21/02	09/21/00	
			S/N NONE		21.83 %	
Carbon Dioxide		CYLINDER #: CC122859	THERMAL CONDUCTIVITY	MEAN:	21.83 %	
			GAS CHROMATOGRAPHY		21.84 %	
			LAST CAL DATE: 09/21/00			
					21.83 %	
Nitric Oxide NOx	✓ 183.2 ± 0.9 ppm 183.2 ppm	GMS	BOVAR MODEL 922M	09/20/02	09/13/00	
			S/N VD92284844		183.3 ppm	183.1 ppm
Nitric Oxide NOx		CYLINDER #: CC72078	CONTINUOUS	MEAN:	182.9 ppm	183.5 ppm
			UV PHOTOMETRY		183.0 ppm	183.3 ppm
			LAST CAL DATE: 09/13/00			
					183.1 ppm	183.3 ppm
Carbon Monoxide	✓ 880 ± 9 ppm	GMS	CARLE INST MODEL 8000	09/14/02	09/05/00	
			S/N 8249		880 ppm	880 ppm
Carbon Monoxide		CYLINDER #: CC108729	METHANATION/FID	MEAN:	880 ppm	879 ppm
			GAS CHROMATOGRAPHY		881 ppm	881 ppm
			LAST CAL DATE: 08/15/00			
					880 ppm	880 ppm
Propane	86.7 ± 1.1 ppm	GMS	VARIAN MODEL 1860 FID	09/07/02	09/07/00	
			S/N NONE		86.9 ppm	
O2-free Nitrogen	Balance	CYLINDER #: CC51261	FLAME IONIZATION	MEAN:	86.7 ppm	
			GAS CHROMATOGRAPHY		86.6 ppm	
			LAST CAL DATE: 09/05/00			
					86.7 ppm	
CYLINDER PRESSURE: 2000 psig		@ 104.1 ppm				

ppm = μmole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R93/224, dated September 1993.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST:
M.S. CALHOUN

APPROVED:
D.T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

HENG01

TO:

David Rossman
Horizon Eng'g/Infrared NW
13585 NE Whitaker Way
Portland, OR 97230-

DATE : 06/07/01

CUSTOMER ORDER NUMBER: 003241

PAGE 1

COMPONENT	CONCENTRATION (v/v) +/-EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CA04567					
Carbon dioxide ✓	12.41 ±.02 %	GMIS	Varian Model 1868	05/23/03	05/23/01
		Cylinder #	S/N None		12.39 %
		CC122859	Thermal Conductivity		12.48 %
		0 17.93 %	Gas Chromatography		12.44 %
			Last Cal Date: 05/09/01	Mean: 12.41 %	
Nitric oxide ✓ NDx	89.8 ±1.2 ppm 89.8 ppm	GMIS	Bovar West Res Model 922	05/23/03	05/15/01 05/23/01
		Cylinder #	S/N V092284841		89.6 ppm 89.6 ppm
		CA03023	Continuous		89.7 ppm 89.5 ppm
		0 181.6 ppm	UV Photometry		89.7 ppm 98.3 ppm
			Last Cal Date: 05/02/01	Mean: 89.7 ppm	89.8 ppm
Carbon monoxide ✓	499 ±5 ppm	GMIS	Carle Insts Model 8088	06/07/03	05/15/01 06/07/01
		Cylinder #	S/N 8249		499 ppm 499 ppm
		CC278	Methanation/FID		498 ppm 499 ppm
		0 539 ppm	Gas Chromatography		499 ppm 508 ppm
			Last Cal Date: 06/06/01	Mean: 499 ppm	499 ppm
Propane	50.2 ±.4 ppm	GMIS	Varian Model 1868	05/17/03	05/17/01
		Cylinder #	S/N None		50.1 ppm
Nitrogen, O2-Free Balance	Cylinder Pressure: 2000 psig	CC121986	Flame Ionization		50.2 ppm
		0 50.6 ppm	Gas Chromatography		50.2 ppm
			Last Cal Date: 05/17/01	Mean: 50.2 ppm	

ppm = umole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

Analyst:

M.S. Calhoun

Approved:

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

HENG01

TO:

David Rossman
Horizon Eng'g/Infrared NW
13585 Whitaker Way
Portland, OR 97230-

DATE : 06/07/01

Handwritten circled 'a' with a line pointing to the right.

CUSTOMER ORDER NUMBER: 003255

PAGE 1

COMPONENT	CONCENTRATION (v/v) +/-EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CA04488					
Oxygen	✓ 11.60 ±.13 %	GMIS Cylinder #	Varian Model 1060 S/N None Thermal Conductivity	05/30/04	05/30/01 11.62 % 11.58 %
Nitrogen	Balance	CC50175	Gas Chromatography		11.59 %
Cylinder Pressure:	2000 psig	@ 25.69 %	Last Cal Date: 05/24/01		Mean: 11.60 %

ppm = umole/mole % = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

Analyst:

Handwritten signature of M.S. Calhoun

M.S. Calhoun

Approved:

Handwritten signature of J.T. Marrin

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

01-24-00

#17

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

HENG01

TO:

DAVID ROSSMAN
HORIZON ENGINEERING
13585 NE WHITAKER WAY
PORTLAND, OR 97230-

DATE : 01/20/00

CUSTOMER ORDER NUMBER: 2809

PAGE 1

COMPONENT	CONCENTRATION (v/v) +/-EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO.: CA03076					
Nitric oxide	✓ 25.25 ±.25 ppm	GMS	Monitor Labs Model 8440 S/N 136	01/11/02	<u>01/04/00</u> <u>01/11/00</u> 25.30 ppm 25.33 ppm
NOx	25.25 ppm	Cylinder #	Continuous		25.16 ppm 25.23 ppm
Nitrogen, O2-Free Balance		CC114778	Chemiluminescence		<u>25.13 ppm</u> <u>25.30 ppm</u>
Cylinder Pressure: 2000 psig		@ 19.88 ppm	Last Cal Date: 01/18/00	Mean:	25.28 ppm 25.29 ppm

ppm = umole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

Analyst:

Steve Kozly

S.B. Kozy

Approved:

J.T. Marrin

J.T. Marrin



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

P22

HENG01

TO: David Rossman
Horizon Engineering / Infrared NW
13585 NE Whitaker Way
Portland OR 97230

DATE: October 3 2001

CUSTOMER ORDER NUMBER: 003351

COMPONENT	CONCENTRATION(v/v) ± EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO: CA05171					
Propane	✓ 89.0 ± 0.9 ppm	GMIS	VARIAN MODEL 1860 FID S/N NONE	10/01/04	10/01/01 89.1 ppm
Zero Air	Balance	CC51261	FLAME IONIZATION GAS CHROMATOGRAPHY		89.0 ppm 89.0 ppm
CYLINDER PRESSURE: 2000 psig		@ 104 ppm	LAST CAL DATE: 09/11/01	MEAN:	89.0 ppm

ppm = $\mu\text{mole/mole}$

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST:

M. S. CALHOUN

APPROVED:

J. T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

P19

HENG01

TO: David Rossman
Horizon Engineering / Infrared NW
13585 NE Whitaker Way
Portland OR 97230

DATE: October 3 2001

CUSTOMER ORDER NUMBER: 003351

COMPONENT	CONCENTRATION(v/v) ± EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO: CA05193					
Propane	✓ 51.6 ± 0.5 ppm	GMIS	VARIAN MODEL 1860 FID S/N NONE	10/01/04	10/01/01 51.4 ppm
Ultrapure Air	Balance	CC121986	FLAME IONIZATION GAS CHROMATOGRAPHY		51.6 ppm 51.7 ppm
CYLINDER PRESSURE: 2000 psig		@ 50.6 ppm	LAST CAL DATE: 09/11/01	MEAN:	51.6 ppm

ppm = $\mu\text{mole/mole}$

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST:

M. S. CALHOUN

APPROVED:

J. T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

For Technical Information Call
1-800-752-1597

R12



Air Products and Chemicals, Inc. • 12722 S. Wentworth Avenue, Chicago, IL 60628

ISO CERTIFICATION: 9002

CERTIFICATE OF ANALYSIS: EPA PROTOCOL GAS STANDARD

PERFORMED ACCORDING TO EPA TRACEABILITY PROTOCOL FOR ASSAY AND CERTIFICATION OF GASEOUS CALIBRATION STANDARDS (PROCEDURE #G1)

Customer:

AIR PRODUCTS & CHEMICALS
1680 OAK TREE RD.
EDISON NJ 08820-

Order No: SRP-410911-04
Batch No: 861-67867
PO:
Release:

Cylinder No: SG9152832BAL
Bar Code No: DGY894
Cylinder Pressure*: 2000 psig
Certification Date: 03/27/2000
Expiration Date: 03/27/2003

CERTIFIED CONCENTRATION		REFERENCE STANDARDS			ANALYTICAL INSTRUMENTATION			
Component	Certified Concentration	Cylinder Number	Standard Type	Standard Concentration	Instrument Make/Model	Serial Number	Last Calibration	Measurement Principal
CARBON MONOXIDE NITROGEN	85.9 ± 0.57 PPM Balance Gas	SG9159515BAL	NIRM	99.90 PPM	HORIBA VIA-510	405079	03/15/00	NOM DISPERSIVE INFRARED

* STANDARD SHOULD NOT BE USED BELOW 150 PSIG

Analyst:

Holly Hattendorf
HOLLY HATTENDORF

(16921)

Approved By:

Richard Fry
RICHARD FRY



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

P18

HENG01
TO: David Rossman
Horizon Engineering / Infrared NW
13585 NE Whitaker Way
Portland OR 97230

DATE: October 3 2001

CUSTOMER ORDER NUMBER: 003351

COMPONENT	CONCENTRATION(v/v) ± EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA
CYLINDER NO: CA05167					
Propane	✓ 28.69 ± 0.28 ppm	GMIS	VARIAN MODEL 1860 FID S/N NONE	09/21/04	<u>09/21/01</u> 28.62 ppm
Ultrapure Air	Balance	CC121986	FLAME IONIZATION GAS CHROMATOGRAPHY		28.77 ppm 28.68 ppm
CYLINDER PRESSURE: 2000 psig		@ 50.6 ppm	LAST CAL DATE: 09/17/01	MEAN:	28.69 ppm

ppm = μ mole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST: M.S. Calhoun
M. S. CALHOUN

APPROVED: J.T. Marrin
J. T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.
STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

S 3
P.J. 3088
9/25/00

HENG01
TO: DAVID ROSSMAN
HORIZON ENG'G/INFRARED NW
13585 NE WHITAKER WAY
PORTLAND OR 97230

DATE: September 21 2000

CUSTOMER ORDER NUMBER: 003088

COMPONENT	CONCENTRATION(v/v) ± EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	
CYLINDER NO: CC49351						
Sulfur Dioxide ✓	26.47 ± 0.27 ppm	GMISR	BOVAR MODEL 922M S/N VD92284844	03/01/01	09/12/00 26.38 ppm	09/21/00 26.37 ppm
Nitrogen	Balance	CC68759	CYLINDER #: CONTINUOUS UV PHOTOMETRY		26.48 ppm	26.47 ppm
CYLINDER PRESSURE: 2000 psig		@ 25.64 ppm	LAST CAL DATE: 09/08/00	MEAN:	26.56 ppm	26.55 ppm
					26.47 ppm	26.46 ppm

ppm = $\mu\text{mole/mole}$

t = mole-t

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R93/224, dated September 1993.

This cylinder should not be used if the pressure is less than 150 psig.

ANALYST: Mark Monson

M. J. MONSON

APPROVED: J. T. Marrin

J. T. MARRIN

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS



SCOTT-MARRIN, INC.

6531 BOX SPRINGS BLVD. • RIVERSIDE, CA 92507
TELEPHONE (909) 653-6780 • FAX (909) 653-2430

REPORT OF ANALYSIS EPA PROTOCOL GAS MIXTURES

HENGZ1

TO:

David Rossman
Horizon Eng'g / Infrared NW
13585 NE Whitaker Way
Portland, OR 97230-

DATE : 09/13/01

CUSTOMER ORDER NUMBER: 003329

PAGE 1

COMPONENT	CONCENTRATION (v/v) +/-EPA UNCERTAINTY	REFERENCE STANDARD	ANALYZER MAKE, MODEL, S/N, DETECTION	EXPIRATION DATE	REPLICATE ANALYSIS DATA	

CYLINDER NO.:	CC25763	S4				
Sulfur dioxide	15.27 ±.16 ppm	GMIS	Bovar West Res Model 922 S/N 922M8379-1	03/12/02	09/04/01	09/12/01
Nitrogen	Balance	Cylinder #	Continuous		15.23 ppm	15.14 ppm
Cylinder Pressure:	2002 psig	CC28050	UV Photometry		15.34 ppm	15.24 ppm
		@ 26.72 ppm	Last Cal Date: 08/28/01		15.38 ppm	15.26 ppm
					Mean: 15.32 ppm	15.21 ppm

CYLINDER NO.:	CC53849	S9				
Sulfur dioxide	26.96 ±.29 ppm	GMIS	Bovar West Res Model 922 S/N 922M8379-1	03/12/02	09/04/01	09/12/01
Nitrogen	Balance	Cylinder #	Continuous		26.78 ppm	26.90 ppm
Cylinder Pressure:	2000 psig	CC28050	UV Photometry		27.01 ppm	26.95 ppm
		@ 26.72 ppm	Last Cal Date: 08/28/01		27.07 ppm	27.05 ppm
					Mean: 26.95 ppm	26.97 ppm

ppm = umole/mole

% = mole-%

The above analyses were performed in accordance with Procedure G1 of the EPA Traceability Protocol, Report Number EPA-600/R97/121, dated September 1997.

This cylinder should not be used if the pressure is less than 150 psig.

Analyst:

Mark Monson

M.J. Monson

Approved:

J.T. Marrin

J.T. Marrin

The only liability of this company for gas which fails to comply with this analysis shall be replacement or reanalysis thereof by the company without extra cost.

STANDARD CALIBRATION GASES IN ALUMINUM CYLINDERS

125



Environmental Services Laboratory, Inc.

17400 SW Upper Boones Ferry Road, Suite 270 • Portland, OR 97224 • (503) 670-8520

December 07, 2001

Nichole Karl
Horizon Engineering
13585 NE Whitaker Way
Portland, OR 97230
TEL: (503) 255-5050
FAX (503) 255-0505

RE: 1685 Audit / OSM Audit Samples

Order No.: 0111194

Dear Nichole Karl,

Environmental Services Laboratory received 5 samples on 11/26/01 for the analyses presented in the following report.

The Samples were analyzed for the following tests:

ICP Metals (EPA 6010B)


There were no analytical problems encountered, and all data met laboratory QC criteria, unless noted in a Case Narrative. Results apply only to the samples analyzed. Reproduction of this report is permitted only in its entirety, without the written approval of the Laboratory.

The following checked data sections are included in this report, and numbered to indicate total pages within each report section.

Base Sample Report Method Blank Report Sample Duplicate Report
 Matrix Spike/Matrix Spike Duplicate Report Laboratory Control Spike/Spike Duplicate Report Continuing Calibration Verification Report Initial Calibration Verification Report

If you have any questions regarding these test results, please feel free to call.

Sincerely,


Leslie Rush
Project Manager


Keith Hunter
Technical Review

**Method 12 Compliance Audit Material
(Lead Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-0482-01 / AMH2-123 Date Issued: 11/09/01

Concentration Level: High

Auditee:

Company: 0

Address: 0

Attention of: 0 Phone: -

Requestor:

Agency: OR DEQ / NW Region

Address: 2020 SW 4th Ave, Suite 400, Portland, OR 97230

Attention of: Jack Herbert Phone: (503) 229-5579

Project Name: Oregon Steel Mills

Audit Results (Results in µg/mL)

<u>Compound</u>	<u>Result</u>
Lead	<u>49.7</u>

**Method 12 Compliance Audit Material
(Lead Spiked Aqueous Solution)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-0482-02 / AMM2-122 Date Issued: 11/09/01

Concentration Level: Medium

Auditee:

Company: 0

Address: 0

Attention of: 0 Phone: 0

Requestor:

Agency: OR DEQ / NW Region

Address: 2020 SW 4th Ave, Suite 400, Portland, OR 97230

Attention of: Jack Herbert Phone: (503) 229-5579

Project Name: Oregon Steel Mills

Audit Results (Results in $\mu\text{g/mL}$)

<u>Compound</u>	<u>Result</u>
Lead	<u>5.93</u>

**Method 12 Compliance Audit Material
(Lead Spiked Filter)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-0480-01 / FMH1-109 Date Issued: 11/09/01

Concentration Level: High

Auditee:

Company: 0

Address: 0

Attention of: 0 Phone: 0

Requestor:

Agency: OR DEQ / NW Region

Address: 2020 SW 4th Ave, Suite 400, Portland, OR 97230

Attention of: Jack Herbert Phone: (503) 229-5579

Project Name: Oregon Steel Mills

Audit Results (Results in µg)

<u>Compound</u>	<u>Result</u>
Lead	<u>888</u>

**Method 12 Compliance Audit Material
(Lead Spiked Filter)**

REPORTING FORM: To be completed by laboratory

Request Number/Sample Number: M29-0480-02 / Fil-1590 Date Issued: 11/09/01

Concentration Level: Medium

Auditee:

Company: 0

Address: 0

Attention of: 0 Phone: 0

Requestor:

Agency: OR DEQ / NW Region

Address: 2020 SW 4th Ave, Suite 400, Portland, OR 97230

Attention of: Jack Herbert Phone: (503) 229-5579

Project Name: Oregon Steel Mills

Audit Results (Results in µg)

<u>Compound</u>	<u>Result</u>
Lead	<u>104</u>

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111194
Project: 1685 Audit / OSM Audit Samples
Lab ID: 0111194-01A

Client Sample ID: AMH2-123
Tag Number:
Collection Date: 11/21/01
Matrix: AQUEOUS

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	49.7	0.00500		ug/ml	1	12/4/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

131

1 of 5

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111194
Project: 1685 Audit / OSM Audit Samples
Lab ID: 0111194-02A

Client Sample ID: AMM2-122
Tag Number:
Collection Date: 11/21/01
Matrix: AQUEOUS

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	5.93	0.00500		ug/ml	1	12/4/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

132

2 of 5

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111194
Project: 1685 Audit / OSM Audit Samples
Lab ID: 0111194-03A

Client Sample ID: FMH1-109
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	888	0.500		ug	1	12/3/01

Qualifiers:
ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

133

3 of 5

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
Lab Order: 0111194
Project: 1685 Audit / OSM Audit Samples
Lab ID: 0111194-04A

Client Sample ID: FIL-1590
Tag Number:
Collection Date: 11/21/01
Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	104	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
J - Analyte detected below quantitation limits
B - Analyte detected in the associated Method Blank
* - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
R - RPD outside accepted recovery limits
E - Value above quantitation range

134

4 of 5

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
 Lab Order: 0111194
 Project: 1685 Audit / OSM Audit Samples
 Lab ID: 0111194-05A

Client Sample ID: BLANK
 Tag Number:
 Collection Date: 11/21/01
 Matrix: FILTER

Analyses	Result	Limit	Qual	Units	DF	Date Analyzed
ICP METALS		EPA 6010B				Analyst: lmr
Lead	0.540	0.500		ug	1	12/3/01

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 B - Analyte detected in the associated Method Blank
 * - Value exceeds Maximum Contaminant Level

S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 E - Value above quantitation range

135

5 of 5

Environmental Services Laboratory

CLIENT: Horizon Engineering
 Work Order: 0111194
 Project: 1685 Audit / OSM Audit Samples

Date: 07-Dec-01

QC SUMMARY REPORT

Sample ID:	Batch ID:	Test Code:	EPA 6010B	Units:	mg/Kg	Analysis Date:	12/3/01	Prep Date:	11/30/01	Method Blank			
Client ID:	0111194	Run ID:	ICP_011203A	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Sample ID: MB-3578	Batch ID: 3578	Run ID: 0111194	ICP_011203A	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Client ID:	0111194	Run ID: 0111194	ICP_011204B	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Analyte	Result	ND											
Lead	Result	ND											

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Environmental Services Laboratory

CLIENT: Horizon Engineering
 Work Order: 0111194
 Project: 1685 Audit / OSM Audit Samples

Date: 07-Dec-01

QC SUMMARY REPORT

Laboratory Control Spike - generic

Sample ID	Batch ID	Test Code	EPA Code	Units	mg/Kg	Analysis Date	SeqNo	Prep Date				
Client ID	Run ID	Run ID	ICP Code	SPK value	SPK Ref Val	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual	
LCS-3578	3578	0111194	EPA 6010B	mg/Kg	0	12/3/01	98958	11/30/01				
			ICP_011203A									
		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
		49.4	1	50	0	98.8%	80	120	0			
Sample ID: LCS-3579	Batch ID: 3579	0111194	EPA 6010B	mg/L	0	12/4/01	98952	11/30/01				
Client ID:	Run ID:	Run ID:	ICP Code	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
			ICP_011204B									
		Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
		.494	0.005	0.5	0	98.8%	80	120	0			

Qualifiers: ND - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 B - Analyte detected in the associated Method Blank

Environmental Services Laboratory

Date: 07-Dec-01

CLIENT: Horizon Engineering
 Work Order: 0111194
 Project: 1685 Audit / OSM Audit Samples

QC SUMMARY REPORT
 Minerals ICV for ICP

Sample ID: ICVHI	Batch ID: 3578	Test Code: EPA 6010B	Units: mg/L	Analysis Date: 12/3/01	Prep Date: 11/30/01						
Client ID:	0111194	Run ID: ICP_011203A		SeqNo: 98966							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	9.98	0.005	10	0	99.8%	90	110	0			
Sample ID: ICVLOW	Batch ID: 3578	Test Code: EPA 6010B	Units: mg/L <td>Analysis Date: 12/3/01 <td>Prep Date: 11/30/01</td> </td>	Analysis Date: 12/3/01 <td>Prep Date: 11/30/01</td>	Prep Date: 11/30/01						
Client ID:	0111194	Run ID: ICP_011203A		SeqNo: 98965							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	.513	0.005	0.5	0	102.6%	90	110	0			
Sample ID: ICVHI	Batch ID: 3579	Test Code: EPA 6010B	Units: mg/L <td>Analysis Date: 12/4/01 <td>Prep Date: 11/30/01</td> </td>	Analysis Date: 12/4/01 <td>Prep Date: 11/30/01</td>	Prep Date: 11/30/01						
Client ID:	0111194	Run ID: ICP_011204B		SeqNo: 98950							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	9.79	0.005	10	0	97.9%	90	110	0			
Sample ID: ICVLOW	Batch ID: 3579	Test Code: EPA 6010B	Units: mg/L <td>Analysis Date: 12/4/01 <td>Prep Date: 11/30/01</td> </td>	Analysis Date: 12/4/01 <td>Prep Date: 11/30/01</td>	Prep Date: 11/30/01						
Client ID:	0111194	Run ID: ICP_011204B		SeqNo: 98949							
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	.504	0.005	0.5	0	100.8%	90	110	0			

Qualifiers: NID - Not Detected at the Reporting Limit
 J - Analyte detected below quantitation limits
 S - Spike Recovery outside accepted recovery limits
 R - RPD outside accepted recovery limits
 U - Analyte detected in the associated Method Blank

Dave Rossman

From: HERBERT.Jack@deq.state.or.us
Sent: Monday, December 17, 2001 6:47 PM
To: info@horizonengineering.com; drossman@horizonengineering.com
Subject: Attn Michelle: Thank you for the info for the Or Steel audit samples. Audit passed.

The lab passed the audit according to the EPA's database response.

Jack Herbert
Source Test Coordinator
Oregon Department of Environmental Quality, Northwest Region
(503)229-5579
(503)229-5265 fax
herbert.jack@deq.state.or.us

QA/QC Documentation

Introduction The QA procedures outlined in the U. S. Environmental Protection Agency (EPA) test methods are followed, including procedures, equipment specifications, calibrations, sample extraction and handling, calculations, and performance tolerances. Many of the checks performed have been cited in the Sampling section of the report text. The results of those checks are on the applicable field data sheets in the Appendix.

Continuous Analyzer Methods Field crews operate the continuous analyzers according to the test method requirements, and Horizon's additional specifications. On site quality control procedures include:

- calibrations with EPA Protocol 1 gases or NIST traceable gases
- pre-test zero and span checks and linearity test
- bias checks (introducing calibration gas as near to the probe tip as possible)
- calibration error (linearity) checks if any analyzer adjustments are made
- leak checks on the gas sampling system
- correction of problems that show up as the results of checks
- strip chart recordings for backup to the electronic data acquisition system

Manual Equipment QC Procedures On site quality control procedures include pre- and post-test leak checks on trains and pitot systems. If pre-test checks indicate problems, the system is fixed and rechecked before starting testing. If post-test leak checks are not acceptable, the test run is voided and the run is repeated. Thermocouples and readouts are verified in the field to read ambient prior to the start of any heating or cooling devices. Nozzles are checked for nicks or dents and are measured on three diameters twice each year.

Sample Handling Samples taken during testing are handled to prevent contamination from other runs and ambient conditions. Sample containers are glass, Teflon™, or polystyrene (filter petri dishes) and are pre-cleaned by the laboratory and in the Horizon Engineering shop. Sample levels are marked on containers and are verified by the laboratory. All particulate sample containers are kept upright and are delivered to the laboratory by Horizon personnel.

Data Processing Personnel performing data processing double-check that data entry and calculations are correct. Results include corrections for field blanks and analyzer drift. Any abnormal values are verified with testing personnel and the laboratory, if necessary.

After results are obtained, the data processing supervisor validates the data with the following actions:

- verify data entry
- check for variability within replicate runs
- account for variability that is not within performance goals (check the method, testing, and operation of the plant)
- verify field quality checks

Equipment Calibrations Periodic calibrations are performed on each piece of measurement equipment according to manufacturers' specifications and applicable test method requirements. The Oregon Department of Environmental Quality (ODEQ) Source Testing Calibration Requirements sheet is used as a guideline. Calibrations are performed using primary standard references and calibration curves where applicable.

Thermocouples Thermocouples are calibration checked against an NIST traceable thermocouple and indicator system every six months at three points. Thermocouple indicators and temperature controllers are checked using a NIST traceable signal generator. Readouts are checked over their usable range and are adjusted if necessary (which is very unusual).

Pitots Every six months, S-type pitots are checked for misalignment, angles, lengths, and proximity to thermocouples. They are then calibrated in a wind tunnel at four points against a standard pitot using inclined manometers. They are examined for dents or distortion before each test. Pitots are protected with covers during storage and handling until they are ready to be inserted in the sample ports.

Dry Gas Meters Dry gas meters used in the manual sampling trains are calibrated at five rates using a standard dry gas meter that is never taken into the field. The standard meter is calibration verified by the Northwest Natural Gas meter shop once every year. Dry gas meters are post-test calibrated with documentation provided in test reports.

High Volume Sampler Orifice The orifice for the High Volume sampler is calibrated annually against a positive displacement (Roots type) flow meter, two or more trials at six flow rates. The Roots meter came with a manufacturer's calibration curve and has been calibration checked by the Northwest Natural Gas meter shop.

Correspondence
Source Test Plan and Correspondence



TO: DEBBIE SILVA
DEPT: _____
CO: OSM
FAX: 503-240-5775

HP FAX
FROM: Nichole Karl
DATE: 10/16/01
19

13585 NE Whitaker Way • Portland, OR 97230
Phone (503) 255-5050 • Fax (503) 255-0505
www.horizonengineering.com

October 15, 2001

Mr. Jack Herbert
Oregon Department of Environmental Quality
2020 SW 4th, Suite #400
Portland, OR 97201-4987



Re: Source Testing: Oregon Steel Mills
14400 N Rivergate Boulevard
Portland, Oregon 97203

This correspondence is notice that Horizon Engineering is to do source testing for the above-referenced facility, scheduled for November 5 through 8, 2001. This will serve as the Source Test Plan unless changes are requested prior to the start of testing.

1. **Source(s) to be Tested:** ICA Baghouse (EAF) System and Reheat Furnace.
2. **Purpose of the Testing:** Compliance with Title V Permit No. 26-1865 conditions 37,38, and 39.
3. **Source Description:** 16-compartment baghouse controlling particulate emissions from the EAF.
4. **Pollutants to be Tested:** Particulate, CO, NO_x, SO₂, VOC, Lead and Opacity.
5. **Test Methods to be Used:** Testing will be conducted in accordance with EPA Methods in Title 40 Code of Federal Regulations Part 60 (40 CFR 60), Appendix A, July 1, 1999; and Oregon Department of Environmental Quality (ODEQ) methods in Source Sampling Manual Volume 1, January 1992.

Source: ICA Baghouse (EAF system)

Inlet tests:

Flow Rate:	EPA Methods 1 and 2 (at BH inlet, twice on test day)
CO ₂ and O ₂ :	EPA Method 3A (NDIR and paramagnetic analyzers)
Moisture:	ODEQ Method 4 (wet bulb and dry bulb temperatures, inlet)
SO ₂ :	EPA Method 6C (non-dispersive ultraviolet analyzer)
NO _x :	EPA Method 7E (chemiluminescent analyzer)
CO:	EPA Method 10 (gas filter correlation analyzer)
VOC:	EPA Method 25A, (heated sample line and two analyzers, one with simultaneous VOC "cutter" for back-out of CH ₄ content)

144

Outlet tests:

Flow Rate: EPA Methods 1 and 2 (at each compartment, as done in past)
 Particulate: ODEQ Method 8 (High Volume sampler)
 Lead: Analysis of M-8 catch, with audit sample analysis (3 expected)
 Opacity: EPA Method 9 (six minutes per test)

Source: Reheat Furnace

Flow Rate: EPA Methods 1 and 2 (traversing)
 Flow Rate: EPA Method 19 (gas fuel meter and O₂ in exhaust)
 CO₂ and O₂: EPA Method 3A (NDIR and paramagnetic analyzers)
 Moisture: EPA Method 4 (impinger train, traversing)
 NO_x: EPA Method 7E (chemiluminescent analyzer)
 CO: EPA Method 10 (gas filter correlation analyzer)
 VOC: EPA Method 25A, (heated sample line and two analyzers, one with simultaneous VOC "cutter" for back-out of CH₄ content)

*expect very low
(~1 ppm)*

6. **Continuous Analyzer Data Recording:** Data acquisition system (DAS) with strip chart records as backup. Either 10-second data points or one-minute averages of one-second readings are logged. Run averages, the graphic outputs from the DAS, annotated strip charts, and a few minutes of manually recorded data will be included in the test reports.
7. **Continuous Analyzer Gas Sampling:** Fixed point in the baghouse inlet. Reheat gas sampling probes will be traversed with the moisture probe.
8. **Quality Assurance /Quality Control (QA/QC):** Documentation of the procedures and results will be presented in the source test report for review. This documentation will include at least the following:

Continuous Analyzer QC Procedures: Field crews will operate the analyzers according to the manufacturer's specification, the test method's requirements, and Horizon's additional specifications. On-site quality control procedures include:

- daily calibration (zero and span) and calibration error (linearity) checks
- pre- and post-test zero bias and span bias checks
- checks performed with EPA Protocol 1 or NIST traceable gases
- data acquisition systems record 10-second data points or one-minute averages of one second readings
- strip chart recordings
- manual readings for a few minutes

Manual Equipment QC Procedures: Operators will perform pre- and post-test leak checks on the sampling system and pitot lines. Thermocouple systems are checked for ambient temperature before heaters are started. Nozzles and pitots are inspected for nicks or dents before each test. Pre- and post-test calibrations on the meter boxes will be included with the report, along with semi-annual calibrations on the pitots, thermocouples, and nozzles. Blank reagents (water, acetone and filter) are submitted to the laboratory with

18. Other Considerations, including sampling site configurations, equipment limitations, special methods, etc.:

Particulate: Each Oregon Method 8 test shall encompass two complete heat cycles with samples collected for 5 minutes from as many as possible of the 16 compartments. The next test shall begin in the next compartment after the final compartment sampled in the previous test. Particulate is to be sampled in the gas stream above the bags in the slot shaped area where gas flows up and toward the center of the baghouse. This allows the sampler nozzle to be inserted through ports in the ceiling of the breezeway at the top of the baghouse. As in the past, sampling will be isokinetic at a single point at the outlet of each compartment.

Flow Rate Measurements: Velocities will be measured at five points through each port, giving 5 velocities per compartment, 80 points for the baghouse. Velocity pressure determinations will be by use of an S-type pitot and a micro-manometer. Past testing has shown that traversing this single port adequately characterizes the outlet flow rate.

Gaseous Pollutant Measurements: Gas analyzer readings at the baghouse inlet will be continuous through all of the M-8 tests with calibrations only at the beginning and end of the test day. Instrument drift may exceed normal run allowances for the entire period. Instrument results will be corrected for drift.

Timing: The testers will synchronize their watches to record times in sync with the OSM heat log in the arc furnace control pulpit.

19. Administrative: Unless notified prior to the start of testing, this test plan is considered approved for compliance testing of this source. A letter acknowledging receipt of this plan and agreement on the content (or changes as necessary) would be appreciated.

The Department will be notified of any changes in source test plans prior to testing. It is recognized that significant changes not acknowledged, which could affect accuracy and reliability of the results, could result in test report rejection.

Source test reports will be prepared by Horizon Engineering and will include all results and example calculations, field sampling and data reduction procedures, laboratory analysis reports, and QA/QC documentation. Source test reports will be submitted to you within 45 days of the completion of the field work, unless another deadline has been stipulated. Oregon Steel Mills will send two (2) copies of the completed Source Test Report to you at the address above.

Any questions or comments relating to this test plan should be directed to me.

Sincerely,



David R. Rossman, P. E.

cc: Debbie Deetz Silva, Oregon Steel Mills



13585 N.E. Whitaker Way • Portland, OR 97230
Phone (503)255-5050 • Fax (503)255-0505
horizone@teleport.com

TO: DEBBIE SILVA

DEPT: _____

CO: OSM

FAX: 503-240-5775



FROM: Nichole Karl

DATE: 11/5/01

November 5, 2001

Mr. Jack Herbert
Oregon Department of Environmental Quality
Northwestern Region – Portland Office
2020 SW 4th Avenue, Suite 400
Portland, OR 97201-4987

Dear Mr. Herbert,

This correspondence is to notify you that the Source Testing for the Reheat Furnace at Oregon Steel Mills has been postponed due to technical difficulties. Testing on the Baghouse will be as scheduled with set-up on Tuesday, November 6 and testing on Wednesday, November 7th. Testing on the Reheat Furnace scheduled for November 8, will now take place on a date yet to be determined. ODEQ will be notified once the testing has been rescheduled. If you have any questions or concerns about these arrangements please feel free to call me. Thank you for your time.

Sincerely,

Nichole Karl

Nichole Karl,
Project Coordinator

cc: Debbie Dietz Silva, Oregon Steel Mills



Oregon

John A. Kitzhaber, M.D., Governor

Department of Environmental Quality

Northwest Region
2020 SW Fourth Avenue
Suite 400
Portland, OR 97201-4987
(503) 229-5263 Voice
TTY (503) 229-5471

November 6, 2001

Oregon Steel Mills, Inc.
Attn: Debbie Deetz Silva
PO Box 2760
Portland, Oregon 97208

Horizon Engineering
Attn: David R Rossman and C David Bagwell
13585 NE Whitaker Way
Portland, Oregon 97230

11-09-01

Re: AQ Multnomah County
Title V Permit No 26-1865
Oregon Steel Mills
Source-test plan for electric-arc and
ladle-metallurgy furnaces' annual
baghouse test for emission-factor
verification and PM and SO₂
concentrations' compliance

Dear Ms Silva and Messrs Rossman and Bagwell:

On October 16, 2001, I received your test plan for Oregon Steel Mills' ICA baghouse's and reheat furnace's emissions. The baghouse test will measure particulate, lead, and visible emissions from the baghouse and carbon-monoxide (CO), nitrogen-oxide (NO_x), sulfur-dioxide (SO₂), and volatile-organic-compound (VOC) emissions in the baghouse inlet. You will calculate emission factors based on cold charges to the electric-arc furnace. You will test compliance of filterable-particulate and sulfur-dioxide concentrations. You plan to test on November 7, 2001.

Oregon Steel Mills' Title V Operating Permit Conditions require annual emissions tests:

37. Verify emission factors for filterable particulate matter, lead, carbon monoxide, nitrogen oxides, and volatile organic compounds.
38. Measure filterable particulate grain loading.
39. Measure sulfur-dioxide concentrations, at least during the permit's first two years.

I approve your test plan for the baghouse with these conditions:

1. Tell me the lead sample solutions' volumes for analysis. I will then order audit samples. Send only filter audit samples with field samples for particulate-analysis.
2. Use analyzer ranges and calibrations corresponding to expected measurements.

Check most measurement levels with non-zero calibration gases. December 2000 results suggest about 50, 150, and 500 ppm CO, 5 to 10 and 20 to 50 ppm NO_x, 2 to


Debbie Deetz Silva, David R Rossman, and C David Bagwell
November 6, 2001
Page 2

5 and 7 to 15 ppm SO₂, and 1 to 3, 3 to 8, and 8 to 30 ppm propane.

3. Check non-VOC analyzers for interferences. Sections 6.2 in EPA Methods 3A and 7E require doing so before first field use and whenever you change analyzers in ways that could affect interference responses. Follow Section 5.4 in Method 20. Document in all test reports.
4. Oregon Method 8 requires two blank filters.
5. The laboratory performing lead analyses should identify the digestion, analytical, and quality-control procedures that they follow and record the analytical sample volumes.
6. Have the laboratories read and perform the quality control in Section 8 in your plan.
7. In the future, send laboratory quality-assurance plans with test plans. See 40 CFR 63.7(c). List quality-control procedures and their frequency.
8. Oregon Steel Mills is to document any significant furnace production delays.
9. Oregon Steel Mills is to send me one (1) test report within seventy-five (75) days after testing.

Please call me at 503-229-5579 if you have questions or change the test schedule or plan. My fax number is 229-5265. Herbert.jack@deq.state.or.us is my email address.

Sincerely,


Jack Herbert
Source Testing Coordinator

JHH

c: Greg Grunow:NWR