

Note: This is a reference cited in *AP 42, Compilation of Air Pollutant Emission Factors, Volume I Stationary Point and Area Sources*. AP42 is located on the EPA web site at [www.epa.gov/ttn/chief/ap42/](http://www.epa.gov/ttn/chief/ap42/)

The file name refers to the reference number, the AP42 chapter and section. The file name "ref02\_c01s02.pdf" would mean the reference is from AP42 chapter 1 section 2. The reference may be from a previous version of the section and no longer cited. The primary source should always be checked.

## **Background Report Reference**

**AP-42 Section Number:** 12.20

**Background Chapter:** 4

**Reference Number:** 58

**Title:** Screening Study Chromium, Emission  
Test Report

CS Ohm Manufacturing Company

December 1985

United States  
Environmental Protection  
Agency

Office of Air Quality  
Planning and Standards  
Research Triangle Park NC 27711

EMB Report 85-CHM-10  
December 1985

*ELECTROPLATING*

Air

REF. 4-58



# Neshap Screening Study Chromium

Emission Test  
Report  
C. S. Ohm  
Manufacturing  
Company  
Sterling Heights, MI

Source category:  
Plant name:  
Process:

Electroplating  
C.S. Ohm Manufacturing  
Decorative chrome

Filename: ELEC\_R58.WQ1  
Location: Sterling Heights, MI  
Test date: June 17-21, 1985

Date: 12/15/94  
Ref. No.: 4-58  
Process rate basis: production

Source	Type of control	Pollutant	Run No.	Test Method	Samp. time, min	Isokinetic, %	Gas volume, DSCF	Volum. flow rate, DSCFM	Mass, ug	Concen., gr/DSCF	Emission rate, lb/hr	Process rate, A-hr	Emission factor		
													mg/A-hr	gr/A-hr	
Decorative chrome tank	FS	total Cr	1	Imping.	320	98.7	234.39	11,947	80.5	5.3E-06	0.00054	25,000	0.053	0.00081	
		total Cr	4		320	98.6	234.82	11,980	45.4	3.0E-06	0.00031	0.00052	22,100	0.034	0.00052
		total Cr	7		320	98.4	234.253	11,983	88.9	5.9E-06	0.00060	0.00085	26,300	0.055	0.00085
		Cr+6	4		320	98.7	234.388	11,947	15.6	1.0E-06	0.00011	0.00016	Average	0.047	0.00073
		Cr+6	5		320	98.6	234.821	11,980	13.4	8.8E-07	9.0E-05	0.00015	25,000	0.010	0.00016
		Cr+6	6		320	98.4	234.253	11,983	20.8	1.4E-06	0.00014	0.00020	22,100	0.0099	0.00015
													26,300	0.013	0.00020
	FS	filt. PM	2	5	320	97.6	230.186	11,416	8.300	0.00056	0.0544	0.0544	Average	0.011	0.00017
		filt. PM	5		320	100.6	229.972	11,065	1.300	8.7E-05	0.0083	0.0083	25,000	5.3	0.081
		filt. PM	8		320	99.2	240.408	11,719	6.700	0.00043	0.0432	0.0432	22,100	0.91	0.014
		total Cr	2		320	97.6	230.186	11,416	3.500	0.00023	0.02296	0.02296	26,300	4.0	0.061
		total Cr	5		320	100.6	229.972	11,065	10.800	0.00072	0.06874	0.06874	Average	3.4	0.052
		total Cr	8		320	99.2	240.408	11,719	16.200	0.00104	0.10446	0.10446	25,000	2.2	0.034
		Cr+6	2		320	97.6	230.186	11,416	800	5.4E-05	0.00525	0.00525	22,100	7.5	0.12
		Cr+6	5		320	100.6	229.972	11,065	2.800	0.00019	0.0178	0.0178	26,300	2.0	0.030
FS/PBS	Cr+6	8	320	99.2	240.408	11,719	4.200	0.00027	0.02708	0.02708	Average	2.5	0.038		
	filt. PM	3	5	288	94.2	275.95	12,477				26,300	1.6	0.025		
	filt. PM	6		288	94.6	276.54	12,443	4.100	0.00023	0.02440	0.02440	Average	2.6	0.040	
	filt. PM	9		288	94.5	275.27	12,404		0.0E+00			23,400			
	total Cr	3		320	94.2	275.95	12,477	18.800	0.00105	0.11244	0.11244	Average	2.6	0.040	
	total Cr	6		320	94.6	276.54	12,443	14.300	0.00080	0.08511	0.08511	23,300	12	0.18	
	total Cr	9		320	94.5	275.27	12,404	14.800	0.00083	0.08822	0.08822	20,500	10	0.15	
	Cr+6	3		320	98.7	275.95	12,477	2.100	0.00012	0.01256	0.01256	23,400	9.1	0.14	
	Cr+6	6		320	98.6	276.54	12,443	2.700	0.00015	0.01607	0.01607	Average	10	0.16	
Cr+6	9	320		98.4	275.27	12,404	3.200	0.00018	0.01907	0.01907	23,300	1.3	0.020		
										20,500	1.9	0.029			
										23,400	2.0	0.030			
										Average	1.7	0.027			

Basis for rating: For chromium, outlet factors higher than inlet factors; for outlet PM, only one run performed.

EMISSION TEST REPORT

C. S. OHM MANUFACTURING COMPANY  
STERLING HEIGHTS, MICHIGAN

ESED 85/02

EMB 85-CHM-10

by

Entropy Environmentalists, Inc.  
Post Office Box 12291  
Research Triangle Park, North Carolina 27709

Contract No. 68-02-3852  
Work Assignments No. 18, 21, and 23  
PN: 3023

EPA Task Manager  
Dan Bivins

U. S. ENVIRONMENTAL PROTECTION AGENCY  
EMISSION MEASUREMENT BRANCH  
EMISSION STANDARDS AND ENGINEERING DIVISION  
RESEARCH TRIANGLE PARK, NORTH CAROLINA 27711

January 1986

## CONTENTS

	<u>Page</u>
Figures	iv
Tables	v
1.0 INTRODUCTION	1-1
2.0 PROCESS OPERATION	2-1
2.1 Process Description	2-1
2.2 Air Pollution Control	2-3
2.3 Process Conditions During Testing	2-4
3.0 SUMMARY OF RESULTS	3-1
3.1 Particulate Matter, Hexavalent Chromium and Total Chromium	3-3
3.1.1 Scrubber Inlet (EPA Method 5)	3-3
3.1.2 Scrubber Inlet (Impinger Train)	3-7
3.1.3 Scrubber Outlet	3-8
3.2 Emissions in Units of Process Rate and Control Equipment Collection Efficiency	3-9
3.2.1 Emissions in Units of Process Rate	3-9
3.2.2 Control Equipment Collection Efficiency	3-11
3.3 Summary of Analytical Results for Hexavalent and Total Chromium	3-11
4.0 SAMPLING LOCATIONS AND TEST METHODS	4-1
4.1 Scrubber Inlet (Sampling Location A)	4-1
4.2 Scrubber Outlet (Sampling Location B)	4-5
4.3 Velocity and Gas Temperature	4-5
4.4 Molecular Weight	4-7
4.5 Particulate Matter	4-7
4.6 Impinger Collection Efficiency	4-8
4.7 Hexavalent Chromium Content	4-8
4.8 Total Chromium Content	4-9
5.0 QUALITY ASSURANCE	5-1

CONTENTS (Continued)

	<u>Page</u>
APPENDICES	
A TEST RESULTS AND EXAMPLE CALCULATIONS	A-1
Particulate, Hexavalent Chromium and Total Chromium	A-3
Example Particulate Test Calculations	A-15
Total Chromium Analysis Calculation	A-28
Explanation of Total Chromium Analysis Calculation Table	A-29
B FIELD AND ANALYTICAL DATA	B-1
Particulate Matter	B-3
Total Particulate Analysis	B-21
Hexavalent Chromium Analysis	B-27
Total Chromium Analysis	B-31
C SAMPLING AND ANALYTICAL PROCEDURES	C-1
Determination of Total Particulate Emissions	C-3
Determination of Hexavalent Chromium Emissions	C-8
Determination of Total Chromium Content	C-15
D CALIBRATION AND QUALITY ASSURANCE DATA	D-1
E MRI PROCESS DATA	E-1
Source Sampling Program - Process Data Sheets	E-3
Current Usage Calculations	E-6
F TEST PARTICIPANTS AND OBSERVERS	F-1

FIGURES

<u>Number</u>		<u>Page</u>
2-1	Sequence of tanks on the decorative plating line at C. S. Ohm Manufacturing Company	2-2
4-1	Diagram of decorative chromium plating line and emissions control system at C. S. Ohm Manufacturing Company	4-2
4-2	Scrubber Inlet (Sampling Location A)	4-4
4-3	Scrubber Outlet (Sampling Location B)	4-6

TABLES

<u>Number</u>		<u>Page</u>
2.1	Total Current Supplied to Tank During Source Tests	2-5
3.1	Testing Schedule for C. S. Ohm	3-2
3.2	Summary of Flue Gas Conditions	3-4
3.3	Summary of Particulate, Hexavalent Chromium, and Total Chromium Emissions	3-6
3.4	Summary of Emission Rates in Units of Process Rate and Efficiency	3-10
3.5	Summary of Analytical Results for Hexavalent and Total Chromium	3-12
3.6	Summary of Analytical Results for Hexavalent and Total Chromium Quality Assurance Samples	3-14
4.1	Sampling Plan for C. S. Ohm	4-3
5.1	Field Equipment Calibration	5-2
5.2	Audit Report Chromium Analysis	5-4



## 1.0 INTRODUCTION

During the week of June 17-21, 1985, Entropy Environmentalists, Inc. conducted an emission measurement program at C. S. Ohm Manufacturing Company's chromium plating plant located in Sterling Heights, Michigan. The purpose of this program was to provide data for a screening study to determine the quantity and form of chromium emissions associated with decorative chromium plating.

Comprehensive testing was conducted on a decorative chromium plating tank whose emissions are controlled by a packed-bed wet scrubber. This fume scrubber controlling emissions from the decorative chromium plating tank at the plant was selected for source testing for the following reasons:

- The plating tank appears to be typical of other automated decorative plating tanks in the chromium plating industry, based on operating parameters such as temperature, current, voltage, and plating time. The automatic hoist is programmed to change the rack in the chromium plating tank every 4.5 minutes. Electrolysis occurs in this tank for 1.5 minutes during each cycle, or 33 percent of the time. A demisting agent called MSP-1, manufactured by Harshaw Chemicals, is used in the tank to suppress misting. The use of demisting agents is common practice for decorative platers.
- The emissions capture system is highly efficient in directing fumes from the plating tank to the control device. The tank is equipped with a push-pull ventilation system that draws 16,000 scfm across a total tank surface area of 90 ft<sup>2</sup>. (Included in this area is a storage tank used to concentrate chromic acid solutions from the rinse tank and the fume scrubber. No electrolysis occurs in this tank.)
- The emissions control device used at C. S. Ohm is typical of control devices in use at other decorative plating facilities. Most decorative plating facilities use impingement-type mist eliminators or packed-bed fume scrubbers to control chromic acid emissions. Emission data from testing at the outlet of the Viron wet packed-bed fume scrubber at this facility will represent emissions controlled by a typical fume scrubber.

Particulate concentrations and mass emission rates were measured at the scrubber inlet and outlet using U. S. Environmental Protection Agency (EPA) Reference Method 5.\* Total chromium concentrations and hexavalent chromium concentrations were measured at the same locations by further analysis of the Method 5 samples using the alternate sample preparation and analytical procedures as described in Appendix C. Flue gas flow rates, temperature, moisture content, and composition [oxygen (O<sub>2</sub>), carbon dioxide (CO<sub>2</sub>), and carbon monoxide (CO)] were measured in conjunction with the particulate tests. In addition, an impinger train was run concurrent with the Method 5 train at the scrubber inlet to determine impinger collection efficiency for total and hexavalent chromium. And for approximately 8 1/2 hours on the second day of testing, a special high volume, constant rate, single point sampling run was conducted at the scrubber inlet using a Method 5 train.

Ms. Barbara Duletsky [Midwest Research Institute (MRI)] monitored process operation throughout the test period. Mr. Dan Bivins (EPA Task Manager) of the Emission Measurement Branch (EMB) and Mr. Al Vervaert of the Industrial Studies Branch (ISB) observed the test program. Mr. Robert Waters, Plating Plant Manager served as the contact for C. S. Ohm Manufacturing.

This report is organized into several sections addressing various aspects of the testing program. Immediately following this introduction is the "Process Operation" section which includes a description of the process and control device tested. Following this is the "Summary of Results" section which presents table summaries of the test data and discusses these results. The next section, "Sampling Locations and Test Methods" describes and

---

\*40 CFR 60, Appendix A, Reference Method 5, July 1, 1980.

illustrates the sampling locations for emissions testing and then explains the sampling strategies used. The final section, "Quality Assurance," notes the procedures used to ensure the integrity of the sampling program. The Appendices present the complete Test Results and Example Calculations (Appendix A); Field and Analytical Data (Appendix B); Sampling and Analytical Procedures (Appendix C); Calibration Data (Appendix D); MRI Process Data (Appendix E); and Test Participants and Observers (Appendix F).

## 2.0 PROCESS OPERATION

### 2.1 PROCESS DESCRIPTION

The C. S. Ohm Manufacturing Company manufactures bumpers for use in the automotive industry. The company has a captive plating shop that performs decorative nickel-chromium plating of the bumpers. The plating plant operates 24 hours per day, 6 days per week, 52 weeks per year, with the exception of Wednesday mornings from midnight to 6:00 a.m., when the operation ceases for maintenance purposes.

The decorative plating line consists of 36 tanks that contain various plating and cleaning solutions. The sequence of tanks is shown in Figure 2-1. The line is serviced by an automatically controlled hoist that transfers each rack of bumpers through the various tanks in the plating line.

The chromium plating segment of the line is comprised of one plating tank, one evaporation tank, and three rinse tanks. Emissions from the chromium plating tank were measured during this source test program. The tank measures 3.0 meters (m) (10 feet [ft]) in length, 1.4 m (4.5 ft) in width, 2.4 m (8 ft) in depth, and holds 10,600 liters (ℓ) (2,800 gallons) of plating solution. The solution contains chromic acid in a concentration of 330 to 340 grams per liter (g/ℓ) (44 to 46 ounces per gallon [oz/gal]). This is in the range of 220 to 370 g/ℓ (30 to 50 oz/gal) typically used by decorative chromium platers. Sulfuric acid is used in the solution as a catalyst in a concentration of 1.0 to 1.2 g/ℓ (0.14 to 0.16 oz/gal). The proper concentration of constituents is maintained by adding chromic acid and sulfuric acid every other day, and by adding make-up solution from the evaporation tank on alternate days. The total chromic acid consumption at C. S. Ohm is about 8,200 kilograms (18,000 pounds) per year.

Typically, a rack remains in the chromium plating tank for 4 minutes and 20 seconds. The normal operating temperature of the tank is between 46° and 63°C (115° and 145°F). The electrodes are charged by a single transformer/rectifier set that automatically controls the operating voltage and current. During a typical plating cycle, the tank operates at 2.5 volts (V) and 1,500 amperes (A) for 15 seconds to activate the nickel-plated surfaces. Then, the voltage increases to 12.4 V and the

<u>Tank sequence</u>	<u>Description</u>
1	Soap tank
2	Power spray
3	Electro-cleaner No. 1
4	Electro-cleaner No. 2
5	Water rinse
6	Water rinse
7	Anodic etch (contains H <sub>2</sub> )
	Anodic etch (contains H <sub>2</sub> )
8	Rinse
9	Rinse
10	Rinse
11	Electro-cleaner No. 3
12	Rinse
13	Muriatic acid
14	Rinse
15	Nickel strike
16	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
	Dull nickel plate
17	Bright nickel plate
	Bright nickel plate
18	Micro-porous (MP) nickel plate
19	Nickel reclaim
20	Rinse
21	Activator chrome
	Chromium plate (evaporation tank)
22	Chromium plate
23	Chromic acid reclaim
24	Rinse
25	Rinse
26	Hot water rinse

Figure 2-1. Sequence of tanks on the decorative plating line at C. S. Ohm Manufacturing Company

current increases to 12,000 to 16,000 A for 90 seconds, during which chromium is deposited on the activated surfaces. This 90-second period is called "electrolysis." The current required during electrolysis is dependent on the surface area being plated and is automatically adjusted for each new rack of bumpers.

## 2.2 AIR POLLUTION CONTROL

A fume suppressant called "MSP-1" is used in the chromium plating tank to inhibit the release of gases generated during electrolysis. The suppressant is manufactured by Harshaw Chemical Company. It contains a fluorocarbon that decreases the surface tension of the plating solution, thus, decreasing the generation of mist. There are no test data available showing the emission reduction achieved by using this fume suppressant, although it is used commonly in the electroplating industry to preclude misting.

The chromium plating tank and evaporation tank are equipped with a push-pull ventilation system. Air jets on one end of the tanks push mist across the plating solution to a 1.2-m-high (4-foot-high) hood on the other end. An induced draft fan driven by a 20-horsepower motor draws emissions away from the tanks to the control device.

The control device is a wet, double-packed-bed scrubber manufactured by Viron International (Model HSDP-2000). The scrubber is designed to treat about 7.6 cubic meters per second ( $m^3/s$ ) (16,765 standard cubic feet per minute [scfm]) of plating tank exhaust gases. Chromic acid is removed from the gas stream by impacting on two 30-cm-deep (12-inch-deep) beds of filter media that are continuously sprayed with scrubbing liquid. The spent liquid drains into a remote holding tank from which it is recirculated through the scrubber. The holding tank is emptied once every 2 or 3 days and refilled with fresh water. The holding tank has an estimated volume of 500  $\ell$  (132 gal) and pumps about 91  $\ell/min$  (24 gal/min) of liquid to the scrubber.

The scrubber also contains a mist eliminator stage for the final removal of liquid droplets from the gas stream. This stage consists of a "Chevron-type" arrangement of baffles that change the direction of gas

flow several times. The entire scrubbing unit has a design removal efficiency of 99 percent for chromic acid.

### 2.3 PROCESS CONDITIONS DURING TESTING

The process was operating normally during the source test program. Process operating parameters such as temperature, voltage, and current were monitored during each test run and are recorded on the process data sheets in Appendix E. No operating parameters were monitored for the scrubber; however, there were no indications of any malfunction in the system during the testing.

Normal operating conditions allowed all three test runs to be performed without interruption. A scheduled 10-minute break in operation occurred each day at 10:30 a.m., but this was not considered cause to suspend testing because it was of short duration. Inlet and outlet testing were performed simultaneously.

The total current supplied to the tank during each test run is calculated in terms of ampere-seconds and included in Appendix E. A summary of the total current values is presented in terms of ampere-seconds and ampere-hours in Table 2-1.

TABLE 2-1. TOTAL CURRENT SUPPLIED TO TANK DURING SOURCE TESTS

Test No.	Total current, ampere-seconds		Total current, ampere-hours	
	Inlet	Outlet	Inlet	Outlet
1	90,000,000	83,900,000	25,000	23,300
2	79,590,000	73,740,000	22,100	20,500
3	94,620,000	84,350,000	26,300	23,400



### 3.0 SUMMARY OF RESULTS

Particulate matter (EPA Method 5) tests were conducted at the inlet and the outlet of the packed-bed wet scrubber controlling the decorative chromium plating tank. Because the emissions were chromic acid fumes, "impinger train" tests were run at the scrubber inlet to evaluate the use of Method 5 for sample collection. An additional run using the Method 5 train was conducted at a high sampling rate (HV) for eight hours at a single point. The data is presented for the high volume run but not discussed since the other tests were quantifiable and conducted isokinetically at all points. Table 3.1 summarizes the testing schedule for this testing program.

In brief, from the results of the Method 5 testing, the uncontrolled emissions from the tank averaged 0.035 pounds per hour of particulate matter, 0.000017 pounds per hour of hexavalent chromium, and 0.000065 pounds per hour of total chromium. Based on the Method 5 results, the controlled emissions averaged 0.024 pounds per hour of particulate matter, 0.000016 pounds per hour of hexavalent chromium, and 0.000095 pounds per hour of total chromium. Also based on the Method 5 results, the collection efficiency of the wet scrubber appeared to be low, however, this is inconclusive due to questionable data quality as indicated by the methods evaluation comparison with the impinger train. The impinger train samples were not analyzed for particulate matter. The collection efficiency of the impinger train indicated that essentially all the chromium was collected by the impingers and the impinger train results for hexavalent chromium at 0.00011 pounds per hour averaged about seven times greater than those from the Method 5 train.

TABLE 3.1. TESTING SCHEDULE FOR C. S. OHM

Date (1985)	Sample Type	Scrubber Inlet		Scrubber Inlet (Impinger Train)*		Scrubber Outlet	
		Run No.	Test Time 24 h clock	Run No.	Test Time 24 h clock	Run No.	Test Time 24 h clock
6/18	Particulate	2	1004-1529	1	1005-1530	3	1003-1505
6/19	Particulate Particulate (HV)**	5 SR	0838-1404 1419-2247	4	0839-1405	6	0837-1336
6/20	Particulate	8	0855-1420	7	0856-1421	9	0855-1350

\*Runs 1, 4, and 7 utilized an impinger train.

\*\*Special high volume, constant rate, single point, run (SR).

In the following sections, the results addressed above and additional results are presented and discussed in detail according to the emission type and sampling location. The computer printouts of the emission calculations can be found in Appendix A. The original field data sheets and the analytical data are located in Appendix B.

### 3.1 PARTICULATE MATTER, HEXA VALENT CHROMIUM, AND TOTAL CHROMIUM

Particulate matter tests (EPA Method 5) along with the determination of the associated flue gas flow rates were conducted at both the scrubber inlet and outlet; impinger train method evaluation tests were conducted at the scrubber inlet. The particulate matter samples were initially analyzed using gravimetric techniques to determine the mass of particulate matter. Then the samples were further analyzed for hexavalent and total chromium. The impinger train samples were analyzed for hexavalent and total chromium only. Complete descriptions of each sampling location and the sampling and analytical procedures are given in Chapter 4 (and Appendix C).

#### 3.1.1 Scrubber Inlet (EPA Method 5)

The results for the scrubber inlet (EPA Method 5) represent the uncontrolled emissions from the plating tank as measured by EPA Method 5. The circular vertical inlet duct was traversed with both an EPA Method 5 sampling train and an impinger train. The results from these two trains should be compared for methods evaluation purposes as a check on the ability of the EPA Method 5 sample train to collect chromic acid fumes.

Flue Gas Conditions and Isokinetic Sampling Rate - A summary of the flue gas conditions at the scrubber inlet (EPA Method 5 and impinger train) and the scrubber outlet (EPA Method 5 train) is presented in Table 3.2. The volumetric

TABLE 3.2. SUMMARY OF FLUE GAS CONDITIONS

Run No.	Date (1985)	Test Time 24 h clock	Volumetric Flow Rate				Stack Temperature		Moisture %	O <sub>2</sub> %	CO <sub>2</sub> %	CO %	Isokinetic %
			Actual <sup>a</sup>		Standard <sup>b</sup>		°C	°F					
			acmh x 10 <sup>6</sup>	acfh x 10 <sup>6</sup>	dscmh x 10 <sup>6</sup>	dscfh x 10 <sup>6</sup>							
Scrubber Inlet (Impinger Train) ✓													
1	6/18	1005-1530	0.0216	0.764	0.0203	0.717	25	77	1.0	20.9	0.0	0.0	98.7
4	6/19	0839-1405	0.0215	0.759	0.0204	0.719	24	76	1.0	20.9	0.0	0.0	98.6
7	6/20	0856-1421	0.0216	0.764	0.0204	0.719	26	79	1.0	20.9	0.0	0.0	98.4
Average			0.0216	0.762	0.0204	0.718	25	77	1.0	20.9	0.0	0.0	
Scrubber Inlet (Method 5)													
2	6/18	1004-1529	0.0206	0.728	0.0194	0.685	25	77	0.8	20.9	0.0	0.0	97.6
5	6/19	0838-1404	0.0200	0.705	0.0188	0.664	25	77	1.3	20.9	0.0	0.0	100.6
8	6/20	0855-1420	0.0212	0.748	0.0199	0.703	26	79	1.2	20.9	0.0	0.0	99.2
Average			0.0206	0.727	0.0194	0.684	25	78	1.1	20.9	0.0	0.0	
Scrubber Inlet - Special Run													
SR	6/19	1419-2247	0.0197	0.695	0.0187	0.660	26	79	0.2	20.9	0.0	0.0	79.8
Scrubber Outlet ✓													
3	6/18	1003-1505	0.0222	0.785	0.0212	0.749	20	68	1.4	20.9	0.0	0.0	94.2
6	6/19	0837-1336	0.0221	0.780	0.0211	0.747	20	68	1.7	20.9	0.0	0.0	94.6
9	6/20	0855-1350	0.0222	0.783	0.0211	0.744	22	72	1.8	20.9	0.0	0.0	94.5
Average			0.0222	0.783	0.0211	0.747	21	69	1.6	20.9	0.0	0.0	

<sup>a</sup>Volumetric flow rate in actual cubic meters per hour (acmh) and actual cubic feet per hour (acfh) at stack conditions.  
<sup>b</sup>Volumetric flow rate in dry standard cubic meters per hour (dscmh) and dry standard cubic feet per hour (dscfh).

flow rates for the inlet Method 5 tests were fairly consistent and averaged 20,600 actual cubic meters per hour (727,000 actual cubic feet per hour).

The flue gas temperature averaged 25°C (78°F), with a moisture content of 1.1 percent. The oxygen, carbon dioxide, and carbon monoxide content was that of air at 20.9, 0.0, and 0.0 percent, respectively. The volumetric flow rate at standard conditions averaged 19,400 dry standard cubic meters per hour (684,000 dry standard cubic feet per hour). Standard conditions are 20°C (68°F), 760 mm Hg (29.92 in. Hg), and dry. The isokinetic sampling rate was within the allowable range for all three sample runs.

Particulate Emissions - The particulate emissions from the plating tank (see Table 3.3) were variable. The particulate emissions for the inlet runs averaged 0.82 milligrams per dry standard cubic meter (0.00036 grains per dry standard cubic foot) and 0.016 kilograms per hour (0.035 pounds per hour). The variability was likely due to sampling and analytical error in measuring the extremely low pollutant concentrations.

Hexavalent Chromium Emissions - The hexavalent chromium emissions for each test run (see Table 3.3) were also variable with the corresponding particulate run. They averaged 95, 2150, and 633 milligrams of hexavalent chromium per gram of particulate emissions for runs 2, 5, and 8, respectively. The hexavalent chromium emissions for the inlet tests averaged  $0.39 \times 10^{-3}$  milligrams per dry standard cubic meter ( $0.17 \times 10^{-6}$  grains per dry standard cubic foot) and  $7 \times 10^{-6}$  kilograms per hour ( $17 \times 10^{-6}$  pounds per hour).

Total Chromium Emissions - The total chromium emissions for each test run (see Table 3.3) were variable with respect to the corresponding particulate run and averaged 423, 8290, and 2429 milligrams of total chromium per gram of

TABLE 3.3. SUMMARY OF PARTICULATE, HEXAVALENT CHROMIUM, AND TOTAL CHROMIUM EMISSIONS

Run No.	Date (1985)	Particulate			Hexavalent Chromium			Total Chromium			
		concentration		mass emissions	concentration		mass emissions	concentration		mass emissions	
		mg/dscm	gr/dscf	kg/h	mg/dscm	gr/dscf	kg/h	mg/dscm	gr/dscf	kg/h	
Scrubber Inlet (Impinger Train)											
1	6/18				2.35	0.00103	0.048	0.10	12.13	0.0053	0.246
4	6/19		(not analyzed)		2.02	0.00088	0.041	0.09	6.83	0.0030	0.139
7	6/20				3.14	0.00137	0.064	0.14	13.40	0.0059	0.273
Average					2.50	0.00109	0.051	0.11	10.8	0.0047	0.22
Scrubber Inlet (Method 5)											
2	6/18	1.27	0.00056	0.025	0.12	0.00005	0.002	0.005	0.537	0.00023	0.010
5	6/19	0.20	0.00009	0.004	0.43	0.00019	0.008	0.018	1.658	0.00072	0.031
8	6/20	0.98	0.00043	0.020	0.62	0.00027	0.012	0.027	2.380	0.00104	0.047
Average		0.82	0.00036	0.016	0.39	0.00017	0.007	0.017	1.52	0.0007	0.029
Scrubber Inlet (Special Run)											
SR	6/19	0.226	0.00010	0.004	0.36	0.00016	0.007	0.015	0.91	0.0004	0.017
Scrubber Outlet											
3	6/18	*	*	*	0.27	0.00012	0.006	0.013	2.406	0.00105	0.051
6	6/19	0.524	0.00023	0.011	0.34	0.00015	0.007	0.016	1.826	0.00080	0.039
9	6/20	*	*	*	0.41	0.00018	0.009	0.019	1.899	0.00083	0.040
Average		0.524	0.00023	0.011	0.34	0.00015	0.007	0.016	2.04	0.0009	0.043

\*Particulate catch was not quantifiable.

particulate. The total chromium emissions averaged  $1.52 \times 10^{-3}$  milligrams per dry standard cubic meter ( $0.7 \times 10^{-6}$  grams per dry standard cubic foot) and  $0.029 \times 10^{-3}$  kilograms per hour ( $0.065 \times 10^{-3}$  pounds per hour).

### 3.1.2 Scrubber Inlet (Impinger Train)

The results for the scrubber inlet (impinger train) represent the uncontrolled emissions from the plating tank as measured by the impinger train. The Method 5 and impinger train sampling were conducted simultaneously in the vertical circular duct prior to the packed bed scrubber. The impinger train tests were conducted to evaluate the use of the Method 5 train for the reference method collection of the chromic acid fumes for the chromium plating industry. The results of the Method 5 and impinger train testing should be comparable.

Flue Gas Conditions and Isokinetic Sampling Rate - A summary of the flue gas conditions at the scrubber inlet (impinger train) is presented in Table 3.2. The volumetric flow rate results for both the Method 5 train and impinger train were within standard measurement error of each other. The isokinetic sampling rate was within the allowable range for all three impinger train sample runs.

Particulate Emissions - The collected samples were not analyzed for particulate emissions since all of the impinger contents would have had to be taken to dryness. Also, it would have made the analysis for hexavalent and total chromium more difficult in the sample preparation phase.

Hexavalent Chromium Emissions - The hexavalent chromium emissions were fairly consistent averaging  $2.5 \times 10^{-3}$  milligrams per dry standard cubic meter ( $1.1 \times 10^{-6}$  grains per dry standard cubic foot) and  $51 \times 10^{-6}$  kilograms per hour ( $110 \times 10^{-6}$  pounds per hour). This was about seven times greater than the hexavalent chromium emissions measured by the EPA Method 5 train. The reason for the extremely poor agreement is not known.

Total Chromium Emissions - The total chromium emissions averaged  $10.8 \times 10^{-3}$  milligrams per dry standard cubic meter ( $4.7 \times 10^{-6}$  grains per dry standard cubic foot) and  $0.22 \times 10^{-3}$  kilograms per hour ( $0.48 \times 10^{-3}$  pounds per hour). This was about eight times greater than the total chromium emissions measured by the EPA Method 5 train. This is in agreement with the comparison of the hexavalent chromium results between the two sampling trains.

### 3.1.3 Scrubber Outlet

The scrubber outlet represents the controlled emissions from the chromium plating tank as measured by EPA Method 5; no impinger train tests were conducted at the scrubber outlet. A four-inch filter and larger than normal size nozzle were used in an effort to collect the maximum sample volume under isokinetic sampling conditions.

Flue Gas Conditions and Isokinetic Sampling Rate - A summary of flue gas conditions at the scrubber outlet is presented in Table 3.2. The volumetric flow rates for the three outlet runs were very consistent. The outlet volumetric flow rate averaged 22,200 actual cubic meters per hour (783,000 actual cubic feet per hour) with a flue gas temperature of  $21^{\circ}\text{C}$  ( $69^{\circ}\text{F}$ ) and a moisture content of 1.6 percent. The oxygen, carbon dioxide, and carbon monoxide concentrations were that of ambient air at 20.9, 0.0, and 0.0 percent, respectively. The volumetric flow rate at standard conditions averaged 21,100 dry standard cubic meters per hour (747,000 dry standard cubic feet per hour). Standard conditions are  $20^{\circ}\text{C}$  ( $68^{\circ}\text{F}$ ), 760 mm Hg (29.92 in. Hg), and dry.

The isokinetic sampling rates were well within the allowable range for all runs.

Particulate Emissions - The particulate emissions exiting from the control equipment to the atmosphere were not quantifiable (see Table 3.3) for two of the three runs. For the one run which had quantifiable results, the particulate



emissions averaged 0.5 milligrams per dry standard cubic meter (0.0002 grains per dry standard cubic foot) and 0.01 kilograms per hour (0.02 pounds per hour). The other two runs had negative sample weights. Method 5 was intended to accurately measure pollutant concentrations at these low levels.

Hexavalent Chromium Emissions - The hexavalent chromium emissions for each test run were fairly consistent and averaged  $0.34 \times 10^{-3}$  milligrams per dry standard cubic meter ( $0.15 \times 10^{-6}$  grains per dry standard cubic foot) and  $7 \times 10^{-6}$  kilograms per hour ( $16 \times 10^{-6}$  pounds per hour). These results were similar in magnitude to the Method 5 uncontrolled results.

Total Chromium Emissions - The total chromium emissions were fairly consistent and averaged  $2.04 \times 10^{-3}$  milligrams per dry standard cubic meter ( $0.9 \times 10^{-6}$  grams per dry standard cubic foot) and  $0.043 \times 10^{-3}$  kilograms per hour ( $0.095 \times 10^{-3}$  pounds per hour). These results were greater than the controlled emissions as measured by the EPA Method 5 train.

### 3.2 EMISSIONS IN UNITS OF PROCESS RATE AND CONTROL EQUIPMENT COLLECTION EFFICIENCY

The emission rates in units of process rate are given in terms of milligrams of emissions per hour per square foot of tank surface area, and in units of milligrams of emissions per amperage input to the plating operation. To determine the collection efficiency of the scrubber, the milligrams per hour per square foot (uncontrolled emissions and controlled emissions) were used for the calculations.

#### 3.2.1 Emissions in Units of Process Rate

Two process parameters were used to determine the emissions in terms of units of the process rate as shown in Table 3.4. The first was milligrams of emissions per amperage input to the plating operation. The second was milligrams of emissions per hour per square foot of tank surface area. The surface area of the tank was  $45 \text{ ft}^2$  for all tests.

TABLE 3.4. SUMMARY OF EMISSION RATES IN UNITS OF PROCESS RATE AND EFFICIENCY

Run Nos.	Process Rate current supplied to tank in amps/hr	Uncontrolled Emissions				Controlled Emissions				Collection Efficiency**					
		particulate		hexavalent chromium	total chromium	particulate		hexavalent chromium	total chromium	particulate	hexavalent chromium	total chromium	particulate	hexavalent chromium	total chromium
		mg/amp	mg/hr ft <sup>2</sup>	mg/amp hr	mg/amp ft <sup>2</sup>	mg/amp	mg/hr ft <sup>2</sup>	mg/amp	mg/hr ft <sup>2</sup>	mg/amp	mg/hr ft <sup>2</sup>	mg/amp	mg/amp	mg/hr ft <sup>2</sup>	mg/amp
Scrubber Inlet (Impinger Train)															
1	25,000	not analyzed	not analyzed	0.0019	1.07	0.0098	5.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
4	22,100			0.0019	0.91	0.0063	3.09								
7	26,300			0.0024	1.42	0.0104	6.07								
Average				0.0021	1.13	0.0088	4.87								
Scrubber Inlet (Method 5)															
2	25,000	0.0010	556	0.0008	0.04	0.0004	0.22	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
5	22,100	0.0002	89	0.00036	0.18	0.0014	0.69								
8	26,300	0.0008	444	0.00046	0.27	0.0018	1.04								
Average		0.0007	363	0.00030	0.16	0.0012	0.65								
Scrubber Outlet (Method 5)															
3	23,300	N/A	N/A	N/A	N/A	N/A	N/A	no val	no val	0.00026	0.13	0.0022	1.13	no val	---
6	20,500							0.00054	244	0.00034	0.16	0.0019	0.87	---	11.1
9	23,400							no val	no val	0.00038	0.20	0.0017	0.89	no val	25.9
Average								0.00054	244	0.00033	0.16	0.0019	0.96	32.8***	0***

\*Emission rate in units of milligrams of emissions per hour per square foot of tank surface using a tank surface of 45 ft<sup>2</sup> for all tests.  
 \*\*Air pollution control efficiency calculations are based on uncontrolled and controlled emissions in units of mg/hr/ft<sup>2</sup>.  
 \*\*\*Calculated based on averages of uncontrolled and controlled emissions.

### 3.2.2 Control Equipment Collection Efficiency

The collection efficiency of the packed-bed scrubber (see Table 3.4) was extremely low based on the EPA Method 5 results. The control equipment collection efficiency was 32.8 percent for particulate and was zero percent for hexavalent chromium. The measured emissions for total chromium were greater after the scrubber than prior to the scrubber. The validity of the results are questionable based on the methods evaluation tests and should not be used as an accurate indication of collection efficiency.

### 3.3 SUMMARY OF ANALYTICAL RESULTS FOR HEXAVALENT AND TOTAL CHROMIUM

The summary of analytical results for the hexavalent chromium and total chromium analyses of samples collected is presented in Table 3.5. The analytical data sheets are contained in Appendix B. The results shown in Table 3.5 for hexavalent and total chromium are the results obtained using the EPA tentative method for "Determination of Hexavalent Chromium Emissions from Stationary Sources" and the "EPA Protocol for Emissions Sampling for Both Hexavalent and Total Chromium" (see Appendix C). When, for total chromium analysis, the table indicates that the sample "residue" was analyzed, then the values presented for total chromium content are a sum of (1) the hexavalent chromium in the sample filtrate from the extraction of the sample and (2) the chromium in the residue from the extraction as measured by Neutron Activation Analysis. When the table indicates that the "total" sample was analyzed, then the values presented for total chromium content are from the direct analysis of the total sample for total chromium by Neutron Activation Analysis. A table showing the total chromium calculations for each sample can be found at the end of Appendix A of this report.

The collection efficiency of hexavalent chromium by the impinger train is believed to be greater than 99%. The efficiency was determined by analyzing the impinger contents separately as shown in Table 3.5.

TABLE 3.5 SUMMARY OF ANALYTICAL RESULTS FOR HEXAVALENT AND TOTAL CHROMIUM

Run No.	Sample Type	Sample No. Analyzed	Amount of Sample Analyzed	Hexavalent Chromium		Amount of Sample Analyzed	Total Chromium	
				Results $\mu\text{g}$	Concentration $\mu\text{g/g}$		Results $\mu\text{g}$	Concentration $\mu\text{g/g or } \mu\text{g/ml}$
Scrubber Inlet (Impinger Train)								
1	1st Impinger Contents	C-255	Total	15.6	15.6 $\mu\text{g total}^\dagger$	Half	77.38*	80.5 $\mu\text{g total}^\dagger$
1	2nd Impinger Contents	C-256	Total	< 0.2		Half	2.56*	
1	3rd Impinger Contents	C-257	Total	< 0.2		Half	2.26*	
4	1st Impinger Contents	C-258	Total	13.2	13.2 $\mu\text{g total}^\dagger$	Half	40.54*	45.4 $\mu\text{g total}^\dagger$
4	2nd Impinger Contents	C-259	Total	< 0.2		Half	2.82*	
4	3rd Impinger Contents	C-260	Total	0.2		Half	4.26*	
7	1st Impinger Contents	C-261	Total	19.4	19.4 $\mu\text{g total}^\dagger$	Half	71.70*	88.9 $\mu\text{g total}^\dagger$
7	2nd Impinger Contents	C-262	Total	0.7		Half	8.84*	
7	3rd Impinger Contents	C-263	Total	0.7		Half	10.36*	
Scrubber Inlet (Method 5 and High Volume Train)								
2	Particulate Front Half	C-241	8.3 mg Total	0.8	96 negligible	Residue	2.5	301.2
2	Impinger Contents	C-249	Total	< 0.2		Half	1.0	
5	Particulate Front Half	C-242	1.3 mg Total	2.8	2150	Residue	9.4	7230.8
5	Impinger Contents	C-250	Total	< 0.2		Half	1.4	
8	Particulate Front Half	C-243	6.7 mg Total	4.2	627	Residue	16.2	2417.9
8	Impinger Contents	C-251	Total	< 0.2		Half	---	
SR	Particulate Front Half	C-244	3.7 mg Total	5.9	1590	Residue	14.9	4027.0
SR	Impinger Contents	C-267	Total	< 0.2		Half	---	
Scrubber Outlet								
3	Particulate Front Half	C-245	** Total	2.1	** negligible	Residue	18.8	---
3	Impinger Contents	C-252	Total	< 0.2		Half	---	
6	Particulate Front Half	C-246	4.1 mg Total	2.7	659	Residue	14.3	3487.8
6	Impinger Contents	C-253	Total	< 0.2		Half	---	
9	Particulate Front Half	C-247	** Total	3.2	** negligible	Residue	14.8	---
9	Impinger Contents	C-254	Total	< 0.2		Half	---	
Scrubber Water Discharge (Liquids)								
	Scrubber H <sub>2</sub> O	C-265	--	--	5.09 $\mu\text{g/ml}$	1.0 ml	12.7	12.7 $\mu\text{g/ml}$
Blank Samples								
	Particulate Filter	C-248	--	1.1		Residue	6.7	---
	Distilled H <sub>2</sub> O w/Acetone	C-264	--	--	< 0.2 $\mu\text{g/ml}$	1.0 ml	2.0	2.0 $\mu\text{g/ml}$

\*Not blank corrected. \*\*particulate catch was not quantifiable.

† The concentration in terms of  $\mu\text{g/g}$  could not be calculated since the mass collected by the impingers was not determined; the value represents the total weight of chromium collected in all three impingers.

Both the quantity of the particulate and the hexavalent chromium analyzed were extremely low and, under these circumstances, both sets of analytical results are subject to greater analytical error.

Quality assurance audit samples were analyzed for both the hexavalent and total chromium methods. As shown in Table 3.6, no bias was present and the results are considered acceptable.

There is some sample analysis variability due to the small amount of hexavalent chromium present. However, the average values for the runs are believed to be fairly accurate.

TABLE 3.6. SUMMARY OF ANALYTICAL RESULTS FOR HEXAVALENT AND TOTAL CHROMIUM QUALITY ASSURANCE SAMPLES

Run No.	Sample Type	Sample No.	True Value	Hexavalent Chromium		Total Chromium	
				Results $\mu\text{g/ml}$	% Dev.	Results $\mu\text{g}$	% Dev.
Quality Assurance Samples							
--	Quality Assurance	C-266	50 $\mu\text{g/ml Cr}^{+6}$	52.4	+4.8	---	---
--	Quality Assurance	QA-16	50 $\mu\text{g Cr}$	---	---	45.69	-8.6
--	Quality Assurance	QA-17	100 $\mu\text{g Cr}$	---	---	96.49	-3.5
--	Quality Assurance	QA-18	150 $\mu\text{g Cr}$	---	---	146.4	-2.4

#### 4.0 SAMPLING LOCATIONS AND TEST METHODS

This section describes the sampling locations and test methods used to characterize emissions from the decorative chromium plating tank at C. S. Ohm Manufacturing Company in Sterling, Michigan. Two sampling locations were used in the emission testing program. At each sampling location (one at the scrubber inlet and one at the scrubber outlet), emissions testing was conducted for particulate matter, total chromium content, and hexavalent chromium content. Sampling for chromium and an impinger collection efficiency determination was also conducted at the scrubber inlet using an impinger train. One special high volume, constant flow rate, single point sampling run was conducted at the inlet, also. The relative positions and the type of testing conducted at each location are shown in the simplified process flow diagram (see Figure 4-1) and accompanying Table 4.1. The subsections which follow further describe each sampling location and applicable test methods.

##### 4.1 SCRUBBER INLET (SAMPLING LOCATION A)

Particulate matter, hexavalent chromium, and total chromium were measured at the inlet to the packed-bed scrubber controlling emissions from the decorative chromium plating tank as shown in Figure 4-2. Two sampling ports were installed 90° apart in the vertical circular duct (32 inches in diameter). These ports were located 26 inches (0.81 duct diameters) upstream of a bend in the duct to the scrubber and 168 inches (5.25 duct diameters) downstream from another bend.

16,000 SCFM  
TO ATMOSPHERE




Figure 4-1. Diagram of decorative chromium plating line and emissions control system at C. S. Ohm Manufacturing Company.




TABLE 4.1. SAMPLING PLAN FOR C. S. OHM


Sample Type	Sampling Locations	Number of Samples	Methods
Particulate matter	A, B	3 (M5) 1 (M5 HV. at A)	EPA Method 5 or EPA Method 5 High Volume
Hexavalent chromium	A, B	3 (M5) 1 (M5 HV. at A)	EPA Method 5 or EPA Method 5 High Volume using Tentative EPA Method for Hexavalent Chromium
Total chromium	A, B	3 (M5) 1 (M5 HV. at A)	EPA Method 5 or EPA Method 5 High Volume using EPA Protocol for Total Chromium
Chromium (Impinger efficiency)	A	3	Impinger Train using Tentative EPA Method for Hexavalent Chromium and EPA Protocol for Total Chromium

TRAYERSE POINTS

2 AXES  
8 POINTS/AXIS  
16 TOTAL POINTS



SECTION L-L



ELEVATION VIEW

FIGURE 4-2. SCRUBBER INLET (SAMPLING LOCATION A)

For the Method 5 testing, (used for particulate matter, hexavalent chromium, and total chromium determinations) and the impinger train testing, a total of 16 points, as per Method 1, were sampled. Each of the 16 points was sampled for 20 minutes for a total of 320 minutes of sampling per run. Each of three Method 5 and three impinger train runs were conducted to coincide with the sampling at the scrubber outlet location.


#### 4.2 SCRUBBER OUTLET STACK (SAMPLING LOCATION B)

Particulate matter, hexavalent chromium, and total chromium were measured at the scrubber outlet as shown in Figure 4-3. Four sampling ports were installed along the shorter side of the 26 1/2 by 34 3/4 inch vertical rectangular stack. The ports were located about 8 inches (0.025 duct diameters) upstream from the stack exit and 32 1/4 inches (1.07 duct diameters) downstream from the fan. Because of the close proximity of the flow disturbance (stack exit) downstream of the ports, this location did not meet EPA Method 1 sampling requirements; a planned stack extension was refused by EPA for reasons of excessive additional cost.

For the EPA Method 5 sampling (used for particulate matter, hexavalent chromium, and total chromium determinations), a total of 24 points, 6 per axis, were sampled. Each point was sampled for 12 minutes for a total sampling time of 288 minutes.

#### 4.3 VELOCITY AND GAS TEMPERATURE

A type S pitot tube and an inclined draft gauge manometer or two differential pressure gauges in-parallel were used to measure the gas velocity pressure ( p ). Velocity pressures were measured at each sampling point across



TRAYERSE POINTS  
 4 AXES  
 6 POINTS/AXIS  
 24 TOTAL POINTS

SECTION R-R




FIGURE 4-3. SCRUBBER OUTLET (SAMPLING LOCATION B)

the duct to determine an average value according to the procedures outlined in Method 2 of the Federal Register.\* The temperature at each sampling point was measured using a thermocouple and digital readout.

#### 4.4 MOLECULAR WEIGHT

Flue gas composition was essentially that of the ambient air drawn in from above the plating tank. Therefore, the dry molecular weight and composition of air was used.

#### 4.5 PARTICULATE MATTER

Method 5, as described in the Federal Register,\* was used to measure particulate grain loading at locations A and B. All tests (except the special high volume run) were conducted isokinetically by traversing the cross-sectional area of the stack and regulating the sample flow rate relative to the flue gas flow rate as measured by the pitot tube attached to the sample probe. A sampling train consisting of a heated, glass-lined probe, 79 mm (3 inch) [or 102 mm (4 inch) for the high volume run] diameter Teflon filter (Schleicher & Schuell), and a series of Greenburg-Smith impingers was employed for each test. An acetone rinse and a water rinse of the nozzle, probe, and filter holder portions of the sample train were made at the end of each test. The particulate caught on the filter media was dried at room temperature, the combined acetone and water rinse was taken to dryness in an oven; both were desiccated to a constant weight, and weighed on an analytical balance. Total filterable particulate matter was determined by adding these three values. See Appendix C for detailed sampling procedures.

#### 4.6 IMPINGER COLLECTION EFFICIENCY

A sample train similar to that used for EPA Methods 1-5 was used to measure the impinger collection efficiency at the scrubber inlet. The train did not contain any filter, instead a filter bypass was inserted in the line and three Greenburg-Smith impingers each containing 100 ml of distilled water were used to collect the emissions. The impinger train tests were run simultaneously with the Method 5 tests and were conducted isokinetically by traversing the cross-sectional area of the stack and regulating the sample flow rate relative to the flue gas flow rate as measured by the pitot tube attached to the sample probe. The contents of each impinger were recovered separately at the end of each test. Each impinger was rinsed first with acetone and then with water; these rinses were then added to the corresponding impinger contents. The probe and filter bypass were also rinsed with both acetone and water and these rinses were added to the first impinger contents. The contents and rinses from each impinger were concentrated and analyzed for hexavalent and total chromium content.

#### 4.7 HEXAVALENT CHROMIUM CONTENT

Hexavalent chromium content was determined utilizing procedures described in the tentative EPA Method "Determination of Hexavalent Chromium Emissions from Stationary Sources" (see Appendix C). The Method 5 filter catches collected and weighed for each Method 5 run and the impinger train impinger catches were taken and analyzed for hexavalent chromium content using this method. It was also used to determine the hexavalent chromium content in the first impinger for representative Method 5 runs.

---

• 40 CFR 60, Appendix A, Reference Methods 2, 3, and 5, July 1, 1980.

#### 4.8 TOTAL CHROMIUM CONTENT

Total chromium content was determined using procedures described in the "EMB Protocol for Sample Preparation and Emission Calculation of Field Samples for Total Chromium" in combination with Neutron Activation Analysis (NAA) (see Appendix C). Samples collected during Method 5 and impinger train runs and first submitted for analysis for hexavalent chromium were then analyzed for total chromium using this method.

## 5.0 QUALITY ASSURANCE

Because the end product of testing is to produce representative emission results, quality assurance is one of the main facets of stack sampling. Quality assurance guidelines provide the detailed procedures and actions necessary for defining and producing acceptable data. Two such documents were used in this test program to ensure the collection of acceptable data and to provide a definition of unacceptable data. These documents are: the EPA Quality Assurance Handbook Volume III, EPA-600/4-77-027 and Entropy's "Quality Assurance Program Plan" which has been approved by the U. S. EPA, EMB.

Relative to this test program, the following steps were taken to ensure that the testing and analytical procedures produce quality data.

- Calibration of field sampling equipment. (Appendix D describes calibration guidelines in more detail.)
- Checks of train configuration and on calculations.
- On-site quality assurance checks such as sampling train, pitot tube, and Orsat line leak checks, and quality assurance checks of all test equipment prior to use.
- Use of designated analytical equipment and sampling reagents.

Table 5-1 summarizes the on-site audit data sheets for the sampling equipment used for particulate testing at each sampling location, including deviation limits. In addition to the pre- and post-test calibration audits, a field audit was performed on the meter boxes used for sampling. Entropy used the procedures described in the December 14, 1983 Federal Register (48FR55670). In addition, the analytical balance used for filter weighing was audited with Class "S" weights. Appendix D includes the audit run data sheets for each dry gas meter used for particulate testing and audit data sheets for the other sampling equipment.



TABLE 5.1. FIELD EQUIPMENT CALIBRATION

Equipment	Reference	Allowable Error	Actual Error	Within Allowable Limits
Scrubber Inlet				
Meter box (N-5)	Wet test meter	$Y \pm 0.03Y$	+0.025	✓
Meter box thermometer	ASTM-3F at ambient temperature	5°F	+1°F	✓
Trip balance	IOLM standard weight	0.5 grams	0.1 gram	✓
Analytical balance	Class "S" standard weight	0.1 mg	0.02 mg	✓
Scrubber Inlet (Impinger Train)				
Meter box (N-6)	Wet test meter	$Y \pm 0.03Y$	+0.0158	✓
Meter box thermometer	ASTM-3F at ambient temperature	5°F	-2°F	✓
Trip balance	IOLM standard weight	0.5 grams	0.1 gram	✓
Analytical balance	Class "S" standard weight	0.1 mg	0.02 mg	✓
Scrubber Outlet				
Meter box (N-8)	Wet test meter	$Y \pm 0.03Y$	+0.016	✓
Meter box thermometer	ASTM-3F at ambient temperature	5°F	0°F	✓
Trip balance	IOLM standard weight	0.1 gram	0.1 gram	✓
Analytical balance	Class "S" standard weight	0.1 mg	0.02 mg	✓

Audit solutions prepared by the EPA were used to check the analytical procedures of the laboratories conducting the hexavalent and total chromium analyses. Table 5-2 presents the results of these analytical audits. The audit tests show that the analytical techniques were good.

The sampling equipment, reagents, and analytical procedures for this test series were in compliance with all necessary guidelines set forth for accurate test results as described in Volume III of the Quality Assurance Handbook.

TABLE 5.2. AUDIT REPORT CHROMIUM ANALYSIS

Plant: C.S. Ohm Task No.: 3021  
 Date samples received: 7/2/85 Date analyzed: 7/12/85  
 Sample analyzed by: RTI  
 Reviewed by: Peter Grohse Date of review: \_\_\_\_\_

Sample Number	$\mu\text{g/ml}$ $\text{Cr}^{+6}$ or Cr	Source of Sample	Audit Value	Relative error, %
C-266	50 $\mu\text{g/ml}$	QAD	52.4	+4.8%
QA-16	50 $\mu\text{g Cr}$	NBS	45.69	-8.6%
QA-17	100 $\mu\text{g Cr}$	NBS	96.49	-3.5%
QA-18	150 $\mu\text{g Cr}$	NBS	146.4	-2.4%

APPENDIX A.  
TEST RESULTS AND EXAMPLE CALCULATIONS

ANT	C. S. Ohm	DATE	06/18/85
SAMPLING LOCATION	Scrubber Inlet	RUN NUMBER	1
OPERATOR	BB	PROBE LENGTH, ft.	4'5"
BAR. PRESS., in. Hg	29.000	ASSUMED MOISTURE, %	2
STATIC PRESS., in. H2O	-2.000	NOZZLE #	405
FILTER NUMBER(S)		NOZZLE DIAMETER, in.	0.252
TOT TUBE COEFF.	0.840	METER BOX ΔH@	1.8
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	24
LEAK TEST VACUUM, in.Hg	10.000	METER BOX NUMBER	N-5

Trav. Time (Min.)	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
	ON/O	698.200	0.300	1.38	1.38	90	3.0	95	60	52	
	10.0	704.770	0.300	1.38	1.38	94	3.0	92	60	55	
	20.0	711.250	0.300	1.38	1.38	95	3.0	92	60	56	
	30.0	717.830	0.300	1.38	1.38	97	3.0	92	60	56	
	40.0	724.430	0.300	1.38	1.38	98	3.0	90	60	75	
	50.0	731.040	0.300	1.38	1.38	99	3.0	90	60	76	
	60.0	738.150	0.350	1.58	1.58	100	3.0	90	60	79	
	70.0	745.100	0.350	1.58	1.58	100	3.0	90	60	80	
	80.0	752.060	0.350	1.58	1.58	100	3.0	90	60	78	
	90.0	758.750	0.350	1.58	1.58	100	3.0	90	60	78	
	100.0	765.800	0.350	1.58	1.58	100	3.0	90	60	78	
	110.0	772.960	0.350	1.58	1.58	100	3.0	90	60	78	
	120.0	779.920	0.350	1.58	1.58	100	3.0	90	60	82	
	130.0	786.960	0.350	1.58	1.58	100	3.0	93	60	80	
	140.0	794.050	0.350	1.58	1.58	100	3.0	93	60	80	
	150.0	801.140	0.350	1.58	1.58	100	3.0	93	60	80	
A	160/O	808.238	0.500	2.30	2.30	95	5.0	90	60	75	808.238
	10.0	816.840	0.550	2.53	2.53	98	5.0	90	60	75	808.300
	20.0	825.750	0.550	2.53	2.53	98	5.0	90	60	78	
	30.0	834.760	0.550	2.53	2.53	98	5.0	90	60	76	
	40.0	843.780	0.550	2.53	2.53	96	5.0	90	60	75	
	50.0	852.740	0.550	2.53	2.53	95	5.0	90	60	73	
	60.0	861.750	0.550	2.53	2.53	96	5.0	90	60	80	
	70.0	871.000	0.550	2.53	2.53	96	5.0	90	60	82	
	80.0	879.770	0.550	2.53	2.53	95	5.0	90	60	80	
	90.0	888.800	0.550	2.53	2.53	95	5.0	90	60	80	
	100.0	897.780	0.550	2.53	2.53	95	5.0	90	60	80	
	110.0	906.850	0.550	2.53	2.53	95	5.0	90	60	82	
	120.0	915.950	0.550	2.53	2.53	95	5.0	90	60	81	
	130.0	925.050	0.550	2.53	2.53	95	5.0	90	60	79	
	140.0	934.120	0.550	2.53	2.53	95	5.0	90	60	80	
	150.0	943.190	0.550	2.53	2.53	95	5.0	90	60	80	
	FINAL 320/OFF	952.429									
	DIFF/AVG.	254.167	0.43205		2.010	97				77	0.062

PLANT C. S. Ohm  
 SAMPLING LOCATION Scrubber Inlet  
 OPERATOR BB  
 BAR. PRESS., in. Hg 29.200  
 STATIC PRESS., in. H2O -1.900  
 FILTER NUMBER(S)  
 PITOT TUBE COEFF. 0.840  
 LEAK RATE, CFM 0.000  
 LEAK TEST VACUUM, in.Hg 10.000

DATE 06/19/85  
 RUN NUMBER 4  
 PROBE LENGTH, ft. 4' 5"  
 ASSUMED MOISTURE, % 2  
 NOZZLE # 406  
 NOZZLE DIAMETER, in. 0.252  
 METER BOX ΔH@ 1.8  
 SAMPLE BOX NUMBER 24  
 METER BOX NUMBER N-5

Trav. Point No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Voo. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
B	0M/0	952.700	0.330	1.45	1.45	68	3.0	90	60	75	
	10.0	959.350	0.330	1.45	1.45	75	3.0	90	60	75	
	20.0	966.400	0.330	1.45	1.45	80	3.0	90	60	76	
	30.0	972.800	0.360	1.58	1.58	82	3.0	90	60	75	
	40.0	979.880	0.360	1.58	1.58	82	3.0	90	60	74	
	50.0	986.930	0.360	1.58	1.58	84	3.0	90	60	79	
	60.0	994.000	0.360	1.58	1.58	85	3.0	90	60	75	
	70.0	1001.050	0.360	1.58	1.58	85	3.0	90	60	76	
	80.0	1001.100	0.360	1.58	1.58	85	3.0	90	60	76	
	90.0	1015.170	0.360	1.58	1.58	85	3.0	90	60	75	
	100.0	1022.250	0.400	1.75	1.75	85	3.0	90	60	76	
	110.0	1029.680	0.400	1.75	1.75	85	3.0	90	60	76	
	120.0	1037.160	0.400	1.75	1.75	85	3.0	90	60	76	
	130.0	1044.610	0.400	1.75	1.75	86	3.0	90	60	77	
	140.0	1052.110	0.390	1.66	1.66	87	3.0	90	60	76	
	150.0	1059.500	0.390	1.66	1.66	87	3.0	90	60	77	
A	160/0	1066.755	0.480	2.10	2.10	86	5.0	90	60	68	1066.755
	10.0	1075.030	0.480	2.10	2.10	88	5.0	90	60	73	1066.850
	20.0	1083.300	0.480	2.10	2.10	88	5.0	90	60	75	
	30.0	1091.570	0.480	2.10	2.10	88	5.0	90	60	73	
	40.0	1099.840	0.480	2.10	2.10	88	5.0	90	60	73	
	50.0	1108.100	0.480	2.10	2.10	88	5.0	90	60	74	
	60.0	1116.340	0.480	2.10	2.10	88	5.0	90	60	78	
	70.0	1124.550	0.480	2.10	2.10	87	5.0	90	60	77	
	80.0	1132.790	0.520	2.27	2.27	86	6.0	90	60	77	
	90.0	1141.180	0.520	2.27	2.27	86	6.0	90	60	79	
	100.0	1149.600	0.520	2.27	2.27	86	7.0	90	60	79	
	110.0	1158.000	0.520	2.27	2.27	87	7.0	90	60	79	
	120.0	1166.440	0.520	2.27	2.27	88	7.0	90	60	79	
	130.0	1174.880	0.520	2.27	2.27	89	7.0	90	60	79	
	140.0	1183.350	0.520	2.27	2.27	90	7.0	90	60	84	
	150.0	1191.820	0.520	2.27	2.27	90	7.0	90	60	84	
FINAL	320/OFF	1200.318									
DIFF/AVG.		247.523	0.43056		1.897	85				76	0.095

PLANT	C. S. Ohm	DATE	05/20/85
SAMPLING LOCATION	Scrubber Inlet	RUN NUMBER	7
GENERATOR	BB	PROBE LENGTH, ft.	4'5"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	2
STATIC PRESS., in. H2O	-1.950	NOZZLE #	406
FILTER NUMBER(S)		NOZZLE DIAMETER, in.	0.252
WET TUBE COEFF.	0.840	METER BOX ΔH@	1.3
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	24
LEAK TEST VACUUM, in.Hg	5.000	METER BOX NUMBER	N-5

Av. Int. No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O)	ΔH (Actual)	Gas Meter Temp. (deg. F)	Pump Voo. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
	DN/O	215.600	0.310	1.39	1.39	78	3.0	90	60	73	
	10.0	222.050	0.310	1.39	1.39	83	3.0	90	60	73	
	20.0	228.520	0.310	1.39	1.39	90	3.0	90	60	77	
	30.0	235.000	0.330	1.48	1.48	93	3.0	90	60	79	
	40.0	241.950	0.330	1.48	1.48	96	4.0	90	60	79	
	50.0	248.780	0.330	1.48	1.48	98	4.0	90	60	79	
	60.0	255.670	0.330	1.48	1.48	100	4.0	90	60	83	
	70.0	262.510	0.330	1.48	1.48	102	4.0	90	60	82	
	80.0	269.570	0.360	1.61	1.61	102	4.0	90	60	79	
	90.0	276.620	0.360	1.61	1.61	102	4.0	90	60	81	
	100.0	283.820	0.360	1.61	1.61	102	4.0	90	60	80	
	110.0	291.010	0.390	1.75	1.75	103	4.0	90	60	81	
	120.0	298.500	0.390	1.75	1.75	103	4.0	90	60	80	
	130.0	306.000	0.390	1.75	1.75	103	4.0	90	60	80	
	140.0	313.460	0.390	1.75	1.75	102	4.0	90	60	78	
	150.0	320.960	0.390	1.75	1.75	100	4.0	90	60	79	
	160/O	328.515	0.520	2.33	2.33	97	5.0	90	60	74	328.515
	10.0	336.820	0.520	2.33	2.33	99	5.0	90	60	70	328.600
	20.0	345.380	0.520	2.33	2.33	99	5.0	90	60	76	
	30.0	353.950	0.520	2.33	2.33	99	5.0	90	60	77	
	40.0	362.710	0.520	2.33	2.33	98	6.0	90	60	78	
	50.0	371.480	0.520	2.33	2.33	95	6.0	90	60	78	
	60.0	380.320	0.520	2.33	2.33	95	6.0	90	60	80	
	70.0	389.800	0.520	2.33	2.33	93	6.0	90	60	79	
	80.0	397.480	0.520	2.33	2.33	93	6.0	90	60	79	
	90.0	406.120	0.520	2.33	2.33	93	6.0	90	60	80	
	100.0	414.750	0.520	2.33	2.33	93	6.0	90	60	81	
	110.0	423.320	0.520	2.33	2.33	93	6.0	90	60	82	
	120.0	431.900	0.520	2.33	2.33	94	6.0	90	60	85	
	130.0	440.480	0.550	2.47	2.47	94	6.0	90	60	82	
	140.0	449.500	0.550	2.47	2.47	93	6.0	90	60	79	
	150.0	458.190	0.550	2.47	2.47	92	6.0	90	60	79	
	FINAL 320/OFF	467.551									
	DIFF/AVG.	251.866	0.43331		1.954	96				79	0.085

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: C.S. Ohm, Detroit, Michigan

RUN	SAMPLING LOCATION	TEST TEAM LEADER		
1	Scrubber Inlet	Gerard M. Carty		
4	Scrubber Inlet	Gerard M. Carty		
7	Scrubber Inlet	Gerard M. Carty		
		1	4	7
	RUN DATE	06/18/85	06/19/85	06/20/85
	RUN START TIME	1005	839	856
	RUN FINISH TIME	1530	1405	1421
	NET SAMPLING POINTS	32	32	32
Theta	NET RUN TIME, MINUTES	320.00	320.00	320.00
Dia	NOZZLE DIAMETER, INCHES	0.252	0.252	0.252
Cp	PITOT TUBE COEFFICIENT	0.840	0.840	0.840
Y	DRY GAS METER CAL. FACTOR	0.999	0.999	0.999
Pbar	BAROMETRIC PRESSURE, IN. HG.	29.00	29.20	29.20
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H2O	2.010	1.897	1.964
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET	254.167	247.523	251.866
tm	DRY GAS METER TEMP., DEG. F	97	85	96
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*	234.388	234.821	234.253
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML	50.0	50.0	50.0
Vw(std)	VOLUME OF WATER VAPOR, SCF*	2.354	2.354	2.354
%H2O	MOISTURE, PERCENT BY VOLUME	1.0	1.0	1.0
Mfd	DRY MOLE FRACTION	0.990	0.990	0.990

(continued next page)



		1	4	7
Md	DRY MOLECULAR WT, LB/LB-MOLE	28.84	28.84	28.84
Ms	WET MOLECULAR WT, LB/LB-MOLE	28.73	28.73	28.73
Ps	GAS STATIC PRESS., IN. H2O	-2.0	-1.9	-2.0
P <sub>s</sub>	ABSOLUTE GAS PRESS., IN. HG.	28.85	29.06	29.06
t <sub>s</sub>	GAS TEMPERATURE, DEG. F	77	76	79
Delta P	AVG VELOCITY HEAD, IN. H2O	0.4321	0.4306	0.4333
v <sub>s</sub>	FLUE GAS VELOCITY, FT/SEC	38.0	37.8	38.0
A	STACK/DUCT AREA, SQUARE IN.	804.2	804.2	804.2
Q <sub>sd</sub>	GAS FLOW RATE, DRY SCFM *	11,947	11,980	11,983
Q <sub>aw</sub>	GAS FLOW RATE, WET ACFM	12,731	12,652	12,728
%I	PERCENT ISOKINETIC	98.7	98.6	98.4
	METHOD 5 RESULTS: **			
mg	CATCH, MILLIGRAMS	1.0	1.0	1.0
gr/DSCF	CONCEN., GRAINS PER DSCF*	0.0001	0.0001	0.0001
Lb/Hr	EMISSION RATE, LBS/HOUR	0.01	0.01	0.01
	HEXAVALENT CHROMIUM:			
	CATCH, MILLIGRAMS	(15.6)	(13.4)	(20.8)
	TOTAL CHROMIUM:			
	CATCH, MILLIGRAMS	(80.5)	(45.4)	(88.9)

\* 68 Deg. F - 29.92 in. Hg.

\*\* Efficiency run impinger catches were not gravimetrically analyzed for particulate determination. The value of 1.0 mg was entered for calculation purposes only and does not represent a true value.

( ) = x 10<sup>-3</sup>

RUN NUMBER	1	4	7	
<u>FLUE GAS TEMPERATURE:</u>				
Degrees Fahrenheit	77	76	79	des. F
Degrees Centigrade	25	24	26	des. C
<u>AIR FLOW RATES x million:</u>				
Actual Cubic Meters/hr	0.0216	0.0215	0.0216	acmh
Actual Cubic Feet/hr	0.7639	0.7591	0.7637	acfh
Dry Std. Cubic Meters/hr	0.0203	0.0204	0.0204	dscmh
Dry Std. Cubic Feet/hr	0.7168	0.7188	0.7190	dscfh
<u>PARTICULATE: **</u>				
Concentration, mg/dscm	0.151	0.150	0.151	mg/dscm
Concentration, gr/dscf	0.00007	0.00007	0.00007	gr/dscf
Emissions, kg/hr	0.003	0.003	0.003	kg/hr
Emissions, lb/hr	0.007	0.007	0.007	lb/hr
<u>HEXAVALENT CHROMIUM:</u>				
Concentration, mg/dscm	(2.350)	(2.015)	(3.136)	mg/dscm
Concentration, gr/dscf	(0.00103)	(0.00088)	(0.00137)	gr/dscf
Emissions, kg/hr	(0.048)	(0.041)	(0.064)	kg/hr
Emissions, lb/hr	(0.105)	(0.090)	(0.141)	lb/hr
<u>TOTAL CHROMIUM:</u>				
Concentration, mg/dscm	(12.129)	(6.828)	(13.402)	mg/dscm
Concentration, gr/dscf	(0.00530)	(0.00298)	(0.00586)	gr/dscf
Emissions, kg/hr	(0.246)	(0.139)	(0.273)	kg/hr
Emissions, lb/hr	(0.543)	(0.306)	(0.602)	lb/hr

\*\* Efficiency run impinger catches were not gravimetrically analyzed for particulate determination. The value of 1.0 mg was entered for calculation purposes only and does not represent a true value.

( ) = x 10<sup>-3</sup>

PLANT	C. S. Ohm	DATE	06/18/85
SAMPLING LOCATION	Scrubber Inlet	RUN NUMBER	2
GENERATOR	BB	PROBE LENGTH, ft.	4' 1"
BAR. PRESS., in. Hg	29.000	ASSUMED MOISTURE, %	2
STATIC PRESS., in. H2O	-2.000	NOZZLE #	405
FILTER NUMBER(S)	T025	NOZZLE DIAMETER, in.	0.257
TOT TUBE COEFF.	0.840	METER BOX ΔH@	1.58
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	25
LEAK TEST VACUUM, in.Hg	10.000	METER BOX NUMBER	N-14

Int. No.	Sample Time (Min.)	Gas Meter Reading (Du.Ft.)	Velocity Head (in.H2O)	Drift (in. H2O)	ΔH (Actual)	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
	00/0	515.500	0.350	1.53	1.53	90	5.0	95	60	62	
	10.0	522.810	0.350	1.53	1.53	94	5.0	92	60	65	
A2	20.0	530.060	0.400	1.75	1.75	98	5.0	92	60	66	
	30.0	538.050	0.400	1.75	1.75	100	6.0	92	60	66	
	40.0	545.720	0.520	2.28	2.28	102	7.0	90	60	76	
	50.0	554.440	0.520	2.28	2.28	105	7.0	90	60	76	
	60.0	564.000	0.340	1.49	1.49	103	5.0	90	60	79	
	70.0	571.750	0.340	1.49	1.49	100	5.0	90	60	80	
A5	80.0	579.500	0.370	1.62	1.62	98	5.0	90	60	79	
	90.0	585.600	0.370	1.62	1.62	100	5.0	90	60	78	
	100.0	593.210	0.430	1.88	1.88	100	6.0	90	60	79	
	110.0	601.360	0.430	1.88	1.88	102	6.0	90	60	79	
A7	120.0	609.700	0.430	1.88	1.88	102	6.0	90	60	82	
	130.0	618.110	0.430	1.88	1.88	103	6.0	92	60	80	
	140.0	626.650	0.430	1.88	1.88	104	6.0	92	60	80	
	150.0	634.310	0.430	1.88	1.88	104	6.0	92	60	80	
B1	160/0	642.534	0.250	1.10	1.10	100	5.0	90	60	75	642.534
	10.0	649.030	0.250	1.10	1.10	101	5.0	90	60	75	642.602
	20.0	655.380	0.250	1.10	1.10	100	5.0	90	60	78	
	30.0	661.710	0.250	1.10	1.10	100	5.0	90	60	76	
	40.0	668.160	0.250	1.10	1.10	100	5.0	90	60	75	
	50.0	674.420	0.250	1.10	1.10	100	5.0	90	60	73	
B4	60.0	680.900	0.320	1.40	1.40	100	5.0	90	60	80	
	70.0	688.510	0.320	1.40	1.40	100	5.0	90	60	82	
	80.0	695.090	0.450	1.97	1.97	100	6.0	90	60	80	
	90.0	704.000	0.450	1.97	1.97	100	6.0	90	60	80	
B6	100.0	711.900	0.550	2.41	2.41	102	7.0	90	60	80	
	110.0	721.150	0.550	2.41	2.41	103	7.0	90	60	82	
	120.0	731.200	0.550	2.41	2.41	104	7.0	90	60	81	
	130.0	739.850	0.550	2.41	2.41	104	7.0	90	60	78	
	140.0	749.250	0.500	2.19	2.19	104	7.0	90	60	80	
	150.0	758.000	0.500	2.19	2.19	104	7.0	90	60	80	
FINAL 320/OFF		766.885									
DIFF/AVG.		251.317	0.39302		1.749	101				77	0.058

PLANT	C. S. Ohm	DATE	06/19/85
SAMPLING LOCATION	Scrubber Inlet	RUN NUMBER	5
OPERATOR	BB	PROBE LENGTH, ft.	4' 1"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	2
STATIC PRESS., in. H2O	-1.900	NOZZLE #	405
FILTER NUMBER(S)		NOZZLE DIAMETER, in.	0.257
PITOT TUBE COEFF.	0.840	METER BOX ΔH@	1.68
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	25
LEAK TEST VACUUM, in.Hg	10.000	METER BOX NUMBER	N-14

Trav. Point No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O)	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
A-1	ON/O	757.202	0.370	1.52	1.62	68	5.0	90	60	75	
	10.0	774.550	0.370	1.52	1.62	76	5.0	90	60	75	
A-2	20.0	782.410	0.520	2.28	2.28	82	5.0	90	60	76	
	30.0	790.090	0.520	2.28	2.28	86	6.0	90	60	75	
A-3	40.0	799.600	0.520	2.28	2.28	86	6.0	90	60	74	
	50.0	808.310	0.480	2.10	2.10	86	6.0	90	60	79	
A-4	60.0	817.000	0.350	1.53	1.53	86	6.0	90	60	75	
	70.0	824.410	0.350	1.53	1.53	84	6.0	90	60	76	
A-5	80.0	831.800	0.350	1.53	1.53	84	6.0	90	60	76	
	90.0	839.150	0.350	1.53	1.53	84	6.0	90	60	76	
A-6	100.0	846.500	0.400	1.75	1.75	84	6.0	90	60	76	
	110.0	854.000	0.400	1.75	1.75	84	6.0	90	60	76	
A-7	120.0	862.500	0.400	1.75	1.75	86	6.0	90	60	76	
	130.0	869.920	0.400	1.75	1.75	86	6.0	90	60	77	
A-8	140.0	878.000	0.400	1.75	1.75	86	6.0	90	60	76	
	150.0	885.510	0.400	1.75	1.75	86	6.0	90	60	77	
B-1	160/O	893.500	0.220	0.96	0.96	84	4.0	90	60	68	893.500
	10.0	899.510	0.270	1.18	1.18	84	4.0	90	60	73	893.550
B-2	20.0	905.910	0.220	0.96	0.96	84	4.0	90	60	75	
	30.0	911.910	0.220	0.96	0.96	83	4.0	90	60	75	
B-3	40.0	917.900	0.220	0.96	0.96	82	4.0	90	60	73	
	50.0	924.600	0.220	0.96	0.96	82	4.0	90	60	74	
B-4	60.0	929.810	0.300	1.31	1.31	84	4.0	90	60	78	
	70.0	936.700	0.300	1.31	1.31	86	4.0	90	60	77	
B-5	80.0	943.570	0.370	1.62	1.62	84	5.0	90	60	77	
	90.0	951.100	0.370	1.62	1.62	82	5.0	90	60	79	
B-6	100.0	958.630	0.400	1.75	1.75	82	5.0	90	60	79	
	110.0	965.530	0.440	1.93	1.93	82	5.0	90	60	79	
B-7	120.0	974.850	0.570	2.50	2.50	83	6.0	90	60	79	
	130.0	984.150	0.570	2.50	2.50	84	6.0	90	60	79	
B-8	140.0	993.610	0.390	1.71	1.71	86	5.0	90	60	84	
	150.0	1001.370	0.390	1.71	1.71	86	5.0	90	60	84	
FINAL 320/OFF		1009.128									
DIFF/AVG.		241.876	0.37002		1.648	84				77	0.05

PLANT	C. S. Ohm	DATE	06/20/85
SAMPLING LOCATION	Scrubber Inlet	RUN NUMBER	8
GENERATOR	BB	PROBE LENGTH, ft.	4'1"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	2
STATIC PRESS., in. H2O	-2.000	NOZZLE #	405
FILTER NUMBER(S)	T-0.2-1	NOZZLE DIAMETER, in.	0.257
WET TUBE COEFF.	0.940	METER BOX ΔH@	1.57
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	25
LEAK TEST VACUUM, in.Hg	5.000	METER BOX NUMBER	N-5

Prov. Int. No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
	00/0	73.752	0.400	1.75	1.75	80	4.0	90	60	73	
	10.0	81.500	0.400	1.75	1.75	85	4.0	90	60	73	
A2	20.0	89.200	0.470	2.06	2.06	91	5.0	90	60	77	
	30.0	97.450	0.470	2.06	2.06	94	5.0	90	60	79	
	40.0	105.750	0.520	2.28	2.28	97	5.0	90	60	79	
	50.0	115.100	0.520	2.28	2.28	100	5.0	90	60	79	
	60.0	123.020	0.520	2.28	2.28	101	5.0	90	60	83	
	70.0	130.620	0.520	2.28	2.28	102	5.0	90	60	82	
A5	80.0	139.850	0.400	1.75	1.75	103	4.0	90	60	78	
	90.0	148.600	0.400	1.75	1.75	103	4.0	90	60	81	
	100.0	156.270	0.400	1.75	1.75	103	4.0	90	60	80	
	110.0	163.940	0.400	1.75	1.75	102	4.0	90	60	81	
A7	120.0	171.850	0.470	2.06	2.06	103	4.0	90	60	80	
	130.0	180.310	0.470	2.06	2.06	103	5.0	90	60	80	
	140.0	188.850	0.450	1.97	1.97	102	5.0	90	60	78	
	150.0	197.260	0.450	1.97	1.97	101	5.0	90	60	79	
B1	160/0	205.688	0.370	1.62	1.62	97	4.0	90	60	74	205.688
	10.0	213.410	0.250	1.10	1.10	98	4.0	90	60	70	205.736
B2	20.0	220.000	0.250	1.10	1.10	96	4.0	90	60	76	
	30.0	226.500	0.250	1.10	1.10	95	3.0	90	60	77	
	40.0	233.000	0.250	1.10	1.10	94	3.0	90	60	78	
	50.0	239.500	0.250	1.10	1.10	91	3.0	90	60	78	
B4	60.0	245.850	0.300	1.31	1.31	90	3.0	90	60	80	
	70.0	252.250	0.300	1.31	1.31	88	3.0	90	60	79	
	80.0	259.120	0.400	1.75	1.75	89	4.0	90	60	79	
	90.0	267.060	0.400	1.75	1.75	90	4.0	90	60	80	
B6	100.0	275.020	0.550	2.41	2.41	90	5.0	90	60	81	
	110.0	284.080	0.550	2.41	2.41	91	5.0	90	60	82	
	120.0	293.100	0.570	2.49	2.49	92	5.0	90	60	85	
	130.0	302.300	0.570	2.49	2.49	94	5.0	90	60	82	
	140.0	311.510	0.500	2.19	2.19	93	5.0	90	60	79	
	150.0	319.990	0.500	2.19	2.19	92	5.0	90	60	79	
FINAL 320/OFF		328.829									
DIFF/AVG.		255.029	0.41599		1.851	95				79	0.048

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: C.S. Ohm, Detroit, Michigan

RUN	SAMPLING LOCATION	TEST TEAM LEADER		
2	Scrubber Inlet	Gerard M. Carty		
5	Scrubber Inlet	Gerard M. Carty		
8	Scrubber Inlet	Gerard M. Carty		
		2	5	8
	RUN DATE	06/18/85	06/19/85	06/20/85
	RUN START TIME	1004	838	855
	RUN FINISH TIME	1529	1404	1420
	NET SAMPLING POINTS	32	32	32
Theta	NET RUN TIME, MINUTES	320.00	320.00	320.00
Dia	NOZZLE DIAMETER, INCHES	0.257	0.257	0.257
Cp	PITOT TUBE COEFFICIENT	0.840	0.840	0.840
Y	DRY GAS METER CAL. FACTOR	1.000	1.000	1.011
Pbar	BAROMETRIC PRESSURE, IN. HG.	29.00	29.20	29.20
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H <sub>2</sub> O	1.749	1.648	1.851
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET	251.317	241.876	255.029
tm	DRY GAS METER TEMP., DEG. F	101	84	95
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*	230.186	229.972	240.408
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML	37.2	65.3	62.2
Vw(std)	VOLUME OF WATER VAPOR, SCF*	1.751	3.074	2.928
%H <sub>2</sub> O	MOISTURE, PERCENT BY VOLUME	0.8	1.3	1.2
Mfd	DRY MOLE FRACTION	0.992	0.987	0.988

(continued next page)

		2	5	8
Md	DRY MOLECULAR WT, LB/LB-MOLE	28.84	28.84	28.84
Ms	WET MOLECULAR WT, LB/LB-MOLE	28.75	28.69	28.71
Ps	GAS STATIC PRESS., IN. H2O	-2.0	-1.9	-2.0
Ps	ABSOLUTE GAS PRESS., IN. HG.	28.85	29.06	29.05
ts	GAS TEMPERATURE, DEG. F	77	77	79
Delta P	AVG VELOCITY HEAD, IN. H2O	0.3930	0.3700	0.4159
vs	FLUE GAS VELOCITY, FT/SEC	36.2	35.1	37.2
A	STACK/DUCT AREA, SQUARE IN.	804.2	804.2	804.2
Qsd	GAS FLOW RATE, DRY SCFM *	11,416	11,065	11,719
Qaw	GAS FLOW RATE, WET ACFM	12,136	11,746	12,475
%I	PERCENT ISOKINETIC	97.6	100.6	99.2
	METHOD 5 RESULTS:			
ms	CATCH, MILLIGRAMS	8.3	1.3	6.7
gr/DSCF	CONCEN., GRAINS PER DSCF*	0.0006	0.0001	0.0004
Lb/Hr	EMISSION RATE, LBS/HOUR	0.05	0.01	0.04
	HEXAVALENT CHROMIUM:			
	CATCH, MILLIGRAMS	(0.8)	(2.8)	(4.2)
	TOTAL CHROMIUM:			
	CATCH, MILLIGRAMS	(3.5)	(10.8)	(16.2)

\* 68 Deg. F - 29.92 in. Hg.

( ) = x 10<sup>-3</sup>

RUN NUMBER	2	5	8	
<u>FLUE GAS TEMPERATURE:</u>				
Degrees Fahrenheit	77	77	79	deg. F
Degrees Centigrade	25	25	26	deg. C
<u>AIR FLOW RATES x million:</u>				
Actual Cubic Meters/hr	0.0206	0.0200	0.0212	acmh
Actual Cubic Feet/hr	0.7282	0.7048	0.7485	acfh
Dry Std. Cubic Meters/hr	0.0194	0.0188	0.0199	dscmh
Dry Std. Cubic Feet/hr	0.6850	0.6639	0.7032	dscfh
<u>PARTICULATE:</u>				
Concentration, mg/dscm	1.273	0.200	0.984	mg/dscm
Concentration, gr/dscf	0.00056	0.00009	0.00043	gr/dscf
Emissions, kg/hr	0.025	0.004	0.020	kg/hr
Emissions, lb/hr	0.054	0.008	0.043	lb/hr
<u>HEXAVALENT CHROMIUM:</u>				
Concentration, mg/dscm	(0.123)	(0.430)	(0.617)	mg/dscm
Concentration, gr/dscf	(0.00005)	(0.00019)	(0.00027)	gr/dscf
Emissions, kg/hr	(0.002)	(0.008)	(0.012)	kg/hr
Emissions, lb/hr	(0.005)	(0.018)	(0.027)	lb/hr
<u>TOTAL CHROMIUM:</u>				
Concentration, mg/dscm	(0.537)	(1.658)	(2.380)	mg/dscm
Concentration, gr/dscf	(0.00023)	(0.00072)	(0.00104)	gr/dscf
Emissions, kg/hr	(0.010)	(0.031)	(0.047)	kg/hr
Emissions, lb/hr	(0.023)	(0.069)	(0.104)	lb/hr

( ) = x 10<sup>-3</sup>



EXAMPLE PARTICULATE TEST CALCULATIONS NO. 2

Scrubber Inlet

VOLUME OF DRY GAS SAMPLED AT STANDARD CONDITIONS

---

$$V_m(\text{std}) = 17.64 * Y * V_m * \frac{(P_{\text{bar}} + \Delta H/13.6)}{(460 + t_m)}$$

$$V_m(\text{std}) = 17.64 * 1.000 * 251.317 * \frac{(29.00 + 1.749/13.6)}{(460 + 101)} = 230.186 \text{ DSCF}$$

VOLUME OF WATER VAPOR AT STANDARD CONDITIONS

---

$$V_w(\text{std}) = 0.04707 * V_{1c}$$

$$V_w(\text{std}) = 0.04707 * 37.2 = 1.751 \text{ SCF}$$

PERCENT MOISTURE, BY VOLUME, AS MEASURED IN FLUE GAS

---

$$\%H_2O = 100 * V_w(\text{std}) / (V_w(\text{std}) + V_m(\text{std}))$$

$$\%H_2O = \frac{1.751}{1.751 + 230.186} * 100 = 0.8 \%$$

DRY MOLE FRACTION OF FLUE GAS

---

$$M_{fd} = 1 - \%H_2O/100$$

$$M_{fd} = 1 - 0.8/100 = 0.992$$

WET MOLECULAR WEIGHT OF FLUE GAS

---

$$M_s = (M_d * M_{fd}) + (0.18 * \%H_2O)$$

$$M_s = 28.84 * 0.992 + (0.18 * 0.8) = 28.75 \text{ LB/LB-MOLE}$$

ABSOLUTE FLUE GAS PRESSURE

---

$$P_s = P_{bar} + P_g / 13.6$$

$$P_s = 29.00 + (-2.0 / 13.6) = 28.85 \text{ IN. HG.}$$

AVERAGE FLUE GAS VELOCITY [Note: (Delta P)avg is square of avg sq. root]

---

$$v_s = 85.49 * C_p * \text{SQRT} \left[ \frac{(\Delta P)_{avg} * (460 + t_s)}{P_s * M_s} \right]$$

$$v_s = 85.49 * 0.840 * \text{SQRT} \left[ \frac{0.3930 * (460 + 77)}{28.85 * 28.75} \right] = 36.2 \text{ FT/SEC}$$

DRY VOLUMETRIC FLUE GAS FLOW RATE @ STANDARD CONDITIONS

---

$$Q_{sd} = \frac{60}{144} * M_{fd} * v_s * A * \frac{T_{std}}{t_s + 460} * \frac{P_s}{P_{std}}$$

$$Q_{sd} = \frac{60}{144} * 0.992 * 36.2 * 804.2 * \frac{528}{77 + 460} * \frac{28.85}{29.92}$$

$$Q_{sd} = 11,416 \text{ SCFM}$$

WET VOLUMETRIC STACK GAS FLOW RATE @ FLUE GAS CONDITIONS

---

$$Q_{aw} = 60 / 144 * v_s * A$$

$$Q_{aw} = 60 / 144 * 36.2 * 804.2 = 12,136 \text{ ACFM}$$

PERCENT ISOKINETIC OF SAMPLING RATE

---

$$\%I = \frac{P_{std}}{T_{std}} * \frac{100}{60} * \frac{(t_s + 460) * V_m(std)}{P_s * v_s * M_{fd} * \text{Theta} * \text{Area-nozzle, sq.ft.}}$$

$$\%I = \frac{29.92}{528} * \frac{100}{60} * \frac{(77 + 460) * 230.186}{28.85 * 36.2 * 0.992 * 320.00 * 0.0003602}$$

$$\%I = 97.6 \%$$

GRAINS PER DRY STANDARD CUBIC FOOT

$$\text{gr/DSCF} = \frac{7000}{453,592} * \frac{\text{mgs}}{V_m(\text{std})}$$

$$\text{gr/DSCF} = \frac{7000}{453,592} * \frac{8.3}{230.186} = 0.0006 \text{ gr/DSCF}$$

POUNDS PER HOUR

$$\text{Lb/Hr} = 60 / 7000 * \text{gr/DSCF} * Q_{sd}$$

$$\text{Lb/Hr} = 60/7000 * 0.0006 * 11,416 = 0.05 \text{ LB/HR}$$

PLANT C. S. Ohm  
 SAMPLING LOCATION Scrubber Outlet Stack  
 OPERATOR BB  
 BAR. PRESS., in. Hg 29.000  
 STATIC PRESS., in. H2O -0.380  
 FILTER NUMBER(S) T-0.252  
 PITOT TUBE COEFF. 0.840  
 LEAK RATE, CFM 0.000  
 LEAK TEST VACUUM, in.Hg 13.000

DATE 05/18/85  
 RUN NUMBER 3  
 PROBE LENGTH, ft. 5'3"  
 ASSUMED MOISTURE, % 3  
 NOZZLE # 407  
 NOZZLE DIAMETER, in. 0.309  
 METER BOX ΔH@ 1.51  
 SAMPLE BOX NUMBER 19  
 METER BOX NUMBER N-8

Trav. Point. No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
A-1	ON/O	687.800	0.950	7.95	7.10	70	12.0	100	63	66	
A-2	12.0	705.180	0.670	5.60	5.60	90	9.0	100	60	67	
A-3	24.0	722.750	0.440	3.68	3.68	88	5.0	100	61	66	
A-4	36.0	736.260	0.270	2.26	2.26	85	4.0	100	61	66	
A-5	48.0	746.950	0.150	1.25	1.25	80	1.0	100	66	66	
A-6	60.0	750.330	0.280	2.34	2.34	78	1.0	100	65	66	
B-1	72/O	766.705	0.530	4.43	4.43	79	6.0	100	63	66	
B-2	12.0	781.460	0.500	4.18	4.18	82	6.0	100	60	68	
B-3	24.0	795.860	0.260	2.17	2.17	83	3.0	100	60	68	
B-4	36.0	806.330	0.080	0.67	0.67	79	1.0	100	60	68	
B-5	45.0	812.330	0.060	0.50	0.50	79	1.0	100	60	68	825.590
B-6	68.0	817.450	0.210	1.76	1.76	79	1.0	100	60	71	825.700
C-1	144/O	825.590	0.450	3.76	3.76	79	5.0	100	60	71	
C-2	12.0	840.300	0.730	6.11	6.11	83	9.0	100	60	68	
C-3	24.0	857.530	0.360	3.01	3.01	84	5.0	100	60	71	
C-4	36.0	869.820	0.100	0.84	0.84	83	1.0	100	60	70	
C-5	48.0	876.580	0.070	0.59	0.59	82	1.0	100	60	68	
C-6	60.0	880.250	0.290	2.43	2.43	81	1.0	100	60	68	
D-1	216/O	893.139	0.370	3.09	3.09	80	5.0	100	60	68	
D-2	12.0	905.140	0.550	4.60	4.60	84	6.0	100	60	68	
D-3	24.0	920.200	0.700	5.85	5.85	85	8.0	100	60	68	
D-4	36.0	937.150	0.470	3.93	3.93	88	6.0	100	60	69	
D-5	48.0	951.040	0.420	3.51	3.51	86	5.0	100	60	69	
D-6	60.0	964.260	0.490	4.10	4.10	85	6.0	100	60	69	
FINAL 298/OFF		978.482									
DIFF / AVG.		290.572	0.35444		3.240	82				68	0.11

PLANT	C. S. Ohm	DATE	06/19/85
SAMPLING LOCATION	Scrubber Outlet Stack	RUN NUMBER	5
OPERATOR	BB	PROBE LENGTH, ft.	5'3"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	3
STATIC PRESS., in. H2O	-0.370	NOZZLE #	407
FILTER NUMBER(S)	T-0.253	NOZZLE DIAMETER, in.	0.309
WET TUBE COEFF.	0.940	METER BOX ΔH@	1.51
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	19
LEAK TEST VACUUM, in.Hg	12.000	METER BOX NUMBER	N-8

Prov. Int. No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
1	00/0	979.100	0.900	7.53	7.10	71	11.0	90	55	62	
2	12.0	997.700	0.570	5.60	5.60	88	8.0	95	59	64	
A-3	24.0	1014.400	0.450	3.76	3.76	80	6.0	95	60	66	
4	36.0	27.910	0.290	2.34	2.34	75	4.0	97	61	67	
5	48.0	38.610	0.170	1.42	1.42	71	1.0	98	62	66	
A-6	60.0	46.880	0.290	2.43	2.43	71	4.0	99	62	66	
B-1	72/0	57.765	0.540	4.52	4.52	71	7.0	100	62	67	
2	12.0	72.600	0.460	3.85	3.85	82	6.0	100	62	67	
3	24.0	86.330	0.260	2.17	2.17	86	4.0	100	62	68	
B-4	36.0	96.770	0.090	0.75	0.75	76	1.0	100	62	67	
5	48.0	103.200	0.070	0.58	0.58	72	1.0	100	62	68	
6	60.0	103.760	0.210	1.76	1.76	71	3.0	100	62	67	
C-1	144/0	117.979	0.420	3.51	3.51	70	5.0	100	62	67	117.979
C-2	12.0	131.240	0.700	5.85	5.85	74	9.0	100	62	67	118.100
3	24.0	147.870	0.360	1.89	1.89	75	2.0	100	61	68	
4	36.0	157.480	0.100	0.83	0.83	73	1.0	100	61	68	
C-5	48.0	164.120	0.070	0.58	0.58	71	1.0	100	61	68	
6	60.0	169.620	0.290	2.43	2.43	73	4.0	100	61	71	
1	216/0	180.566	0.370	3.09	3.09	75	5.0	100	61	72	
D-2	12.0	193.120	0.520	4.35	4.35	79	6.0	100	61	72	
D-3	24.0	207.680	0.700	5.85	5.85	80	9.0	100	61	72	
4	36.0	224.520	0.500	4.18	4.18	83	6.0	100	60	71	
5	48.0	238.850	0.380	3.18	3.18	81	5.0	100	60	72	
D-6	60.0	251.440	0.460	3.85	3.85	82	6.0	100	60	71	
FINAL 288/OFF		1265.287									
OFF/AVG.		285.066	0.35183		3.161	76				68	0.121

PLANT	C. S. Ohm	DATE	06/20/95
SAMPLING LOCATION	Scrubber Outlet Stack	RUN NUMBER	9
OPERATOR	BB	PROBE LENGTH, ft.	5'3"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	3
STATIC PRESS., in. H2O	-0.250	NOZZLE #	407
FILTER NUMBER(S)	T-0.251	NOZZLE DIAMETER, in.	0.309
PITOT TUBE COEFF.	0.940	METER BOX ΔH@	1.51
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	19
LEAK TEST VACUUM, in.Hg	12.000	METER BOX NUMBER	N-3

Trav. Point. No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
A-1	00/0	284.100	0.940	7.86	6.80	75	12.0	100	66	71	
A-2	12.0	302.120	0.650	5.44	5.44	88	9.0	100	64	71	
A-3	24.0	318.390	0.410	3.43	3.43	87	6.0	100	63	71	
A-4	36.0	331.270	0.280	2.34	2.34	82	4.0	100	62	71	
A-5	48.0	341.950	0.160	1.34	1.34	82	2.0	100	62	71	
A-6	60.0	350.060	0.310	2.59	2.59	83	5.0	100	62	72	
B-1	72/0	361.440	0.540	4.52	4.52	84	7.0	100	62	73	
B-2	12.0	376.320	0.480	4.01	4.01	84	7.0	100	62	72	
B-3	24.0	390.430	0.260	2.17	2.17	85	4.0	100	62	73	
B-4	36.0	400.360	0.100	0.84	0.84	82	1.0	100	62	74	
B-5	48.0	407.570	0.080	0.67	0.67	81	1.0	100	62	74	
B-6	60.0	413.620	0.230	1.92	1.92	80	4.0	100	62	74	
C-1	144/0	423.462	0.420	3.51	3.51	79	6.0	100	62	72	423.462
C-2	12.0	436.830	0.690	5.77	5.77	84	10.0	100	62	73	423.500
C-3	24.0	453.650	0.350	2.93	2.93	86	5.0	100	62	72	
C-4	36.0	465.660	0.080	0.67	0.67	82	1.0	100	62	72	
C-5	48.0	471.790	0.060	0.50	0.50	81	1.0	100	62	74	
C-6	60.0	476.860	0.280	2.34	2.34	82	4.0	100	62	73	
D-1	216/0	487.240	0.350	2.93	2.93	82	5.0	100	65	74	
D-2	12.0	499.330	0.500	4.18	4.18	82	7.0	100	67	70	
D-3	24.0	513.840	0.700	5.85	5.85	85	9.0	100	64	71	
D-4	36.0	530.820	0.500	4.18	4.18	88	7.0	100	65	71	
D-5	48.0	545.040	0.440	3.68	3.68	85	6.0	102	66	71	
D-6	60.0	556.220	0.480	4.01	4.01	85	7.0	102	66	70	
FINAL 298/OFF		572.682									
DIFF/AVG.		298.444	0.35225		3.192	83				72	0.138

PARTICULATE FIELD DATA & RESULTS TABULATION

PLANT: C.S. Ohm, Detroit, Michigan

RUN	SAMPLING LOCATION	TEST TEAM LEADER		
3	Scrubber Outlet	Henry B. Lons		
6	Scrubber Outlet	Henry B. Lons		
9	Scrubber Outlet	Henry B. Lons		
		3	6	9
	RUN DATE	06/18/85	06/19/85	06/20/85
	RUN START TIME	1003	837	855
	RUN FINISH TIME	1505	1336	1350
	NET SAMPLING POINTS	24	24	24
Theta	NET RUN TIME, MINUTES	288.00	288.00	288.00
Dia	NOZZLE DIAMETER, INCHES	0.309	0.309	0.309
Cp	PITOT TUBE COEFFICIENT	0.840	0.840	0.840
Y	DRY GAS METER CAL. FACTOR	0.998	0.998	0.998
Fbar	BAROMETRIC PRESSURE, IN. HG.	29.00	29.20	29.20
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H <sub>2</sub> O	3.240	3.161	3.193
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET	290.572	286.066	288.444
tm	DRY GAS METER TEMP., DEG. F	82	76	83
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*	275.953	276.540	275.266
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML	85.1	103.3	104.6
Vw(std)	VOLUME OF WATER VAPOR, SCF*	4.006	4.862	4.924
%H <sub>2</sub> O	MOISTURE, PERCENT BY VOLUME	1.4	1.7	1.8
Mfd	DRY MOLE FRACTION	0.986	0.983	0.982

(continued next page)

		3	6	9
Md	DRY MOLECULAR WT, LB/LB-MOLE	28.84	28.84	28.84
Ms	WET MOLECULAR WT, LB/LB-MOLE	28.68	28.65	28.65
Ps	GAS STATIC PRESS., IN. H2O	-0.4	-0.4	-0.3
Fs	ABSOLUTE GAS PRESS., IN. HG.	28.97	29.17	29.18
ts	GAS TEMPERATURE, DEG. F	68	68	72
Delta P	AVG VELOCITY HEAD, IN. H2O	0.3544	0.3518	0.3523
vs	FLUE GAS VELOCITY, FT/SEC	34.1	33.9	34.0
A	STACK/DUCT AREA, SQUARE IN.	921.0	921.0	921.0
Qsd	GAS FLOW RATE, DRY SCFM *	12,477	12,443	12,404
Qaw	GAS FLOW RATE, WET ACFM	13,077	12,992	13,049
%I	PERCENT ISOKINETIC	94.2	94.6	94.5
	METHOD 5 RESULTS: **			
ms	CATCH, MILLIGRAMS	1.0	4.1	1.0
sr/DSCF	CONCEN., GRAINS PER DSCF*	0.0001	0.0002	0.0001
Lb/Hr	EMISSION RATE, LBS/HOUR	0.01	0.02	0.01
	HEXAVALENT CHROMIUM:			
	CATCH, MILLIGRAMS	(2.1)	(2.7)	(3.2)
	TOTAL CHROMIUM:			
	CATCH, MILLIGRAMS	(18.8)	(14.3)	(14.8)

\* 68 Deg. F - 29.92 in. Hg.

\*\* Particulate catches for run Nos. 3 and 9 were not quantifiable. The value of 1.0 mg was entered for calculation purposes only and does not represent a true value.

( ) =  $\times 10^{-3}$



RUN NUMBER	3	6	9	
<u>FLUE GAS TEMPERATURE:</u>				
Degrees Fahrenheit	68	68	72	deg. F
Degrees Centigrade	20	20	22	deg. C
<u>AIR FLOW RATES x million:</u>				
Actual Cubic Meters/hr	0.0222	0.0221	0.0222	acmh
Actual Cubic Feet/hr	0.7846	0.7795	0.7829	acfh
Dry Std. Cubic Meters/hr	0.0212	0.0211	0.0211	dscmh
Dry Std. Cubic Feet/hr	0.7486	0.7466	0.7443	dscfh
<u>PARTICULATE: **</u>				
Concentration, mg/dscm	0.128	0.524	0.128	mg/dscm
Concentration, gr/dscf	0.00006	0.00023	0.00006	gr/dscf
Emissions, kg/hr	0.003	0.011	0.003	kg/hr
Emissions, lb/hr	0.006	0.024	0.006	lb/hr
<u>HEXAVALENT CHROMIUM:</u>				
Concentration, mg/dscm	(0.269)	(0.345)	(0.411)	mg/dscm
Concentration, gr/dscf	(0.00012)	(0.00015)	(0.00018)	gr/dscf
Emissions, kg/hr	(0.006)	(0.007)	(0.009)	kg/hr
Emissions, lb/hr	(0.013)	(0.016)	(0.019)	lb/hr
<u>TOTAL CHROMIUM:</u>				
Concentration, mg/dscm	(2.406)	(1.826)	(1.899)	mg/dscm
Concentration, gr/dscf	0.00105	0.00080	0.00083	gr/dscf
Emissions, kg/hr	0.051	0.039	0.040	kg/hr
Emissions, lb/hr	0.112	0.085	0.088	lb/hr

\*\* Particulate catches for run Nos. 3 and 9 were not quantifiable. The value of 1.0 mg was entered for calculation purposes only and does not represent a true value.

( ) =  $\times 10^{-3}$

PLANT	C. S. Ohm	DATE	06/19/85
SAMPLING LOCATION	Scrubber inlet	RUN NUMBER	SPECIAL
OPERATOR	BB	PROBE LENGTH, ft.	4'4"
BAR. PRESS., in. Hg	29.200	ASSUMED MOISTURE, %	3
STATIC PRESS., in. H2O	-1.900	NOZZLE #	711
FILTER NUMBER(S)	T-0.2-2	NOZZLE DIAMETER, in.	0.354
PITOT TUBE COEFF.	0.940	METER BOX ΔH@	1.58
LEAK RATE, CFM	0.000	SAMPLE BOX NUMBER	2
LEAK TEST VACUUM, in.Hg	12.000	METER BOX NUMBER	N-14

Trav. Point No.	Sample Time (Min.)	Gas Meter Reading (Cu.Ft.)	Velocity Head (in.H2O)	Orifice (in. H2O) Desired	ΔH Actual	Gas Meter Temp. (deg. F)	Pump Vac. (in.Hg)	Filter Box Temp. (deg.F)	Imp. Exit Temp. (deg.F)	Stack Temp. (deg.F)	Leak Check
A5	0N/0	10.132	0.350	5.40	6.40	80	11.0	90	60	79	
	508.0	624.935	0.370	2.60	2.60	110	5.0	130	35	78	
DIFF / AVG.		614.803	0.35993		4.500	95				79	

## PARTICULATE FIELD DATA &amp; RESULTS TABULATION

PLANT: C.S. Ohm, Detroit, Michigan

<u>RUN</u>	<u>SAMPLING LOCATION</u>	<u>TEST TEAM LEADER</u>
SR	Scrubber Inlet	Robert W. Bridges
		<u>SR</u>
	RUN DATE	06/19/85
	RUN START TIME	1419
	RUN FINISH TIME	2247
	NET SAMPLING POINTS	2
Theta	NET RUN TIME, MINUTES	508.00
Dia	NOZZLE DIAMETER, INCHES	0.364
Cp	PITOT TUBE COEFFICIENT	0.840
Y	DRY GAS METER CAL. FACTOR	1.000
Pbar	BAROMETRIC PRESSURE, IN. HG.	29.20
Delta H	AVG. PRESS. DIFFERENTIAL OF ORIFICE METER, IN. H <sub>2</sub> O	4.500
Vm	VOLUME OF METERED GAS SAMPLE DRY ACTUAL CUBIC FEET	614.803
tm	DRY GAS METER TEMP., DEG. F	95
Vm(std)	VOLUME OF METERED GAS SAMPLE @ DRY STD. COND., DSCF*	577.057
Vlc	VOLUME OF WATER CATCH IN IMPINGERS & SIL. GEL., ML	27.6
Vw(std)	VOLUME OF WATER VAPOR, SCF*	1.299
%H <sub>2</sub> O	MOISTURE, PERCENT BY VOLUME	0.2
Mfd	DRY MOLE FRACTION	0.998

(continued next page)

		SR
Md	DRY MOLECULAR WT, LB/LB-MOLE	28.84
Ms	WET MOLECULAR WT, LB/LB-MOLE	28.81
Ps	GAS STATIC PRESS., IN. H2O	-1.9
Ps	ABSOLUTE GAS PRESS., IN. HG.	29.06
ts	GAS TEMPERATURE, DEG. F	79
Delta P	AVG VELOCITY HEAD, IN. H2O	0.3599
vs	FLUE GAS VELOCITY, FT/SEC	34.6
A	STACK/DUCT AREA, SQUARE IN.	804.2
Qsd	GAS FLOW RATE, DRY SCFM *	10,991
Qaw	GAS FLOW RATE, WET ACFM	11,582
%I	PERCENT ISOKINETIC	79.8
METHOD 5 RESULTS:		
ms	CATCH, MILLIGRAMS	3.7
gr/DSCF	CONCEN., GRAINS PER DSCF*	0.0001
Lb/Hr	EMISSION RATE, LBS/HOUR	0.01
HEXAVALENT CHROMIUM:		
	CATCH, MILLIGRAMS	(5.9)
TOTAL CHROMIUM:		
	CATCH, MILLIGRAMS	(14.9)

\* 68 Deg. F - 29.92 in. Hg.

( ) =  $\times 10^{-3}$

RUN NUMBER

SR  
-----

FLUE GAS TEMPERATURE:

Degrees Fahrenheit	79	deg. F
Degrees Centigrade	26	deg. C

AIR FLOW RATES x million:

Actual Cubic Meters/hr	0.0197	acmh
Actual Cubic Feet/hr	0.6949	acfh
Dry Std. Cubic Meters/hr	0.0187	dscmh
Dry Std. Cubic Feet/hr	0.6595	dscfh

PARTICULATE:

Concentration, mg/dscm	0.226	mg/dscm
Concentration, gr/dscf	0.00010	gr/dscf
Emissions, kg/hr	0.004	kg/hr
Emissions, lb/hr	0.009	lb/hr

HEXAVALENT CHROMIUM:

Concentration, mg/dscm	(0.361)	mg/dscm
Concentration, gr/dscf	(0.00016)	gr/dscf
Emissions, kg/hr	(0.007)	kg/hr
Emissions, lb/hr	(0.015)	lb/hr

TOTAL CHROMIUM:

Concentration, mg/dscm	(0.912)	mg/dscm
Concentration, gr/dscf	(0.00040)	gr/dscf
Emissions, kg/hr	(0.017)	kg/hr
Emissions, lb/hr	(0.038)	lb/hr

( ) = x 10<sup>-3</sup>

TOTAL CHROMIUM ANALYSIS CALCULATION

(A) Sample No.	(B) Total Wt of Sample mg	(C) NAA Results of Cr µg	Cr Analysis of Sample				Cr Analysis of Residue						(M) Blank Value µg	(N) Cr In Sample Blank Corrected µg	(P) Cr Conc. µg/g
			(D) Wt of Sample Analyzed mg	(E) Aliquot Factor	(F) Cr In Sample w/Blank µg	(G) Wt of Residue Analyzed mg	(H) Aliquot Factor	(J) Cr In Sample Residue µg	(K) Cr+6 from Filtrate µg	(L) Cr In Sample w/Blank µg					
241	8.3	9.20				Total	1		9.20	<0.2	9.2	6.7	2.5	301.2	
242	1.3	13.27				Total	1		13.27	2.8	16.1	6.7	9.4	7,230.8	
243	6.7	18.74				Total	1		18.74	4.2	22.9	6.7	16.2	2,417.9	
244	3.7	15.65				Total	1		15.65	5.9	21.6	6.7	14.9	4,027.0	
245	•	23.44				Total	1		23.44	2.1	25.5	6.7	18.8	----	
246	4.1	18.27				Total	1		18.27	2.7	21.0	6.7	14.3	3,487.8	
247	*	18.31				Total	1		18.31	3.2	21.5	6.7	14.8	----	
248	Blank	5.56				Total	1		5.56	1.1	6.7	---	----	----	
249	Total	1.12				Half	2		2.24	0.8	3.0	2.0	1.0	----	
250	Total	1.68				Half	2		3.36	<0.2	3.4	2.0	1.4	----	
251	Total	0.60				Half	2		1.20	<0.2	1.2	2.0	----	----	
252	Total	0.94				Half	2		1.88	<0.2	1.9	2.0	----	----	
253	Total	0.84				Half	2		1.68	<0.2	1.7	2.0	----	----	
254	Total	0.72				Half	2		1.44	<0.2	1.4	2.0	----	----	
255	Total	30.89				Half	2		61.78	15.6	82.5	2.0	80.5	----	
256	Total	1.28				Half	2		2.56	<0.2				----	
257	Total	1.13				Half	2		2.26	<0.2				----	
258	Total	13.67				Half	2		27.34	13.2	47.4	2.0	45.4	----	
259	Total	1.41				Half	2		2.82	<0.2				----	
260	Total	2.03				Half	2		4.06	0.2				----	
261	Total	26.15				Half	2		52.30	19.4	90.9	2.0	88.9	----	
262	Total	4.07				Half	2		8.14	0.7				----	
263	Total	4.83				Half	2		9.66	0.7				----	
264	Blank	0.99				Half	2		1.98	<0.2	2.0	---	----	12.7 µg/ml	
265	1 mL	12.69			1	Half	2	12.7				---	12.7	----	
267	Total	0.79				Half	2		1.58	<0.2	1.6	2.0	----	----	

\*Particulate catch was not quantifiable.

EXPLANATION OF TOTAL CHROMIUM ANALYSIS CALCULATION TABLE

Column


- A (Sample Number) - Used to identify samples transferred to RTI and NCSU for hexavalent and total chromium analysis. Samples are identified on the Request for Analysis sheets in Appendix B.
- B (Total Weight of Sample in mg) - Given for Method 5 and particle sizing samples (filters and catch or precutter contents). Taken from Particulate Sampling Laboratory Results and Particle Sizing Laboratory Data found in Appendix B.
- C (NAA Results for Cr in  $\mu\text{g}$ ) - Reported results for total chromium in the sample. Taken from computer printout of results found in Appendix B.
- D (Weight of Sample Analyzed in mg) - If only a portion of the total sample was taken for NAA, the weight was recorded here. This weight was taken from the Sample Preparation and Analysis Data Form which is transferred with the samples for NAA (found in Appendix B).
- E (Aliquot Factor) - The ratio of the total weight of the sample to amount of sample analyzed; should be 1 in all cases.
- F (Cr in Sample with Blank in  $\mu\text{g}$ ) - Total chromium in sample as measured by NAA; blank value, if any, has not been subtracted out. Results are taken from computer printout in Appendix B or Column C of this table.
- G (Weight of Residue Analyzed in mg) - In some cases (i.e., Method 5, particle size, and some impinger samples), the hexavalent chromium was first extracted from the sample before it was submitted for NAA. The remainder of the sample following the hexavalent chromium extraction is termed the "residue." This column gives the weight of the residue analyzed and is taken from the Sample Preparation and Analysis Data Form found in Appendix B.
- H (Aliquot Factor) - The ratio of the total weight of the sample to the amount of residue analyzed. This number multiplied by the total chromium results yields the total chromium in the sample residue.
- J (Cr in Sample Residue in  $\mu\text{g}$ ) - Total chromium content of the sample residue calculated by multiplying the total chromium results by NAA (column C) times the aliquot factor (column H). Thus,  $H \times C = J$ .
- K ( $\text{Cr}^{+6}$  in the Filtrate in  $\mu\text{g}$ ) - Amount of hexavalent chromium in the filtrate extracted from the sample. This value must be added to the total chromium measured by NAA to get the total chromium in the sample. The hexavalent chromium value is taken from the Wet Chemical Analysis Sheets found in Appendix B.
- L (Cr in Sample with Blank in  $\mu\text{g}$ ) - Total chromium in sample; blank value, if any, has not been subtracted out. This value is the sum of the hexavalent chromium in the sample filtrate (column K) and the total chromium in the sample residue (column J). Thus,  $K + J = L$ .
- M (Blank Value in  $\mu\text{g}$ ) - Total chromium value for the appropriate sample blank, if any.
- N (Cr in Sample, Blank Corrected in  $\mu\text{g}$ ) - Total chromium in sample with value of sample blank, if any, subtracted out. Thus,  $L - M = N$ .
- P (Cr Concentration in  $\mu\text{g}/\text{g}$ ) - Chromium concentration in sample calculated by dividing the total chromium content of the sample by the sample weight:  
 $N \div B = P$  or  $N \div D = P$ .

APPENDIX B.  
FIELD AND ANALYTICAL DATA



# Preliminary Field Data

PLANT NAME <u>C.S. OHM</u>	
LOCATION <u>DETROIT, MICH</u>	
SAMPLING LOCATION <u>SCRUBBER INLET</u>	
DUCT DEPTH	
FROM INSIDE FAR WALL TO OUTSIDE OF PORT	<u>32 1/4"</u>
NIPPLE LENGTH	
	<u>1/4"</u>
DEPTH OF DUCT	
	<u>32"</u>
WIDTH (RECTANGULAR DUCT)	
EQUIVALENT DIAMETER:	
$D_E = \frac{2 \times \text{DEPTH} \times \text{WIDTH}}{\text{DEPTH} + \text{WIDTH}} = \frac{2( \quad )( \quad )}{( \quad + \quad )} = \underline{\hspace{2cm}}$	
DISTANCE FROM PORTS <u>UPSTREAM</u> <u>DOWNSTREAM</u>	
TO NEAREST FLOW DISTURBANCE:	FEET <u>14' = 168"</u> <u>2' = 26"</u>
STACK DIAMETERS <u>5.25</u> <u>0.81</u>	
STACK AREA = $(\frac{32}{2})^2 \pi =$ <u>804.28</u> $\text{IN}^2$	



Point	% OF DIAMETER	DISTANCE FROM INSIDE WALL	DISTANCE FROM OUTSIDE OF PORT
1	3.2	1"	1 1/4
2	10.5	3 3/8	3 5/8
3	19.4	6 1/4	6 1/2
4	32.3	10 3/8	10 5/8
5	47.7	21 5/8	21 1/8
6	60.6	25 3/4	26
7	79.5	28 5/8	28 7/8
8	96.8	30 3/4	31 1/4
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			

LOCATION OF TRAVERSE POINTS IN CIRCULAR STACKS

	4	6	8	10	12	14	16	18	20	22	24
1	6.7	4.4	3.2	2.6	2.1	1.8	1.6	1.4	1.3	1.1	1.1
2	25.0	14.6	10.5	8.2	6.7	5.7	4.9	4.4	3.9	3.5	3.2
3	75.0	29.8	19.4	14.6	11.9	9.9	8.5	7.5	6.7	6.0	5.5
4	93.3	70.4	32.3	22.6	17.7	14.6	12.5	10.9	9.7	8.7	7.9
5		85.4	67.7	34.2	25.0	20.1	16.9	14.6	12.9	11.6	10.5
6		95.4	80.6	65.8	35.6	26.9	22.0	18.0	16.5	14.6	13.2
7			89.5	77.4	64.4	36.6	28.3	23.6	20.4	18.0	16.1
8			96.8	85.4	75.0	63.4	37.5	29.6	25.0	21.8	19.4
9				91.8	82.3	73.1	62.5	38.2	30.6	26.2	23.0
10				97.4	88.2	79.9	71.7	61.8	38.8	31.5	27.2
11					93.3	85.4	78.0	70.4	61.2	39.3	32.3
12					97.9	90.1	83.1	76.4	69.4	60.7	39.8
13						94.3	87.5	81.2	75.0	68.5	60.2
14						98.2	91.5	85.4	79.6	73.8	67.7
15							95.1	89.1	83.5	78.2	72.8
16							98.4	92.5	87.1	82.0	77.0
17								95.6	90.3	85.4	80.6
18								98.6	93.3	88.4	83.9
19									96.1	91.3	86.8
20									98.7	94.0	89.5
21										96.5	92.1
22										98.9	94.5
23											96.8
24											98.9

LOCATION OF TRAVERSE POINTS IN RECTANGULAR STACKS

	2	3	4	5	6	7	8	9	10	11	12
1	25.0	16.7	12.5	10.0	8.3	7.1	6.3	5.6	5.0	4.5	4.2
2	75.0	50.0	37.5	30.0	25.0	21.4	18.8	16.7	15.0	13.6	12.5
3		83.3	62.5	50.0	41.7	35.7	31.3	27.8	25.0	22.7	20.8
4			87.5	70.0	58.3	50.0	43.8	38.9	35.0	31.8	29.2
5				90.0	75.0	64.3	56.3	50.0	45.0	40.9	37.5
6					91.7	78.6	68.8	61.1	55.0	50.0	45.8
7						92.9	81.3	72.2	65.0	59.1	54.2
8							93.8	83.3	75.0	68.2	62.5
9								94.4	85.0	77.3	70.8
10									95.0	86.4	79.2
11										95.5	87.5
12											95.8

PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 1  
 ADDRESS DETROIT, MICH. TIME START 1005  
 SAMPLING LOCATION SCRUBBER INLET TIME FINISH 1530  
 DATE 6-18-85 TEAM LEADER gr TECHNICIANS B.B.  
 BAROMETRIC PRESSURE, IN. HG 29.0 STATIC PRESSURE, IN. H<sub>2</sub>O -2.00  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10 10  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000 0.000

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>216</u>	NOZZLE <u>406</u> DIAMETER <u>0.252</u>
<input type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-5</u>	T/C READOUT <u>04</u>
<input type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-52</u>	T/C PROBE <u>5-8</u>
<input type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>24</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>80</u> °F		PROBE <u>4-5</u>	TEDLAR BAG <u>NA</u>
FILTER #		NOMOGRAPH SET-UP	
	TARE	ΔH@ <u>1.80</u>	C FACTOR <u>1.10</u>
		METER TEMP <u>100</u>	STACK TEMP <u>80</u>
		% MOISTURE <u>2</u>	REF. ΔP <u>0.40</u>
			NOMOGRAPH # <u>gr</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
B	0/0	698.200	0.30	1.38	1.38	90	3	95	60	62	
	10	704.77	0.30	1.38	1.38	94	3	92	60	65	
	20	711.25	0.30	1.38	1.38	96	3	92	60	66	
	30	717.83	0.30	1.38	1.38	97	3	92	60	66	
	40	724.43	0.30	1.38	1.38	98	3	90	60	76	
	50	731.04	0.30	1.38	1.38	99	3	90	60	76	
	60	738.15	0.35	1.58	1.58	100	3	90	60	79	
	70	745.10	0.35	1.58	1.58	100	3	90	60	80	
	80	752.06	0.35	1.58	1.58	100	3	90	60	78	
	90	758.75	0.35	1.58	1.58	100	3	90	60	78	
	100	765.80	0.35	1.58	1.58	100	3	90	60	78	
	110	772.86	0.35	1.58	1.58	100	3	90	60	78	
	120	779.92	0.35	1.58	1.58	100	3	90	60	82	
	130	786.96	0.35	1.58	1.58	100	3	93	60	80	
	140	794.05	0.35	1.58	1.58	100	3	93	60	80	
	150	801.14	0.35	1.58	1.58	100	3	93	60	80	
A	160/0	808.238	0.50	2.30	2.30	96	5	90	60	75	808.238
A	10	816.84	0.55	2.53	2.53	98	5	90	60	75	808.300
	20	825.75	0.55	2.53	2.53	98	5	90	60	78	
	30	834.76	0.55	2.53	2.53	98	5	90	60	76	
	40	843.78	0.55	2.53	2.53	96	5	90	60	75	
	50	852.74	0.55	2.53	2.53	96	5	90	60	73	
	60	861.75	0.55	2.53	2.53	96	5	90	60	80	
	70	871.00	0.55	2.53	2.53	96	5	90	60	82	
	80	879.77	0.55	2.53	2.53	95	5	90	60	80	

$$V_M \sqrt{(\Delta P)^2} \quad \Delta H \quad T_M \quad T_S$$

ENTROPY



PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 4  
 ADDRESS DETROIT, MICH. TIME START 0839  
 SAMPLING LOCATION SCRUBBER INLET TIME FINISH 1405  
 DATE 6-19-85 TEAM LEADER SM TECHNICIANS BB  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -1.90  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>216</u>	NOZZLE <u>406</u> DIAMETER <u>252</u>
<input type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-5</u>	T/C READOUT <u>04</u>
<input type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-25</u>	T/C PROBE <u>5-8</u>
<input type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>24</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>80</u> °F		PROBE <u>4-5</u>	TEDLAR BAG <u>NA</u>
FILTER #		NOMOGRAPH SET-UP	
	TARE	ΔH@ <u>1.80</u>	C FACTOR <u>1.08</u>
		METER TEMP <u>80</u>	STACK TEMP <u>80</u>
		% MOISTURE <u>2</u>	REF. ΔP <u>0.42</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
B		952.700	0.33	1.45	1.45	68	3	90	60	75	
	10	989.35	0.33	1.45	1.45	75	3	90	60	75	
	20	966.40	0.33	1.45	1.45	80	3	90	60	76	
	30	972.80	0.36	1.58	1.58	82	3	90	60	75	
	40	979.88	0.36	1.58	1.58	82	3	90	60	74	
	50	986.93	0.36	1.58	1.58	84	3	90	60	79	
	60	994.00	0.36	1.58	1.58	85	3	90	60	75	
	70	1008.05	0.36	1.58	1.58	85	3	90	60	76	
	80	1008.10	0.36	1.58	1.58	85	3	90	60	76	
	90	1015.17	0.36	1.58	1.58	85	3	90	60	76	
	100	1022.25	0.40	1.75	1.75	85	3	90	60	76	
	110	1029.68	0.40	1.75	1.75	85	3	90	60	76	
	120	1037.16	0.40	1.75	1.75	85	3	90	60	76	
	130	1044.61	0.40	1.75	1.75	86	3	90	60	77	
	140	1052.11	0.38	1.66	1.66	87	3	90	60	76	
	150	1059.50	0.38	1.66	1.66	87	3	90	60	77	
A	160/0	1066.755	0.48	2.10	2.10	86	3	90	60	68	1066.755
	10	1075.03	0.48	2.10	2.10	88	5	90	60	73	1066.850
	20	1083.30	0.48	2.10	2.10	88	5	90	60	75	
	30	1091.57	0.48	2.10	2.10	88	5	90	60	73	
	40	1099.84	0.48	2.10	2.10	88	5	90	60	73	
	50	1108.10	0.48	2.10	2.10	88	5	90	60	74	
	60	1116.34	0.48	2.10	2.10	88	5	90	60	78	
	70	1124.55	0.48	2.10	2.10	87	5	90	60	77	
	80	1132.79	0.52	2.27	2.27	86	5	90	60	77	

$$V_M \sqrt{(\Delta P)^2} \quad \Delta H \quad T_M \quad T_S$$

ENTROPY



PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 7  
 ADDRESS DETROIT, MICH. TIME START 0856  
 SAMPLING LOCATION SCRUBBER INLET TIME FINISH 1421  
 DATE 6.20.85 TEAM LEADER gmc TECHNICIANS B.B  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -1.95  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 6 6  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000 0.000

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>216</u>	NOZZLE <u>406</u> DIAMETER <u>0.252</u>
<input type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-5</u>	T/C READOUT <u>04</u>
<input type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-25</u>	T/C PROBE <u>6-8</u>
<input type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>24</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>90</u> °F		PROBE <u>4-5</u>	TEDLAR BAG <u>NA</u>
FILTER #		NOMOGRAPH SET-UP	
<u>    </u>	<u>    </u>	ΔH@ <u>1.80</u>	C FACTOR <u>1.09</u>
<u>    </u>	<u>    </u>	METER TEMP <u>90</u>	STACK TEMP <u>80</u>
<u>    </u>	<u>    </u>	% MOISTURE <u>2</u>	REF. ΔP <u>0.41</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
B	0	215.600	0.31	1.39	1.39	78	3	90	60	73	
	10	222.05	0.31	1.39	1.39	83	3	90	60	73	
	20	228.52	0.31	1.39	1.39	90	3	90	60	77	
	30	235.00	0.33	1.48	1.48	93	3	90	60	79	
	40	241.95	0.33	1.48	1.48	96	4	90	60	79	
	50	248.78	0.33	1.48	1.48	98	4	90	60	79	
	60	255.67	0.33	1.48	1.48	100	4	90	60	83	
	70	262.51	0.33	1.48	1.48	102	4	90	60	82	
	80	269.57	0.36	1.61	1.61	102	4	90	60	78	
	90	276.62	0.36	1.61	1.61	102	4	90	60	81	
	100	283.82	0.36	1.61	1.61	102	4	90	60	80	
	110	291.01	0.39	1.75	1.75	103	4	90	60	81	
	120	298.50	0.39	1.75	1.75	103	4	90	60	80	
	130	306.00	0.39	1.75	1.75	103	4	90	60	80	
	140	313.46	0.39	1.75	1.75	102	4	90	60	78	
	150	320.96	0.39	1.75	1.75	100	4	90	60	79	
A	160/0	328.515	0.52	2.33	2.33	97	5	90	60	74	328.515
	10	336.82	0.52	2.33	2.33	99	5	90	60	70	328.600
	20	345.38	0.52	2.33	2.33	99	5	90	60	76	
	30	353.95	0.52	2.33	2.33	99	5	90	60	77	
	40	362.71	0.52	2.33	2.33	98	6	90	60	78	
	50	371.48	0.52	2.33	2.33	95	6	90	60	78	
	60	380.32	0.52	2.33	2.33	95	6	90	60	80	
	70	388.80	0.52	2.33	2.33	93	6	90	60	79	
	80	397.48	0.52	2.33	2.33	93	6	90	60	79	

$V_M \sqrt{(\Delta P)^2} \Delta H T_M T_S$

**ENTROPY**  
B-8



PARTICULATE FIELD DATA

COMPANY NAME C.S.OHM RUN NUMBER 2  
 ADDRESS DETROIT, MICH. TIME START 1004  
 SAMPLING LOCATION SCRUBBER INLET TIME FINISH 1529  
 DATE 6-18-85 TEAM LEADER gmc TECHNICIANS B.B.  
 BAROMETRIC PRESSURE, IN. HG 29.0 STATIC PRESSURE, IN. H<sub>2</sub>O -2.00  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10 10  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000 0.000

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>228</u>	NOZZLE <u>405</u> DIAMETER <u>0.257</u>
<input type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-14</u>	T/C READOUT <u>04</u>
<input type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-50</u>	T/C PROBE <u>7-0</u>
<input type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>25</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ _____ °F		PROBE <u>4-1</u>	TEDLAR BAG <u>NA</u>
FILTER # TARE		NOMOGRAPH SET-UP	
<u>T025</u>	<u>.4576</u>	ΔH@ <u>1.68</u>	C FACTOR <u>1.03</u>
		METER TEMP <u>100</u>	STACK TEMP <u>80</u>
		% MOISTURE <u>2</u>	REF. ΔP <u>0.42</u>
			NOMOGRAPH # <u>gmc</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS	
				IDEAL	ACTUAL							
A	1	0	515.500	0.35	1.53	1.63	90	5	95	60	62	
	10		522.81	0.35	1.53	1.53	94	5	92	60	65	
	20		530.06	0.40	1.75	1.75	98	6	92	60	66	
	30		538.05	0.40	1.75	1.75	100	6	92	60	66	
	40		545.72	0.52	2.28	2.28	102	7	90	60	76	
	50		554.44	0.52	2.28	2.28	105	7	90	60	76	
	60		564.00	0.34	1.49	1.49	103	5	90	60	79	
	70		571.75	0.34	1.49	1.49	100	5	90	60	80	
	80		579.50	0.37	1.62	1.62	98	5	90	60	78	
	90		585.60	0.37	1.62	1.62	100	5	90	60	78	
	100		593.21	0.43	1.88	1.88	100	6	90	60	79	
	110		601.36	0.43	1.88	1.88	102	6	90	60	79	
	120		609.70	0.43	1.88	1.88	102	6	90	60	82	
	130		618.11	0.43	1.88	1.88	103	6	92	60	80	
	140		626.65	0.43	1.88	1.88	104	6	92	60	80	
	150		634.31	0.43	1.88	1.88	104	6	92	60	80	
B	1	1600	642.534	0.25	1.10	1.10	100	5	90	60	75	642.534
	10		649.03	0.25	1.10	1.10	101	5	90	60	75	648.602
	20		655.38	0.25	1.10	1.10	100	5	90	60	78	
	30		661.71	0.25	1.10	1.10	100	5	90	60	76	
	40		668.16	0.25	1.10	1.10	100	5	9390	60	75	
	50		674.42	0.25	1.10	1.10	100	5	90	60	73	
	60		680.80	0.32	1.40	1.40	100	5	90	60	80	
	70		688.51	0.32	1.40	1.40	100	5	90	60	82	
	80		695.09	0.45	1.97	1.97	100	6	90	60	80	

$$\frac{251.317}{V_M} \frac{101}{(\sqrt{\Delta P})^2} \frac{77}{T_S}$$

# ENTROPY





PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 5  
 ADDRESS DETROIT, MICH. TIME START 0838  
 SAMPLING LOCATION Scrubber inlet TIME FINISH 1404  
 DATE 6-19-85 TEAM LEADER gpk TECHNICIANS B.B  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -1.90  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 10  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>228</u>	NOZZLE <u>4065</u> DIAMETER <u>.257</u>
<input checked="" type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-14</u>	T/C READOUT <u>04</u>
<input checked="" type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-50</u>	T/C PROBE <u>9-4</u>
<input checked="" type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>25</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>80</u> °F		PROBE <u>4-1</u>	TEDLAR BAG <u>NA</u>
FILTER # TARE		NOMOGRAPH SET-UP	
<u>T-0-2-3</u>	<u>.4721</u>	ΔH <sub>0</sub> <u>1.68</u>	C FACTOR <u>1.0</u>
		METER TEMP <u>80</u>	STACK TEMP <u>80</u>
		% MOISTURE <u>2</u>	REF. ΔP <u>0.42</u>
			NOMOGRAPH # <u>gpk</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A	1	767.202	0.37	1.62	1.62	68	5	90	60	75	
	10	774.55	0.37	1.62	1.62	76	5	90	60	75	
2	20	782.41	0.52	2.28	2.28	82	6	90	60	76	
	30	790.09	0.52	2.28	2.28	86	6	90	60	75	
3	40	799.60	0.52	2.28	2.28	86	6	90	60	74	
	50	808.31	0.48	2.10	2.10	86	6	90	60	79	
4	60	817.00	0.35	1.53	1.53	86	6	90	60	75	
	70	824.41	0.35	1.53	1.53	84	6	90	60	76	
5	80	831.80	0.35	1.53	1.53	84	6	90	60	76	
	90	839.15	0.35	1.53	1.53	84	6	90	60	76	
6	100	846.50	0.40	1.75	1.75	84	6	90	60	76	
	110	854.00	0.40	1.75	1.75	84	6	90	60	76	
7	120	862.50	0.40	1.75	1.75	86	6	90	60	76	
	130	869.92	0.40	1.75	1.75	86	6	90	60	77	
8	140	878.00	0.40	1.75	1.75	86	6	90	60	76	
	150	885.61	0.40	1.75	1.75	86	6	90	60	77	
B	1	893.500	0.22	0.96	0.96	84	4	90	60	68	893.500
	10	899.51	0.27	1.18	1.18	84	4	90	60	73	893.550
2	20	905.91	0.22	0.96	0.96	84	4	90	60	75	
	30	911.91	0.22	0.96	0.96	83	4	90	60	75	
3	40	917.90	0.22	0.96	0.96	82	4	90	60	73	
	50	924.60	0.22	0.96	0.96	82	4	90	60	74	
4	60	929.81	0.30	1.31	1.31	84	4	90	60	78	
	70	936.70	0.30	1.31	1.31	86	4	90	60	77	
5	80	943.57	0.37	1.62	1.62	84	5	90	60	77	

$$V_M \sqrt{(\Delta P)^2} \quad \Delta H \quad T_M \quad T_S$$



PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 8  
 ADDRESS DETROIT, MI TIME START 0855  
 SAMPLING LOCATION SCRUBBER INLET TIME FINISH 1420  
 DATE 6-20-85 TEAM LEADER gmc TECHNICIANS B.B  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -2.00  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 6 5  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. 0.000 0.000 0.000

EQUIPMENT CHECKS	IDENTIFICATION NUMBERS
<input checked="" type="checkbox"/> PITOTS, PRE-TEST	REAGENT BOX <u>228</u> NOZZLE <u>405</u> DIAMETER <u>0.257</u>
<input type="checkbox"/> PITOTS, POST-TEST	METER BOX <u>N.6</u> T/C READOUT <u>04</u>
<input checked="" type="checkbox"/> ORSAT SAMPLING SYSTEM	UMBILICAL <u>U-50</u> T/C PROBE <u>9-4</u>
<input checked="" type="checkbox"/> TEDLAR BAG	SAMPLE BOX <u>25</u> ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>80</u> °F	PROBE <u>4-1</u> TEDLAR BAG <u>NA</u>

FILTER #	TARE	NOMOGRAPH SET-UP	NOMOGRAPH #
<u>T-0.2-1</u>	<u>.4696</u>	ΔH@ <u>1.67</u> C FACTOR <u>1.00</u>	<u>gmc</u>
		METER TEMP <u>90</u> STACK TEMP <u>80</u>	
		% MOISTURE <u>2</u> REF. ΔP <u>0.42</u>	

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS	
				IDEAL	ACTUAL							
A	1	90	73.752	0.40	1.75	1.75	80	4	90	60	73	
		10	81.50	0.40	1.75	1.75	85	4	90	60	73	
	2	20	89.20	0.47	2.06	2.06	91	5	90	60	77	
		30	97.45	0.47	2.06	2.06	94	5	90	60	79	
	3	40	105.75	0.52	2.28	2.28	97	5	90	60	79	
		50	115.10	0.52	2.28	2.28	100	5	90	60	79	
	4	60	123.02	0.52	2.28	2.28	101	5	90	60	83	
		70	130.62	0.52	2.28	2.28	102	5	90	60	82	
	5	80	139.85	0.40	1.75	1.75	103	4	90	60	78	
		90	148.60	0.40	1.75	1.75	103	4	90	60	81	
6	100	156.27	0.40	1.75	1.75	103	4	90	60	80		
	110	163.94	0.40	1.75	1.75	102	4	90	60	81		
7	120	171.85	0.47	2.06	2.06	103	4	90	60	80		
	130	180.31	0.47	2.06	2.06	103	5	90	60	80		
8	140	188.85	0.45	1.97	1.97	102	5	90	60	78		
	150	197.26	0.45	1.97	1.97	101	5	90	60	79		
B	1	160/0	205.688	0.37	1.62	1.62	97	4	90	60	74	205.628
		10	213.41	0.25	1.10	1.10	98	4	90	60	70	205.736
	2	20	220.00	0.25	1.10	1.10	96	4	90	60	76	
		30	226.50	0.25	1.10	1.10	95	3	90	60	77	
	3	40	233.00	0.25	1.10	1.10	94	3	90	60	78	
		50	239.50	0.25	1.10	1.10	91	3	90	60	78	
	4	60	245.85	0.30	1.31	1.31	90	3	90	60	80	
		70	252.25	0.30	1.31	1.31	88	3	90	60	79	
	5	80	259.12	0.40	1.75	1.75	89	4	90	60	79	

$V_M \quad (\sqrt{\Delta P})^2 \quad \Delta H \quad T_M \quad T_S$

ENTROPY







PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 3  
 ADDRESS Detroit, Mi. TIME START 10:03  
 SAMPLING LOCATION Scrubber Outlet Stack TIME FINISH 15:05  
 DATE 6/18/85 TEAM LEADER HBL TECHNICIANS BR  
 BAROMETRIC PRESSURE, IN. HG 29.0 STATIC PRESSURE, IN. H<sub>2</sub>O -.38  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 12 13  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. .60 .00 .00

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX <u>0224</u>	NOZZLE <u>407</u> DIAMETER <u>.309</u>
<input checked="" type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-8</u>	T/C READOUT <u>0004</u>
<input checked="" type="checkbox"/> ORSAT POST-TEST SYSTEM		UMBILICAL <u>J-102</u>	T/C PROBE <u>7-7</u>
<input checked="" type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>19</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>70</u> °F		PROBE <u>5-3</u>	TEDLAR BAG <u>NA</u>
FILTER # TARE		NOMOGRAPH SET-UP	
<u>T-0.252</u>	<u>.7180</u>	ΔH <sub>g</sub> <u>1.61</u>	C FACTOR <u>0.92</u>
		METER TEMP <u>70</u>	STACK TEMP <u>70</u>
		% MOISTURE <u>3</u>	REF. ΔP <u>0.25 0.22</u>
			NOMOGRAPH # <u>WN</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP, °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP, °F	IMP. EXIT TEMP, °F	STACK TEMP, °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A 1	04/0	687.000	.95	7.95	7.10	70	12	100	63	66	
2	12	706.18	.67	5.60	5.60	90	9	100	60	67	
3	24	722.75	.44	3.68	3.68	88	5	100	61	66	
4	36	736.26	.27	2.26	2.26	85	4	100	61	66	
5	48	746.95	.15	1.25	1.25	80	1	100	66	66	
6	60	750.33	.28	2.34	2.34	78	1	100	65	66	
B 1	02/0	766.705	.53	4.43	4.43	79	6	100	63	66	
2	12	781.46	.50	4.12	4.18	82	6	100	60	68	
3	24	795.86	.26	2.17	2.17	83	3	100	60	68	L.C.
4	36	806.33	.08	0.67	0.67	79	1	100	60	68	
5	48	812.33	.06	.50	.50	79	1	100	60	68	826.590
6	60	817.45	.21	1.76	1.76	79	1	100	60	71	826.700
C 1	144/0	826.590	.45	3.76	3.76	79	5	100	60	71	
2	12	840.30	.73	6.11	6.11	83	9	100	60	68	
3	24	857.53	.86	3.01	2.01	84	5	100	60	71	
4	36	869.82	.10	.84	.84	83	1	100	60	70	
5	48	876.58	.07	.59	.59	82	1	100	60	68	
6	60	880.25	.29	0.43	2.43	81	1	100	60	68	
D 1	24/0	893.139	.37	3.09	3.09	80	5	100	60	68	
2	12	905.14	.55	4.60	4.60	84	6	100	60	68	
3	04	920.20	.70	5.85	5.85	85	8	100	60	68	
4	36	937.15	.47	3.93	3.93	88	6	100	60	69	
5	48	951.04	.42	3.51	3.51	86	5	100	60	69	
6	60	964.26	.49	4.10	4.10	85	6	100	60	69	
	288/0	978.482									

$$V_M = \frac{290.572}{(\sqrt{\Delta P})^2} \quad \Delta H = 3.24 \quad T_M = 82 \quad T_S = 68$$

ENTROPY



PARTICULATE FIELD DATA

COMPANY NAME C.S. OHM RUN NUMBER 6  
 ADDRESS Detroit, Mi. TIME START 8:37  
 SAMPLING LOCATION Scrubber Outlet Stack TIME FINISH 13:36  
 DATE 6/19/85 TEAM LEADER HBL TECHNICIANS AB  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -.37  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 13 12  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. .00 .00 .00

EQUIPMENT CHECKS		IDENTIFICATION NUMBERS	
<input checked="" type="checkbox"/> PITOTS, PRE-TEST		REAGENT BOX	NOZZLE <u>407</u> DIAMETER <u>.309</u>
<input checked="" type="checkbox"/> PITOTS, POST-TEST		METER BOX <u>N-8</u>	T/C READOUT <u>0004</u>
<input checked="" type="checkbox"/> ORSAT SAMPLING SYSTEM		UMBILICAL <u>U-102</u>	T/C PROBE <u>7-7</u>
<input checked="" type="checkbox"/> TEDLAR BAG		SAMPLE BOX <u>19</u>	ORSAT PUMP <u>NA</u>
<input checked="" type="checkbox"/> THERMOCOUPLE @ <u>70</u> °F		PROBE <u>5-3</u>	TEDLAR BAG <u>NA</u>
FILTER # TARE		NOMOGRAPH SET-UP	
<u>T-0.2-53</u>	<u>.6983</u>	ΔH@ <u>1.61</u>	C FACTOR <u>.92</u>
		METER TEMP <u>80</u>	STACK TEMP <u>70</u>
		% MOISTURE <u>3</u>	REF. ΔP <u>.22</u>
			NOMOGRAPH # <u>WN</u>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A 1	0%	979.100	.90	7.53	7.10	71	11	90	55	62	
2	12	997.70	.67	5.60	5.60	88	8	95	59	64	
3	24	1014.40	.45	3.76	3.76	80	6	95	60	66	
4	36	027.91	.28	2.34	2.34	75	4	97	61	67	
5	48	038.61	.17	1.42	1.42	71	1	98	62	66	
6	60	046.88	.29	2.43	2.43	71	4	99	62	66	
B 1	72%	057.765	.54	4.52	4.52	71	7	100	62	67	
2	12	072.60	.46	3.85	3.85	82	6	100	62	67	
3	24	086.33	.26	2.17	2.17	86	4	100	62	68	
4	36	096.77	.09	.75	.75	76	1	100	62	67	
5	48	103.20	.07	.58	.58	72	1	100	62	68	
6	60	108.76	.21	1.76	1.76	71	3	100	62	67	Lock Check
C 1	144%	117.079	.42	3.51	3.51	70	5	100	62	67	117.979
2	12	131.24	.70	5.85	5.85	74	9	100	62	67	118.100
3	24	147.87	.36	1.89	1.89	75	2	100	61	68	
4	36	157.48	.10	.83	.83	73	1	100	61	68	
5	48	164.12	.07	.58	.58	71	1	100	61	68	
6	60	169.62	.29	2.43	2.43	73	4	100	61	71	
D 1	216%	180.566	.37	3.09	3.09	75	5	100	61	72	
2	12	193.12	.52	4.35	4.35	79	6	100	61	72	
3	24	207.68	.70	5.85	5.85	80	9	100	61	72	
4	36	224.52	.50	4.18	4.18	83	6	100	60	71	
5	48	238.85	.38	3.18	3.18	81	5	100	60	72	
6	60	251.44	.46	3.85	3.85	82	6	100	60	71	
		288/14	265.287								

$\checkmark \frac{286.066}{286.308} \frac{0.3518}{(\sqrt{\Delta P})^2} \frac{3.161}{\Delta H} \frac{76}{T_M} \frac{168}{T_S}$   
 $\frac{V_M}{286.066}$   
**ENTROPY**  
 B-19

PARTICULATE FIELD DATA

COMPANY NAME C.S. OHMS RUN NUMBER 9  
 ADDRESS Detroit, Mi. TIME START 8:55  
 SAMPLING LOCATION scrubber outlet stack TIME FINISH 13:50  
 DATE 6/20/85 TEAM LEADER HBL TECHNICIANS BB  
 BAROMETRIC PRESSURE, IN. HG 29.2 STATIC PRESSURE, IN. H<sub>2</sub>O -0.25  
 SAMPLING TRAIN LEAK TEST VACUUM, IN. HG 15 12 12  
 SAMPLING TRAIN LEAK RATE, CU. FT./MIN. .20 0.00 0.000

<p><b>EQUIPMENT CHECKS</b></p> <p><input checked="" type="checkbox"/> PITOTS, PRE-TEST</p> <p><input type="checkbox"/> PITOTS, POST-TEST</p> <p><input type="checkbox"/> ORSAT SAMPLING SYSTEM</p> <p><input type="checkbox"/> TEDLAR BAG</p> <p><input checked="" type="checkbox"/> THERMOCOUPLE @ <u>70</u> °F</p>	<p><b>IDENTIFICATION NUMBERS</b></p> <p>REAGENT BOX <u>6224</u> NOZZLE <u>407</u> DIAMETER <u>.309</u></p> <p>METER BOX <u>N-8</u> T/C READOUT <u>8520-40</u></p> <p>UMBILICAL <u>U-102</u> T/C PROBE <u>7-7/1</u></p> <p>SAMPLE BOX <u>19</u> ORSAT PUMP <u>NA</u></p> <p>PROBE <u>S-3</u> TEDLAR BAG <u>NA</u></p>
<p><b>FILTER # TARE</b></p> <p><u>T. 0.2-51 .7526</u></p>	<p><b>NOMOGRAPH SET-UP</b> NOMOGRAPH # <u>WN</u></p> <p>ΔH@ <u>1.61</u> C FACTOR <u>0.92</u></p> <p>METER TEMP <u>80</u> STACK TEMP <u>70</u></p> <p>% MOISTURE <u>3</u> REF. ΔP <u>0.22</u></p>

SAMPLE POINT	CLOCK TIME, MIN.	DRY GAS METER READING, CU. FT.	PITOT READING (ΔP), IN. H <sub>2</sub> O	ORIFICE SETTING (ΔH), IN. H <sub>2</sub> O		GAS METER TEMP. °F	PUMP VACUUM IN. HG GAUGE	FILTER BOX TEMP. °F	IMP. EXIT TEMP. °F	STACK TEMP. °F	LK. CHECK READINGS
				IDEAL	ACTUAL						
A 1	0%	284.100	.94	7.86	6.80	75	12	100	66	71	
2	12	302.12	.65	5.44	5.44	88	9	100	64	71	
3	24	318.39	.41	3.43	3.43	87	6	100	63	71	
4	36	331.27	.28	2.34	2.34	82	4	100	62	71	
5	48	341.95	.16	1.34	1.34	82	2	100	62	71	
6	60	350.06	.31	2.59	2.59	83	5	100	62	72	
B 1	72%	361.440	.54	4.52	4.52	84	7	100	62	73	
2	12	376.32	.48	4.01	4.01	84	7	100	62	72	
3	24	390.43	.26	2.17	2.17	85	4	100	62	73	
4	36	400.86	.10	.836	0.84	82	1	100	62	74	
5	48	407.57	.08	.67	.67	81	1	100	62	74	
6	60	413.62	.23	1.92	1.92	80	4	100	62	74	
C 1	14%	423.462	.42	3.51	3.51	79	6	100	62	72	423.462
2	12	436.83	.69	5.77	5.77	84	10	100	62	73	423.600
3	24	452.65	.35	2.93	2.93	86	5	100	62	72	
4	36	465.66	.08	.67	.67	82	1	100	62	72	
5	48	471.78	.06	.50	.50	81	1	100	62	74	
6	60	476.88	.28	2.34	2.34	82	4	100	62	73	
D 1	21%	487.240	.35	2.93	2.93	82	5	100	65	74	
2	12	499.33	.50	4.18	4.18	82	7	100	67	70	
3	24	513.84	.70	5.85	5.85	85	9	100	64	71	
4	36	530.82	.50	4.18	4.18	88	7	100	65	71	
5	48	545.04	.44	3.68	3.68	85	6	102	66	71	
6	60	556.22	.48	4.01	4.01	85	7	102	66	70	
	218/0A	572.682									

$$\frac{288.444}{V_M} \sqrt{\frac{0.3523}{(\Delta P)^2}} \frac{3.193}{\Delta H} \frac{83}{T_M} \frac{72}{T_S}$$

**ENTROPY**

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name C.S. OHM (E.M.B.) EEI Ref. # 3018

Sampling Location \_\_\_\_\_

Date Received 6/21/85 Date Analyzed \_\_\_\_\_ Reagent Box(es) 0228

Run Number	<u>2</u>	<u>5</u>	<u>8</u>
Run Date	<u>6/18</u>	<u>6/19</u>	<u>6/20</u>

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg.	<u>466.1</u>	<u>473.6</u>	<u>476.6</u>
Total Filter Tare mg.	<u>457.6</u>	<u>472.1</u>	<u>469.6</u>
Blank Residue, mg. (100 ml)	<u>0.2</u>	<u>0.2</u>	<u>0.3</u>
	<u>8.3</u>	<u>1.3</u>	<u>6.7</u>
TOTAL PARTICULATE CATCH, mg.	<input type="text"/>	<input type="text"/>	<input type="text"/>

ANALYSIS OF MOISTURE CATCH

<u>Reagent 1 (H<sub>2</sub>O):</u>			
Final Weight, g.	<u>186.0</u>	<u>215.0</u>	<u>208.0</u>
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
Water Catch, g.	<u>-14.0</u>	<u>15.0</u>	<u>8.0</u>
<u>Reagent 2 ( )::</u>			
Final Weight, g.	<u>-</u>	<u>-</u>	<u>-</u>
Tared Weight, g.	<u>-</u>	<u>-</u>	<u>-</u>
Water Catch, g.	<u>-</u>	<u>-</u>	<u>-</u>
CONDENSED WATER, g.	<u>-14.0</u>	<u>15.0</u>	<u>8.0</u>
<u>Silica Gel:</u>			
Final Weight, g.	<u>251.2</u>	<u>250.3</u>	<u>254.2</u>
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
ABSORBED WATER, g.	<u>51.2</u>	<u>50.3</u>	<u>54.2</u>
TOTAL WATER COLLECTED, g.	<input type="text" value="37.2"/>	<input type="text" value="65.3"/>	<input type="text" value="62.2"/>

Blank Beaker # <u>28</u>	--- Legend ---	<u>Notes and Comments</u>
Final wt. mg. <u>57431.6</u>	✓ = Final Weight	
Tare wt. mg. <u>57431.2</u>	L = Loose Particulate	
Residue, mg. <u>0.4</u>	F = Filter    D = Dish	
Volume, ml. <u>200</u>	R = Rinse    P = Pan	
Concen., mg/ml. <input type="text" value=".002"/>	B-21	

LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name C.S. OHM

EI Ref. # 3018

Run Number

2

5

8

Run Date

6/18

6/19

6/20

Sample ID/Container #

F&R 386

F&R 407

F&R 409

Tare Wt., g.

133.5764  
✓ 133.5760  
133.1099

120.8795  
✓ 120.8793  
120.4057

113.9622  
✓ 113.9619  
113.9625  
113.9630  
113.4853

SAMPLE WT., g.

.4661

.4736

.4766

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.

PARTICULATE SAMPLING LABORATORY RESULTS

Plant Name C.S. OHM (EMB) EEI Ref. # 3018

Sampling Location \_\_\_\_\_

Date Received 6/21/85 Date Analyzed \_\_\_\_\_ Reagent Box(es) 0224

Run Number	<u>3</u>	<u>6</u>	<u>9</u>
Run Date	<u>6/18</u>	<u>6/19</u>	<u>6/20</u>

SUMMARY OF PARTICULATE ANALYSES

Sum of Particulate, mg.	<u>685.9</u>	<u>702.6</u>	<u>709.6</u>
Total Filter Tare mg.	<u>718.0</u>	<u>698.3</u>	<u>752.6</u>
Blank Residue, mg. (100 ml)	<u>0.2</u>	<u>0.2</u>	<u>0.3</u>
	<u>-32.3</u>	<u>4.1</u>	<u>-43.3</u>
TOTAL PARTICULATE CATCH, mg.	<input type="text"/>	<input type="text"/>	<input type="text"/>

ANALYSIS OF MOISTURE CATCH

<u>Reagent 1 (DI. H<sub>2</sub>O):</u>			
Final Weight, g.	<u>234.0</u>	<u>248.0</u>	<u>252.0</u>
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
Water Catch, g.	<u>34.0</u>	<u>48.0</u>	<u>52.0</u>
<u>Reagent 2 ( )::</u>			
Final Weight, g.	<u>-</u>	<u>-</u>	<u>-</u>
Tared Weight, g.	<u>-</u>	<u>-</u>	<u>-</u>
Water Catch, g.	<u>-</u>	<u>-</u>	<u>-</u>
CONDENSED WATER, g.	<u>34.0</u>	<u>48.0</u>	<u>52.0</u>
<u>Silica Gel:</u>			
Final Weight, g.	<u>251.1</u>	<u>255.3</u>	<u>252.6</u>
Tared Weight, g.	<u>200.0</u>	<u>200.0</u>	<u>200.0</u>
ABSORBED WATER, g.	<u>51.1</u>	<u>55.3</u>	<u>52.6</u>
TOTAL WATER COLLECTED, g.	<input type="text" value="85.1"/>	<input type="text" value="103.3"/>	<input type="text" value="104.6"/>

Blank Beaker # <u>28</u>	--- Legend ---	Notes and Comments
Final wt. mg. <u>57431.6</u>	✓ = Final Weight	
Tare wt. mg. <u>57431.2</u>	L = Loose Particulate	
Residue, mg. <u>0.4</u>	F = Filter    D = Dish	
Volume, ml. <u>200</u>	R = Rinse    P = Pan	
Concen., mg/ml. <input type="text" value=".002"/>	B-23	

LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name C.S. OHM

EEI Ref. # 3018

Run Number

3

6

9

Run Date

6/18

6/19

6/20

Sample ID/Container #

F&R 410

F&R 424

F&R 431

Tare Wt., g.

118.1259  
 $\checkmark$ 118.1259  
 118.1262  
117.4400

126.5506  
 $\checkmark$ 126.5501  
 126.5507  
125.8475

126.2014  
 $\checkmark$ 126.2010  
 126.2019  
125.4914

SAMPLE WT., g.

.6859

.7026

.7096

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.

Sample ID/Container #

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Tare Wt., g.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

SAMPLE WT., g.



LABORATORY SAMPLE WEIGHT CALCULATIONS

Plant Name C.S. OHM (EMB)

EEI Ref. # 3018

Run Number

SPECIAL  
INLET

Run Date

6/19

Sample ID/Container #

F&R 433

Tare Wt., g.

124.0933  
✓124.0931  
124.0937  
123.5919

SAMPLE WT., g.

.5012

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.

Sample ID/Container #

Tare Wt., g.

SAMPLE WT., g.



# ENTROPY

ENVIRONMENTALISTS, INC.

POST OFFICE BOX 12291  
RESEARCH TRIANGLE PARK  
NORTH CAROLINA 27709-2291  
919-781-3550

## REQUEST FOR ANALYSIS

REFERENCE

~~PURCHASE~~

ORDER # 3018

JOB NAME: EMB 3018

LABORATORY: RTI ATT. BILL GUTKNECKT OR PETER GROHSE

DATE SAMPLES WERE TRANSMITTED: 7/2/85 EXPECTED DATE OF RESULTS: 7/12/85

SAMPLE MATRIX: \_\_\_\_\_

TYPE OF ANALYSIS REQUESTED: Cr<sup>+6</sup> AND PREPARE FOR NAA

SAMPLE #	RUN #	SAMPLE I.D.	BASIS
C-241	2	M-5-3" - INLET	Concentrate — to <i>total</i>
C-242	5	M-5-3" - INLET	" "
C-243	8	M-5-3" - INLET	" "
C-244	SPECIAL	M-5-3" - INLET	" "
C-245	3	M-5-4" - OUTLET	" "
C-246	6	M-5-4" - OUTLET	" "
C-247	9	M-5-4" - OUTLET	" "
C-248	BLANK	M-5-4"	
C-249	2	IMPINGER REAGENT	Concentrate to 50ml — <i>mg/ml</i>
C-250	5	IMPINGER REAGENT	" "
C-251	8	IMPINGER REAGENT	" "
C-252	SPECIAL	IMPINGER REAGENT	" "

267  
SUBMITTED BY: \_\_\_\_\_

CONTINUED



Original Sample Volume - Impingers

C-249	460 mL
C-250	345 mL
C-251	350 mL
C-252	360 mL
C-253	380 mL
C-254	350 mL
C-255	385 mL
C-256	193 mL
C-257	230 mL
C-258	400 mL
C-259	193 mL
C-260	230 mL
C-261	390 mL
C-262	190 mL
C-263	201 mL
C-264	192 mL
C-267	295 mL

WET CHEMICAL ANALYSIS SHEETS

DATE RECEIVED: 7/8/85      DATE ANALYZED 7/10/85  
 ANALYST: RTL      CLIENT: ENTROPY  
 ANALYTE: C<sub>r</sub>+6

RTI #	CLIENT #	SAMPLE CONCENTRATION		
		Total ug	ug/g	ug/mL
<u>C-241</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-242</u>	<u>      </u>	<u>2.79</u>	<u>      </u>	<u>      </u>
<u>C-243</u>	<u>      </u>	<u>4.17</u>	<u>      </u>	<u>      </u>
<u>C-244</u>	<u>      </u>	<u>5.94</u>	<u>      </u>	<u>      </u>
<u>C-245</u>	<u>      </u>	<u>2.13</u>	<u>      </u>	<u>      </u>
<u>C-246</u>	<u>      </u>	<u>2.73</u>	<u>      </u>	<u>      </u>
<u>C-247</u>	<u>      </u>	<u>3.24</u>	<u>      </u>	<u>      </u>
<u>C-248</u>	<u>      </u>	<u>1.12</u>	<u>      </u>	<u>      </u>
<u>C-249</u>	<u>      </u>	<u><del>0.53</del></u>	<u>      </u>	<u>      </u>
<u>C-250</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-251</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-252</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-253</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-254</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-255</u>	<u>      </u>	<u>15.57</u>	<u>      </u>	<u>      </u>
<u>C-256</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-257</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-258</u>	<u>      </u>	<u>13.23</u>	<u>      </u>	<u>      </u>
<u>C-259</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>
<u>C-260</u>	<u>      </u>	<u>0.21</u>	<u>      </u>	<u>      </u>
<u>C-261</u>	<u>      </u>	<u>19.38</u>	<u>      </u>	<u>      </u>
<u>C-262</u>	<u>      </u>	<u>0.69</u>	<u>      </u>	<u>      </u>
<u>C-263</u>	<u>      </u>	<u>0.74</u>	<u>      </u>	<u>      </u>
<u>C-264</u>	<u>      </u>	<u><del>20.2</del></u>	<u>      </u>	<u>&lt;0.2</u>
<u>C-265</u>	<u>      </u>	<u>      </u>	<u>      </u>	<u>5.09</u>
<u>C-266</u>	<u>      </u>	<u>      </u>	<u>      </u>	<u>52.37</u>
<u>C-267</u>	<u>      </u>	<u>&lt;0.2</u>	<u>      </u>	<u>      </u>

Figure 1. Sample Preparation and Analysis Data Form

Sample No. <sup>a</sup>	Particulate Sample		Solid Process Sample		Liquid Process Samples			Sample Weight $\mu\text{g}$ of $\text{Cr}^{+6}$	Results by NVA $\mu\text{g}$ of $\text{Cr}^{+6}$
	Filter/Rinse <sup>b</sup> Residue	Impinger <sup>c</sup> Volume	Weight of Sample, $\text{mg}^d$	Sample Concentration <sup>e</sup>	Initial Volume	Final Volume <sup>g</sup>	Aliquot <sup>h</sup>		
C-241	Total								
C-248		400	230 <sup>k</sup>						
C-249		345	173 <sup>k</sup>						
C-250		350	175 <sup>k</sup>						
C-251		360	180 <sup>k</sup>						
C-252		380	190 <sup>k</sup>						
C-253		350	175 <sup>k</sup>						
C-254		385	193 <sup>k</sup>						
C-255		193	97 <sup>k</sup>						
C-256		230	125 <sup>k</sup>						
C-257		400	200 <sup>k</sup>						
C-258		193	97 <sup>k</sup>						
C-259									

<sup>a</sup> Sample number marked on sample vial or sample container.  
<sup>b</sup> Mark whether the particulate sample is a sample residue or filtrate sample aliquot.  
<sup>c</sup> Record exact volume impinger sample after concentrate and indicate that the sample is 2.0 ml aliquot.  
<sup>d</sup> The weight in mg of the process sample analyzed will be recorded by NVA personnel.  
<sup>e</sup> Concentration of process sample in terms of  $\mu\text{g/g}$  of  $\text{Cr}^{+6}$  for process sample when the NVA facility is to weigh sample.  
<sup>f</sup> Record initial volume of liquid sample if liquid sample is concentrated.  
<sup>g</sup> Record final volume of liquid sample if liquid sample is concentrated.  
<sup>h</sup> Indicate that the sample is a 2.0 ml aliquot of a liquid process sample.  
<sup>i</sup> Total mass of hexavalent chromium in sample vial in  $\mu\text{g}$ .  
<sup>j</sup> Analytical results by NVA in terms of  $\mu\text{g}$  of  $\text{Cr}$  per sample vial.  
<sup>k</sup> Concentrated to less than 2.5 mL

Figure 1. Sample Preparation and Analysis Data Form

Sample No. <sup>a</sup>	Particulate Sample			Solid Process Sample		Liquid Process Samples			Sample Weight, $\mu\text{g}$ of Cr <sup>16</sup>	Results by NAA $\mu\text{g}$ of Cr <sup>16</sup>
	Filter/Rinse <sup>b</sup> Residue	Volume	Impinger <sup>c</sup> Aliquot	Weight of Sample, mg <sup>d</sup>	Sample Concentration <sup>e</sup>	Initial Volume <sup>f</sup>	Final Volume <sup>g</sup>	Aliquot <sup>h</sup>		
C-260		230	125 <sup>k</sup>							
C-261		190	195 <sup>k</sup>	1000						
C-262		190	95 <sup>k</sup>							
C-263		201	101 <sup>k</sup>							
C-264		192	96 <sup>k</sup>							
C-265		295	118 <sup>k</sup>					1 ml	5.07 $\mu\text{g}$	
C-267				140.7						
C-268				112.8						
C-269				133.3						
C-270				145.1						
C-271				135.7						
C-272				138.0						
C-273				103.6						
C-274				103.9						
C-275				113.3						
C-276				100.9						
C-277										

<sup>a</sup>Sample number marked on sample vial or sample container.

<sup>b</sup>Mark whether the particulate sample is a sample residue or filtrate sample aliquot.

<sup>c</sup>Record exact volume impinger sample after concentrate and indicate that the sample is 2.0 ml aliquot.

<sup>d</sup>The weight in mg of the process sample analyzed will be recorded by NAA personnel.

<sup>e</sup>Concentration of process sample in terms of  $\mu\text{g}/\text{g}$  of Cr<sup>16</sup> for process sample when the NAA facility is to weigh sample.

<sup>f</sup>Record initial volume of liquid sample if liquid sample is concentrated.

<sup>g</sup>Record final volume of liquid sample if liquid sample is concentrated.

<sup>h</sup>Indicate that the sample is a 2.0 ml aliquot of a liquid process sample.

<sup>i</sup>Total mass of hexavalent chromium in sample vial in  $\mu\text{g}$ .

<sup>j</sup>Analytical results by NAA in terms of  $\mu\text{g}$  of Cr per sample vial.

<sup>k</sup> Concentrate to less than 2.5 ml

Figure 1. Sample Preparation and Analysis Data Form

Sample No. <sup>a</sup>	Particulate Sample		Solid Process Sample		Liquid Process Samples			Sample Weight $\mu\text{g}$ of Cr <sup>16</sup>	Results by NAA $\mu\text{g}$ of Cr <sup>1</sup>
	Filter/Rinse Residue	Impinger Volume	Weight of Sample, mg	Sample Concentration <sup>e</sup>	Initial Volume	Final Volume <sup>g</sup>	Aliquot <sup>h</sup>		
C-324			114.2						
C-325			116.1						
C-326 Hexavalent Chromium $\downarrow$									
C-336 Total									
C-337 (QA-16)			25.0					50	
C-338 (QA-14)			75.0					50	
C-339 (QA-17)			50.0					100	
C-340 (QA-20)			50.0					100	
C-341 (QA-12)			75.0					150	
C-342 (QA-21)			100.0					200	

- <sup>a</sup> Sample number marked on sample vial or sample container.
- <sup>b</sup> Mark whether the particulate sample is a sample residue or filtrate sample aliquot.
- <sup>c</sup> Record exact volume impinger sample after concentrate and indicate that the sample is 2.0 ml aliquot.
- <sup>d</sup> The weight in mg of the process sample analyzed will be recorded by NAA personnel.
- <sup>e</sup> Concentration of process sample in terms of  $\mu\text{g/g}$  of Cr <sup>16</sup> for process sample when the NAA facility is to weigh sample.
- <sup>f</sup> Record initial volume of liquid sample if liquid sample is concentrated.
- <sup>g</sup> Record final volume of liquid sample if liquid sample is concentrated.
- <sup>h</sup> Indicate that the sample is 2.0 ml aliquot of a liquid process sample.
- <sup>i</sup> Total mass of hexavalent chromium in sample vial in  $\mu\text{g}$ .
- <sup>j</sup> Analytical results by NAA in terms of  $\mu\text{g}$  of Cr per sample vial.

Legend: < - Below Minimum Detectable limit > - Cvr Instrument analytical range \* - Nonreportable constituent  
 "No value" - No data value present "Fit fail" - Curve fit failure

Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent
CR5 No Value	# 231 Cd	5.535E-01	Cr	85/ 9/ 4 @ 14:23:28 No Value	NI	by NAA002	(JPL)	Multiplier: 1.401E+00	( 1 )
CR5 No Value	# 232 Cd	3.912E-01	Cr	85/ 9/ 4 @ 14:25: 8 No Value	NI	by NAA002	(JPL)	Multiplier: 1.191E+00	( 2 )
CR5 No Value	# 233 Cd	1.926E+00	Cr	85/ 9/ 4 @ 14:23:33 No Value	NI	by NAA002	(JPL)	Multiplier: 1.401E+00	( 3 )
CR5 No Value	# 234 Cd	6.195E-01	Cr	85/ 9/ 4 @ 14:23:48 No Value	NI	by NAA002	(JPL)	Multiplier: 1.401E+00	( 4 )
CR5 No Value	# 235 Cd	1.068E+00	Cr	85/ 9/ 4 @ 14:22:33 No Value	NI	by NAA002	(JPL)	Multiplier: 1.044E+00	( 5 )
CR5 No Value	# 236 Cd	1.320E+00	Cr	85/ 9/ 4 @ 14:19:28 No Value	NI	by NAA002	(JPL)	Multiplier: 1.023E+00	( 6 )
CR5 No Value	# 237 Cd	8.784E+03	Cr	85/ 9/ 4 @ 14:20:49 No Value	NI	by NAA002	(JPL)	Multiplier: 1.410E+00	( 7 )
CR5 No Value	# 238 Cd	8.899E+04	Cr	85/ 9/ 4 @ 14:17:33 5.467E+02	NI	by NAA002	(JPL)	Multiplier: 1.097E+00	( 8 )
CR5 No Value	# 239 Cd	1.088E+01	Cr	85/ 9/ 4 @ 14:19:59 No Value	NI	by NAA002	(JPL)	Multiplier: 1.424E+00	( 9 )
CR5 No Value	# 240 Cd	4.125E+02	Cr	85/ 9/ 4 @ 14:21:48 No Value	NI	by NAA002	(JPL)	Multiplier: 1.046E+00	( 10 )
CR5 No Value	# 241 Cd	9.201E+00	Cr	85/ 9/ 4 @ 14:22:48 No Value	NI	by NAA002	(JPL)	Multiplier: 1.100E+00	( 11 )
CR5 No Value	# 242 Cd	1.327E+01	Cr	85/ 9/ 4 @ 14:21:58 No Value	NI	by NAA002	(JPL)	Multiplier: 1.046E+00	( 12 )
CR5 No Value	# 243 Cd	1.874E+01	Cr	85/ 9/ 4 @ 14:19:18 5.824E+01	NI	by NAA002	(JPL)	Multiplier: 1.023E+00	( 13 )
CR5 No Value	# 244 Cd	1.563E+01	Cr	85/ 9/ 4 @ 14:17: 8 9.645E+01	NI	by NAA002	(JPL)	Multiplier: 1.000E+00	( 14 )
CR5 No Value	# 245 Cd	2.344E+01	Cr	85/ 9/ 4 @ 14:26:38 No Value	NI	by NAA002	(JPL)	Multiplier: 1.540E+00	( 15 )
CR5 No Value	# 246 Cd	1.827E+01	Cr	85/ 9/ 4 @ 14:17:18 No Value	NI	by NAA002	(JPL)	Multiplier: 1.000E+00	( 16 )



Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent
CR5 No Value	# 247 Cd	1.831E+01	Cr	85/ 9/ 4 @ 14:22: 8 No Value	NI	(JPL)	Multiplier: 1.046E+00	( 17 )	
CR5 No Value	# 248 Cd	5.563E+00	Cr	85/ 9/ 4 @ 14:22:53 No Value	NI	(JPL)	Multiplier: 1.100E+00	( 18 )	
CR5 No Value	# 249 Cd	1.119E+00	Cr	85/ 9/13 @ 16:52: 3 No Value	NI	(JPL)	Multiplier: 1.055E+00	( 19 )	
CR5 No Value	# 250 Cd	1.679E+00	Cr	85/ 9/ 4 @ 14:20:13 No Value	NI	(JPL)	Multiplier: 1.424E+00	( 20 )	
CR5 No Value	# 251 Cd	6.010E-01	Cr	85/ 9/13 @ 16:50:33 5.615E+00	NI	(JPL)	Multiplier: 3.160E+00	( 21 )	
CR5 No Value	# 252 Cd	9.448E-01	Cr	85/ 9/13 @ 16:53:48 No Value	NI	(JPL)	Multiplier: 1.401E+00	( 22 )	
CR5 No Value	# 253 Cd	8.384E-01	Cr	85/ 9/13 @ 16:52:13 No Value	NI	(JPL)	Multiplier: 5.250E+00	( 23 )	
CR5 No Value	# 254 Cd	7.172E-01	Cr	85/ 9/ 4 @ 14:22:13 No Value	NI	(JPL)	Multiplier: 1.000E+00	( 24 )	
CR5 No Value	# 255 Cd	3.089E+01	Cr	85/ 9/13 @ 16:47:23 No Value	NI	(JPL)	Multiplier: 1.360E+00	( 25 )	
CR5 No Value	# 256 Cd	1.280E+00	Cr	85/ 9/13 @ 16:54:38 3.870E+00	NI	(JPL)	Multiplier: 1.217E+00	( 26 )	
CR5 No Value	# 257 Cd	1.129E+00	Cr	85/ 9/ 4 @ 14:23: 3 No Value	NI	(JPL)	Multiplier: 1.044E+00	( 27 )	
CR5 No Value	# 258 Cd	1.367E+01	Cr	85/ 9/13 @ 16:49:33 No Value	NI	(JPL)	Multiplier: 1.055E+00	( 28 )	
CR5 No Value	# 259 Cd	1.402E+00	Cr	85/ 9/13 @ 16:54:58 3.002E+00	NI	(JPL)	Multiplier: 4.380E+00	( 29 )	
CR5 No Value	# 260 Cd	2.029E+00	Cr	85/ 9/ 4 @ 14:24: 3 No Value	NI	(JPL)	Multiplier: 1.401E+00	( 30 )	
CR5 No Value	# 261 Cd	2.615E+01	Cr	85/ 9/13 @ 16:48:48 8.967E+01	NI	(JPL)	Multiplier: 1.105E+00	( 31 )	
CR5 No Value	# 262 Cd	4.067E+00	Cr	85/ 9/13 @ 16:49:13 No Value	NI	(JPL)	Multiplier: 1.750E+00	( 32 )	
CR5 No Value	# 263 Cd	4.833E+00	Cr	85/ 9/13 @ 16:51:33 No Value	NI	(JPL)	Multiplier: 1.390E+00	( 33 )	

Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent
CR5 # 264 No Value Cd	C0264	9.945E+01 Cr	95/ 9/13 @ 15:51:23 by NAA002 6.505E+00 Ni	(JPL)	Multiplier: 1.009E+00	1.009E+00	(JPL)	Multiplier: 1.009E+00	( 34 )
CR5 # 265 No Value Cd	C0265	1.269E+01 Cr	95/ 9/ 4 @ 14:24:43 by NAA002 No Value Ni	(JPL)	Multiplier: 1.263E+00	1.263E+00	(JPL)	Multiplier: 1.263E+00	( 35 )
CR5 # 267 No Value Cd	C0267	7.853E-01 Cr	35/ 9/13 @ 16:53: 3 by NAA002 No Value Ni	(JPL)	Multiplier: 1.401E+00	1.401E+00	(JPL)	Multiplier: 1.401E+00	( 36 )
CR5 # 268 No Value Cd	C0268	7.670E+00 Cr	85/ 9/13 @ 16:50: 3 by NAA002 No Value Ni	(JPL)	Multiplier: 1.272E+00	1.272E+00	(JPL)	Multiplier: 1.272E+00	( 37 )
CR5 # 269 No Value Cd	C0269	4.769E+00 Cr	85/ 9/ 4 @ 14:20:58 by NAA002 No Value Ni	(JPL)	Multiplier: 1.410E+00	1.410E+00	(JPL)	Multiplier: 1.410E+00	( 38 )
CR5 # 270 No Value Cd	C0270	6.343E+00 Cr	35/ 9/13 @ 16:48:23 by NAA002 No Value Ni	(JPL)	Multiplier: 1.185E+00	1.185E+00	(JPL)	Multiplier: 1.185E+00	( 39 )
CR5 # 271 No Value Cd	C0271	9.830E+00 Cr	95/ 9/13 @ 15:47:38 by NAA002 No Value Ni	(JPL)	Multiplier: 1.000E+00	1.000E+00	(JPL)	Multiplier: 1.000E+00	( 40 )
CR5 # 272 No Value Cd	C0272	9.076E+00 Cr	85/ 9/ 4 @ 14:23:53 by NAA002 No Value Ni	(JPL)	Multiplier: 1.470E+00	1.470E+00	(JPL)	Multiplier: 1.470E+00	( 41 )
CR5 # 273 No Value Cd	C0273	9.803E+00 Cr	85/ 9/ 4 @ 14:21: 8 by NAA002 No Value Ni	(JPL)	Multiplier: 1.410E+00	1.410E+00	(JPL)	Multiplier: 1.410E+00	( 42 )
CR5 # 274 No Value Cd	C0274	3.525E+00 Cr	85/ 9/13 @ 16:49:48 by NAA002 No Value Ni	(JPL)	Multiplier: 1.055E+00	1.055E+00	(JPL)	Multiplier: 1.055E+00	( 43 )
CR5 # 275 No Value Cd	C0275	3.261E+00 Cr	85/ 9/13 @ 16:53:38 by NAA002 No Value Ni	(JPL)	Multiplier: 1.556E+00	1.556E+00	(JPL)	Multiplier: 1.556E+00	( 44 )
CR5 # 276 No Value Cd	C0276	3.995E+00 Cr	85/ 9/ 4 @ 14:21:18 by NAA002 No Value Ni	(JPL)	Multiplier: 1.410E+00	1.410E+00	(JPL)	Multiplier: 1.410E+00	( 45 )
CR5 # 277 No Value Cd	C0277	1.963E+00 Cr	85/ 9/13 @ 16:52:59 by NAA002 No Value Ni	(JPL)	Multiplier: 1.401E+00	1.401E+00	(JPL)	Multiplier: 1.401E+00	( 46 )
CR5 # 278 No Value Cd	C0278	2.387E+00 Cr	85/ 9/ 4 @ 14:17:48 by NAA002 No Value Ni	(JPL)	Multiplier: 1.097E+00	1.097E+00	(JPL)	Multiplier: 1.097E+00	( 47 )
CR5 # 279 No Value Cd	C0279	2.246E+00 Cr	85/ 9/ 4 @ 14:18:28 by NAA002 No Value Ni	(JPL)	Multiplier: 1.097E+00	1.097E+00	(JPL)	Multiplier: 1.097E+00	( 48 )
CR5 # 280 No Value Cd	C0280	6.922E+00 Cr	85/ 9/13 @ 16:54: 3 by NAA002 No Value Ni	(JPL)	Multiplier: 1.289E+00	1.289E+00	(JPL)	Multiplier: 1.289E+00	( 49 )
CR5 # 231 No Value Cd	C0281	9.539E+00 Cr	35/ 9/ 4 @ 14:20: 8 by NAA002 No Value Ni	(JPL)	Multiplier: 1.424E+00	1.424E+00	(JPL)	Multiplier: 1.424E+00	( 50 )

Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent
CR5 No Value	# 282 Cd	35/ 9/ 4 @ 2.427E+00	Cr	14:25:28 No Value	by NAA002 NI	(JPL)	Multiplier: 1.587E+00	( 51 )	
CR5 No Value	# 283 Cd	85/ 9/ 4 @ 3.067E+00	Cr	14:26:43 No Value	by NAA002 NI	(JPL)	Multiplier: 1.818E+00	( 52 )	
CR5 No Value	# 294 Cd	35/ 9/ 4 @ 3.775E+00	Cr	14:18:53 No Value	by NAA002 NI	(JPL)	Multiplier: 1.023E+00	( 53 )	
CR5 No Value	# 285 Cd	35/ 9/ 4 @ 3.186E+00	Cr	14:16:38 No Value	by NAA002 NI	(JPL)	Multiplier: 1.000E+00	( 54 )	
CR5 No Value	# 236 Cd 207	85/ 9/ 4 @ 1.443E+02 1.26	Cr	14:26:59 No Value	by NAA002 NI	(JPL)	Multiplier: 1.940E+00	( 55 )	
CR5 No Value	# 288 Cd	35/ 9/ 13 @ 6.765E+01	Cr	16:51:19 No Value	by NAA002 NI	(JPL)	Multiplier: 1.059E+00	( 56 )	
CR5 No Value	# 289 Cd	85/ 9/ 4 @ <del>4.477E+01</del>	Cr	14:25:38 No Value	by NAA002 NI	(JPL)	Multiplier: 7.135E+01	( 57 )	
CR5 No Value	# 290 Cd	35/ 9/ 4 @ 4.426E+01	Cr	14:25:48 No Value	by NAA002 NI	(JPL)	Multiplier: 1.792E+00	( 58 )	
CR5 No Value	# 291 Cd	85/ 9/ 4 @ 4.250E+01	Cr	14:24:53 No Value	by NAA002 NI	(JPL)	Multiplier: 1.263E+00	( 59 )	
CR5 No Value	# 292 Cd	85/ 9/ 4 @ 7.026E+01	Cr	14:19: 9 No Value	by NAA002 NI	(JPL)	Multiplier: 1.023E+00	( 60 )	
CR5 No Value	# 293 Cd	85/ 9/ 4 @ 1.016E+01	Cr	14:25:58 No Value	by NAA002 NI	(JPL)	Multiplier: 1.587E+00	( 61 )	
CR5 No Value	# 294 Cd	35/ 9/ 4 @ 1.256E+02	Cr	14:18: 3 No Value	by NAA002 NI	(JPL)	Multiplier: 1.097E+00	( 62 )	
CR5 No Value	# 295 Cd	35/ 9/ 4 @ 4.664E+00	Cr	14:26: 9 No Value	by NAA002 NI	(JPL)	Multiplier: 1.587E+00	( 63 )	
CR5 No Value	# 337 Cd (QA-16)	35/ 9/ 4 @ 4.569E+01	Cr	14:18:13 No Value	by NAA002 NI	(JPL)	Multiplier: 1.097E+00	( 64 )	
CR5 No Value	# 338 Cd (QA-19)	35/ 9/ 4 @ 5.230E+01	Cr	14:21:29 No Value	by NAA002 NI	(JPL)	Multiplier: 1.410E+00	( 65 )	
CR5 No Value	# 339 Cd (QA-17)	25/ 9/ 4 @ 9.649E+01	Cr	14:16:53 No Value	by NAA002 NI	(JPL)	Multiplier: 1.000E+00	( 66 )	
CR5 No Value	# 340 Cd (QA-20)	35/ 9/ 4 @ 9.722E+01	Cr	14:16:43 No Value	by NAA002 NI	(JPL)	Multiplier: 1.023E+00	( 67 )	

Value	Constituent	Value	Constituent	Value	Constituent	Value	Constituent
CRS No Value	# 327 Cd C0327	85/ 8/23 1.940E+04 Cr	@ 11:15:23 No Value NI	by NAA002 Multiplier: 1.351E+00	(JPL)	1.351E+00	( 34 )
CRS No Value	# 329 Cd C0329	85/ 8/23 2.543E+04 Cr	@ 11:13:13 No Value NI	by NAA002 Multiplier: 1.056E+00	(JPL)	1.056E+00	( 35 )
CRS No Value	# 330 Cd C0330	85/ 8/23 1.479E+04 Cr	@ 11:11: 3 No Value NI	by NAA002 Multiplier: 1.000E+00	(JPL)	1.000E+00	( 36 )
CRS No Value	# 332 Cd C0332	85/ 8/23 3.017E+02 Cr	@ 11:11:13 No Value NI	by NAA002 Multiplier: 1.000E+00	(JPL)	1.000E+00	( 37 )
CRS No Value	# 333 Cd C0333	85/ 8/23 5.247E+02 Cr	@ 11:12: 3 No Value NI	by NAA002 Multiplier: 1.025E+00	(JPL)	1.025E+00	( 38 )
CRS No Value	# 334 Cd C0334	85/ 8/23 4.340E+03 Cr	@ 11:13:23 No Value NI	by NAA002 Multiplier: 1.056E+00	(JPL)	1.056E+00	( 39 )
CRS No Value	# 336 Cd C0336	85/ 8/23 8.445E+01 Cr	@ 11:12:13 No Value NI	by NAA002 Multiplier: 1.025E+00	(JPL)	1.025E+00	( 40 )
CRS No Value	# 341 Cd (QA-78) C0341	85/ 8/23 1.464E+02 Cr	@ 11:20:13 No Value NI	by NAA002 Multiplier: 9.970E-01	(JPL)	9.970E-01	( 41 )
CRS No Value	# 342 Cd (QA-21) C0342	85/ 8/23 2.001E+02 Cr	@ 11:20:53 No Value NI	by NAA002 Multiplier: 1.476E+00	(JPL)	1.476E+00	( 42 )
CRS No Value	# 770 Cd C328A	85/ 8/23 5.635E+03 Cr	@ 11:16:13 No Value NI	by NAA002 Multiplier: 1.216E+00	(JPL)	1.216E+00	( 43 )
CRS No Value	# 771 Cd C328B	85/ 8/23 3.526E+03 Cr	@ 11:16:23 No Value NI	by NAA002 Multiplier: 1.216E+00	(JPL)	1.216E+00	( 44 )
CRS No Value	# 772 Cd C331B	85/ 8/23 3.211E+03 Cr	@ 11:17:33 No Value NI	by NAA002 Multiplier: 1.013E+00	(JPL)	1.013E+00	( 45 )
CRS No Value	# 773 Cd C331A	85/ 8/23 5.207E+03 Cr	@ 11:18:43 No Value NI	by NAA002 Multiplier: 1.012E+00	(JPL)	1.012E+00	( 46 )

APPENDIX C.

SAMPLING AND ANALYTICAL PROCEDURES

## DETERMINATION OF TOTAL PARTICULATE EMISSIONS

All particulate samples were collected using an EPA Method 5 sampling train, and Method 5 sampling procedures, as described in the Federal Register\*.

### SAMPLING APPARATUS

The particulate sampling train used in these tests met design specifications established by the EPA. The sampling apparatus, which was assembled by Entropy personnel, consisted of the following:

Nozzle - Stainless steel (316) with sharp, tapered leading edge and accurately measured round opening.

Probe - Borosilicate glass with a heating system capable of maintaining a minimum gas temperature of 121°C (250°F) at the exit end during sampling.

Pitot Tube - A type S pitot tube that met all geometric standards was attached to a probe to monitor stack gas velocity pressure.

Temperature Gauge - A Chromel/Alumel type-K thermocouple (or equivalent) was attached to the pitot tube, in an interference-free arrangement, to monitor stack gas temperature within 1.5°C (5°F) using a digital readout.

Filter Holder - The filter holder was made of Pyrex glass, with heating system capable of maintaining a filter temperature of approximately 121°C (250°F).

Filter - A 79-mm (3-in.) diameter Teflon filter (Scheicher & Schuell) was used.

Draft Gauge - The draft was measured with two in-parallel Magnehelic<sup>R</sup> gauges (made by Dwyer) with subdivisions of 0.25 mm (0.01 in.) H<sub>2</sub>O in the 0 to 12.5 mm (0 to 0.5 in.) H<sub>2</sub>O range and 1.25 mm (0.05 in.) subdivisions in the 12.5 to 50 mm (0.5 to 2 in.) range.

Impingers - Four Greenburg-Smith design impingers were connected in series with screw-type connectors. The first, third, and fourth impingers were modified by removing the tip and extending the tube to within 1.3 cm (0.5 in.) of the bottom of the flask.

Metering System - The metering system consisted of a vacuum gauge, a leak-free pump, thermometers capable of measuring temperature to within 1.5°C (5°F), a calibrated dry gas meter, and related equipment, to

\*40 CFR 60, Appendix A, Reference Method 5, July 1, 1980.

maintain an isokinetic sampling rate and to determine sample volume. The dry gas meter was made by Rockwell, and the fiber vane pump was made by Gast.

Barometer - An aneroid type barometer was used to measure atmospheric pressures to 0.3 kPa (0.1 in. Hg).

#### SAMPLING PROCEDURES


After the sampling site and minimum number of traverse points were selected, the stack pressure, temperature, moisture, and range of velocity head were measured according to procedures described in the Federal Register.\*

Approximately 200 grams of silica gel was weighed and placed in a sealed impinger prior to each test. Teflon filters were desiccated for at least 24 hours to a constant weight and weighed to the nearest 0.1 mg on an analytical balance. One hundred (100) milliliters of deionized-distilled water was placed in each of the first two impingers; the third impinger was initially empty; and the fourth impinger containing the silica gel was placed next in series. The train was set up as shown in Figure C-1. The sampling train was leak-checked at the sampling site prior to each test run by plugging the inlet to the nozzle and pulling a 50 kPa (15 in. Hg) vacuum, and at the conclusion of the test by plugging the inlet to the nozzle and pulling a vacuum equal to the highest vacuum reached during the test run.

The pitot tube and lines were leak-checked at the test site prior to each test run and at the conclusion of each test run. The check was made by blowing into the impact opening of the pitot tube until 7.6 cm (3 in.) or more of water was recorded on the Magnehelic<sup>R</sup> gauge and then capping the impact opening and holding it for 15 seconds to assure it was leak-free. The same procedure was used to leak-check the static pressure side of the pitot tube, except suction

---

\*40 CFR 60, Appendix A, Methods 1, 2, 3, and 4, July 1, 1980.



C-5

Figure C-1. Method 5 sample train.



was used to obtain the 7.6 cm (3 in.) H<sub>2</sub>O manometer reading. Crushed ice was placed around the impingers to ensure that the temperature of the gases leaving the last impinger was at 20°C (68°F) or less.

During the sampling, stack gas and sampling train data were recorded at each sampling point and whenever significant changes in stack flow conditions occurred. Isokinetic sampling rates were set throughout the sampling period with the aid of a nomograph or calculator. All sampling data were recorded on the field data sheets.

#### SAMPLE RECOVERY PROCEDURES

The sampling train was carefully moved from the test site to the cleanup area. The volume of water from the first three impingers was measured, and the silica gel from the fourth impinger was weighed to the nearest 0.1 gram.

Sample fractions were recovered as follows:

Container No. 1 - The filter was removed from its holder and placed in a petri dish and sealed.

Container No. 2 - Loose particulate and acetone washings from all sample-exposed surfaces prior to the filter were placed in a glass or polyethylene jar, sealed, and labeled. Particulate was removed from the probe with the aid of a brush and acetone rinsing. The sample-exposed surfaces prior to the filter were also washed with distilled water. These washings were added to the glass jar. The liquid level was marked after the container was sealed and labeled.

Container No. 3 - A minimum of 200 ml of acetone was taken for the blank analysis. The blank was obtained and treated in a manner similar to the acetone washing.

Container No. 4 - After being measured, distilled water in the impinger section of the sampling train was placed in a glass or polyethylene container. The impingers and connecting glassware were rinsed with distilled H<sub>2</sub>O and this rinse was added to the container for shipment to the laboratory.

Container No. 5 - A minimum of 200 ml of distilled water was taken for the blank analysis. The blank was obtained and treated in a manner similar to the water rinse.

Container No. 6 - An unused Teflon filter was taken for blank analysis.

Data was recorded on the appropriate sample recovery and laboratory data sheets.

## ANALYTICAL PROCEDURES

The following procedures were used and followed the methods described in the Federal Register\*.

Container No. 1 - The filter and any loose particulate matter from this sample container were placed into a tared glass weighing dish, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Container No. 2 - The acetone and water washings were transferred to a tared beaker, evaporated to dryness in an oven, desiccated for 24 hours to a constant weight, and weighed to the nearest 0.1 mg.

Container No. 3 - The acetone blank was transferred to a tared beaker and evaporated to dryness at ambient temperature and pressure. The blank was then desiccated for 24 hours to a constant weight and weighed to the nearest 0.1 mg.

Container No. 4 - The impinger contents were marked with the sample run number and saved for chromium analysis.

Container No. 5 - The distilled water blank was saved for chromium analysis.

Container No. 6 - The unused glass fiber filter was treated in an identical manner as the filter in Container No. 1.

The term "constant weight" referred to above means a difference of no more than 0.5 mg or 1 percent of total weight less tare weight, whichever is greater between two consecutive readings, with no less than 6 hours of desiccation between weighings. All analytical data were recorded on the analytical data sheets.

\*40 CFR 60, Appendix A, Reference Method 5, July 1, 1980.

DETERMINATION OF HEXAVALENT CHROMIUM EMISSIONS  
(DRAFT METHOD)

Particulate samples collected using the EPA Method 5 sampling train and Method 5 sampling procedures\* were analyzed for hexavalent chromium using the tentative method "Determination of Hexavalent Chromium Emissions from Stationary Sources" (dated December 13, 1984) by digesting in an alkaline solution and assaying with the diphenylcarbazide colorimetric method.

#### SAMPLING APPARATUS

The sampling train used in these tests were the same as for the particulate (Method 5) tests. These trains met design specifications established by the U. S. EPA and were assembled by Entropy personnel.

#### SAMPLING PROCEDURES

The sampling procedures were performed according to Method 5. All sampling data were recorded on the field data sheets.

#### SAMPLE RECOVERY PROCEDURES

Sample recovery was done according to Method 5. Data was recorded on the appropriate sample recovery and laboratory data sheets.

#### SAMPLE AND REAGENT PREPARATION

Samples for analysis and reagents were prepared as described in the following subsections.

##### Reagents

All reagents conformed to the specifications established by the Committee on Analytical Reagents of the American Chemical Society. In all cases, the water used was deionized and distilled and met the ASTM specifications for

---

\*40 CFR 60, Appendix A, Reference Method 5, July 1, 1980.

type 2 reagent - ASTM Test Method D 1193-77. Solutions were made as follows:

Digestion Solution - 20.0 g of NaOH and 30.0 g anhydrous  $\text{Na}_2\text{CO}_3$  were dissolved in water in a 1-liter volumetric flask, and this solution diluted to the mark. It was stored in a tightly capped polyethylene bottle and was prepared fresh monthly.

Potassium Dichromate Stock Solution - 141.4 mg of analytical reagent grade  $\text{K}_2\text{Cr}_2\text{O}_7$  was dissolved in water, and this solution diluted to 1 liter (1 ml = 50  $\mu\text{g Cr}^{+6}$ ).

Potassium Dichromate Standard Solution - 10.00 ml of  $\text{K}_2\text{Cr}_2\text{O}_7$  stock solution was diluted to 100 ml (1 ml = 5  $\mu\text{g Cr}^{+6}$ ) with water.

Sulfuric Acid - A ten percent (v/v) solution was made by diluting 10 ml  $\text{H}_2\text{SO}_4$  to 100 ml in water.

Acetone - Same as Method 5.

Diphenylcarbazide Solution - 250 mg of 1, 5-diphenylcarbazide was dissolved in 50 ml acetone and stored in a brown bottle. The solution was discarded whenever it became discolored.

#### Sample Preparation

To prevent the possibility of sample deterioration, all samples were protected from extreme heat, were kept dry, and were analyzed within one month of collection. Sample preparation involved digestion and filtration. The contents of Container No. 2 (the acetone probe rinse) was placed in a 250 ml beaker and evaporated to dryness. Following this, the contents of Container No. 1 (with the filter cut into small pieces) was added to the beaker; digestion solution (40 ml) was added and the beaker covered with a watch glass. Using a hot plate, this solution was heated to near boiling with constant stirring for 30 minutes; it was not allowed to evaporate to dryness.

The solution was then cooled and transferred quantitatively to the filtration apparatus with water. This apparatus consists of a vacuum unit constructed of plastic or glass which accommodates a 47 mm diameter, 3.0  $\mu\text{m}$  pore size Teflon filter. The solution was filtered and transferred quantitatively to a 100 ml volumetric flask which was then filled to the mark with water.

To serve as a blank, a representative amount of acetone and a blank Method 5 filter were prepared in the same manner as the sample described above.

The spent silica gel (in Container No. 3) was weighed to the nearest 0.5 g using a balance.

#### SAMPLE ANALYSIS

Analysis of the samples involved four basic elements: (1) color development and measurement, (2) a check for matrix results on the  $\text{Cr}^{+6}$  results, (3) calibration of the spectrophotometer, and (4) calculation of the results.

##### Color Development and Measurement

An aliquot of the prepared sample 50 ml or smaller was transferred to a 100 ml volumetric flask and diluted with sufficient water to bring the volume to approximately 80 ml. The pH was adjusted to  $2 \pm 0.5$  with 10 percent  $\text{H}_2\text{SO}_4$ , 2.0 ml of diphenylcarbazide solution was added, and this solution diluted to volume with water. The solution then stood about 10 minutes for color development. For each set of samples analyzed, an identical aliquot of reagent blank solution was treated in the same way.

To measure, a portion of the sample was transferred to a 1-cm absorption cell, and the absorbance read at the optimum wavelength as determined during spectrophotometer calibration. After each sample measurement, the reagent blank absorbance reading, if any, was subtracted to obtain a net reading. If the absorbance of the sample exceeded the absorbance of the 100 g  $\text{Cr}^{+6}$  standard as determined during calibration, the sample and the reagent blank were diluted with equal volumes of water.

##### Check for Matrix Effects on the $\text{Cr}^{+6}$ Results

Since the analysis for  $\text{Cr}^{+6}$  by colorimetry is sensitive to the chemical composition of the sample (matrix effects), at least one sample from each source was checked using the method of additions as follows:

Two equal volume aliquots of the same sample solution were taken; each contained between 30 and 50  $\mu\text{g}$  of  $\text{Cr}^{+6}$  (less if that was not possible). One of the aliquots was spiked with an aliquot of standard solution containing 30 to 50  $\mu\text{g}$  of  $\text{Cr}^{+6}$ . Then both the spiked and unspiked sample aliquots were readied for measurement as described in the previous section.

The  $\text{Cr}^{+6}$  mass,  $C_s$ , in  $\mu\text{g}$  in the aliquot of the unspiked sample solution was then calculated using the following equation:

$$C_s = C_a \frac{A_s}{A_t - A_s} \quad \text{Equation D-1}$$

Where:

$C_a$  =  $\text{Cr}^{+6}$  in the standard solution,  $\mu\text{g}$ .

$A_s$  = Absorbance of the unspiked sample solution.

$A_t$  = Absorbance of the spiked sample solution.

Volume corrections were not required since the solutions as analyzed were made to the same final volume. When the results of the method of additions procedure used on the single source sample did not agree within 10 percent of the value obtained by the routine spectrophotometric analysis, all samples from the source were reanalyzed using the method of additions procedure.

#### SPECTROPHOTOMETER CALIBRATION

Calibration of the spectrophotometer involved two basic sets of operations and these are described below.

##### Optimum Wavelength Determination

Every 6 months, the wavelength scale of the spectrophotometer was calibrated using an energy source with an intense line emission or a series of glass filters spanning the measuring range of the spectrophotometer. The spectrophotometer was checked to see that the wavelength scale read within  $\pm 5$  nm at all calibration points. After confirming that the wavelength scale of

that the wavelength scale of the spectrophotometer was in proper calibration, 540 nm was used as the optimum wavelength for the measurement of the absorbance of the standards and samples.

In some cases, a scanning procedure was employed to determine the proper measuring wavelength. For both the blank and a 50  $\mu\text{g Cr}^{+6}$  standard solution, the spectrum was scanned between 530 and 550 nm. The optimum wavelength was chosen as the wavelength at which the maximum difference in absorbance between the standard and the blank occurred.

#### Spectrophotometer Calibration

To calculate the spectrophotometer calibration factor, 0.0 ml, 1 ml, 2 ml, 5 ml, 10 ml, 15 ml, and 20 ml of the working standard solution (1 ml = 5  $\mu\text{g Cr}^{+6}$ ) were added to a series of seven 100-ml volumetric flasks. These calibration standards were analyzed as described in the section on color development and measurement. The calibration procedure was repeated on each day that samples were analyzed. The spectrophotometer calibration factor,  $K_C$ , was calculated using the following equation:

$$K_C = 5 \frac{A_1 + 2A_2 + 5A_3 + 10A_4 + 15A_5 + 20A_6}{A_1 + A_2 + A_3 + A_4 + A_5 + A_6} \quad \text{Equation D-2}$$

Where:

- $K_C$  = Calibration factor.
- $A_1$  = Absorbance of the 5  $\mu\text{g Cr}^{+6}$  standard.
- $A_2$  = Absorbance of the 10  $\mu\text{g Cr}^{+6}$  standard.
- $A_3$  = Absorbance of the 25  $\mu\text{g Cr}^{+6}$  standard.
- $A_4$  = Absorbance of the 50  $\mu\text{g Cr}^{+6}$  standard.
- $A_5$  = Absorbance of the 75  $\mu\text{g Cr}^{+6}$  standard.
- $A_6$  = Absorbance of the 100  $\mu\text{g Cr}^{+6}$  standard.

### Spectrophotometer Calibration Quality Control

The absorbance value obtained for each standard was multiplied by the  $K_c$  factor (least squares slope) to determine the distance each calibration point was from the theoretical calibration line. To maintain quality control, it was assured that these concentration values did not differ from the actual concentrations (i.e., 5, 10, 25, 50, 75, and 100  $\mu\text{g Cr}^{+6}$ ) by more than 7 percent (to be determined) for five of the six standards.

### EMISSION CALCULATIONS

All emission calculations were done retaining at least one extra decimal figure beyond that of the acquired data. Figures were rounded off after final calculations.

### Total $\text{Cr}^{+6}$ in Sample

The total  $\mu\text{g Cr}^{+6}$  in each sample,  $m$ , was calculated as follows:

$$m = \frac{100 K_c AF}{v_a} \quad \text{Equation D-3}$$

Where:

100 = Volume in ml of total sample.

A = Absorbance of sample.

F = Dilution factor (required only if sample dilution was needed to reduce the absorbance into the range of calibration.)

$v_a$  = Volume in ml of aliquot analyzed.

### Average Dry Gas Meter Temperature and Average Orifice Pressure Drop

The average dry gas meter temperature and average orifice pressure drop was calculated as described in Method 5.



Dry Gas Volume, Volume of Water Vapor, Moisture Content

The dry gas volume, volume of water vapor, and moisture content was calculated as described in Method 5.

Cr<sup>+6</sup> Emission Concentration

The Cr<sup>+6</sup> concentration in the stack gas, C<sub>s</sub> (g/dscm), dry basis, corrected to standard conditions was calculated as follows:

$$C_s = (10^{-6} \text{g}/\mu\text{g}) (m/V_{m(\text{std})}) \quad \text{Equation D-4}$$

Isokinetic Variation, Acceptable Results

Isokinetic variation and acceptable results were calculated as described in Method 5.

DETERMINATION OF TOTAL CHROMIUM CONTENT  
(DRAFT METHOD)

Particulate samples collected using the EPA Method 5 sampling train and Method 5 sampling procedures\* or particle sizing equipment (see section on Determination of Particle Size Distribution) were prepared and analyzed for total chromium content using Neutron Activation Analysis (NAA). This was done following the procedures in the "EPA Protocol for Emissions Sampling for Both Hexavalent and Total Chromium," dated February 22, 1985.\*\*

SAMPLING APPARATUS

The sampling train used in these tests were the same as for the Method 5 tests. No sample-exposed stainless steel or chrome-plated equipment was used with the exception of the sample nozzle. In some cases, paper filters were used for particulate testing or particle size testing. These trains met design specifications established by the U. S. EPA and were assembled by Entropy personnel.

SAMPLING PROCEDURES

The sampling procedures were performed according to Method 5 (or according to the particle size determination sampling procedures). All sampling data were recorded on the field data sheets.

SAMPLE RECOVERY PROCEDURES

Following sample recovery, all samples were kept dry, protected from extreme heat, and analyzed within one month of collection.

---

\*40 CFR 60, Appendix A, Reference Method 5, July 1, 1980.

\*\*For Chromium Screening Study ESED No. 85/02 and 85/02a, U. S. Environmental Protection Agency, Emission Measurement Branch, Research Triangle Park, North Carolina.

## SAMPLE PREPARATION

In all cases, samples collected using EPA Method 5 were analyzed first for hexavalent chromium content (as described in the previous section) and then for total chromium content. Most of the process samples collected were also treated in this manner. The exception to this was in respect to the solid process samples; in this case, the sample was made homogeneous and then representative portions were taken quantitatively and used separately in the analyses for hexavalent chromium and total chromium content.

All samples prepared for NAA were put into suitable sample vials which had been properly prepared. Procedures for this are described below. The subsections which follow describe the sample and blank preparation procedures used for the various categories of sample states.

### Sample Preparation Apparatus

No chrome-plated or stainless steel equipment was used. The following items were also required:

Analytical Balance - To determine weight of material submitted for total chromium analysis to within 0.1 mg.

Polyethylene Sample Vials - Five (5) ml size to contain samples submitted for total chromium.

Teflon Spatula - To assist in sample transfer.

Teflon Gloves - To be used for sample handling.

### Preparation of Sample Vials

For use in the analytical phase, sample vials were prepared in the following manner. All vials were initially cleaned with soap and water, rinsed with tap water, soaked for 48 hours in a rinse solution of 1 to 1 (v/v) water and concentrated nitric acid, and finally rinsed with deionized-distilled water. After the vials dried, each was marked on both sides with the appropriate sample identification number using a permanent pen (water

insoluble). All sample identification numbers, volumes, and weights were recorded on the Sample Preparation and Analysis Data Forms.

#### Preparation and Analysis for Method 5 Samples

Initially, the entire sample was analyzed for hexavalent chromium by the EPA Cr<sup>+6</sup> Method described in the previous section. The sample residue (particulate filter, filtration filter and insoluble materials) for each run was then transferred to a separate cleaned and marked sample vial. For samples with 2 to 10 grams of material, multiple 5 ml vials (least possible number) were used. For samples with greater than 10 grams of material, a portion of the filter catch (approximately 4-5 grams) were taken, weighed to the nearest 0.1 mg, and transferred to a sample vial. For one sample run at each emission test location, a 2.0 ml aliquot of the filtrate from the hexavalent chromium analysis was transferred to a cleaned and marked vial.

The sample blank consisted of the blank residue, including the acetone blank (the volume of the acetone blank being approximately equal to the average of the acetone rinse volume); a blank particulate filter; and a solution filtration filter that had been prepared in the same manner as the field samples. This was transferred to a separate cleaned/marked sample vial.

All samples were analyzed for total chromium in terms of  $\mu\text{g}$  of total chromium per sample vial.

#### Preparation and Analysis for Liquid Process Samples

Initially, a representative portion of the liquid process sample was analyzed for hexavalent chromium by the EPA Cr<sup>+6</sup> method. For total chromium analysis, a separate representative sample (2.0 ml aliquot) that contained greater than 1  $\mu\text{g/ml}$  of total chromium was transferred to a sample vial for analysis. When the liquid sample was below 1  $\mu\text{g/ml}$  concentration, a

representative sample was concentrated and then a 2.0 ml aliquot transferred to a sample vial for analysis. Representative portions were taken according to EPA Method 160.2 (EPA-600/4-79-020, March 1974). No sample blank was required.

#### Preparation and Analysis for Solid Process Samples

A representative sample of solid process samples was first taken and analyzed for hexavalent chromium by the EPA Cr<sup>+6</sup> Method. A separate representative sample was taken for total chromium analysis. Two procedures were followed in preparing these samples for total chromium analysis: (1) a representative sample not exceeding the volume of the 5.0 ml sample vial and containing 5 to 100 µg of Cr<sup>+6</sup> was taken and weighed to the nearest 0.1 mg, or (2) a representative sample (about 10 to 20 grams) was taken and placed in a marked and cleaned polyethylene container, then the exact sample fraction and weight analyzed was selected and performed by the NAA staff. The concentration of the process material in terms of µg/g of hexavalent chromium was included on the sample log to provide the NAA staff with the information necessary to make the proper sample size selection. When the sample concentration was unknown, the second procedure was followed. An estimate of sample concentration was then determined by NAA prior to the actual sample analysis.

For samples that completely passed through a 200 mesh screen, a representative portion was obtained by thoroughly mixing the entire sample. For samples with material greater than 200 mesh, the sample was initially screened and then all materials that did not pass through the screen were ground, using a technique that would not provide chromium contamination, until all material passed through the screen. The sample was then thoroughly mixed and a representative sample taken. No sample blank was required.

For sludge process samples, the entire sample was thoroughly mixed and then a representative portion was taken.

#### Procedures to Reduce NAA Time

For all samples that were placed in sample vials, an estimate of the mass of chromium was included on the sample log to provide the NAA facility with the information necessary to select the proper sample irradiation time and strength. When possible, all samples were added to the sample vials in amounts that ensured the mass of chromium per sample was between 10  $\mu\text{g}$  and 5,000  $\mu\text{g}$ . When the total chromium value was not known, samples were prepared so that each sample vial contained between 5  $\mu\text{g}$  and 100  $\mu\text{g}$  of hexavalent chromium. These procedures were followed to allow all known value samples to be irradiated at the same time and strength.

When the sample concentration was unknown or possibly could have exceeded 5,000  $\mu\text{g}$  of total chromium, such was noted on the sample log sheet. A preliminary run on the material was then made to estimate the sample concentration.

When liquid process sample or the 2.0 ml aliquot of the filtrate from the hexavalent analysis were below the 10  $\mu\text{g}$  of total chromium value, total mass of chromium was recorded on the data sheet to allow these samples to be irradiated separately for a longer time and to allow for the selection of a lower concentration standard.

#### Quality Assurance Sample Analysis

With every set of 15 samples submitted for NAA, one audit sample was submitted to check the analytical technique.

#### SAMPLE ANALYSIS

Sample analysis for total chromium content was done using Neutron Activation Analysis (NAA) and was conducted by the Department of Nuclear

Engineering at North Carolina State University in Raleigh. In brief, NAA is based on the determination of the number and energy of gamma and/or x-rays emitted by radioisotopes produced in a sample matrix by neutron irradiation. Quantitative analysis is obtained by comparing the x- or gamma-rays of the sample with the number determined for a standard that has been subjected to the identical irradiation.

The samples (prepared as described) were heat-sealed in the 25 ml polyethylene vials. Chromium standards were similarly sealed in identical vials. Sets of samples and standards were irradiated for a predetermined neutron fluence. They were then allowed to radiate for a minimum of 10 days prior to analysis to eliminate possible inference from sodium and cobalt which have short half-lives. After this time, samples and standards were counted on a solid state detector connected to a multichannel analyzer.

Results were reported for samples in terms of total  $\mu\text{g}$  of chromium for the sample.

#### CALCULATIONS

Particulate and chromium emissions and concentrations were calculated as described below.

##### Emission Calculations for Particulate and Hexavalent Chromium

Particulate and hexavalent chromium emissions were calculated as described in the EPA  $\text{Cr}^{+6}$  Method (see previous section).

##### Emission Calculations for Total Chromium

The total chromium emissions,  $C_s$  ( $\mu\text{g}/\text{dscm}$ ), were calculated as follows:

$$C_s = (m_r - m_b) + (m_h) / V_{m(\text{std})} \quad \text{Equation C-5}$$

Where:

- $C_s$  = Stack gas concentration, g/dscm.
- $m_r$  = Mass of Cr in each particulate residue sample,  $\mu\text{g}$ .
- $m_b$  = Mass of Cr in each particulate residue blank,  $\mu\text{g}$ .
- $m_h$  = Mass of Cr in filtrate solution ( $\text{Cr}^{+6}$ ) minus blank,  $\mu\text{g}$ .
- $V_{m(\text{std})}$  = Volume of gas sampled, corrected to standard conditons, dscm.

Note: In some cases, the mass of Cr was calculated separately, for the filter/rinse sample and impinger contents sample, or the masses of both samples and both blanks were added to obtain the total concentration.

#### Calculation of Chromium in Solid Process Samples

The chromium concentration in solid process samples,  $C_o$  ( $\mu\text{g/g}$ ), was calculated as follows:

$$C_o = (m_s - m_b)/wt \quad \text{Equation C-6}$$

Where:

- $C_o$  = Concentration of chromium in process sample,  $\mu\text{g/g}$ .
- $m_s$  = Mass of Cr in process sample,  $\mu\text{g}$ .
- $m_b$  = Mass of Cr in blank sample (if applicable),  $\mu\text{g}$ .
- $wt$  = Weight of sample analyzed, g.

#### Calculation of Chromium in Liquid Process Samples

The chromium concentration in liquid process samples,  $C_l$  ( $\mu\text{g/ml}$ ), was calculated as follows:

$$C_l = (m_s/2) (V_f/V_i) \quad \text{Equation C-7}$$

Where:

- $C_l$  = Concentration of chromium in liquid sample,  $\mu\text{g/ml}$ .
- $m_s$  = Mass of Cr in liquid process sample,  $\mu\text{g}$ .
- 2 = 2.0 ml aliquot analyzed.
- $V_f$  = Final volume if a sample is concentrated, ml.
- $V_i$  = Initial volume of sample concentrated, ml.



APPENDIX D  
CALIBRATION DATA

## CALIBRATIONS

All measuring equipment Entropy uses is initially calibrated before use. Equipment which can change calibration is both checked upon return from each field use and is also periodically recalibrated in full. When an instrument is found out of calibration, it is so noted in the report and appropriate adjustments are made to the final results. The equipment is then repaired and recalibrated or retired as needed. Specific equipment is handled as follows:

Pitot Tube - All pitot tubes used by Entropy, whether separate or attached to a sampling probe, are constructed in-house or by Nutech Corporation. Prior to their initial usage, they are calibrated using EPA geometry standards. In general, if a type "S" pitot tube is assembled correctly, and positioned properly in relation to the probe nozzle, it will have an average  $C_p$  of 0.84. As long as it is not damaged, it should not change its calibration. The recalibration schedule for pitot tubes is related to the physical condition and usage of the pitot tube, not a fixed time schedule. Each pitot tube is inspected upon return to the laboratory from each field use.

Dry Gas Meter and Orifice Meter - All Entropy meter boxes are calibrated upon purchase and at least once every six months against a secondary test meter (one calibrated against a wet test meter) according to their usage history. Basic procedures are outlined in the EPA Publication No. APTD-0576. The only differences are in the choice of flow rates used and the volumes metered at each flow rate. After each field use, quick checks are performed to ensure delta  $H_0$  changes of less than 5%. These checks compare the orifice against the dry gas meter. If greater than 5% changes occur, recalibration and repair are instituted.

Nozzles - Each nozzle is calibrated upon purchase, and thereafter whenever it becomes apparent that the nozzle has become damaged. Each nozzle is inspected upon return to laboratory from each field use. The diameter is measured on five different axes, with the high and low readings differing by no more than 0.004 inches as a tolerance.

Temperature Measuring Instruments - After each field use, the thermocouples or thermometers are calibrated against an ASTM precision mercury-in-glass thermometer across a wide range of temperatures. If the initial reading is not within  $\pm 1.5\%$  of the absolute temperature reading of the standard thermometer, the instrument is adjusted until it is in the acceptable range.

Magnehelic<sup>R</sup> Gauges - After each field use, each Magnehelic<sup>R</sup> Gauge is calibrated against an inclined manometer at three different settings (low, medium, high) over the range of the individual gauges. If the readings differ more than + 5% from the manometer readings, the Magnehelics<sup>R</sup> are recalibrated.

Barometer - After each field use, each barometer is checked against a mercury barometer.







CALIBRATION BY: BDR

METER BOX NUMBER: N14

DATE: 10-26-84

BAROMETRIC PRESSURE (P<sub>B</sub>): 29.86 IN. HG

\*DATE: \_\_\_\_\_

\*BAROMETRIC PRESSURE (P<sub>B</sub>): \_\_\_\_\_ IN. HG

STANDARD METER NUMBER: 1017057

COEFFICIENT (Y<sub>DS</sub>): 0.9942

NOMINAL FLOW RATE (Q) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V <sub>DS</sub> )	TEMP. (T <sub>DS</sub> )	TIME (t)	ORIFICE SETTING (ΔH)	GAS VOLUME (V <sub>D</sub> )	TEMP. (T <sub>D</sub> )
	FT <sup>3</sup>	°F	MIN.	IN. H <sub>2</sub> O	FT <sup>3</sup>	°F
0.4	4.185	72	10.00	0.50	4.202	75
	4.161	71	10.00	0.50	4.202	78
0.8	8.243	72	10.00	2.1	8.349	83
	8.201	72	10.00	2.1	8.368	88
1.2	12.517	72	10.00	4.8	12.620	92
	12.526	72	10.00	4.8	12.769	95

NOMINAL FLOW RATE (Q) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q <sub>D</sub> )	ORIFICE FACTOR	COEFF.	Δ H @
	CFM	(OF)	(Y <sub>D</sub> )	IN. H <sub>2</sub> O
0.4	0.4120	2.993	0.9945	1.622
	0.4104	3.001	0.9963	1.626
0.8	0.8114	6.180	0.9967	1.730
	0.8073	6.208	0.9985	1.732
1.2	1.2321	9.420	1.0012	1.687
	1.2330	9.445	1.0056	1.676
AVERAGE			1.000	1.68

$$\Delta H_e = \frac{0.0317 \cdot \Delta H}{P_b \cdot (t_d + 460)} \cdot \left[ \frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/13.6)}$$











TEMPERATURE SENSING EQUIPMENT CALIBRATION DATA

BAROMETRIC PRESSURE: 29.72 DATE: 1-16-84 CALIBRATED BY: YJC

MERCURY-IN-GLASS REFERENCE NUMBER: 1962175-ASTH3F AMBIENT TEMP.: 63

CALIBRATION SYSTEM USED	POTENTIOMETER I.D. NUMBER	THERMOCOUPLE/ THERMOMETER I.D. NUMBER	REFERENCE THERMOMETER TEMPERATURE		MEAN TEMPERATURE OF Hg COLUMN $T_m$ (°F)	THERMOCOUPLE/ THERMOMETER TEMPERATURE $T_t$ (°F)	$\Delta T^B$ $\leq 1.5\%$
			$T_o$ (°F)	$T_c$ (°F)			
ice water	01	4-3	33	33	51	32	0.2
	04	"	33	33	51	32	0.2
	05	"	33	33	51	34	0.4
	07	"	33	33	51	32	0.2
	09	"	33	33	51	32	0.2
	10	"	33	33	51	31	0.4
	Blue box	"	33	33	51	31	0.4
	Red box-1	"	33	33	51	31	0.4
	Red box-2	"	33	33	51	32	0.2
	ambient air	01	"	63	63	63	61
04		"	63	63	63	61	0.4
05		"	63	63	63	61	0.4
07		"	63	63	63	61	0.4
09		"	63	63	63	61	0.4
10		"	63	63	63	61	0.4
Blue box		"	63	63	63	62	0.2
Red box-1		"	63	63	63	61	0.4
Red box-2		"	63	63	63	62	0.2
hot water		01	"	212	213	127	213
	04	"	212	213	127	213	0.0
	05	"	212	213	127	212	0.1
	07	"	212	213	127	213	0.0
	09	"	212	213	127	213	0.0
	10	"	212	213	127	212	0.1
	Blue box	"	212	213	127	212	0.1
	Red box-1	"	212	213	127	213	0.0
	Red box-2	"	212	213	127	213	0.0

CORRECTED TEMPERATURE =  $T_c = T_o + 0.00009 (T_o - 20) (T_o - T_m)$

TEMPERATURE DIFFERENCE =  $\Delta T = \frac{[(T_c, ^\circ F + 460) - (T_t, ^\circ F + 460)]}{T_c, ^\circ F + 460} \times 100 \leq 1.5\%$

ENTROPY





TEMPERATURE SENSING EQUIPMENT CALIBRATION DATA

BAROMETRIC PRESSURE: 29.72 DATE: 1-16-84 CALIBRATED BY: HJC

MERCURY-IN-GLASS REFERENCE NUMBER: 1962175-ASTM3F AMBIENT TEMP.: 61

CALIBRATION SYSTEM USED	POTENTIOMETER I.D. NUMBER	THERMOCOUPLE/THERMOMETER I.D. NUMBER	REFERENCE THERMOMETER TEMPERATURE		MEAN TEMPERATURE OF Hg COLUMN $T_m$ (°F)	THERMOCOUPLE/THERMOMETER TEMPERATURE $T_c$ (°F)	$\Delta T^B$ $\leq 1.5\%$
			$T_o$ (°F)	$T_c$ (°F)			
ice water	DS-1	2-7	33	33	52	32	0.2
"	"	3-3-1	33	33	51	31	0.4
"	"	3-3-2	33	33	52	32	0.2
"	"	3-9	33	33	51	32	0.2
"	"	4-3	33	33	51	32	0.2
"	"	4-5	33	33	52	31	0.4
"	"	4-10	33	33	51	32	0.2
"	"	4-11	33	33	51	32	0.2
"	"	5-3	33	33	51	31	0.4
"	"	5-5	33	33	51	31	0.4
"	"	5-9	33	33	52	31	0.4
"	"	6	33	33	51	32	0.2
"	"	6-5	33	33	52	32	0.2
"	"	6-7	33	33	52	31	0.4
"	"	7-1	33	33	51	32	0.2
"	"	7-4	33	33	52	32	0.2
"	"	7-5	33	33	52	31	0.4
"	"	8-5	33	33	51	31	0.4
"	"	8-6	33	33	52	31	0.4
"	"	9	33	33	51	32	0.2
"	"	9-3	33	33	51	32	0.2
"	"	9-4	33	33	51	31	0.4
"	"	10-11	33	33	52	31	0.4
"	"	11	33	33	51	31	0.4
"	"	11-1	33	33	52	31	0.4
"	"	11-9	33	33	51	31	0.4
"	"	12-5	33	33	52	31	0.4
"	"	15-9	33	33	51	31	0.4
"	"	16-1	33	33	52	31	0.4
"	"	16-2	33	33	52	31	0.4

CORRECTED TEMPERATURE =  $T_c = T_o + .00009 (T_o - 20)(T_o - T_m)$

TEMPERATURE DIFFERENCE =  $\Delta T = \frac{[(T_c, ^\circ F + 460) - (T_c, ^\circ F + 460)]}{T_c, ^\circ F + 460} \times 100 \leq 1.5\%$

ENTROPY

TEMPERATURE SENSING EQUIPMENT CALIBRATION DATA

BAROMETRIC PRESSURE: 29.80 DATE: 1-17-84 CALIBRATED BY: HJC

MERCURY-IN-GLASS REFERENCE NUMBER: 1962175-ASTM3F AMBIENT TEMP.: 63

CALIBRATION SYSTEM USED	POTENTIOMETER I.D. NUMBER	THERMOCOUPLE/ THERMOMETER I.D. NUMBER	REFERENCE THERMOMETER TEMPERATURE		MEAN TEMPERATURE OF Hg COLUMN T <sub>m</sub> (°F)	THERMOCOUPLE/ THERMOMETER TEMPERATURE T <sub>c</sub> (°F)	ΔT <sup>B</sup> ≤1.5%
			T <sub>0</sub> (°F)	T <sub>c</sub> (°F)			
ambient air	DS-1	2-7	63	63	63	61	0.4
"	"	3-3-1	63	63	63	61	0.4
"	"	3-3-2	63	63	63	61	0.4
"	"	3-9	63	63	63	61	0.4
"	"	4-3	63	63	63	61	0.4
"	"	4-5	63	63	63	61	0.4
"	"	4-10	63	63	63	61	0.4
"	"	4-11	63	63	63	61	0.4
"	"	5-3	63	63	63	61	0.4
"	"	5-5	63	63	63	61	0.4
"	"	5-9	63	63	63	61	0.4
"	"	6	63	63	63	61	0.4
"	"	6-5	63	63	63	61	0.4
"	"	6-7	63	63	63	61	0.4
"	"	7-1	63	63	63	61	0.4
"	"	7-4	63	63	63	61	0.4
"	"	7-5	63	63	63	61	0.4
"	"	8-5	63	63	63	61	0.4
"	"	8-6	63	63	63	61	0.4
"	"	9	63	63	63	61	0.4
"	"	9-3	63	63	63	61	0.4
"	"	9-4	63	63	63	61	0.4
"	"	10-11	63	63	63	61	0.4
"	"	11	63	63	63	61	0.4
"	"	11-1	63	63	63	61	0.4
"	"	11-9	63	63	63	61	0.4
"	"	12-5	63	63	63	61	0.4
"	"	15-9	63	63	63	61	0.4
"	"	16-1	63	63	63	61	0.4
"	"	16-2	63	63	63	61	0.4

CORRECTED TEMPERATURE = T<sub>c</sub> = T<sub>0</sub> + .00009 (T<sub>0</sub>-20) (T<sub>0</sub>-T<sub>m</sub>)

TEMPERATURE DIFFERENCE = ΔT =  $\frac{[(T_c, ^\circ F + 460) - (T_m, ^\circ F + 460)]}{T_c, ^\circ F + 460} \times 100 \leq 1.5\%$

ENTROPY



TEMPERATURE SENSING EQUIPMENT CALIBRATION DATA

BAROMETRIC PRESSURE: 29.80 DATE: 1-17-84 CALIBRATED BY: YJC

MERCURY-IN-GLASS REFERENCE NUMBER: 1962175-ASTM3F AMBIENT TEMP.: 65

CALIBRATION SYSTEM USED	POTENTIOMETER I.D. NUMBER	THERMOCOUPLE/THERMOMETER I.D. NUMBER	REFERENCE THERMOMETER TEMPERATURE		MEAN TEMPERATURE OF Hg COLUMN T <sub>m</sub> (°F)	THERMOCOUPLE/THERMOMETER TEMPERATURE T <sub>c</sub> (°F)	ΔT <sup>B</sup> ≤1.5%
			T <sub>0</sub> (°F)	T <sub>c</sub> (°F)			
Boiling water	DS-1	2-7	213	214	142	215	-0.2
"	"	3-3-1	213	214	147	214	0
"	"	3-3-2	213	214	142	215	-0.2
"	"	3-9	213	214	140	215	-0.2
"	"	4-3	213	214	147	214	0
"	"	4-5	213	214	144	214	0
"	"	4-10	213	214	139	214	0
"	"	4-11	213	214	146	214	0
"	"	5-3	213	214	142	214	0
"	"	5-5	213	214	148	215	-0.2
"	"	5-9	213	214	142	215	-0.2
"	"	6	213	214	142	215	-0.2
"	"	6-5	213	214	149	214	0
"	"	6-7	213	214	149	214	0
"	"	7-1	213	214	149	215	-0.2
"	"	7-4	214	215	142	214	0.2
"	"	7-5	213	214	141	214	0
"	"	8-5	213	214	144	215	-0.2
"	"	8-6	213	214	144	215	-0.2
"	"	9	213	214	144	214	0
"	"	9-3	213	214	144	214	0
"	"	9-4	213	214	148	215	-0.2
"	"	10-11	214	215	143	216	-0.2
"	"	11	213	214	142	214	0
"	"	11-1	213	214	137	215	-0.2
"	"	11-9	213	214	146	215	-0.2
"	"	12-5	214	215	142	214	0.2
"	"	15-9	213	214	148	214	0
"	"	16-1	213	214	148	215	-0.2
"	"	16-2	213	214	148	214	0

CORRECTED TEMPERATURE = T<sub>c</sub> = T<sub>0</sub> + 0.00009 (T<sub>0</sub>-20) (T<sub>0</sub>-T<sub>m</sub>)

TEMPERATURE DIFFERENCE = ΔT =  $\frac{[(T_c, ^\circ F + 460) - (T_t, ^\circ F + 460)]}{T_c, ^\circ F + 460} \times 100 \leq 1.5\%$

ENTROPY

TEMPERATURE SENSING EQUIPMENT CALIBRATION DATA

BAROMETRIC PRESSURE: 29.80 DATE: 1-17-84 CALIBRATED BY: HJC

MERCURY-IN-GLASS REFERENCE NUMBER: 1962175-ASTM3F AMBIENT TEMP.: 69

CALIBRATION SYSTEM USED	POTENTIOMETER I.D. NUMBER	THERMOCOUPLE/ THERMOMETER I.D. NUMBER	REFERENCE THERMOMETER TEMPERATURE		MEAN TEMPERATURE OF Hg COLUMN T <sub>m</sub> (°F)	THERMOCOUPLE/ THERMOMETER TEMPERATURE T <sub>c</sub> (°F)	ΔT <sup>B</sup> ≤1.5%
			T <sub>O</sub> (°F)	T <sub>C</sub> (°F)			
Hot oil	DS-1	2-7	299	304	102	301	0.4
"	"	3-3-1	300	305	104	302	0.4
"	"	3-3-2	298	303	102	300	0.4
"	"	3-9	298	303	100	300	0.4
"	"	4-3	298	303	100	299	0.5
"	"	4-5	298	303	101	300	0.4
"	"	4-10	298	303	104	300	0.4
"	"	4-11	299	304	108	301	0.4
"	"	5-3	298	303	103	300	0.4
"	"	5-5	298	303	104	300	0.4
"	"	5-9	298	303	104	300	0.4
"	"	6	298	303	100	301	0.3
"	"	6-5	298	303	104	299	0.5
"	"	6-7	298	303	104	300	0.4
"	"	7-1	298	303	103	300	0.4
"	"	7-4	299	304	99	301	0.4
"	"	7-5	299	304	106	301	0.4
"	"	8-5	298	303	100	301	0.3
"	"	8-6	300	305	104	302	0.4
"	"	9	300	305	100	302	0.4
"	"	9-3	300	305	106	302	0.4
"	"	9-4	300	305	106	302	0.4
"	"	10-11	298	303	104	301	0.3
"	"	11	298	303	102	300	0.4
"	"	11-1	298	303	102	301	0.3
"	"	11-9	298	303	101	300	0.4
"	"	12-5	298	303	103	300	0.4
"	"	15-9	299	304	99	301	0.4
"	"	16-1	300	305	106	302	0.4
"	"	16-2	299	304	101	300	0.5

CORRECTED TEMPERATURE = T<sub>c</sub> = T<sub>O</sub> + .00009 (T<sub>O</sub>-20) (T<sub>O</sub>-T<sub>m</sub>)


TEMPERATURE DIFFERENCE = ΔT =  $\frac{[(T_c, ^\circ F + 460) - (T_o, ^\circ F + 460)]}{T_c, ^\circ F + 460} \times 100 \leq 1.5\%$

ENTROPY

PITOT TUBE INSPECTION DATA SHEET

Pre-sample Date 2-20-84

Post Sample Date \_\_\_\_\_



YES	level?	
NO	obstructions?	
NO	damaged?	
2°	$-10^\circ < \alpha_1 < +10^\circ$	
0°	$-10^\circ < \alpha_2 < +10^\circ$	
1°	$-5^\circ < \beta_1 < +5^\circ$	
1°	$-5^\circ < \beta_2 < +5^\circ$	
1°	γ	
0	θ	
.890	A	
.458	$1.05 D_t < P_a < 1.5 D_t$	
.432	$1.05 D_t < P_b < 1.5 D_t$	
.375	$3/16'' \leq D_t \leq 3/8''$	
.017	$A \tan \gamma < 0.125''$	
0	$A \tan \theta < 0.03125''$	
YES	$P_a = P_b \pm 0.063''$	

Comments: \_\_\_\_\_

I certify that pitot tube/probe number 4-1 meets or exceeds all specifications, criteria and/or applicable design features\* and is hereby assigned a pitot tube calibration factor of 0.84.

Signature Guido J. Carrara  
Date 2-20-84

\*See 40 CFR 60, Vol. 42, No. 160, Method 2. Verify the minimum 2 inch setback of the thermocouple and the minimum 3/4 inch separation between the pitot tube and the nozzle as shown at the top of this page.


PITOT TUBE INSPECTION DATA SHEET

Pre-sample

Post Sample

Date 1/19/84

Date \_\_\_\_\_



YES	level?	
No	obstructions?	
No	damaged?	
4°	$-10^\circ < \alpha_1 < +10^\circ$	
3°	$-10^\circ < \alpha_2 < +10^\circ$	
0°	$-5^\circ < \beta_1 < +5^\circ$	
2°	$-5^\circ < \beta_2 < +5^\circ$	
1°	$\gamma$	
0	$\theta$	
.892	A	
.474	$1.05 D_t < P_a < 1.5 D_t$	
.418	$1.05 D_t < P_b < 1.5 D_t$	
.375	$3/16" \leq D_t \leq 3/8"$	
.016	$A \tan \gamma < 0.125"$	
0	$A \tan \theta < 0.03125"$	
YES	$P_a = P_b \pm 0.063"$	

Comments: \_\_\_\_\_

I certify that pitot tube/probe number 4-3 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature

Patrick L. Owen

Date


1/19/84

\*See 40 CFR 60, Vol. 42, No. 160, Method 2. Verify the minimum 2 inch setback of the thermocouple and the minimum 3/4 inch separation between the pitot tube and the nozzle as shown at the top of this page.

PITOT TUBE INSPECTION DATA SHEET

Pre-sample Date 1/19/84

Post Sample Date \_\_\_\_\_



YES	level?	
No	obstructions?	
No	damaged?	
4°	$-10^\circ < \alpha_1 < +10^\circ$	
5°	$-10^\circ < \alpha_2 < +10^\circ$	
3°	$-5^\circ < \beta_1 < +5^\circ$	
3°	$-5^\circ < \beta_2 < +5^\circ$	
1°	$\gamma$	
0	$\theta$	
.778	A	
.398	$1.05 D_t < P_a < 1.5 D_t$	
.380	$1.05 D_t < P_b < 1.5 D_t$	
.375	$3/16" < D_t < 3/8"$	
.014	$A \tan \gamma < 0.125"$	
0	$A \tan \theta < 0.03125"$	
YES	$P_a = P_b \pm 0.063"$	

Comments: \_\_\_\_\_

I certify that pitot tube/probe number 4-4 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature Patrick L. Owen

Date 1/19/84

\*See 40 CFR 60, Vol. 42, No. 160, Method 2. Verify the minimum 2 inch setback of the thermocouple and the minimum 3/4 inch separation between the pitot tube and the nozzle as shown at the top of this page.


PITOT TUBE INSPECTION DATA SHEET

Pre-sample

Post Sample

Date 1/19/84

Date \_\_\_\_\_



YES	level?	
No	obstructions?	
No	damaged?	
4°	$-10^\circ < \alpha_1 < +10^\circ$	
3°	$-10^\circ < \alpha_2 < +10^\circ$	
2°	$-5^\circ < \beta_1 < +5^\circ$	
2°	$-5^\circ < \beta_2 < +5^\circ$	
0°	$\gamma$	
0°	$\theta$	
.884	A	
.443	$1.05 D_t < P_a < 1.5 D_t$	
.441	$1.05 D_t < P_b < 1.5 D_t$	
.375	$3/16" \leq D_t \leq 3/8"$	
0	$A \tan \gamma < 0.125"$	
0	$A \tan \theta < 0.03125"$	
YES	$P_a = P_b \pm 0.063"$	

Comments: \_\_\_\_\_

I certify that pitot tube/probe number 4-5 meets or exceeds all specifications, criteria and/or applicable design features\* and is hereby assigned a pitot tube calibration factor of 0.84.

Signature \_\_\_\_\_




*Patrick L. Owen*

Date \_\_\_\_\_

1/19/84

\*See 40 CFR 50, Vol. 42, No. 160, Method 2. Verify the minimum 2 inch setback of the thermocouple and the minimum 3/4 inch separation between the pitot tube and the nozzle as shown at the top of this page.

PITOT TUBE INSPECTION DATA SHEET



level?	YES
obstructions?	No
damaged?	No
$-10^\circ < \alpha_1 < +10^\circ$	$-2^\circ$
$-10^\circ < \alpha_2 < +10^\circ$	$0^\circ$
$-5^\circ < \beta_1 < +5^\circ$	$2^\circ$
$-5^\circ < \beta_2 < +5^\circ$	$1^\circ$
$\gamma$	$0^\circ$
$\theta$	$0^\circ$
A	.848
$1.05 D_t < p_a < 1.5 D_t$	.431
$1.05 D_t < p_b < 1.5 D_t$	.417
$3/16" < D_c < 3/8"$	.369
$A \tan \gamma < 0.125"$	0
$A \tan \theta < 0.03125"$	0
$p_a = p_b + 0.063"$	Yes

Comments:




I certify that pitot tube/probe number S-3 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature Bruce Hawks


Date 10/5/84

\*SEE 40 CFR 60, VOL 42 NO. 160 METHOD D 2. VERIFY THE MINIMUM 2 INCH SETBACK OF THE THERMOCOUPLE AND THE MINIMUM 3/4 INCH SEPARATION BETWEEN THE PITOT TUBE AND THE NOZZLE AS SHOWN AT THE TOP OF THIS PAGE.

PITOT TUBE INSPECTION DATA SHEET



DEGREE INDICATING LEVEL POSITION FOR DETERMINING  $\alpha_1$  AND  $\alpha_2$



DEGREE INDICATING LEVEL POSITION FOR DETERMINING  $\beta_1$  AND  $\beta_2$

level?	YES
obstructions?	NO
damaged?	NO
$-10^\circ < \alpha_1 < +10^\circ$	0'
$-10^\circ < \alpha_2 < +10^\circ$	1'
$-5^\circ < \beta_1 < +5^\circ$	3'
$-5^\circ < \beta_2 < +5^\circ$	0'
$\gamma$	0'
$\theta$	0'
A	0.863
$1.05 D_t < p_a < 1.5 D_t$	.412
$1.05 D_t < p_b < 1.5 D_t$	.451
$3/16" < D_t < 3/8"$	.374
$A \tan \gamma < 0.125"$	0
$A \tan \theta < 0.03125"$	0
$p_a = p_b \pm 0.063"$	YES

Comments:

I certify that pitot tube/probe number 5-4 meets or exceeds all specifications, criteria and/or applicable design features and is hereby assigned a pitot tube calibration factor of 0.84.

Signature: Bruce Hawks

Date: 10/5/84

\*SEE 40 CFR 60, VOL 42 NO. 160 METHOD D 2. VERIFY THE MINIMUM 2 INCH SETBACK OF THE THERMOCOUPLE AND THE MINIMUM 3/4 INCH SEPARATION BETWEEN THE PITOT TUBE AND THE NOZZLE AS SHOWN AT THE TOP OF THIS PAGE.



CALIBRATION BY: BDR METER BOX NUMBER: N5  
 DATE: 6-21-85 BAROMETRIC PRESSURE (P<sub>B</sub>): 29.62 IN. HG  
 \*DATE: \_\_\_\_\_ \*BAROMETRIC PRESSURE (P<sub>B</sub>): \_\_\_\_\_ IN. HG  
 STANDARD METER NUMBER: 1017057 COEFFICIENT (Y<sub>DS</sub>): 0.9942


POST-TEST METER BOX CALIBRATION

NOMINAL FLOW RATE (Q̃) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V <sub>DS</sub> ) FT <sup>3</sup>	TEMP. (T <sub>DS</sub> ) °F	TIME (θ) MIN.	ORIFICE SETTING (ΔH) IN. H <sub>2</sub> O	GAS VOLUME (V <sub>D</sub> ) FT <sup>3</sup>	TEMP. (T <sub>D</sub> ) °F
		7.999	73	10.00	2.0	8.003
	7.981	73	10.00	2.0	8.011	80
	7.976	73	10.00	2.0	8.046	84
VACUUM = <u>0</u> IN. HG						

METER BOX METERING SYSTEM				
NOMINAL FLOW RATE (Q̃) CFM	FLOW RATE (Q <sub>D</sub> ) CFM	ORIFICE FACTOR (OF)	COEFF. (Y <sub>D</sub> )	Δ H @ IN. H <sub>2</sub> O
	0.7796	6.022	0.9962	1.790
	0.7778	6.038	0.9985	1.789
	0.7773	6.061	1.0009	1.778
AVERAGE			0.999	1.79

$$\Delta H_b = \frac{0.0217 \cdot \Delta P}{F_b \cdot (t_d + 460)} \cdot \left[ \frac{(t_{ds} + 460) \cdot \rho}{y_{ds} \cdot v_{ds}} \right]^2$$

$$y_d = \frac{y_{ds} \cdot v_{ds} \cdot (t_d + 460) \cdot P_b}{v_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/29.6)}$$



SCHEMATIC OF EQUIPMENT SET-UP FOR FULL AND POST-TEST METER BOX CALIBRATIONS

CALIBRATION BY: BDR

METER BOX NUMBER: N6

DATE: 6-21-85

BAROMETRIC PRESSURE (P<sub>B</sub>): 29.62 IN. HG

\*DATE: \_\_\_\_\_

\*BAROMETRIC PRESSURE (P<sub>B</sub>): \_\_\_\_\_ IN. HG

STANDARD METER NUMBER: 1017057

COEFFICIENT (Y<sub>DS</sub>): 0.9942


POST-TEST METER BOX CALIBRATION

NOMINAL FLOW RATE (Q) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V <sub>DS</sub> ) FT <sup>3</sup>	TEMP. (T <sub>DS</sub> ) OF	TIME (t) MIN.	ORIFICE SETTING (ΔH) IN. H <sub>2</sub> O	GAS VOLUME (V <sub>D</sub> ) FT <sup>3</sup>	TEMP. (T <sub>D</sub> ) OF
		7.988	73	10.00	1.9	7.983
	7.969	74	10.00	1.9	8.007	82
	7.946	74	10.00	1.9	8.066	87
VACUUM = <u>5</u> IN. HG						

NOMINAL FLOW RATE (Q) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q <sub>D</sub> ) CFM	ORIFICE FACTOR (OF)	COEFF. (Y <sub>D</sub> )	Δ H @ IN. H <sub>2</sub> O
	0.7785	5.875	0.9994	1.702
	0.7752	5.896	0.9996	1.704
	0.7730	5.923	0.9985	1.699
AVERAGE			0.999	1.70

$$\Delta H_e = \frac{0.0317 \cdot \Delta F}{F_b \cdot (t_d + 460)} \cdot \left[ \frac{(t_{ds} + 460) \cdot \rho}{V_{ds} \cdot V_{ds}} \right]^2$$

$$V_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_c + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/13.6)}$$



SCHMATIC OF EQUIPMENT SET-UP FOR FULL AND POST-TEST METER BOX CALIBRATIONS

CALIBRATION BY: BDR

METER BOX NUMBER: N8

DATE: 6-21-85

BAROMETRIC PRESSURE (P<sub>B</sub>): 29.62 IN. HG

\*DATE: \_\_\_\_\_

\*BAROMETRIC PRESSURE (P<sub>B</sub>): \_\_\_\_\_ IN. HG

STANDARD METER NUMBER: 1017057

COEFFICIENT (Y<sub>DS</sub>): 0.9942


POST-TEST METER BOX CALIBRATION

NOMINAL FLOW RATE (Q̇) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V <sub>DS</sub> ) FT <sup>3</sup>	TEMP. (T <sub>DS</sub> ) °F	TIME (θ) MIN.	ORIFICE SETTING (ΔH) IN. H <sub>2</sub> O	GAS VOLUME (V <sub>D</sub> ) FT <sup>3</sup>	TEMP. (T <sub>D</sub> ) °F
		10.506	74	10.00	3.2	10.568
	10.498	74	10.00	3.2	10.603	86
	10.477	74	10.00	3.2	10.689	89
VACUUM = <u>12</u> IN. HG						

METER BOX METERING SYSTEM				
NOMINAL FLOW RATE (Q̇) CFM	FLOW RATE (Q <sub>D</sub> ) CFM	ORIFICE FACTOR (OF)	COEFF. (Y <sub>D</sub> )	Δ H θ IN. H <sub>2</sub> O
	1.0220	7.631	0.9898	1.661
	1.0212	7.680	0.9985	1.642
	1.0192	7.701	0.9940	1.640
AVERAGE			0.994	1.65

$$\Delta E_{\theta} = \frac{0.0317 \cdot \Delta H}{P_b \cdot (t_d + 460)} \cdot \left[ \frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/13.6)}$$



SCHMATIC OF EQUIPMENT SET-UP FOR FULL AND POST-TEST METER BOX CALIBRATIONS

CALIBRATION BY: BDR METER BOX NUMBER: N14  
 DATE: 6-24-85 BAROMETRIC PRESSURE (P<sub>B</sub>): 29.62 IN. HG  
 \*DATE: \_\_\_\_\_ \*BAROMETRIC PRESSURE (P<sub>B</sub>): \_\_\_\_\_ IN. HG  
 STANDARD METER NUMBER: 1017057 COEFFICIENT (Y<sub>DS</sub>): 0.9942

POST-TEST METER BOX CALIBRATION


NOMINAL FLOW RATE (Q̃) CFM	STANDARD DRY GAS METER			METER BOX METERING SYSTEM		
	GAS VOLUME (V <sub>DS</sub> ) FT <sup>3</sup>	TEMP. (T <sub>DS</sub> ) °F	TIME (θ) MIN.	ORIFICE SETTING (ΔH) IN. H <sub>2</sub> O	GAS VOLUME (V <sub>D</sub> ) FT <sup>3</sup>	TEMP. (T <sub>D</sub> ) °F
	9.402	74	10.00	2.6	9.401	80
9.382	75	10.00	2.6	9.438	85	
9.357	75	10.00	2.6	9.513	91	

VACUUM = 11 IN. HG

NOMINAL FLOW RATE (Q̃) CFM	METER BOX METERING SYSTEM			
	FLOW RATE (Q <sub>D</sub> ) CFM	ORIFICE FACTOR (OF)	COEFF. (Y <sub>D</sub> )	Δ H @ IN. H <sub>2</sub> O
	0.9146	6.885	0.9990	1.682
	0.9110	6.917	1.0003	1.680
	0.9085	6.955	1.0007	1.670
	AVERAGE		1.0000	1.68

$$\Delta H_e = \frac{0.0317 \cdot \Delta F}{P_b \cdot (t_d + 460)} \cdot \left[ \frac{(t_{ds} + 460) \cdot \theta}{Y_{ds} \cdot V_{ds}} \right]^2$$

$$Y_d = \frac{Y_{ds} \cdot V_{ds} \cdot (t_d + 460) \cdot P_b}{V_d \cdot (t_{ds} + 460) \cdot (P_b + \Delta H/23.6)}$$



SCHEMATIC OF EQUIPMENT SET-UP FOR FULL AND POST-TEST METER BOX CALIBRATIONS



Date: 6/20/85  
 Client: EMB  
 P<sub>bar</sub>: 29.2 in. Hg.  
 ΔH<sub>0</sub>: 1.67

Time: 08:17 - 08:27  
 Auditor: WSN  
 Meter Box No.: N.6  
 Pretest Y: 1.011

Orifice gauge reading ΔH <sub>0</sub> in. H <sub>2</sub> O	Dry gas meter reading V <sub>i</sub> /V <sub>f</sub> ft <sup>3</sup>	Meter Temperatures	Duration of run min.
		T <sub>i</sub> /T <sub>f</sub>	
1.67	65.400	62	10
	72.778	70	

Dry Gas meter volume V ft <sup>3</sup>	Meter temperature average T <sub>avg</sub>	Pretest Y 0.97Y 1.03Y	Calculated Y <sub>c</sub>	Audit 0.97Y < Y <sub>c</sub> < 1.03Y Acceptable
7.378	66	0.9807	1.027	YES
		1.041		

Calculated Y<sub>c</sub>

$$\frac{10}{V_m} \left[ \frac{0.0319 (t_m + 460)}{P_{bar}} \right]^{1/2} = \frac{10}{(7.378)} \left[ \frac{0.0319 (66 + 460)}{(29.2)} \right]^{1/2}$$

Date: 6/20/85

Time: 08:22 - 08:32

Client: EMB

Auditor: WSN

P<sub>bar</sub>: 29.2 in. Hg.

Meter Box No.: N. 8

ΔH@: 1.61

Pretest Y: .998

Orifice gauge reading ΔH@ in. H <sub>2</sub> O	Dry gas meter reading $V_i/V_f$ ft <sup>3</sup>	Meter Temperatures	Duration of run min.
		T <sub>i</sub> /T <sub>f</sub>	
1.61	276.550	64	10
	284.043	71	

Dry Gas meter volume $V_{m3}$ ft <sup>3</sup>	Meter temperature average $t_{GH}$ °F	Pretest Y 0.97Y 1.03Y	Calculated Y <sub>c</sub>	Audit 0.97Y < Y <sub>c</sub> < 1.03Y Acceptable
7.493	68	.9681	1.014	YES
		1.028		

Calculated Y<sub>c</sub>

$$\frac{10}{V_m} \left[ \frac{0.0319 (t_m + 460)}{P_{bar}} \right]^{1/2} = \frac{10}{(7.493)} \left[ \frac{0.0319 (68 + 460)}{(29.2)} \right]^{1/2}$$

**ENTROPY**

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/18/85  
 Sample location SCRUBBER INLET Run number 2  
 Sample recovery person HL Recovery date 6/18/85  
 Filter(s) number I-02-5 (0.4576)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>186.0</u> ml (g)	Final wt <u>251.2</u> g <u>        </u> g
Initial volume (wt) <u>200.0</u> ml (g)	Initial wt <u>200.0</u> g <u>        </u> g
Net volume (wt) <u>-14.0</u> ml (g)	Net wt <u>51.2</u> g <u>        </u> g
Total moisture <u>37.2</u> g	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number #2 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>#2 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO BLANK</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked _____	

Remarks \_\_\_\_\_  
 \_\_\_\_\_  
 Date of laboratory custody 6/21/85  
 Laboratory personnel taking custody \_\_\_\_\_  
 Remarks \_\_\_\_\_  
 \_\_\_\_\_

**ENTROPY**



SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/19/85  
 Sample location SCRUBBER INLET Run number 5  
 Sample recovery person HL Recovery date 6/19/85  
 Filter(s) number T-02-3 (0.4721)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>215.0</u> ml (g)	Final wt <u>250.3</u> g <u>-</u> g
Initial volume (wt) <u>200.0</u> ml (g)	Initial wt <u>200.0</u> g <u>-</u> g
Net volume (wt) <u>15.0</u> ml (g)	Net wt <u>50.3</u> g <u>-</u> g
Total moisture <u>65.3</u> g	
Color of silica gel <u>RNK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number #5 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>#25 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO RINSE BLANK</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_

Date of laboratory custody 6/21/85

Laboratory personnel taking custody \_\_\_\_\_

Remarks \_\_\_\_\_

**ENTROPY**

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/20/85  
 Sample location SCRUBBER INET Run number 8  
 Sample recovery person HL Recovery date 6/20/85  
 Filter(s) number T-0.2-1 (0.4696)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>208.0 ml (g)</u>	Final wt <u>254.2 g</u> <u>-</u> g
Initial volume (wt) <u>200.0 ml (g)</u>	Initial wt <u>200.0 g</u> <u>-</u> g
Net volume (wt) <u>8.0 ml (g)</u>	Net wt <u>54.2 g</u> <u>-</u> g
Total moisture <u>62.2 g</u>	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number # 8 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u># 8 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO BLANK</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_

Date of laboratory custody 6/21/85

Laboratory personnel taking custody \_\_\_\_\_

Remarks \_\_\_\_\_

**ENTROPY**

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/18/85  
 Sample location SCRUBBER OUTLET Run number 3  
 Sample recovery person HL Recovery date 6/18/85  
 Filter(s) number T-0.2-52 (0.7180)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>234.0</u> ml (g)	Final wt <u>251.1</u> g <u>    </u> g
Initial volume (wt) <u>200.0</u> ml (g)	Initial wt <u>200.0</u> g <u>    </u> g
Net volume (wt) <u>34.0</u> ml (g)	Net wt <u>51.1</u> g <u>    </u> g
Total moisture <u>85.1</u> g	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number #3 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>#3 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO BLANK</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_

Date of laboratory custody 6/21/85

Laboratory personnel taking custody \_\_\_\_\_

Remarks \_\_\_\_\_

**ENTROPY**

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/19/85  
 Sample location SCRUBBER OUTLET Run number 6  
 Sample recovery person HL Recovery date 6/19/85  
 Filter(s) number T-0.2-53 (0.6983)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>248.0</u> ml (g)	Final wt <u>255.3</u> g <u>-</u> g
Initial volume (wt) <u>200.0</u> ml (g)	Initial wt <u>200.0</u> g <u>-</u> g
Net volume (wt) <u>48.0</u> ml (g)	Net wt <u>55.3</u> g <u>-</u> g
Total moisture <u>103.3</u> g	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number #6 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>#6 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_  
 \_\_\_\_\_  
 Date of laboratory custody 6/21/85  
 Laboratory personnel taking custody \_\_\_\_\_  
 Remarks \_\_\_\_\_  
 \_\_\_\_\_

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/20/85  
 Sample location SCRUBBER OUTLET Run number 9  
 Sample recovery person WSN Recovery date 6/20/85  
 Filter(s) number T-0:2-51 (0.7526)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>252.0</u> ml (g)	Final wt <u>252.6</u> g <u>-</u> g
Initial volume (wt) <u>200.0</u> ml (g)	Initial wt <u>200.0</u> g <u>-</u> g
Net volume (wt) <u>52.0</u> ml (g)	Net wt <u>52.6</u> g <u>-</u> g
Total moisture <u>104.6</u> g	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number #9 FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>#9 RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_

Date of laboratory custody 6/21/85

Laboratory personnel taking custody \_\_\_\_\_

Remarks \_\_\_\_\_

**ENTROPY**

SAMPLE RECOVERY AND INTEGRITY DATA FORM

Plant C.S. OHM Sample date 6/19/85  
 Sample location SCRUBBER INLET Run number SR  
 Sample recovery person HL Recovery date 6/19/85  
 Filter(s) number T- 0.2-2 (0.4973)

MOISTURE

<u>Impingers</u>	<u>Silica gel</u>
Final volume (wt) <u>200.0 ml (g)</u>	Final wt <u>267.2 g - 160.4 g</u>
Initial volume (wt) <u>200.0 ml (g)</u>	Initial wt <u>200.0 g - 200.0 g</u>
Net volume (wt) <u>0.0 ml (g)</u>	Net wt <u>67.2 g - 39.6 g</u>
Total moisture <u>27.6 g</u>	
Color of silica gel <u>PINK</u>	
Description of impinger water <u>CLEAR</u>	

RECOVERED SAMPLE

Blank filter container number CSO BLANK Sealed   
 Filter container number # SR FILTER Sealed   
 Description of particulate on filter \_\_\_\_\_

Acetone rinse container number <u>SR RINSE</u>	Liquid level marked? <input checked="" type="checkbox"/>
Acetone blank container number <u>CSO BLANK</u>	Liquid level marked? <input checked="" type="checkbox"/>
Samples stored and locked <input checked="" type="checkbox"/>	

Remarks \_\_\_\_\_

Date of laboratory custody 6/21/85

Laboratory personnel taking custody \_\_\_\_\_

Remarks \_\_\_\_\_

**ENTROPY**

CUSTODY SHEET FOR REAGENT BOX # 0216

Date of Makeup 6/14 Initials MSJ Locked?

Individual Tare of Reagent: 300 mls. of DISTILLED H<sub>2</sub>O

Individual Tare of Reagent: \_\_\_\_\_ mls. of \_\_\_\_\_

Individual Silica Gel Tare Weight 200 gms.

PLANT NAME C.S. OHM

SAMPLING LOCATION SCRUBBER INLET

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked
1	6/12/85	HL	<input checked="" type="checkbox"/>	6/18/85	100	HL	<input checked="" type="checkbox"/>
4	6/19/85	HL	<input checked="" type="checkbox"/>	6/19/85	100	HL	<input checked="" type="checkbox"/>
7	6/20/85	HL	<input checked="" type="checkbox"/>	6/20/85	100	HL	<input checked="" type="checkbox"/>

Received in Lab Date 6/21 Initials J.F.J. Locked?

Zero & Span Balance Initials J.F.J.

Sampling Method: MOISTURES

Filter # \_\_\_\_\_ Tare Weight (mgms) \_\_\_\_\_ Used on Test \_\_\_\_\_

Remarks:


CUSTODY SHEET FOR REAGENT BOX # 0228

Date of Makeup 6/13 Initials GR Locked?

Individual Tare of Reagent: 200 mls. of DI H<sub>2</sub>O

Individual Tare of Reagent: \_\_\_\_\_ mls. of \_\_\_\_\_

Individual Silica Gel Tare Weight 200 gms.

PLANT NAME C.S. OHM

SAMPLING LOCATION Scrubber Inlet

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
2	6/18/85	HL	<input checked="" type="checkbox"/>	6/18/85	100	HL	<input checked="" type="checkbox"/>
5	6/19/85	HL	<input checked="" type="checkbox"/>	6/19/85	95	HL	<input checked="" type="checkbox"/>
8	6/20/85	HL	<input checked="" type="checkbox"/>	6/20/85	90	HL	<input checked="" type="checkbox"/>

Received in Lab Date 6/21 Initials MSY Locked?

Zero & Span Balance Initials MSY

Sampling Method: M5

Filter # Tare Weight (mgms) Used on Test

Remarks: Run 2 total H<sub>2</sub>O 186 mls  
Net - 14 mls

<u>T-0.2-5</u>	<u>.4576</u>	<u>2</u>
<u>T-0.2-3</u>	<u>.4721</u>	<u>5</u>
<u>T-0.2-1</u>	<u>.4696</u>	<u>8</u>



CUSTODY SHEET FOR REAGENT BOX # 0224

Date of Makeup 6/15 Initials MSJ Locked?

Individual Tare of Reagent: 200 mls. of distilled H<sub>2</sub>O

Individual Tare of Reagent: \_\_\_\_\_ mls. of \_\_\_\_\_

Individual Silica Gel Tare Weight 200 gms.

PLANT NAME C.S. OHM Detroit

SAMPLING LOCATION Scrubber Outlet Stack

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
3	6/18/85	HL	<input checked="" type="checkbox"/>	6/18/85	100	HL	<input checked="" type="checkbox"/>
6	6/19/85	HL	<input checked="" type="checkbox"/>	6/19/85	95	HL	<input checked="" type="checkbox"/>
9	6/20/85	HL	<input checked="" type="checkbox"/>	6/20/85	95	WSN	<input checked="" type="checkbox"/>

Received in Lab Date 6/21 Initials J.F.J. Locked?

Zero & Span Balance Initials J.F.J.

Sampling Method: M.S. w/ back half

Filter # Tare Weight (mgms) Used on Test

Remarks: Run 3 - 34 mls Net H<sub>2</sub>O catch  
 Min teflon Filter  
 6 - 48 mls Net H<sub>2</sub>O catch

T-0.252	.7180	3
T-0.253	.6983	6
T-0.2-51	.7526	9

CUSTODY SHEET FOR REAGENT BOX # 0218

Date of Makeup 6/13 Initials GR Locked?

Individual Tare of Reagent: 200 mls. of DI H<sub>2</sub>O

Individual Tare of Reagent: \_\_\_\_\_ mls. of \_\_\_\_\_

Individual Silica Gel Tare Weight 200 gms.

PLANT NAME C.S. OHM

SAMPLING LOCATION Scrubber Inlet

Run Number	Date Used	Initials	Locked?	Date Cleanup	% S. Gel Spent	Initials	Locked?
<u>Inlet Special</u>	<u>6/19/85</u>	<u>HL</u>	<input checked="" type="checkbox"/>	<u>6/20/85</u>	<u>100</u>	<u>HL</u>	<input checked="" type="checkbox"/>

Received in Lab Date 6/21 Initials J.F.J. Locked?

Zero & Span Balance Initials J.F.J.

Sampling Method: \_\_\_\_\_

Filter # \_\_\_\_\_ Tare Weight (mgms) \_\_\_\_\_ Used on Test \_\_\_\_\_

Remarks: Double charge Silica gel wet + busted

Filter #	Tare Weight (mgms)	Used on Test
<u>T-0.2-2</u>	<u>.4973</u>	<u>SPECIAL INLET</u>

APPENDIX E  
MRI PROCESS DATA







TEST NO. 1--CURRENT USAGE CALCULATIONS

Clock time	Seconds of operation		Current, amperes	Ampere-seconds ( $\times 10^3$ )	
	Inlet	Outlet		Inlet	Outlet
1000	90 540	93 561	1,500 12,500	135 6,750	140 7,010
1030	69 415	69 415	1,500 12,500	104 5,190	104 5,190
1100	104 623	104 623	1,500 12,500	156 7,790	156 7,790
1130	104 623	104 623	1,600 16,000	166 9,970	166 9,970
1200	104 623	104 623	1,600 16,000	166 9,970	166 9,970
1230	104 623	104 623	1,500 12,500	156 7,790	156 7,790
1300	104 623	104 623	1,500 12,500	156 7,790	156 7,790
1330	104 623	104 623	1,500 12,500	156 7,790	156 7,790
1400	104 623	104 623	1,500 12,500	156 7,790	156 7,790
1430	104 623	104 623	1,600 16,000	166 9,970	166 9,970
1500	100 602	17 104	1,500 12,500	150 7,525	26 1,300
TOTAL				90,000	83,900

$$\frac{90,000 \text{ amp-sec}}{7632 \text{ sec}} = 11.79 \text{ amp/sec}$$

$$(11.79 \text{ amp/sec}) \left( \frac{60 \text{ sec}}{\text{min}} \right) \left( \frac{60 \text{ min}}{\text{hr}} \right)$$

$$= 42,453 \text{ amp/hr.}$$

$$\frac{83,900 \text{ amp-sec}}{7075 \text{ sec}} = 11.86$$

$$(11.86) \left( \frac{3600}{\text{hr}} \right) = 42,696$$

TEST NO. 3--CURRENT USAGE CALCULATIONS

Clock time	Seconds of operation		Current, amperes	Ampere-seconds ( $\times 10^3$ )	
	Inlet	Outlet		Inlet	Outlet
0830	17 104	17 104	1,500 13,200	26 1,370	26 1,370
0900	104 623	104 623	1,500 12,800	156 7,970	156 7,970
0930	104 623	104 623	1,500 12,300	156 7,660	156 7,660
1000	104 623	104 623	1,800 16,000	187 9,970	187 9,970
1045	52 312	52 312	1,700 16,500	88 5,150	88 5,150
1100	104 623	104 623	1,700 16,500	177 10,280	177 10,280
1130	104 623	104 623	1,700 16,500	177 10,280	177 10,280
1200	104 623	104 623	1,300 12,800	135 7,970	135 7,970
1230	104 623	104 623	1,300 12,400	135 7,730	135 7,730
1300	104 623	104 623	1,300 13,000	135 8,100	135 8,100
1330	104 623	69 415	1,600 15,400	166 9,590	110 6,390
1400	69 415	-- --	1,800 16,600	124 6,890	-- --
TOTAL	7,512	5,785		94,620	84,350



TEST NO. 2--CURRENT USAGE CALCULATIONS

Clock time	Seconds of operation		Current, amperes	Ampere-seconds ( $\times 10^3$ )	
	Inlet	Outlet		Inlet	Outlet
0830	73 436	80 478	1,500 12,500	110 5,450	120 5,980
0900	104 623	104 623	1,500 12,800	156 7,980	156 7,980
0930	104 623	104 623	1,500 12,500	156 7,980	156 7,980
1000	104 623	104 623	1,500 12,800	156 7,980	156 7,980
1030	34 208	34 208	1,500 12,800	51 2,660	51 2,660
1100	104 623	104 623	1,800 14,000	187 8,720	187 8,720
1130	104 623	104 623	1,800 14,000	187 8,720	187 8,720
1200	104 623	104 623	1,800 12,000	187 7,480	187 7,480
1230	104 623	104 623	1,500 11,000	156 6,850	156 6,850
1300	104 623	104 623	1,500 10,500	156 6,540	156 6,540
1330	121 727	21 125	1,500 10,500	182 7,630	32 1,310
TOTAL				79,590	73,740

$$\frac{94,620}{7512} = 12.60$$

$$(12.60)(3600) = 45,345$$


---


$$\frac{84,350}{6785} = (12.43)(3600) = 44,748$$

$$\frac{79,590 \text{ amp}}{7415 \text{ sec}} = 10.73$$

$$(10.73)(3600) = 38,641$$

E-7

$$\frac{73,740}{6762} = 10.91$$

$$(10.91)(3600) = 39,258$$

APPENDIX F

TEST PARTICIPANTS AND OBSERVERS

TEST PARTICIPANTS AND OBSERVERS

Name	Organization	Responsibility
Willis Nesbit	Entropy Environmentalists, Inc.	Field Coordinator
Henry Long	Entropy Environmentalists, Inc.	Sampling Team Leader
Gerry Carty	Entropy Environmentalists, Inc.	Sampling Team Leader
Bobby Bridges	Entropy Environmentalists, Inc.	Engineering Technician
Bill DeWees	Entropy Environmentalists, Inc.	Quality Assurance Observer
Barb Duletsky	Midwest Research Institute	Monitor Process Operation
Dan Bivins	EPA, Emission Measurement Branch	EPA Task Manager
Al Vervaert	EPA, Industrial Studies Branch	EPA Task Manager