


# Review of Compressor Station Measurements

EPA Emissions Inventory Conference  
Greenhouse Gases Session  
September 28, 2010



**URS**



# **Preliminary Results, Phase 1**

## **Fugitive Emission Measurements of Selected Components at Natural Gas Compressor Stations**

**Matthew R. Harrison**

**URS Corporation**

**9400 Amberglen Blvd, Austin, Texas 78729**

**[matt\\_harrison@urscorp.com](mailto:matt_harrison@urscorp.com)**

# Project Management

- Dr. David Allen, UT Project Manager
- Lisa Hanle, EPA Project Manager
- Matt Harrison, URS Corp Team  
(former project manager for GRI/EPA project)

# Overall Project Goals

(from initial project report in 2008)

- Update emission factors for
  - **Production:** Well clean-ups, completion flaring, well workovers, pipelines leaks
  - **Processing:** fugitive emissions from reciprocating and centrifugal compressors
  - **Transmission and Storage:** *fugitive emissions from reciprocating and centrifugal compressors*, pneumatic devices, and M&R stations
  - **Distribution:** Residential customer meters, plastic mains and services (*Note: GTI is doing some of these*)

# Stations Visited To Date

Ownership	Date Visited	Description	IR screening?	Hi Flow on component leaks	Vent Pipes Measured
Co #1	11/3/09 TX	6 Recips (1965)	√	√	√
Co #1	11/4/09 TX	5 Recips (‘92 – ‘09)	√	√	√
Co #1	11/3/09 TX	3 Centrif (1982)	√	√	√
Co #2	2/23/10 W. TX	15 Recips (1950’s)	√	√	√
Co #2	2/24/10 NM	8 Recips (1950’s)	√	√	√

# Compressor Blowdown OEL's




Figure 4-1. Illustration of Compressor Blowdown Valve Arrangement

# Results

(vent measurements, 2 stations)

	Mscfy	GRI/EPA Mscfy per compr.
Average BD vent for IDLE (recip)	14347	3683
Avg BD vent for RUNNING (recip)	8807	
Avg Packing Vent RUNNING	13798	396

# Results

(vent measurements, last 3 stations)

	Mscfy	GRI/EPA Mscfy per compr.
Average BD vent for IDLE, recip	699	3683
Avg BD vent for IDLE+RUN, centrif	15787	
Avg Packing Vent <b>IDLE</b>	8379	396

# Compressor Miscellaneous Fugitives

(valves, flanges, etc; all stations)

	Mscfy per compr.	GRI/EPA Mscfy per compr.
Pressurized idle	60	
Operating	48	
Average	52	180

# GRI/EPA Study

- Operation Info
  - Recip Compressors were Pressurized 79.1% of time
  - Centrifugal Compressor were Pressurized 24.2% of time
  - Based on FERC, GRI TRANSDAT, Field data from one large transmission company, and practices observed during GRI/EPA campaign
- Measurement Basis:
  - 6 Storage stations (5 national storage companies)
  - 15 transmission stations

# Comments

## Comparison to GRI/EPA Data

- Comparison Basis: The GRI/EPA data is from Table 4-15 of "Methane Emissions from the Natural Gas Industry: Volume 8".
- **REDUCES the EF for packing vents for recip**
  - Co #1 = 8739, lower than Co #2's 13798 Mscf/yr. Both are larger than the previous GRI/EPA study of 396 Mscf/yr.
  - Note: Co #1 keeps idle compressors pressurized.

# Comments (cont'd)

## Comparison to GRI/EPA Data

- **RAISES EF for BD vents (Recips IDLE and RUNNING)**
  - IDLE: Co #1 avg 699 Mscfy vs 14347 for Co #2 and vs combined 3683 for GRI/EPA.
  - This company differences are expected, as Co #1 keeps compressors pressurized (the only possible leak is the 2" BD valve, rather than the big suction and discharge valves)
  - RUNNING: Only Co #2 data: 8807 vs 3683 for GRI/EPA
  - GRI/EPA PRV's at 372 Mscf/compr/yr may need to be added to the GRI/EPA value for comparison (Co #2 sites had both routed to the elevated BD line stack). Even with that addition, the new data is still higher.
- **RAISES EF for BD vents (for centrifugal)**
  - Co #1's centrifugal average BD leak is much larger at 15787 Mscfy/compressor

# Measurement Comments

There are a few observations to make:

1. Preliminary results are not ready for use, and not formally published and reviewed
2. Site layouts and designs limit some measurements
  - a. Not all vents are accessible, or safely accessible
  - b. Some vents are joined, and when different equipment in different operating modes are joined to the same vent, we cannot produce the stratified EF's.

# Photos from Recent Visits

## (3 stations)

Photos show:

- Large design variability, access issues
- Need to customize approach for measurement of vents at each site

# Outside Packing Vent Stack (joined at bottom to common oil drain)



# Individual Recip BD Vents



# Recip BD Vent Measurement



# Site BD (All Recips to 1 Vent)



# Calibrated Bag Measurement



# Rod Packing Vent



# Compressor Starter Vent



# Station Combined Vent (1 of 4)



# Some Conclusions

- More Sampling Needed
  - Station Design....each is unique
- EPA GHG MRR Subpart W may have a large effect on this program. Direction of the final rule should be monitored.

# Path Forward

- Monitor EPA's Mandatory Reporting Rule, Subpart W, which should be issued in Sept or Oct 2010
- Gather more direct measurement data (Measure more compressor station sites and gas plant sites) Target: 6-10 more stations geographically diverse.
- Survey INGAA members for company practices on compressor operating practices that affect leak rate
- Produce and publish updated compressor emission factors.