

**SHELL CLAUS OFFGAS TREATMENT
UNIT 1 (203) AND UNIT 2 (804)
EMISSIONS TEST REPORT
VALERO DELAWARE CITY REFINERY
DELAWARE CITY, DELAWARE**

Testing Date: September 15, 2009

Prepared for:

Valero Delaware City Refinery
4550 Wrangle Hill Road
Delaware City, Delaware 19706

Prepared by:


Air/Compliance Consultants, Inc.
1050 William Pitt Way
Pittsburgh, Pennsylvania 15238
412-826-3636

Project No. 09-129


**SHELL CLAUS OFFGAS TREATMENT
UNIT 1 (203) AND UNIT 2 (804)
EMISSIONS TEST REPORT
VALERO DELAWARE CITY REFINERY
DELAWARE CITY, DELAWARE**

Testing Date: September 15, 2009

AIR/COMPLIANCE CONSULTANTS, INC.



Jaimes C. Contreras
Senior Scientist, QSTI



Robert N. Frey
Vice President

TABLE OF CONTENTS

	<u>Page</u>
1. INTRODUCTION.....	1
2. TEST PERSONNEL.....	1
3. TESTING METHODOLOGY.....	1
3.1. Flow Rate, Molecular Weight and Moisture Determinations.....	1
3.2. Sulfuric Acid Emissions– USEPA Method 8.....	2
3.3. CEM Determinations.....	2
4. TEST RESULTS.....	3
5. CONCLUSION.....	3

FIGURE

1. ACCI CEMS Sample Flow and Calibration System Schematic

TABLES

1. Sulfuric Acid Mist Test Results SCOT 1 (203)
2. CEM Test Results SCOT 1 (203)
3. Sulfuric Acid Mist Test Results SCOT 2 (804)
4. CEM Test Results SCOT 2 (804)
5. Table Nomenclature

APPENDICES

- A. Field and Computerized Data Sheets
- B. RM Bias Sheets and 1-Minute Averages
- C. Calibration QA/QC Data
- D. Laboratory Analytical Data
- E. Sample Calculations
- F. Facility Data

**SHELL CLAUS OFFGAS TREATMENT
UNIT 1 (203) AND UNIT 2 (804)
EMISSIONS TEST REPORT
VALERO DELAWARE CITY REFINERY
DELAWARE CITY, DELAWARE**

1. INTRODUCTION

Air/Compliance Consultants, Inc. (ACCI) conducted a compliance testing program on the Shell Claus Offgas Treatment (SCOT) Unit 1 (203) and Unit 2 (804) for the Valero Delaware City Refinery (Valero) in Delaware City, Delaware. Testing was performed for sulfuric acid mist (H_2SO_4), nitrogen oxides (NO_x), and carbon monoxide (CO) as required by Permit ACP-90/0264-C/O (A7)(NSPS).

2. TEST PERSONNEL

Testing was performed September 15, 2009. An additional day of testing was required due to weather conditions. The ACCI test team consisted of Mr. Jaimes C. Contreras, Senior Project Scientist; Mr. Todd Haas, Mr. Francis Barton, Mr. Michael Belfoure, and Mr. Christian Bartley, Scientists.

Mr. Mark Lutrzykowski of the Delaware Department of Natural Resources and Environmental Control (DNREC) observed portions of the testing program.

3. TESTING METHODOLOGY

ACCI conducted the measurements in accordance with the United States Environmental Protection Agency (USEPA) Title 40, Code of Federal Regulations (CFR) Part 60, Appendix A Testing Methods. Figure 1 represents an ACCI CEMS Sample Flow and Calibration System Schematic.

3.1. Flow Rate, Molecular Weight and Moisture Determinations

ACCI conducted testing in accordance with USEPA Methods 1 through 4 at the two SCOT Stacks. The ducts are designated as 1 and 2. USEPA Method 1 was followed for selection of traverse points. Sixteen (16) sampling points were utilized at SCOT 1, 8 in each of 2 test ports. Sixteen (16) sampling points were utilized at SCOT 2, 8 in each of 2 test ports. The ports met the criteria of

USEPA Method 1. USEPA Method 2 was followed for the determination of gas velocity and volumetric flow rate. This procedure utilized an S-type Pitot tube and inclined manometer to determine stack-gas velocity head. USEPA Method 3A was utilized for the determination of carbon dioxide (CO₂), oxygen (O₂), and stack-gas molecular weight. Nitrogen (N₂) was determined by the difference.

USEPA Method 4 was followed to determine the gas moisture content of the exhaust gas. A moisture determination was performed on each test run to allow determination of dry stack-gas molecular weight and to calculate the dry standard cubic feet per minute (DSCFM) flow rate. The USEPA Method 4 train was incorporated with the Method 8 sampling train.

3.2. Sulfuric Acid Emissions– USEPA Method 8

USEPA Method 8 was used to determine H₂SO₄ concentration and mass emission rates. Stack gas was passed through a glass-lined, temperature-controlled probe equipped with a Type S Pitot tube. The exit of the probe was connected to a series of full-sized impingers. A knock out impinger was added to cool the gas stream. The second impinger contained 100 milliliters (mL) of 80% isopropanol, the third and fourth impingers each contained 100 mL of 30% hydrogen peroxide (H₂O₂) and the fifth impinger contained a known amount of silica gel. Samples were analyzed by the barium-thorin titration method by Enthalpy Analytical, Inc.

Sampling was conducted at a central point not using a nozzle and analysis did not occur on site. These deviations from normal sampling procedures were clarified with DNREC prior to testing.

3.3. CEM Determinations

ACCI utilized a mobile continuous emission monitoring (CEM) vehicle for determining CO and NO_x. USEPA Protocol Gases were used to verify the instrumentation used in the test program. CEM sampling took place from a single point in the center of each of the stacks after testing for stratification.

3.3.1. CO Determinations

USEPA Method 10 was used to continuously measure CO concentrations. A Thermo Environmental Model 48 gas filter correlation gas analyzer was used to measure CO. An extractive gas-conditioning system was used to convey the sample gas to the analyzer.

3.3.2. NO_x Determinations

ACCI measured NO_x on a continuous basis by real-time extraction and analysis using a TECO chemiluminescent analyzer following procedures in USEPA Method 7E.

USEPA Protocol calibration gases were utilized to calibrate all RM analyzers. Data acquisition was conducted with a multi-channel Yokogawa datalogger. Data was sampled continuously and scanned into memory in 2-second intervals.

4. TEST RESULTS

Tables 1 and 2 contain the results of the testing for the SCOT Unit 1. Tables 3 and 4 contain the results of the testing for the SCOT Unit 2. Table 5 contains the table nomenclature.

To document the work performed, Appendix A includes all field data generated during the program including all manual method field data sheets and computerized spreadsheets. Appendix B contains CEM bias sheets and 1-minute averages.

Meter box, Pitot, and nozzle calibration data sheets can be found in Appendix C. Calibration gas Certificates of Analysis are also contained in Appendix C. Results of the nitrogen dioxide (NO₂)/nitrogen oxide (NO) conversion test and the NO_x interference test for the analyzer used during testing are also located in the Appendix C. Analytical data is contained in Appendix D. Sample calculations are contained in Appendix E and relevant facility process data is contained in Appendix F.

5. CONCLUSION

A compliance test program has been conducted for SCOT 1 and 2 Units at Valero Delaware City Refinery located in Delaware City, Delaware. Testing was performed September 15, 2009 for NO_x,

H₂SO₄, and CO. All of the testing has yielded data that is considered to be representative of the emission rates at the prevailing operating conditions.


The following tables contain brief summaries of the test results:

Permit APC-90/0262-C/O (A7)(NSPS)		Source Name: SCOT Unit 1 (203)	
Pollutant	Test Result	Permit Limit	Pass / Fail
H ₂ SO ₄	0.65 lb/hr	1.6 lb/hr	Pass
	2.86 TPY	12.7 TPY	Pass
NO _x	4.31 lb/hr	7.0 lb/hr	Pass
	18.89 TPY	51.9 TPY	Pass
CO	0.56 ppm _{dv}	100 ppm _{dv}	Pass
	0.18 TPY	90.4 TPY	Pass

Permit APC-90/0262-C/O (A7)(NSPS)		Source Name: SCOT Unit 2 (804)	
Pollutant	Test Result	Permit Limit	Pass / Fail
H ₂ SO ₄	0.29 lb/hr	1.6 lb/hr	Pass
	1.26 TPY	12.7 TPY	Pass
NO _x	1.43 lb/hr	7.0 lb/hr	Pass
	6.26 TPY	51.9 TPY	Pass
CO	8.59 ppm _{dv}	100 ppm _{dv}	Pass
	2.28 TPY	90.4 TPY	Pass



FIGURE



TABLES

Table 1. Sulfuric Acid Mist Test Results, SCOT 1 (203)
Valero Delaware City Refinery, Delaware City, Delaware

Test Data		Run 1	Run 2	Run 3	Average	
Date		9/15/2009	9/15/2009	9/15/2009		
Start Time		9:30 AM	11:00 AM	12:50 PM		
End Time		10:30 AM	12:00 PM	1:50 PM		
Flow Rate	(ACFM)	55,682	57,146	56,124	56,317	
Flow Rate	(SCFM)	17,763	18,446	18,315	18,175	
Flow Rate	(DSCFM)	16,282	16,849	16,844	16,658	
Sample Volume	(DSCF)	45.709	44.915	45.611	45.412	
Carbon Dioxide (CO ₂)	(dry volume %)	16.8	16.2	15.6	16.2	
Oxygen (O ₂)	(dry volume %)	4.1	4.3	4.5	4.3	
Water Vapor (H ₂ O)	(volume %)	8.3%	8.7%	8.0%	8.3%	
Stack Temperature	(°F)	1198.8	1179.3	1161.5	1,180	
Results						Permit Limit
Sulfuric Acid (H₂SO₄)						
Mass Collected	(mg)	17.10	15.10	8.30	13.50	
Emission Concentration	(lb/DSCF)	8.25E-07	7.41E-07	4.01E-07	6.56E-07	
Emission Concentration	(ppm _{dv})	3.24	2.91	1.58	2.58	
Emission Rate	(lb/hr)	0.81	0.75	0.41	0.65	1.6
Emission Rate	(tons/year)	3.53	3.28	1.78	2.86	12.7

Table 3. Sulfuric Acid Mist Test Results, SCOT 2 (804)
Valero Delaware City Refinery, Delaware City, Delaware

Test Data		Run 1	Run 2	Run 3	Average	
Date		9/15/2009	9/15/2009	9/15/2009		
Start Time		9:30 AM	11:00 AM	12:52 PM		
End Time		10:30 AM	12:00 PM	1:52 PM		
Flow Rate	(ACFM)	53,089	54,339	54,857	54,095	
Flow Rate	(SCFM)	15,785	16,118	16,326	16,076	
Flow Rate	(DSCFM)	13,665	13,936	14,167	13,923	
Sample Volume	(DSCF)	44.809	44.035	44.003	44.283	
Carbon Dioxide (CO ₂)	(dry volume %)	14.8	14.8	14.3	14.6	
Oxygen (O ₂)	(dry volume %)	2.0	2.2	2.2	2.1	
Water Vapor (H ₂ O)	(volume %)	13.4%	13.5%	13.2%	13.4%	
Stack Temperature	(°F)	1315.3	1319.6	1313.7	1316.2	
Results						Permit Limit
Sulfuric Acid (H₂SO₄)						
Mass Collected	(mg)	7.44	6.14	7.11	6.90	
Emission Concentration	(lb/DSCF)	3.66E-07	3.07E-07	3.56E-07	3.43E-07	
Emission Concentration	(ppm _{dv})	1.44	1.21	1.40	1.35	
Emission Rate	(lb/hr)	0.30	0.26	0.30	0.29	1.6
Emission Rate	(tons/year)	1.31	1.13	1.33	1.26	12.7

Table 2. CEM Test Results, SCOT 1 (203)
Valero Delaware City Refinery, Delaware City, Delaware

Test Data		Run 1	Run 2	Run 3	Average	
Date		9/15/2009	9/15/2009	9/15/2009		
Start Time		9:30 AM	11:00 AM	12:50 PM		
End Time		10:30 AM	12:00 PM	1:50 PM		
Flow Rate	(ACFM)	55,682	57,146	56,124	56,317	
Flow Rate	(SCFM)	17,763	18,446	18,315	18,175	
Flow Rate	(DSCFM)	16,282	16,849	16,844	16,658	
Sample Volume	(DSCF)	45.709	44.915	45.611	45.412	
Carbon Dioxide (CO ₂)	(dry volume %)	16.83	16.20	15.57	16.20	
Oxygen (O ₂)	(dry volume %)	4.06	4.34	4.46	4.29	
Water Vapor (H ₂ O)	(volume %)	8.34	8.66	8.03	8.34	
Stack Temperature	(°F)	1198.8	1179.3	1161.5	1179.9	
Results						Permit Limit
Carbon Monoxide (CO)						
Emission Concentration	(ppm _{dv})	0.79	0.20	0.69	0.56	100
Emission Rate	(lb/hr)	0.06	0.01	0.05	0.04	
Emission Rate	(tons/year)	0.24	0.06	0.22	0.18	90.4
Nitrogen Oxides (NO_x) as NO₂						
Emission Concentration	(ppm _{dv})	30.5	39.5	38.2	36.07	
Emission Rate	(lb/hr)	3.56	4.76	4.61	4.31	7.0
Emission Rate	(tons/year)	15.60	20.87	20.20	18.89	51.9

CEM results have been bias calibration corrected.

Table 4. CEM Test Results, SCOT 2 (804)
Valero Delaware City Refinery, Delaware City, Delaware

Test Data		Run 1	Run 2	Run 3	Average	
Date		9/15/2009	9/15/2009	9/15/2009		
Start Time		9:30 AM	11:00 AM	12:52 PM		
End Time		10:30 AM	12:00 PM	1:52 PM		
Flow Rate	(ACFM)	53,089	54,339	54,857	54,095	
Flow Rate	(SCFM)	15,785	16,118	16,326	16,076	
Flow Rate	(DSCFM)	13,665	13,936	14,167	13,923	
Sample Volume	(DSCF)	44.809	44.035	44.003	44.283	
Carbon Dioxide (CO ₂)	(dry volume %)	14.80	14.76	14.28	14.62	
Oxygen (O ₂)	(dry volume %)	2.05	2.18	2.15	2.13	
Water Vapor (H ₂ O)	(volume %)	13.44	13.54	13.22	13.40	
Stack Temperature	(°F)	1315.3	1319.6	1313.7	1316.2	
Results						Permit Limit
Carbon Monoxide (CO)						
Emission Concentration	(ppm _{dv})	10.87	7.66	7.25	8.59	100
Emission Rate	(lb/hr)	0.65	0.47	0.45	0.52	
Emission Rate	(tons/year)	2.84	2.04	1.96	2.28	90.4
Nitrogen Oxides (NOx) as NO₂						
Emission Concentration	(ppm _{dv})	12.0	15.6	15.4	14.32	
Emission Rate	(lb/hr)	1.17	1.56	1.56	1.43	7.0
Emission Rate	(tons/year)	5.13	6.82	6.84	6.26	51.9

CEM results have been bias calibration corrected.

Table 5

TABLE NOMENCLATURE

SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
%	- Percent	gr/DSCF	- Grains per dry standard cubic feet	OSHA	- Occupational Safety & Health Administration
% Volume	- Percent by volume	gpm	- Gallons per minute	PADEP	- PA Department of Environmental Protection
°F	- Degrees Fahrenheit	H ₂ O	- Water	Pb	- Lead
<	- Less than	H ₂ SO ₄	- Sulfuric acid	PEL	- Permissible exposure limit
>	- Greater than	Hg	- Mercury	PM	- Particulate matter
AB	- Acetone Blank	HI	- Heat input	PM ₁₀	- Particulate matter less than 10 microns
ACFM	- Actual cubic feet per minute	hr	- Hour	ppb	- Parts per billion
BTU	- British thermal units	IC	- Ion chromatography	PPE	- Personal protective equipment
C ₃ H ₈	- Propane	in H ₂ O	- Inches of Water	ppm	- Parts per million
CE	- Capture efficiency	in Hg	- Inches of Mercury	ppm _{dv}	- Parts per million, dry volume
CEMS	- Continuous emission monitor system	Kg	- Kilograms	ppm _{wv}	- Parts per million, wet volume
cf	- Cubic foot	lb	- Pound	PTE	- Permanent total enclosure
CFR	- Code of Federal Regulations	lb/hr	- Pound per hour	RA	- Relative Accuracy
CH ₄	- Ethane	lb/lb-mole	- Pound per pound mole	RATA	- Relative Accuracy Test Audit
Cl ₂	- Chlorine	lb/MMBTU	- Pound per million British thermal units	RM	- Reference Method
CO	- Carbon monoxide	m ³	- Cubic meters	RMD	- Relative mean difference
CO ₂	- Carbon dioxide	MDL	- Minimum detection limit	S	- Sulfur
COG	- Coke oven gas	mg	- Milligrams	SCF	- Standard cubic feet
DACF	- Dry actual cubic feet	mg/g	- Milligrams per gram	SCFM	- Standard cubic feet per minute
DACM	- Dry actual cubic meters	mL	- Milliliter	SCM	- Standard cubic meters
DE	- Destruction efficiency	mm HG	- Millimeters of mercury	SO ₂	- Sulfur dioxide
DSCF	- Dry standard cubic feet	MMBtu	- Million British thermal units	STD	- Standard
DSCFM	- Dry standard cubic feet per minute	MMBtu/hr	- Million British thermal units per hour	THC	- Total hydrocarbons
FID	- Flame Ionization Detector	MNOC	- Maximum normal operating capacity	tph	- Tons per hour
ft	- Foot	N ₂	- Nitrogen	tpy	- Tons per year
ft/sec	- Feet per second	NDO	- Natural draft opening	µg	- Micrograms
Ft ²	- Square feet	ng	- Nanograms	µg/DSCM	- Micrograms per dry standard cubic meter
Ft ³	- Cubic feet	NMNVOC	- Non-methane, non-ethane volatile organic compounds	USEPA	- United States Environmental Protection Agency
ft ³ /lb-mole	- Cubic feet per pound mole	NMVOC	- Non-methane volatile organic compound	VE	- Visible emissions
g	- Grams	NO ₂	- Nitrous Oxide	VOC	- Volatile organic compound
g/mL	- Gram per milliliter	NO _x	- Oxides of Nitrogen	vol.	- Volume
GC	- Gas Chromatography	O ₂	- Oxygen	w/o	- With out

APPENDIX A

Field and Computerized Data Sheets

SCOT 1 (203)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 1 (203)
 Unit Operation: normal
 Blue is data input.
 Red is a calculation.
 Pink is a reference to a cell on another sheet.

Data Input

Control Box	1581	
Meter DI ₁ (0.75 scfm)	1.626	in. H ₂ O
Meter Calibration Factor (Yd)	0.988	
Test Time (Theta)	60	minutes
Barometric Pressure (Pbar)	30.00	in. Hg
Stack Static Pressure (P _g)	-0.20	in. H ₂ O
Stack Diameter (Ds) (L if rectangular)	80.0	inches
Stack Width (enter NA if circular)	NA	inches
Nozzle Diameter (Dn) (NA if NA)	na	inches
CO2	16.83	% dv
O2	4.06	% dv
Product Rate (enter NA if not needed)	NA	input ton/hr
Is the input ton/hr metric? (YES=1)	0	
Pitot Tube Coefficient (Cp)	0.84	
Sample Calculation Title	H2SO4 and CEMS	
F _c @ 68 F and 760 mm Hg (NA if NA)	NA	dscf/MMBtu
Standard Temperature	68	F
Standard Pressure	760	mm Hg
Pitot Tube Constant (Kp)	85.49	

Calculations

Meter Temperature (Tm)	83.8	F
Stack Temperature (T _{avg})	1198.8	F
Orifice Pressure Drop (dP _{avg})	1.600	in. H ₂ O
Gas Velocity Head (dP) ^{1/2} avg	0.2717	in. H ₂ O ^{1/2}
F _c @ Standard Conditions	NA	dscf/MMBtu
F _c @ Stan. Cond. & Actual O2	NA	dscf/MMBtu
Heat Input Based on F _c	NA	MMBtu/hr
K1method 4	0.04707	scf/mi
K2method 4	0.04715	scf/mi
K3method 5	17.64	R/in. Hg
K4method 5	0.0945	
Standard lb-mole volume	385.3	ft ³ /lb-mole

Carbon Monoxide (CO)

MW	28	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration	0.79	ppm _{v, std}
Concentration	0.79	ppm _{v, stack}
Concentration	NA	ppm _{v, 7% O2}
Concentration	0.0000001	lb/dscf
Emission	0.06	lb/hr
Emission	0.000	lb/MMBtu

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run 1
 Test Start Time: 9:30 AM
 Test Finish Time: 10:30 AM
 Green is a reference to a cell on this sheet.

Calculations

CO + N2	79.10	% dv
Water Collected (V _w - V _i)	0.0	ml
Water Vapor Condensed (V _{wc} (std))	0.000	scf
Water Collected (W _w - W _i)	88.2	g
Water Vapor in Silica Gel (V _{wsg} (std))	4.159	scf
Vol. Water Vapor in Gas Stand.(V _w (std))	4.159	scf
Volume Dry Gas Metered (V _m)	47.350	dscf
Vol. Dry Gas Metered Stand.(V _m (std))	45.709	dscf
Volume Dry Gas Metered (V _m (m ³))	1.341	dacm
Vol. Dry Gas Metered Stand.(V _m (std)m ³)	1.294	dscm
Stack Absolute Pressure (P _s)	29.99	in. Hg
Stack Absolute Temperature (T _{savg})	1658.4	R
H2O Vapor Pressure @ avg Stack Temp.	59033.58	in. Hg
H2O in the gas at saturation (B _{ws})	1.0000	vol. fraction
H2O in the gas from test data (H _{ws})	0.0834	vol. fraction
H2O in the gas used (lower of the 2 B _{ws})	0.0834	vol. fraction
Is the Gas Stream Saturated With H2O?	NO	
Dry Gas Molecular Weight (Md)	30.86	lb/lb-mole
Wet Gas Molecular Weight (Ms)	29.78	lb/lb-mole
Gas Velocity (Vs)	26.59	ft/s
Is the stack circular or rectangular?	CIRCULAR	
Area Stack (A _s)	34.907	ft ²
Actual Gas Flowrate	55.682	acfm
Standard Gas Flowrate	17.763	scfm
Dry Standard Gas Flowrate	16.282	dscfm
Actual Gas Flowrate	1.577	acm/min
Standard Gas Flowrate	503	scm/min
Dry Standard Gas Flowrate	461	dscm/min
Area Nozzle (A _n)	NA; Dn = NA	ft ²
Percent of Isokinetic Sampling (I)	NA; Dn = NA	%

Nitrogen Oxides (NOx) as NO2

MW	46	lb/lb-mole
O2 for Correction	NA; Dn = NA	vol. %
Concentration	30.53	ppm _v
Concentration	NA	ppm _{v, 7% O2}
Concentration	0.0000036	lb/dscf
Emission	3.56	lb/hr
Emission	0.000	lb/MMBtu

Sulfuric Acid (H2SO4)

Total mass as H2SO4	17.100	mg
MW H2SO4	98	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration as H2SO4	8.25E-07	lb/dscf
Concentration as H2SO4	3.24	ppm _v
Concentration as H2SO4	NA	ppm _{v, 7% O2}
Emission as H2SO4	0.81	lb/hr
Emission as H2SO4	0.000	lb/MMBtu

Valero Run 1 F or C? F=1, C=0

SCOT 1 (203)

Point	Pitot DP (dP) (in. H2O)	SQRT dP (in. H2O) ^{1/2}	Orifice DP (dP) (in. H2O)	Stack Temp (F)	Meter Temp In/Out (F or C)	(F or C)
A-1	0.06	0.245	1.60	1196	80	78
A-2	0.06	0.245	1.60	1197	82	78
A-3	0.07	0.265	1.60	1198	85	79
A-4	0.08	0.283	1.60	1198	86	80
A-5	0.09	0.300	1.60	1199	87	80
A-6	0.08	0.283	1.60	1200	88	80
A-7	0.06	0.245	1.60	1200	88	81
A-8	0.06	0.245	1.60	1198	89	81
B-1	0.06	0.245	1.60	1197	89	81
B-2	0.07	0.265	1.60	1198	90	82
B-3	0.08	0.283	1.60	1199	90	83
B-4	0.09	0.300	1.60	1200	90	83
B-5	0.10	0.316		1200		
B-6	0.09	0.300		1201		
B-7	0.08	0.283		1200		
B-8	0.06	0.245		1199		
Average						
	0.07	0.272	1.60	1198.8		83.8
Initial volume	831.865	ft ³		Initial volume	0.000	liters
Final volume	879.215	ft ³		Final volume	0.000	liters
Total metered	47.350	dscf		Total metered	0.000	dry actual liters
Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml	ml Gain
1	884.5	895	-10.5			0.0
2	894	860.5	33.5			0.0
3	818.5	818	0.5			0.0
4	757	711.5	45.5			0.0
5	257.3	238.1	19.2			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	3611.3	3523.1	88.2	0.0	0.0	0.0
	W _f	W _i	(W _f - W _i)	V _f	V _i	(V _f - V _i)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 1 (203)
 Unit Operation: normal
 Blue is data input.
 Red is a calculation.
 Pink is a reference to a cell on another sheet.

Data Input

Control Box	1581	
Meter DI _{1/2} (0.75 scfm)	1.626	in. H ₂ O
Meter Calibration Factor (Yd)	0.988	
Test Time (Theta)	60	minutes
Barometric Pressure (Pbar)	30.0	in. Hg
Stack Static Pressure (Pg)	-0.20	in. H ₂ O
Stack Diameter (Ds) (L if rectangular)	80.0	inches
Stack Width (enter NA if circular)	na	inches
Nozzle Diameter (Dn) (NA if NA)	na	inches
CO2	16.20	% dv
O2	4.34	% dv
Product Rate (enter NA if not needed)	NA	input ton/hr
Is the input ton/hr metric? (YES=1)	0	
Pitot Tube Coefficient (Cp)	0.84	
Sample Calculation Title	Particulate and CEMS	
F _c @ 68 F and 760 mm Hg (NA if NA)	NA	dscf/MMBtu
Standard Temperature	68	F
Standard Pressure	760	mm Hg
Pitot Tube Constant (Kp)	85.49	

Calculations

Meter Temperature (Tm)	90.4	F
Stack Temperature (Tsvag)	1179.3	F
Orifice Pressure Drop (dPavg)	1.600	in. H ₂ O
Gas Velocity Head (dP) ^{1/2} avg	0.2799	in. H ₂ O ^{1/2}
F _c @ Standard Conditions	NA	dscf/MMBtu
F _c @ Stan. Cond. & Actual O2	NA	dscf/MMBtu
Heat Input Based on F _c	NA	MMBtu/hr
K1method 4	0.04707	scf/ml
K2method 4	0.04715	scf/g
K1method 5	17.64	R/in. Hg
K4method 5	0.0945	ft ³ /lb-mole
Standard lb-mole volume	385.3	ft ³ /lb-mole

Carbon Monoxide (CO)

MW	28	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration	0.20	ppm _{v, stack}
Concentration	0.20	ppm _{v, stack}
Concentration	NA	ppm _{v, 7% O2}
Concentration	0.0000000	lb/dscf
Emission	0.01	lb/hr
Emission	0.000	lb/MMBtu

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run 2
 Test Start Time: 11:00 AM
 Test Finish Time: 12:00 PM
 Green is a reference to a cell on this sheet.

Calculations

CO + N2	79.47	% dv
Water Collected (V _c - V _i)	0.0	ml
Water Vapor Condensed (Vwc(std))	0.000	scf
Water Collected (W _c - W _i)	90.3	g
Water Vapor in Silica Gel (Vwsg(std))	4.258	scf
Vol. Water Vapor in Gas Stand.(Vw(std))	4.258	scf
Volume Dry Gas Metered (Vm)	47.095	dacf
Vol. Dry Gas Metered Stand.(Vm(std))	44.915	dscf
Volume Dry Gas Metered (Vm(m ³))	1.334	dacm
Vol. Dry Gas Metered Stand.(Vm(std)m ³)	1.272	dscm
Stack Absolute Pressure (Ps)	29.99	in. Hg
Stack Absolute Temperature (Tsvag)	1639.0	R
H2O Vapor Pressure @ avg Stack Temp.	55596.83	in. Hg
H2O in the gas at saturation (Bws)	1.0000	vol. fraction
H2O in the gas from test data (Bws)	0.0866	vol. fraction
H2O in the gas used (lower of the 2 Bws)	0.0866	vol. fraction
Is the Gas Stream Saturated With H2O?	NO	
Dry Gas Molecular Weight (Md)	50.76	lb/lb-mole
Wet Gas Molecular Weight (Ms)	29.66	lb/lb-mole
Gas Velocity (Vs)	27.29	ft/s
Is the stack circular or rectangular?	CIRCULAR	
Area Stack (As)	34.907	ft ²
Actual Gas Flowrate	57.146	acfm
Standard Gas Flowrate	18.446	scfm
Dry Standard Gas Flowrate	16.849	dscfm
Actual Gas Flowrate	1.618	acm/min
Standard Gas Flowrate	522	scm/min
Dry Standard Gas Flowrate	477	dscm/min
Area Nozzle (An)	NA; Dn = NA	ft ²
Percent of Isokinetic Sampling (I)	NA; Dn = NA	%

Nitrogen Oxides (NOx) as NO2

MW	46	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration	39.47	ppm _v
Concentration	NA	ppm _{v, 7% O2}
Concentration	0.0000047	lb/dscf
Emission	4.76	lb/hr
Emission	0.000	lb/MMBtu

Sulfuric Acid (H2SO4)

Total mass as H2SO4	15.100	mg
MW H2SO4	98	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration as H2SO4	7.41E-07	lb/dscf
Concentration as H2SO4	2.91	ppm _v
Concentration as H2SO4	NA	ppm _{v, 7% O2}
Emission as H2SO4	0.75	lb/hr
Emission as H2SO4	0.000	lb/MMBtu

Valero		Run 2		F or C?		
SCOT 1 (203)				F=1, C=0 1		
Point	Pitot DP (dP) (in. H2O)	SQRT dP (in. H2O) ^{1/2}	Orifice DP (dH) (in. H2O)	Stack Temp (F)	Meter Temp In/Out (F or C)	(F or C)
A-1	0.06	0.245	1.60	1177	91	86
A-2	0.07	0.265	1.60	1178	93	86
A-3	0.07	0.265	1.60	1175	94	87
A-4	0.08	0.283	1.60	1178	94	87
A-5	0.10	0.316	1.60	1179	94	87
A-6	0.09	0.300	1.60	1178	94	87
A-7	0.08	0.283	1.60	1177	94	88
A-8	0.07	0.265	1.60	1176	94	87
B-1	0.06	0.245	1.60	1180	94	88
B-2	0.08	0.283	1.60	1181	94	88
B-3	0.08	0.283	1.60	1181	94	88
B-4	0.09	0.300	1.60	1182	93	87
B-5	0.10	0.316		1182		
B-6	0.08	0.283		1182		
B-7	0.08	0.283		1182		
B-8	0.07	0.265		1181		
Average		0.280	1.60	1179.3	90.4	
Initial volume	891.075	ft ³	Initial volume	0.000	liters	
Final volume	938.170	ft ³	Final volume	0.000	liters	
Total metered	47.095	dacf	Total metered	0.000	dry actual liters	
Impinger	Final grams	Initial grams	Gram Gain			ml Gain
1	771	760	11.0			0.0
2	772.5	766.5	6.0			0.0
3	748.5	707	41.5			0.0
4	714.5	706.5	8.0			0.0
5	265.2	241.4	23.8			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	3271.7	3181.4	90.3	0.0	0.0	0.0
	W _i	W _f	(W _f - W _i)	V _f	V _i	(V _f - V _i)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 1 (203)
 Unit Operation: normal
 Blue is data input.
 Red is a calculation.
 Pink is a reference to a cell on another sheet.

Data Input

Control Box:	1581	
Meter DI _w (0.75 scfm)	1.626	in. H ₂ O
Meter Calibration Factor (Yd)	0.9880	
Test Time (Theta)	60	minutes
Barometric Pressure (Pbar)	30.0	in. Hg
Stack Static Pressure (Psg)	-0.20	in. H ₂ O
Stack Diameter (Ds) (L if rectangular)	80.0	inches
Stack Width (enter NA if circular)	na	inches
Nozzle Diameter (Dn) (NA if NA)	na	inches
CO2	15.57	% dv
O2	4.46	% dv
Product Rate (enter NA if not needed)	NA	input ton/hr
Is the input ton/hr metric? (YES=1)	0	
Pitot Tube Coefficient (Cp)	0.84	
Sample Calculation Title	Particulate and CEMS	
F ₁ @ 68 F and 760 mm Hg (NA if NA)	NA	dscf/MMBtu
Standard Temperature	68	F
Standard Pressure	760	mm Hg
Pitot Tube Constant (Kp)	85.49	

Calculations

Meter Temperature (Tm)	89.5	F
Stack Temperature (Tsvag)	1161.5	F
Orifice Pressure Drop (dHavg)	1.600	in. H ₂ O
Gas Velocity Head (dH) ^{1/2} avg	0.2763	in. H ₂ O ^{1/2}
F ₂ @ Standard Conditions	NA	dscf/MMBtu
F ₂ @ Stan. Cond. & Actual O2	NA	dscf/MMBtu
Heat Input Based on F ₂	NA	MMBtu/hr
K1method 4	0.04707	scf/ml
K2method 4	0.04715	scf/g
K1method 5	17.64	R/in. Hg
K4method 5	0.0945	ft ³ /lb-mole
Standard lb-mole volume	385.3	ft ³ /lb-mole

Carbon Monoxide (CO)

MW	28	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration	0.69	ppm _{w, sarr}
Concentration	0.69	ppm _{w, sarr}
Concentration	NA	ppm _{w, 7% O2}
Concentration	0.0000001	lb/dscf
Emission	0.05	lb/hr
Emission	0.000	lb/MMBtu

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run J
 Test Start Time: 12:50 PM
 Test Finish Time: 1:50 PM
 Green is a reference to a cell on this sheet.

Calculations

CO + N2	79.97	% dv
Water Collected (V _w - V _w)	0.0	nil
Water Vapor Condensed (V _{wet} (std))	0.000	scf
Water Collected (W _w - W _w)	84.5	g
Water Vapor in Silica Gel (V _{wsg} (std))	3.984	scf
Vol. Water Vapor in Gas Stand (V _w (std))	3.984	scf
Volume Dry Gas Metered (Vm)	47.745	dscf
Vol. Dry Gas Metered Stand (Vm(std))	45.611	dscf
Volume Dry Gas Metered (Vm(m ³))	1.352	dacm
Vol. Dry Gas Metered Stand (Vm(std)m ³)	1.292	dscm
Stack Absolute Pressure (Ps)	29.99	in. Hg
Stack Absolute Temperature (T _{svag})	1621.2	R
H2O Vapor Pressure @ avg Stack Temp.	52522.73	in. Hg
H2O in the gas at saturation (Bws)	1.0000	vol. fraction
H2O in the gas from test data (Bws)	0.0803	vol. fraction
H2O in the gas used (lower of the 2 Bws)	0.0803	vol. fraction
Is the Gas Stream Saturated With H2O?	NO	
Dry Gas Molecular Weight (Md)	30.67	lb/lb-mole
Wet Gas Molecular Weight (Ms)	29.65	lb/lb-mole
Gas Velocity (Vs)	26.80	ft/s
Is the stack circular or rectangular?	CIRCULAR	
Area Stack (As)	34.907	ft ²
Actual Gas Flowrate	56.124	acfm
Standard Gas Flowrate	18.315	scfm
Dry Standard Gas Flowrate	16.844	dscfm
Actual Gas Flowrate	1.589	acm/min
Standard Gas Flowrate	519	scm/min
Dry Standard Gas Flowrate	477	dscm/min
Area Nozzle (An)	NA; Dn = NA	ft ²
Percent of Isokinetic Sampling (I)	NA; Dn = NA	%

Nitrogen Oxides (NOx) as NO2

MW	46	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration	38.21	ppm _w
Concentration	NA	ppm _{w, 7% O2}
Concentration	0.0000946	lb/dscf
Emission	4.61	lb/hr
Emission	0.000	lb/MMBtu

Sulfuric Acid (H2SO4)

Total mass as H2SO4	8.300	mg
MW H2SO4	98	lb/lb-mole
O2 for Correction	NA	vol. %
Concentration as H2SO4	4.01E-07	lb/dscf
Concentration as H2SO4	1.58	ppm _w
Concentration as H2SO4	NA	ppm _{w, 7% O2}
Emission as H2SO4	0.41	lb/hr
Emission as H2SO4	0.000	lb/MMBtu

Point	Valero		Run J		F or C?	
	Pitot DP (dP)	Sort dP	Orifice DP (dH)	Stack Temp	Meter Temp In/Out	F or C?
	(in. H ₂ O)	(in. H ₂ O) ^{1/2}	(in. H ₂ O)	(F)	(F or C)	(F or C)
A-1	0.06	0.245	1.60	1158	89	86
A-2	0.07	0.265	1.60	1160	89	86
A-3	0.08	0.283	1.60	1161	91	86
A-4	0.09	0.300	1.60	1162	92	86
A-5	0.09	0.300	1.60	1162	93	87
A-6	0.08	0.283	1.60	1163	93	87
A-7	0.07	0.265	1.60	1163	93	87
A-8	0.06	0.245	1.60	1162	93	87
B-1	0.06	0.245	1.60	1160	93	87
B-2	0.07	0.265	1.60	1161	93	87
B-3	0.08	0.283	1.60	1162	94	87
B-4	0.09	0.300	1.60	1162	94	87
B-5	0.10	0.316		1162		
B-6	0.09	0.300		1162		
B-7	0.08	0.283		1162		
B-8	0.06	0.245		1162		
Average						
	0.077	0.276	1.60	1161.5		89.5
Initial volume	952.845	ft ³	Initial volume	0.000	liters	
Final volume	1000.590	ft ³	Final volume	0.000	liters	
Total metered	47.745	dscf	Total metered	0.000	dry actual liters	
Impinger	Final grams	Initial grams	Gram Gain			ml Gain
1	707	746	-39.0			0.0
2	769.5	765	4.5			0.0
3	743.5	696.5	47.0			0.0
4	746.5	713.5	33.0			0.0
5	293.6	254.6	39.0			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	3260.1	3175.6	84.5	0.0	0.0	0.0
	W _i	W _f	(W _i - W _f)	V _f	V _i	(V _f - V _i)

**AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET**

Client: <u>Valero</u>	Test Type: <u>Method 8</u>	Meter Delta H@: <u>1.626</u>	Start Time: <u>0930</u>
Date: <u>9/15/09</u>	Run Number: <u>1</u>	Meter Correction: <u>0.988</u>	Stop Time: <u>1030</u>
Plant: <u>Delaware City Refinery</u>	Nozzle Dia: <u>-</u>	Pitot Correction: <u>.84</u>	Umbilical Length: <u>50'</u>
Sampling Location: <u>Scot 203 SRU</u>	Static Press, Ps: <u>-0.20</u>	Control Box Num.: <u>1581</u>	Probe Number: <u>SAC-1</u>
Project Number: <u>09-129</u>	Barometric Press: <u>30.00</u>	Assumed Moisture: <u></u>	Pitot Number: <u>SAC-1</u>
Test Crew: <u>JCCB FB MB TH</u>	Ambient Temp: <u>75</u> °F	Thermocouple ID: <u>SAC-1</u>	Filter Number: <u></u>
	K-factor (K _f): <u> </u> <u> </u> <u> </u>		Measured Stack Diameter: <u>80"</u>

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (Δ P)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. Ts °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
		<u>0930</u>	<u>831.865</u>										<u>FILTER °F</u>
	<u>5</u>		<u>835.840</u>		<u>1.6</u>	<u>4.0</u>	<u>80</u>	<u>78</u>	<u>1194</u>	<u>256</u>	<u>250</u>	<u>53</u>	<u>77</u>
	<u>10</u>		<u>840.095</u>		<u>1.6</u>	<u>4.0</u>	<u>82</u>	<u>78</u>	<u>1197</u>	<u>250</u>	<u>253</u>	<u>53</u>	<u>76</u>
	<u>15</u>		<u>843.765</u>		<u>1.6</u>	<u>4.0</u>	<u>85</u>	<u>79</u>	<u>1203</u>	<u>251</u>	<u>255</u>	<u>55</u>	<u>75</u>
	<u>20</u>		<u>847.725</u>		<u>1.6</u>	<u>4.0</u>	<u>86</u>	<u>80</u>	<u>1202</u>	<u>251</u>	<u>250</u>	<u>57</u>	<u>75</u>
	<u>25</u>		<u>851.700</u>		<u>1.6</u>	<u>4.0</u>	<u>87</u>	<u>80</u>	<u>1200</u>	<u>249</u>	<u>248</u>	<u>58</u>	<u>75</u>
	<u>30</u>		<u>855.525</u>		<u>1.6</u>	<u>4.0</u>	<u>88</u>	<u>80</u>	<u>1198</u>	<u>249</u>	<u>245</u>	<u>58</u>	<u>74</u>
	<u>35</u>		<u>859.710</u>		<u>1.6</u>	<u>4.0</u>	<u>88</u>	<u>81</u>	<u>1196</u>	<u>247</u>	<u>246</u>	<u>59</u>	<u>74</u>
	<u>40</u>		<u>863.675</u>		<u>1.6</u>	<u>4.0</u>	<u>89</u>	<u>81</u>	<u>1195</u>	<u>252</u>	<u>253</u>	<u>59</u>	<u>75</u>
	<u>45</u>		<u>867.610</u>		<u>1.6</u>	<u>4.0</u>	<u>89</u>	<u>81</u>	<u>1194</u>	<u>249</u>	<u>250</u>	<u>59</u>	<u>75</u>
	<u>50</u>		<u>871.570</u>		<u>1.6</u>	<u>4.0</u>	<u>90</u>	<u>82</u>	<u>1204</u>	<u>248</u>	<u>247</u>	<u>59</u>	<u>75</u>
	<u>55</u>		<u>875.450</u>		<u>1.6</u>	<u>4.0</u>	<u>90</u>	<u>83</u>	<u>1196</u>	<u>250</u>	<u>250</u>	<u>57</u>	<u>76</u>
	<u>60</u>	<u>1030</u>	<u>879.215</u>		<u>1.6</u>	<u>4.0</u>	<u>90</u>	<u>83</u>	<u>1197</u>	<u>253</u>	<u>246</u>	<u>57</u>	<u>77</u>
TOTAL/AVERAGE													
Sample Train Leak Check													

	(in. Hg)	Rate (ft ³ /m)
Initial	<u>15"</u>	<u>0.00</u>
Final	<u>16"</u>	<u>0.00</u>

Pitot Leak Check		
Pressure	<u>+-</u>	<u>✓</u>
Static	<u>+-</u>	<u>✓</u>

CEMS

	1	2	3	Average
CO2				
O2				
CO				
N2				

IMP	Contents	Final	Initial	Difference
1	<u>IPA</u>	<u>785.5 888.5</u>	<u>895.0</u>	
2	<u>IPA</u>	<u>894.0</u>	<u>860.5</u>	
3	<u>H₂O₂</u>	<u>785.5 818.3</u>	<u>818.0</u>	
4	<u>H₂O₂</u>	<u>757.0</u>	<u>711.5</u>	
5	<u>SILICA</u>	<u>257.3</u>	<u>238.1</u>	

**AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET**

Page _____ of _____

Client: Valero
Date: 9/15/09
Plant: Delaware City Refinery
Sampling Location: Scot 203 SRU
Project Number: 09-129
Test Crew: JC CO TH MB FB

Test Type: Method 8
Run Number: 2
Nozzle Dia: -
Static Press, Ps: -0.20
Barometric Press: 30.00
Ambient Temp: 75 °F
K-factor (K_f): [] [] []

Meter Delta H@: 1.626
Meter Correction: 0.988
Pitot Correction: .84
Control Box Num.: 1581
Assumed Moisture:
Thermocouple ID: SAC-1

Start Time: 1100
Stop Time: 1200
Umbilical Length: 50'
Probe Number: SAC-1
Pitot Number: -
Filter Number:
Measured Stack Diameter: 8.6"

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (Δ P)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. Ts °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
			891.075										FILTER °F
		5	895.070		1.6	4.0	91	86	1171	250	248	56	68
		10	898.995		1.6	4.0	93	86	1165	251	246	56	68
		15	902.925		1.6	4.0	94	87	1167	250	247	56	69
		20	906.830		1.6	4.0	94	87	1164	250	248	57	70
		25	910.750		1.6	4.0	94	87	1181	249	245	58	70
		30	914.675		1.6	4.0	94	87	1176	250	249	59	70
		35	918.580		1.6	4.0	94	88	1182	248	244	59	70
		40	922.510		1.6	4.0	94	87	1183	251	248	56	70
		45	926.440		1.6	4.0	94	88	1182	249	253	57	69
		50	930.345		1.6	4.0	94	88	1178	250	252	59	70
		55	934.155		1.6	4.0	94	88	1176	248	253	60	71
		60	938.170		1.6	4.0	93	87	1182	250	248	61	71

TOTAL/AVERAGE

Sample Train Leak Check

	(in. Hg)	Rate (ft ³ /m)
Initial	15"	0.00
Final	10"	0.00

Pitot Leak Check

Pressure	+/-	✓
Static	+/-	✓

CEMS

	1	2	3	Average
CO2				
O2				
CO				
N2				

JCC OK

IMP	Contents	Final	Initial	Difference
1	IPA	771.0	766.0 764	
2	IPA	772.5	766.5 766.5	
3	H ₂ O ₂	748.5	707.0	
4	H ₂ O ₂	714.5	707.0 706.5	
5	4111A	265.2	241.4	

AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET

Client: Valero Test Type: Method 8 Meter Delta H@: 1.626 Start Time: 1250
 Date: 9/15/09 Run Number: 3 Meter Correction: 0.998 Stop Time: 1350
 Plant: Delaware City Refinery Nozzle Dia: - Pitot Correction: .84 Umbilical Length: 50'
 Sampling Location: Scot 203 SRU Static Press, Ps: -0.70 Control Box Num.: 1581 Probe Number: SAC-1
 Barometric Press: 30.00 Assumed Moisture: _____ Pitot Number: -
 Project Number: 09-129 Ambient Temp: 75 °F Thermocouple ID: SAC-1 Filter Number: -
 Test Crew: SC CA KA SH MB K-factor (K_p): Measured Stack Diameter: 80"

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (ΔP)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. T _s °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
			952.845										Filter °F
5		5	956.830		1.6	4.5	89	86	1160	250	251	60	70
10			960.800		1.6	4.5	89	86	1158	249	249	59	71
15			964.790		1.6	4.5	91	86	1165	250	247	60	71
20			968.695		1.6	4.5	92	86	1161	252	250	61	72
25			972.575		1.6	4.5	93	87	1164	248	249	61	72
30			976.460		1.6	4.5	93	87	1179	249	250	59	72
35			980.450		1.6	4.5	93	87	1164	252	250	59	73
40			984.430		1.6	4.5	93	87	1158	248	252	60	73
45			988.425		1.6	4.5	93	87	1167	249	251	61	73
50			992.565		1.6	4.5	93	87	1143	252	253	61	73
55			996.685		1.6	4.5	94	87	1148	254	252	62	74
60			1000.590		1.6	4.5	94	87	1147	250	253	62	74
TOTAL/AVERAGE													

TOTAL/AVERAGE

Sample Train Leak Check

	(in. Hg)	Rate (ft ³ /m)
Initial	15"	0.00
Final	10"	0.00

Pitot Leak Check

Pressure	+/-	✓
Static	+/-	✓

CEMS

	1	2	3	Average
CO2				
O2				
CO				
N2				

IMP	Contents	Final	Initial	Difference
1	IPA	767.0	746.0	
2	IPA	769.5	765.0	
3	H ₂ O ₂	743.5	696.5	
4	H ₂ O ₂	746.5	713.5	
5	SILICA	293.6	254.6	

AIR/COMPLIANCE CONSULTANTS, INC.
USEPA METHOD 2 DATA SHEET

Client: VALERO
 Project No.: 09-129
 Test Location: S-203 SEV
 Test Crew: JC CB FB MB TH
 Pitot Tube ID No.: 9PPG-1

Date: <u>9/15/09</u> Time: <u>0951</u>			Date: <u>9/15/09</u> Time: <u>1131</u>			Date: <u>9/15/09</u> Time: <u>1255</u>		
Stack ID <u>S-203</u>		Stack ID <u>S-203</u>	Stack ID <u>S-203</u>		Stack ID <u>S-203</u>	Stack ID <u>S-203</u>		Stack ID <u>S-203</u>
Measured Stack Diameter <u>80"</u>		Stack Diameter <u>80"</u>	Stack Diameter <u>80"</u>		Stack Diameter <u>80"</u>	Stack Diameter <u>80"</u>		Stack Diameter <u>80"</u>
Run No. <u>1</u>		Run No. <u>2</u>	Run No. <u>2</u>		Run No. <u>3</u>	Run No. <u>3</u>		Run No. <u>3</u>
Static Pressure (in H ₂ O) <u>-0.20</u>		Static Pressure (in H ₂ O) <u>-0.20</u>	Static Pressure (in H ₂ O) <u>-0.20</u>		Static Pressure (in H ₂ O) <u>-0.20</u>	Static Pressure (in H ₂ O) <u>-0.20</u>		Static Pressure (in H ₂ O) <u>-0.20</u>
Barometric Pressure (in Hg) <u>30.00</u>		Barometric Pressure (in Hg) <u>30.00</u>	Barometric Pressure (in Hg) <u>30.00</u>		Barometric Pressure (in Hg) <u>30.00</u>	Barometric Pressure (in Hg) <u>30.00</u>		Barometric Pressure (in Hg) <u>30.00</u>
Traverse Point no.	Velocity Delta P	Stack Temp (°F)	Traverse Point no.	Velocity Delta P	Stack Temp (°F)	Traverse Point no.	Velocity Delta P	Stack Temp (°F)
A1	.06	1196	A1	.06	1177	A1	.06	1158
2	.06	1197	2	.07	1178	2	.07	1160
3	.07	1198	3	.07	1175	3	.08	1161
4	.08	1198	4	.08	1178	4	.09	1162
5	.09	1199	5	.10	1179	5	.09	1162
6	.08	1200	6	.09	1178	6	.08	1163
7	.06	1200	7	.08	1177	7	.07	1163
8	.06	1198	8	.07	1176	8	.06	1162
B1	.06	1197	B1	.06	1180	B1	.06	1160
2	.07	1198	2	.08	1181	2	.07	1161
3	.08	1199	3	.08	1181	3	.08	1162
4	.09	1200	4	.09	1182	4	.09	1162
5	.10	1200	5	.10	1182	5	.10	1162
6	.09	1201	6	.08	1182	6	.09	1162
7	.08	1200	7	.08	1182	7	.08	1162
8	.06	1199	8	.07	1181	8	.06	1162

SCOT 2 (804)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 2 (804)
 Unit Operation: normal
 Blue is data input. Red is a calculation. Pink is a reference to a cell on another sheet.

Data Input

Control Box:	1462	
Meter $DH_{1/2}$ (0.75 scfm)	1.684	in. H ₂ O
Meter Calibration Factor (Yd)	0.994	
Test Time (Theta)	60	minutes
Barometric Pressure (Pbar)	30.00	in. Hg
Stack Static Pressure (Psg)	-1.20	in. H ₂ O
Stack Diameter (Ds) (L if rectangular)	72.0	inches
Stack Width (enter NA if circular)	NA	inches
Nozzle Diameter (Dn) (NA if NA)	NA	inches
CO ₂	14.80	% dv
O ₂	2.05	% dv
Product Rate (enter NA if not needed)	na	input ton/hr
Is the input ton/hr metric? (YES=1)	0	
Pitot Tube Coefficient (Cp)	0.84	
Sample Calculation Title	H2SO4 and CEMS	
Fe @ 68 F and 760 mm Hg (NA if NA)	1.094	dscf/MMBtu
Standard Temperature	68	F
Standard Pressure	760	mm Hg
Pitot Tube Constant (Kp)	85.49	

Calculations

Meter Temperature (Tm)	76.4	F
Stack Temperature (Tavg)	1315.3	F
Orifice Pressure Drop (dhavg)	1.700	in. H ₂ O
Gas Velocity Head (dPV) avg	0.3034	in. H ₂ O ^{1/2}
F _g @ Standard Conditions	1.094	dscf/MMBtu
F _g @ Stan. Cond. & Actual O ₂	1.094	dscf/MMBtu
Heat Input Based on F _g	750	MMBtu/hr
K1method 4	0.04707	scf/ml
K2method 4	0.04715	scf/g
K1method 5	17.64	R/in. Hg
K4method 5	0.0945	ft ³ /lb-mole
Standard lb-mole volume	385.3	ft ³ /lb-mole

Carbon Monoxide (CO)

MW	28	lb/lb-mole
O ₂ for Correction	7	vol. %
Concentration	10.87	ppm _{v, std}
Concentration	10.87	ppm _{v, std}
Concentration	8.01	ppm _{v, 7% O₂}
Concentration	0.000008	lb/dscf
Emission	0.65	lb/hr
Emission	0.006	lb/MMBtu

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run 1
 Test Start Time: 9:30 AM
 Test Finish Time: 10:30 AM
 Green is a reference to a cell on this sheet.

Calculations

CO + N ₂	83.15	% dv
Water Collected (V _r - V _i)	0.0	ml
Water Vapor Condensed (V _{wc} (std))	0.000	scf
Water Collected (W _r - W _i)	147.5	g
Water Vapor in Silica Gel (V _{wsg} (std))	6.955	scf
Vol. Water Vapor in Gas Stand. (V _w (std))	6.955	scf
Volume Dry Gas Metered (Vm)	45.505	dscf
Vol. Dry Gas Metered Stand. (Vm(std))	44.809	dscf
Volume Dry Gas Metered (Vm(m ³))	1.289	daem
Vol. Dry Gas Metered Stand. (Vm(std)m ³)	1.269	dscm
Stack Absolute Pressure (Ps)	29.91	in. Hg
Stack Absolute Temperature (Tavg)	1774.9	R
H ₂ O Vapor Pressure @ avg Stack Temp.	80661.60	in. Hg
H ₂ O in the gas at saturation (Bws)	1.0000	vol. fraction
H ₂ O in the gas from test data (Bws)	0.1344	vol. fraction
H ₂ O in the gas used (lower of the 2 Bws)	0.1344	vol. fraction
Is the Gas Stream Saturated With H ₂ O?	NO	
Dry Gas Molecular Weight (Md)	30.45	lb/lb-mole
Wet Gas Molecular Weight (Ms)	28.78	lb/lb-mole
Gas Velocity (Vs)	31.29	ft/s
Is the stack circular or rectangular?	CIRCULAR	
Area Stack (As)	28.274	ft ²
Actual Gas Flowrate	53.089	acfm
Standard Gas Flowrate	15.785	scfm
Dry Standard Gas Flowrate	13.665	dscfm
Actual Gas Flowrate	1.503	acm/min
Standard Gas Flowrate	447	scm/min
Dry Standard Gas Flowrate	387	dscm/min
Area Nozzle (An)	NA; Dn = NA	ft ²
Percent of Isokinetic Sampling (I)	NA; Dn = NA	%

Nitrogen Oxides (NOx) as NO₂

MW	46	lb/lb-mole
O ₂ for Correction	7	vol. %
Concentration	11.96	ppm _v
Concentration	8.82	ppm _{v, 7% O₂}
Concentration	0.0000014	lb/dscf
Emission	1.17	lb/hr
Emission	0.011	lb/MMBtu

Sulfuric Acid (H₂SO₄)

Total mass as H ₂ SO ₄	7.440	mg
MW H ₂ SO ₄	98	lb/lb-mole
O ₂ for Correction	7	vol. %
Concentration as H ₂ SO ₄	1.66E-07	lb/dscf
Concentration as H ₂ SO ₄	1.44	ppm _v
Concentration as H ₂ SO ₄	0.96	ppm _{v, 7% O₂}
Emission as H ₂ SO ₄	0.30	lb/hr
Emission as H ₂ SO ₄	0.003	lb/MMBtu

Point	Run 1		For C ₂			
	Pitot DP (dP) (in. H ₂ O)	SQRT dP (in. H ₂ O) ^{1/2}	Orifice DP (dh) (in. H ₂ O)	Stack Temp (F)	Meter Temp In/Out (F or C)	(F or C)
A-1	0.08	0.283	1.70	1310	72	71
A-2	0.09	0.300	1.70	1318	74	71
A-3	0.09	0.300	1.70	1305	76	71
A-4	0.11	0.332	1.70	1322	77	72
A-5	0.10	0.316	1.70	1308	78	72
A-6	0.10	0.316	1.70	1324	79	73
A-7	0.08	0.283	1.70	1325	81	74
A-8	0.07	0.265	1.70	1306	82	75
B-1	0.09	0.300	1.70	1315	82	76
B-2	0.10	0.316	1.70	1311	83	76
B-3	0.10	0.316	1.70	1308	83	76
B-4	0.12	0.346	1.70	1331	83	77
B-5	0.10	0.316				
B-6	0.09	0.300				
B-7	0.08	0.283				
B-8	0.08	0.283				
Average		0.09	0.303	1.70	1315.3	76.4
Initial volume	642.440	ft ³	Initial volume	0.000	liters	
Final volume	687.945	ft ³	Final volume	0.000	liters	
Total metered	45.505	dscf	Total metered	0.000	dry actual liters	
Impinger	Final grams	Initial grams	Gram Gain	Final ml	Initial ml	ml Gain
1	763.3	777.9	-14.6			0.0
2	749.4	682	67.4			0.0
3	772.3	724.1	48.2			0.0
4	713	689.9	23.1			0.0
5	265.6	242.2	23.4			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	3263.6	3116.1	147.5	0.0	0.0	0.0
W _i		W _f	(W _f - W _i)	V _i	V _f	(V _f - V _i)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 2 (804)
 Unit Operation: normal
 Blue is data input.
 Red is a calculation.
 Pink is a reference to a cell on another sheet.

Data Input

Control Box: 1462
 Meter DH_{sc} (0.75 scfm): 1.684 m. H₂O
 Meter Calibration Factor (Yd): 0.994
 Test Time (Theta): 60 minutes
 Barometric Pressure (Pbar): 30.0 in. Hg
 Stack Static Pressure (Pg): -1.20 in. H₂O
 Stack Diameter (Ds) (L if rectangular): 72.0 inches
 Stack Width (enter NA if circular): na inches
 Nozzle Diameter (Dn) (NA if NA): na inches
 CO2: 14.76 % dv
 O2: 2.18 % dv
 Product Rate (enter NA if not needed): na input ton/hr
 Is the input ton/hr metric? (YES=1): 0
 Pitot Tube Coefficient (Cp): 0.84
 Sample Calculation Title: Particulate and CEMS
 F₁ @ 68 F and 760 mm Hg (NA if NA): 1.094 dscf/MMBtu
 Standard Temperature: 68 F
 Standard Pressure: 760 mm Hg
 Pitot Tube Constant (Kp): 85.49
Calculations
 Meter Temperature (Tm): 83.6 F
 Stack Temperature (Tsvg): 1319.6 F
 Orifice Pressure Drop (dHavg): 1.700 in. H₂O
 Gas Velocity Head (dH)^{1/2} avg: 0.310 in. H₂O^{1/2}
 F₁ @ Standard Conditions: 1.094 dscf/MMBtu
 F₁ @ Stan. Cond. & Actual O2: 1.094 dscf/MMBtu
 Heat Input Based on F₁: 765 MMBtu/hr
 K1method 4: 0.04707 scf/ml
 K2method 4: 0.04715 scf/g
 K1method 5: 17.64 R/in. Hg
 K4method 5: 0.0945 ft³/lb-mole
 Standard lb-mole volume: 385.3

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run 2
 Test Start Time: 11:00 AM
 Test Finish Time: 12:00 PM
 Green is a reference to a cell on this sheet.

Calculations

CO + N2: 83.06 % dv
 Water Collected (V_l - V_g): 0.0 ml
 Water Vapor Condensed (Vwv(std)): 0.000 scf
 Water Collected (W_l - W_g): 146.2 g
 Water Vapor in Silica Gel (Vwsg(std)): 6.893 scf
 Vol. Water Vapor in Gas Stand (Vwv(std)): 6.893 scf
 Volume Dry Gas Metered (Vm): 45.320 dscf
 Vol. Dry Gas Metered Stand (Vm(std)): 44.035 dscf
 Volume Dry Gas Metered (Vm(m³)): 1.283 dacm
 Vol. Dry Gas Metered Stand (Vm(std)m³): 1.247 dscm
 Stack Absolute Pressure (Ps): 29.91 in. Hg
 Stack Absolute Temperature (Tsvg): 1779.3 R
 H2O Vapor Pressure @ avg Stack Temp.: 81471.05 in. Hg
 H2O in the gas at saturation (Bws): 1.0000 vol. fraction
 H2O in the gas from test data (Bwt): 0.1354 vol. fraction
 H2O in the gas used (lower of the 2 Bws): 0.1354 vol. fraction
 Is the Gas Stream Saturated With H2O?: NO
 Dry Gas Molecular Weight (Md): 30.45 lb/lb-mole
 Wet Gas Molecular Weight (Ms): 28.76 lb/lb-mole
 Gas Velocity (Vs): 32.03 ft/s
 Is the stack circular or rectangular?: CIRCULAR
 Area Stack (As): 28.274 ft²
 Actual Gas Flowrate: 54.339 acfm
 Standard Gas Flowrate: 16.118 scfm
 Dry Standard Gas Flowrate: 13.936 dscfm
 Actual Gas Flowrate: 1.539 acm/min
 Standard Gas Flowrate: .456 scm/min
 Dry Standard Gas Flowrate: .395 dscm/min
 Area Nozzle (An): NA; Dn = NA ft²
 Percent of Isokinetic Sampling (I): NA; Dn = NA %

Nitrogen Oxides (NOx) as NO2

MW: 46 lb/lb-mole
 O2 for Correction: 7 vol. %
 Concentration: 15.60 ppm_{ds}, STAP
 Concentration: 11.59 ppm_{ds}, STACK
 Concentration: 0.0000019 ppm_{ds}, 7% O2
 Concentration: 1.56 lb/dscf
 Emission: 0.014 lb/hr
Sulfuric Acid (H2SO4)
 Total mass as H2SO4: 6.140 mg
 MW H2SO4: 98 lb/lb-mole
 O2 for Correction: 7 vol. %
 Concentration as H2SO4: 3.07E-07 lb/dscf
 Concentration as H2SO4: 1.21 ppm_{ds}
 Concentration as H2SO4: 0.80 ppm_{ds}, 7% O2
 Emission as H2SO4: 0.26 lb/hr
 Emission as H2SO4: 0.002 lb/MMBtu

Valero		Run 2			For C?	
SCOT 2 (804)		Pitot DP (dP)	SQRT dP	Orifice DP (dH)	Stack Temp	Meter Temp In/Out
Point	(in. H ₂ O)	(in. H ₂ O) ^{1/2}	(in. H ₂ O)	(F)	(F or C)	(F or C)
A-1	0.09	0.300	1.70	1312	85	81
A-2	0.10	0.316	1.70	1314	86	81
A-3	0.12	0.346	1.70	1321	87	82
A-4	0.12	0.346	1.70	1324	88	82
A-5	0.10	0.316	1.70	1309	88	82
A-6	0.09	0.300	1.70	1317	87	82
A-7	0.08	0.283	1.70	1315	87	81
A-8	0.07	0.265	1.70	1312	85	81
B-1	0.09	0.300	1.70	1322	85	80
B-2	0.11	0.332	1.70	1324	85	80
B-3	0.11	0.332	1.70	1334	86	80
B-4	0.12	0.346	1.70	1331	86	80
B-5	0.10	0.316				
B-6	0.10	0.316				
B-7	0.08	0.283				
B-8	0.07	0.265				
Average		0.310	1.70	1319.6	83.6	
Initial volume	699.000	ft ³	Initial volume	0.000	liters	
Final volume	744.320	ft ³	Final volume	0.000	liters	
Total metered	45.320	dscf	Total metered	0.000	dry actual liters	
Impinger		Gram Gain	Final ml	Initial ml	ml Gain	
1	762.9	768	-5.1			0.0
2	778	720.6	57.4			0.0
3	748.4	705.2	43.2			0.0
4	744.1	726.2	17.9			0.0
5	292.3	259.5	32.8			0.0
6			0.0			0.0
7			0.0			0.0
8			0.0			0.0
9			0.0			0.0
10			0.0			0.0
Total	3325.7	3179.5	146.2	0.0	0.0	0.0
	W ₁	W ₂	(W ₁ - W ₂)	V ₁	V ₂	(V ₁ - V ₂)

Client: Valero
 Project No.: 09-129
 Plant: Valero DCR
 Unit: SCOT 2 (804)
 Unit Operation: normal

Blue is data input.
 Red is a calculation. Pink is a reference to a cell on another sheet.

Data Input

Control Box: 1462
 Meter DIH₂ (0.75 scfm): 1.684 in. H₂O
 Meter Calibration Factor (Yd): 0.9940
 Test Time (Theta): 60 minutes
 Barometric Pressure (Pbar): 30.0 in. Hg
 Stack Static Pressure (Pg): -1.20 in. H₂O
 Stack Diameter (Ds) (L if rectangular): 72.0 inches
 Stack Width (enter NA if circular): na inches
 Nozzle Diameter (Dn) (NA if NA): na inches
 CO2: 14.28 % dv
 O2: 2.15 % dv
 Product Rate (enter NA if not needed): na input ton/hr
 Is the input ton/hr metric? (YES=1): 0
 Pitot Tube Coefficient (Cp): 0.84
 Sample Calculation Title: Particulate and CEMS
 F_c @ 68 F and 760 mm Hg (NA if NA): 1.094 dscf/MMBtu
 Standard Temperature: 68 F
 Standard Pressure: 760 mm Hg
 Pitot Tube Constant (Kp): 85.49

Calculations

Meter Temperature (Tm): 88.6 F
 Stack Temperature (Tavg): 1313.7 F
 Orifice Pressure Drop (dHavg): 1.700 in. H₂O
 Gas Velocity Head (dH)^{1/2} avg: 0.3135 in. H₂O^{1/2}
 F_c @ Standard Conditions: 1.094 dscf/MMBtu
 F_c @ Stan. Cond. & Actual O2: 1.094 dscf/MMBtu
 Heat Input Based on F_d: 777 MMBtu/hr
 K1method 4: 0.04707 scf/ml
 K2method 4: 0.04715 scf/g
 K1method 5: 17.64 R/gm. Hg
 K4method 5: 0.0945 ft³/lb-mole
 Standard lb-mole volume: 385.3 ft³/lb-mole

Carbon Monoxide (CO)

MW: 28 lb/lb-mole
 O2 for Correction: 7 vol. %
 Concentration: 7.25 ppm_{25, NDIR}
 Concentration: 7.25 ppm_{25, Stack}
 Concentration: 5.38 ppm_{25, 7% O2}
 Concentration: 0.0000005 lb/dscf
 Emission: 0.45 lb/hr
 Emission: 0.004 lb/MMBtu

Test Date: September 15, 2009
 Test Location: Exhaust
 Test Run: Run J
 Test Start Time: 12:52 PM
 Test Finish Time: 1:52 PM

Green is a reference to a cell on another sheet.

Calculations

CO + N2: 83.56 % dv
 Water Collected (V_l - V_g): 0.0 ml
 Water Vapor Condensed (V_{wc}(std)): 0.000 scf
 Water Collected (W_l - W_g): 142.2 g
 Water Vapor in Silica Gel (V_{wsg}(std)): 6.705 scf
 Vol. Water Vapor in Gas Stand.(V_w(std)): 6.705 scf
 Volume Dry Gas Metered (Vm): 45.700 dscf
 Vol. Dry Gas Metered Stand.(Vm(std)): 44.003 dscf
 Volume Dry Gas Metered (Vm(m³)): 1.294 dacm
 Vol. Dry Gas Metered Stand.(Vm(std)m³): 1.246 dscm
 Stack Absolute Pressure (Ps): 29.91 in. Hg
 Stack Absolute Temperature (Tavg): 1773.3 R
 H2O Vapor Pressure @ avg Stack Temp.: 80365.44 in. Hg
 H2O in the gas at saturation (Bws): 1.0000 vol. fraction
 H2O in the gas from test data (Bws): 0.1322 vol. fraction
 H2O in the gas used (lower of the 2 Bws): 0.1322 vol. fraction
 Is the Gas Stream Saturated With H2O?: NO
 Dry Gas Molecular Weight (Md): 30.37 lb/lb-mole
 Wet Gas Molecular Weight (Ms): 28.74 lb/lb-mole
 Gas Velocity (Vs): 32.34 ft/s

Is the stack circular or rectangular? CIRCULAR
 Area Stack (As): 28.274 ft²
 Actual Gas Flowrate: 54.857 acfm
 Standard Gas Flowrate: 16.326 scfm
 Dry Standard Gas Flowrate: 14.167 dscfm
 Actual Gas Flowrate: 1.553 acm/min
 Standard Gas Flowrate: .462 scm/min
 Dry Standard Gas Flowrate: .401 dscm/min
 Area Nozzle (An): NA; Dn = NA ft²
 Percent of Isokinetic Sampling (I): NA; Dn = NA %

Nitrogen Oxides (NOx) as NO2

MW: 46 lb/lb-mole
 O2 for Correction: 7 vol. %
 Concentration: 15.39 ppm₂₅
 Concentration: 11.41 ppm_{25, 7% O2}
 Concentration: 0.0000018 lb/dscf
 Emission: 1.56 lb/hr
 Emission: 0.014 lb/MMBtu

Sulfuric Acid (H2SO4)

Total mass as H2SO4: 7.110 mg
 MW H2SO4: 98 lb/lb-mole
 O2 for Correction: 7 vol. %
 Concentration as H2SO4: 3.56E-07 lb/dscf
 Concentration as H2SO4: 1.40 ppm₂₅
 Concentration as H2SO4: 0.93 ppm_{25, 7% O2}
 Emission as H2SO4: 0.30 lb/hr
 Emission as H2SO4: 0.003 lb/MMBtu

Valero Run J F or C7
 SCOT 2 (804) F=1,C=0 I

Poin	Pitot DP (dP) (in. H ₂ O)	SORT dP (in. H ₂ O) ^{1/2}	Orifice DP (dH) (in. H ₂ O)	Stack Temp (F)	Meter Temp In/Out (F or C)	(F or C)
A-1	0.08	0.283	1.70	1320	88	84
A-2	0.10	0.316	1.70	1313	89	84
A-3	0.11	0.332	1.70	1326	90	84
A-4	0.12	0.346	1.70	1320	91	85
A-5	0.11	0.332	1.70	1319	92	86
A-6	0.10	0.316	1.70	1299	92	86
A-7	0.10	0.316	1.70	1300	91	86
A-8	0.08	0.283	1.70	1320	92	87

B-1	0.09	0.300	1.70	1325	92	87
B-2	0.10	0.316	1.70	1303	93	87
B-3	0.10	0.316	1.70	1315	93	87
B-4	0.11	0.332	1.70	1304	93	87
B-5	0.12	0.346				
B-6	0.10	0.316				
B-7	0.09	0.300				
B-8	0.07	0.265				

Average		0.313	1.70	1313.7	88.6
Initial volume	756.345	ft ³	Initial volume	0.000	liters
Final volume	802.045	ft ³	Final volume	0.000	liters
Total metered	45.700	dscf	Total metered	0.000	dry-actual liters

Impinger	Gram Gain	Final ml	Initial ml	ml Gain
1	755.7	780.4	-24.7	0.0
2	744.2	682.6	61.6	0.0
3	777.7	724	53.7	0.0
4	717.1	691.4	25.7	0.0
5	276.1	250.2	25.9	0.0
6			0.0	0.0
7			0.0	0.0
8			0.0	0.0
9			0.0	0.0
10			0.0	0.0
Total	3270.8	3128.6	142.2	0.0
	W _l	W _g	(W _l - W _g)	V _l V _g (V _l - V _g)

AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET

Client: Valero Test Type: Method 8 Meter Delta H@: 1.684 Start Time: 9:30
 Date: 9/15/09 Run Number: 1 Meter Correction: .994 Stop Time: 10:30
 Plant: Delaware City Refinery Nozzle Dia: _____ Pitot Correction: .84 Umbilical Length: 50'
 Sampling Location: Scot 804 SRU Static Press, Ps: -1.2 Control Box Num.: 1462 Probe Number: 7AL1
 Barometric Press: 30.00 Assumed Moisture: _____ Pitot Number: 10-1
 Project Number: 09-69 Ambient Temp: 65 °F Thermocouple ID: 7-1 Filter Number: _____
 Test Crew: MB, TH, JL K-factor (K_f) Measured Stack Diameter: 72"

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (ΔP)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. T _s °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
	0		642.440		1.7							68°	
A1	5		646.215	.08	1.7	5.0	72	71	1310	239	241	53	
2	10		650.265	.09	1.7	5.0	74	71	1318	251	251	54	
3	15		653.980	.09	1.7	5.0	76	71	1325	254	254	55	
4	20		657.970	.11	1.7	5.0	77	72	1322	256	241	58	
5	25		661.815	.10	1.7	5.0	78	72	1308	249	241	59	
6	30		665.650	.10	1.7	5.0	79	73	1324	251	240	60	
7	35		669.485	.08	1.7	5.0	81	74	1325	249	240	61	
8	40		673.345	.07	1.7	5.0	82	75	1306	250	239	61	
B1	45		677.135	.09	1.7	5.0	82	76	1315	251	242	61	
B2	50		680.735	.10	1.7	5.0	83	76	1311	249	242	61	
3	55		684.330	.10	1.7	5.0	83	76	1308	249	248	61	
4	60		687.945	.12	1.7	5.0	83	77	1331	250	245	62	
5				.10									
6				.09									
7				.08									
8				.08									

TOTAL/AVERAGE

Sample Train Leak Check

	(in. Hg)	Rate (ft ³ /m)
Initial	10.00	0.000
Final	6.00	0.000

Pitot Leak Check

Pressure	✓	✓
Static	✓	✓

	1	2	3	Average
CO2				
O2				
CO				
N2				

IMP	Contents	Final	Initial	Difference
1	IPA	763.3	777.9	
2	IPA	749.4	682.0	
3		772.3	724.1	
4		713.0	689.9	
5	Silica	272.8 265.6	255.6 272.2	

**AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET**

Client: Valero Test Type: Method 8 Meter Delta H@: 1.684 Start Time: 11:00
 Date: 9/15/09 Run Number: 2 Meter Correction: .994 Stop Time: 12:00
 Plant: Delaware City Refinery Nozzle Dia: _____ Pitot Correction: .84 Umbilical Length: 50'
 Sampling Location: Scot 804 SRU Static Press, Ps: -1.7 Control Box Num.: 1462 Probe Number: 746-1
 Barometric Press: 30.00 Assumed Moisture: _____ Pitot Number: 10-1
 Project Number: 09-129 Ambient Temp: 70 °F Thermocouple ID: 7-1 Filter Number: _____
 Test Crew: MB, TH, JL K-factor (K_f): Measured Stack Diameter: 22"

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (ΔP)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. Ts °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
	0		699.000		1.7							68°	
A1	5		702.845	.09	1.7	4.5	85	81	1312	255	250	52	
2	10		706.655	.10	1.7	4.5	86	81	1314	258	249	53	
3	15		710.440	.12	1.7	4.5	87	82	1321	253	251	53	
4	20		714.180	.12	1.7	4.5	88	82	1324	251	243	55	
5	25		717.175	.10	1.7	4.5	88	82	1309	251	245	56	
6	30		721.635	.09	1.7	4.5	87	82	1317	251	249	57	
7	35		725.320	.08	1.7	4.5	87	81	1315	249	247	59	
8	40		729.045	.07	1.7	4.5	85	81	1312	251	243	60	
B1	45		732.775	.09	1.7	4.5	85	80	1322	251	242	61	
2	50		736.565	.11	1.7	4.5	85	80	1324	250	244	62	
3	55		740.440	.11	1.7	5.0	86	80	1334	254	248	63	
4	60		744.320	.12	1.7	5.0	86	80	1331	256	247	62	
5				.10									
6				.10									
7				.08									
8				.07									

TOTAL/AVERAGE
Sample Train Leak Check

	(in. Hg)	Rate (ft ³ /m)
Initial	10.00	0.000
Final	8.00	0.060

Pitot Leak Check

Pressure	✓	✓
Static	✓	✓

	1	2	3	Average
CO2				
O2				
CO				
N2				

IMP	Contents	Final	Initial	Difference
1	IPA	762.9	762.9 768.0	
2	IPA	778.0	778.0 720.6	
3		748.4	705.2	
4		744.1	726.2	
5	Silica	292.3	292.3 259.5	

AIR/COMPLIANCE CONSULTANTS INC.
USEPA METHOD 8 DATA SHEET

Client: <u>Valero</u>	Test Type: <u>Method 8</u>	Meter Delta H@: <u>1.684</u>	Start Time: <u>12:52</u>
Date: <u>9/15/09</u>	Run Number: <u>3</u>	Meter Correction: <u>.994</u>	Stop Time: <u>13:52</u>
Plant: <u>Delaware City Refinery</u>	Nozzle Dia: _____	Pitot Correction: <u>.84</u>	Umbilical Length: <u>.50'</u>
Sampling Location: <u>Scot 804 SRU</u>	Static Press, Ps: <u>-1.2</u>	Control Box Num.: <u>1462</u>	Probe Number: <u>74C-1</u>
	Barometric Press: <u>30.00</u>	Assumed Moisture: _____	Pitot Number: <u>10-1</u>
Project Number: <u>09-129</u>	Ambient Temp: <u>75°</u>	°F Thermocouple ID: <u>7-1</u>	Filter Number: _____
Test Crew: <u>MB, TH, JL</u>	K-factor (K _p): <input type="text"/> <input type="text"/> <input type="text"/>		Measured Stack Diameter: <u>72''</u>

Traverse Point Number	Elapsed Time	Clock Time	Metered Volume (dcf)	Velocity Head (ΔP)	Orifice Delta H in. H ₂ O	Meter Vacuum in. Hg	Meter Temp. °F		Stack Temp. °F	Probe Temp. T _s °F	Oven Temp °F	Imp Out Temp °F	Comments
							IN/AVG	OUT					
	0		756.345	1.08	1.7							68°	
A1	.5		760.225	1.08	1.7	5.0	88	84	1320	248	252	55	
2	10		764.135	.10	1.7	5.0	89	84	1313	254	251	56	
3	15		767.950	.11	1.7	5.0	90	84	1326	252	245	59	
4	20		771.785	.12	1.7	5.0	91	85	1320	250	244	61	
5	25		775.620	.11	1.7	5.0	92	86	1319	251	246	61	
6	30		779.450	.10	1.7	5.0	92	86	1299	250	250	62	
7	35		783.390	.10	1.7	5.0	91	86	1300	249	240	62	
8	40		787.035	.08	1.7	5.0	92	87	1320	249	242	62	
B1	45		790.790	.09	1.7	5.0	92	87	1325	250	245	62	
2	50		794.540	.10	1.7	5.0	93	87	1303	248	245	63	
3	55		798.290	.10	1.7	5.0	93	87	1315	250	251	63	
4	60		802.045	.11	1.7	5.0	93	87	1304	250	247	64	
5				.12									
6				.10									
7				.09									
8				.07									
TOTAL/AVERAGE													

Sample Train Leak Check

	(in. Hg)	Rate (ft ³ /m)
Initial	2.00	10.00
Final	1.00	8.00

Pitot Leak Check

Pressure	✓	✓
Static	✓	✓

	1	2	3	Average
CO2				
O2				
CO				
N2				

IMP	Contents	Final	Initial	Difference
1		755.7	780.4	
2		744.2	682.6	
3		727.7	724.0	
4		717.1	691.4	
5	Silica	276.1	250.2	

APPENDIX B

RM Bias Sheets and 1-Minute Averages

ACCI 1 Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
1	2009/09/15	07:33:02	0.0	0.2	-0.2	0.0	2.0	14.7	9.5	20.8
2	2009/09/15	07:34:02	9.8	22.6	-0.2	0.0	1.8	14.7	10.1	5.6
3	2009/09/15	07:35:02	21.2	11.1	-0.2	0.0	2.0	14.7	9.5	11.0
4	2009/09/15	07:36:02	22.6	10.0	-0.2	0.0	2.1	14.7	9.2	28.9
5	2009/09/15	07:37:02	1.2	1.2	-0.2	22.5	1.9	14.8	9.7	10.8
6	2009/09/15	07:38:02	-0.1	0.5	-0.2	25.6	2.0	14.7	10.1	8.2
7	2009/09/15	07:39:02	-0.1	0.3	-0.2	25.6	2.1	14.6	9.7	23.6
8	2009/09/15	07:40:02	-0.1	0.2	-0.2	52.5	1.9	14.7	9.9	6.6
9	2009/09/15	07:41:02	-0.1	0.2	-0.2	55.7	2.0	14.6	9.7	8.6
10	2009/09/15	07:42:02	-0.1	0.2	-0.2	57.0	2.1	14.6	9.5	20.2
11	2009/09/15	07:43:02	-0.1	0.2	24.5	3.2	1.9	14.7	9.9	4.0
12	2009/09/15	07:44:02	-0.1	0.2	25.4	1.0	2.1	14.6	9.6	8.1
13	2009/09/15	07:45:02	-0.1	0.2	51.4	0.0	2.1	14.5	9.4	19.1
14	2009/09/15	07:46:02	-0.1	0.2	52.3	0.0	1.9	14.6	9.8	5.5
15	2009/09/15	07:47:02	-0.1	0.2	89.6	0.0	2.1	14.6	9.6	9.7
16	2009/09/15	07:48:02	-0.1	0.2	47.6	0.0	0.1	2.1	2.1	2.1
17	2009/09/15	07:49:02	-0.1	0.2	47.0	0.0	0.0	0.1	0.0	1.0
18	2009/09/15	07:50:02	-0.1	0.2	47.1	0.0	22.1	9.4	0.0	-0.1
19	2009/09/15	07:51:02	-0.1	0.2	47.1	0.0	22.7	9.9	0.0	-0.1
20	2009/09/15	07:52:02	-0.1	0.2	47.0	0.0	10.1	22.0	0.0	-0.1
21	2009/09/15	07:53:02	-0.1	0.2	47.0	0.0	9.9	22.7	0.0	-0.1
22	2009/09/15	07:54:02	-0.1	0.2	47.1	0.0	1.1	2.1	0.0	22.4
23	2009/09/15	07:55:02	-0.1	0.2	47.0	0.0	0.0	0.4	0.0	25.6
24	2009/09/15	07:56:02	-0.1	0.2	47.1	0.0	0.0	0.1	0.0	55.4
25	2009/09/15	07:57:02	-0.1	0.2	47.0	0.0	0.0	0.1	0.0	56.8
26	2009/09/15	07:58:02	12.3	0.2	88.7	0.0	0.0	0.1	25.0	4.3
27	2009/09/15	07:59:02	20.8	0.2	1.2	0.0	0.0	0.1	25.5	0.2
28	2009/09/15	08:00:02	20.8	0.2	-0.2	0.0	0.0	0.1	52.0	-0.1
29	2009/09/15	08:01:02	20.8	0.2	-0.2	0.0	0.0	0.1	52.5	-0.1
30	2009/09/15	08:02:02	20.8	0.2	-0.2	0.0	0.0	0.1	52.9	-0.1
31	2009/09/15	08:03:02	20.8	0.2	-0.2	0.0	0.0	0.1	77.7	-0.1
32	2009/09/15	08:04:02	20.8	0.2	-0.2	0.0	0.0	0.1	48.2	-0.1
33	2009/09/15	08:05:02	20.8	0.2	-0.2	2.0	0.0	0.1	46.9	-0.1
34	2009/09/15	08:06:02	20.8	0.2	-0.2	2.0	0.0	0.1	46.8	-0.1
35	2009/09/15	08:07:02	20.8	0.2	-0.2	1.8	0.0	0.1	47.0	-0.1
36	2009/09/15	08:08:02	19.7	0.3	-0.2	2.1	0.0	0.1	46.9	-0.1
37	2009/09/15	08:09:02	12.3	0.6	-0.2	2.2	0.0	0.1	46.9	-0.1
38	2009/09/15	08:10:02	0.0	0.2	-0.2	1.3	0.0	0.1	46.9	-0.1
39	2009/09/15	08:11:02	1.9	4.2	-0.2	0.3	0.0	0.1	47.0	-0.1
40	2009/09/15	08:12:02	9.7	20.5	-0.2	0.3	1.2	4.5	67.8	4.4
41	2009/09/15	08:13:02	9.8	21.6	-0.2	0.0	2.6	11.8	12.3	96.1
42	2009/09/15	08:14:02	9.8	21.9	-0.2	0.0	2.4	12.2	9.0	85.9
43	2009/09/15	08:15:02	7.8	18.1	-0.2	0.0	3.0	12.4	9.3	2.1
44	2009/09/15	08:16:02	0.0	1.8	3.6	0.0	2.2	12.5	9.4	22.6
45	2009/09/15	08:17:02	-0.1	1.1	18.6	0.0	2.1	12.6	9.5	93.9
46	2009/09/15	08:18:02	-0.1	0.8	20.1	0.2	2.2	12.4	9.6	-0.1
47	2009/09/15	08:19:02	-0.1	0.6	25.3	0.1	2.5	12.4	9.3	1.3
48	2009/09/15	08:20:02	-0.1	0.4	20.5	5.4	2.6	12.4	9.2	5.8
49	2009/09/15	08:21:02	-0.1	0.3	0.3	26.0	2.4	12.4	9.3	0.9
50	2009/09/15	08:22:02	0.8	2.2	0.0	26.0	2.5	10.1	9.0	3.7
51	2009/09/15	08:23:02	5.0	10.4	4.1	21.2	2.2	0.4	4.3	15.1
52	2009/09/15	08:24:02	6.8	12.7	21.2	1.7	-0.1	0.3	0.0	2.0
53	2009/09/15	08:25:02	6.8	12.9	21.5	1.1	0.0	0.3	-0.1	1.5
54	2009/09/15	08:26:02	6.6	13.3	21.8	0.8	0.0	0.2	23.5	-0.1
55	2009/09/15	08:27:02	6.7	13.1	21.6	0.6	0.0	0.2	25.5	2.4
56	2009/09/15	08:28:02	6.7	13.2	21.7	0.8	0.0	0.2	11.2	15.7
57	2009/09/15	08:29:02	6.6	13.3	22.1	0.8	1.2	4.1	0.0	24.8
58	2009/09/15	08:30:02	6.6	13.3	21.9	0.8	7.0	19.9	0.1	16.9
59	2009/09/15	08:31:02	6.7	13.2	22.1	0.8	10.0	22.2	0.0	-1.0
60	2009/09/15	08:32:02	6.5	13.4	21.8	0.8	9.2	18.0	0.0	-1.0
61	2009/09/15	08:33:02	6.5	13.6	21.6	0.8	4.8	0.7	0.0	3.0
62	2009/09/15	08:34:02	6.5	13.4	21.6	0.8	0.5	3.0	0.0	23.7
63	2009/09/15	08:35:02	6.7	13.3	21.8	0.8	2.1	13.8	0.2	22.6
64	2009/09/15	08:36:02	6.5	13.5	21.7	0.9	2.3	14.0	0.2	27.7
65	2009/09/15	08:37:02	6.5	13.5	21.5	1.1	2.1	14.0	0.2	1.8
66	2009/09/15	08:38:02	6.7	13.3	21.9	1.0	2.2	14.1	0.2	3.4
67	2009/09/15	08:39:02	6.6	13.5	21.6	0.9	2.3	14.1	2.0	21.7
68	2009/09/15	08:40:02	6.6	13.5	21.8	1.1	2.1	14.2	9.3	8.0
69	2009/09/15	08:41:02	6.7	13.4	21.6	1.1	2.1	14.2	9.6	2.7
70	2009/09/15	08:42:02	6.6	13.5	21.7	1.0	2.3	14.2	9.0	17.0
71	2009/09/15	08:43:02	6.5	13.5	22.0	1.2	2.1	14.2	9.6	6.7
72	2009/09/15	08:44:02	6.6	13.4	21.8	1.1	2.0	14.2	9.7	1.1
73	2009/09/15	08:45:02	6.5	13.5	21.8	1.2	2.2	14.2	9.2	12.9
74	2009/09/15	08:46:02	6.5	13.5	21.6	1.2	2.0	14.2	9.5	8.3
75	2009/09/15	08:47:02	6.5	13.5	21.6	1.2	2.0	14.3	9.8	2.3
76	2009/09/15	08:48:02	6.7	13.4	21.7	1.2	2.1	14.2	9.3	15.2
77	2009/09/15	08:49:02	6.6	13.4	21.5	1.2	1.9	14.3	9.7	5.9
78	2009/09/15	08:50:02	6.6	13.3	21.8	1.2	1.9	14.3	9.8	2.9
79	2009/09/15	08:51:02	6.5	13.4	21.6	1.2	2.0	14.2	9.3	16.7
80	2009/09/15	08:52:02	6.6	13.3	21.8	1.2	1.8	14.4	9.8	2.5
81	2009/09/15	08:53:02	6.6	13.4	21.6	1.4	1.9	14.3	9.8	3.5

ACCI 1 Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
82	2009/09/15	08:54:02	6.4	13.6	21.6	1.5	2.0	14.2	9.3	16.7
83	2009/09/15	08:55:02	6.5	13.4	21.5	1.4	1.8	14.3	9.9	2.9
84	2009/09/15	08:56:02	6.5	13.4	21.2	1.4	1.9	14.3	10.0	2.5
85	2009/09/15	08:57:02	6.5	13.4	21.4	1.5	2.0	14.2	9.3	17.5
86	2009/09/15	08:58:02	6.5	13.4	21.6	1.4	1.8	14.4	9.7	6.1
87	2009/09/15	08:59:02	6.6	13.3	21.5	1.4	1.8	14.4	9.8	3.0
88	2009/09/15	09:00:02	5.9	14.0	22.5	1.6	1.9	14.3	9.3	18.4
89	2009/09/15	09:01:02	3.1	16.2	28.0	1.9	1.7	14.4	9.7	4.0
90	2009/09/15	09:02:02	3.2	16.1	29.4	2.2	1.7	14.4	9.8	3.4
91	2009/09/15	09:03:02	3.1	16.3	29.2	2.4	1.9	14.3	9.1	21.6
92	2009/09/15	09:04:02	3.1	16.3	29.1	2.4	1.7	14.4	9.7	4.4
93	2009/09/15	09:05:02	3.3	16.2	28.6	2.6	1.8	14.4	10.0	3.4
94	2009/09/15	09:06:02	3.3	16.2	28.7	2.6	1.9	14.4	9.1	24.1
95	2009/09/15	09:07:02	3.5	16.1	28.4	2.6	1.7	14.5	9.6	11.4
96	2009/09/15									
97	2009/09/15									
98	2009/09/15									
99	2009/09/15	09:11:47	INVALID	INVALID	INVALID	INVALID	INVALID	INVALID	INVALID	INVALID
100	2009/09/15	09:12:47	4.35	15.9	25.67	2.07	1.91	14.5	9.58	10.23
101	2009/09/15	09:13:47	4.49	15.9	25.33	1.93	1.69	14.6	9.88	5.41
102	2009/09/15	09:14:47	4.54	15.9	25.31	1.79	1.65	14.7	10.13	1.12
103	2009/09/15	09:15:47	4.58	15.9	24.91	1.75	1.66	14.7	9.77	8.47
104	2009/09/15	09:16:47	4.62	15.8	24.75	1.68	1.42	14.7	10.24	2.14
105	2009/09/15	09:17:47	4.68	15.7	24.93	1.59	1.53	14.7	10.30	0.01
106	2009/09/15	09:18:47	4.66	15.7	24.88	1.52	1.74	14.7	9.77	8.68
107	2009/09/15	09:19:47	4.68	15.7	24.61	1.44	1.61	14.7	10.01	6.03
108	2009/09/15	09:20:47	4.74	15.7	24.48	1.44	1.61	14.7	10.23	-0.06
109	2009/09/15	09:21:47	4.71	15.8	24.82	1.41	1.84	14.6	9.70	9.74
110	2009/09/15	09:22:47	4.76	15.8	24.59	1.35	1.86	14.6	9.71	14.20
111	2009/09/15	09:23:47	4.80	15.9	24.65	1.35	1.76	14.6	10.00	1.41
112	2009/09/15	09:24:47	4.71	16.0	24.39	1.27	1.95	14.6	9.66	10.60
113	2009/09/15	09:25:47	4.41	16.2	25.11	1.28	1.87	14.6	9.77	15.74
114	2009/09/15	09:26:47	4.33	16.3	25.36	1.28	1.80	14.6	10.04	1.24
115	2009/09/15	09:27:47	4.13	16.4	25.41	1.20	1.98	14.6	9.60	8.09
116	2009/09/15	09:28:47	4.05	16.4	25.74	1.19	1.95	14.6	9.52	15.05
117	2009/09/15	09:29:47	4.04	16.4	25.99	1.15	1.79	14.6	9.99	2.40
RUN 1										
1	2009/09/15	09:30:47	4.00	16.4	26.33	1.16	1.92	14.6	10.00	3.03
2	2009/09/15	09:31:47	3.94	16.4	26.39	1.13	2.07	14.6	9.53	17.16
3	2009/09/15	09:32:47	3.93	16.5	26.37	1.12	1.93	14.6	9.75	10.75
4	2009/09/15	09:33:47	3.92	16.5	25.84	1.17	1.88	14.7	9.91	3.13
5	2009/09/15	09:34:47	3.86	16.6	25.70	1.18	2.03	14.6	9.44	15.68
6	2009/09/15	09:35:47	3.85	16.5	25.95	1.20	1.85	14.7	9.70	8.75
7	2009/09/15	09:36:47	3.85	16.5	25.87	1.21	1.88	14.7	9.81	5.05
8	2009/09/15	09:37:47	3.81	16.7	25.74	1.23	2.02	14.7	9.33	20.55
9	2009/09/15	09:38:47	3.80	16.7	25.68	1.19	1.85	14.8	9.61	8.61
10	2009/09/15	09:39:47	3.80	16.6	25.82	1.15	1.94	14.7	9.49	7.79
11	2009/09/15	09:40:47	3.84	16.6	25.59	1.10	2.00	14.7	9.48	20.80
12	2009/09/15	09:41:47	3.78	16.6	25.41	1.08	1.82	14.7	10.10	5.65
13	2009/09/15	09:42:47	3.86	16.6	25.38	1.01	2.00	14.7	9.45	10.95
14	2009/09/15	09:43:47	3.88	16.6	25.69	0.99	2.08	14.7	9.21	28.86
15	2009/09/15	09:44:47	4.01	16.5	25.54	0.98	1.90	14.8	9.72	10.81
16	2009/09/15	09:45:47	4.01	16.5	25.05	1.01	1.97	14.7	10.08	8.19
17	2009/09/15	09:46:47	4.01	16.5	24.60	1.04	2.09	14.6	9.69	23.62
18	2009/09/15	09:47:47	4.02	16.4	24.55	1.02	1.89	14.7	9.90	6.61
19	2009/09/15	09:48:47	3.97	16.4	24.73	1.03	2.01	14.6	9.67	8.58
20	2009/09/15	09:49:47	3.94	16.4	24.72	1.01	2.05	14.6	9.50	20.23
21	2009/09/15	09:50:47	3.98	16.4	24.75	0.97	1.89	14.7	9.92	4.03
22	2009/09/15	09:51:47	3.95	16.4	24.69	0.98	2.06	14.6	9.60	8.11
23	2009/09/15	09:52:47	3.97	16.4	24.70	1.01	2.11	14.5	9.45	19.13
24	2009/09/15	09:53:47	4.02	16.3	24.85	0.99	1.94	14.6	9.81	5.54
25	2009/09/15	09:54:47	4.01	16.3	24.84	0.96	2.08	14.6	9.58	9.68
26	2009/09/15	09:55:47	3.99	16.4	24.51	1.01	2.15	14.6	9.28	26.15
27	2009/09/15	09:56:47	4.05	16.3	24.53	1.02	1.98	14.6	9.56	10.05
28	2009/09/15	09:57:47	4.07	16.3	24.60	0.98	2.03	14.6	9.65	7.15
29	2009/09/15	09:58:47	4.05	16.4	24.70	1.00	2.17	14.6	9.25	27.15
30	2009/09/15	09:59:47	4.06	16.4	24.22	1.02	1.96	14.7	9.66	14.76
31	2009/09/15	10:00:47	4.05	16.4	24.18	1.03	1.98	14.6	9.74	4.95
32	2009/09/15	10:01:47	4.00	16.4	24.19	1.01	2.15	14.5	9.38	21.08
33	2009/09/15	10:02:47	4.02	16.3	24.53	1.01	1.99	14.5	9.59	14.83
34	2009/09/15	10:03:47	4.04	16.2	24.70	1.00	1.98	14.6	9.77	8.40
35	2009/09/15	10:04:47	3.95	16.3	24.91	0.98	2.23	14.5	9.34	37.46
36	2009/09/15	10:05:47	3.94	16.3	24.88	1.02	2.03	14.6	9.58	28.27
37	2009/09/15	10:06:47	3.95	16.4	25.34	1.04	1.92	14.7	10.01	4.44
38	2009/09/15	10:07:47	3.91	16.5	28.16	1.01	2.10	14.7	11.32	14.38
39	2009/09/15	10:08:47	3.84	16.6	37.63	1.01	1.92	14.8	15.90	3.59
40	2009/09/15	10:09:47	3.88	16.5	40.14	1.01	2.01	14.7	16.48	-0.46
41	2009/09/15	10:10:47	3.82	16.6	39.92	1.03	2.25	14.7	15.63	4.50
42	2009/09/15	10:11:47	3.87	16.6	39.65	1.06	2.07	14.7	15.92	2.73
43	2009/09/15	10:12:47	3.90	16.5	40.44	1.02	2.02	14.7	16.03	0.30
44	2009/09/15	10:13:47	3.97	16.4	39.98	1.04	2.28	14.6	15.31	6.59

ACCI 1 Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
45	2009/09/15	10:14:47	4.01	16.3	39.31	1.02	2.09	14.7	15.53	5.06
46	2009/09/15	10:15:47	4.14	16.3	39.57	1.09	2.05	14.7	15.81	1.03
47	2009/09/15	10:16:47	4.14	16.3	39.38	1.13	2.23	14.6	15.43	7.03
48	2009/09/15	10:17:47	4.17	16.3	39.01	1.01	2.03	14.7	15.75	3.23
49	2009/09/15	10:18:47	4.22	16.4	39.05	1.04	2.12	14.7	15.83	1.70
50	2009/09/15	10:19:47	4.15	16.5	38.69	1.06	2.15	14.8	15.48	7.59
51	2009/09/15	10:20:47	4.13	16.5	39.10	1.05	1.90	14.8	16.07	2.23
52	2009/09/15	10:21:47	4.19	16.5	38.86	1.11	1.95	14.9	16.03	0.75
53	2009/09/15	10:22:47	4.15	16.5	37.99	1.12	2.20	14.7	15.41	7.96
54	2009/09/15	10:23:47	4.25	16.4	38.39	1.04	2.00	14.8	15.79	4.03
55	2009/09/15	10:24:47	4.23	16.4	38.08	1.01	2.00	14.8	15.68	1.31
56	2009/09/15	10:25:47	4.31	16.3	38.11	1.04	2.19	14.7	15.23	7.81
57	2009/09/15	10:26:47	4.34	16.3	38.17	1.19	1.95	14.8	15.65	3.00
58	2009/09/15	10:27:47	4.30	16.3	38.03	1.23	2.05	14.8	15.51	2.53
59	2009/09/15	10:28:47	4.33	16.2	37.99	1.13	2.11	14.7	15.35	8.00
60	2009/09/15	10:29:47	4.36	16.3	38.18	1.20	1.89	14.9	15.74	1.58
RUN AVERAGES			4.01	16.43	30.23	1.06	2.02	14.67	11.89	9.87
61	2009/09/15	10:30:47	5.32	16.3	36.09	2.68	2.08	14.8	15.31	3.65
62	2009/09/15	10:31:47	9.29	17.5	23.17	6.85	2.03	14.8	15.30	6.23
63	2009/09/15	10:32:47	9.90	22.0	0.67	0.47	1.96	14.8	15.38	2.30
64	2009/09/15	10:33:47	8.82	19.9	-0.13	1.96	2.21	14.7	14.86	11.09
65	2009/09/15	10:34:47	3.74	9.3	-0.20	8.73	2.00	14.8	15.25	7.28
66	2009/09/15	10:35:47	0.00	1.4	-0.20	25.13	1.99	14.8	15.38	2.70
67	2009/09/15	10:36:47	0.00	0.9	2.87	21.72	2.12	14.8	15.27	10.64
68	2009/09/15	10:37:47	-0.02	0.3	16.64	4.77	1.90	14.9	15.70	3.63
69	2009/09/15	10:38:47	0.09	1.1	25.13	0.75	2.07	13.2	15.44	1.86
70	2009/09/15	10:39:47	1.42	5.8	26.94	0.67	2.07	5.4	16.10	7.14
71	2009/09/15	10:40:47	4.23	15.6	34.48	0.66	0.14	0.5	25.33	0.60
72	2009/09/15	10:41:47	4.24	15.9	38.39	0.48	0.00	0.5	19.58	5.62
73	2009/09/15	10:42:47	4.15	16.2	37.86	0.40	0.00	0.4	1.13	22.98
74	2009/09/15	10:43:47	4.11	16.3	37.76	0.41	1.12	4.1	0.00	25.31
75	2009/09/15	10:44:47	4.13	16.2	38.34	0.43	6.31	18.7	0.00	13.52
76	2009/09/15	10:45:47	4.11	16.2	38.76	0.40	9.92	22.2	0.00	-1.64
77	2009/09/15	10:46:47	4.12	16.3	38.58	0.43	8.64	20.6	2.19	-3.47
78	2009/09/15	10:47:47	4.18	16.2	38.46	0.52	3.25	15.0	11.45	-1.54
79	2009/09/15	10:48:47	4.25	16.2	39.04	0.47	2.07	14.9	15.25	4.05
80	2009/09/15	10:49:47	4.23	16.3	39.11	0.46	2.02	14.9	15.38	8.24
81	2009/09/15	10:50:47	4.25	16.3	38.68	0.44	1.81	15.0	15.76	0.94
82	2009/09/15	10:51:47	4.27	16.3	38.71	0.47	1.96	14.9	15.61	2.05
83	2009/09/15	10:52:47	4.28	16.4	38.41	0.47	2.02	14.9	15.26	7.18
84	2009/09/15	10:53:47	4.30	16.4	38.00	0.49	1.85	15.0	15.71	2.14
85	2009/09/15	10:54:47	4.27	16.4	38.46	0.61	1.96	14.9	15.54	2.17
86	2009/09/15	10:55:47	4.18	16.5	38.44	0.67	2.00	14.9	15.25	5.40
87	2009/09/15	10:56:47	4.19	16.4	39.06	0.69	1.84	14.9	15.79	1.22
88	2009/09/15	10:57:47	4.11	16.4	38.93	0.76	1.97	14.8	15.62	1.84
89	2009/09/15	10:58:47	4.04	16.3	39.32	0.60	2.09	14.8	15.67	8.46
90	2009/09/15	10:59:47	4.11	16.3	40.00	0.60	1.91	14.9	15.42	2.84
RUN 2										
1	2009/09/15	11:00:47	4.07	16.3	39.65	0.60	2.07	14.8	15.13	5.35
2	2009/09/15	11:01:47	4.06	16.4	39.03	0.60	2.20	14.6	14.98	16.62
3	2009/09/15	11:02:47	4.11	16.3	39.58	0.56	1.95	14.9	15.86	4.02
4	2009/09/15	11:03:47	4.15	16.3	39.48	0.55	2.26	14.8	15.34	13.05
5	2009/09/15	11:04:47	4.16	16.2	39.54	0.61	2.09	14.8	15.72	13.93
6	2009/09/15	11:05:47	4.29	16.1	39.95	0.64	1.93	14.8	16.32	0.72
7	2009/09/15	11:06:47	4.30	16.1	39.71	0.65	2.12	14.8	15.78	2.60
8	2009/09/15	11:07:47	4.29	16.1	39.47	0.57	2.13	14.8	15.58	5.03
9	2009/09/15	11:08:47	4.33	16.1	38.97	0.61	1.97	14.9	15.67	1.28
10	2009/09/15	11:09:47	4.25	16.3	38.12	0.68	2.13	14.9	15.11	4.38
11	2009/09/15	11:10:47	4.30	16.2	37.76	0.71	2.10	14.9	14.81	9.25
12	2009/09/15	11:11:47	4.28	16.2	37.38	0.61	1.96	15.0	15.20	2.08
13	2009/09/15	11:12:47	4.22	16.3	37.63	0.64	2.21	14.9	14.81	8.07
14	2009/09/15	11:13:47	4.25	16.2	37.45	0.67	2.07	14.9	14.98	8.16
15	2009/09/15	11:14:47	4.25	16.2	37.26	0.67	1.98	15.0	15.13	1.48
16	2009/09/15	11:15:47	4.24	16.2	37.38	0.65	2.22	14.8	14.67	7.79
17	2009/09/15	11:16:47	4.28	16.1	37.55	0.60	2.05	14.9	15.01	4.70
18	2009/09/15	11:17:47	4.28	16.1	37.09	0.61	2.12	14.8	14.90	3.37
19	2009/09/15	11:18:47	4.30	16.1	37.18	0.63	2.24	14.8	14.73	11.55
20	2009/09/15	11:19:47	4.29	16.1	37.33	0.60	2.01	14.9	15.17	3.26
21	2009/09/15	11:20:47	4.30	16.1	37.67	0.60	2.18	14.8	15.08	5.44
22	2009/09/15	11:21:47	4.32	16.1	38.73	0.60	2.17	14.8	15.48	10.17
23	2009/09/15	11:22:47	4.30	16.0	39.28	0.61	2.00	14.9	16.11	1.46
24	2009/09/15	11:23:47	4.27	16.0	39.39	0.63	2.27	14.7	15.79	5.94
25	2009/09/15	11:24:47	4.30	16.0	39.36	0.61	2.17	14.8	15.91	7.35
26	2009/09/15	11:25:47	4.31	16.0	39.71	0.63	2.08	14.9	16.15	2.05
27	2009/09/15	11:26:47	4.27	16.2	39.60	0.63	2.28	14.9	15.62	9.62
28	2009/09/15	11:27:47	4.33	16.1	39.33	0.63	2.09	14.9	15.99	6.08
29	2009/09/15	11:28:47	4.30	16.1	39.43	0.60	2.01	15.0	16.27	0.90
30	2009/09/15	11:29:47	4.26	16.1	39.72	0.61	2.31	14.8	15.67	7.17
31	2009/09/15	11:30:47	4.29	16.1	39.51	0.69	2.19	14.8	15.82	6.64

ACCI 1 Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
32	2009/09/15	11:31:47	4.30	16.0	39.36	0.74	2.16	14.8	15.89	2.81
33	2009/09/15	11:32:47	4.27	15.9	39.80	0.67	2.37	14.7	15.44	11.00
34	2009/09/15	11:33:47	4.29	15.8	40.02	0.65	2.15	14.7	15.85	5.26
35	2009/09/15	11:34:47	4.27	15.9	40.38	0.61	2.26	14.7	15.83	4.50
36	2009/09/15	11:35:47	4.27	15.9	39.88	0.64	2.35	14.7	15.54	14.10
37	2009/09/15	11:36:47	4.32	15.9	40.09	0.67	2.11	14.8	16.00	5.04
38	2009/09/15	11:37:47	4.30	15.9	40.02	0.67	2.15	14.8	15.99	2.76
39	2009/09/15	11:38:47	4.30	15.8	39.98	0.69	2.32	14.7	15.55	10.60
40	2009/09/15	11:39:47	4.35	15.7	40.09	0.77	2.13	14.8	15.91	4.03
41	2009/09/15	11:40:47	4.37	15.6	39.73	0.77	2.32	14.6	15.63	5.70
42	2009/09/15	11:41:47	4.35	15.6	39.61	0.77	2.32	14.5	15.50	13.16
43	2009/09/15	11:42:47	4.40	15.5	39.43	0.77	2.11	14.5	16.10	2.60
44	2009/09/15	11:43:47	4.38	15.5	39.80	0.67	2.30	14.4	15.84	4.61
45	2009/09/15	11:44:47	4.41	15.5	39.76	0.71	2.31	14.4	15.67	9.34
46	2009/09/15	11:45:47	4.46	15.4	39.88	0.73	2.13	14.5	16.03	1.88
47	2009/09/15	11:46:47	4.37	15.5	39.59	0.72	2.31	14.4	15.72	4.49
48	2009/09/15	11:47:47	4.40	15.6	39.65	0.69	2.34	14.4	15.61	11.11
49	2009/09/15	11:48:47	4.39	15.6	39.69	0.64	2.15	14.5	15.84	2.74
50	2009/09/15	11:49:47	4.38	15.7	39.15	0.70	2.39	14.4	15.29	7.63
51	2009/09/15	11:50:47	4.38	15.7	38.73	0.80	2.21	14.5	15.45	6.92
52	2009/09/15	11:51:47	4.31	15.8	38.64	0.80	2.20	14.6	15.45	3.57
53	2009/09/15	11:52:47	4.33	15.8	38.04	0.81	2.38	14.4	15.03	12.67
54	2009/09/15	11:53:47	4.37	15.7	37.54	0.83	2.18	14.5	15.44	3.95
55	2009/09/15	11:54:47	4.37	15.7	37.96	0.80	2.35	14.5	15.20	6.05
56	2009/09/15	11:55:47	4.40	15.6	38.18	0.80	2.32	14.4	15.34	11.88
57	2009/09/15	11:56:47	4.46	15.6	38.50	0.80	2.15	14.5	15.73	2.47
58	2009/09/15	11:57:47	4.44	15.6	38.50	0.80	2.39	14.4	15.22	7.72
59	2009/09/15	11:58:47	4.51	15.5	38.66	0.81	2.27	14.4	15.41	8.23
60	2009/09/15	11:59:47	4.51	15.3	38.94	0.87	2.19	14.3	15.71	1.46
RUN AVERAGES			4.31	15.92	38.98	0.68	2.18	14.70	15.53	6.30

61	2009/09/15	12:00:47	4.44	15.3	39.16	0.88	2.35	14.2	15.37	6.07
62	2009/09/15	12:01:47	4.39	15.2	39.06	0.80	2.12	14.3	15.84	1.62
63	2009/09/15	12:02:47	4.12	13.5	39.28	2.19	2.30	14.2	15.60	3.17
64	2009/09/15	12:03:47	2.60	5.8	35.56	6.24	2.38	14.1	15.40	8.77
65	2009/09/15	12:04:47	0.00	1.0	25.09	2.30	2.24	14.2	15.68	1.84
66	2009/09/15	12:05:47	-0.02	0.5	19.25	8.49	2.44	14.1	15.34	5.53
67	2009/09/15	12:06:47	1.02	2.8	1.53	26.12	2.38	14.1	15.31	9.97
68	2009/09/15	12:07:47	6.20	13.5	-0.06	17.22	2.25	14.2	15.80	1.81
69	2009/09/15	12:08:47	9.80	22.1	-0.20	1.47	2.68	13.2	15.16	8.27
70	2009/09/15	12:09:47	8.74	20.7	3.13	0.49	2.76	7.6	15.89	7.88
71	2009/09/15	12:10:47	4.73	15.7	20.59	1.04	0.53	0.5	21.52	-0.11
72	2009/09/15	12:11:47	4.51	15.5	39.08	1.00	0.00	0.5	25.46	-1.90
73	2009/09/15	12:12:47	4.57	15.4	38.83	0.76	0.00	0.4	21.62	2.23
74	2009/09/15	12:13:47	4.62	15.4	39.09	0.73	0.00	0.4	5.77	16.32
75	2009/09/15	12:14:47	4.62	15.4	39.04	0.72	0.81	3.3	0.05	25.05
76	2009/09/15	12:15:47	4.64	15.5	38.29	0.79	5.12	16.0	0.11	16.01
77	2009/09/15	12:16:47	4.62	15.4	37.75	0.77	9.84	22.3	-0.02	-1.82
78	2009/09/15	12:17:47	4.59	15.4	37.59	0.81	9.52	21.4	0.16	-3.86
79	2009/09/15	12:18:47	4.59	15.4	37.93	0.82	6.59	17.3	3.97	-3.15
80	2009/09/15	12:19:47	4.65	15.3	38.43	0.76	2.42	14.3	15.05	-0.98
81	2009/09/15	12:20:47	4.64	15.3	37.69	0.77	2.46	14.2	14.98	11.23
82	2009/09/15	12:21:47	4.69	15.2	37.58	0.90	2.26	14.2	15.34	6.38
83	2009/09/15	12:22:47	4.67	15.3	37.95	0.88	2.32	14.2	15.46	2.74
84	2009/09/15	12:23:47	4.63	15.3	38.03	0.81	2.42	14.2	15.16	10.08
85	2009/09/15	12:24:47	4.65	15.3	37.71	0.85	2.22	14.3	15.69	3.39
86	2009/09/15	12:25:47	4.61	15.3	37.85	0.77	2.28	14.3	15.72	2.46
87	2009/09/15	12:26:47	4.63	15.3	37.98	0.81	2.44	14.3	15.14	10.54
88	2009/09/15	12:27:47	4.67	15.3	38.26	0.90	2.21	14.3	15.48	4.43
89	2009/09/15	12:28:47	4.69	15.3	38.39	1.05	2.32	14.3	15.57	3.08
90	2009/09/15	12:29:47	4.61	15.4	38.90	1.07	2.44	14.3	15.16	12.05
91	2009/09/15	12:30:47	4.60	15.4	38.87	0.98	2.25	14.3	15.54	5.91
92	2009/09/15	12:31:47	4.61	15.3	38.73	1.06	2.23	14.4	15.80	1.70
93	2009/09/15	12:32:47	4.57	15.4	39.05	0.82	2.48	14.3	15.15	9.98
94	2009/09/15	12:33:47	4.57	15.5	38.97	0.87	2.31	14.4	15.50	8.92
95	2009/09/15	12:34:47	4.61	15.5	39.08	0.89	2.27	14.4	15.72	1.97
96	2009/09/15	12:35:47	4.55	15.5	39.60	0.83	2.43	14.5	15.28	9.54
97	2009/09/15	12:36:47	4.57	15.6	38.74	0.85	2.29	14.5	15.57	7.81
98	2009/09/15	12:37:47	4.55	15.6	38.98	0.91	2.16	14.4	15.85	0.67
99	2009/09/15	12:38:47	4.51	15.5	39.58	0.86	2.39	14.3	15.56	4.21
100	2009/09/15	12:39:47	4.51	15.5	39.26	0.95	2.34	14.3	15.49	9.06
101	2009/09/15	12:40:47	4.49	15.5	39.51	0.87	2.19	14.4	15.89	0.94
102	2009/09/15	12:41:47	4.53	15.5	39.97	0.92	2.37	14.3	15.55	3.99
103	2009/09/15	12:42:47	4.42	15.6	39.58	1.00	2.34	14.4	15.34	9.29
104	2009/09/15	12:43:47	4.39	15.6	39.06	1.00	2.14	14.4	15.78	1.55
105	2009/09/15	12:44:47	4.37	15.5	39.36	0.98	2.22	14.3	15.71	1.08
106	2009/09/15	12:45:47	4.34	15.5	39.58	0.91	2.38	14.3	15.24	7.53
107	2009/09/15	12:46:47	4.39	15.4	38.94	0.94	2.21	14.3	15.66	3.73
108	2009/09/15	12:47:47	4.41	15.4	38.67	0.93	2.23	14.2	15.74	0.78
109	2009/09/15	12:48:47	4.39	15.4	39.00	0.93	2.42	14.3	15.21	8.93

ACCI I Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
110	2009/09/15	12:49:47	4.40	15.6	38.69	0.92	2.34	14.4	15.30	10.87
111	2009/09/15	12:50:47	4.50	15.6	38.56	1.01	2.20	14.4	15.74	1.85
112	2009/09/15	12:51:47	4.47	15.6	38.22	1.01	2.31	14.4	15.46	4.42
RUN 3										
1	2009/09/15	12:52:47	4.45	15.6	37.82	0.93	2.26	14.3	15.30	12.39
2	2009/09/15	12:53:47	4.47	15.5	37.56	0.91	2.02	14.4	15.84	2.89
3	2009/09/15	12:54:47	4.49	15.5	37.87	0.95	2.10	14.3	15.73	2.18
4	2009/09/15	12:55:47	4.43	15.5	37.41	1.01	2.21	14.3	15.29	9.38
5	2009/09/15	12:56:47	4.48	15.4	37.99	1.04	2.01	14.3	15.65	2.89
6	2009/09/15	12:57:47	4.45	15.4	37.98	1.05	2.13	14.3	15.49	3.06
7	2009/09/15	12:58:47	4.47	15.3	37.89	1.00	2.21	14.2	15.34	8.75
8	2009/09/15	12:59:47	4.51	15.2	38.09	1.00	2.10	14.2	15.56	1.81
9	2009/09/15	13:00:47	4.43	15.3	37.74	1.01	2.27	14.2	15.32	6.87
10	2009/09/15	13:01:47	4.42	15.4	37.98	1.03	2.19	14.2	15.37	12.05
11	2009/09/15	13:02:47	4.43	15.4	37.96	1.00	2.06	14.3	15.52	1.59
12	2009/09/15	13:03:47	4.43	15.4	37.21	0.99	2.23	14.3	15.08	7.95
13	2009/09/15	13:04:47	4.41	15.5	36.75	0.98	2.13	14.3	15.26	9.74
14	2009/09/15	13:05:47	4.43	15.4	37.52	1.04	2.02	14.3	15.38	0.95
15	2009/09/15	13:06:47	4.39	15.4	37.70	1.15	2.28	14.2	14.93	8.07
16	2009/09/15	13:07:47	4.44	15.3	37.47	1.13	2.21	14.2	15.00	11.85
17	2009/09/15	13:08:47	4.48	15.3	37.78	1.22	2.11	14.3	15.28	3.36
18	2009/09/15	13:09:47	4.47	15.3	37.38	1.05	2.30	14.1	15.05	12.41
19	2009/09/15	13:10:47	4.52	15.3	37.39	1.01	2.12	14.2	15.27	8.31
20	2009/09/15	13:11:47	4.53	15.3	37.18	1.09	2.18	14.2	15.29	4.02
21	2009/09/15	13:12:47	4.49	15.3	37.46	1.17	2.23	14.2	15.00	12.02
22	2009/09/15	13:13:47	4.55	15.3	37.32	1.18	2.01	14.3	15.51	2.63
23	2009/09/15	13:14:47	4.44	15.3	36.77	1.09	2.16	14.3	15.21	3.85
24	2009/09/15	13:15:47	4.39	15.4	36.49	1.03	2.20	14.2	15.17	11.28
25	2009/09/15	13:16:47	4.41	15.4	36.69	1.05	1.98	14.3	15.68	2.12
26	2009/09/15	13:17:47	4.36	15.3	36.90	1.10	2.17	14.2	15.12	5.03
27	2009/09/15	13:18:47	4.29	15.4	37.08	1.09	2.18	14.2	15.07	11.66
28	2009/09/15	13:19:47	4.31	15.3	37.04	1.06	1.99	14.2	15.04	1.64
29	2009/09/15	13:20:47	4.35	15.3	37.61	1.14	2.21	14.1	15.26	5.42
30	2009/09/15	13:21:47	4.36	15.2	37.59	1.15	2.29	14.0	15.05	16.13
31	2009/09/15	13:22:47	4.39	15.2	38.06	1.11	2.05	14.1	15.61	4.17
32	2009/09/15	13:23:47	4.45	15.2	38.02	1.15	2.20	14.1	15.28	4.74
33	2009/09/15	13:24:47	4.37	15.3	38.16	1.07	2.25	14.1	15.10	13.82
34	2009/09/15	13:25:47	4.45	15.2	38.13	1.08	2.06	14.2	15.60	4.50
35	2009/09/15	13:26:47	4.47	15.2	37.94	1.15	2.14	14.2	15.54	2.96
36	2009/09/15	13:27:47	4.39	15.4	37.43	1.20	2.25	14.2	15.04	12.49
37	2009/09/15	13:28:47	4.32	15.5	37.23	1.19	2.04	14.3	15.35	7.46
38	2009/09/15	13:29:47	4.35	15.5	37.58	1.15	2.00	14.3	15.52	1.72
39	2009/09/15	13:30:47	4.32	15.6	36.85	1.20	2.20	14.2	15.08	9.20
40	2009/09/15	13:31:47	4.36	15.5	37.05	1.19	2.02	14.2	15.46	5.98
41	2009/09/15	13:32:47	4.36	15.4	37.50	1.15	2.11	14.2	15.38	3.79
42	2009/09/15	13:33:47	4.36	15.5	37.03	1.20	2.20	14.1	15.33	12.97
43	2009/09/15	13:34:47	4.45	15.4	37.03	1.20	1.99	14.2	15.60	2.79
44	2009/09/15	13:35:47	4.42	15.4	37.32	1.23	2.18	14.2	15.26	6.02
45	2009/09/15	13:36:47	4.41	15.3	37.53	1.36	2.08	14.2	15.37	8.97
46	2009/09/15	13:37:47	4.41	15.3	37.79	1.42	1.98	14.2	15.73	0.55
47	2009/09/15	13:38:47	4.33	15.4	37.66	1.34	2.15	14.2	15.29	5.69
48	2009/09/15	13:39:47	4.30	15.4	37.13	1.23	2.01	14.3	15.36	6.65
49	2009/09/15	13:40:47	4.24	15.4	37.27	1.20	1.89	14.3	15.71	-0.04
50	2009/09/15	13:41:47	4.25	15.4	38.08	1.20	2.08	14.2	15.29	3.95
51	2009/09/15	13:42:47	4.23	15.4	38.14	1.20	2.02	14.2	15.26	7.51
52	2009/09/15	13:43:47	4.28	15.3	38.29	1.20	1.87	14.2	15.85	-0.10
53	2009/09/15	13:44:47	4.32	15.3	38.49	1.20	2.07	14.2	15.45	1.91
54	2009/09/15	13:45:47	4.30	15.4	38.45	1.20	2.16	14.2	15.16	8.79
55	2009/09/15	13:46:47	4.29	15.5	37.86	1.21	1.98	14.3	15.53	3.91
56	2009/09/15	13:47:47	4.36	15.5	37.99	1.23	1.99	14.3	15.63	0.26
57	2009/09/15	13:48:47	4.36	15.5	38.70	1.19	2.15	14.3	15.14	6.73
58	2009/09/15	13:49:47	4.30	15.6	38.85	1.18	2.04	14.4	15.35	8.72
59	2009/09/15	13:50:47	4.32	15.6	38.56	1.21	1.87	14.4	15.82	0.13
60	2009/09/15	13:51:47	4.32	15.6	38.13	1.23	2.03	14.3	15.46	2.00
RUN AVERAGES										
			4.39	15.39	37.63	1.13	2.11	14.23	15.37	6.01
61	2009/09/15	13:52:47	4.17	14.1	37.31	2.93	2.10	14.2	15.17	8.15
62	2009/09/15	13:53:47	2.93	6.9	32.63	8.02	1.88	14.3	15.62	1.45
63	2009/09/15	13:54:47	-0.07	1.1	23.69	2.72	2.04	14.2	15.48	2.24
64	2009/09/15	13:55:47	-0.10	0.8	25.00	0.40	2.07	14.2	15.23	8.11
65	2009/09/15	13:56:47	-0.10	0.6	24.40	1.37	1.87	14.4	15.67	1.16
66	2009/09/15	13:57:47	-0.09	0.5	17.72	10.30	2.02	14.3	15.38	4.00
67	2009/09/15	13:58:47	0.98	2.6	0.89	25.44	1.94	14.3	15.38	7.29
68	2009/09/15	13:59:47	6.06	13.3	-0.18	17.81	1.80	14.4	15.63	-0.21
69	2009/09/15	14:00:47	9.80	22.1	-0.20	1.80	2.18	13.6	15.17	4.83
70	2009/09/15	14:01:47	8.75	20.8	3.27	1.46	2.35	8.7	16.47	7.85
71	2009/09/15	14:02:47	4.66	16.3	20.74	1.54	0.59	0.5	25.48	-1.89
72	2009/09/15	14:03:47	4.17	15.7	37.44	1.53	-0.10	0.5	21.75	1.08
73	2009/09/15	14:04:47	4.14	15.6	37.49	1.50	-0.10	0.5	6.33	15.12
74	2009/09/15	14:05:47	4.20	15.5	37.48	1.43	0.31	2.4	0.07	24.95

ACCI 1 Minute Average Data Sheet: O2, CO2, CO, NOx, SO2, THC			
Client	Valero	Units	SCOT 1 and 2
Project No	09-129	Operation	normal
Plant	Valero DCR	Location	Exhaust

MINUTE	DATE	TIME	203 O2 (DV %)	203 CO2 (DV %)	203 NOx (PPMdv)	203 CO (PPMdv)	804 O2 (DV %)	804 CO2 (DV %)	804 NOx (PPMdv)	804 CO (PPMdv)
75	2009/09/15	14:06:47	4.21	15.5	37.68	1.61	3.42	12.4	0.31	17.94
76	2009/09/15	14:07:47	4.19	15.4	37.54	1.35	9.46	22.2	0.16	0.04
77	2009/09/15	14:08:47	4.24	15.4	37.29	1.17	9.88	22.1	0.00	0.50
78	2009/09/15	14:09:47	4.44	15.2	37.94	1.08	10.44	17.9	1.20	0.22
79	2009/09/15	14:10:47	8.48	11.7	33.66	0.88	14.46	3.5	4.53	1.00
80	2009/09/15	14:11:47	20.83	1.4	19.40	-0.08	20.84	0.6	0.09	1.00

SCOT 1 (203)

ACCI CEM Calibration, Bias and Drift Data Sheet
Based on 40 CFR Part 60, Appendix A-4, Method 6C

Client	Valcor	Date	September 15, 2009
Project No	09-129	Location	Exhaust
Plant	Valero DCR	Run	Run 1
Unit	Scot 1 (203)	Start Time	09:45:47
Operation	Normal	End Time	10:44:47
Tester(s)	JCC, cb, mb, fb, th		

Cal. Gas	LOW		MID		HIGH		Span	Conc. Units	Response Time	
	Conc.	(% of Span)	Conc.	(% of Span)	Conc.	(% of Span)			Up	Down
O2	N/A	N/A	9.885	43.8	22.59	100.0	22.59	d. vol. %	38	38
CO2	N/A	N/A	9.967	44.1	22.58	100.0	22.58	d. vol. %	39	40
NOx	N/A	N/A	25.5	48.6	52.5	100.0	52.5	ppmdv	60	60
CO	N/A	N/A	25.6	45.1	56.7	100.0	56.7	ppmdv	70	70
LIMITS				40 % to 60 %		80 % to 100 %				
THC LIMITS		25 % to 35 %		45 % to 55 %		80 % to 90 %				

Gas	Upscale: Enter "Low" "Mid" or "High" below "Zero"	Actual Upscale Conc.	Analyzer Cal. Response	Initial Values		Final Values		Drift (% of Span)	Span	Average of Initial and Final System Responses	Average Indicated Gas Conc.	Corrected Gas Conc.	Conc. Units
				System Cal. Response	System Cal. Bias (% of Span)	System Cal. Response	System Cal. Bias (% of Span)						
O2	Zero		-0.1	-0.10	0.00	-0.02	0.35	0.35	22.59	-0.060642806			
	Mid	9.885	9.8	9.80	0.00	9.90	0.44	0.44	22.59	9.849999809	4.01	4.06	d. vol. %
CO2	Zero		0.2	0.30	0.44	0.30	0.44	0.00	22.58	0.3			
	HIGH	22.58	22.6	21.90	-1.10	21.97	-2.79	0.31	22.58	21.93446941	16.43	16.83	d. vol. %
NOx	Zero		-0.2	-0.20	0.00	-0.20	0.00	0.00	52.5	-0.2000000001			
	Mid	25.5	25.4	25.30	-0.19	25.13	-0.51	-0.32	52.5	25.21655216	30.23	30.53	ppmdv
CO	Zero		0.0	0.10	0.18	0.47	0.83	0.65	56.7	0.285			
	Mid	25.6	25.6	26.00	0.71	25.13	-0.84	-1.54	56.7	25.56316757	1.06	0.79	ppmdv
LIMITS													

Gas	ZERO Analyzer Response (System for THC)	ZERO Analyzer Cal. Error (% of Span)	LOW Actual Conc.	LOW Analyzer Response (System for THC)	LOW Analyzer Cal. Error (% of Span)	LOW System Cal. Error (% of Actual)	MID Actual Conc.	MID Analyzer Response (System for THC)	MID Analyzer Cal. Error (% of Span)	MID System Cal. Error (% of Actual)	HIGH Actual Conc.	HIGH Analyzer Response (System for THC)	HIGH Analyzer Cal. Error (% of Span)	HIGH System Calibration Error (% of Actual)	Span	Conc. Units
O2	-0.1	-0.44					9.885	9.8	-0.38		22.59	22.6	0.04		22.59	d. vol. %
CO2	0.2	0.89					9.967	10.0	0.15		22.58	22.6	0.09		22.58	d. vol. %
NOx	-0.2	-0.38					25.5	25.4	-0.19		52.5	52.3	-0.38		52.5	ppmdv
CO	0.0	0.00					25.6	25.6	0.00		56.7	57.0	0.53		56.7	ppmdv
LIMITS		+/- 2 %			+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %		

ACCI CEM Calibration, Bias and Drift Data Sheet
Based on 40 CFR Part 60, Appendix A-4, Method 6C

Client	Valcor	Date	2009/09/15
Project No	09-129	Location	Exhaust
Plant	Valero DCR	Run	Run 2
Unit	Scot 1 (203)	Start Time	11:00:47
Operation	Normal	End Time	11:59:47
Tester(s)	JCC, cb, mb, fb, th		

Cal. Gas	LOW		MID		HIGH		Span	Conc. Units
	Conc.	(% of Span)	Conc.	(% of Span)	Conc.	(% of Span)		
O2	N/A	N/A	9.885	43.8	22.59	100.0	22.59	d. vol. %
CO2	N/A	N/A	9.967	44.1	22.58	100.0	22.58	d. vol. %
NOx	N/A	N/A	25.5	48.6	52.5	100.0	52.5	ppmdv
CO	N/A	N/A	25.6	45.1	56.7	100.0	56.7	ppmdv
LIMITS				40 % to 60 %		80 % to 100 %		
THC LIMITS		25 % to 35 %		45 % to 55 %		80 % to 90 %		

Gas	Upscale. Enter "Low" "Mid" or "High" below "Zero"	Actual Upscale Conc.	Analyzer Cal. Response	Initial Values		Final Values		Drift (% of Span)	Span	Average of Initial and Final System Responses	Average Indicated Gas Conc.	Corrected Gas Conc.	Conc. Units
				System Cal. Response	System Cal. Bias (% of Span)	System Cal. Response	System Cal. Bias (% of Span)						
O2	Zero		-0.1	-0.02	0.35	-0.02	0.34	-0.01	22.59	-0.022618388			
	Mid	9.885	9.8	9.90	0.44	9.80	-0.01	-0.45	22.59	9.848950863	4.31	-4.34	d. vol. %
CO2	Zero		0.2	0.30	0.44	0.58	1.33	0.89	22.58	0.4			
	HIGH	22.58	22.6	21.97	-2.79	22.10	-2.21	0.58	22.58	22.03446941	15.92	16.20	d. vol. %
NOx	Zero		-0.2	-0.20	0.00	-0.20	0.00	0.00	52.5	-0.200000003			
	Mid	25.5	25.4	25.13	-0.51	25.09	-0.59	-0.08	52.5	25.1112175	38.98	39.47	ppmdv
CO	Zero		0.0	0.47	0.83	0.49	0.86	0.04	56.7	0.48			
	Mid	25.6	25.6	25.13	-0.84	26.12	0.92	1.75	56.7	25.62316757	0.68	0.20	ppmdv
LIMITS					+/- 5 %		+/- 5 %	+/- 3 %					

Gas	ZERO Analyzer Response (System for THC)	ZERO Analyzer Cal. Error (% of Span)	LOW Actual Conc.	LOW Analyzer Response (System for THC)	LOW Analyzer Cal. Error (% of Span)	LOW System Cal. Error (% of Actual)	MID Actual Conc.	MID Analyzer Response (System for THC)	MID Analyzer Cal. Error (% of Span)	MID System Cal. Error (% of Actual)	HIGH Actual Conc.	HIGH Analyzer Response (System for THC)	HIGH Analyzer Cal. Error (% of Span)	HIGH System Calibration Error (% of Actual)	Span	Conc. Units
O2	-0.1	-0.44					9.885	9.8	-0.38		22.59	22.6	0.04		22.59	d. vol. %
CO2	0.2	0.89					9.967	10.0	0.15		22.58	22.6	0.09		22.58	d. vol. %
NOx	-0.2	-0.38					25.5	25.4	-0.19		52.5	52.3	-0.38		52.5	ppmdv
CO	0.0	0.00					25.6	25.6	0.00		56.7	57.0	0.53		56.7	ppmdv
LIMITS		+/- 2 %							+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %		

SCOT 2 (804)

ACCI CEM Calibration, Bias and Drift Data Sheet
Based on 40 CFR Part 60, Appendix A-4, Method 6C

Client	Valero	Date	2009/09/15
Project No	09-129	Location	Exhaust
Plant	Valero DCR	Run	Run 1
Unit	SCOT 2 (804)	Start Time	09:45:47
Operation	normal	End Time	10:44:47
Tester(s)	JCC, cb, mb, fb, th		

Cal. Gas	LOW		MID		HIGH		Span	Conc. Units	Response Time	
	Conc.	(% of Span)	Conc.	(% of Span)	Conc.	(% of Span)			Up	Down
O2	N/A	N/A	9.885	43.8	22.59	100.0	22.59	d. vel. %	26	27
CO2	N/A	N/A	9.967	44.1	22.58	100.0	22.58	d. vel. %	27	28
NOx	N/A	N/A	25.5	48.6	52.5	100.0	52.5	ppmdv	40	40
CO	N/A	N/A	25.6	45.1	56.7	100.0	56.7	ppmdv	40	40
LIMITS				40 % to 60 %		80 % to 100 %				
THC LIMITS		25 % to 35 %		45 % to 55 %		80 % to 90 %				

Gas	Upscale. Enter "Low" "Mid" or "High" below "Zero"	Actual Upscale Conc.	Analyzer Cal. Response	Initial Values		Final Values		Drift (% of Span)	Span	Average of Initial and Final System Responses	Average Indicated Gas Conc.	Corrected Gas Conc.	Conc. Units
				System Cal. Response	System Cal. Bias (% of Span)	System Cal. Response	System Cal. Bias (% of Span)						
O2	Zero		0.0	-0.10	-0.44	0.00	0.00	0.44	22.59	-0.05			
	Mid	9.885	9.9	10.00	0.44	9.92	0.10	-0.34	22.59	9.961788634	2.02	2.05	d. vel. %
CO2	Zero		0.1	0.20	0.44	0.41	1.39	0.94	22.58	0.306617162			
	HIGH	22.58	22.7	22.20	-2.21	22.24	-2.02	0.20	22.58	22.22210846	14.67	14.80	d. vel. %
NOx	Zero		0.0	-0.10	-0.19	0.00	0.00	0.19	52.5	-0.05			
	Mid	25.5	25.5	25.50	0.00	25.33	-0.32	-0.32	52.5	25.415	11.89	11.96	ppmdv
CO	Zero		-0.1	-1.00	-1.59	-1.64	-2.72	-1.13	56.7	-1.32			
	Mid	25.6	25.6	24.80	-1.41	25.31	-0.51	0.90	56.7	25.055	9.87	10.87	ppmdv
LIMITS					+/- 5 %		+/- 5 %	+/- 3 %					

Gas	ZERO Analyzer Response (System for THC)	ZERO Analyzer Cal. Error (% of Span)	LOW Actual Conc.	LOW Analyzer Response (System for THC)	LOW Analyzer Cal. Error (% of Span)	LOW System Cal. Error (% of Actual)	MID Actual Conc.	MID Analyzer Response (System for THC)	MID Analyzer Cal. Error (% of Span)	MID System Cal. Error (% of Actual)	HIGH Actual Conc.	HIGH Analyzer Response (System for THC)	HIGH Analyzer Cal. Error (% of Span)	HIGH System Calibration Error (% of Actual)	Span	Conc. Units
O2	0.0	0.00					9.885	9.9	0.07		22.59	22.7	0.49		22.59	d. vel. %
CO2	0.1	0.44					9.967	9.9	-0.30		22.58	22.7	0.53		22.58	d. vel. %
NOx	0.0	0.00					25.5	25.5	0.00		52.5	52.5	0.00		52.5	ppmdv
CO	-0.1	-0.18					25.6	25.6	0.00		56.7	56.8	0.11		56.7	ppmdv
LIMITS		+/- 2 %			+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %		

ACCT CEM Calibration, Bias and Drift Data Sheet
Based on 40 CFR Part 60, Appendix A-4, Method 6C

Client	Valero	Date	2009/09/15
Project No	09-129	Location	Exhaust
Plant	Valero DCR	Run	2
Unit	SCOT 2 (R04)	Start Time	11:00:47
Operation	normal	End Time	11:59:47
Tester(s)	JCC. cb. mb. fb. th		

Cal. Gas	LOW		MID		HIGH		Span	Conc. Units
	Conc.	(% of Span)	Conc.	(% of Span)	Conc.	(% of Span)		
O2	N/A	N/A	9.885	43.8	22.59	100.0	22.59	d. vol. %
CO2	N/A	N/A	9.967	44.1	22.58	100.0	22.58	d. vol. %
NOx	N/A	N/A	25.5	48.6	52.5	100.0	52.5	ppmdv
CO	N/A	N/A	25.6	45.1	56.7	100.0	56.7	ppmdv
LIMITS				40 % to 60 %		80 % to 100 %		
THC LIMITS		25 % to 35 %		45 % to 55 %		80 % to 90 %		

Gas	Upscale: Enter "Low" "Mid" or "High" below "Zero"	Actual Upscale Conc.	Analyzer Cal. Response	Initial Values		Final Values		Drift (% of Span)	Span	Average of Initial and Final System Responses	Average Indicated Gas Conc.	Corrected Gas Conc.	Conc. Units
				System Cal. Response	System Cal. Bias (% of Span)	System Cal. Response	System Cal. Bias (% of Span)						
O2	Zero		0.0	0.00	0.00	0.00	0.00	0.00	22.59	0			
	Mid	9.885	9.9	9.92	0.10	9.84	-0.26	-0.36	22.59	9.882770538	2.18	2.18	d. vol. %
CO2	Zero		0.1	0.41	1.39	0.40	1.33	-0.05	22.58	0.407141715			
	HIGH	22.58	22.7	22.24	-2.02	22.29	-1.80	0.22	22.58	22.26907635	14.70	14.76	d. vol. %
NOx	Zero		0.0	0.00	0.00	-0.02	-0.03	-0.03	52.5	-0.007693349			
	Mid	25.5	25.5	25.33	-0.32	25.46	-0.08	0.24	52.5	25.39343742	15.53	15.60	ppmdv
CO	Zero		-0.1	-1.64	-2.72	-1.90	-3.17	-0.46	56.7	-1.77			
	Mid	25.6	25.6	25.31	-0.51	25.05	-0.97	-0.46	56.7	25.18	6.30	7.66	ppmdv
LIMITS													
					+/- 5 %			+/- 5 %					+/- 3 %

Gas	ZERO Analyzer Response (System for THC)	ZERO Analyzer Cal. Error (% of Span)	LOW Actual Conc.	LOW Analyzer Response (System for THC)	LOW Analyzer Cal. Error (% of Span)	LOW System Cal. Error (% of Actual)	MID Actual Conc.	MID Analyzer Response (System for THC)	MID Analyzer Cal. Error (% of Span)	MID System Cal. Error (% of Actual)	HIGH Actual Conc.	HIGH Analyzer Response (System for THC)	HIGH Analyzer Cal. Error (% of Span)	HIGH System Calibration Error (% of Actual)	Span	Conc. Units
O2	0.0	0.00					9.885	9.9	0.07		22.59	22.7	0.49		22.59	d. vol. %
CO2	0.1	0.44					9.967	9.9	-0.30		22.58	22.7	0.53		22.58	d. vol. %
NOx	0.0	0.00					25.5	25.5	0.00		52.5	52.5	0.00		52.5	ppmdv
CO	-0.1	-0.18					25.6	25.6	0.00		56.7	56.8	0.18		56.7	ppmdv
LIMITS		+/- 2 %							+/- 2 %	+/- 5 %			+/- 2 %	+/- 5 %		

ACCT CEM Calibration, Bias and Drift Data Sheet
Based on 40 CFR Part 60, Appendix A-4, Method GC

Client	Valero	Date	#REF!
Project No	09-129	Location	Exhaust
Plant	Valero DCR	Run	5
Unit	SCOT 2 (804)	Start Time	12:52:47
Operation	normal	End Time	13:51:47
Tester(s)	JCC, cb, mb, fb, th		

Cal. Gas	LOW		MID		HIGH		Span	Conc. Units
	Conc.	(% of Span)	Conc.	(% of Span)	Conc.	(% of Span)		
O2	N/A	N/A	9.885	43.8	22.59	100.0	22.59	d. vol. %
CO2	N/A	N/A	9.967	44.1	22.58	100.0	22.58	d. vol. %
NOx	N/A	N/A	25.5	48.6	52.5	100.0	52.5	ppmdv
CO	N/A	N/A	25.6	45.1	56.7	100.0	56.7	ppmdv
LIMITS				40 % to 60 %		80 % to 100 %		
THC LIMITS		25 % to 35 %		45 % to 55 %		80 % to 90 %		

Gas	Upscale. Enter "Low" "Mid" or "High" below "Zero"	Actual Upscale Conc.	Analyzer Cal. Response	Initial Values		Final Values		Drift (% of Span)	Span	Average of Initial and Final System Responses	Average Indicated Gas Conc.	Corrected Gas Conc.	Conc. Units
				System Cal. Response	System Cal. Bias (% of Span)	System Cal. Response	System Cal. Bias (% of Span)						
O2	Zero		0.0	0.00	0.00	-0.10	-0.44	-0.44	22.59	-0.050000001			
	Mid	9.885	9.9	9.84	-0.26	9.88	-0.10	0.16	22.59	9.859951019	2.11	2.15	d. vol. %
CO2	Zero		0.1	0.40	1.33	0.48	1.69	0.36	22.58	0.441777334			
	HIGH	22.58	22.7	22.29	-1.80	22.20	-2.23	-0.43	22.58	22.24520111	14.23	14.28	d. vol. %
NOx	Zero		0.0	-0.02	-0.03	0.00	0.00	0.03	52.5	-0.007693349			
	Mid	25.5	25.5	25.46	-0.08	25.48	-0.04	0.04	52.5	25.46843742	15.37	15.39	ppmdv
CO	Zero		-0.1	-1.90	-3.17	-1.09	-1.74	1.43	56.7	-1.494468284			
	Mid	25.6	25.6	25.05	-0.97	24.95	-1.15	-0.18	56.7	25	6.01	7.25	ppmdv
LIMITS						+/- 5 %		+/- 5 %					+/- 3 %

Gas	ZERO Analyzer Response (System for THC)	ZERO Analyzer Cal. Error (% of Span)	LOW Actual Conc.	LOW Analyzer Response (System for THC)	LOW Analyzer Cal. Error (% of Span)	LOW System Cal. Error (% of Actual)	MID Actual Conc.	MID Analyzer Response (System for THC)	MID Analyzer Cal. Error (% of Span)	MID System Cal. Error (% of Actual)	HIGH Actual Conc.	HIGH Analyzer Response (System for THC)	HIGH Analyzer Cal. Error (% of Span)	HIGH System Calibration Error (% of Actual)	Span	Conc. Units
O2	0.0	0.00					9.885	9.9	0.07		22.59	22.7	0.49		22.59	d. vol. %
CO2	0.1	0.44					9.967	9.9	-0.30		22.58	22.7	0.53		22.58	d. vol. %
NOx	0.0	0.00					25.5	25.5	0.00		52.5	52.5	0.00		52.5	ppmdv
CO	-0.1	-0.18					25.6	25.6	0.00		56.7	56.8	0.18		56.7	ppmdv
LIMITS		+/- 2 %				+/- 2 %			+/- 2 %	+/- 5 %			+/- 2 %			+/- 5 %

APPENDIX C

Calibration QA/QC Data

NOX CONVERTER EFFICIENCY TEST

SCOT 1 NOX ANALYZER

MUST USE NO2 GAS BETWEEN 40 AND 60 PPMV
PER 7.1.4

NO2 CAL GAS USED
MUST BE EPA PROTOCOL

46.7

ANALYZER RESPONSE

DATE	TIME	NOX RESPONSE
2009/09/15	07:49:02	47
2009/09/15	07:50:02	47.1
2009/09/15	07:51:02	47.1
2009/09/15	07:52:02	47
2009/09/15	07:53:02	47
2009/09/15	07:54:02	47.1
2009/09/15	07:55:02	47
2009/09/15	07:56:02	47.1
2009/09/15	07:57:02	47

AVERAGE RESPONSE 47.04444444

EQ. 7E-7

$$\text{EFFNO2} = \frac{\text{MEASURED CONCENTRATION OF CALIBRATION GAS}}{\text{MANUFACTURER CERTIFIED CONCENTRATION OF CAL GAS}} \times 100$$

$$\text{EFFNO2} = \frac{47.04444444}{46.7} \times 100$$

$$\text{EFFNO2} = 8$$

MUST BE GREATER THAN OR EQUAL TO 90 PERCENT
PER 13.5

NOX CONVERTER EFFICIENCY TEST

SCOT 2 NOX ANALYZER

MUST USE NO2 GAS BETWEEN 40 AND 60 PPMV
PER 7.1.4

NO2 CAL GAS USED
MUST BE EPA PROTOCOL

46.7

ANALYZER RESPONSE

DATE	TIME	NOX RESPONSE
2009/09/15	08:05:02	46.9
2009/09/15	08:06:02	46.8
2009/09/15	08:07:02	47
2009/09/15	08:08:02	46.9
2009/09/15	08:09:02	46.9
2009/09/15	08:10:02	46.9
2009/09/15	08:11:02	47

AVERAGE RESPONSE 46.91428571

EQ. 7E-7

$$\text{EFFNO2} = \frac{\text{MEASURED CONCENTRATION OF CALIBRATION GAS}}{\text{MANUFACTURER CERTIFIED CONCENTRATION OF CAL GAS}} \times 100$$

$$\text{EFFNO2} = \frac{46.91428571}{46.7} \times 100$$


$$\text{EFFNO2} = 100.4588559$$

MUST BE GREATER THAN OR EQUAL TO 90 PERCENT
PER 13.5

AIR/COMPLIANCE CONSULTANTS, INC.
 DRAFT
 USEPA METHOD 2 AND METHOD 4 DATA SHEET

Cyclonic

Client VALECO Date 9/10/09
 ACCI Project # 09-129 Run # 1
 Plant Location DELAWARE CITY Meter Box # 1581
 Stack ID S-203 Yd 0.988
 Stack Diameter 80" Delta H 1.626
 Pitot ID 9PP6-1 Test Crew: JC CB MB
 Pitot Cp .84 Pre-Test Leak Check
 B. P. (in Hg) 30.33 Impingers 0.00 @ 10"
 Ps (in H₂O) -0.20 Pitot (+/-)
 Start Time: 0920 Post-Test Leak Check
 Stop Time: 0950 Impingers 0.00 @ 10"
 Pitot (+/-)



MOISTURE DATA

Clock	Elapsed	Meter Volume	Meter Temp	Delta H	Vacuum/Pressure	Impinger Temp.
	Initial	601.695	63	1.6	3.0	61
	5 Min	605.455	63	1.6	3.0	62
	10 Min	609.035	64	1.6	3.0	60
	15 Min	612.840	65	1.6	3.0	59
	20 Min	616.495	67	1.6	3.0	60
	25 Min	619.805	64	1.6	3.0	61
	30 Min	623.642	69	1.6	3.0	61
	35 Min					
	Final					

IMPINGER WEIGHTS

Impinger	Initial	Final
1	100	130
2	100	102
3	0	0
4	241.7	248.0
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %
CEMS		

start: 0925 stop: 0928

TRAVERSE PORT/POINT	Delta P	Stack Temp °F	Cyclonic ° from Hor.
A1	.08	1239	4
2	.08	1240	9
3	.10	1239	2
4	.10	1240	12
5	.11	1240	10
6	.09	1238	14
7	.08	1237	12
8	.06	1237	10
B1	.07	1241	12
2	.08	1242	4
3	.08	1242	12
4	.10	1241	13
5	.11	1241	13
6	.07	1241	10
7	.07	1242	9
8	.06	1241	10

start: stop:

TRAVERSE PORT/POINT	Delta P	Stack Temp °F	Cyclonic ° from Hor.

203

STRATIFICATION CHECK				2009/09/10	AVERAGE			DIFFERENCE FROM MEAN	DIFFERENCE FROM MEAN	DIFFERENCE FROM MEAN
POINT	O2 %	CO2 %	SO2 ppm	POINT	O2 %	CO2 %	SO2 ppm	O2 %	CO2 %	SO2 ppm
1	3.2	17.2	67.4	1	3.2	17.2	67.2	-0.04	-0.10	-2.99%
1	3.2	17.2	67.1	2	3.3	17.1	65.7	0.02	-0.21	-0.62%
2	3.3	17.1	66.1	3	3.3	17.1	64.5	0.06	-0.19	1.24%
2	3.3	17.1	65.3	4	3.3	17.1	64.1	0.03	-0.17	1.78%
3	3.3	17.1	64.7	5	3.2	17.3	65.2	0.00	-0.03	0.09%
3	3.3	17.1	64.3	6	3.2	17.4	66.4	-0.06	0.10	-1.71%
4	3.3	17.1	64.0	7	3.2	17.4	66.4	-0.04	0.10	-1.75%
4	3.3	17.1	64.2	8	3.2	17.5	66.3	-0.03	0.20	-1.58%
5	3.3	17.2	64.9	9	3.2	17.4	65.8	-0.03	0.10	-0.83%
5	3.2	17.3	65.6	10	3.2	17.3	64.9	-0.01	0.04	0.63%
6	3.2	17.4	66.2	11	3.3	17.3	63.8	0.02	0.05	2.32%
6	3.2	17.4	66.6	12	3.3	17.4	63.1	0.08	0.10	3.41%
7	3.2	17.4	66.5							
7	3.2	17.4	66.3							
8	3.2	17.5	66.4							
8	3.2	17.5	66.3							
9	3.2	17.4	65.9							
9	3.2	17.4	65.7							
10	3.2	17.4	65.2							
10	3.2	17.3	64.5							
11	3.3	17.3	64.0							
11	3.3	17.4	63.6							
12	3.3	17.4	63.2							
12	3.3	17.4	62.9							
				MEAN	3.2	17.3	65.3			

Per USEPA Part 60, three point traverse used.

AIR/COMPLIANCE CONSULTANTS, INC.
 USEPA METHOD 2 AND METHOD 4 DATA SHEET

804
Cyclonic

INITIAL FLOW

Client: VALERO Date: _____
 ACCI Project #: _____ Run #: _____
 Plant Location: DELAWARE CITY, DE Meter Box #: 1462
 Stack ID: S-804 Yd: _____
 Stack Diameter: 72" Delta H: _____
 Pitot ID: 10PPG-1 Test Crew: _____
 Pitot Cp: .84 Pre-Test Leak Check:
 B. P. (in. Hg): _____ Impingers: _____
 Ps (in. H₂O): _____ Pitot (+/-): _____
 Start Time: _____ Post-Test Leak Check:
 Stop Time: _____ Impingers: _____
 Pitot (+/-): _____

Stack Dia. Measured? 72"

DIAGRAM

MOISTURE DATA

Clock	Elapsed	Meter Volume	Meter Temp	Delta H	Vacuum/Pressure	Impinger Temp.
	Initial					
	5 Min					
	10 Min					
	15 Min					
	20 Min					
	25 Min					
	30 Min					
	35 Min					
	Final					

IMPINGER WEIGHTS

Impinger	Initial	Final
1		
2		
3		
4		
WET bulb		
DRY Bulb		

O ₂ %	CO ₂ %	N ₂ %

start: _____ stop: ~~static 1.2~~

TRAVERSE PORT/POINT	Delta P	Stack Temp °F	Cyclonic ° from Hor.
A 1	.131		4
2	.13		4
3	.09		8
4	.09		8
5	.11		4
6	.11		2
7	.107		2
8	.105		2
B 1	.102		5
2	.092		5
3	.102		8
4	.106		6
5	.11		4
6	.10		2
7	.107		3
8	.107		2

start: _____ stop: static 1.2

TRAVERSE PORT/POINT	Delta P	Stack Temp °F	Cyclonic ° from Hor.
A 1	.09	1332	6
2	.10	1334	6
3	.11	1334	8
4	.12	1335	8
5	.10	1334	4
6	.08	1332	2
7	.08	1330	2
8	.107	1330	2
B 1	.10	1334	5
2	.11	1334	5
3	.12	1335	8
4	.13	1333	6
5	.11	1334	4
6	.09	1332	2
7	.07	1334	3
8	.04	1334	2

804

STRATIFICATION CHECK				2009/09/09			DIFFERENCE FROM MEAN			
POINT	O2 %	CO2 %	SO2 ppm	POINT	AVERAGE O2 %	AVERAGE CO2 %	AVERAGE SO2 ppm	O2 %	CO2 %	SO2 ppm
1	3.6	17.7	57.4	1	3.6	17.9	57.2	-0.11	0.08	-16.08%
1	3.6	18.0	57.0							
2	3.5	18.0	56.9	2	3.5	18.0	55.5	-0.18	0.20	-12.56%
2	3.5	18.0	54.1							
3	3.5	17.9	51.0	3	3.5	17.9	50.3	-0.18	0.11	-2.07%
3	3.5	17.9	49.7							
4	3.5	17.8	47.7	4	3.5	17.8	46.8	-0.20	0.03	5.00%
4	3.5	17.8	45.9							
5	3.5	17.7	45.5	5	3.6	17.8	46.0	-0.12	0.02	6.72%
5	3.6	17.9	46.5							
6	3.6	17.9	47.4	6	3.7	18.0	47.9	-0.02	0.19	2.79%
6	3.7	18.0	48.5							
7	3.8	18.0	50.0	7	3.8	18.0	50.1	0.10	0.17	-1.72%
7	3.8	17.9	50.3							
8	3.8	17.9	50.6	8	3.8	18.0	50.2	0.09	0.20	-1.93%
8	3.7	18.0	49.9							
9	3.8	17.9	48.3	9	3.8	17.8	47.4	0.09	0.03	3.79%
9	3.8	17.7	46.5							
10	3.8	17.6	45.1	10	3.9	17.5	44.9	0.19	-0.25	8.88%
10	3.9	17.5	44.8							
11	3.9	17.4	46.0	11	3.9	17.3	47.7	0.24	-0.47	3.20%
11	3.9	17.2	49.5							
12	3.9	17.2	46.8	12	3.8	17.5	47.3	0.11	-0.32	3.99%
12	3.7	17.8	47.9							
				MEAN	3.7	17.8	49.3			

Per PS2, 3 point traverse conducted.



164337

Airgas Great Lakes, Inc
2009 Bellaire Ave.
Royal Oak, MI 48067
Ph: (248) 399-9150
Fax: (248) 584-2540
http://www.airgas.com

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Customer: PITTSBURG
Part Number: E03NI67E15A3611 Reference Number: 32-112736601-2
Cylinder Number: CC87369 Cylinder Volume: 160 Cu Ft
Laboratory: MIC - Royal Oak - MI Cylinder Pressure: 2015 PSIG
Analysis Date: Sep 02, 2008 Valve Outlet: 590

Expiration Date: Sep 02, 2011

Certification performed in accordance with 'EPA Traceability Protocol (Sept. 1997)' using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig or 1 Mega Pascal

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
OXYGEN	10.00 %	9.885 %	G1	+/- 1% NIST Traceable
CARBON DIOXIDE	22.50 %	22.59 %	G2	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS


Type	Lot ID	Cylinder No	Concentration	Expiration Date
IITRM	99051103	SG9168330BAL	9.507% OXYGEN/NITROGEN	Jan 01 2010
NTRM	99061020	XCO192658	3.44% CARBON DIOXIDE/NITROGEN	Jul 01 2011

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
E/N 54, 20% FS CO2 Nicolet 6700	Fourier Transform Infrared (FTIR)	Aug 08, 2008
E/N 51, 25% FS O2, Rosemont 755R	Paramagnetic (Para)	Aug 11, 2008

Triad Data Available Upon Request

Notes: ORDER#074661


QA Approval



164334

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Great Lakes, Inc
2009 Bellaire Ave.
Royal Oak, MI 48067
Ph: (248) 399-9150
Fax: (248) 584-2540
http://www.airgas.com

Customer: PITTSBURG
Part Number: E03NI67E 15A1068
Cylinder Number: CC53162
Laboratory: MIC - Royal Oak - MI
Analysis Date: Sep 12, 2008
Reference Number: 32-112740141-1
Cylinder Volume: 152 Cu Ft
Cylinder Pressure: 2015 PSIG
Valve Outlet: 590

Expiration Date: Sep 12, 2011

Certification performed in accordance with EPA Traceability Protocol (Sept 1997) using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig i.e. 1 Mega Pascal

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
CARBON DIOXIDE	10.00 %	9.967 %	G1	+/- 1% NIST Traceable
OXYGEN	22.50 %	22.56 %	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	06060803	CC206012	22.51% OXYGEN/NITROGEN	May 01 2010
NTRM	970510	SG9198969BAL	10.818% CARBON DIOXIDE/NITROGEN	May 15 2012

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
E/N 136 20%FS CO2 Horiba VIA-510	Nondispersive Infrared (NDIR)	Aug 25 2008
E/N 51, 25%FS O2, Rosemont 755R	Paramagnetic (Para)	Sep 12, 2008

Triad Data Available Upon Request

Notes:

AFM

QA Approval



Inv. 173465

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Airgas Great Lakes, Inc.
2009 Bellaire Ave.
Royal Oak, MI 48067
Ph: (248) 399-9150
Fax: (248) 584-2540
<http://www.airgas.com>

Customer: CRAFTON
Part Number: E02NI99E15A0129 Reference Number: 32-112786333-1
Cylinder Number: CC152699 Cylinder Volume: 144 Cu Ft.
Laboratory: MIC - Royal Oak - MI Cylinder Pressure: 2015 PSIG
Analysis Date: Dec 29, 2008 Valve Outlet: 660

Expiration Date: Dec 29, 2010

Certification performed in accordance with "EPA Traceability Protocol (Sept. 1997)" using the assay procedures listed. Analytical Methodology does not require correction for analytical interferences. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.
Do Not Use This Cylinder below 150 psig i.e. 1 Mega Pascal

ANALYTICAL RESULTS				
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty
NOx	25.00 PPM	25.68 PPM	G1	+/- 1% NIST Traceable
NITRIC OXIDE	25.00 PPM	25.50 PPM	G1	+/- 1% NIST Traceable
NITROGEN	Balance			

CALIBRATION STANDARDS				
Type	Lot ID	Cylinder No	Concentration	Expiration Date
NTRM	46-E-18	CC206032	49.38PPM NITRIC OXIDE/NITROGEN	Oct 02, 2012
NTRM	07060302X	CC206032	49.87PPM NOx/NITROGEN	Oct 02, 2012

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
E/N 54 25ppmFS NO Nicolet 6700	Fourier Transform Infrared (FTIR)	Dec 18, 2008
E/N 54 25ppmFS NO Nicolet 6700	Fourier Transform Infrared (FTIR)	Dec 18, 2008

Triad Data Available Upon Request

Notes

AFM

QA Approval

In. 169139

Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

Certificate of Analysis

- EPA PROTOCOL GAS -

Customer Jackson Welding (Pittsburgh, PA)
Date December 30, 2008
Delivery Receipt DR-23379
Gas Standard 55.0 ppm Nitric Oxide/Nitrogen - EPA PROTOCOL
Final Analysis Date December 29, 2008
Expiration Date December 29, 2010

Component Nitric Oxide
Balance Gas Nitrogen

Analytical Data: DO NOT USE BELOW 150 psig
EPA Protocol, Section No. 2.2. Procedure G-1

Reported Concentrations

Nitric Oxide: 51.8 ppm +/- 0.51 ppm

Nitrogen: Balance

Total Oxides of Nitrogen: 52.5 ppm

** NOx for Reference Use Only **

Reference Standards:

SRM/GMIS:	GMIS	GMIS
Cylinder Number:	CC-159052	CC-125597
Concentration:	50.6 ppm NO/Nitrogen	57.2 ppm NO/Nitrogen
Expiration Date:	September 18, 2010	April 05, 2009


Certification Instrumentation

Component: Nitric Oxide
Make/Model: Nicolet-NEXUS 470
Serial Number: AEP99000154
Principal of Measurement: FTIR
Last Calibration: December 02, 2008

Cylinder Data

Cylinder Serial Number: CC-251502 Cylinder Outlet: CGA 660
Cylinder Volume: 140 Cubic Feet Cylinder Pressure: 2000 psig, 70°F
Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by:
Date:


December 30, 2008

Unmatched Excellence

164871

Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

Certificate of Analysis - EPA PROTOCOL GAS -

Customer Jackson Welding - (Pittsburgh, PA)
Date September 18, 2008
Delivery Receipt DR-22620
Gas Standard 25.0 ppm Carbon Monoxide/Nitrogen - EPA PROTOCOL GAS
Final Analysis Date September 10, 2008
Expiration Date September 10, 2011

DO NOT USE BELOW 150 psig

Analytical Data:
EPA Protocol, Section No. 2.2, Procedure G-1.

Reported Concentrations:
Carbon Monoxide: 25.6 ppm +/- 0.25 ppm
Nitrogen: Balance

Reference Standards

SRM/GMIS	GMIS	GMIS
Cylinder Number:	CC-158976	CC-166348
Concentration:	25.1 ppm CO/Nitrogen	45.9 ppm CO/Nitrogen
Expiration Date:	August 04, 2010	February 25, 2009

Certification Instrumentation

Component: Carbon Monoxide
Make/Model: Nicolet NEXUS 470
Serial Number: AEP99000154
Principal of Measurement: FTIR
Last Calibration: September 09, 2008

Cylinder Data

Cylinder Number:	CC-129106	Cylinder Volume:	140 Cubic Feet
Cylinder Outlet:	CGA 350	Cylinder Pressure:	2000 psig, 70°F
Expiration Date:	September 10, 2011		

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by: 
Date: September 18, 2008

Unmatched Excellence

164871

Liquid Technology Corporation

Industry Leader in Specialty Gases, Equipment and Service

Certificate of Analysis - EPA PROTOCOL GAS -

<u>Customer</u>	<u>Jackson Welding - (Pittsburgh, PA)</u>
<u>Date</u>	<u>September 18, 2008</u>
<u>Delivery Receipt</u>	<u>DR-22620</u>
<u>Gas Standard</u>	<u>55.0 ppm Carbon Monoxide/Nitrogen - EPA PROTOCOL GAS</u>
<u>Final Analysis Date</u>	<u>September 10, 2008</u>
<u>Expiration Date</u>	<u>September 10, 2011</u>

DO NOT USE BELOW 150 psig

Analytical Data:
EPA Protocol, Section No. 2.2, Procedure G-1.

Reported Concentrations:
Carbon Monoxide: 56.7 ppm +/- 0.56 ppm
Nitrogen: Balance

Reference Standards

SRM/GMIS	GMIS	GMIS
Cylinder Number:	CC-184191	CC-231409
Concentration:	50.9 ppm CO/Nitrogen	98.6 ppm CO/Nitrogen
Expiration Date:	June 15, 2010	November 30, 2011

Certification Instrumentation

Component:	Carbon Monoxide
Make/Model:	Nicolet NEXUS 470
Serial Number:	AEP99000154
Principal of Measurement:	FTIR
Last Calibration:	September 09, 2008

Cylinder Data

Cylinder Number:	CC-166625	Cylinder Volume:	140 Cubic Feet
Cylinder Outlet:	CGA 350	Cylinder Pressure:	2000 psig, 70°F
Expiration Date:	September 10, 2011		

Analytical Uncertainty and NIST Traceability are in compliance with EPA-600/R-97/121.

Certified by: 
Date: September 18, 2008

Unmatched Excellence

NOX CONVERTER EFFICIENCY TEST

SCOT 1 NOX ANALYZER

MUST USE NO2 GAS BETWEEN 40 AND 60 PPMV
PER 7.1.4

NO2 CAL GAS USED
MUST BE EPA PROTOCOL

46.7

ANALYZER RESPONSE

DATE	TIME	NOX RESPONSE
2009/09/15	07:49:02	47
2009/09/15	07:50:02	47.1
2009/09/15	07:51:02	47.1
2009/09/15	07:52:02	47
2009/09/15	07:53:02	47
2009/09/15	07:54:02	47.1
2009/09/15	07:55:02	47
2009/09/15	07:56:02	47.1
2009/09/15	07:57:02	47

AVERAGE RESPONSE 47.04444444

EQ. 7E-7

$$\text{EFFNO2} = \frac{\text{MEASURED CONCENTRATION OF CALIBRATION GAS}}{\text{MANUFACTURER CERTIFIED CONCENTRATION OF CAL GAS}} \times 100$$

$$\text{EFFNO2} = \frac{47.04444444}{46.7} \times 100$$

$$\text{EFFNO2} = 100.7375684$$

MUST BE GREATER THAN OR EQUAL TO 90 PERCENT
PER 13.5

NOX CONVERTER EFFICIENCY TEST

SCOT 2 NOX ANALYZER

MUST USE NO2 GAS BETWEEN 40 AND 60 PPMV
PER 7.1.4

NO2 CAL GAS USED
MUST BE EPA PROTOCOL

46.7

ANALYZER RESPONSE

DATE	TIME	NOX RESPONSE
2009/09/15	08:05:02	46.9
2009/09/15	08:06:02	46.8
2009/09/15	08:07:02	47
2009/09/15	08:08:02	46.9
2009/09/15	08:09:02	46.9
2009/09/15	08:10:02	46.9
2009/09/15	08:11:02	47

AVERAGE RESPONSE 46.91428571

EQ. 7E-7

$$\text{EFFNO2} = \frac{\text{MEASURED CONCENTRATION OF CALIBRATION GAS}}{\text{MANUFACTURER CERTIFIED CONCENTRATION OF CAL GAS}} \times 100$$

$$\text{EFFNO2} = \frac{46.91428571}{46.7} \times 100$$

$$\text{EFFNO2} = 100.4588559$$

MUST BE GREATER THAN OR EQUAL TO 90 PERCENT
PER 13.5

Oxides of Nitrogen Interference Test.

Analyzer Type	TECO 42C HIGH LEVEL
Model Number	42C
Serial Number	42 CHL 69556-363
Date	5-Jan-09
Calibration Span	100 NOX

Potential Interferent		NOX PRESENT Dried	NOX ABSENT Dried	NOX* Analyzer Response (PPM)
CO2	9.83%	0.0	0.0	0.0
CO2	22.09%	0.0	0.0	0.0
O2	1%	0.0	0.0	0.0
O2	10%	0.0	0.0	0.0
O2	22%	0.0	0.0	0.0
CO	30	0.0	0.0	0.0
CO	302	0.0	0.0	0.0
CO	5104	0.0	0.0	0.0
NH3	20	0.0	0.0	0.0
CH4	99.2	0.0	0.0	0.0
CH4	907	0.0	0.0	0.0
SO2	25	0.0	0.0	0.0
SO2	253	0.0	0.0	0.0
SO2	2032	0.0	0.0	0.0
H2	50	0.0	0.0	0.0
HCl	55	0.0	0.0	0.0

* Uses the larger of the absolute values obtained for the interferent tested with and without the pollutant present

Sum of Responses 0.0
 % of Calibration Span 0.00%

**MUST NOT BE GREATER THAN 2.50% OF CALIBRATION SPAN
 PER METHOD 7E 13.4**

Carbon Monoxide Interference Test.

Analyzer Type	Gas Filter Correlation CO Analyzer
Model Number	48 C CO Analyzer High Level
Serial Number	48CHL-68385-360
Date	5-Jan-09
Calibration Span	100

Potential Interferent	Dried	CO	CO	CO*
		Analyzer Response (ppm)	Analyzer Response (ppm)	Analyzer Response (ppm)
		CO ABSENT	CO PRESENT	
CO2	22.59%	1.5	1.5	1.5
CO2	10.00%	0.6	0.6	0.6
H2O	1%	0.0	0.0	0.0
NO	25.3 ppm	0.0	0.0	0.0
NO2	49.4 ppm	0.0	0.0	0.0
NH3	20 ppm	0.0	0.0	0.0
CH4	87.2	0.0	0.0	0.0
SO2	25.2	0.0	0.0	0.0
H2	50 ppm	0.0	0.0	0.0
HCl	54.8	0.0	0.0	0.0

* Uses the larger of the absolute values obtained for the interferent tested with and without the pollutant present

Sum of Responses	2.1
% of Calibration Span	2.10%
MUST NOT BE GREATER THAN 2.50% OF CALIBRATION SPAN PER METHOD 7E 13.4	

CO	Carbon monoxide.
ppmv	Parts per million by volume.
ppm	Parts per million.
USEPA	U.S. Environmental Protection Agency.

Oxygen and Carbon Dioxide Interference Test.

Analyzer Type	California Analytical Instruments O2 and CO2	
Model Number	Model 200	Model 200
Serial Number	1L04001	1L04001
Date	5-Jan-09	5-Jan-09
Calibration Span	22	17.9
	O2	CO2

Potential Interferent	Dried	O2	O2	O2*	Dried	CO2	CO2	CO2*
		Analyzer Response (%)	Analyzer Response (%)	Analyzer Response (%)		Analyzer Response (%)	Analyzer Response (%)	Analyzer Response (%)
		O2 ABSENT	O2 PRESENT			CO2 ABSENT	CO2 PRESENT	
CO2	22.09%	0.0	0.0	0.0				
CO2	9.83%	0.0	0.0	0.0				
H2O	1%	0.0	0.0	0.0	1%	0.0	0.0	0.0
NOx	24.7	0.0	0.0	0.0	24.7	0.0	0.0	0.0
NOx	227	0.0	0.0	0.0	227	0.0	0.0	0.0
NOx	1026	0.0	0.0	0.0	1026	0.0	0.0	0.0
NO2	49.97	0.0	0.0	0.0	49.97	0.0	0.0	0.0
NH3	20	0.0	0.0	0.0	20	0.0	0.0	0.0
CH4	99.2	0.0	0.0	0.0	99.2	0.0	0.0	0.0
CH4	907	0.0	0.0	0.0	907	0.0	0.0	0.0
SO2	25.4	0.0	0.0	0.0	25.4	0.0	0.0	0.0
SO2	253	0.0	0.0	0.0	253	0.0	0.0	0.0
SO2	2032	0.0	0.0	0.0	2032	0.0	0.0	0.0
H2	50	0.0	0.0	0.0	50	0.0	0.0	0.0
HCl	55	0.0	0.0	0.0	55	0.0	0.0	0.0
CO	30	0.0	0.0	0.0	30	0.0	0.0	0.0
CO	302	0.0	0.0	0.0	302	0.0	0.0	0.0
CO	5104	0.0	0.0	0.0	5104	0.0	0.0	0.0

* Uses the larger of the absolute values obtained for the interferent tested with and without the pollutant present

Sum of Responses	0.0	0.0
% of Calibration Span	0.00%	0.00%
MUST NOT BE GREATER THAN 2.50% OF CALIBRATION SPAN PER METHOD 3A 8.3		

Air Compliance Consultants, Inc.
 EPA Method 5
 Meter Box Calibration
 Pre-Test Orifice Method
 English Meter Box Units, English K Factor
 Apex Orifices

	Previous Cal	New Cal	% Difference
Y	0.997	0.994	0.295
dH	1.653	1.684	1.263

Model #: C-5000
 Serial #: 1462

Date: 08/10/09 60.00
 Barometric Pressure: 29.32 (in. Hg)
 Theoretical Critical Vacuum: 13.83 (in. Hg)

!!!!!!!
 IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
 IMPORTANT The Critical Orifice Coefficient, K, must be entered in English units, (ft)³*(deg R)^{0.5}/((in.Hg)*(min)).
 !!!!!!!!

DRY GAS METER READINGS					-CRITICAL ORIFICE READINGS-									
dH (in H ₂ O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	- Ambient Temperature -		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.46	15.00	503.912	510.434	6.522	82.0	81.0	84.0	82.0	47	0.3249	22.0	81.0	81.0	81.0
0.87	10.00	526.572	532.503	5.931	87.0	84.0	88.0	85.0	55	0.4419	20.5	83.0	83.0	83.0
1.50	10.00	496.238	503.802	7.564	81.0	80.0	82.0	80.0	63	0.5756	19.0	81.0	81.0	81.0
2.85	11.00	533.058	544.593	11.535	87.0	85.0	89.0	86.0	73	0.7835	17.0	83.0	83.0	83.0
4.20	13.00	510.527	526.493	15.966	83.0	82.0	89.0	84.0	81	0.9463	15.0	82.0	83.0	82.5

***** RESULTS *****

-- DRY GAS METER -- VOLUME CORRECTED	
Vm(std) (cu ft)	Vm(std) (liters)
6.228	176.4
5.630	159.5
7.262	205.7
10.990	311.2
15.325	434.0

-- ORIFICE -- VOLUME CORRECTED			VOLUME NOMINAL
Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Vcr (cu ft)
6.143	174.0	6.426	6.426
5.560	157.5	5.837	5.837
7.256	205.5	7.590	7.590
10.844	307.1	11.385	11.385
15.486	438.6	16.243	16.243

-- DRY GAS METER -- CALIBRATION FACTOR	
Y	Variation
Value (number)	(number)
0.986	-0.008
0.988	-0.007
0.999	0.005
0.987	-0.007
1.010	0.016

-- ORIFICE -- CALIBRATION FACTOR		
dH@		
Value (in H ₂ O)	Value (mm H ₂ O)	Variation (in H ₂ O)
1.613	40.96	-0.071
1.658	42.11	-0.026
1.680	42.68	-0.004
1.725	43.80	0.040
1.745	44.33	0.061

Avg Y--> 0.994 Avg dH@--> 1.684 42.78

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +/-0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H₂O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +/-0.2.

SIGNED: _____

Date: 08-10-09

Air Compliance Consultants, Inc.
 EPA Method 5
 Meter Box Calibration
 Pre-Test Orifice Method
 English Meter Box Units, English K Factor
 Apex Orifices

	Previous Cal	New Cal	% Difference
Y	1.003	0.988	1.516
dH	1.680	1.626	3.251

Model #: C-5000
 Serial #: 1581

Date: 08/12/09 60.00
 Barometric Pressure: 29.40 (in. Hg)
 Theoretical Critical Vacuum: 13.87 (in. Hg)

!!!!!!!
 IMPORTANT For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.
 IMPORTANT The Critical Orifice Coefficient, K', must be entered in English units, (ft)³(deg R)^{0.5}/((in.Hg)²(min)).
 !!!!!!!!

--- DRY GAS METER READINGS ---									--- CRITICAL ORIFICE READINGS ---					
dH (in H2O)	Time (min)	Volume Initial (cu ft)	Volume Final (cu ft)	Volume Total (cu ft)	Initial Temps.		Final Temps.		Orifice Serial# (number)	K' Orifice Coefficient (see above)	Actual Vacuum (in Hg)	--- Ambient Temperature ---		
					Inlet (deg F)	Outlet (deg F)	Inlet (deg F)	Outlet (deg F)				Initial (deg F)	Final (deg F)	Average (deg F)
0.46	15.00	910.537	917.038	6.501	80.0	76.0	80.0	76.0	47	0.3249	23.0	75.0	75.0	75.0
0.88	10.00	930.004	935.901	5.897	84.0	79.0	81.0	79.0	55	0.4419	21.5	75.0	75.0	75.0
1.50	11.00	902.006	910.419	8.413	80.0	78.0	80.0	79.0	63	0.5756	20.0	75.0	75.0	75.0
2.85	10.00	936.014	946.482	10.468	81.0	79.0	84.0	80.0	73	0.7835	17.0	75.0	75.0	75.0
4.25	10.00	917.155	929.755	12.600	80.0	79.0	84.0	80.0	81	0.9463	15.0	75.0	75.0	75.0

RESULTS

--- DRY GAS METER --- VOLUME CORRECTED	
Vm(std) (cu ft)	Vm(std) (liters)
6.274	177.7
5.668	160.5
8.121	230.0
10.106	286.2
12.213	345.9

--- ORIFICE --- VOLUME CORRECTED			VOLUME NOMINAL
Vcr(std) (cu ft)	Vcr(std) (liters)	Vcr (cu ft)	Vcr (cu ft)
6.195	175.4	6.390	6.390
5.617	159.1	5.794	5.794
8.048	227.9	8.302	8.302
9.959	282.0	10.273	10.273
12.028	340.6	12.408	12.408

--- DRY GAS METER --- CALIBRATION FACTOR	
Y	Variation
Value (number)	(number)
0.987	-0.001
0.991	0.003
0.991	0.003
0.985	-0.003
0.985	-0.003

--- ORIFICE --- CALIBRATION FACTOR		
dH@		
Value (in H2O)	Value (mm H2O)	Variation (in H2O)
1.563	39.70	-0.063
1.607	40.82	-0.019
1.616	41.05	-0.010
1.654	42.02	0.028
1.691	42.95	0.065

Avg Y → 0.988

Avg dH@ → 1.626 41.31

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is +0.02.

For Orifice Calibration Factor dH@, the orifice differential pressure in inches of H2O that equates to 0.75 cfm of air at 68 F and 29.92 inches of Hg, acceptable tolerance of individual values from the average is +0.2.

SIGNED: 

Date: 08-12-09

**AIR COMPLIANCE/CONSULTANTS, INC.
TYPE S PITOT TUBE INSPECTION DATA**

DATE 9/4/2009
 PITOT ID 9-1
 IS TUBE ASSEMBLY LEVEL ? yes
 ARE OPENINGS DAMAGED? no


PA= 0.576 PB= 0.577 Pavg= 0.577
 DT= 0.386 A= 1.153 Pavg/Dt= 1.494
 (1.05<X<1.5)

TRAVERSE AXIS (ALPHA 1) 0 (<10)
 TRAVERSE AXIS (ALPHA 2) 1 (<10)

LONG AXIS (BETA 1) 1 (<05)
 LONG AXIS (BETA 2) 0 (<05)

FRONT ANGLE (GAMMA) 0 0
 SIDE ANGE (THETA) 0 0

ALIGN DISPLACEMENT Z 0 <0.125 INCHES
 ALIGN DISPLACEMENT W 0 <0.03125 INCHES

CALIBRATION REQUIRED? NO
 CALIBRATED BY ? jcc 

ALL PARAMETERS MEET SPECS? YES

thermocouple calibration

bp in Hg. 29.8
 ambient temp 63
 mercury in glass yes

reference point	mercury	thermocouple	temperature difference(%)
	36	35	0.20%
ambient day of test	64	62	0.38%
	103	101	0.36%
	211	208	0.45%
	302	299	0.39%
	406	401	0.58%
	489	484	0.53%

difference must be less than or equal to 1.50%

**AIR COMPLIANCE/CONSULTANTS, INC.
TYPE S PITOT TUBE INSPECTION DATA**

DATE 9/4/2009
 PITOT ID 10-1
 IS TUBE ASSEMBLY LEVEL ? yes
 ARE OPENINGS DAMAGED? no


PA= 0.577 PB= 0.579 Pavg= 0.578
 DT= 0.390 A= 1.156 Pavg/Dt= 1.482
 (1.05<X<1.5)

TRAVERSE AXIS (ALPHA 1) 1 (<10)
 TRAVERSE AXIS (ALPHA 2) 1 (<10)

LONG AXIS (BETA 1) 1 (<05)
 LONG AXIS (BETA 2) 1 (<05)

FRONT ANGLE (GAMMA) 0 0
 SIDE ANGE (THETA) 0 0

ALIGN DISPLACEMENT Z 0 <0.125 INCHES
 ALIGN DISPLACEMENT W 0 <0.03125 INCHES

CALIBRATION REQUIRED? NO
 CALIBRATED BY ? jcc 

ALL PARAMETERS MEET SPECS? YES

thermocouple calibration

bp in Hg.	29.3			
ambient temp	78			
mercury in glass	yes			
		mercury	thermocouple	temperature difference(%)
reference point		34	32	0.40%
	ambient day of test	68	66	0.38%
		101	99	0.36%
		203	200	0.45%
		298	295	0.40%
		400	396	0.47%
		503	499	0.42%
difference must be less than or equal to		1.50%		

APPENDIX D

Laboratory Analytical Data

Air Compliance Consultants, Inc

1050 William Pitt Way
Pittsburgh, PA 15238

Valero Energy
Delaware City Refinery
Project # 09-129
PO # 831-09

Analytical Report
(0909-78)

EPA Method 8
Sulfuric acid mist



Enthalpy Analytical, Inc.

Phone: (919) 850 - 4392 / Fax: (919) 850 - 9012 / www.enthalpy.com
2202 Ellis Road Durham, NC 27703 - 5518

I certify that to the best of my knowledge all analytical data presented in this report:

- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)
- This analytical report was prepared in Portable Document Format (.PDF) and contains 14 pages.

Valgena Respass

QA Review Performed by – Valgena Respass



Summary of Results



Company	ACC, Inc.
Analyst	EO
Parameters	EPA Method 8
# Samples	6 Runs & 2 blanks

Client #	09-129
Job #	0909-78
PO #	831-09
Report Date	10/1/2009

Sample Identification	Compound / Catch Weight (mg)
	Sulfuric acid mist (H₂SO₄)
<i>Run 1 S-804</i>	7.44
<i>Run 2 S-804</i>	6.14
<i>Run 3 S-804</i>	7.11
<i>Run 1 S203</i>	17.1
<i>Run 2 S203</i>	15.1
<i>Run 3 S203</i>	8.30
<i>IPA Blank</i>	0.0474 ND

Results



Company	ACC, Inc.
Analyst	EO
Parameters	EPA Method 8
# Samples	6 Runs & 1 Blank

Client #	09-129
Job #	0909-78
PO #	831-09
Report Date	10/1/2009

MDL 0.04
Blank titrant amount (Vtb) 0.03
BaCl₂ normality 0.0097

Sulfuric acid mist (H₂SO₄)

Sample ID.	Volume Received (mL)	Titration Aliquot Vol (mL)	1st Titration BaCl ₂ Vol (mL)	2nd Titration BaCl ₂ Vol (mL)	Average BaCl ₂ Vol (mL)	% Difference	Aliquot Factor	Catch Weight H ₂ SO ₄ (mg)
IPA Fractions								
Run 1 S-804	365	10.0	0.45	0.47	0.46	4.3	36.5	7.44
Run 2 S-804	350	10.0	0.40	0.40	0.40	0.0	35.0	6.14
Run 3 S-804	300	10.0	0.52	0.54	0.53	3.8	30.0	7.11
Run 1 S203	445	10.0	0.83	0.85	0.84	2.4	44.5	17.1
Run 2 S203	300	10.0	1.08	1.10	1.09	1.8	30.0	15.1
Run 3 S203	240	10.0	0.75	0.77	0.76	2.6	24.0	8.30
IPA Blank	100	10.0	0.04 ND	0.04 ND	0.04 ND	0.0	10.0	0.0474 ND
LCS-1	100	1.00	0.32	0.34	0.33	6.1	100	14.2
							Spike Amount	15.4
							Spike Recovery (%)	92.5%
LCS-2	100	1.00	0.56	0.57	0.57	1.8	100	25.3
							Spike Amount	24.0
							Spike Recovery (%)	106%

Narrative Summary



Enthalpy Analytical Narrative Summary

Company	ACC, Inc.
Analyst	EO
Parameters	EPA Method 8
# Samples	6 Runs & 1 blank

Client #	09-129
Job #	0909-78
PO #	831-09
Report Date	10/1/2009

Custody Tony Mastriani of Enthalpy Analytical, Inc. received the samples on 9/18/2009 at 21.6 °C after being relinquished by Air Compliance Consultants, Inc. The samples were received in good condition. Prior to and during analysis, the samples were kept under lock with access only to authorized personnel by Enthalpy Analytical, Inc.

Analysis The samples were analyzed for sulfuric acid mist using the analytical procedures in EPA Method 8, Determination of Sulfuric Acid and Sulfur Dioxide Emissions from Stationary Sources (40 CFR Part 60, Appendix A).

The samples were titrated using a barium chloride solution prepared in the lab. The normality was determined according to the procedures described in the method. The samples were titrated to a pink endpoint using a thordin indicator. Replicate titrations were performed, with the titrant volumes meeting the QC criteria established for EPA Method 8. Results are reported in milligrams (mg) catch.

Sulfuric acid (H₂SO₄) calculations:

$$C_{H_2SO_4} = (N)(V_t - V_b)(V_{sol}/V_a)(49.04)$$

Where:

- C_{H₂SO₄} Catch weight as sulfuric acid (mg)
- N Normality of the barium chloride titrant
- V_t Volume of the titrant used to achieve pink endpoint
- V_b Titrant volume to achieve pink endpoint w/Lab IPA
- V_{sol} Volume of the entire sample solution
- V_a Volume of the aliquot taken for the titration
- 49.04 Equivalent weight for sulfuric acid

QC Notes No blank corrections were applied to the sample results (aside from the titrant blank as shown above).



Enthalpy Analytical Narrative Summary (continued)

Reporting Notes Samples are analyzed using a micro-burette to conserve sample and reduce waste. The burette is 1/10th the volume of that specified in EPA Method 8. Therefore, the reproducibility criteria used is 1% or 0.02 mL (1/10th the 0.2 mL default volume specified in EPA Method 8).

Enthalpy Analytical, Inc. is accredited to perform this method for compliance purposes by the National Environmental Laboratory Accreditation Conference (NELAC) through the Louisiana Environmental Laboratory Accreditation Program (LELAP), certificate number 04010.



General Reporting Notes

The following are general reporting notes that are applicable to all Enthalpy Analytical, Inc. reports, unless specifically noted otherwise.

- The symbol **MDL** represents the Minimum Detection Limit. Below this value the laboratory cannot determine the presence of the analyte of interest reliably.
- The symbol **LOQ** represents the Limit of Quantification. Below this value the laboratory cannot quantitate the analyte of interest within the criteria of the method.
- The symbol **ND** following a value indicates a non-detect or analytical result below the MDL.
- The symbol **J** following a value indicates an analytical result between the MDL and the LOQ. A J flag indicates that the laboratory can positively identify the analyte of interest as present, but the value should be considered an estimate.
- The symbol **E** following a value indicates an analytical result exceeding 100% of the highest calibration point. The associated value should be considered as an estimate.
- The symbol **DF** represents a Dilution Factor. This number represents dilution of the sample during the preparation and/or analysis process. The analytical result taken from a laboratory instrument is multiplied by the DF to get final results.
- The Sample ID **MS** represents a Matrix Spike. An aliquot of an actual sample is spiked with a known amount of analyte so that a percent recovery value can be determined. This shows what effect the sample matrix may have on the target analyte, i.e. whether or not anything in the sample matrix prohibits analysis for the analyte(s).
- The Sample ID **MSD** represents a Matrix Spike Duplicate. Prepared in the same manner as an MS, the use of duplicate matrix spikes allows further confirmation of laboratory quality by showing the consistency of results gained by performing the same steps multiple times. Most methods performed by Enthalpy do not require analysis of an MSD.
- The Sample ID **LD** represents a Laboratory Duplicate. The analyst prepares an additional aliquot of sample for testing and the results for the duplicate analysis are compared to the initial result. The result should have a % difference value of 10% or less, though either aliquot receiving a 'J-flagged' result makes the pair exempt from this criteria.
- The Sample ID **AD** represents an Alternate Dilution. The analyst prepares an additional aliquot at a different dilution factor (usually double the initial factor). This analysis helps confirm that no additional compound is present and coeluting or sharing absorbance with the analyte of interest, as they would have a different response/absorbance than the analyte of interest.
- The Sample ID **LCS** represents a Laboratory Control Sample. Clean matrix, similar to the client sample matrix, prepared and analyzed by the laboratory using the same reagents, spiking standards and procedures used for the client samples. The LCS is used to assess the control of the laboratory's analytical system. Whenever spikes are prepared for our clients more spikes are prepared than needed. The extras (randomly chosen) are kept in-house at the appropriate temperature conditions. When the spike samples come back from the client for analysis, the LCSs (usually two are saved) are analyzed to confirm that the analyte could be recovered from the media, separate from the spike samples which were used on the project and which may have had issues caused during collection and/or transport.



General Reporting Notes

(continued)

- **Significant Figures:** Where the reported value is much greater than unity (1.00) in the units expressed, the number is rounded to a whole number of units, rather than to 3 significant figures. For example, a value of 10,456.45 ug catch is rounded to 10,456 ug. There are five significant digits displayed, but no confidence should be placed on more than two significant digits.
- **Manual Integration:** The data systems used for processing will flag manually integrated peaks with an "M". There are several reasons a peak may be manually integrated. These reasons will be identified by the following two letter designations. The peak was not integrated by the software "NI", the peak was integrated incorrectly by the software "II" or the wrong peak was integrated by the software "WP". These codes will accompany the analyst's manual integration stamp placed next to the compound name.



Sample Custody



1 Client Name: VALERO ENERGY
 Project Location: DELAWARE CITY REFINERY Project No.: 09-129
 Project Manager (PM): JAIMES CONTRERAS
 PM Email: jcontrer@air-comp.com
 Laboratory: FENTHALPY PO #: 231-07
 Lab Contact / Phone #: BRIAN TYLER / 919-850-4392

Analysis Request / Chain of Custody Form



Air/Compliance Consultants, Inc.

1050 William Pitt Way
 Pittsburgh, PA 15238
 Phone: 412-826-3636
 Fax: 412-826-3640

Please Print Neatly

Sample Identification ②				Date Collected	Time Collected	Grab ③	Composite	Matrix ④	Source	Ambient	Total # of Containers	Canisters*	Analysis Requested ⑤	Remarks ⑥	Temperature of samples upon receipt (if requested)
IMP 1+2+RINSE RUN 1 S804				9/15	-			80% IPA SOL'N					EPA METHOD 8		
IMP 1+2+RINSE RUN 2 S804				9/15	-										
IMP 1+2+RINSE RUN 3 S804				9/15	-										
IMP 1+2+RINSE RUN 1 S203				9/15	-										
IMP 1+2+RINSE RUN 2 S203				9/15	-										
IMP 1+2+RINSE RUN 3 S203				9/15	-										
20% IPA SOL'N BLANK				9/15	-										
80% IPA SOL'N BLANK				9/15	-										

7 Turnaround Time Requested (TAT)
 (please circle): Normal Rush
 Date results are needed: _____
 If rush results requested please fax to: _____
 Fax #: _____

Relinquished by:	Date	Time	Received by:	Date	Time
<u>Chad Bull</u>	9/16/09	10:30	<u>Anthony Mactawan</u>	9/18/09	09:55
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time

10 *Canister Pressure / Vacuum			
Initial	Final	Units	Receipt

8 Notes: SECOND BLANK CAN BE USED FOR SAMPLE DILUTION IF NECESSARY

Please call (412) 826-3636 if there are any questions prior to proceeding. Please cc slindquist@air-comp.com with all laboratory results

11 Project Manager Approval (Print & Sign)
 PM Sign: [Signature]
 PM Print: JAIMES CONTRERAS
 COC completed by (initial): CWB Date: 9/16/09

Instructions on reverse side correspond with circled numbers

WHITE - LAB • YELLOW - FILE

No 2264

**This Is The Last Page
Of This Report.**



APPENDIX E

Sample Calculations

SCOT 1 (203)

ACCI SAMPLE CALCULATIONS
H2SO4 and CEMS
Valero
09-129
Valero DCR
SCOT 1 (203)
normal
15-Sep-09
Exhaust
Run 1

	Vf	0.0	ml		Tstandard	68	F
	Vi	0.0	ml		Pstandard	760	mm Hg
	Wf	3,611.3	g		K1method 4	0.04707	scf/ml
	Wi	3,523.1	g		K2method 4	0.04715	scf/g
	Vm	47.350	daef		K1method 5	17.64	R/in Hg
	Vm	0.000	dry actual liters		K4method 5	0.0945	
	Yd	0.9880			V/n _{standard}	385.3	ft ³ /lb-mole
	Pbar	30.00	in Hg		Kp	85.49	
	dfavg	1.60	in H2O		Pa	0	0
	Tm	83.8	F		π	3.141593	
	O2	4.06	% dv		Ds (or L)	80.00	inches
	CO2	16.83	% dv		Stack Width (W)	NA	inches
	Pg	-0.20	in H2O		Dn	na	inches
	Cp	0.84			Time	60	minutes
	(dP) ^{1/2} avg	0.272	in H2O ^{1/2}		Tsavg	1198.8	F
	Fc	NA	dscf/MMBtu		Product rate	0.00	0.00
					An	NA;Dn = NA	ft ²
CEMS DATA							
	Carbon Monoxide				Oxides of Nitrogen (NOX)		
	Coverage _{CO}	1.1	ppmdv		Coverage _{NO2}	30.2	ppmdv
	C _{0CO}	0.3	ppmdv		C _{0NO2}	-0.2	ppmdv
	C _{maCO}	25.6	ppmdv		C _{maNO2}	25.5	ppmdv
	C _{mCO}	25.6	ppmdv		C _{mNO2}	25.2	ppmdv
					MW SO2	64.0	lb/lb-mole
					MW NO2	46.0	lb/lb-mole
					MW CO	28.0	lb/lb-mole

Volume of Water Vapor Condensed (Vwc)

$$Vwc(std) = K1method\ 4 * (Vf - Vi)$$

K1method 4= 0.04707 scf/ml
 Vf= 0.0 ml
 Vi= 0.0 ml
 Vwc(std)= 0.000 scf

Volume of Water Vapor Collected in Silica Gel (Vwsg)

$$Vwsg(std) = K2method\ 4 * (Wf - Wi)$$

K2method 4= 0.04715 scf/g
 Wf= 3,611.3 g
 Wi= 3,523.1 g
 Vwsg(std)= 4.159 scf

Total Volume of Water Vapor in Gas Sample (Vw)

$$Vw(std) = Vwc(std) + Vwsg(std)$$

Vwc(std)= 0.000 scf
 Vwsg(std)= 4.159 scf
 Vw(std)= 4.159 scf

Volume of Gas Metered

$V_m = \text{Volume metered in dacf} + \text{Volume metered in dry actual liters} * (1 \text{ cf} / 28.317 \text{ liters})$
 Volume metered in dacf= 47.350 dacf
 Volume metered in dry actual liters= 0.000 dry actual liters
 Vm= 47.350 dacf

 $V_m(m^3) = V_m * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 Vm= 47.350 dacf
 Vm(m³)= 1.341 dactm

Volume of Gas Metered , dry basis, STD

$V_m(\text{std}) = (K1_{\text{method 5}} * V_m * Y_d * (P_{\text{bar}} + (dH_{\text{avg}}/13.6))) / (T_m + 460)$
 K1method 5= 17.64 R/in Hg
 Vm= 47.350 dacf
 Yd= 0.9880
 Pbar= 30.00 in Hg
 dHavg= 1.60 in H2O
 Tm= 83.8 F
 Vm(std)= 45.709 dscf

 $V_m(\text{std})m^3 = V_m(\text{std}) * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 Vm(std)= 45.709 dscf
 Vm(std)m³= 1.294 dscm

Water Vapor in the Gas Stream

Bws used = the lower of $SP_{H_2O@T_{\text{savg}}} / P_5$
 and $V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std}))$

 Bws = $SP_{H_2O@T_{\text{savg}}} / P_5$ With a maximum allowable value of 1.0
 $SP_{H_2O@T_{\text{savg}}}$ = The saturation pressure of water at stack temperature
 1997 ASHRAE Handbook page 6.2 Eq. (6)
 $EXP(C_8/T + C_9 + C_{10}*T + C_{11}*T^2 + C_{12}*T^3 + C_{13}*\ln(T)) * (29.921/14.696)$

 $T = T_{\text{savg}} + 459.67$
 Tsavg= 1198.8 F
 T= 1658.4 R
 C8= -1.044040E+04
 C9= -1.1294650E+01
 C10= -2.702236E-02
 C11= 1.289036E-05
 C12= -2.478068E-09
 C13= 6.545967E+00

 $SP_{H_2O@T_{\text{savg}}}$ = 59033.58 in. Hg
 P5= 29.99 in. Hg
 Bws= 1.0000 vol. fraction

 $Bws = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std}))$
 Vw(std)= 4.159 scf
 Vm(std)= 45.709 dscf
 Bws= 0.0834 vol. fraction

 Bws used= 0.0834 vol. fraction

Carbon Monoxide and Nitrogen in gas

$CO + N_2 = 100 - (CO_2 + O_2)$
 CO2= 16.83 % dv
 O2= 4.06 % dv
 CO + N2= 79.10 % dv

Molecular weight of dry gas stream

$M_d = 0.44 * CO_2 \%dv + 0.32 * O_2 \%dv + 0.28 * (CO + N_2 \%dv)$	
CO ₂ =	16.83 % dv
O ₂ =	4.06 % dv
CO + N ₂ =	79.10 % dv
M _d =	30.86 lb/lb-mole

Molecular weight of wet gas stream

$M_s = M_d * (1 - B_{ws}) + 18 * B_{ws}$	
M _d =	30.86 lb/lb-mole
B _{ws} =	0.0834 vol. fraction
M _s =	29.78 lb/lb-mole

Stack Pressure

$P_s = P_{bar} + P_g/13.6$	
P _{bar} =	30.00 in. Hg
P _g =	-0.20 in. H ₂ O
P _s =	29.99 in. Hg

Average Stack Gas Velocity

$V_s = K_p * C_p * (dP)^{1/2}_{avg} * ((T_{savg} + 460) / (P_s * M_s))^{1/2}$	
K _p =	85.49
C _p =	0.84
$(dP)^{1/2}_{avg}$ =	0.2717 in. H ₂ O ^{1/2}
T _{savg} =	1198.8 F
P _s =	29.99 in. Hg
M _s =	29.78 lb/lb-mole
V _s =	26.59 ft/s

Area of the Stack

If W = 0, the stack is circular	
Circular	
$A_s = \pi * (D_s)^2 / 4 * (1 \text{ ft} / 12 \text{ in.})^2$	
PI=	3.141593
D _s =	80.00 inches
A _s =	34.91 ft ²
Rectangular	
$A_s = L * W * (1 \text{ ft} / 12 \text{ in.})^2$	
L=	0.00 inches
W=	NA inches
A _s =	0.00 ft ²

Stack Gas Flow Rate, Actual

$Q_{acfm} = V_s * A_s * 60$	
V _s =	26.59 ft/s
A _s =	34.91 ft ²
Q _{acfm} =	55,682 acfm
$Q_{acm}/min = Q_{acfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
Q _{acfm} =	55,682 acfm
Q _{acm} /min=	1,577 acm/min

Stack Gas Flow Rate, Standard

$Q_{scfm} = Q_{acfm} * ((T_{standard} + 460) / (T_{avg} + 460)) * (P_s / P_{standard})$	
$Q_{acfm} =$	55,682 acfm
$T_{standard} =$	68 F
$T_{avg} =$	1198.8 F
$P_s =$	29.99 in. Hg
$P_{standard} =$	29.92 in. Hg
$Q_{scfm} =$	17,763 scfm
$Q_{scm/min} = Q_{scfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
$Q_{scfm} =$	17,763 scfm
$Q_{scm/min} =$	503 scm/min

Stack Gas Flow Rate, Dry Standard

$Q_{dscfm} = Q_{scfm} * (1 - B_{ws})$	
$Q_{scfm} =$	17,763 scfm
$B_{ws} =$	0.0834 vol. fraction
$Q_{dscfm} =$	16,282 dscfm
$Q_{dscm/min} = Q_{dscfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$	
$Q_{dscfm} =$	16,282 dscfm
$Q_{dscm/min} =$	461 dscm/min

Oxides of Nitrogen concentration (ppmdv)

$C_{NO_x} = (C_{average_{NO_x}} - C_{0_{NO_x}}) * C_{ma_{NO_x}} / (C_{m_{NO_x}} - C_{0_{NO_x}})$	
$C_{average_{NO_x}} =$	30.23 ppmdv
$C_{0_{NO_x}} =$	-0.20 ppmdv
$C_{ma_{NO_x}} =$	25.50 ppmdv
$C_{m_{NO_x}} =$	25.22 ppmdv
$C_{NO_x} =$	30.53 ppmdv

Oxides of Nitrogen emission rate (lb/hr)

$NO_x(\text{lb/hr}) = C_{NO_x} / 1,000,000 * Q_{dscfm} * (60 \text{ min} / 1 \text{ hour}) / V/n_{standard} * NO_{x_{MW}}$	
$C_{NO_x} =$	30.53 ppmdv
$Q_{dscfm} =$	16,282 dscfm
$V/n_{standard} =$	385.3 ft ³ /lb-mole
$NO_{x_{MW}} =$	46.0 lb/lb-mole
$NO_x(\text{lb/hr}) =$	3.56 lb/hr

Carbon Monoxide concentration (ppmdv)

$C_{CO} = (C_{averageCO} - C_{CO}) * C_{maCO} / (C_{mCO} - C_{CO})$	
$C_{averageCO} =$	1.06 ppmdv
$C_{CO} =$	0.29 ppmdv
$C_{maCO} =$	25.60 ppmdv
$C_{mCO} =$	25.56 ppmdv
$C_{CO} =$	0.79 ppmdv

Carbon Monoxide emission rate (lb/hr)

$CO(lb/hr) = C_{CO} / 1,000,000 * Q_{dscfm} * (60 \text{ min} / 1 \text{ hour}) / V/n_{standard} * CO_{MW}$	
$C_{CO} =$	0.79 ppmdv
$Q_{dscfm} =$	16,282 dscfm
$V/n_{standard} =$	385.3 ft ³ /lb-mole
$COMW =$	28.0 lb/lb-mole
$CO(lb/hr) =$	0.06 lb/hr

Sulfuric Acid Emission Concentration (lb/dscf)

$E = \text{Sulfuric Acid} * (1/1000 * (1/453.593) / Vm(std))$	
$H_2SO_4 =$	17.10 mg
$Vm(std) =$	45,709 dscf
$E =$	8.25E-07 lb/dscf

Sulfuric Acid Emission Concentration (ppmdv)

$E = E/MW * V/n_{standard} * 1000000$	
$MW =$	98 lb/lb-mole
$V/n_{standard} =$	385.3 ft ³ /lb-mole
$E =$	8.25E-07 lb/dscf
$E =$	3.24 ppmdv

Sulfuric Acid Emission Rate (lb/hr)

$E = E(lb/dscf) * dscfm * 60$	
$E =$	8.25E-07 lb/dscf
$Q_{dscfm} =$	16,282 dscfm
$E =$	0.81 lb/hr

SCOT 2 (804)

**ACCI SAMPLE CALCULATIONS
H2SO4 and CEMS**

Valero
09-129

Valero DCR
SCOT 2 (804)

normal

September 15, 2009

Exhaust

Run 1

Vf	0.0	ml	Tstandard	68	F
Vi	0.0	ml	Pstandard	760	mm Hg
Wf	3,263.6	g	K1method 4	0.04707	scf/ml
Wi	3,116.1	g	K2method 4	0.04715	scf/g
Vm	45.505	dacf	K1method 5	17.64	R/in Hg
Vm	0.000	dry actual liters	K4method 5	0.0945	
Yd	0.9940		V/n _{standard}	385.3	ft ³ /lb-mole
Pbar	30.00	in Hg	Kp	85.49	
dHavg	1.70	in. H2O	pa	0	0
Tm	76.4	F	π	3.141593	
O2	2.05	% dv	Ds (or L)	72.00	inches
CO2	14.80	% dv	Stack Width (W)	NA	inches
Pg	-1.20	in. H2O	Dn	NA	inches
Cp	0.84		Time	60	minutes
(dP) ^{1/2} avg	0.303	in. H2O ^{1/2}	Isavg	1315.3	F
Fc	1,094	dscf/MMBtu	Product rate	#REF!	#REF!
			An	NA;Dn = NA	ft ²
CEMS DATA			Oxides of Nitrogen (NOX)		
Carbon Monoxide			Coverage _{NO2}		
Coverage _{CO}	9.9	ppmdv	C _{0NO2}	-0.1	ppmdv
C _{0CO}	-1.3	ppmdv	C _{maNO2}	25.5	ppmdv
C _{maCO}	25.6	ppmdv	C _{mNO2}	25.4	ppmdv
C _{mCO}	25.1	ppmdv	MW SO2	64.0	lb/lb-mole
			MW NO2	46.0	lb/lb-mole
			MW CO	28.0	lb/lb-mole

Volume of Water Vapor Condensed (Vwc)

$$Vwc(std) = K1method\ 4 * (Vf - Vi)$$

K1method 4= 0.04707 scf/ml
Vf= 0.0 ml
Vi= 0.0 ml
Vwc(std)= 0.000 scf

Volume of Water Vapor Collected in Silica Gel (Vwsg)

$$Vwsg(std) = K2method\ 4 * (Wf - Wi)$$

K2method 4= 0.04715 scf/g
Wf= 3,263.6 g
Wi= 3,116.1 g
Vwsg(std)= 6.955 scf

Total Volume of Water Vapor in Gas Sample (Vw)

$$Vw(std) = Vwc(std) + Vwsg(std)$$

Vwc(std)= 0.000 scf
Vwsg(std)= 6.955 scf
Vw(std)= 6.955 scf

Volume of Gas Metered

$V_m = \text{Volume metered in dacf} + \text{Volume metered in dry actual liters} * (1 \text{ cf} / 28.317 \text{ liters})$
 Volume metered in dacf= 45.505 dacf
 Volume metered in dry actual liters= 0.000 dry actual liters
 Vm= 45.505 dacf

 $V_m(m^3) = V_m * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 Vm= 45.505 dacf
 Vm(m³)= 1.289 dactm

Volume of Gas Metered , dry basis, STD

$V_m(\text{std}) = (K1_{\text{method 5}} * V_m * Y_d * (P_{\text{bar}} + (dH_{\text{avg}}/13.6))) / (I_m + 460)$
 K1method 5= 17.64 R/in Hg
 Vm= 45.505 dacf
 Yd= 0.9940
 Pbar= 30.00 in Hg
 dHavg= 1.70 in. H2O
 Im= 76.4 F
 Vm(std)= 44.809 dscf

 $V_m(\text{std})m^3 = V_m(\text{std}) * (1 \text{ m}^3 / 35.3145 \text{ cf})$
 Vm(std)= 44.809 dscf
 Vm(std)m³= 1.269 dscm

Water Vapor in the Gas Stream

Bws used = the lower of $SP_{H_2O@T_{\text{savg}}} / P_s$
 and $V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std}))$

 Bws = $SP_{H_2O@T_{\text{savg}}} / P_s$ With a maximum allowable value of 1.0
 $SP_{H_2O@T_{\text{savg}}}$ = The saturation pressure of water at stack temperature
 1997 ASHRAE Handbook page 6.2 Eq. (6)
 $EXP(C_8/T + C_9 + C_{10} * T + C_{11} * T^2 + C_{12} * T^3 + C_{13} * \ln(T)) * (29.921/14.696)$

 $T = T_{\text{savg}} + 459.67$
 Tsavg= 1315.3 F
 T= 1774.9 R
 C8= -1.044040E+04
 C9= -1.1294650E+01
 C10= -2.702236E-02
 C11= 1.289036E-05
 C12= -2.478068E-09
 C13= 6.545967E+00

 $SP_{H_2O@T_{\text{savg}}}$ = 80661.60 in. Hg
 Ps= 29.91 in. Hg
 Bws= 1.0000 vol fraction

 $Bws = V_w(\text{std}) / (V_m(\text{std}) + V_w(\text{std}))$
 Vw(std)= 6.955 scf
 Vm(std)= 44.809 dscf
 Bws= 0.1344 vol fraction

 Bws used= 0.1344 vol. fraction

Carbon Monoxide and Nitrogen in gas

$CO + N_2 = 100 - (CO_2 + O_2)$
 CO2= 14.80 % dv
 O2= 2.05 % dv
 CO + N2= 83.15 % dv

Molecular weight of dry gas stream

$Md = 0.44 * CO2 \%dv + 0.32 * O2 \%dv + 0.28 * (CO + N2 \%dv)$	
CO2=	14.80 % dv
O2=	2.05 % dv
CO + N2=	83.15 % dv
Md=	30.45 lb/lb-mole

Molecular weight of wet gas stream

$Ms = Md * (1 - Bws) + 18 * Bws$	
Md=	30.45 lb/lb-mole
Bws=	0.1344 vol fraction
Ms=	28.78 lb/lb-mole

Stack Pressure

$Ps = Pbar + Pg/13.6$	
Pbar=	30.00 in. Hg
Pg=	-1.20 in. H2O
Ps=	29.91 in. Hg

Average Stack Gas Velocity

$Vs = Kp * Cp * (dP)^{1/2} avg * ((Tsavg + 460) / (Ps * Ms))^{1/2}$	
Kp=	85.49
Cp=	0.84
$(dP)^{1/2} avg=$	0.3034 in. H2O ^{1/2}
Tsavg=	1315.3 F
Ps=	29.91 in. Hg
Ms=	28.78 lb/lb-mole
Vs=	31.29 ft/s

Area of the Stack

If W = 0, the stack is circular.	
Circular	
$As = PI * (Ds)^2 / 4 * (1 ft / 12 in.)^2$	
PI=	3.141593
Ds=	72.00 inches
As=	28.27 ft ²
Rectangular	
$As = L * W * (1 ft / 12 in.)^2$	
L=	0.00 inches
W=	NA inches
As=	0.00 ft ²

Stack Gas Flow Rate, Actual

$Qacfm = Vs * As * 60$	
Vs=	31.29 ft/s
As=	28.27 ft ²
Qacfm=	53,089 acfm
$Qacm/min = Qacfm * (1 m^3 / 35.3145 cf)$	
Qacfm=	53,089 acfm
Qacm/min=	1,503 acm/min

Stack Gas Flow Rate, Standard

$$Q_{scfm} = Q_{acfm} * ((T_{standard} + 460) / (T_{avg} + 460)) * (P_s / P_{standard})$$

Q _{acfm} =	53,089 acfm
T _{standard} =	68 F
T _{avg} =	1315.3 F
P _s =	29.91 in Hg
P _{standard} =	29.92 in Hg
Q _{scfm} =	15,785 scfm

$$Q_{scm/min} = Q_{scfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

Q _{scfm} =	15,785 scfm
Q _{scm/min} =	447 scm/min

Stack Gas Flow Rate, Dry Standard

$$Q_{dscfm} = Q_{scfm} * (1 - B_{ws})$$

Q _{scfm} =	15,785 scfm
B _{ws} =	0.1344 vol. fraction
Q _{dscfm} =	13,665 dscfm

$$Q_{dscm/min} = Q_{dscfm} * (1 \text{ m}^3 / 35.3145 \text{ cf})$$

Q _{dscfm} =	13,665 dscfm
Q _{dscm/min} =	387 dscm/min

Oxides of Nitrogen concentration (ppmdv)

$$C_{NOx} = (C_{average_{NOx}} - C_{0_{NOx}}) * C_{ma_{NOx}} / (C_{m_{NOx}} - C_{0_{NOx}})$$

C _{average_{NOx}} =	11.89 ppmdv
C _{0_{NOx}} =	-0.05 ppmdv
C _{ma_{NOx}} =	25.50 ppmdv
C _{m_{NOx}} =	25.42 ppmdv
C _{NOx} =	11.96 ppmdv

Oxides of Nitrogen emission rate (lb/hr)

$$NOx(lb/hr) = C_{NOx} / 1,000,000 * Q_{dscfm} * (60 \text{ min} / 1 \text{ hour}) / V/n_{standard} * NOx_{MW}$$

C _{NOx} =	11.96 ppmdv
Q _{dscfm} =	13,665 dscfm
V/n _{standard} =	385.3 ft ³ /lb-mole
NO _{x,MW} =	46.0 lb/lb-mole
NO _x (lb/hr)=	1.17 lb/hr

Carbon Monoxide concentration (ppmdv)

$$C_{CO} = (C_{average_{CO}} - C_{0_{CO}}) * C_{ma_{CO}} / (C_{m_{CO}} - C_{0_{CO}})$$

$C_{average_{CO}} =$	9.87 ppmdv
$C_{0_{CO}} =$	-1.32 ppmdv
$C_{ma_{CO}} =$	25.60 ppmdv
$C_{m_{CO}} =$	25.06 ppmdv
$C_{CO} =$	10.87 ppmdv

Carbon Monoxide emission rate (lb/hr)

$$CO(lb/hr) = C_{CO} / 1,000,000 * Q_{dscfm} * (60 \text{ min} / 1 \text{ hour}) / V/n_{standard} * CO_{MW}$$

$C_{CO} =$	10.87 ppmdv
$Q_{dscfm} =$	13,665 dscfm
$V/n_{standard} =$	385.3 ft ³ /lb-mole
$CO_{MW} =$	28.0 lb/lb-mole
$CO(lb/hr) =$	0.65 lb/hr

Sulfuric Acid Emission Concentration (lb/dscf)

$$E = \text{Sulfuric Acid} * (1/1000) * (1/453.593) / Vm(std)$$

$H_2SO_4 =$	7.44 mg
$Vm(std) =$	44.809 dscf
$E =$	3.66E-07 lb/dscf

Sulfuric Acid Emission Concentration (ppmdv)

$$E = E/MW * V/n_{standard} * 1000000$$

$MW =$	98 lb/lb-mole
$V/n_{standard} =$	385.3 ft ³ /lb-mole
$E =$	3.66E-07 lb/dscf
$E =$	1.44 ppmdv

Sulfuric Acid Emission Rate (lb/hr)

$$E = E(lb/dscf) * dscfm * 60$$

$E =$	3.66E-07 lb/dscf
$Q_{dscfm} =$	13,665 dscfm
$E =$	0.30 lb/hr

Nomenclature

NOMENCLATURE

SYMBOL	DESCRIPTION
ACFM	- Actual cubic feet per minute
A_s	- Stack Area
AB	- Acetone Blank
AB1	- Acetone Blank Tare Weight 1
AB2	- Acetone Blank Tare Weight 2
ABF1	- Acetone Blank Final Weight 1
ABF2	- Acetone Blank Final Weight 2
AT1	- Acetone Rinse Tare Weight 1
AT2	- Acetone Rinse Tare Weight 2
A_n	- Nozzle Area
B_{wo}	- Moisture content of sample gas, measured impinger collection
B_{ws}	- Moisture content of sample gas, wet saturated
BTU	- British Thermal Units
C	- Carbon
C_3H_8	- Propane
C_a	- Acetone Blank Correction
C_M	- Average of initial and final system calibration bias check responses for the upscale gas, ppm
cf	- Cubic foot
C_{MA}	- Actual concentration of the upscale calibration gas, ppm
C_d	- Concentration of Particulate Emissions
C_0	- Average of initial and final system calibration bias check responses for the zero gas, ppm
CO	- Carbon monoxide
CO ₂	- Carbon dioxide
C_p	- Pitot co-efficient, 0.84 for S-type, 0.99 for standard (English units)
E_{NOX}	- Emission rate of Oxides of nitrogen as NO ₂ , lb/hr
DACF	- Dry actual cubic feet
DSCF	- Dry standard cubic feet
DACM	- Dry actual cubic meters
DSCFM	- Dry standard cubic feet per minute
dscf/MMBtu	- Dry standard cubic feet per Million British Thermal Units (units for Fd)
D_s	- Stack diameter
D_n	- Nozzle diameter
°F	- Degrees Fahrenheit
ft	- foot
F1	- Filter Final Weight 1
F2	- Filter Final Weight 2
FT1	- Filter Tare Weight 1
FT2	- Filter Tare Weight 2
F_c	- CO ₂ based F-Factor for natural gas (1,040 SCF/MMBtu)
F_d	- F-factor
ft^2	- Square feet
ft^3	- Cubic feet
FTIR	- Fourier Transform Infrared
ft ³ /lb-mole	- Cubic feet per pound mole
ft/sec	- Feet per second
g	- Grams
g/mL	- Gram per milliliter
gr/DSCF	- Grains per dry standard cubic feet

HI	-	Heat Input
ΔH_{avg}	-	Average pressure drop across the meter box during test run, inches H ₂ O
H ₂ O	-	Water
Hg	-	Mercury
hr	-	Hour
in Hg	-	Inches of Mercury
in H ₂ O	-	Inches of Water
$\sqrt{inH_2O}$	-	Square root of Inches of Water
I	-	Isokinetic Sampling
K1 method 5	-	Conversion to standard conditions, 17.64 °R/inches Hg
K1 method 4	-	Conversion to standard conditions, 0.04707 f3/ml
K2 method 4	-	Conversion to standard conditions, 0.04715 ft ³ /g
K4 method 5	-	Conversion to standard conditions, 0.0945
K _p	-	Pitot tube constant, 85.49 for English units
Kg	-	Killograms
L	-	Length of Stack if Rectangular
lb	-	Pound
lb/lb-mole	-	Pound per pound mole
lb-mole	-	Pound mole
lb/hr	-	Pound per hour
lb/MMBTU	-	Pound per million British thermal units
ma	-	Average Final (total) weight after evaporation - Average Tare Weight of Acetone Blank
m ³	-	Cubic meters
mg	-	Milligrams
mg/g	-	Milligrams per gram
mL	-	Milliliter
M _d	-	Molecular weight of stack gas mixture, dry basis
MMBTU	-	Million British Thermal Units
MMBtu/hr	-	Million British Thermal Units per hour
mm HG	-	Millimeters of Mercury
M _n	-	Mass of particulate matter, g
M _s	-	Molecular weight of stack gas mixture, wet basis
M _{SAT}	-	Ratio of vapor pressure of water at stack conditions to stack pressure
M _w	-	Molecular weight of a specific compound or element
N ₂	-	Nitrogen
O ₂	-	Oxygen
ng	-	Nanograms
NMNEVOC	-	Non-Methane, Non-Ethane Volatile Organic Compounds
NO _x	-	Oxides of Nitrogen
NO ₂	-	Nitrous Oxide
%	-	Percent
% Volume	-	Percent by volume
% dv	-	Percent by volume, dry basis
ΔP	-	Gas velocity pressure, in H ₂ O
P _a	-	Density of Acetone
P _{BAR}	-	Barometric pressure, in H ₂ O
P _s	-	Static Pressure, in H ₂ O
P _g	-	Total pressure of gas at stack conditions
P _{STD}	-	Standard pressure, 760 mmHG
$\sqrt{(P)_{avg}}$	-	Average of the square root of gas velocity pressure, in H ₂ O
ppm _{dv}	-	Parts per million, volume and dry basis
ppb _{dv}	-	Parts per billion, volume and dry basis
Q _{ACFM}	-	Flow rate of stack gas, actual cubic feet per minute
Q _{SCFM}	-	Flow rate of stack gas, standard cubic feet per minute
Q _{DSCFM}	-	Flow rate of stack gas, dry standard cubic feet per minute

°R	-	Degrees Rankin
°R/in. Hg	-	Degrees Rankin per inches of Mercury
scf/ml	-	Standard cubic feet per milliliter
scf/g	-	Standard cubic feet per gram
SCFM	-	Standard cubic feet per minute
SCM	-	Standard cubic meters
SCF	-	Standard cubic feet
$SP_{H_2O@T_{avg}}$	-	Saturation pressure of water at average stack temperature
STD	-	Standard
s	-	Second
T	-	Stack Temperature
tph	-	Tons per hour
ton/yr	-	Tons per year
T_M	-	Temperature of the dry gas meter
T_S	-	Temperature of the stack
T_{STD}	-	Standard temperature, 68 °F
THC	-	Total Hydrocarbons
ug	-	Micrograms
V_a	-	Volume of Acetone Blank, in mL
V_{aw}	-	Volume of Acetone Rinse, in mL
vol.	-	Volume
V/n_{std}	-	Volume mole in standard conditions, in cubic feet per pound mole
V_{lc}	-	Total volume of water vapor condensed, at STP
V_m	-	Volume of sample gas measured by the dry gas meter
V_{MSTD}	-	Volume of sample gas measured by the dry gas meter, corrected to standard conditions
VOC	-	Volatile Organic Compounds
V_S	-	Velocity of stack gas, ft/s
$V_{wc(std)}$	-	Volume of water condensed, corrected to standard conditions
$V_{wsg(std)}$	-	Volume of water collected in silica gel, corrected to standard conditions
$V_{w(std)}$	-	Volume of water vapor in gas stream. corrected to standard conditions
Y_d	-	Dry gas meter calibration factor
V_f	-	Final volume of water
V_i	-	Initial volume of water
W1	-	Acetone Rinse Final Weight 1
W2	-	Acetone Rinse Final Weight 2
W	-	Width of Stack if Rectangular
W_a	-	Weight of Acetone
W_f	-	Final weight
W_i	-	Initial weight

APPENDIX F

Facility Data

SCOT 1 (203)

S-203 Emission Test (Minute Results)

Date/Time	2BAI2015A (INCINERA TOR STACK 5-203 SO2)	2BAI2015B (2S-5-203 FLUE GAS O2)	2BAI2017A (SRU TAIL GAS H2S)	2BAI2017B (SRU TAIL GAS SO2)	2BFC210 (FUEL GAS TO WHB 2S-5-204)	2BFC210 (PROC AIR TO WHB 2S-5-204)	2BFI284 (FUEL GAS TO S203)	2BFC214 (SRU2 REFORMER TO D201)	2BFC213 (SRU2 GAG TO R201 ZONE 2)	2BFC221 (SRU2 R201 RAG+SCO T ZONE 3)	2BFC220 (SRU2 RAG+SCO T TO R201 ZONE 2)	2BIC623 (WASTE HEAT INCINER ATOR OUTLET)	2BIC620 (STACK INCINERATOR STACK)	2BFI285 (STACK SO2 FLOW THERMAL OXIDZR)	2BFI285 (SO2 STACK FLOW DP)	2BT1628 (TEMPERATURE THERMAL OXIDZR)
(Avg)	PM15O2	% O2	% H2S	% SO2	MMISCFD	MMISCFD	MISCFD	MMISCFD	MMISCFD	MMISCFD	MMISCFD	DEG F	DEG F	PPH	INH2O	DEGF
09/15/2009 09:30	101.31	4.01	0.00	0.00	0.00	633.70	483.03	0.21	2.12	4.01	2.18	0.00	1246.42	10.45	0.00	22.92
09/15/2009 09:31	101.49	4.02	0.00	0.00	0.00	633.70	483.49	0.21	2.19	4.06	2.17	0.00	1247.34	10.45	0.00	1282.24
09/15/2009 09:32	101.34	4.02	0.00	0.00	0.00	633.70	483.57	0.21	2.18	4.05	2.20	0.00	1248.04	10.45	0.00	1.64
09/15/2009 09:33	101.49	4.01	0.00	0.00	0.00	633.70	483.90	0.21	2.20	4.08	2.19	0.00	1248.68	10.45	0.05	1257.23
09/15/2009 09:34	101.66	4.01	0.00	0.00	0.00	633.70	484.22	0.21	2.25	4.08	2.20	0.00	1250.16	10.62	0.04	1289.06
09/15/2009 09:35	114.44	3.93	0.00	0.00	0.00	633.70	485.63	0.21	2.27	4.10	2.20	0.00	1251.38	11.72	0.04	1284.98
09/15/2009 09:36	118.10	3.71	0.00	0.00	0.00	633.70	483.25	0.21	2.26	4.12	2.21	0.00	1252.16	12.42	0.05	1292.27
09/15/2009 09:37	103.97	3.72	0.00	0.00	0.00	633.70	483.97	0.21	2.27	4.12	2.21	0.00	1253.48	11.53	0.05	1291.52
09/15/2009 09:38	104.42	3.72	0.00	0.00	0.00	633.70	477.22	0.21	2.26	4.12	2.23	0.00	1253.96	11.22	0.05	1292.27
09/15/2009 09:39	103.95	3.65	0.00	0.00	0.00	633.70	474.19	0.21	2.28	4.12	2.23	0.00	1254.50	10.83	0.04	1293.44
09/15/2009 09:40	107.11	3.71	0.00	0.00	0.00	633.70	473.20	0.21	2.25	4.12	2.23	0.00	1254.50	11.47	0.00	23.09
09/15/2009 09:41	107.37	3.71	0.00	0.00	0.00	633.70	471.16	0.21	2.26	4.14	2.23	0.00	1254.34	11.48	0.00	1269.49
09/15/2009 09:42	107.17	3.71	0.00	0.00	0.00	633.70	470.24	0.21	2.26	4.14	2.23	0.00	1254.34	11.48	0.00	1.56
09/15/2009 09:43	107.17	3.72	0.00	0.00	0.00	633.70	468.63	0.21	2.24	4.14	2.24	0.00	1253.80	12.09	0.05	1289.18
09/15/2009 09:44	106.88	3.72	0.00	0.00	0.00	633.70	467.58	0.21	2.24	4.14	2.24	0.00	1253.96	11.90	0.05	1292.27
09/15/2009 09:45	95.53	4.01	0.00	0.00	0.00	633.70	465.59	0.21	2.22	4.16	2.24	0.00	1254.02	10.17	0.05	1292.15
09/15/2009 09:46	96.76	3.97	0.00	0.00	0.00	633.70	464.06	0.21	2.26	4.16	2.24	0.00	1253.44	9.81	0.04	1291.02
09/15/2009 09:47	98.59	3.88	0.00	0.00	0.00	633.70	464.47	0.21	2.24	4.21	2.25	0.00	1252.86	10.43	0.04	1287.89
09/15/2009 09:48	103.50	3.88	0.00	0.00	0.00	633.70	463.10	0.21	2.24	4.18	2.25	0.00	1252.58	10.47	0.04	1287.77
09/15/2009 09:49	101.17	3.92	0.00	0.00	0.00	633.70	463.18	0.21	2.26	4.20	2.25	0.00	1252.58	10.80	0.05	1294.80
09/15/2009 09:50	100.59	3.89	0.00	0.00	0.00	633.70	461.25	0.21	2.27	4.15	2.24	0.00	1252.00	10.34	0.00	1.56
09/15/2009 09:51	101.61	3.89	0.00	0.00	0.00	633.70	460.61	0.21	2.27	4.14	2.23	0.00	1251.68	10.34	0.00	1281.72
09/15/2009 09:52	101.43	3.89	0.00	0.00	0.00	633.70	460.28	0.21	2.27	4.15	2.23	0.00	1251.53	10.34	0.00	1.64
09/15/2009 09:53	100.59	3.88	0.00	0.00	0.00	633.70	459.58	0.21	2.27	4.16	2.24	0.00	1251.53	9.99	0.04	1264.64
09/15/2009 09:54	101.61	3.89	0.00	0.00	0.00	633.70	460.28	0.21	2.23	4.17	2.24	0.00	1250.74	10.53	0.04	1296.60
09/15/2009 09:55	98.30	4.04	0.00	0.00	0.00	633.70	460.52	0.21	2.21	4.22	2.26	0.00	1250.94	9.65	0.04	1296.05
09/15/2009 09:56	97.66	4.04	0.00	0.00	0.00	633.70	458.85	0.21	2.21	4.23	2.27	0.00	1250.63	9.68	0.04	1284.80
09/15/2009 09:57	99.20	3.97	0.00	0.00	0.00	633.70	459.57	0.21	2.18	4.24	2.28	0.00	1250.04	10.34	0.04	1284.15
09/15/2009 09:58	98.62	3.97	0.00	0.00	0.00	633.70	461.61	0.21	2.17	4.25	2.27	0.00	1249.73	10.23	0.04	1282.23
09/15/2009 09:59	100.46	3.97	0.00	0.00	0.00	633.70	459.73	0.21	2.18	4.21	2.26	0.00	1248.82	9.79	0.04	1279.26
09/15/2009 10:00	99.69	4.01	0.00	0.00	0.00	633.70	458.99	0.21	2.24	4.19	2.25	0.00	1248.82	9.29	0.00	1.56
09/15/2009 10:01	100.00	4.00	0.00	0.00	0.00	633.70	459.08	0.21	2.23	4.18	2.26	0.00	1247.50	9.29	0.00	1248.32
09/15/2009 10:02	100.00	4.00	0.00	0.00	0.00	633.70	464.59	0.21	2.26	4.20	2.26	0.00	1247.18	9.29	0.00	1271.37
09/15/2009 10:03	99.71	4.01	0.00	0.00	0.00	633.70	463.25	0.21	2.25	4.18	2.26	0.00	1246.98	10.33	0.05	1261.55
09/15/2009 10:04	99.69	4.01	0.00	0.00	0.00	633.70	466.88	0.21	2.25	4.17	2.26	0.00	1247.41	10.17	0.04	1289.53
09/15/2009 10:05	105.18	4.04	0.00	0.00	0.00	633.70	464.71	0.21	2.27	4.18	2.25	0.00	1248.15	10.29	0.04	1280.43
09/15/2009 10:06	107.62	3.89	0.00	0.00	0.00	633.70	435.23	0.21	2.26	4.19	2.27	0.00	1248.72	11.47	0.05	1296.05
09/15/2009 10:07	108.71	3.71	0.00	0.00	0.00	633.70	434.91	0.21	2.18	4.19	2.26	0.00	1249.62	11.62	0.04	1296.05
09/15/2009 10:08	107.62	3.60	0.00	0.00	0.00	633.70	433.71	0.21	2.21	4.19	2.25	0.00	1251.68	11.38	0.04	1285.43
09/15/2009 10:09	107.20	3.79	0.00	0.00	0.00	633.70	433.56	0.21	2.19	4.19	2.24	0.00	1252.74	11.87	0.05	1284.80
09/15/2009 10:10	110.07	3.72	0.00	0.00	0.00	633.70	432.26	0.21	2.20	4.18	2.25	0.00	1254.29	11.99	0.00	1.56
09/15/2009 10:11	109.81	3.72	0.00	0.00	0.00	633.70	432.15	0.21	2.20	4.18	2.26	0.00	1255.10	11.99	0.00	1287.89
09/15/2009 10:12	109.65	3.72	0.00	0.00	0.00	633.70	434.25	0.21	2.19	4.18	2.24	0.00	1255.73	11.99	0.00	1.56
09/15/2009 10:13	109.81	3.72	0.00	0.00	0.00	633.70	432.08	0.21	2.18	4.15	2.25	0.00	1255.73	11.80	0.05	1283.63
09/15/2009 10:14	110.10	3.71	0.00	0.00	0.00	633.70	419.77	0.21	2.25	4.16	2.25	0.00	1255.73	12.45	0.05	1281.72
09/15/2009 10:15	109.91	4.12	0.00	0.00	0.00	633.70	417.51	0.21	2.21	4.19	2.26	0.00	1256.03	11.22	0.04	1285.31
09/15/2009 10:16	108.88	4.08	0.00	0.00	0.00	633.70	415.99	0.21	2.22	4.22	2.27	0.00	1255.51	11.68	0.05	1284.80
09/15/2009 10:17	102.11	4.09	0.00	0.00	0.00	633.70	413.91	0.21	2.24	4.27	2.28	0.00	1254.61	10.86	0.05	1281.17
09/15/2009 10:18	101.87	4.09	0.00	0.00	0.00	633.70	411.20	0.21	2.23	4.26	2.30	0.00	1254.56	10.21	0.04	1283.48
09/15/2009 10:19	101.34	4.04	0.00	0.00	0.00	633.70	409.48	0.21	2.22	4.28	2.29	0.00	1254.52	11.08	0.05	1284.69
09/15/2009 10:20	99.84	3.98	0.00	0.00	0.00	633.70	409.51	0.21	2.24	4.25	2.29	0.00	1254.20	11.25	0.00	1.64
09/15/2009 10:21	100.13	3.96	0.00	0.00	0.00	633.70	407.66	0.21	2.24	4.21	2.27	0.00	1253.88	11.25	0.00	1261.29
09/15/2009 10:22	99.98	3.98	0.00	0.00	0.00	633.70	407.09	0.21	2.23	4.19	2.25	0.00	1253.18	11.25	0.03	1279.91
09/15/2009 10:23	99.98	3.98	0.00	0.00	0.00	633.70	406.44	0.21	2.22	4.16	2.24	0.00	1252.65	10.68	0.05	1281.17
09/15/2009 10:24	99.69	3.99	0.00	0.00	0.00	633.70	405.61	0.21	2.22	4.16	2.25	0.00	1252.49	11.01	0.05	1284.06
09/15/2009 10:25	94.42	4.29	0.00	0.00	0.00	633.70	404.61	0.21	2.20	4.16	2.25	0.00	1251.99	9.88	0.05	1280.61
09/15/2009 10:26	94.65	4.29	0.00	0.00	0.00	633.70	404.66	0.21	2.20	4.15	2.24	0.00	1251.66	9.76	0.04	1279.26
09/15/2009 10:27	96.76	4.16	0.00	0.00	0.00	633.70	405.00	0.21	2.21	4.20	2.27	0.00	1250.85	10.11	0.04	1276.37
09/15/2009 10:28	96.94	4.18	0.00	0.00	0.00	633.70	403.95	0.21	2.21	4.24	2.28	0.00	1250.11	10.43	0.05	1273.83
09/15/2009 10:29	98.44	4.13	0.00	0.00	0.00	633.70	405.56	0.21	2.21	4.22	2.26	0.00	1249.57	10.74	0.05	1273.71
09/15/2009 10:30	104.64	4.17	0.00	0.00	0.00	633.70	405.29	0.21	2.23	4.21	2.26	0.00	1248.53	10.99	0.00	43.97

S-203 Emission Test (Minute Results)

Date/Time	28A12015A	28A12015B	28A12017A	28A12017B	28FC230	28FC240	28FH2H	28FC214	28FC213	28FC221	28FC220	28TC62A	28TC62B	28FI285	28FD1285	28TI628
	(INCINERA TOR STACK S-203 S02)	(28-5-203 FLUE GAS O2)	(SRU TAIL GAS H2S)	(SRU TAIL GAS SO2)	(FUEL GAS TO WHB 25-S-204)	(PROC AIR TO WHB 25-S-204)	(FUEL GAS TO S003)	(SRU1 REPOVERIER NC AC FD TO D01)	(SRU2 CAG TO R201 ZONE 2)	(SRU2 R201 RAG+SCD T ZONE 2)	(SRU2 RAG+SCD T TO R201 ZONE 2)	(WASTE HEAT INCINERATOR OUTLET)	(SCOTT INCINERATOR STACK)	(STACK SO2 FLOW THERMAL OXIDZR)	(S003 STACK FLOW DP)	(STACK TEMPERAT URE THERMAL OXIDZR)
	PPM502 (Ave)	% O2	% H2S	% SO2	MMSCFD	MMSCFD	MSCFD	MMSCFD	MMSCFD	MMSCFD	MMSCFD	DEG F	DEG F	PPH	INH2O	DEGF
	98.24	4.20	0.00	0.00	633.70	633.70	406.26	0.22	MMSCFD	MMSCFD	MMSCFD	2.24	1251.73	10.76	0.01	1113.21
Run #2																
09/15/2009 11:00	103.33	3.96	0.00	0.00	0.00	633.70	424.42	0.22	2.13	4.13	2.23	0.00	1252.78	11.50	0.00	22.97
09/15/2009 11:01	103.33	3.96	0.00	0.00	0.00	633.70	420.23	0.22	2.06	4.12	2.23	0.00	1253.26	11.50	0.00	1284.14
09/15/2009 11:02	103.33	3.97	0.00	0.00	0.00	633.70	417.74	0.22	2.09	4.15	2.23	0.00	1254.04	11.50	0.04	1286.05
09/15/2009 11:03	103.04	3.97	0.00	0.00	0.00	633.70	417.10	0.22	2.13	4.13	2.23	0.00	1254.04	10.86	0.04	1282.89
09/15/2009 11:04	103.04	3.97	0.00	0.00	0.00	633.70	415.75	0.22	2.14	4.12	2.23	0.00	1253.68	11.17	0.05	1284.14
09/15/2009 11:05	94.91	4.23	0.00	0.00	0.00	633.70	414.55	0.21	2.19	4.13	2.24	0.00	1253.89	9.76	0.04	1284.14
09/15/2009 11:06	94.91	4.12	0.00	0.00	0.00	633.70	414.55	0.21	2.25	4.17	2.25	0.00	1253.68	9.52	0.04	1282.91
09/15/2009 11:07	98.59	4.21	0.00	0.00	0.00	633.70	414.29	0.21	2.28	4.22	2.26	0.00	1253.37	10.67	0.05	1287.23
09/15/2009 11:08	103.49	4.20	0.00	0.00	0.00	633.70	413.82	0.22	2.30	4.24	2.26	0.00	1253.14	11.04	0.05	1283.52
09/15/2009 11:09	98.20	4.17	0.00	0.00	0.00	633.70	411.80	0.22	2.31	4.22	2.26	0.00	1253.10	10.59	0.05	1281.72
09/15/2009 11:10	100.88	4.17	0.00	0.00	0.00	633.70	410.92	0.22	2.32	4.18	2.24	0.00	1252.24	10.01	0.00	1.56
09/15/2009 11:11	100.91	4.17	0.00	0.00	0.00	633.70	409.89	0.22	2.33	4.14	2.24	0.00	1252.74	10.00	0.00	1281.72
09/15/2009 11:12	100.88	4.17	0.00	0.00	0.00	633.70	409.89	0.22	2.31	4.11	2.22	0.00	1251.93	10.01	0.04	1278.09
09/15/2009 11:13	101.17	4.16	0.00	0.00	0.00	633.70	409.01	0.22	2.31	4.11	2.23	0.00	1252.52	10.88	0.05	1281.00
09/15/2009 11:14	101.20	4.16	0.00	0.00	0.00	633.70	407.87	0.22	2.29	4.11	2.23	0.00	1252.36	10.71	0.05	1284.14
09/15/2009 11:15	113.56	4.24	0.00	0.00	0.00	633.70	408.19	0.22	2.27	4.15	2.25	0.00	1252.04	11.86	0.05	1280.62
09/15/2009 11:16	107.00	4.25	0.00	0.00	0.00	633.70	407.55	0.22	2.23	4.23	2.25	0.00	1251.88	11.62	0.05	1278.59
09/15/2009 11:17	101.24	4.12	0.00	0.00	0.00	633.70	408.90	0.21	2.25	4.24	2.27	0.00	1251.18	10.77	0.05	1279.77
09/15/2009 11:18	97.21	4.17	0.00	0.00	0.00	633.70	408.90	0.22	2.22	4.23	2.27	0.00	1250.69	10.59	0.05	1278.09
09/15/2009 11:19	101.82	4.18	0.00	0.00	0.00	633.70	405.94	0.22	2.20	4.17	2.25	0.00	1250.13	10.31	0.04	1273.05
09/15/2009 11:20	101.84	4.20	0.00	0.00	0.00	633.70	405.06	0.22	2.26	4.12	2.23	0.00	1249.38	10.35	0.00	1.64
09/15/2009 11:21	101.65	4.20	0.00	0.00	0.00	633.70	404.59	0.22	2.26	4.09	2.23	0.00	1249.38	10.35	0.00	1216.60
09/15/2009 11:22	101.68	4.21	0.00	0.00	0.00	633.70	403.77	0.22	2.29	4.11	2.22	0.00	1249.86	10.55	0.00	1275.74
09/15/2009 11:23	101.49	4.21	0.00	0.00	0.00	633.70	402.74	0.22	2.29	4.12	2.23	0.00	1249.54	10.92	0.05	1281.17
09/15/2009 11:24	101.24	4.21	0.00	0.00	0.00	633.70	402.42	0.22	2.30	4.14	2.23	0.00	1249.38	10.32	0.04	1280.55
09/15/2009 11:25	89.48	4.25	0.00	0.00	0.00	633.70	402.01	0.22	2.31	4.15	2.24	0.00	1249.99	9.33	0.05	1283.52
09/15/2009 11:26	89.32	4.21	0.00	0.00	0.00	633.70	401.60	0.22	2.25	4.17	2.24	0.00	1249.61	8.72	0.04	1279.88
09/15/2009 11:27	93.88	4.15	0.00	0.00	0.00	633.70	401.78	0.22	2.22	4.14	2.23	0.00	1249.13	9.83	0.05	1281.72
09/15/2009 11:28	96.46	4.16	0.00	0.00	0.00	633.70	401.58	0.22	2.21	4.15	2.24	0.00	1249.45	10.34	0.05	1281.72
09/15/2009 11:29	102.14	4.19	0.00	0.00	0.00	633.70	400.18	0.22	2.18	4.14	2.23	0.00	1250.12	11.05	0.05	1282.21
09/15/2009 11:30	99.23	4.09	0.00	0.00	0.00	633.70	400.49	0.22	2.12	4.16	2.23	0.00	1250.35	10.86	0.00	22.25
09/15/2009 11:31	99.23	4.09	0.00	0.00	0.00	633.70	400.58	0.22	2.03	4.14	2.24	0.00	1250.67	10.65	0.00	1279.26
09/15/2009 11:32	99.41	4.08	0.00	0.00	0.00	633.70	402.89	0.22	2.06	4.15	2.23	0.00	1250.35	10.85	0.04	1283.63
09/15/2009 11:33	99.23	4.09	0.00	0.00	0.00	633.70	401.22	0.22	2.00	4.18	2.24	0.00	1250.42	10.53	0.05	1284.14
09/15/2009 11:34	99.33	4.08	0.00	0.00	0.00	633.70	401.86	0.22	1.93	4.21	2.26	0.00	1250.42	10.38	0.04	1287.23
09/15/2009 11:35	101.49	4.32	0.00	0.00	0.00	633.70	401.78	0.22	1.79	4.23	2.28	0.00	1250.19	10.68	0.05	1287.89
09/15/2009 11:36	101.20	4.21	0.00	0.00	0.00	633.70	401.69	0.22	1.75	4.26	2.28	0.00	1250.51	10.59	0.05	1288.40
09/15/2009 11:37	101.65	4.21	0.00	0.00	0.00	633.70	401.05	0.22	1.65	4.23	2.29	0.00	1250.13	9.79	0.04	1278.59
09/15/2009 11:38	93.98	4.25	0.00	0.00	0.00	633.70	401.76	0.22	1.63	4.25	2.28	0.00	1250.50	9.82	0.05	1281.55
09/15/2009 11:39	90.10	4.25	0.00	0.00	0.00	633.70	402.98	0.22	1.60	4.26	2.29	0.00	1250.83	9.79	0.05	1279.88
09/15/2009 11:40	96.14	4.25	0.00	0.00	0.00	633.70	402.31	0.22	1.62	4.24	2.28	0.00	1250.73	16.67	0.00	1.64
09/15/2009 11:41	96.44	4.25	0.00	0.00	0.00	633.70	401.92	0.22	1.62	4.22	2.27	0.00	1250.67	16.67	0.00	1286.05
09/15/2009 11:42	96.30	4.25	0.00	0.00	0.00	633.70	401.63	0.22	1.62	4.19	2.27	0.00	1250.67	16.67	0.04	1284.14
09/15/2009 11:43	96.44	4.25	0.00	0.00	0.00	633.70	401.92	0.22	1.70	4.19	2.27	0.00	1250.67	10.41	0.05	1286.05
09/15/2009 11:44	95.98	4.25	0.00	0.00	0.00	633.70	401.22	0.22	1.76	4.17	2.25	0.00	1250.67	10.58	0.05	1282.89
09/15/2009 11:45	89.32	4.41	0.00	0.00	0.00	633.70	401.22	0.22	1.78	4.18	2.26	0.00	1250.28	9.38	0.05	1284.69
09/15/2009 11:46	90.63	4.23	0.00	0.00	0.00	633.70	402.81	0.22	1.82	4.19	2.25	0.00	1249.78	9.54	0.05	1286.05
09/15/2009 11:47	92.33	4.23	0.00	0.00	0.00	633.70	402.83	0.22	1.88	4.18	2.23	0.00	1249.77	9.76	0.05	1285.43
09/15/2009 11:48	94.17	4.21	0.00	0.00	0.00	633.70	403.07	0.22	1.93	4.17	2.23	0.00	1249.52	10.14	0.05	1275.74
09/15/2009 11:49	96.87	4.25	0.00	0.00	0.00	633.70	404.33	0.22	1.96	4.14	2.24	0.00	1249.52	10.73	0.05	1284.54
09/15/2009 11:50	96.59	4.25	0.00	0.00	0.00	633.70	404.50	0.22	1.94	4.13	2.23	0.00	1250.10	10.41	0.00	0.90
09/15/2009 11:51	96.75	4.25	0.00	0.00	0.00	633.70	404.18	0.22	1.87	4.12	2.22	0.00	1250.10	10.41	0.00	1283.52
09/15/2009 11:52	96.59	4.23	0.00	0.00	0.00	633.70	405.47	0.22	1.87	4.13	2.22	0.00	1250.26	10.41	0.00	1.36
09/15/2009 11:53	96.91	4.24	0.00	0.00	0.00	633.70	406.26	0.22	1.69	4.13	2.22	0.00	1250.19	9.66	0.04	1253.12
09/15/2009 11:54	96.91	4.25	0.00	0.00	0.00	633.70	406.11	0.22	1.59	4.11	2.23	0.00	1249.26	9.76	0.04	1278.09
09/15/2009 11:55	100.88	4.49	0.00	0.00	0.00	633.70	405.59	0.22	1.50	4.16	2.25	0.00	1248.98	10.31	0.04	1281.66
09/15/2009 11:56	97.26	4.33	0.00	0.00	0.00	633.70	406.35	0.22	1.58	4.18	2.26	0.00	1248.98	9.76	0.04	1281.17
09/15/2009 11:57	94.83	4.35	0.00	0.00	0.00	633.70	406.12	0.22	1.31	4.19	2.25	0.00	1248.63	9.64	0.04	1273.83
09/15/2009 11:58	68.07	4.37	0.00	0.00	0.00	633.70	409.95	0.22	1.26	4.15	2.22	0.00	1247.87	8.79	0.04	1274.45
09/15/2009 11:59	65.39	4.43	0.00	0.00	0.00	633.70	409.06	0.22	1.23	4.12	2.22	0.00	1247.33	9.46	0.04	1280.55
09/15/2009 12:00	91.29	4.25	0.00	0.00	0.00	633.70	407.40	0.22	1.21	4.09	2.20	0.00	1247.87	16.12	0.00	1.56

SCOT 2 (804)

