EPA Methods 3A, 6C, 7E, 10 & 20

Corrections to May 15, 2006 Final Rule That Updated the Methods

Foston Curtis US EPA

Updated Methods

- $\square Method 3A O2 \& CO2$
- $\square Method 6C SO2$
- $\square Method 7E NOx$
- $\square Method 10 CO$
- □ Method 20 NOx/SO2/Diluent

Update of Methods 3A, 6C, 7E, 10, and 20 *Purpose*

□ Harmonize

- **Consistent Equipment Requirements**
- Consistent Performance Tests
- □ Calibration Gases & Ranges
- Simplify & Make Flexible
 - Make Equipment Performance-Based Instead of Technology-Based
 - Allow Verifications by Manufacturer
- Update
 - Relax Outdated Requirements
 - □ Incorporate Recently Accepted Options & New Techniques
 - Address Dilution Sampling Systems

EPA Methods 3A, 6C, 7E, 10 & 20


In This Talk


A Discussion of

- Technical Corrections
- Clarifications

Rule Clarifications on Website

www.epa.gov/ttn/emc





Stratification Test Requirement

Clarifications

- Stratification Test Required at Each Site
- Only 1 Stratification Test/Group of Methods
- No Need to Test Stacks < 4"

Sample Collection

Clarifications

- Method 20 Min. Test Run Time = 21 Min.
- Single-Point OK for Stacks < 4"

Dilution Sampling Systems

 No Initial Bias Test for Dilution Sampling Systems

General Equipment Specifications

- Performance Based OK If Can Pass Interference Check, CE, System Bias Tests
- Before Sample Conditioning –
 Maintain Components Above Gas Dew Point
- Components Not Included in System Bias Check Must Be SS, Teflon, or Glass

Calibration Gas Clarifications

Zero Air

Part 72.2 Definition for Zero Air Materials

- SOx/NOx/VOC < 0.1 ppm
- CO < 1 ppm
- CO2 < 400 ppm
- Part 72.2 Definition for Zero Air Material

Method 3A High Calibration Gas

May Use Precleaned or Scrubbed Air

Calibration Gas Clarifications

- Must Obtain Gas Quality Certificate from Gas Manufacturer
- Analyzers That Measure NO & NO2 w/o Using Converter – Must Calibrate With Both NO & NO2

Interference Test - Clarifications

- □ Table 7E-3 Lists *Example* Test Gases
- Must Address All Potential Interferences
- □ May Be Verified by the Manufacturer
- □ Test Gases Manufacturer-Certified
- One Initial Test Per Analyzer Make & Model
- Repeat for Non-model Replacement Parts
- Current Analyzers Grandfathered

Potential Interferent Gas ¹	Concentrations ² Sample Conditioning Typ	
	Hot Wet	Dried
CO2	5 and 15%	5 and 15%
H ₂ O	25%	1 %
NO	15 ppmv	15 ppmv
NO ₂	15 ppmv	15 ppmv
N ₂ O	10 ppmv	10 ppmv
со	50 ppmv	50 ppmv
NH ₃	10 ppmv	10 ppmv
CH4	50 ppmv	50 ppmv
SO ₂	20 ppmv	20 ppmv
H ₂	50 ppmv	50 ppmv
HCI	10 ppmv	10 ppmv

Table 7E-3. Example Interference Check Gas Concentrations

- Any applicable gas may be eliminated or tested at a reduced level if the manufacturer has provided reliable means for limiting or scrubbing that gas to a specified level.
- As Practicable, gas concentrations should be the highest expected at test sites.

Calibration Drift

- □ Section 3.9 of Method 7E
- "Difference between measurement system readings for pre- & post-bias checks"
- Should read:
- "Difference between pre- and post-run system bias checks"

System Bias Check

Particulate Media Included Only When Using Out-of-Stack Filters

Method 7E NO₂ Converter Check

May Be Performed Before or After a Test or After a Series of Tests

Converter Efficiency Check Direct Conversion of NO₂ Gas

Protocol Traceable Gas Unstable

- Use Manufacturer-Certified Gas
- Use Mid- to High-Concentration Range Gas Instead of 40-60 ppm Gas
- □ Other, Lower Concentrations Also Allowed

Converter Efficiency Check Method 20 Bag Procedure

- Procedure Amendment
 - Secondary Steps For Determining Conversion
 Efficiency Were Confusing Dropped
 - Acceptance Criterion: 2% Drop from NOx Peak
 - Requirement to Introduce Test Gas Upstream of Dilution Assembly For Sample Dilution Systems has been Dropped

Manufacturer Stability Test

- Use Procedures Similar to 40 CFR 53.23 (not 53.55 or 53.56 as listed in Final Rule)
- □ Stability Against Test Site Variations in
 - Temperature*
 - Line Voltage*
- □ For Routine Analyses Below 20 ppm
- Performed by Manufacturer or Tester
- One Time Test

Alternative Dynamic Spike Check

- □ Optional in place of:
 - Bias Test
 - Interference Check
- Best on Steady-State Process
- □ Approval Required for CAMD Tests

Converter Eff. Calculation Corrections

Old Method 20 Converter Check Calculation

□ Final Rule Incorrect Equation

 $EffNO2 = \frac{NOxfinal - NOfinal}{NOxpeak - NOxfinal} x 100$

□ Correct Equation

% $Decrease = \frac{NOxpeak - NOxfinal}{NOxpeak} x 100$

Calculation Corrections/Revisions System Calibration Error Calculation

Missing DF in Eq. 7E-3

$$SCE = \frac{(Cs - Cv) \ x \ DF}{CS} \ x \ 100 \quad Eq.7E - 3$$

Calculations Corrections/Revisions Dynamic Spike Recovery Calculation

□ Final Rule Incorrect Equation

$$R = \frac{Css - Cavg}{Ccalc} \times 100 \quad Eq.7E - 12$$

□ Correct Equation

$$R = \frac{DF(Css - Cnative) + Cnative}{Cspike} x100$$

Calculations Corrections/Revisions

Missing Sample Concentration Calculation When Using a Zero Gas

□ Final Rule Equation for Non-Zero Gas

$$Cgas = (Cavg - Cm) \frac{Cma - Coa}{Cm - Co} + Cma \quad Eq. \, 7E - 5a$$

Added Equation For Zero Gas

$$Cgas = (Cavg - Co) \frac{Cma}{Cm - Co} \qquad Eq. 7E - 5b$$